Cricket Valley Energy

July 23, 2020

Ms. Alyssa Carbone
Assistant Environmental Engineer
Division of Air Resources, Region 3
New York State Department of Environmental Conservation
21 South Putt Corners Road
New Paltz, NY 12561-1620

RE: Title V Operating Permit Renewal Application
Cricket Valley Energy Center, LLC

Dear Ms. Carbone,

Please find enclosed a Title V Operating Permit (TVOP) renewal application prepared by Tetra Tech for the Cricket Valley Energy Center, LLC (CVEC) located in Dover, NY. CVEC's TVOP Permit ID 3-1326-00275/00009 expires on February 2, 2021. In accordance with the Title 6 of the New York Code, Rules and Regulations, Subpart 201 (6 NYCRR 201-6.2(a)(4)), a renewal application must be submitted no later than 180 days prior to expiration of the permit, which is August 6, 2020.

This application does not propose any modifications to the current TVOP. We do note that Condition 1-13 (pages 41-42) in the current TVOP has compliance language for natural gas but this Condition is for the fire pump engine and the language should be for diesel. We also request a correction for Condition 23.2, that the ammonia limit of 5.0 ppmvd corrected to 15% Oxygen limit applies "*during all turbine loads, **excluding combustion turbine startup and shutdown**, all fuels being fired and all duct burner operations*."

Additionally, the Auxiliary Boiler (Process P02) is not equipped with Flue Gas Recirculation as it can meet its NO_x emission limit with the installed low-NO_x burners. Therefore, Emission Source/Control FGR01 has been removed in the TVOP renewal application.

This application includes an update to the proposed Startup and Shutdown Limits, as required by Condition 24 of TVOP, that was submitted to the Department on May 20, 2020. Based upon discussions with the Department, additional startup and shutdown data have been reviewed through June 2020. Provided in Attachment 8 are proposed Startup and Shutdown Limits.

Please contact me at 617-320-5219 or mduquette@cricketvalley.com if you have any questions regarding this application.

Sincerely,

Marc J. Duquette
Director, Environmental Health and Safety

Title V Operating Permit Renewal Application
Permit ID: 3-1326-00275/00009

Cricket Valley Energy Center
Dover, Dutchess County, New York

July 2020

Prepared for:

Cricket Valley Energy Center LLC
c/o Advanced Power Services (NA), Inc.
155 Federal St.
Boston, MA 02110

Prepared by:

Tetra Tech, Inc.
10 Post Office Square
Suite 1100
Boston, MA 02110

TETRA TECH

TABLE OF CONTENTS

Acronyms/Abbreviations iii

1.0 INTRODUCTION 1-1
1.1 Application Overview 1-1
1.1.1 Application Organization 1-1
1.1.2 Application Contacts 1-1

2.0 FACILITY DESCRIPTION 2-1
2.1 Facility Description 2-1
2.2 Description of SignIficant Emission Sources 2-1
2.2.1 Combustion Turbine Generators and Duct Burners 2-1
2.2.2 Auxiliary Boiler 2-1
2.2.3 Emergency Generator Engine 2-2
2.2.4 Emergency Diesel Fire Pump Engine 2-2
2.3 Description of INSignIficant Emission Sources 2-2
2.3.1 Aqueous Ammonia Storage Tanks 2-2
2.3.2 Fuel Oil Storage Tank 2-2
2.3.3 Trivial Activities 2-2
2.4 Emissions Estimates 2-3
2.4.1 Potential Annual Emissions 2-3
2.4.2 Startup and Shutdown Emissions 2-3

3.0 REGULATORY APPLICABILITY EVALUATION 3-1
3.1 New Source Review 3-1
3.2 New Source Performance Standards 3-2
3.2.1 40 CFR 60 Subpart A – General Provisions 3-2
3.2.2 40 CFR 60 Subpart KKKK – Stationary Combustion Turbines 3-2
3.2.3 40 CFR 60 Subpart TTTT – Greenhouse Gas Emissions for New or Modified Electric Generating Units 3-3
3.2.4 40 CFR 60 – Subpart Dc – Small Industrial-Commercial-Institutional Steam Generating Units 3-3
3.2.5 40 CFR 60 – Subpart IIII – Stationary Compression Ignition Internal Combustion Engines 3-3
3.3 National Emission Standards for Hazardous Air Pollutants (40 CFR Parts 61 and 63) 3-4
3.4 Accidental Release Program 3-4
3.5 Acid Rain Program 3-4
3.6 Cross-State Air Pollution Rule 3-5
3.7 State of New York Regulations 3-5
3.7.1 Regional Greenhouse Gas Initiative 3-6

4.0 REFERENCES 4-1

LIST OF TABLES

Table 2-1. Summary of Potential Emissions For Significant Emission units (tpy) 2-3
Table 2-2. Proposed Startup and Shutdown Limits for Combustion Turbines 2-4
Table 3-1. Summary of Permitted Potential Emissions and NSR Thresholds 3-2

Table 3-2. NYSDEC Applicable Regulations 3-5

APPENDICES

Appendix A: Permit Application Forms
Appendix B: List of Exempt Activities
Appendix C: Plot Plan
Appendix D: Process Flow Diagrams
Appendix E: Methods Used To Determine Compliance
Appendix F: Emission Calculations
Appendix G: Proposed CTG Startup and Shutdown Limits
Appendix H: Acid Rain Permit Renewal Application
Appendix I: Performance Emission Test Reports
Appendix J: CEMS Monitoring Plan

ACRONYMS/ABBREVIATIONS

Acronyms/Abbreviations	Definition
%	percent
BACT	Best Available Control Technology
CFR	Code of Federal Regulations
CI	compression ignition
CO	carbon monoxide
CO_{2e}	carbon dioxide equivalents
CTG	combustion turbine generator
CVEC	Cricket Valley Energy Center, LLC
the Facility	Cricket Valley Energy Center
GE	General Electric
GHG	greenhouse gas
g/hp-hr	grams per horsepower-hour
HAP	hazardous air pollutant
hp	horsepower
HRSG	heat recovery steam generator
H_2SO_4	sulfuric acid mist
kW	kilowatts
lb/MMBtu	pounds per million British thermal units
MW	megawatt
NAAQS	National Ambient Air Quality Standards
NESHAP	National Emissions Standards for Hazardous Air Pollutants
NNSR	Nonattainment New Source Review
NO_x	nitrogen oxides
NSPS	New Source Performance Standards
NSR	New Source Review
NYCRR	New York Codes, Rules and Regulations
NYSDEC	New York State Department of Environmental Conservation
Pb	lead

the Permit	Air State Facility Permit Number 3-1326-00275/00009
PM	particulate matter
PM_{10}	particulate matter with a diameter equal to or less than 10 microns
$PM_{2.5}$	particulate matter with a diameter equal to or less than 2.5 microns
ppmw	parts per million by weight
PSD	Prevention of Significant Deterioration
RACT	Reasonably Available Control Technology
RBLC	RACT/BACT/LAER Clearinghouse
SCR	selective catalytic reduction
SER	Significant Emission Rate
SO_2	sulfur dioxide
SO_3	sulfur trioxide
tpy	tons per year
ULSD	ultra-low sulfur distillate
USEPA	United States Environmental Protection Agency
VOC	volatile organic compounds

1.0 INTRODUCTION

Cricket Valley Energy Center, LLC (CVEC) was issued Permit Number 3-1326-00275/00009 (the Permit) for the construction and operation of the Cricket Valley Energy Center (the Facility), a nominal net 1,000-megawatt (MW) combined-cycle electric generating facility, on a site located in Dover, Dutchess County, New York. In accordance with New York State Department of Environmental Conservation's (NYSDEC) regulations, the Permit authorized both construction of the facility in accordance with Title 6 New York Codes, Rules and Regulations (6 NYCRR) Part 231 and operating as a Title V source in accordance with 6 NYCRR Part 201-6. The Permit expires on February 2, 2021 and this application has been submitted more than 180 days prior to expiration in accordance with 6 NYCRR Part 201-6.2(a)(4)).

CVEC operates three General Electric (GE) Model 7FA.05 combustion turbine generators (CTGs) operating in combined-cycle mode with supplemental firing of the heat recovery steam generators (HRSGs). Natural gas is the sole fuel fired in the CTGs and duct burners. In addition to the CTGs, the facility operates a natural gas-fired auxiliary boiler, a 1,500-kilowatt (kW) ultra-low sulfur distillate (ULSD) fired emergency generator engine, and a 260-horsepower (hp) ULSD-fired emergency fire pump engine.

CVEC is operating in compliance with the Permit.

1.1 APPLICATION OVERVIEW

1.1.1 Application Organization

In accordance with NYSDEC regulations and guidance, a Title V Permit renewal application must contain all information required for an initial Title V Permit. This application includes the following:

- Application Forms
- List of Exempt Activities
- Plot Plan
- Process Flow Diagrams
- Methods Used to Determine Compliance
- Emission Calculations

1.1.2 Application Contacts

To facilitate agency review of this application, individuals familiar with the Facility and this application are identified below.

Marc Duquette
Cricket Valley Energy Center LLC
c/o Advanced Power Services (NA), Inc.
155 Federal St., 17th Floor
Boston, MA 02110
Phone: 617-320-5219
e-mail: mduquette@advancedpowerna.com

Jeff Harrington
Tetra Tech, Inc.
10 Post Office Square, Suite 1100
Boston, MA 02110
Phone: 207-358-2394
e-mail: jeff.harrington@tetratech.com

2.0 FACILITY DESCRIPTION

2.1 FACILITY DESCRIPTION

The facility is located in Dover, Dutchess County, New York. The Facility uses GE 7FA.05 combustion turbine technology; supplemental (duct) firing in the combined-cycle unit HRSGs is incorporated into the facility's design. An auxiliary boiler is used to assist plant start-up and maintain warm or hot-start conditions during standby periods. The sole fuel for the CTGs, duct burners and auxiliary boiler is natural gas. The facility operates a 1,500 kW ULSD-fired emergency generator engine and a 260-hp ULSD-fired emergency fire pump engine to support facility operations. ULSD is the sole fuel for the emergency generator and emergency fire pump engines. An air-cooled condenser is a dry cooling system where steam is condensed inside air-cooled finned tubes; this system component is not an emission source.

2.2 DESCRIPTION OF SIGNIFICANT EMISSION SOURCES

2.2.1 Combustion Turbine Generators and Duct Burners

Thermal energy is produced by combustion of natural gas in the three CTGs and each CTG is capable of running independently of the other. The thermal energy is converted to mechanical energy in the CTG that drives its integral compressor and electric generator. Each CTG has a rated heat input of 2,395.7 million British thermal units per hour (MMBtu/hr). The duct burners in each HRSG have a permitted heat input of 247 MMBtu/hr, which was used as the basis for determining the potential to emit (PTE).

Each HRSG is equipped with a selective catalytic reduction (SCR) system to control nitrogen oxide (NO_x) emissions and an oxidation catalyst to control carbon monoxide (CO) and volatile organic compound (VOC) emissions from the CTG and duct burners. The SCR uses 19 percent aqueous ammonia (NH_3) as a reagent. The aqueous NH_3 is injected into the flue gas stream upstream of the SCR catalyst, where it mixes with NO_x. A catalyst bed is located in a temperature zone of the HRSG where the catalyst is most effective. The exhaust gases pass through the catalyst where the NO_x reacts with NH_3 to form nitrogen gas (N_2) and water (H_2O). NO_x concentrations are controlled to 2.0 parts per million by volume dry basis corrected to 15 percent O_2 (ppmvdc), with or without duct-firing, during all steady-state operating load conditions, including with and without duct firing. A small amount of NH_3 passes through the catalyst and is emitted to the atmosphere, which is called "ammonia slip."

Exhaust gases from the CTGs and duct burners pass through the oxidation catalyst where excess air oxidizes the CO and VOC to form carbon dioxide (CO_2) and H_2O. The oxidation catalyst system reduces CO concentrations to no greater than 2.0 parts per million by volume dry basis corrected to 15 percent O_2 (ppmvdc), with or without duct-firing, during all steady-state operating load conditions, including with and without duct firing. VOC concentrations are controlled to 0.7 ppmvdc without duct firing, and 2.0 ppmvdc with duct firing.

2.2.2 Auxiliary Boiler

The Facility operates an auxiliary boiler rated at 60 MMBtu/hr to assist with startup of the CTGs by maintaining warm or hot-start conditions during most standby periods. The auxiliary boiler fires natural gas as the sole fuel and operates as needed to keep the HRSG warm during periods when the CTGs are not operating and provide steam to the steam turbine generator to minimize start-up duration. The auxiliary boiler is limited to a maximum of 4,500 hours of operation per rolling 12-month period. The auxiliary boiler is equipped with low-NO_x burners to minimize NO_x emissions. Emissions of all other pollutants are minimized by using natural gas as the sole fuel and by employing good combustion practices.

2.2.3 Emergency Generator Engine

The Facility operates a Caterpillar Model 3512C emergency generator engine rated at 1,500 kW (electrical) to provide power to the Facility during periods when there is loss of power from the grid, for emergency lighting and other necessary systems to ensure plant safety. The emergency generator engine fires ULSD and has a mechanical power rating of 2,206 hp. The emergency generator engine is only used during periods when power from the grid is unavailable and for testing to maintain operational readiness in the event of an emergency. Therefore, operating hours are limited to 500 hours per year. The emergency generator engine has an associated small ULSD storage tank.

2.2.4 Emergency Diesel Fire Pump Engine

The Facility operates a Clarke Model JU6H-UFADS8 emergency fire pump powered by a John Deere Model 6068HFC48 engine rated at 260 hp (mechanical) to provide on-site firefighting capabilities. The emergency fire pump engine fires ULSD and typically only operates for testing and to maintain operational readiness in the event of an emergency. Similar to the emergency generator, it is limited to a maximum of 500 operating hours per year. The emergency fire pump engine has an associated small ULSD storage tank.

2.3 DESCRIPTION OF INSIGNIFICANT EMISSION SOURCES

The Facility utilizes ancillary equipment to support facility operations. This ancillary equipment is exempt from Title V permitting requirements as Exempt Activities in accordance with 6 NYCRR Subpart 201-3.2. The Facility also includes a number of Trivial Activities as defined under 6 NYCRR Subpart 201-3.3.

2.3.1 Aqueous Ammonia Storage Tanks

The Facility includes a 19 percent by weight aqueous NH_3 tank for use in the SCR system. The tank is exempt from air permitting as a pressurized storage vessel in accordance with 6 NYCRR Subpart 201-3.2(22).

2.3.2 Fuel Oil Storage Tank

The emergency generator and emergency fire pump engines each have a dedicated ULSD storage tank. These tanks are exempt from air permitting as distillate fuel storage tanks with a capacity less than 300,000 gallons in accordance with 6 NYCRR Subpart 201-3.2(21).

2.3.3 Trivial Activities

The Facility conducts the following trivial activities:

- Boiler water treatment operations;
- Office equipment - copying machines, computer/word processor printers, blueprint copying machines, paper shredders, and photographic processing equipment;
- Hand-held or manually operated equipment used for buffing, polishing, carving, cutting, drilling, machining, routing, sanding, sawing, surface grinding, sand blasting or turning ceramic art work, ceramic precision parts, leather, metal parts, plastics. fiberboard, fiberglass, masonry, carbon, glass, graphite, wood or rubber;
- General facility maintenance activities - plastic pipe welding, soldering, brazing, cutting torches, janitorial activities, steam cleaning, water washing, acid and caustic washing activities, miscellaneous use of solvents, adhesives and caulking, miscellaneous sandblasting, non-asbestos insulation removal, application of refractory and insulation, the periodic use of air for clean-up, and, the process of demolition and rebricking boilers, smelters, furnaces and kilns (this does not include the subsequent operation of such

equipment), the surface coating of equipment and buildings as is related to maintenance and construction, and activities which occur for maintenance of grounds such as lawn care, weed control and pest control;
- Employee/visitor activities - smoking areas for the consumption of tobacco products, cooking equipment for food, comfort air conditioning systems, hot water tanks, and clothes dryer vents;
- Vehicle emissions - vehicle emissions from forklifts, automobiles, trucks, cranes, bulldozers, etc.;
- Storage of portable containers, drums, and bags of chemicals in rooms, buildings and warehouses;
- Trivial activities that have been identified by U.S. EPA in Appendix A of the "White Paper" issued on July 10, 1995.

2.4 EMISSIONS ESTIMATES

2.4.1 Potential Annual Emissions

Air emissions from the Facility consist of products of combustion from the CTGs, duct burners, auxiliary boiler, and two emergency engines. Emissions from the insignificant activities and trivial activities have not been quantified in accordance with OAC Chapter 3745-77-03(C)(3). The Facility does not operate any sources of fugitive emissions with quantifiable emissions and therefore, fugitive emissions are not provided with this application.

Table 2-1 presents a summary of the potential annual criteria pollutant, GHG, and total hazardous air pollutants (HAPs) emissions for each significant emission source listed in Section 2.2 in units of tpy.

Table 2-1. Summary of Potential Emissions For Significant Emission units (tpy)

Pollutant	CTGS	Auxiliary Boiler	Emergency Generator Engine	Emergency Fire Pump Engine	Facility Total
NO_x	244.0	1.15	5.84	0.43	251.4
CO	287.8	4.99	3.16	0.37	296.3
VOC	94.9	0.20	0.24	0.03	95.4
SO_2	37.8	0.15	0.005	0.001	38.0
$PM_{10}/PM_{2.5}$	173.3	0.68	0.18	0.02	174.1
H_2SO4	20	0.01	0.0004	0.00005	19.7
GHG	3,577,129	15,811	595	74	3,593,609
Total HAPs	17.67	0.25	0.02	0.003	17.9

Supporting emission calculations for Table 2-1 are provided in Appendix F.

2.4.2 Startup and Shutdown Emissions

Condition 24 of the Permit requires the Facility to monitor all occurrences of startup and shutdown from the combustion turbines, including the duration of each startup and shutdown event, and the total pounds of emissions of NO_X, CO, and NH_3 during each startup and shutdown event.

Condition 24 also requires the Facility to submit proposed startup and shutdown limits to the Department. Initial proposed limits were submitted to NYSDEC by email on May 20, 2020, based on actual startup and shutdown data

through April 30, 2020. NYSDEC has agreed that the Facility may submit revisions to the proposed startup and shutdown limits as part of this application.

Table 2-2 presents the currently proposed startup and shutdown limits, which are based on an updated analysis of actual operating and emissions data for a total of 131 startup events and 121 shutdown events, occurring between February 21 and June 30, 2020. A detailed description of this analysis, and requested permit language for the proposed startup and shutdown limits, are provided in Appendix G.

Table 2-2. Proposed Startup and Shutdown Limits for Combustion Turbines

Type of Event	Duration (minutes)	NO_X (lb/event)	CO (lb/event)	NH_3 (lb/event)
Startup	60	80.0	330.0	25.0
Shutdown	20	5.0	5.0	3.0

The initial application for the Permit was based upon a maximum startup duration of 60 minutes. However, the Facility has experienced several startup events on all three units longer than 60 minutes since the Facility has achieved commercial operation. CVEC is reviewing startup procedures with GE to make every effort to limit startup duration to less than 60 minutes. However, CVEC does not want to propose a permit limit that cannot be met consistently. Therefore, CVEC may propose a startup duration longer than 60 minutes pending the outcome of the review of startup procedures with GE. Should CVEC determine that a longer startup time is necessary, we will provide NYSDEC with a detailed analysis to document why the longer duration is necessary with supporting documentation from GE. If deemed necessary by CVEC, a proposal for a longer startup duration will be provided to NYSDEC within 45 calendar days of submittal of the application. The proposed pound per event limits in Table 2-2 are supported by the analysis of facility-specific SU/SD data provided in Appendix G and consequently would not be changed by any future proposed change in startup duration.

Appendix G also requests that a condition be added to define a “tuning event,” which is a twice-yearly maintenance activity performed on each combustion turbine to optimize its performance prior to each summer and winter season. The requested permit language states that the emission limits for steady-state operation, startup, and shutdown would not apply during “tuning events,” and states that each turbine would be allowed up to two tuning events per calendar year, not to exceed four hours per event.

Finally, Appendix G requests modified permit language for the existing ppmvd limits for NO_X, CO, and NH_3, to state that the steady-state ppmvd limits do not apply to any 1-hour average that contains at least one minute of startup or shutdown, and do not apply to any 1-hour average that includes part of a tuning event.

3.0 REGULATORY APPLICABILITY EVALUATION

This section contains an analysis of the applicability of federal and state air quality regulations to the proposed Facility. The specific regulations and programs that are included in this review include:

- New Source Review (NSR);
- New Source Performance Standards (NSPS);
- Federal National Emission Standards for Hazardous Air Pollutants (NESHAP);
- Federal Acid Rain Program; and
- Other NYSDEC requirements.

3.1 NEW SOURCE REVIEW

NSR applies to proposed new major sources of air pollutants. The NSR program for major sources includes two distinct permitting programs, Prevention of Significant Deterioration (PSD) permitting for projects located in an area designated as unclassified or attainment with the National Ambient Air Quality Standards (NAAQS) and Non-Attainment New Source Review (NNSR) permitting for projects located in an area designated as nonattainment with the NAAQS. As an area may be in attainment with one or more NAAQS and nonattainment with one or more NAAQS at any time, an individual project may be subject to both PSD and NNSR permitting depending upon its potential emissions. The NYSDEC has adopted under Title 6 New York Codes, Rules and Regulations (NYCRR) Part 231 permitting requirements for new sources that establishes the requirements for projects subject to NNSR and/or PSD requirements. Dutchess County is designated as unclassified or attainment with all applicable ambient air quality standards. However, all of New York State is located in the Ozone Transport Region and therefore, the entire state is treated as a marginal nonattainment area for ozone.

Under the NNSR program, a project located in an area designated as nonattainment for ozone must satisfy NNSR requirements for NOx and/or VOC emissions if they exceed the NNSR thresholds. The NNSR thresholds for NO_x and VOC emissions in Dutchess County are 100 tons per year (tpy) and 50 tpy, respectively. Under the PSD program, combined-cycle CTG power plants with potential emissions greater than 100 tpy of one or more criteria pollutants are considered new major stationary sources. Once a major source threshold is triggered for one pollutant under the PSD program, PSD review must also be completed for all pollutants whose potential emissions exceed their respective Significant Emission Rate (SER).

Table 3-1 presents a comparison of the Facility's potential emissions with the applicable NNSR and PSD major source thresholds. As summarized in Table 3-1, the Facility exceeds the NNSR major source thresholds for NO_x and VOC emissions and exceeds the PSD major source threshold for NO_x, CO, and $PM_{10}/PM_{2.5}$. In addition, the Facility's potential emissions of VOC, sulfuric acid (H_2SO_4), and greenhouse gases (GHGs) exceed their respective SER and, therefore, PSD review is also required for these pollutants.

The Permit contains all applicable requirements under the PSD and NNSR programs.

Table 3-1. Summary of Permitted Potential Emissions and NSR Thresholds

Pollutant	Annual Emissions (tpy)	NNSR Major Source Threshold (tpy)	PSD Major Source Threshold (tpy)	PSD SER (tpy)	NNSR Applies? (Yes/No)	PSD Applies? (Yes/No)
PM_{10}	174.1	N/A	100	15	N/A	Yes
$PM_{2.5}$	174.1	N/A	100	10	N/A	Yes
SO_2	38.0	N/A	100	40	N/A	No
NO_x	251.4	100	100	40	Yes	Yes
CO	296.3	N/A	100	100	N/A	Yes
VOC	95.4	50	100	40	Yes	Yes
H_2SO_4	19.7	N/A	100	7	N/A	Yes
Pb	1.3×10^{-3}	N/A	10	0.6	N/A	No
GHGs[a]	3,593,609	N/A	NA	75,000	N/A	Yes

[a] GHGs are expressed as carbon dioxide equivalents (CO_2e). Note that as of a June 23,2014, Supreme Court Decision, GHG emissions cannot determine major source status. The United States Environmental Protection Agency (USEPA) issued a Policy Memo dated July 24, 2014, indicating that it will apply the current GHG SER threshold for requiring PSD BACT review for GHG "anyway" sources.

3.2 NEW SOURCE PERFORMANCE STANDARDS

NSPS are technology-based standards applicable to new and modified stationary sources. NSPS have been established for approximately 70 source categories. Several NSPS subparts apply to the Facility. Following is a description of the applicable subparts and the Facility's compliance with these standards.

3.2.1 40 CFR 60 Subpart A – General Provisions

Any source subject to an applicable standard under 40 Code of Federal Regulations (CFR) 60 is also subject to the general provisions under Subpart A. Because the Facility is subject to other Subparts of the regulation, the requirements of Subpart A also apply. The Facility has complied with the applicable notifications, performance testing, recordkeeping, and reporting outlined in Subpart A.

3.2.2 40 CFR 60 Subpart KKKK – Stationary Combustion Turbines

Subpart KKKK places emission limits on NO_x and SO_2 on the combustion turbines and duct burners. For new CTGs firing natural gas with a rated heat input greater than 850 MMBtu/hr, the applicable NO_x emission limits are:

- 15 ppmvdc for natural gas and 42 ppmvdc for oil; or
- 54 nanograms per Joule (ng/J) of useful output (0.43 pounds per megawatt-hour [lb/MW-hr]) for natural gas and 160 ng/J or useful energy output (1.3 lb/MW-hr) for oil.

Additionally, SO_2 emissions are limited to:

- Emissions limited to 110 ng/J (0.90 lb/MW-hr) gross output; or
- Emissions limited to 26 ng/J (0.060 lb/MMBtu).

The CTGs and duct burners are controlled with an SCR system to limit NO_x emissions to 2.0 ppmvdc for natural gas firing. SO_2 emissions are limited to 0.0015 lb/MMBtu by firing pipeline-quality natural gas.

Additionally, the provisions of this Subpart require continuous monitoring of NO_x emissions, which can be satisfied by use of a 40 CFR Part 75 certified NO_x continuous emissions monitoring system (CEMS). Each combustion turbine is equipped with a CEMS.

3.2.3 40 CFR 60 Subpart TTTT – Greenhouse Gas Emissions for New or Modified Electric Generating Units

Subpart TTTT limits carbon dioxide (CO_2) emissions from new CTGs with an annual capacity factor (on a 3-year rolling basis) that exceeds its "design efficiency" as defined in the rule. The combustion turbines and duct burners are subject to this standard and the applicable limit is 1,000 pounds of CO_2 per megawatt-hour (lb CO_2/MW-hr) gross energy output or 1,030 lb CO_2/MW-hr net energy output on a rolling 12-month basis. The Facility continuously monitors CO_2 emissions in accordance with 40 CFR Part 75 and gross electrical output in accordance with Subpart TTTT to demonstrate compliance with this emission limit. The Subpart TTTT applicable requirements, including emission limits, operating limits, monitoring, recordkeeping, and reporting, have been included in the applicable requirements provided in the eBusiness Center Title V application form.

3.2.4 40 CFR 60 – Subpart Dc – Small Industrial-Commercial-Institutional Steam Generating Units

Subpart Dc is applicable to steam generating units with a maximum heat input capacity greater than 10 MMBtu/hr and less than 100 MMBtu/hr. The installed auxiliary boiler has a maximum heat input capacity of 60 MMBtu/hr and is subject to this standard. The standard requires initial notifications at the start of construction and at initial start-up. In addition, records must be maintained regarding the amount of fuel burned on a monthly basis. No emission or operating limits are imposed by this standard on natural gas fired boilers.

3.2.5 40 CFR 60 – Subpart IIII – Stationary Compression Ignition Internal Combustion Engines

Subpart IIII is applicable to owners and operators of stationary compression ignition (CI) internal combustion engines that commence operation after July 11, 2005. This standard applies to the emergency generator and emergency fire pump diesel engines.

For model year 2009 and later, fire pump engines with a displacement less than 30 liters per cylinder and an energy rating between 175 and 300 hp, Table 4 of Subpart IIII provides the following emission limits:

- 3.0 grams per horsepower-hour [g/hp-hr]) of NOx + VOC
- 2.6 g/hp-hr of CO
- 0.15 g/hp-hr of PM

To comply with Subpart IIII, new emergency stationary CI generator engines with a displacement less than 30 liters per cylinder must meet the emission standards per 40 CFR 60.4205(b). The applicable limits for a 2,206-hp mechanical emergency generator engine (1,500 kW electrical) are USEPA's Tier 2 limits as follows:

- 4.8 g/hp-hr of NO_x + VOC
- 2.6 g/hp-hr of CO
- 0.15 g/hp-hr of PM

Compliance with these emission standards are demonstrated by purchasing an engine that has been certified by the manufacturer to meet these limits. The Facility has purchased engines meeting these limits as certified by the manufacturer. In addition to these emission limits, this standard imposes operating restrictions, maintenance requirements, and recordkeeping requirements. The Subpart IIII requirements applicable to each engine, including

emission limits, operating limits, monitoring, recordkeeping, and reporting, have been included in the applicable requirements provided in the application forms.

3.3 NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (40 CFR PARTS 61 AND 63)

There are no 40 CFR Part 61 standards applicable to the Facility's operations. USEPA AP-42 emission factors, other applicable emission factors, and vendor information were reviewed to determine the Facility's applicability to a standard under 40 CFR Part 63. Based on potential emission calculations, the potential emissions of a single HAP do not exceed the major source threshold of 10 tpy and potential emissions of combined HAPs are less than the major source threshold of 25 tpy. Therefore, the major source NESHAP standards under 40 CFR Part 63 are not applicable to the Facility.

NESHAP Subpart YYYY is applicable to new combustion turbines located at major sources of HAP emissions. CVEC is a minor source of HAP emissions and therefore, NESHAP Subpart YYYY does not apply.

The USEPA has also promulgated a variety of standards applicable to area sources, those sources that are not considered major sources of HAPs. NESHAP Subpart JJJJJJ applies to certain industrial, commercial, and institutional boilers located at an area source. Natural gas fired boilers are exempt from this standard and therefore it does not apply to the auxiliary boiler.

NESHAP Subpart ZZZZ applies to reciprocating internal combustion engines located at an area source. In accordance with this NESHAP, new emergency engines are required to meet the requirements under the applicable NSPS. As discussed in Section 3.2.5, the emergency generator and emergency fire pump engines meet the NSPS requirements under 40 CFR 60 Subpart IIII and therefore are compliant with NESHAP Subpart ZZZZ.

3.4 ACCIDENTAL RELEASE PROGRAM

Section 112(r) of the Clean Air Act governs the storage and handling of certain chemicals. Aqueous NH_3 at a concentration of 19% by weight will be used as the reagent for the SCR systems for controlling NO_x emissions. Facilities that store aqueous NH_3 solutions containing less than 20% ammonia by weight are not subject to the accidental release requirements under Section 112(r) and are not required to prepare a Risk Management Plan in accordance with 40 CFR 68, Subpart G.

3.5 ACID RAIN PROGRAM

Title IV of the Clean Air Act Amendments required USEPA to establish a program to reduce emissions of acid rain forming pollutants, called the Acid Rain Program. The overall goal of this program is to achieve significant environmental benefits through reduction in SO_2 and NO_x emissions. To achieve this goal, the program employs a market-based approach for controlling air pollution. Under the market-based aspect of the program, affected units are allocated SO_2 allowances by the USEPA, which may be used to offset emissions, or traded under the market allowance program. In addition, to ensure that facilities do not exceed their allowances, affected units are required to monitor and report their emissions using a CEMS system or optional emissions data protocol per Appendix D, as approved under 40 CFR Part 75.

The Facility is subject to the Acid Rain Program based on the provisions of 40 CFR 72.6(a)(3) because the combined cycle gas turbine units are considered "utility units" under the program definition and they do not meet the exemptions listed under paragraph (b) of this Section. The Facility's Acid Rain Permit is incorporated into the Permit. The Facility is operating in accordance with its Acid Rain permit. A renewal application for the Acid Rain Permit is provided in Appendix H.

3.6 CROSS-STATE AIR POLLUTION RULE

The Cross-State Air Pollution Rule (CSAPR) went into effect on January 1, 2015, and replaced the Clean Air Interstate Rule (CAIR). New York is subject to the CSAPR and subject units must comply with the program. The facility's three CTGs are subject units and therefore must comply with CSAPR.

The NYSDEC has adopted regulations under 6 NYCRR Parts 243 (NO_x Ozone Season Group 2 Trading Program), 244 (NO_x Annual Trading Program), and 245 (SO_2 Group 1 Trading Program) to administer the CSAPR program in New York. In accordance with these regulations, the NYSDEC controls the allowance allocation and accounting process; emissions are reported to the United States Environmental Protection Agency (EPA) through their Clean Air Markets program, specifically via the Acid Rain CEMS installed on each budget unit. The NYSDEC CSAPR rules establish both seasonal and annual power plant emission budgets for SO_2 and NO_X based upon the budgets established for New York State by the EPA. "Seasonal" refers to the five-month ozone season (OS, May 1st through September 30th). New York sources are subject to the annual NO_X allowance program, the Group 2 NO_X OS allowance program, and Group 1 annual SO_2 allowance program. For states in designated Group 1 or Group 2 programs (not relevant to the annual NO_X program), the Group 1 and Group 2 allowances are not interchangeable.

The facility will receive an allocation from New York's CSAPR New Unit Set Aside (NUSA) account for each of the three budget programs. The facility must secure sufficient allowances through the NUSA account, and the allowance market place if necessary, to cover actual emissions for each calendar year. CVEC's first compliance year under the three CSAPR budget rules will be the 2020 operating year. CSAPR does not impose any new permitting requirements on the facility. The facility will comply with the applicable CSAPR requirements.

3.7 STATE OF NEW YORK REGULATIONS

In addition to regulations already discussed in preceding sections, state regulations that pertain to this Facility are listed in Table 3-2. Titles shown in italics in the table are permits, notifications, and/or reports needed for construction and operation of the Facility.

Table 3-2. NYSDEC Applicable Regulations

Rule	Description
6 NYCRR Part 201-6	*Title V Permits*
6 NYCRR Part 202-1	Emissions test methods and procedures for new and existing sources
6 NYCRR Part 225-1	Limits sulfur content of fuels
6 NYCRR Part 227-1	Control of particulate and visible emissions from stationary sources
6 NYCRR Part 227-2	Reasonably Available Control Technology (RACT) for Major Facilities of NOx
6 NYCRR Part 231	*Permit to Install New Sources of Pollution*
6 NYCRR Part 242	CO_2 Budget Trading Program
6 NYCRR Part 251	CO_2 Performance Standards for Major Electric Generating Facilities

The requirements of the regulations listed in Table 3-2 that apply to the facility are provided in the Title V application forms.

3.7.1 Regional Greenhouse Gas Initiative

The NYSDEC has adopted regulations under 6 NYCRR Part 242 (CO_2 Budget Trading Program), to administer the Regional Greenhouse Gas Initiative (RGGI) program in New York. RGGI is a cooperative effort of ten Northeast and Mid-Atlantic states (Connecticut, Delaware, Maine, Maryland, Massachusetts, New Hampshire, New York, New Jersey, Rhode Island, and Vermont) to implement a regional cap-and-trade program to control CO_2 emissions from power plants. The RGGI program requires electric generating units equal to or greater than 25 MW to hold sufficient CO_2 allowances to cover actual emissions. Facilities subject to the Acid Rain Program quantify emissions in accordance with 40 CFR 75. New York's program does not allocate allowances to subject units, all allowances must be purchased through auctions held quarterly. CVEC's first compliance year under the RGGI program rule will be the 2020 operating year.

4.0 REFERENCES

Rising et al. 2004. *Survey of Ultra-Trace Metals in Gas Turbine Fuels* by Rising, Sorurbakhsh and Wu, American Chemical Society Paper, Division of Fuel Chemistry, 2004

USEPA 2000. Compilation of Air Pollutant Emission Factors AP-42, Fifth Edition, Volume I: Stationary Point and Area Sources.

APPENDIX A: PERMIT APPLICATION FORMS

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID	Application ID	Application Type
3-1326-00275	-/	State Facility ¯ Title V

Section I - Certification

Certification

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons directly responsible for gathering the information required to complete this application, I believe the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

Responsible Official Marc Duquette	Title Director, EH&S
Signature Marc A. Duquette	Date 7/24/20

Professional Engineer Certification

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments as they pertain to the practice of engineering. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

Professional Engineer Mark Swyka	NYS License No. 06453
Signature	Date 7-21-2020

STATE OF NEW YORK MARK A. SWYKA LICENSED PROFESSIONAL ENGINEER

Section II - Identification Information

Type of Permit Action Requested

New × Renewal Significant Modification Administrative Amendment Minor Modification

Application for the construction of a new facility ¯ Application involves the construction of new emission unit(s)

Facility Information

Name Cricket Valley Energy Center, LLC

Location Address 2241 NY Route 22

City / × Town / ¯ Village Dover Plains | Zip

Owner/Firm Information

Business Taxpayer ID: 270605498

Name Cricket Valley Energy Center, LLC

Street Address 155 Federal Street, 17th Floor

City Boston | State/Province MA | Country United States | Zip 02110

Owner Classification: Federal State Municipal × Corporation/Partnership Individual

Owner/Firm Contact Information

Name Marc Duquette	Phone (617) 320-5219
E-mail Address mduquette@cricketvalley.com	Fax
Affiliation Cricket Valley Energy Center, LLC	Title Director, EH&S
Street Address 2241 ST RTE 22	
City Dover Plains | State/Province NY | Country United States	Zip 12522

Facility Contact Information

Name Marc Duquette	Phone
E-mail Address mduquette@cricketvalley.com	Fax
Affiliation Cricket Valley Energy Center, LLC	Title
Street Address 2241 ST RTE 22	
City Dover Plains | State/Province NY | Country United States	Zip 12522

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Project Description ☐ Continuation Sheet(s)

Title V Operating Permit No. 3-1326-00275/00009 (Mod 1 effective date 03/23/2018, Mod 2 effective date 12/05/2018, expiration date 02/02/2021) renewal application.

Section III - Facility Information

Facility Classification

☐ Hospital ☐ Residential ☐ Educational/Institutional ☐ Commercial ☐ Industrial ☒ Utility

Affected States (Title V Applications Only)

☐ Vermont ☐ Massachusetts ☐ Rhode Island ☐ Pennsylvania Tribal Land: _____
☐ New Hampshire ☐ Connecticut ☐ New Jersey ☐ Ohio Tribal Land: _____

SIC Code(s)			NAICS Code(s)			
4911			221112			

Facility Description ☐ Continuation Sheet(s)

The facility is an electric generating plant with three General Electric Model 7FA.05 natural gas fired combustion turbine generators (CTGs) operating in combined cycle mode. The exhaust from each CTG is sent to a heat recovery steam generator (HRSG) to generate additional electricity in a steam turbine generator (STG). Each HRSG is equipped with natural gas fired duct burners to create additional steam during periods of peak demand.

Compliance Statements (Title V Applications Only)

I certify that as of the date of this application the facility is in compliance with all applicable requirements. ☒ Yes ☐ No

If one or more emission units at the facility are not in compliance with all applicable requirements at the time of signing this application (the 'NO' box must be checked), the noncomplying units must be identified in the "Compliance Plan" block on page 8 of this form along with the compliance plan information required. For all emission units at the facility that are operating in compliance with all applicable requirements, complete the following:

☒ This facility will continue to be operated and maintained in such a manner as to assure compliance for the duration of the permit, except those emission units referenced in the compliance plan portion of this application.

☒ For all emission units subject to any applicable requirements that will become effective during the term of the permit, this facility will meet such requirements on a timely basis.

☒ Compliance certification reports will be submitted at least once per year. Each report will certify compliance status with respect to each applicable requirement, and the method used to determine the status.

Facility Applicable Federal Requirements ☐ Continuation Sheet(s)

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	201	1	2					
6	NYCRR	201	1	4					
6	NYCRR	201	1	5					

Facility State Only Requirements ☐ Continuation Sheet(s)

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	201	5						
6	NYCRR	211	2						
6	NYCRR	242							
6	NYCRR	251	3	a	1				

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section III - Facility Information

Facility Description (continuation)

Combustion emissions from the CTGs and duct burners are controlled by the use of natural gas as the sole fuel and good combustion practices. Additional reduction in emissions of nitrogen oxides (NOx) and carbon monoxide (CO) are achieved through the use of selective catalytic reduction (SCR) and an oxidation catalyst, respectively.

In addition to the primary electric generating equipment, the facility includes a natural gas fired auxiliary boiler, a 1,500 kilowatt (kW) emergency diesel generator engine, a 260 horsepower emergency diesel fire pump engine, an air cooled condenser (ACC), an aqueous ammonia storage tank, and a waste water treatment system.

Additional details are provided in the attached application text, completed application forms, supporting emission calculations and vendor equipment specifications.

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section III - Facility Information

Facility Applicable Federal Requirements (continuation)									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	201	6	2	d				
6	NYCRR	201	1	10	a				
6	NYCRR	201	2						
6	NYCRR	201	3	2	a				
6	NYCRR	201	3	3	a				
6	NYCRR	201		1	a	1			
6	NYCRR	201	6	1	a	2			
6	NYCRR	201	6	1	a	4			
6	NYCRR	201	6	2	a	4			
6	NYCRR	202	1	1					
6	NYCRR	202	1	2					
6	NYCRR	202	1	3					
6	NYCRR	211	1						
6	NYCRR	211	2						
6	NYCRR	225	1	2	g				
6	NYCRR	227	1	3	a				
6	NYCRR	227	1	3	b				
6	NYCRR	231	3						
6	NYCRR	231	4						
6	NYCRR	231	5						
6	NYCRR	231	7						
6	NYCRR	231	11	1					
6	NYCRR	231	12						
40	CFR	60	A	7	a	1			
40	CFR	60	A	7	b				
40	CFR	60	A	13					
40	CFR	60	IIII	4211	a				
40	CFR	60	IIII	4211	c				
40	CFR	60	KKKK	4333					
40	CFR	60	KKKK	4375	a				
40	CFR	72							

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section III - Facility Information

Facility Applicable Federal Requirements (continuation)

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	68							
40	CFR	82	F						
6	NYCRR	243							
6	NYCRR	244							
6	NYCRR	245							
6	NYCRR	272							
6	NYCRR	201	6	4					
6	NYCRR	201	6	6					
6	NYCRR	202	1	4					
6	NYCRR	202	2	3					
6	NYCRR	202	2	4					
6	NYCRR	202	2	5					
6	NYCRR	231	10						
40	CFR	60	TTTT						
40	CFR	75							
40	CFR	97	AAAAA						
40	CFR	97	CCCCC						
40	CFR	97	EEEEE						

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section III - Facility Information

Facility State Only Requirements (continuation)									
Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	251	5						
6	NYCRR	251	6						

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Facility Compliance Certification — × Continuation Sheet(s)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	211	2						

Applicable Federal Requirement / × State Only Requirement	Capping	CAS Number	Contaminant Name

Monitoring Information

Work Practice Involving Specific Operations | Ambient Air Monitoring | Record Keeping/Maintenance Procedures

Compliance Activity Description

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Work Practice Type Code	Process Material Code	Process Material Description	Reference Test Method

Monitored Parameter Code	Monitored Parameter Description	Manufacturer's Name/Model Number
01	Opacity	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
20	0	136	percent

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
18	6 min avg (Method 9)	4	Upon request	10	Upon request

Facility Emissions Summary — × Continuation Sheet(s)

CAS Number	Contaminant Name	Potential to Emit (tons/yr)	Actual Emissions (pounds/yr)
0NY075 - 00 - 5	PM-10	174.1	
0NY750 - 02 - 5	PM-2.5	174.1	
007446 - 09 - 5	Sulfur Dioxide	38.0	
0NY210 - 00 - 0	Oxides of Nitrogen	251.4	
000630 - 08 - 0	Carbon Monoxide	296.3	
007439 - 92 - 1	Lead (elemental)	0.0013	
0NY998 - 00 - 0	Total Volatile Organic Compounds	95.4	
0NY100 - 00 - 0	Total Hazardous Air Pollutants	17.9	
0NY750 - 00 - 0	Carbon Dioxide Equivalents	3,593,609	
7664-93-9	Sulfuric Acid Mist	19.7	
7664-41-7	Ammonia	225.5	
106-99-0	1,3-Butadiene	0.013	
75-07-0	Acetaldehyde	1.2	

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section III - Facility Information

Facility Emissions Summary (continuation)

CAS No.	Contaminant Name	PTE		Actual
		(lbs/yr)	Range	(lbs/yr)
107-02-8	Acrolein	2,453		
120-12-7	Anthracene	0.02		
71-43-2	Benzene	753		
56-55-3	Benzo(a)anthracene	0.02		
50-32-8	Benzo(a)pyrene	0.01		
106-97-8	Butane	3,952		
218-01-9	Chrysene	0.02		
53-70-3	Dibenz(a,h)anthracene	0.01		
74-84-0	Ethane	5,834		
100-41-4	Ethylbenzene	1,962		
50-00-0	Formaldehyde	7,129		
110-54-3	Hexane	9,190		
91-20-3	Napthalene	83.8		
109-66-0	Pentane	4,893		
85-01-8	Phenanthrene	0.1		
130498-29-2	PAH	140.1		
74-98-6	Propane	3,011		
115-07-1	Propylene	23		
75-56-9	Propylene Oxide	1,809		
129-00-0	Pyrene	0.06		
108-88-3	Toluene	7,991		
1330-20-7	Xylene(s)	3,926		
07440-38-2	Arsenic	1.0		
07440-39-3	Beryllium	0.06		
07440-41-7	Barium	8.3		
07440-43-9	Cadmium	5.6		
07440-47-3	Chromium	7.2		
07440-48-4	Cobalt	0.4		
07440-50-8	Copper	1.6		
07439-96-5	Manganese	1.9		

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section III - Facility Information

Facility Emissions Summary (continuation)

CAS No.	Contaminant Name	PTE (lbs/yr)	PTE Range	Actual (lbs/yr)
07439-97-6	Mercury	1.3		
07439-98-7	Molybdenum	2.1		
07440-02-0	Nickel	10.7		
07782-49-2	Selenium	0.1		
07440-62-2	Vanadium	4.3		
07440-66-6	Zinc	101		

Continuation Sheet 2 of 2

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section III - Facility Information

Facility Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	227	1	3	a				

		CAS No.	Contaminant Name
☒ Applicable Federal Requirement ☐ State Only Requirement	☐ Capping		Opacity

Monitoring Information

- ☐ Continuous Emission Monitoring
- ☐ Intermittent Emission Testing
- ☐ Ambient Air Monitoring
- ☒ Monitoring of Process or Control Device Parameters as a Surrogate
- ☐ Work Practice Involving Specific Operations
- ☐ Record Keeping/Maintenance Procedures

Description

No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (six minute average), except for one six-minute period per hour of not more than 27 percent opacity.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
01	Parameter	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
20	0	136	Percent

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
18	6-minute avg (Method 9)	4	Upon Request	10	Upon Request

DEC ID
3-1326-00275

Section IV - Emission Unit Information

Emission Unit Description	☐ Continuation Sheet(s)
Emission Unit	U-00001

This emission unit will consist of one natural gas fired GE Model 7F.05 combustion turbine generator (CTG) and one heat recovery team generator (HRSG) with supplemental natural gas firing exhausted through a common stack.

Building Information ☐ Continuation Sheet(s)

Building ID	Building Name	Length (ft)	Width (ft)	Orientation
CTGEN01	Combustion Turbine Generator Building	670	100	0°
HRSG01	Heat Recovery Steam Generator Enclosure	128	160	90°
ACC01	Air Cooled Condenser	190	190	90°

Emission Unit: -

Emission Unit Emissions Summary ☐ Continuation Sheet(s)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3-1326-00275

Emission Point Information

☐ Continuation Sheet(s)

Emission Point	EP001					
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
435	283	170	228	165		
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal
44	756,000					

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Source/Control Information

☐ Continuation Sheet(s)

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
CT001	C	12/2017	10/2019	N/A			General Electric 7F.05

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
2333.1	25	MMBtu/hr (HHV) at ISO conditions				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
DB001	C	12/2017	10/2019	N/A			

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
247	25	MMBtu/hr (HHV)				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
DLN01	K	12/2017	10/2019	N/A	103	Dry low Nox Burner	General Electric

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Source/Control (continuation)

Emission Unit: U - 0 0 0 0 1

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
SCR01	K	12/2017	10/2019	N/A	033	Selective Catalytic Reduction	Alstom

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
OXC01	K	12/2017	10/2019	N/A	110	Oxidation Catalyst	

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
AUX01	C	12/2017	10/2019	N/A			

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
60	25	MMBtu/hr (HHV)				

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
LNB01	K	12/2017	08/2019	N/A	102	Low-NOx Burner	Alzeta CSB560

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

DEC ID
3-1326-00275

Process Information ☒ Continuation Sheet(s)

Emission Unit U-00001 Process P01

Process Description

Natural gas firing of the GE 7F.05 combustion turbine (CT001) with and without supplemental firing (DB001). Dry low-NOx combustors (DLN01) and selective catalytic reduction (SCR01) will be used to control NOx emissions. An oxidation catalyst (OXC01) will be used to control CO and VOC emissions. Natural gas throughput rates based upon a heat content of 1,000 BTU/CF (HHV) and include both CT001 and DB001. Quantity per hour is based upon maximum hourly rate for all ambient conditions and quantity per year is based upon maximum hourly rate at ISO conditions for 8,760 hours per year.

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description
2-01-002-01	2.64	22,050	0115	million cubic feet of natural gas

Confidential / Operating at Maximum Capacity	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
☒ Operating at Maximum Capacity	24	365	CTGEN01	First Floor

Emission Point Identifier(s)

EP001						

Emission Source/Control Identifier(s)

CT001	DLN01	SCR01	OXC01			

Emission Unit U-00001 Process P02

Process Description

Natural gas firing of the auxiliary boiler (AUX01) with a maximum firing rate of 60 MMBtu/hr (HHV). Operation of the auxiliary boiler will be limited to no more than 4,500 hours per 12-month period. Natural gas throughput rates based upon a heat content of 1,000 BTU/CF (HHV). See Section 2 of this application for a more detailed process description.

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description
1-02-006-02	0.06	270	0115	million cubic feet of natural gas

Confidential / Operating at Maximum Capacity	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
☒ Operating at Maximum Capacity	24	See Description		

Emission Point Identifier(s)

EP001						

Emission Source/Control Identifier(s)

AUX01	LNB01					

DEC ID
3-1326-00275

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements										× Continuation Sheet(s)
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.	
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4320	1					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4330	a	2				
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4333	a					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4340	b	1				

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements										× Continuation Sheet(s)
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.	
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	1	5						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	2	4						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	3							
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	4							

Emission Unit Compliance Certification ☐ Continuation Sheet(s)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

Applicable Federal Requirement | State Only Requirement | Capping

Emission Unit	Emission Point	Process	Emission Source	CAS Number	Contaminant Name
U-00001	EP001	P01	CT001 / DB001	NY210-00-0	Oxides of Nitrogen (NOx)

Monitoring Information

× Continuous Emission Monitoring
Intermittent Emission Testing
Ambient Air Monitoring
Monitoring of a Process or Control Device Parameters as a Surrogate
Work Practice Involving Specific Operations
Record Keeping/Maintenance Procedures

Compliance Activity Description

Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (w/ and w/o duct burning) to satisfy LAER. This will be achieved through the application of DLN burners in combination with SCR. This limit applies at all load conditions except startup and shutdown. The facility will use CEMS to monitor NOx stack emissions.

Work Practice Type Code	Process Material		Reference Test Method
	Code	Description	
			40 CFR 60, App. A, Method 7E

Monitored Parameter		Manufacturer's Name/Model Number
Code	Description	
23	concentration	GE DLN, SCR Alstom

Limit		Limit Units	
Upper	Lower	Code	Description
2.0		275	parts per million by volume (dry) at 15% O2

Averaging Method		Monitoring Frequency		Reporting Requirements	
Code	Description	Code	Description	Code	Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4345					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4350					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4365					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4375					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4380					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4395					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4400					
U-00001	EP001	P01	CT001	40	CFR	60	KKKK	4405					
U-00001	EP001	P01	CT001/DB001	40	CFR	72	A	6	a	3	i		
U-00001	EP001	P01	CT001/DB001	40	CFR	72	A	9					
U-00001	EP001	P01	CT001/DB001	40	CFR	75	A	2					
U-00001	EP001	P01	CT001/DB001	40	CFR	75	B	10					
U-00001	EP001	P01	CT001/DB001	40	CFR	75	B	11					
U-00001	EP001	P01	CT001/DB001	40	CFR	75	B	12					
U-00001	EP001	P01	CT001/DB001	40	CFR	75	B	13					
U-00001	EP001	P01	CT001/DB001	40	CFR	75	C						
U-00001	EP001	P01	CT001/DB001	40	CFR	75	D						
U-00001	EP001	P01	CT001/DB001	40	CFR	75	F						
U-00001	EP001	P01	CT001/DB001	40	CFR	75	G						
U-00001	EP001	P01	CT001/DB001	40	CFR	75	H						
U-00001	EP001	P01	CT001/DB001	40	CFR	97	A						
U-00001	EP001	P01	CT001/DB001	40	CFR	97	D						
U-00001	EP001	P01	CT001/DB001	40	CFR	97	H						
U-00001	EP001	P01	CT001/DB001	40	CFR	97	AAAAA						
U-00001	EP001	P01	CT001/DB001	40	CFR	97	CCCCC						
U-00001	EP001	P01	CT001/DB001	40	CFR	97	EEEEE						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	227	2	4	e				
U-00001	EP001	P01	CT001/DB001	6	NYCRR	227	2	6	a	4			
U-00001	EP001	P01	CT001/DB001	6	NYCRR	227	2	6	b				
U-00001	EP001	P01	CT001/DB001	6	NYCRR	231	5	4					
U-00001	EP001	P01	CT001/DB001	6	NYCRR	231	7	6					

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00001	EP001	P01	CT001/DB001	6	NYCRR	243							
U-00001	EP001	P01	CT001/DB001	6	NYCRR	244							
U-00001	EP001	P01	CT001/DB001	6	NYCRR	245							
U-00001	EP001	P02	AUX01	40	CFR	60	Dc	48c	a				
U-00001	EP001	P02	AUX01	6	NYCRR	231	5	5	4				
U-00001	EP001	P02	AUX01	6	NYCRR	231	7	7	6				

Continuation Sheet 2 of 2

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID										
3	-	1	3	2	6	-	0	0	2	7	5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	5						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	6						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	7						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	242	8						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	251	3						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	251	4						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	251	5						
U-00001	EP001	P01	CT001/DB001	6	NYCRR	251	6						

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	227	2	4	e	3			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P01	CT001/DB001	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The turbines will meet a LAER emission rate of 2.0 ppmvd at 15% O2, with and without duct firing. The emission level applies at all operating loads except during startup and shutdown. LAER is more stringent than 227.2.4 and therefore satisfies this requirement.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	DLN from GE, SCR from Alstom

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-1326-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	KKKK	4320					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P01	CT001/DB001	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a LAER emission rate of 2.0 ppmvd at 15% O2, with and without duct firing. The emission levels apply at all operating loads except during startup and shutdown. LAER is more stringent than 40 CFR 60.4320 and therefore satisfies this requirement.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	DLN from GE, SCR from Alstom

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P01	CT001/DB001	NY998-00-0	Volatile Organic Compounds

Monitoring Information

☐ Continuous Emission Monitoring
☒ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a LAER emission rate of 1.8 ppmvd at 15% O2 with duct firing and 0.7 ppmvd at 15% O2 without duct firing. The emission levels apply at all operating loads except during startup and shutdown. These emission levels will be achieved through good combustion practices and an oxidation catalyst. Stack testing for non-methane hydrocarbons will be conducted to demonstrate compliance with these limits.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 25A & 18

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	Oxidation catalyst is TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13261-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P01	CT001/DB001	630-08-0	Carbon Monoxide

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a BACT emission rate of 2.0 ppmvd at 15% O2 with and without duct firing. This emission levels apply at all operating loads except during startup and shutdown. These emission levels will be achieved through good combustion practices and an oxidation catalyst. CEMS will be used to demonstrate compliance.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 10

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	Oxidation catalyst is TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	Continuous	07	Quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13267-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P01	CT001/DB001	NY075-00-0	Particulate Matter

Monitoring Information

☐ Continuous Emission Monitoring
☒ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a PM10/PM2.5 emission limit of 0.005 lb/MMBtu without duct burning and 0.006 lb/MMBtu with duct burning as BACT for the proposed project. These levels of emissions will be achieved by firing pipeline quality natural gas as the sole fuel in the turbines and duct burner. The facility will conduct stack testing to demonstrate compliance with these limits.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 5 and RM201/201A & 202

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.006		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13261-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P01	CT001/DB001	7664-09-5	Sulfur Dioxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF in the combustion turbine and duct burners.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P01	CT001/DB001	7664-93-9	Sulfuric Acid Mist

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a sulfuric acid mist emission limit of 0.00065 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF in the combustion turbine and duct burners.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	227	2	4	c	1	ii		

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P02	AUX01	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

The auxiliary boiler will meet a LAER emission rate of 0.0085 lb/MMBtu. The auxiliary boiler will use low-NOx burners to control NOx emissions. LAER is more stringent than 227.2.4 and therefore satisfies this requirement.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.011		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P02	AUX01	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

The auxiliary boiler will meet a LAER emission rate of 0.0085 lb/MMBtu. The auxiliary boiler will use low-NOx burners to meet this limit. The facility will use vendor guarantees and/or stack testing to document compliance with this LAER emission limit, as required.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.011		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P02	AUX01	NY998-08-0	Volatile Organic Compounds

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

The auxiliary boiler will meet a LAER emission rate of 0.0015 lb/MMBtu through the use of good combustion practices. The facility will use vendor guarantees and/or stack testing to document compliance with this LAER emission limit, as required.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Methods 18 & 25A

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.0015		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-1326-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P02	AUX01	630-08-0	Carbon Monoxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

The auxiliary boiler will meet a BACT emission rate of 0.0375 lb/MMBtu through the use of good combustion practices. The facility will use vendor guarantees and/or stack testing to document compliance with this BACT emission limit, as required.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 10

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.0375		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P02	AUX01	NY075-00-0	Particulate Matter

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

The auxiliary boiler will meet a BACT emission rate of 0.005 lb/MMBtu for PM10/PM2.5 through the use of good combustion practices and firing pipeline quality natural gas as the sole fuel. The facility will use vendor guarantees and/or stack testing to document compliance with this BACT emission limit, as required.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 5 and RM201/201A & 202

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.005		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P02	AUX01	7664-09-05	Sulfur Dioxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural Gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13267-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00001	EP001	P02	AUX01	7664-93-09	Sulfuric Acid Mist

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a sulfuric acid mist emission limit of 0.0001 lb/MMBtu as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural Gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

DEC ID
3-1326-00275

Section IV - Emission Unit Information

Emission Unit Description	☐ Continuation Sheet(s)
Emission Unit: U-00002	

This emission unit will consist of one natural gas fired GE Model 7F.05 combustion turbine generator (CTG) and one heat recovery team generator (HRSG) with supplemental natural gas firing exhausted through a common stack.

Building Information ☐ Continuation Sheet(s)

Building ID	Building Name	Length (ft)	Width (ft)	Orientation
CTGEN02	Combustion Turbine Generator Building	670	100	0°
HRSG02	Heat Recovery Steam Generator Enclosure	128	160	90°
ACC01	Air Cooled Condenser	190	190	90°

Emission Unit Emissions Summary ☐ Continuation Sheet(s)

Emission Unit: -

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3-1326-00275

Emission Point Information

☐ Continuation Sheet(s)

Emission Point	EP002					
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
435	283	170	228	165		
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal
44	756,000					

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Source/Control Information

☐ Continuation Sheet(s)

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
CT002	C	12/2017	11/2019	N/A			General Electric 7F.05

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
2333.1	25	MMBtu/hr (HHV) at ISO conditions				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
DB002	C	12/2017	11/2019	N/A			

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
247	25	MMBtu/hr (HHV)				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
DLN02	K	12/2017	11/2019	N/A	103	Dry low Nox Burner	General Electric

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Source/Control (continuation)

Emission Unit: U - 0 0 0 0 2

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
SCR02	K	12/2017	11/2019	N/A	033	Selective Catalytic Reduction	Alstom

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
OXC02	K	12/2017	11/2019	N/A	110	Oxidation Catalyst	

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
	K						

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3-1326-00275

Process Information [×] Continuation Sheet(s)

Emission Unit	U-00002	Process	P04

Process Description

Natural gas firing of the GE 7F.05 combustion turbine (CT002) with and without supplemental firing (DB002). Dry low-NOx combustors (DLN02) and selective catalytic reduction (SCR02) will be used to control NOx emissions. An oxidation catalyst (OXC02) will be used to control CO and VOC emissions. Natural gas throughput rates based upon a heat content of 1,000 BTU/CF (HHV) and include both CT002 and DB002. Quantity per hour is based upon maximum hourly rate for all ambient conditions and quantity per year is based upon maximum hourly rate at ISO conditions for 8,760 hours per year.

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description
2-01-002-01	2.64	22,050	0115	million cubic feet of natural gas

Confidential / Operating at Maximum Capacity	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
[×] Operating at Maximum Capacity	24	365	CTGEN02	First Floor

Emission Point Identifier(s)

EP002						

Emission Source/Control Identifier(s)

CT002	DLN02	SCR02	OXC02			

Emission Unit	-	Process

Process Description

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description

Confidential / Operating at Maximum Capacity	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		

Emission Point Identifier(s)

Emission Source/Control Identifier(s)

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements							× Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00002	EP002	P04	CT002	40	CFR	60	KKKK	4320	1				
U-00002	EP002	P04	CT002	40	CFR	60	KKKK	4330	a	2			
U-00002	EP002	P04	CT002	40	CFR	60	KKKK	4333	a				
U-00002	EP002	P04	CT002	40	CFR	60	KKKK	4340	b	1			

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements							× Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	1	5					
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	2	4					
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	3						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	4						

Emission Unit Compliance Certification ☐ Continuation Sheet(s)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

Applicable Federal Requirement | State Only Requirement | Capping

Emission Unit	Emission Point	Process	Emission Source	CAS Number	Contaminant Name
U-00002	EP002	P04	CT002/DB002	NY210-00-0	Oxides of Nitrogen (NOx)

Monitoring Information

× Continuous Emission Monitoring
Intermittent Emission Testing
Ambient Air Monitoring
Monitoring of a Process or Control Device Parameters as a Surrogate
Work Practice Involving Specific Operations
Record Keeping/Maintenance Procedures

Compliance Activity Description

Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (w/ and w/o duct burning) to satisfy LAER. This will be achieved through the application of DLN burners in combination with SCR. This limit applies at all load conditions except startup and shutdown. The facility will use CEMS to monitor NOx stack emissions.

Work Practice Type Code	Process Material		Reference Test Method
	Code	Description	
			40 CFR 60, App. A, Method 7E

Monitored Parameter		Manufacturer's Name/Model Number
Code	Description	
23	concentration	GE DLN, SCR Alstom

Limit		Limit Units	
Upper	Lower	Code	Description
2.0		275	parts per million by volume (dry) at 15% O2

Averaging Method		Monitoring Frequency		Reporting Requirements	
Code	Description	Code	Description	Code	Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4345					
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4350					
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4365					
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4375					
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4380					
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4395					
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4400					
U-00002	EP002	P04	CT002/DB002	40	CFR	60	KKKK	4405					
U-00002	EP002	P04	CT002/DB002	40	CFR	72	A	6	a	3	i		
U-00002	EP002	P04	CT002/DB002	40	CFR	72	A	9					
U-00002	EP002	P04	CT002/DB002	40	CFR	75	A	2					
U-00002	EP002	P04	CT002/DB002	40	CFR	75	B	10					
U-00002	EP002	P04	CT002/DB002	40	CFR	75	B	11					
U-00002	EP002	P04	CT002/DB002	40	CFR	75	B	12					
U-00002	EP002	P04	CT002/DB002	40	CFR	75	B	13					
U-00002	EP002	P04	CT002/DB002	40	CFR	75	C						
U-00002	EP002	P04	CT002/DB002	40	CFR	75	D						
U-00002	EP002	P04	CT002/DB002	40	CFR	75	F						
U-00002	EP002	P04	CT002/DB002	40	CFR	75	G						
U-00002	EP002	P04	CT002/DB002	40	CFR	75	H						
U-00002	EP002	P04	CT002/DB002	40	CFR	97	A						
U-00002	EP002	P04	CT002/DB002	40	CFR	97	D						
U-00002	EP002	P04	CT002/DB002	40	CFR	97	H						
U-00002	EP002	P04	CT002/DB002	40	CFR	97	AAAAA						
U-00002	EP002	P04	CT002/DB002	40	CFR	97	CCCCC						
U-00002	EP002	P04	CT002/DB002	40	CFR	97	EEEEE						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	227	2	4	e				
U-00002	EP002	P04	CT002/DB002	6	NYCRR	227	2	6	a	4			
U-00002	EP002	P04	CT002/DB002	6	NYCRR	227	2	6	b				
U-00002	EP002	P04	CT002/DB002	6	NYCRR	231	5	4					
U-00002	EP002	P04	CT002/DB002	6	NYCRR	231	7	6					

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID										
3	-	1	3	2	6	-	0	0	2	7	5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00002	EP002	P04	CT002/DB002	6	NYCRR	243							
U-00002	EP002	P04	CT002/DB002	6	NYCRR	244							
U-00002	EP002	P04	CT002/DB002	6	NYCRR	245							

Continuation Sheet 2 of 2

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID										
3	-	1	3	2	6	-	0	0	2	7	5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	5						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	6						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	7						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	242	8						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	251	3						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	251	4						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	251	5						
U-00002	EP002	P04	CT002/DB002	6	NYCRR	251	6						

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	227	2	4	e	3			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00002	EP002	P04	CT002/DB002	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The turbines will meet a LAER emission rate of 2.0 ppmvd at 15% O2, with and without duct firing. The emission level applies at all operating loads except during startup and shutdown. LAER is more stringent than 227.2.4 and therefore satisfies this requirement.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	DLN from GE, SCR from Alstom

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-1326-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	KKKK	4320					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00002	EP002	P04	CT002/DB002	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a LAER emission rate of 2.0 ppmvd at 15% O2, with and without duct firing. The emission levels apply at all operating loads except during startup and shutdown. LAER is more stringent than 40 CFR 60.4320 and therefore satisfies this requirement.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	DLN from GE, SCR from Alstom

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00002	EP002	P04	CT002/DB002	NY998-00-0	Volatile Organic Compounds

Monitoring Information

☐ Continuous Emission Monitoring
☒ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a LAER emission rate of 1.8 ppmvd at 15% O2 with duct firing and 0.7 ppmvd at 15% O2 without duct firing. The emission levels apply at all operating loads except during startup and shutdown. These emission levels will be achieved through good combustion practices and an oxidation catalyst. Stack testing for non-methane hydrocarbons will be conducted to demonstrate compliance with these limits.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 25A & 18

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	Oxidation catalyst is TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13267-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00002	EP002	P04	CT002/DB002	630-08-0	Carbon Monoxide

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a BACT emission rate of 2.0 ppmvd at 15% O2 with and without duct firing. This emission levels apply at all operating loads except during startup and shutdown. These emission levels will be achieved through good combustion practices and an oxidation catalyst. CEMS will be used to demonstrate compliance.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 10

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	Oxidation catalyst is TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	Continuous	07	Quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00002	EP002	P04	CT002/DB002	NY075-00-0	Particulate Matter

Monitoring Information

☐ Continuous Emission Monitoring
☒ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a PM10/PM2.5 emission limit of 0.005 lb/MMBtu without duct burning and 0.006 lb/MMBtu with duct burning as BACT for the proposed project. These levels of emissions will be achieved by firing pipeline quality natural gas as the sole fuel in the turbines and duct burner. The facility will conduct stack testing to demonstrate compliance with these limits.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 5 and RM201/201A & 202

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.006		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00002	EP002	P04	CT002/DB002	7664-09-5	Sulfur Dioxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF in the combustion turbine and duct burners.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00002	EP002	P04	CT002/DB002	7664-93-9	Sulfuric Acid Mist

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a sulfuric acid mist emission limit of 0.00065 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF in the combustion turbine and duct burners.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

DEC ID
3-1326-00275

Section IV - Emission Unit Information

Emission Unit Description	☐ Continuation Sheet(s)
Emission Unit	U-00003

This emission unit will consist of one natural gas fired GE Model 7F.05 combustion turbine generator (CTG) and one heat recovery team generator (HRSG) with supplemental natural gas firing exhausted through a common stack.

Building Information ☐ Continuation Sheet(s)

Building ID	Building Name	Length (ft)	Width (ft)	Orientation
CTGEN03	Combustion Turbine Generator Building	670	100	0°
HRSG03	Heat Recovery Steam Generator Enclosure	128	160	90°
ACC01	Air Cooled Condenser	190	190	90°

Emission Unit -

Emission Unit Emissions Summary ☐ Continuation Sheet(s)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3-1326-00275

Emission Point Information

☐ Continuation Sheet(s)

Emission Point	EP003					
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
435	283	170	228	165		
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal
44	756,000					

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Source/Control Information

☐ Continuation Sheet(s)

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
CT003	C	12/2017	02/2020	N/A			General Electric 7F.05

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
2333.1	25	MMBtu/hr (HHV) at ISO conditions				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
DB003	C	12/2017	02/2020	N/A			

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
247	25	MMBtu/hr (HHV)				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
DLN03	K	12/2017	02/2020	N/A	103	Dry low Nox Burner	General Electric

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Source/Control (continuation)

Emission Unit: U - 0 0 0 0 3

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
SCR03	K	12/2017	02/2020	N/A	033	Selective Catalytic Reduction	Alstom

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
OXC03	K	12/2017	02/2020	N/A	110	Oxidation Catalyst	

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.
	K						

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Emission Source Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model No.

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

DEC ID
3-13263-00275

Process Information ☒ Continuation Sheet(s)

Emission Unit	U-00003	Process	P05

Process Description

Natural gas firing of the GE 7F.05 combustion turbine (CT003) with and without supplemental firing (DB003. Dry low-NOx combustors (DLN03) and selective catalytic reduction (SCR03) will be used to control NOx emissions. An oxidation catalyst (OXC03) will be used to control CO and VOC emissions. Natural gas throughput rates based upon a heat content of 1,000 BTU/CF (HHV) and include both CT003 and DB003. Quantity per hour is based upon maximum hourly rate for all ambient conditions and quantity per year is based upon maximum hourly rate at ISO conditions for 8,760 hours per year.

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description
2-01-002-01	2.64	22,050	0115	million cubic feet of natural gas

Confidential / Operating at Maximum Capacity	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
☒ Operating at Maximum Capacity	24	365	CTGEN03	First Floor

Emission Point Identifier(s)

EP003						

Emission Source/Control Identifier(s)

CT003	DLN03	SCR03	OXC03			

Emission Unit	-	Process

Process Description

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description

Confidential / Operating at Maximum Capacity	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		

Emission Point Identifier(s)

Emission Source/Control Identifier(s)

DEC ID
3-1326-00275

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements							× Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00003	EP003	P05	CT003	40	CFR	60	KKKK	4320	1				
U-00003	EP003	P05	CT003	40	CFR	60	KKKK	4330	a	2			
U-00003	EP003	P05	CT003	40	CFR	60	KKKK	4333	a				
U-00003	EP003	P05	CT003	40	CFR	60	KKKK	4340	b	1			

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements							× Continuation Sheet(s)		
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	1	5					
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	2	4					
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	3						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	4						

Emission Unit Compliance Certification ☐ Continuation Sheet(s)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

Applicable Federal Requirement | State Only Requirement | Capping

Emission Unit	Emission Point	Process	Emission Source	CAS Number	Contaminant Name
U-00003	EP003	P05	CT003/DB003	NY210-00-0	Oxides of Nitrogen (NOx)

Monitoring Information

× Continuous Emission Monitoring
Intermittent Emission Testing
Ambient Air Monitoring
Monitoring of a Process or Control Device Parameters as a Surrogate
Work Practice Involving Specific Operations
Record Keeping/Maintenance Procedures

Compliance Activity Description

Facility will maintain a NOx emission limit of 2.0 ppmv at 15 percent O2 (w/ and w/o duct burning) to satisfy LAER. This will be achieved through the application of DLN burners in combination with SCR. This limit applies at all load conditions except startup and shutdown. The facility will use CEMS to monitor NOx stack emissions.

Work Practice Type Code	Process Material		Reference Test Method
	Code	Description	
			40 CFR 60, App. A, Method 7E

Monitored Parameter		Manufacturer's Name/Model Number
Code	Description	
23	concentration	GE DLN, SCR Alstom

Limit		Limit Units	
Upper	Lower	Code	Description
2.0		275	parts per million by volume (dry) at 15% O2

Averaging Method		Monitoring Frequency		Reporting Requirements	
Code	Description	Code	Description	Code	Description
08	1-hour average	01	continuous	07	quarterly

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4345					
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4350					
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4365					
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4375					
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4380					
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4395					
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4400					
U-00003	EP003	P05	CT003/DB003	40	CFR	60	KKKK	4405					
U-00003	EP003	P05	CT003/DB003	40	CFR	72	A	6	a	3	i		
U-00003	EP003	P05	CT003/DB003	40	CFR	72	A	9					
U-00003	EP003	P05	CT003/DB003	40	CFR	75	A	2					
U-00003	EP003	P05	CT003/DB003	40	CFR	75	B	10					
U-00003	EP003	P05	CT003/DB003	40	CFR	75	B	11					
U-00003	EP003	P05	CT003/DB003	40	CFR	75	B	12					
U-00003	EP003	P05	CT003/DB003	40	CFR	75	B	13					
U-00003	EP003	P05	CT003/DB003	40	CFR	75	C						
U-00003	EP003	P05	CT003/DB003	40	CFR	75	D						
U-00003	EP003	P05	CT003/DB003	40	CFR	75	F						
U-00003	EP003	P05	CT003/DB003	40	CFR	75	G						
U-00003	EP003	P05	CT003/DB003	40	CFR	75	H						
U-00003	EP003	P05	CT003/DB003	40	CFR	97	A						
U-00003	EP003	P05	CT003/DB003	40	CFR	97	D						
U-00003	EP003	P05	CT003/DB003	40	CFR	97	H						
U-00003	EP003	P05	CT003/DB003	40	CFR	97	AAAAA						
U-00003	EP003	P05	CT003/DB003	40	CFR	97	CCCCC						
U-00003	EP003	P05	CT003/DB003	40	CFR	97	EEEEE						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	227	2	4	e				
U-00003	EP003	P05	CT003/DB003	6	NYCRR	227	2	6	a	4			
U-00003	EP003	P05	CT003/DB003	6	NYCRR	227	2	6	b				
U-00003	EP003	P05	CT003/DB003	6	NYCRR	231	5	4					
U-00003	EP003	P05	CT003/DB003	6	NYCRR	231	7	6					

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00003	EP003	P05	CT003/DB003	6	NYCRR	243							
U-00003	EP003	P05	CT003/DB003	6	NYCRR	244							
U-00003	EP003	P05	CT003/DB003	6	NYCRR	245							

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID										
3	-	1	3	2	6	-	0	0	2	7	5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	5						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	6						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	7						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	242	8						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	251	3						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	251	4						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	251	5						
U-00003	EP003	P05	CT003/DB003	6	NYCRR	251	6						

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	227	2	4	e	3			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00003	EP003	P05	CT003/DB003	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The turbines will meet a LAER emission rate of 2.0 ppmvd at 15% O2, with and without duct firing. The emission level applies at all operating loads except during startup and shutdown. LAER is more stringent than 227.2.4 and therefore satisfies this requirement.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	DLN from GE, SCR from Alstom

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	KKKK	4320					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00003	EP003	P05	CT003/DB003	NY210-00-0	Oxides of Nitrogen

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a LAER emission rate of 2.0 ppmvd at 15% O2, with and without duct firing. The emission levels apply at all operating loads except during startup and shutdown. LAER is more stringent than 40 CFR 60.4320 and therefore satisfies this requirement.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 7E

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	DLN from GE, SCR from Alstom

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	continuous	07	quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	5	4					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00003	EP003	P05	CT003/DB003	NY998-00-0	Volatile Organic Compounds

Monitoring Information

☐ Continuous Emission Monitoring
☒ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a LAER emission rate of 1.8 ppmvd at 15% O2 with duct firing and 0.7 ppmvd at 15% O2 without duct firing. The emission levels apply at all operating loads except during startup and shutdown. These emission levels will be achieved through good combustion practices and an oxidation catalyst. Stack testing for non-methane hydrocarbons will be conducted to demonstrate compliance with these limits.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 25A & 18

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	Oxidation catalyst is TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13267-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00003	EP003	P05	CT003/DB003	630-08-0	Carbon Monoxide

Monitoring Information

☒ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will meet a BACT emission rate of 2.0 ppmvd at 15% O2 with and without duct firing. This emission levels apply at all operating loads except during startup and shutdown. These emission levels will be achieved through good combustion practices and an oxidation catalyst. CEMS will be used to demonstrate compliance.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 10

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	Oxidation catalyst is TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.0		275	parts per million by volume (dry, corrected to 15% O2)

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	01	Continuous	07	Quarterly

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00003	EP003	P05	CT003/DB003	NY075-00-0	Particulate Matter

Monitoring Information

☐ Continuous Emission Monitoring
☒ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a PM10/PM2.5 emission limit of 0.005 lb/MMBtu without duct burning and 0.006 lb/MMBtu with duct burning as BACT for the proposed project. These levels of emissions will be achieved by firing pipeline quality natural gas as the sole fuel in the turbines and duct burner. The facility will conduct stack testing to demonstrate compliance with these limits.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
			40 CFR 60, App. A, Method 5 and RM201/201A & 202

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.006		7	pounds per million Btu

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
08	1-hour average	14	As required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00003	EP003	P05	CT003/DB003	7664-09-5	Sulfur Dioxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF in the combustion turbine and duct burners.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00003	EP003	P05	CT003/DB003	7664-93-9	Sulfuric Acid Mist

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

Facility will maintain a sulfuric acid mist emission limit of 0.00065 lb/MMBtu (with and without duct burning) as BACT. This level of emissions will be achieved by firing pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 SCF in the combustion turbine and duct burners.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method
04	12	Natural gas	

Parameter Code	Parameter Description	Manufacturer Name/Model No.
32	Sulfur Content	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.4		13	grains per 100 DSCF

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
17	Annual maximum rolled monthly	05	Monthly	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Description ☐ Continuation Sheet(s)

Emission Unit: U - 0 0 0 0 4

This emission unit will consist of one diesel fired emergency fire pump engine that will operate no more than 500 hours per year.

Building Information ☐ Continuation Sheet(s)

Building ID	Building Name	Length (ft)	Width (ft)	Orientation
WATANK	Service/fire water storage tank			

Emission Unit: -

Emission Unit Emissions Summary ☐ Continuation Sheet(s)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3-1326-00275

Emission Point Information

☐ Continuation Sheet(s)

Emission Point	EP004					
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
435	14	0	6	687		
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal
108	1,277					

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Source/Control Information

☐ Continuation Sheet(s)

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
FP001	C	12/2017	8/2019	N/A			

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
460	219	horsepower (mechanical)				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

DEC ID
3-1326-00275

Process Information [×] Continuation Sheet(s)

Emission Unit	U-00004	Process	P06

Process Description

Emergency fire pump engine rated at 460 brake horsepower firing diesel fuel. Annual diesel fuel fired based upon 500 hours per rolling 12-month period.

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description
2-02-001-02	20.3	10,150	15	gallons

Confidential	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
× Operating at Maximum Capacity	See description			

Emission Point Identifier(s)

EP004						

Emission Source/Control Identifier(s)

FP01						

Emission Unit	-	Process

Process Description

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description

Confidential	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
Operating at Maximum Capacity				

Emission Point Identifier(s)

Emission Source/Control Identifier(s)

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements										× Continuation Sheet(s)
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.	
U-00004	EP004	P06	FP001	40	CFR	60	IIII	4205	c					
U-00004	EP004	P06	FP001	40	CFR	60	IIII	4206						
U-00004	EP004	P06	FP001	40	CFR	60	IIII	4207	b					
U-00004	EP004	P06	FP001	40	CFR	60	IIII	4209	a					

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements										☐ Continuation Sheet(s)
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.	

Emission Unit Compliance Certification ☐ Continuation Sheet(s)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	4205	c				

Applicable Federal Requirement | State Only Requirement | Capping

Emission Unit	Emission Point	Process	Emission Source	CAS Number	Contaminant Name
U-00004	EP004	P06	FP001	NY210-00-0	Oxides of Nitrogen (NOx)

Monitoring Information

Continuous Emission Monitoring	Monitoring of a Process or Control Device Parameters as a Surrogate
Intermittent Emission Testing	Work Practice Involving Specific Operations
Ambient Air Monitoring	× Record Keeping/Maintenance Procedures

Compliance Activity Description

Facility will purchase a fire pump engine that will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engine will maintain a NOx + HC emission rate of 3.0 g/hp-hr. Compliance with this limit is also considered LAER. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type Code	Process Material		Reference Test Method
	Code	Description	

Monitored Parameter		Manufacturer's Name/Model Number
Code	Description	
23	concentration	

Limit		Limit Units	
Upper	Lower	Code	Description
3.0		319	grams per brake horsepower hour

Averaging Method		Monitoring Frequency		Reporting Requirements	
Code	Description	Code	Description	Code	Description
		14	as required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00004	EP004	P06	FP001	40	CFR	60	IIII	4214	b				
U-00004	EP004	P06	FP001	6	NYCRR	231	7	6					

Continuation Sheet 1 of 1

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4205	c			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00004	EP004	P06	FP001	NY998-00-00	Volatile organic compounds

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

Facility will purchase a fire pump engine that will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engine will maintain a NOx + HC emission rate of 3.0 g/hp-hr. Compliance with these federal limits is also considered LAER. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
3.0		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13267-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4205	c			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00004	EP004	P06	FP001	630-08-0	Carbon Monoxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

Facility will purchase engines that have been certified by the manufacturer to meet the federal emission standards under 40 CFR 60.4202 for the current model year. Thus the engines will maintain a CO emission rate of 2.6 g/hp-hr. Compliance with this federal limit is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.6		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4205	c			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00004	EP004	P06	FP001	NY075-00-0	Particulate

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

Facility will purchase engines that have been certified by the manufacturer to meet the federal emission standards under 40 CFR 60.4202 for the current model year. Thus the engines will maintain a particulate emission rate of 0.15 g/hp-hr. Compliance with this federal limit is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.15		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-132-6-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4205	c			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00004	EP004	P06	FP001	7664-04-5	Sulfur Dioxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu as BACT for the proposed project fire pump engine. The proposed engines will only combust diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.15		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3-13267-00275

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00004	EP004	P06	FP001	07664-93-9	Sulfuric Acid Mist

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will maintain a sulfuric acid mist emission limit of 0.00011 lb/MMBtu as BACT for the proposed project fire pump engine. The proposed engines will only combust diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.15		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

DEC ID
3-1326-00275

Section IV - Emission Unit Information

Emission Unit Description	☐ Continuation Sheet(s)
Emission Unit: U-00005	

This emission unit will consist of one 1,500 kW electrical (1,645 mechanical) diesel fired emergency generator engine that will operate no more than 500 hours per year.

Building Information ☐ Continuation Sheet(s)

Building ID	Building Name	Length (ft)	Width (ft)	Orientation
EGENC	Emergency Generator Engine Enclosure	38.5	11	0°

Emission Unit: -

Emission Unit Emissions Summary ☐ Continuation Sheet(s)

CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)
CAS Number	Contaminant Name			
ERP (lbs/yr)	Potential to Emit		Actual Emissions	
	(lbs/hr)	(lbs/yr)	(lbs/hr)	(lbs/yr)

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3-1326-00275

Emission Point Information

☐ Continuation Sheet(s)

Emission Point	EP005					
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
435	47	15	18	659		
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal
94	10,000					

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Point						
Ground Elevation (ft)	Height (ft)	Height Above Structure (ft)	Inside Diameter (in)	Exit Temp. (°F)	Cross Section	
					Length (in)	Width (in)
Exit Velocity (FPS)	Exit Flow (ACFM)	NYTM (E) (KM)	NYTM (N) (KM)	Building	Distance to Property Line (ft)	Date of Removal

Emission Source/Control Information

☐ Continuation Sheet(s)

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number
EDG01	C	12/2017	8/2019	N/A			Caterpillar 3512C

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description
2206	219	horsepower (mechanical)				

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

Emission Source ID	Type	Date of Construction	Date of Operation	Date of Removal	Control Type Code	Control Type Description	Manufacturer's Name/Model Number

Design Capacity	Design Capacity Units Code	Design Capacity Units Description	Waste Feed Code	Waste Feed Description	Waste Type Code	Waste Type Description

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3-1326-00275

Process Information ☒ Continuation Sheet(s)

Emission Unit	U-00005	Process	P07

Process Description

Emergency generator engine rated at 2,206 brake horsepower firing diesel fuel. Annual diesel fuel fired based upon 500 hours per rolling 12-month period.

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description
2-02-001-02	104.6	52,300	15	gallons

Confidential	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
☒ Operating at Maximum Capacity	See description			

Emission Point Identifier(s)

EP005						

Emission Source/Control Identifier(s)

EDG01						

Emission Unit	-	Process

Process Description

Source Classification Code (SCC)	Total Throughput		Throughput Quantity Units	
	Quantity/Hr	Quantity/Yr	Code	Description

Confidential	Operating Schedule		Building	Floor/Location
	Hours/Day	Days/Year		
Operating at Maximum Capacity				

Emission Point Identifier(s)

Emission Source/Control Identifier(s)

DEC ID
3-1326-00275

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements										☒ Continuation Sheet(s)
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.	
U-00005	EP005	P07	EDG01	40	CFR	60	IIII	4205	b					
U-00005	EP005	P07	EDG01	40	CFR	60	IIII	4206						
U-00005	EP005	P07	EDG01	40	CFR	60	IIII	4207	b					
U-00005	EP005	P07	EDG01	40	CFR	60	IIII	4209	a					

Emission Unit	Emission Point	Process	Emission Source	Emission Unit State Only Requirements										☐ Continuation Sheet(s)
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Cl.	Subcl.	

Emission Unit Compliance Certification ☐ Continuation Sheet(s)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	4205	b				

Applicable Federal Requirement | State Only Requirement | Capping

Emission Unit	Emission Point	Process	Emission Source	CAS Number	Contaminant Name
U-00005	EP005	P07	EDG01	NY210-00-0	Oxides of Nitrogen (NOx)

Monitoring Information

Continuous Emission Monitoring	Monitoring of a Process or Control Device Parameters as a Surrogate
Intermittent Emission Testing	Work Practice Involving Specific Operations
Ambient Air Monitoring	× Record Keeping/Maintenance Procedures

Compliance Activity Description

Facility will purchase an emergency generator engine that will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engine will maintain a NOx + HC emission rate of 4.8 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with these federal limits is also considered LAER. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type Code	Process Material		Reference Test Method
	Code	Description	

Monitored Parameter		Manufacturer's Name/Model Number
Code	Description	
23	concentration	Caterpillar 3512C

Limit		Limit Units	
Upper	Lower	Code	Description
4.8		319	grams per brake horsepower hour

Averaging Method		Monitoring Frequency		Reporting Requirements	
Code	Description	Code	Description	Code	Description
		14	as required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit	Emission Point	Process	Emission Source	Emission Unit Applicable Federal Requirements (continuation)									
				Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.
U-00005	EP005	P07	EDG01	40	CFR	60	IIII	4214	b				
U-00005	EP005	P07	EDG01	6	NYCRR	231	7	6					

Continuation Sheet 1 of 1

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4205	b			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00005	EP005	P07	EDG01	NY998-00-00	Volatile organic compounds

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

Facility will purchase an emergency generator engine that will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus the engine will maintain a NOx + HC emission rate of 4.8 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with these federal limits is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
4.8		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4205	b			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00005	EP005	P07	EDG01	630-08-0	Carbon Monoxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

Facility will purchase an emergency generator engine that will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model year. Thus the engine will maintain a CO emission rate of 2.6 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with this federal limit is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
2.6		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4205	b			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00005	EP005	P07	EDG01	NY075-00-0	Particulate

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☐ Work Practice Involving Specific Operations
☒ Record Keeping/Maintenance Procedures

Description

Facility will purchase an emergency generator engine that will be certified to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model year. Thus the engine will maintain a PM emission rate of 0.15 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with this federal limit is also considered BACT. Compliance will be demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.15		319	Grams per brake horsepower hour

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
40	CFR	60	IIII	6	4207	b			

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00005	EP005	P07	EDG01	7664-04-5	Sulfur Dioxide

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will maintain a SO2 emission limit of 0.0015 lb/MMBtu as BACT for the proposed emergency generator engine. The proposed engines will only combust diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight in accordance with 40 CFR 80.510(b)(1)(i) .

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.0015		7	pounds per million Btus

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application Form

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Section IV - Emission Unit Information

Emission Unit Compliance Certification (continuation)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause
6	NYCRR	231	7	6					

☒ Applicable Federal Requirement ☐ State Only Requirement ☐ Capping

Emission Unit	Emission Point	Process	Emission Source	CAS No.	Contaminant Name
U-00005	EP005	P07	EDG01	07664-93-9	Sulfuric Acid Mist

Monitoring Information

☐ Continuous Emission Monitoring
☐ Intermittent Emission Testing
☐ Ambient Air Monitoring
☐ Monitoring of Process or Control Device Parameters as a Surrogate
☒ Work Practice Involving Specific Operations
☐ Record Keeping/Maintenance Procedures

Description

The facility will maintain a sulfuric acid mist emission limit of 0.00011 lb/MMBtu as BACT for the proposed emergency generator engine. The proposed engines will only combust diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight.

Work Practice Type	Process Material Code	Process Material Description	Reference Test Method

Parameter Code	Parameter Description	Manufacturer Name/Model No.
23	Concentration	TBD

Limit Upper	Limit Lower	Limit Units Code	Limit Units Description
0.00011		7	pounds per million Btus

Averaging Method Code	Averaging Method Description	Monitoring Frequency Code	Monitoring Frequency Description	Reporting Requirements Code	Reporting Requirements Description
		14	As Required	10	Upon request

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Determination of Non-Applicability (Title V Applications Only)

☐ Continuation Sheet(s)

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause

Emission Unit	Emission Point	Process	Emission Source

☐ Applicable Federal Requirement
☐ State Only Requirement

Non-Applicability Description

Rule Citation

Title	Type	Part	Subpart	Section	Subdivision	Paragraph	Subparagraph	Clause	Subclause

Emission Unit	Emission Point	Process	Emission Source

☐ Applicable Federal Requirement
☐ State Only Requirement

Non- Applicability Description

Compliance Plan

☐ Continuation Sheet(s)

For any emission units which are <u>not in compliance</u> at the time of permit application, the applicant shall complete the following:

Consent Order		Certified progress reports are to be submitted every 6 months beginning / /

Emission Unit	Process	Emission Source	Applicable Federal Requirement									
			Title	Type	Part	Subpart	Section	Subdiv.	Parag.	Subparag.	Clause	Subcl.

Remedial Measures and Intermediate Milestones	R/I	Date Scheduled

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Request for Emission Reduction Credits

☐ Continuation Sheet(s)

Emission Source

Emission Reduction Description

Contaminant Emission Reduction Data

Baseline Period ____/____/_____ to ____/____/_____

		Reduction	
		Date	Method

CAS Number	Contaminant Name	ERC (lbs/yr)	
		Netting	Offset

Facility to Use Future Reduction

Name — Application ID

Location Address

☐ City/ ☐ Town / ☐ Village — State — Zip

Use of Emission Reduction Credits

☐ Continuation Sheet(s)

Emission Source

Proposed Project Description

Contaminant Emissions Increase Data

CAS Number	Contaminant Name	Project Emission Potential (lbs/yr)

Statement of Compliance

☐ All facilities under the ownership of this "owner/firm" are operating in compliance with all applicable requirements and state regulations including any compliance certification requirements under Section 114(a)(3) of the Clean Air Act Amendments of 1990, or are meeting the schedule of a consent order.

Source of Emission Reduction Credit - Facility

Name — Permit ID

Location Address

☐ City/ ☐ Town / ☐ Village — State — Zip

Emission Source	CAS Number	Contaminant Name	ERC (lbs/yr)	
			Netting	Offset

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Supporting Documentation and Attachments	
Required Supporting Documentation	Date of Document
× List of Exempt Activities (attach form)	Date of this application
× Plot Plan	05/01/2017
× Process Flow Diagram	Date of this application
× Methods Used to Determine Compliance (attach form)	Date of this application
× Emissions Calculations	12/18/2018
Optional Supporting Documentation	Date of Document
Air Quality Model	
Confidentiality Justification	
Ambient Air Quality Monitoring Plan or Reports	
Stack Test Protocol	
Stack Test Report	
Continuous Emissions Monitoring Plan	
Lowest Achievable Emission Rate (LAER) Demonstration	
Best Available Control Technology (BACT) Demonstration	
Reasonably Available Control Technology (RACT) Demonstration	
Toxic Impact Assessment (TIA)	
Environmental Rating Demonstration	
Operational Flexibility Protocol/Description of Alternate Operating Scenarios	
Title IV Permit Application	
Emission Reduction Credit (ERC) Quantification (attach form)	
Baseline Period Demonstration	
Use of Emission Reduction Credits (attach form)	
Analysis of Contemporaneous Emissions Increase/Decrease	
Other Supporting Documentation	Date of Document

APPENDIX B: LIST OF EXEMPT ACTIVITIES

New York State Department of Environmental Conservation
Air Permit Application

NEW YORK STATE OF OPPORTUNITY | Department of Environmental Conservation

DEC ID										
3	-	1	3	2	6	-	0	0	2	7	5

List of Exempt Activities

Instructions

Applicants for Title V facility permits must provide a listing of each exempt activity, as described in 6 NYCRR Part 201-3.2(c), that is currently operated at the facility. This form provides a means to fulfill this requirement.

In order to complete this form, enter the number and building location of each exempt activity. Building IDs used on this form should match those used in the Title V permit application. If a listed activity is not operated at the facility, leave the corresponding information blank.

Combustion

Rule Citation 201-3.2(c)	Description	Number of Activities	Building Location
(1)	Stationary or portable combustion installations where the furnace has a maximum heat input capacity less than 10 mmBtu/hr burning fuels other than coal or wood; or a maximum heat input capacity of less than 1 mmBtu/hr burning coal or wood. This activity does not include combustion installations burning any material classified as solid waste, as defined in 6 NYCRR Part 360, or waste oil, as defined in 6 NYCRR Subpart 225-2.		
(2)	Space heaters burning waste oil at automotive service facilities, as defined in 6 NYCRR Subpart 225-2, generated on-site or at a facility under common control, alone or in conjunction with used oil generated by a do-it-yourself oil changer as defined in 6 NYCRR Subpart 374-2.		
(3)(i)	Stationary or portable internal combustion engines that are liquid or gaseous fuel powered and located within the New York City metropolitan area or the Orange County towns of Blooming Grove, Chester, Highlands, Monroe, Tuxedo, Warwick, or Woodbury, and have a maximum mechanical power rating of less than 200 brake horsepower.		
(3)(ii)	Stationary or portable internal combustion engines that are liquid or gaseous fuel powered and located outside of the New York City metropolitan area or the Orange County towns of Blooming Grove, Chester, Highlands, Monroe, Tuxedo, Warwick, or Woodbury, and have a maximum mechanical power rating of less than 400 brake horsepower.		
(3)(iii)	Stationary or portable internal combustion engines that are gasoline powered and have a maximum mechanical power rating of less than 50 brake horsepower.		
(4)	Reserved.		
(5)	Gas turbines with a heat input at peak load less then 10 mmBtu/hour		

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Rule Citation 201-3.2(c)	Description	Number of Activities	Building Location
(6)	Emergency power generating stationary internal combustion engines, as defined in 6 NYCRR Part 200.1(cq), and engine test cells at engine manufacturing facilities that are utilized for research and development, reliability performance testing, or quality assurance performance testing. Stationary internal combustion engines used for peak shaving and/or demand response programs are not exempt.		
Combustion Related			
(7)	Non-contact water cooling towers and water treatment systems for process cooling water and other water containers designed to cool, store or otherwise handle water that has not been in direct contact with gaseous or liquid process streams.		
Agricultural			
(8)	Feed and grain milling, cleaning, conveying, drying and storage operations including grain storage silos, where such silos exhaust to an appropriate emissions control device, excluding grain terminal elevators with permanent storage capacities over 2.5 million U.S. bushels, and grain storage elevators with capacities above one million bushels.		
(9)	Equipment used exclusively to slaughter animals, but not including other equipment at slaughterhouses, such as rendering cookers, boilers, heating plants, incinerators, and electrical power generating equipment.		
Commercial - Food Service Industries			
(10)	Flour silos at bakeries, provided all such silos are exhausted through an appropriate emission control device.		
(11)	Emissions from flavorings added to a food product where such flavors are manually added to the product.		
Commercial - Graphic Arts			
(12)	Screen printing inks/coatings or adhesives which are applied by a hand-held squeegee. A hand-held squeegee is one that is not propelled though the use of mechanical conveyance and is not an integral part of the screen printing process.		
(13)	Graphic arts processes at facilities located outside the New York City metropolitan area or the Orange County towns of Blooming Grove, Chester, Highlands, Monroe, Tuxedo, Warwick, or Woodbury whose facility-wide total emissions of volatile organic compounds from inks, coatings, adhesives, fountain solutions and cleaning solutions are less than three tons during any 12-month period.		

Rule Citation 201-3.2(c)	Description	Number of Activities	Building Location
(14)	Graphic label and/or box labeling operations where the inks are applied by stamping or rolling.		
(15)	Graphic arts processes which are specifically exempted from regulation under 6 NYCRR Part 234, with respect to emissions of volatile organic compounds which are not given an A rating as described in 6 NYCRR Part 212.		
Commercial - Other			
(16)	Gasoline dispensing sites registered with the department pursuant to 6 NYCRR Part 612.		
(17)	Surface coating and related activities at facilities which use less than 25 gallons per month of total coating materials, or with actual volatile organic compound emissions of 1,000 pounds or less from coating materials in any 12-month period. Coating materials include all paints and paint components, other materials mixed with paints prior to application, and cleaning solvents, combined. This exemption is subject to the following: (i) The facility is located outside of the New York City metropolitan area or the Orange County towns of Blooming Grove, Chester, Highlands, Monroe, Tuxedo, Warwick, or Woodbury; and (ii) All abrasive cleaning and surface coating operations are performed in an enclosed building where such operations are exhausted into appropriate emission control devices.		
(18)	Abrasive cleaning operations which exhaust to an appropriate emission control device.		
(19)	Ultraviolet curing operations.		
Municipal/Public Health Related			
(20)	Landfill gas ventilating systems at landfills with design capacities less than 2.5 million megagrams (3.3 million tons) and 2.5 million cubic meters (2.75 million cubic yards), where the systems are vented directly to the atmosphere, and the ventilating system has been required by, and is operating under, the conditions of a valid 6 NYCRR Part 360 permit, or order on consent.		
Storage Vessels			
(21)	Distillate fuel oil, residual fuel oil, and liquid asphalt storage tanks with storage capacities below 300,000 barrels.	2	

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Rule Citation 201-3.2(c)	Description	Number of Activities	Building Location
(22)	Pressurized fixed roof tanks which are capable of maintaining a working pressure at all times to prevent emissions of volatile organic compounds to the outdoor atmosphere.		
(23)	External floating roof tanks which are of welded construction and are equipped with a metallic-type shoe primary seal and a secondary seal from the top of the shoe seal to the tank wall.		
(24)	External floating roof tanks which are used for the storage of a petroleum or volatile organic liquid with a true vapor pressure less than 4.0 psi (27.6 kPa), are of welded construction and are equipped with one of the following: (i) a metallic-type shoe seal; (ii) a liquid-mounted foam seal; (iii) a liquid-mounted liquid-filled type seal; or (iv) equivalent control equipment or device.		
(25)	Storage tanks, including petroleum liquid storage tanks as defined in 6 NYCRR Part 229, with capacities less than 10,000 gallons, except those subject to 6 NYCRR Part 229 or Part 233.		
(26)	Horizontal petroleum or volatile organic liquid storage tanks.		
(27)	Storage silos storing solid materials, provided all such silos are exhausted through an appropriate emission control device. This exemption does not include raw material, clinker, or finished product storage silos at Portland cement plants.		
Industrial			
(28)	Processing equipment at existing sand and gravel and stone crushing plants which were installed or constructed before August 31, 1983, where water is used for operations such as wet conveying, separating, and washing. This exemption does not include processing equipment at existing sand and gravel and stone crushing plants where water is used for dust suppression.		
(29)(i)	Sand and gravel processing or crushed stone processing lines at a non-metallic mineral processing facility that are a permanent or fixed installation with a maximum rated processing capacity of 25 tons of minerals per hour or less.		

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Rule Citation 201-3.2(c)	Description	Number of Activities	Building Location
(29)(ii)	Sand and gravel processing or crushed stone processing lines at a non-metallic mineral processing facility that are a portable emission source with a maximum rated processing capacity of 150 tons of minerals per hour or less.		
(29)(iii)	Sand and gravel processing or crushed stone processing lines at a non-metallic mineral processing facility that are used exclusively to screen minerals at a facility where no crushing or grinding takes place.		
(30)	Reserved.		
(31)	Surface coating operations which are specifically exempted from regulation under 6 NYCRR Part 228, with respect to emissions of volatile organic compounds which are not given an A rating pursuant to 6 NYCRR Part 212.		
(32)	Pharmaceutical tablet branding operations.		
(33)	Thermal packaging operations, including, but not limited to, therimage labeling, blister packing, shrink wrapping, shrink banding, and carton gluing.		
(34)	Powder coating operations.		
(35)	All tumblers used for the cleaning and/or deburring of metal products without abrasive blasting.		
(36)	Presses used exclusively for molding or extruding plastics except where halogenated carbon compounds or hydrocarbon solvents are used as foaming agents.		
(37)	Concrete batch plants where the cement weigh hopper and all bulk storage silos are exhausted through fabric filters, and the batch drop point is controlled by a shroud or other emission control device.		
(38)	Cement storage operations not located at Portland cement plants where materials are transported by screw or bucket conveyors.		
(39)(i)	Cold cleaning degreasers with an open surface area of 11 square feet or less and an internal volume of 93 gallons or less or, having an organic solvent loss of 3 gallons per day or less.		
39(ii)	Cold cleaning degreasers that use a solvent with a VOC content or five percent or less by weight, unless subject to the requirements of 40 CFR 63 Subpart T.		

DEC ID										
3	-	1	3	2	6	-	0	0	2	7	5

Rule Citation 201-3.2(c)	Description	Number of Activities	Building Location
(39)(iii)	Conveyorized degreasers with an air/vapor interface smaller than 22 square feet (2 square meters), unless subject to the requirements of 40 CFR 63 Subpart T.		
(39)(iv)	Open-top vapor degreasers with an open-top area smaller than 11 square feet (1 square meter), unless subject to the requirements of 40 CFR 63 Subpart T.		
Miscellaneous			
(40)	Ventilating and exhaust systems for laboratory operations. Laboratory operations do not include processes having a primary purpose to produce commercial quantities of materials.		
(41)	Exhaust or ventilating systems for the melting of gold, silver, platinum and other precious metals.		
(42)	Exhaust systems for paint mixing, transfer, filling or sampling and/or paint storage rooms or cabinets, provided the paints stored within these locations are stored in closed containers when not in use.		
(43)	Exhaust systems for solvent transfer, filling or sampling, and/or solvent storage rooms provided the solvent stored within these locations are stored in containers when not in use.		
(44)	Research and development activities, including both stand-alone and activities within a major facility, until such time as the administrator completes a rule making to determine how the permitting program should be structured for these activities.		
(45)	The application of odor counteractants and/or neutralizers.		
(46)	Hydrogen fuel cells.		
(47)	Dry cleaning equipment that uses only water-based cleaning processes or those using liquid carbon dioxide.		
(48)	Manure spreading, handling and storage at farms and agricultural facilities.		

APPENDIX C: PLOT PLAN


NA_FORMATS.CEL AC=ESTD_NA 03/17/15

EMISSION POINTS

NO.	DESCRIPTION		NORTHING	EASTING
✲	HRSG STACK 1	NAD27	N 611,538.7171	E 705,508.9422
		PLANT COORD	N 5,014.00	E 9,975.75
✲	HRSG STACK 2	NAD27	N 611,529.1405	E 705,535.2535
		PLANT COORD	N 5,000.00	E 10,000.00
✲	HRSG STACK 3	NAD27	N 611,511.1424	E 705,513.8043
		PLANT COORD	N 4,986.00	E 9,975.75
✲	DIESEL GENERATOR	NAD27	N 611,538.7171	E 705,508.9422
		PLANT COORD	N 5,014.00	E 9,975.75
✲	AUXILIARY BOILER	NAD27	N 611,538.7171	E 705,508.9422
		PLANT COORD	N 5,014.00	E 9,975.75
✲	DIESEL FIRE PUMP	NAD27	N 612,043.00	E 705,752.00
		PLANT COORD	N 5,467.85	E 10,303.98
✲	SWITCH YARD EDG	NADB3	N 1,036,956.9182	E 743,832.2573
		PLANT COORD	N 4,970.67	E 10,549.42

TIE-IN POINTS

NO.	DESCRIPTION			NORTHING	EASTING
1	MAKE-UP WATER SUPPLY	WELL B-3	NADB3	N 1,036,948.2226	E 744,212.4711
			PLANT COORD	N 4,887.48	E 10,925.69
		WELL B-4	NADB3	N 1,036,514.1595	E 743,584.6161
			PLANT COORD	N 4,577.65	E 10,228.65
		WELL B-5	NADB3	N 1,036,905.3278	E 743,895.7297
			PLANT COORD	N 4,908.84	E 10,602.96
		WELL B-6	NADB3	N 1,037,139.7686	E 744,205.3043
			PLANT COORD	N 5,085.96	E 10,948.55
2	ELECTRICAL INTERCONNECTION	TAKEOFF TOWER NORTH A PHASE	NADB3	N 1,037,130.6300	E 743,848.2502
			PLANT COORD	N 5,138.97	E 10,595.32
		TAKEOFF TOWER NORTH B PHASE	NADB3	N 1,037,105.0250	E 743,852.7649
			PLANT COORD	N 5,112.97	E 10,595.32
		TAKEOFF TOWER NORTH C PHASE	NADB3	N 1,037,079.4200	E 743,857.2796
			PLANT COORD	N 5,086.97	E 10,595.32
		TAKEOFF TOWER SOUTH A PHASE	NADB3	N 1,037,056.7717	E 743,861.2751
			PLANT COORD	N 5,063.97	E 10,595.32
		TAKEOFF TOWER SOUTH B PHASE	NADB3	N 1,037,031.1666	E 743,865.7898
			PLANT COORD	N 5,037.97	E 10,595.32
		TAKEOFF TOWER SOUTH C PHASE	NADB3	N 1,037,005.5616	E 743,870.3045
			PLANT COORD	N 5,011.97	E 10,595.32
		TAKEOFF TOWER F84 A PHASE	NADB3	N 1,037,174.5380	E 743,719.4280
			PLANT COORD	N 5,204.58	E 10,476.08
		TAKEOFF TOWER F84 B PHASE	NADB3	N 1,037,178.3581	E 743,741.0938
			PLANT COORD	N 5,204.58	E 10,498.08
		TAKEOFF TOWER F84 C PHASE	NADB3	N 1,037,182.1783	E 743,762.7596
			PLANT COORD	N 5,204.58	E 10,520.08
3	FUEL GAS SUPPLY		NADB3	N 1,037,796.442	E 743,646.450
			PLANT COORD	N 5,828.688	E 10,513.906
4	ELECTRICAL POWER SUPPLY AND DCS SERIAL LINK		NADB3	N 1,037,745.099	E 743,590.754
			PLANT COORD	N 5,787.92	E 10,450.06




1	• MAIN GATE
2	• PARKING
3	• SECONDARY GATE
4	PIPE RACK
10	HEAT RECOVERY STEAM GENERATOR (HRSG) BUILDING
11	HEAT RECOVERY STEAM GENERATOR (HRSG)
11A	DUCT FIRING SKID
11B	LP RECIRCULATION PUMP
11C	SAMPLE PANEL (SWAS)
11D	CHEMICAL FEED SYSTEM
12	HRSG BOILER FEEDWATER PUMP
13	HRSG BLOWDOWN TANK
13A	BLOWDOWN SUMP
13B	BLOWDOWN COOLER
14	COMBUSTION TURBINE (CTG)
14A	• WATER WASH SKID
14B	COMBUSTION TURBINE WATER WASH DRAIN SUMP
15	COMBUSTION TURBINE GENERATOR (BELOW)
16	CONDENSATE PUMP
17	• CLOSED COOLING WATER PUMPS
18	INTERNAL DRAINS TANK
19	• AUXILIARY BOILER
20	MCE BUILDING
21	STEAM TURBINE/GENERATOR (STG)
25	• AIR COMPRESSORS/DRYERS/RECEIVER
30	• DELETED
31	LCI COMPARTMENT
32	• COMMON POWER CONTROL CENTER (PCC)
32A	AIR COOLED CONDENSER MCC
32B	START-UP HEATER SWITCHGEAR
32C	CTs/HRSG MCC
32D	• WATER TREATMENT MCC
32E	• FIN FAN MCC
33	MAIN TRANSFORMER
34	AUXILIARY TRANSFORMER
34A	CTG GENERATOR CIRCUIT BREAKER
34B	STEAM TURBINE GENERATOR CIRCUIT BREAKER
34C	ISOLATION TRANSFORMER
34D	START-UP HEATER TRANSFORMER
34E	BACK-UP POWER FEED TRANSFORMER
34F	EXCITATION TRANSFORMER
34G	FUEL GAS ELECTRIC HEATER TRANSFORMERS
35	• GAS INSULATED SWITCHGEAR (GIS) SWITCHYARD BUILDING
36	ISOPHASE BUS DUCT
37	• EMERGENCY DIESEL GENERATOR
41	COMBUSTION TURBINE INLET FILTER
44	• CONTINUOUS EMISSIONS MONITORING (CEMS)
46A	UNIT 1 STACK
46B	UNIT 2 STACK
46C	UNIT 3 STACK
47	SELECTIVE CATALYTIC REDUCTION (SCR) SKID
47A	• AMMONIA STORAGE TANK & FORWARDING PUMPS
47B	• AMMONIA UNLOADING AREA
50	LAYDOWN AREA
60	• FUEL GAS HEATING AND PRESSURE REDUCING STATION
62	FUEL GAS PREHEATER
62A	FUEL GAS ELECTRIC STARTUP HEATER
62B	• FUEL GAS METERING STATION (BY OWNER)
65	• HYDROGEN TUBE TRAILERS
71	• WATER TREATMENT BUILDING
71A	• WATER TREATMENT BUILDING LAB
72	AIR COOLED CONDENSER (ACC)
72A	ACC DRAIN POT AND PUMPS
72B	STEAM JET AIR EJECTOR (SJAE)
73	• FIN FAN COOLER
75	• DIESEL/ELECTRIC FIRE PUMP HOUSE
76	• SERVICE/FIRE WATER STORAGE TANK
76A	• POTABLE WATER STORAGE TANK
76B	• DEMINERALIZED WATER STORAGE TANK
76C	• WASTE WATER COLLECTION TANK
76D	CONDENSATE EXTRACTION TANK
76E	• RO CONCENTRATE COLLECTION TANK
77	• STORM WATER MANAGEMENT COLLECTION POND
77A	• RAIN CAPTURE SUMP
77B	• OIL/WATER SEPARATOR
77C	POWER BLOCK AREA SUMP
77D	• BIO RETENTION POND
81	• ADMINISTRATION/CONTROL ROOM BUILDING
82	• TEMPORARY CRAFT CHANGE HOUSE / FUTURE OWNER'S STORAGE FACILITY
91	• LEACH FIELD
91A	• PUMP CHAMBER
91B	• SEPTIC TANK
92	ACC TRANSFORMERS
93	ACC MECHANICAL BUILDING
94	WATER MIST SKID
95	FUEL GAS ABSOLUTE SEPARATOR
96	FILTER DRAIN TANK
97	FUEL GAS SCRUBBER
98	ELE. ROOM VENTILATION FAN
99A	• FUEL GAS FILTER SEPARATOR
99B	• FUEL GAS DRAIN TANK

• DENOTES EQUIPMENT IS COMMON/SERVICES ALL UNITS

LEGEND

- GRAVEL ROAD
- LIMIT OF DISTURBANCE (LOD)
- FENCELINE



WIND ROSE
PREDOMINANT WIND DIRECTION JUNE - JULY- AUGUST

NO.	DATE	REVISIONS	BY	CHK	DES. SUPV.	ENGR	PROJ ENGR	APPR
2	04/17/20	REVISED AS NOTED & RE-ISSUED FOR USE	ND	SS	RCB	–	RG	–
1	02/14/18	REVISED TO INCORPORATE OWNER'S COMMENTS AND AS NOTED	DPP	SS	RCB	–	UG	–
0	05/01/17	ISSUED FOR USE	CAM	JJS	JCL	–	PK	–

SCALE AS NOTED | DATE | DESIGNED | DRAWN | CHIEF ENGR.

BECHTEL ASSOCIATES PROFESSIONAL CORP

CRICKET VALLEY ENERGY CENTER

PLOT PLAN

JOB NO.	DRAWING NO.	REV.
26068-000	P1-0010-00001	002


34"X44" E SIZE

PSC=


CONFIDENTIAL. © 2017, 2018, 2019,2020 BECHTEL INFRASTRUCTURE AND POWER CORPORATION (BECHTEL). THIS DOCUMENT, PREPARED UNDER CONTRACT 26068 BETWEEN BECHTEL AND CRICKET VALLEY ENERGY CENTER, LLC, CONTAINS INFORMATION CONFIDENTIAL AND/OR PROPRIETARY TO BECHTEL THAT IS NOT TO BE USED, DISCLOSED, REPRODUCED IN ANY FORM, OR RELIED UPON BY ANY PERSON OR ENTITY OTHER THAN BECHTEL OR CRICKET VALLEY ENERGY CENTER, LLC, FOR THIS PROJECT OTHER THAN AS PROVIDED IN AN AGREEMENT WITH BECHTEL OR A BECHTEL AFFILIATE SPECIFIC TO THIS PROJECT OR WITH BECHTEL'S PRIOR WRITTEN PERMISSION. ALL RIGHTS RESERVED.

APPENDIX D: PROCESS FLOW DIAGRAMS


COMBUSTION TURBINE and DUCT BURNERS #1– PROCESS FLOW DIAGRAM




COMBUSTION TURBINE and DUCT BURNERS #2– PROCESS FLOW DIAGRAM




COMBUSTION TURBINE and DUCT BURNERS #3– PROCESS FLOW DIAGRAM




AUXILIARY BOILER – PROCESS FLOW DIAGRAM



EMERGENCY DIESEL GENERATOR – PROCESS FLOW DIAGRAM



EMERGENCY DIESEL FIRE PUMP ENGINE – PROCESS FLOW DIAGRAM



APPENDIX E: METHODS USED TO DETERMINE COMPLIANCE

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Facility Wide	Permit Condition 1, 6 NYCRR 200.6	An ambient air quality impact analysis was submitted with the application for Permit ID 3-1326-00275/00009 to demonstrate compliance with the applicable ambient air quality standards.	02/03/2016
Facility Wide	Permit Condition 2, 6 NYCRR 201-6.4 (a) (7)	CVEC has paid all fees consistent with the fee schedule authorized by ECL 72-0303.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 3, 6 NYCRR 201-6.4 (c)	CVEC includes the following information in any required compliance monitoring records and reports: (i) The date, place, and time of sampling or measurements; (ii) The date(s) analyses were performed; (iii)The company or entity that performed the analyses; (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required; (v) The results of such analyses including quality assurance data where required; and (vi) The operating conditions as existing at the time of sampling or measurement. Any deviation from permit requirements is clearly identified in all records and reports. Reports are certified by a responsible official, consistent with Section 201-6.2 of Part 201.	As of the date of each monitoring record and report.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Facility Wide	Permit Condition 4, 6 NYCRR 201-6.4 (c) (2)	Compliance monitoring and recordkeeping is conducted according to the terms and conditions contained in Permit ID 3-1326-00275/00009 and follows all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information are retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. All supporting information including all calibration and maintenance records and all original data recordings for continuous monitoring instrumentation, and copies of all reports as required by the permit.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 5, 6 NYCRR 201-6.4 (c) (3) (ii)	CVEC submits a compliance monitoring report every 6 months no later than each January 30th and July 30th and contains all information required under 6 NYCRR 201-6.4 (c). Each report identifies all instances of deviations from permit requirements and are certified by the responsible official. The reports state the probable cause of any deviations and any corrective actions or preventive measures taken. Deviation reports are submitted in accordance with the time frame of the applicable requirement or the time frame under Permit Condition 5, Item 5.2, as applicable.	As of the date of the most recent report.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Facility Wide	Permit Condition 6, 6 NYCRR 201-6.4 (e)	CVEC submits an annual compliance certification report no later than each January 30th and contains all information required under 6 NYCRR 201-6.4 (e) and Permit Condition 6, Item 6.2.	As of the date of the most recent compliance certification report.
Facility Wide	Permit Condition 7, 6 NYCRR 202-2.1	CVEC submits an annual emission statement by no later than April 15th each year.	As of the date of the most recent emission statement report.
Facility Wide	Permit Condition 8, 6 NYCRR 202-2.5	CVEC maintains the following records at the facility and these will be made available to representatives of the department upon request during normal business hours. These records will be maintained for at least five years. (1) a copy of each emission statement submitted to the department; and (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.	As of the date of the most recent emission statement report.
Facility Wide	Permit Condition 9, 6 NYCRR 215.2	Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire. CVEC does no allow open fires at the facility.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 10, 6 NYCRR 200.7	CVEC operates and maintains all emission control equipment on emission units U-00001, U-00002, and U-00003 in accordance with industry practices, standards and procedures, inclusive of manufacturer's specifications.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 11, 6 NYCRR 201-1.7	CVEC does not operate any air cleaning devices that collect air contaminants and therefore this requirement is not applicable.	Not Applicable
Facility Wide	Permit Condition 12, 6 NYCRR 201-1.8	CVEC does not operate any air cleaning devices that collect air contaminants and therefore this requirement is not applicable.	Not Applicable
Facility Wide	Permit Condition 13, 6 NYCRR 201-3.2 (a)	CVEC certifies that all Exempt Activities identified in this application are operated and meet the specific criteria for exemption. Records will be maintained on-site for 5 years to verify compliance.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 14, 6 NYCRR 201-3.3 (a)	CVEC certifies that all Trivial Activities, as defined under NYCRR identified in 6 NYCRR 201-3.3 (c), that are performed at the facility meet the specific criteria for a Trivial Activity. Records will be maintained on-site for 5 years to verify compliance.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Facility Wide	Permit Condition 15, 6 NYCRR 201-6.4 (a) (4)	CVEC will upon request furnish to the department in a reasonable time any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. CVEC will also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.	As of the date of certification of this renewal application, the department has not requested any information of this nature.
Facility Wide	Permit Condition 16, 6 NYCRR 201-6.4 (a) (8)	CVEC shall allow the department or an authorized representative to: (i) enter upon the premises or where permit records are kept; (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit; (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 17, 6 NYCRR 201-6.4 (f) (6)	CVEC will provide written notice a minimum of seven days in advance of any changes that contravene an express permit term, provided that such changes would not violate applicable requirements and are not a modification.	CVEC has not made any changes meeting these criteria.
Facility Wide	Permit Condition 18, 6 NYCRR 202-1.1	CVEC will complete emissions testing requested by the department for the purposes of demonstrating compliance with an applicable requirement.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 19, 40 CFR Part 68	CVEC does not have a chemical listed in Tables 1,2,3 or 4 of 40 CFR §68.130 at a quantity greater than the threshold quantity listed in Tables 1,2,3 or 4,	Not Applicable
Facility Wide	Permit Condition 20, 40 CFR 82, Subpart F	CVEC complies with all applicable provisions of 40 CFR Part 82.	As of the date of certification of this renewal application.
Emission Units U-00004 and U-00005	Permit Condition 1-2, 6 NYCRR 200.1 (cq)	The emergency generator and the emergency fire pump engine have been operated less than 500 hours of operation per year per engine, rolled monthly, and CVEC maintains records on site tracking the hours of operation, rolling the hours monthly.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 22, 6 NYCRR 200.7	CVEC maintains records to verify concentration of ammonia stored on-site is equal to or less than 19% by weight. Records of vendor certifications or analyses per delivery are used to verify concentration.	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 23, 6 NYCRR 200.7	CVEC operates continuous emissions monitoring systems (CEMS) to verify that the ammonia concentration in the exhaust is 5.0 parts per million by volume dry basis corrected to 15% oxygen (ppmvdc) during all turbine loads, all fuels being fired, and all duct burner operations. Reports of the CEMS data are submitted quarterly.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Units U-00001, U-00002, and U-00003	Permit Condition 24, 6 NYCRR 201-1.4 (a)	CVEC monitors all occurrences of start-up and shut-down from the combustion turbines including duration of start-up and shut-down and total pounds of emissions of NOx, CO and NH3 monitored by a CEMS. The facility recorded its 15th startup and 15th shutdown on approximately March 22, 2020 and submitted a letter on May 20, 2020 with proposed start-up and shut-down limits to the Department for approval.	May 20, 2020
Emission Unit U-00001	Permit Condition 25, Item 25.1. 6 NYCRR 201-6	This emission unit consists of one natural gas fired GE Model 7F.05 combustion turbine generator (CTG), one heat recovery steam generator (HRSG) with supplemental natural gas firing, and one natural gas fired auxiliary boiler. The CTG, HRSG, and auxiliary boiler are exhausted through a common stack.	As of the date of certification of this renewal application.
Emission Unit U-00002	Permit Condition 25, Item 25.2. 6 NYCRR 201-6	This emission unit consists of one natural gas fired GE Model 7F.05 CTG and one HRSG with supplemental natural gas firing exhausted through a common stack.	As of the date of certification of this renewal application.
Emission Unit U-00003	Permit Condition 25, Item 25.3. 6 NYCRR 201-6	This emission unit consists of one natural gas fired GE Model 7F.05 CTG and one HRSG with supplemental natural gas firing exhausted through a common stack.	As of the date of certification of this renewal application.
Emission Unit U-00004	Permit Condition 25, Item 25.4. 6 NYCRR 201-6	This emission unit consists of one 260 horsepower emergency diesel-fired fire pump engine.	As of the date of certification of this renewal application.
Emission Unit U-00005	Permit Condition 25, Item 25.5. 6 NYCRR 201-6	This emission unit consists of one 1,500 kW electrical (1,645 mechanical) diesel fired emergency generator engine.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 26, 6 NYCRR 201-6.4(d)(4)	CVEC is not subject to any schedule of compliance and therefore semi-annual compliance reports are not required.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 27, 6 NYCRR 202-1.2	No less than 30 days prior to an emission test required by applicable requirement or requested by the department, CVEC will submit written notification to the department of the time and date of the test, the acceptable procedures to be used to stack test, including sampling and analytical procedures. CVEC will allow the commissioner, or his representative, free access to observe the stack testing identified in the notification.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 28, 6 NYCRR 202-2.3	All emission statements required by Permit Condition 7 and 6 NYCRR 202-2.1 will include all information listed in Item 28.1 of Permit Condition 28.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 29, 6 NYCRR 202-2.4	All emission statements required by Permit Condition 7 and 6 NYCRR 202-2.1 will by submitted no later than April 30th each year and include all information listed in Item 29.1 of Permit Condition 29.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Facility Wide	Permit Condition 30, 6 NYCRR 211.1	CVEC will not cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 31, 6 NYCRR 225-1.2 (g)	CVEC will only fire distillate oil with a sulfur content no greater than 0.0015 percent sulfur in any stationary combustion installation at the facility. Records of vendor certifications or analyses per delivery are used to verify concentration.	As of the date of certification of this renewal application.
Facility Wide	Permit Condition 32, 6 NYCRR 225-1.2 (h)	CVEC will only fire distillate oil with a sulfur content no greater than 0.0015 percent sulfur in any stationary combustion installation at the facility. Records of vendor certifications or analyses per delivery are used to verify concentration.	As of the date of certification of this renewal application.
Emission Units U-00004 and U-00005	Permit Condition 1-3, 6 NYCRR 227-1.3	The emergency fire pump engine and emergency generator engine are operated and maintained in accordance with manufacturer specifications to ensure that emissions of opacity do not exceed 20 percent opacity (six minute average), except for one six-minute period per hour of not more than 27 percent opacity. When the emergency generator and fire pump engine are operating, their stacks are observed to ensure that visible emissions do not exceed the limit. CVEC will take corrective actions, as necessary, and will record and maintain these corrective actions on site for Department review.	No corrective actions have been required as of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 1-4, 6 NYCRR 227-1.3(a)	CVEC operates the CTGs, duct burners, and auxiliary boiler to ensure that emissions of opacity do not exceed 20 percent opacity (six minute average), except for one six-minute period per hour of not more than 27 percent opacity. The facility shall conduct performance tests on the combustion turbines, associated duct burners, and the auxiliary boiler operating in conjunction to verify compliance.	Performance tests were completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003) and verified compliance with the applicable opacity limits
Facility Wide	Permit Condition 1-5, 6 NYCRR 231-5.3	The facility maintains rolling 12-month records from emission units U-00001, U-00002, U-00003, U-00004, and U-00005 to verify that facility-wide emissions of NOx and VOC are no greater than 251.4 tons per year (tpy) and 95.4 tpy, respectively.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 1-6, 6 NYCRR 231-5.4	CVEC maintains a NOx emission limit of 2.0 ppmvdc (with and without duct burning) to satisfy LAER. Emissions are controlled through the application of DLN burners in combination with Selective Catalytic Reduction (SCR). This limit applies at all load conditions except start-up and shutdown. CVEC operates CEMS to verify compliance with the NOx emissions limit.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Units U-00001, U-00002, and U-00003	Permit Condition 36, 6 NYCRR 231-5.4	To satisfy LAER requirements, CVEC operates each CTG and associated duct burner to limit the VOC emission rate to no greater than of 0.7 ppmvdc, without duct firing. This emission limit applies at all operating loads, except during startup and shutdown, and is achieved through good combustion practices and an oxidation catalyst. Stack testing will be conducted to demonstrate compliance with these limits.	Performance tests were completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003) and verified compliance with the applicable VOC limit.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 37, 6 NYCRR 231-5.4	To satisfy LAER requirements, CVEC operates each CTG and associated duct burner to limit the VOC emission rate to no greater than of 1.8 ppmvdc, with duct firing. This emission limit applies at all operating loads, except during startup and shutdown, and is achieved through good combustion practices and an oxidation catalyst. Stack testing will be conducted to demonstrate compliance with these limits.	Performance tests were completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003) and verified compliance with the applicable VOC limit.
Facility Wide	Permit Condition 1-7, 6 NYCRR 231-5.5	CVEC obtained 136 tons of VOC emission reduction credits in accordance with Part 231-5.2(d) from the 3M Bristol facility (PA_DEC ID#: PADEP 09-00005) to offset the facility's potential to emit VOCs of 95.4 tons per year at a ratio of 1.15 to 1.	Completed and verified prior to issuance of the Title V permit on 02/03/16.
Facility Wide	Permit Condition 1-8, 6 NYCRR 231-5.5	CVEC obtained 322.11 tons of NOx emission reduction credits in accordance with Part 231-5.2(d) from these facilities: Norbord Industries, Inc. DEC ID# 4-1230-00019, 178.24 tpy; Georgia-Pacific Consumer Operations LLC, DEC ID# 5-0913-00004, 142.87 tpy; and EastRiver Housing Corporation, DEC ID# 2-6206-00096, 1.0 tpy. These offset the facility's potential to emit NOx of 251.4 tons per year at a ratio of 1.15 to 1.	Completed and verified prior to issuance of the Title V permit on 02/03/16.
Facility Wide	Permit Condition 1-9, 6 NYCRR 231-7.5	CVEC operates Emission Units U-00001, U-00002, U-00003, U-00004 and U-00005 to limit Facility-wide PTE to 296.3 tpy of CO, 174.1 tpy of PM2.5, 174.1 tpy of PM10, 19.7 tpy of H2SO4, and 3,593,609 tpy CO2e to satisfy BACT. Records of monthly and rolling 12-month emissions are kept to verify compliance.	As of the date of certification of this renewal application.
Emission Unit U-00004	Permit Condition 1-10, 6 NYCRR 231-7.6	CVEC maintain records of monthly and rolling 12-month operating hours to verify compliance with the emergency fire pump engine greenhouse gas emissions limit of 74 tpy. Monthly and rolling 12-month emissions are calculated based upon operating hours, the rated firing rate of the engine, and the emission factors published in 40 CFR Part 98, Subpart C, Tables C-1 and C-2 for CO2 and CH4/N2O, respectively and the global warming potentials published in in 40 CFR Part 98, Subpart A, Table A-1.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance			
Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Unit U-00005	Permit Condition 1-11, 6 NYCRR 231-7.6	CVEC maintain records of monthly and rolling 12-month operating hours to verify compliance with the emergency generator engine greenhouse gas emissions limit of 595 tpy. Monthly and rolling 12-month emissions are calculated based upon operating hours, the rated firing rate of the engine, and the emission factors published in 40 CFR Part 98, Subpart C, Tables C-1 and C-2 for CO2 and CH4/N2O, respectively and the global warming potentials published in in 40 CFR Part 98, Subpart A, Table A-1.	As of the date of certification of this renewal application.
Emission Unit U-00005	Permit Condition 1-12, 6 NYCRR 231-7.6	CVEC maintain records of diesel sulfur content at or below 0.0015 percent to verify compliance with the emergency generator engine sulfuric acid emissions limit of 0.0001 lb/MMBtu. Fuel sulfur records are kept in accordance with Permit Conditions 31 and 32.	As of the date of certification of this renewal application.
Emission Unit U-00004	Permit Condition 1-13, 6 NYCRR 231-7.6	CVEC maintain records of diesel sulfur content at or below 0.0015 percent to verify compliance with the emergency fire pump engine sulfuric acid emissions limit of 0.0001 lb/MMBtu. Fuel sulfur records are kept in accordance with Permit Conditions 31 and 32. This application requests a correction of the permit language for Condition 1-13 as the current language is redundant with Condition 42 and does not reflect firing of diesel fuel in U-00004.	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 42, 6 NYCRR 231-7.6	CVEC maintain records of natural sulfur content at or below 0.4 grains per 100 dry standard cubic feet of natural gas to verify compliance with the combustion turbine sulfuric acid emissions limit of 0.00065 lb/MMBtu. Fuel sulfur records are kept in accordance with 40 CFR 75, App. D, Sect. 2.3 and through certification or analysis provided by the natural gas supplier.	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 43, 6 NYCRR 231-7.6	CVEC completed performance testing within 180 days of startup that verified compliance with the sulfuric acid emissions limit of 0.00065 lb/MMBtu for each emission unit.	Performance tests were completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003) and verified compliance with the applicable sulfuric acid limit.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 44, 6 NYCRR 231-7.6	CVEC completed performance testing within 180 days of startup that verified compliance with the particulate emission rate limit of 0.006 lb/mmBtu, with duct firing, for each emission unit.	Performance tests were completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003) and verified compliance with the applicable sulfuric acid limit.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Units U-00001, U-00002, and U-00003	Permit Condition 45, 6 NYCRR 231-7.6	CVEC completed performance testing within 180 days of startup that verified compliance with the particulate emission rate limit of 0.005 lb/mmBtu, without duct firing, for each emission unit.	Performance tests were completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003) and verified compliance with the applicable sulfuric acid limit.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 46, 6 NYCRR 231-7.6	CVEC operates 40 CFR 60, Appendices B and F, compliant CEMS on each unit to verify that the CO emissions, with and without duct firing, are at or below 2.0 ppmvdc on a 1-hour average. Reports of the CEMS data are submitted quarterly.	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 47, 6 NYCRR 231-7.6	Within 90 days of start-up of the facility and on an annual basis thereafter, CVEC will conduct a Department-approved heat rate performance test on each combined cycle unit while it is operating at maximum load to verify that the heat rate of each combined cycle combustion turbine will not exceed a heat rate of 7,604 Btu/kW-hr HHV net basis, without duct firing, for full load at ISO conditions.	The most recent heat rate performance test was completed on 04/14/20 (U-00003)
Emission Units U-00001, U-00002, and U-00003	Permit Condition 48, 40 CFR 60.4, Subpart A	All requests, reports, applications, submittals, and other communications to the Administrator pursuant to 40 CFR 60, Subpart A for the combustion turbines, duct burners, and auxiliary boiler will be submitted in duplicate to the following address: Director, Division of Enforcement and Compliance Assistance USEPA Region 2 290 Broadway, 21st Floor New York, NY 10007-1886 Copies of all correspondence to the Administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address: NYSDEC Bureau of Quality Assurance 625 Broadway Albany, NY 12233-3258	CVEC has completed all notifications and performance testing required under 40 CFR 60, Subparts A, Dc, and KKKK. Semi-annual reports of excess emissions and CEMS monitor downtime are submitted in accordance with §60.7(c).
Emission Units U-00001, U-00002, and U-00003	Permit Condition 49, 40 CFR 60.7(a)(1), Subpart A	CVEC submitted notification of the date construction for each subject emission unit within 30 days from commencement as follows: U-00001, P01 (CTG and duct burner): 12/14/2017 U-00001, P02 (auxiliary boiler): 10/17/2018 U-00002, P04 (CTG and duct burner): 02/22/2018 U-00003, P05 (CTG and duct burner): 03/27/2018	See description.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Units U-00001, U-00002, and U-00003	Permit Condition 50, 40 CFR 60.7(b), Subpart A	CVEC maintains records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of the combined cycle combustion turbines and auxiliary boiler; any malfunction of the air pollution control equipment; and periods during which a CEMS or monitoring device is inoperative.	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 51, 40 CFR 60.7(f), Subpart A	CVEC will keep records of all measurements, including CEMS, monitoring devices, and performance testing measurements; all CEMS performance evaluations; all continuous monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. CVEC shall maintain these records for at least two years following the date of such measurements, reports, and records.	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 52, 40 CFR 60.8(b), Subpart A	All performance testing that has been conducted on the combustion turbines and duct burners was completed in accordance with a pretest protocol submitted to the Administrator in advance of the testing, which defined the methods and procedures prescribed in 40 CFR 60 Subparts A and KKKK.	The pretest protocol is dated 06/24/2019
Emission Units U-00001, U-00002, and U-00003	Permit Condition 53, 40 CFR 60.8(d), Subpart A	CVEC notified the Administrator by letter more than 30 days in advance of the performance testing that has been conducted on the combustion turbines and duct burners.	Test notification dated 09/30/2019
Emission Units U-00001, U-00002, and U-00003	Permit Condition 54, 40 CFR 60.8(e), Subpart A	The exhaust stacks on Emission Units U-00001, U-00002, and U-00003 are equipped with sampling ports adequate for applicable test methods; a safe sampling platform; safe access to the sampling platform; and utilities for sampling and testing equipment.	Initial performance testing completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003)
Emission Units U-00001, U-00002, and U-00003	Permit Condition 55, 40 CFR 60.8(f), Subpart A	The initial performance testing for NOx emissions from the combustion turbines and duct burners consisted of three separate 1-hour test runs.	Initial performance testing completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003)
Emission Units U-00001, U-00002, and U-00003	Permit Condition 56, 40 CFR 60.13, Subpart A	The NOx CEMS installed on the combustion turbines and duct burners are installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.	Initial CEMS performance testing completed on 03/06/20 (U-00001), 03/11/20 (U-00002), and 04/17/20 (U-00003)
Emission Units U-00004 and U-00005	Permit Condition 1-14, 40 CFR 60, Subpart IIII	CVEC installed, operates, and maintains the emergency fire pump engine and emergency generator engine in accordance with 40 CFR 60, Subpart IIII.	As of the date of certification of this renewal application.

DEC ID
3-1326-00275

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Unit U-00005	Permit Condition 1-15, 40 CFR 60.4205(b), Subpart IIII	The emergency generator engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a PM emission rate of 0.15 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with these federal limits is also considered BACT. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HCPXL78.1NZS-016 issued by USEPA to Caterpillar Inc. on 07/29/2016.
Emission Unit U-00005	Permit Condition 1-16, 40 CFR 60.4205(b), Subpart IIII	The emergency generator engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a NOx + HC emission rate of 4.8 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with these federal limits is also considered LAER. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HCPXL78.1NZS-016 issued by USEPA to Caterpillar Inc. on 07/29/2016.
Emission Unit U-00005	Permit Condition 1-17, 40 CFR 60.4205(b), Subpart IIII	The emergency generator engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a CO emission rate of 2.6 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with these federal limits is also considered BACT. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HCPXL78.1NZS-016 issued by USEPA to Caterpillar Inc. on 07/29/2016.
Emission Unit U-00005	Permit Condition 1-18, 40 CFR 60.4205(b), Subpart IIII	The emergency generator engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a NOx + HC emission rate of 4.8 g/hp-hr in accordance with 40 CFR 60.4202(b)(2) and 40 CFR 89.112(a), Table 1. Compliance with these federal limits is also considered LAER. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HCPXL78.1NZS-016 issued by USEPA to Caterpillar Inc. on 07/29/2016.
Emission Unit U-00004	Permit Condition 1-19, 40 CFR 60.4205(c), Subpart IIII	The emergency fire pump engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a CO emission rate of 2.6 g/hp-hr in accordance with Table 4 of 40 CFR 60, Subpart IIII. Compliance with these federal limits is also considered BACT. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HJDXL13.5103-011 issued by USEPA to Deere & Company on 08/04/2016.
Emission Unit U-00004	Permit Condition 1-20, 40 CFR 60.4205(c), Subpart IIII	The emergency generator engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a NOx + HC emission rate of 3.0 g/hp-hr in accordance with Table 4 of 40 CFR 60, Subpart IIII. Compliance with these federal limits is also considered LAER. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HJDXL13.5103-011 issued by USEPA to Deere & Company on 08/04/2016.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Unit U-00004	Permit Condition 1-21, 40 CFR 60.4205(c), Subpart IIII	The emergency generator engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a NOx + HC emission rate of 3.0 g/hp-hr in accordance with Table 4 of 40 CFR 60, Subpart IIII. Compliance with these federal limits is also considered LAER. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HJDXL13.5103-011 issued by USEPA to Deere & Company on 08/04/2016.
Emission Unit U-00004	Permit Condition 1-22, 40 CFR 60.4205(c), Subpart IIII	The emergency generator engine has been certified by the manufacturer to meet the federal emission standards under 40 CFR 60 Subpart IIII for the current model years. Thus, the engine will maintain a particulate matter emission rate of 0.15 g/hp-hr in accordance with Table 4 of 40 CFR 60, Subpart IIII. Compliance with these federal limits is also considered BACT. Compliance is demonstrated via certification by the vendor and adherence to vendor specified maintenance recommendations.	Certificate Number HJDXL13.5103-011 issued by USEPA to Deere & Company on 08/04/2016.
Emission Unit U-00005	Permit Condition 1-23, 40 CFR 60.4207(b), Subpart IIII	The emergency generator engine meets an SO2 emission limit of 0.0015 lb/MMBtu by only combusting diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight in accordance with 40 CFR 80.510(b)(1)(i). Records of vendor certifications or analyses per diesel delivery are used to verify sulfur concentration.	As of the date of certification of this renewal application.
Emission Unit U-00004	Permit Condition 1-24, 40 CFR 60.4207(b), Subpart IIII	The emergency generator engine meets an SO2 emission limit of 0.0015 lb/MMBtu by only combusting diesel fuel with a maximum sulfur content of 0.0015 percent sulfur by weight in accordance with 40 CFR 80.510(b)(1)(i). Records of vendor certifications or analyses per diesel delivery are used to verify sulfur concentration.	As of the date of certification of this renewal application.
Emission Units U-00004 and U-00005	Permit Condition 59, 40 CFR 60.4211(a), Subpart IIII	CVEC complies with the emission standards specified in 40 CFR 60 Subpart IIII and does all of the following: (1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions; (2) Change only those emission-related settings that are permitted by the manufacturer; and (3) Meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply.	As of the date of certification of this renewal application.
Emission Units U-00004 and U-00005	Permit Condition 60, 40 CFR 60.4211(c), Subpart IIII	The emergency generator engine complies with the emission standards specified in §60.4205(b) and the emergency fire pump engine complies with the emission standards specified in §60.4205(c). Certificate Numbers HCPXL78.1NZS-016 and HCPXL78.1NZS-016 were issued by the USEPA for the emergency generator engine and emergency fire pump engine, respectively, to certify compliance with the applicable standards. The engines are installed and configured according to the manufacturer's specifications. CVEC provided a copy of the manufacturer's certification of compliance with the emission standards specified in 40 CFR 60 Subpart IIII with the application submitted in January 2018 for Modification 2 of Permit ID 3-1326-00275/00009 issued on March 23, 2018.	January 2018

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Units U-00001, U-00002, and U-00003	Permit Condition 61, 40 CFR 72	CVEC is subject to the Title IV Acid Rain Regulations found in 40 CFR Parts 72, 73, 75, 76, 77 and 78. The Acid Rain Permit is an attachment to this permit. An Acid Rain permit renewal application is included with this Title V operating permit renewal application	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 62, 40CFR 97.406, Subpart AAAAA	CVEC complies has designated representative, Marc Duquette, in accordance with §97.413 through 97.418 of Subpart AAAAA. Marc Duquette is also the Title V Responsible Official and his contact information is provided with this renewal application. CVEC shall notify the Department of any changes made to the representative (or alternative) or their contact information. CVEC operates Emission Units U-00001, U-00002, and U-00003 to comply with the monitoring, reporting, and recordkeeping requirements of §§97.430 through 97.435 of Subpart AAAAA and 40 CFR 75, Subpart H. CEMS emission reports are submitted quarterly. The CEMS emissions data is used to calculate allocations of TR NOx Annual allowances and to determine compliance with the TR NOx Annual emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, CVEC shall hold in the facility's compliance account, TR NOx Annual allowances available for deduction for such control period under §97.424(a) in an amount not less than the tons of total NOx emissions for such control period from Emission Units U-00001 (P01), U-00002 (P04), and U-00003 (P05). CVEC has prepared a Monitoring Plan in accordance with §97.434(b) and §75.73(c) and (e) documenting the emissions monitoring systems and procedures.	As of the date of certification of this renewal application.
Emission Units U-00001, U-00002, and U-00003	Permit Condition 63, 40CFR 97.506, Subpart BBBBB	CVEC complies has designated representative, Marc Duquette, in accordance with §97.513 through 97.518 of Subpart BBBBB. Marc Duquette is also the Title V Responsible Official and his contact information is provided with this renewal application. CVEC shall notify the Department of any changes made to the representative (or alternative) or their contact information. CVEC operates Emission Units U-00001, U-00002, and U-00003 to comply with the monitoring, reporting, and recordkeeping requirements of §97.530 through 97.535 of Subpart BBBBB and 40 CFR 75, Subpart H. CEMS emission reports are submitted quarterly. The CEMS emissions data is used to calculate allocations of TR NOx Ozone Season allowances and to determine compliance with the TR NOx Ozone Season emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, CVEC shall hold in the facility's compliance account, TR NOx Ozone Season allowances available for deduction for such control period under §97.524(a) in an amount not less than the tons of total NOx Ozone Season emissions for such control period from Emission Units U-00001 (P01), U-00002 (P04), and U-00003 (P05). CVEC has prepared a Monitoring Plan in accordance with §97.534(b) and §75.73(c) and (e) documenting the emissions monitoring systems and procedures.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Units U-00001, U-00002, and U-00003	Permit Condition 64, 40CFR 97.606, Subpart CCCCC	CVEC complies has designated representative, Marc Duquette, in accordance with §97.613 through 96.518 of Subpart CCCCC. Marc Duquette is also the Title V Responsible Official and his contact information is provided with this renewal application. CVEC shall notify the Department of any changes made to the representative (or alternative) or their contact information. CVEC operates Emission Units U-00001, U-00002, and U-00003 to comply with the monitoring, reporting, and recordkeeping requirements of §97.630 through 97.635 of Subpart CCCCC and 40 CFR 75, Subpart H. CEMS emission reports are submitted quarterly. The CEMS emissions data is used to calculate allocations of TR SO2 Group 1 allowances and to determine compliance with the TR SO2 Group 1 emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, CVEC shall hold in the facility's compliance account, TR SO2 Group 1 allowances available for deduction for such control period under §97.624(a) in an amount not less than the tons of total SO2 Group 1 emissions for such control period from Emission Units U-00001 (P01), U-00002 (P04), and U-00003 (P05). CVEC has prepared a Monitoring Plan in accordance with §97.634(b) and §75.62 documenting the emissions monitoring systems and procedures.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 65, Item 65.1, 6 NYCRR 201-6	The exhaust stack has a Height of 283 feet and an exit Diameter of 228 inches and is located at NYTMN (km.): 4614.8 and NYTME (km.): 618.142.	As of the date of certification of this renewal application.
Emission Unit U-00004	Permit Condition 65, Item 65.2, 6 NYCRR 201-6	The exhaust stack has a Height of 14 feet and an exit Diameter of 6 inches and is located at NYTMN (km.): 4614.954 and NYTME (km.): 618.216.	As of the date of certification of this renewal application.
Emission Unit U-00005	Permit Condition 65, Item 65.3, 6 NYCRR 201-6	The exhaust stack has a Height of 14 feet and an exit Diameter of 18 inches and is located at NYTMN (km.): 4614.773 and NYTME (km.): 618.217.	As of the date of certification of this renewal application.
Emission Unit U-00002	Permit Condition 65, Item 65.4, 6 NYCRR 201-6	The exhaust stack has a Height of 283 feet and an exit Diameter of 228 inches and is located at NYTMN (km.): 4614.792 and NYTME (km.): 618.15.	As of the date of certification of this renewal application.
Emission Unit U-00003	Permit Condition 65, Item 65.5, 6 NYCRR 201-6	The exhaust stack has a Height of 283 feet and an exit Diameter of 228 inches and is located at NYTMN (km.): 4614.792 and NYTME (km.): 618.144.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 66, Item 66.1, 6 NYCRR 201-6	Process P01 is comprised of natural gas combustion in the combustion turbine and the duct burner. Emission Source/Control: CT001 – Combustion Design Capacity: 2,395.7 million Btu per hour; DB001 – Combustion Design Capacity: 247 million Btu per hour; DLN01 – Control Type: DRY LOW NOx BURNER; OXC01 –Control Type: CATALYTIC OXIDATION; and SCR01 – Control Type: SELECTIVE CATALYTIC REDUCTION (SCR) as described in detail on the application forms.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Unit U-00001	Permit Condition 66, Item 66.2, 6 NYCRR 201-6	Process P02 is comprised of a natural gas fired auxiliary with hours of operation limited to 4500 hours per year, which equates to 270 million cubic feet of natural gas consumption per year. Emission Source/Control: AUX01 – Combustion Design Capacity: 60 million Btu per hour; FGR01 - Control Type: FLUE GAS RECIRCULATION; and LNB01 –Control Type: LOW NOx BURNER as described in detail on the application forms.	As of the date of certification of this renewal application.
Emission Unit U-00002	Permit Condition 66, Item 66.3, 6 NYCRR 201-6	Process P04 is comprised of natural gas combustion in the combustion turbine and the duct burner. Emission Source/Control: CT002 – Combustion Design Capacity: 2,395.7 million Btu per hour; DB002 – Combustion Design Capacity: 247 million Btu per hour; DLN02 – Control Type: DRY LOW NOx BURNER; OXC02 –Control Type: CATALYTIC OXIDATION; and SCR02 – Control Type: SELECTIVE CATALYTIC REDUCTION (SCR) as described in detail on the application forms.	As of the date of certification of this renewal application.
Emission Unit U-00003	Permit Condition 66, Item 66.4, 6 NYCRR 201-6	Process P05 is comprised of natural gas combustion in the combustion turbine and the duct burner. Emission Source/Control: CT003 – Combustion Design Capacity: 2,395.7 million Btu per hour; DB003 – Combustion Design Capacity: 247 million Btu per hour; DLN03 – Control Type: DRY LOW NOx BURNER; OXC03 –Control Type: CATALYTIC OXIDATION; and SCR03 – Control Type: SELECTIVE CATALYTIC REDUCTION (SCR) as described in detail on the application forms.	As of the date of certification of this renewal application.
Emission Unit U-00004	Permit Condition 66, Item 66.5, 6 NYCRR 201-6	Process P06 is comprised of diesel oil combustion in an emergency fire pump engine rated at 260 hp with operation limited to no more than 500 hours per year. Emission Source/Control: FP001 – Combustion Design Capacity: 260 horsepower (mechanical) as described in detail on the application forms.	As of the date of certification of this renewal application.
Emission Unit U-00005	Permit Condition 66, Item 66.6, 6 NYCRR 201-6	Process P07 is comprised of diesel oil combustion in an emergency generator engine rated at 2,206 hp with operation limited to no more than 500 hours per year. Emission Source/Control: FP001 – Combustion Design Capacity: 2206 horsepower (mechanical) as described in detail on the application forms.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 67, 6 NYCRR 231-5.4	CVEC operates Process P02, the auxiliary boiler, no more than 4,500 hours per rolling 12 month period. CVEC maintains records of hourly operation and natural gas consumption.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 68, 6 NYCRR 231-5.4	To satisfy LAER requirements, CVEC operates Process P02, the auxiliary boiler, to limit the VOC emission rate to no greater than 0.0015 lb/mmBtu. This emission limit applies at all operating loads, except during startup and shutdown, and is achieved through good combustion practices. Stack testing will be conducted to demonstrate compliance with these limits.	Performance test completed on 10/04/19 and verified compliance with the applicable VOC limit.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Unit U-00001	Permit Condition 69, 6 NYCRR 231-5.4	To satisfy LAER requirements, CVEC operates Process P02, the auxiliary boiler, to limit the NOx emission rate to no greater than 0.0085 lb/mmBtu. This emission limit applies at all operating loads, except during startup and shutdown, and is achieved through good combustion practices. Stack testing will be conducted to demonstrate compliance with these limits.	Performance test completed on 10/04/19 and verified compliance with the applicable NOx limit.
Emission Unit U-00001	Permit Condition 70, 6 NYCRR 231-7.6	To satisfy BACT requirements for P02, only pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 dscf will be fired in the auxiliary boiler. The natural gas fired in P02 is the same as the gas fired in P01 and compliance will be demonstrated through the records maintained for Permit Condition 42.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 71, 6 NYCRR 231-7.6	To satisfy BACT requirements for P02, only pipeline quality natural gas with a maximum sulfur content of 0.4 grains/100 dscf will be fired in the auxiliary boiler to limit sulfuric acid emissions to no more than 0.00011 lb/mmBtu. The natural gas fired in P02 is the same as the gas fired in P01 and compliance will be demonstrated through the records maintained for Permit Condition 42.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 72, 6 NYCRR 231-7.6	To satisfy BACT requirements, CVEC operates Process P02, the auxiliary boiler, to limit the particulate emission rate to no greater than 0.005 lb/mmBtu. This emission limit is achieved through good combustion practices and by firing pipeline quality natural gas as the sole fuel. Stack testing will be conducted to demonstrate compliance with these limits.	Performance test completed on 10/04/19 and verified compliance with the applicable particulate limit.
Emission Unit U-00001	Permit Condition 73, 6 NYCRR 231-7.6	To satisfy BACT requirements, CVEC operates Process P02, the auxiliary boiler, to limit the CO emission rate to no greater than 0.0375 lb/mmBtu. This emission limit is achieved through good combustion practices. Stack testing will be conducted to demonstrate compliance with these limits.	Performance test completed on 10/04/19 and verified compliance with the applicable particulate limit.
Emission Unit U-00001	Permit Condition 74, 6 NYCRR 231-7.6	To satisfy BACT and 6 NYCRR Part 251.3(a) requirements, CVEC operates Process P02, the auxiliary boiler, to limit the greenhouse gas emission rate to no greater than 119 lb/mmBtu. This emission limit is achieved through firing pipeline quality natural gas as the sole fuel and reporting emissions in accordance with 40 CFR 98, Subpart C.	As of the date of certification of this renewal application.
Emission Unit U-00001	Permit Condition 75, 40 CFR 60.48c(a)	CVEC submitted the following notifications for P02, the auxiliary boiler. The notifications includes all required information listed under 40 CFR 60.48c(a)(1) through (3): • date of construction: submitted 10/17/2018 • date of actual startup: submitted 08/29/2019	See description.
Emission Unit U-00001	Permit Condition 76, 40 CFR 60.48c(g)(2)	CVEC records the amount of natural gas fired in P02, the auxiliary boiler, on a monthly basis.	As of the date of certification of this renewal application.

DEC ID
3 - 1 3 2 6 - 0 0 2 7 5

Methods Used to Determine Compliance

Emission Unit ID	Permit Condition / Applicable Requirement	Method Used to Determine Compliance	Compliance Date
Emission Unit U-00004	Permit Condition 88, 6 NYCRR 231-7.6	CVEC maintain records of diesel sulfur content at or below 0.0015 percent to verify compliance with the emergency fire pump engine sulfuric acid emissions limit of 0.0001 lb/MMBtu. Fuel sulfur records are kept in accordance with Permit Conditions 31 and 32.	As of the date of certification of this renewal application.

APPENDIX F: EMISSION CALCULATIONS

Cricket Valley Energy Center
Summary of Facility-Wide Potential Annual Emissions

Facility-Wide Potential Annual Emissions (TPY)

Pollutant	CTGs (CT & DB) (CT001-CT003)	Auxiliary Boiler (AB01)	Emergency Generator Engine (EDG01)	Fire Pump (FP01)	Facility Total (tpy)
NO_x	244.0	1.15	5.84	0.43	251.4
CO	287.8	4.99	3.16	0.37	296.3
VOC	94.9	0.20	0.24	0.03	95.4
SO_2	37.8	0.15	0.005	0.001	38.0
PM	173.3	0.68	0.18	0.02	174.1
PM_{10}	173.3	0.68	0.18	0.02	174.1
$PM_{2.5}$	173.3	0.68	0.18	0.02	174.1
CO_2e	3,577,129	15,811	595	74	3,593,609
H_2SO_4	20	0.01	0.0004	0.00005	19.7
NH_3	225.5	N/A	N/A	N/A	225.5
Lead (Pb)	1.2E-03	6.6E-05	2.8E-06	3.5E-07	1.3E-03
Total HAPs	17.67	0.25	0.02	0.003	17.9

Cricket Valley Energy Center
Combustion Turbines (CT001-CT003) - Potential Emissions

Each turbine will operate at full rated load for 8,760 hours per year.
Duct firing will be unrestricted at 8,760 hours per year per turbine
Over the course of 8,760 operating hours, the average annual temperature will be 59°F
GE operating Case #14 correspond to full load with duct firing at 59°F

Operating Condition	CTG Load	Fuel	Ambient Temp. (°F)	Duct Firing?	Hours
GE Case #15	100%	Nat. Gas	59	Off	0
GE Case #14	100%	Nat. Gas	59	On	8,760
Total					**8,760**

PTE is the sum of the steady state PTE plus the net increase due to startup/shutdown operation

Pollutant	GE Case #14		SU/SD	PTE/CTG	PTE/3 CTGs
	lb/hr	tpy	tpy	tpy	tpy
NO_x	18.55	81.23	0.10	81.3	244.0
CO	11.29	49.46	46.46	95.9	287.8
VOC	5.82	25.49	6.15	31.6	94.9
$PM_{10}/PM_{2.5}$	13.19	57.76	0	57.8	173.3
SO_2	2.88	12.60	0	12.6	37.8
CO_2e	299,479	1,311,720	0	1,311,720	3,577,129
H_2SO_4	1.63	7.14	0	7.1	19.7
NH3	17.16	75.17	0	75.2	225.5

NOTES:
CO2e and H2SO4 emissions for three turbines capped at limit established in Permit No. 3-1326-00275/00004 issued 09/27/2012.

Cricket Valley Energy Center
Combustion Turbine Startup and Shutdown Emissions - (CT0001, CT0002, and CT0003)

Startup/Shutdown Operating Data

hot starts/unit/gas	10	number/yr	0.50	hours/event	0	Avg. hours downtime	30	minutes/event
warm starts/unit/gas	200	number/yr	0.75	hours/event	8	Avg. hours downtime	525	minutes/event
cold starts/unit/gas	50	number/yr	1.00	hours/event	72	Avg. hours downtime	4,380	minutes/event
shutdowns/unit/gas	260	number/yr	0.33	hours/event	N/A	Avg. hours downtime	20.0	minutes/event

Startup/Shutdown Emissions Self-Correcting Analysis

		Gas Start		
		NOx	**CO**	**VOC**
Hot Start Emissions	lbs/event	30.0	250.0	40.0
Warm Start Emissions	lbs/event	45.0	260.0	40.0
Cold Start Emissions	lbs/event	80.0	570.0	50.0
Shutdown Emissions	lbs/event	10.0	280.0	70.0
Shutdown/Hot start - duration (including downtime)	hrs	0.8	0.8	0.8
Shutdown/Warm start - duration (including downtime)	hrs	9.1	9.1	9.1
Shutdown/Cold start - duration (including downtime)	hrs	73.3	73.3	73.3
Shutdown/Hot start - avg hourly emissions[1]	lb/hr	43.1	531.9	111.0
Shutdown/Warm start - avg hourly emissions[1]	lb/hr	6.1	59.4	12.1
Shutdown/Cold start - avg hourly emissions[1]	lb/hr	1.2	11.6	1.6
Steady state average hourly (GE Case #14)	lb/hr	18.55	11.29	5.82
Hot start - self correcting?	lb/hr	no	no	no
Warm start - self correcting?	lb/hr	yes	no	no
Cold start - self correcting?	lb/hr	yes	no	yes
Hot Start Net increase	lb/event	20.5	433.8	87.6
Warm Start Net increase	lb/event	0.0	437.4	57.1
Cold Start Net increase	lb/event	0.0	21.9	0.0

[1] Includes balance of the hour at the steady state hourly rate (GE Case #14)

Startup/Shutdown Potential Net Emissions Increase Over Full Load Steady State Operation (tpy/unit)

SUSD Type	**NOx**	**CO**	**VOC**
Shutdown/Hot Start	0.10	2.17	0.44
Shutdown/Warm Start	-	43.74	5.71
Shutdown/Cold Start	-	0.55	-
TOTAL	**0.10**	**46.46**	**6.15**

Cricket Valley Energy Center
Potential Emissions From Ancillary Equipment

Pollutant	Auxiliary Boiler (AB01)	Emergency Generator Engine (EDG01)	Emergency Fire Pump Engine (FP01)
	60 MMBtu/hr	2206 bhp	260 bhp
NO_x	7 ppmvd @ 3% O_2	4.80 g/bhp	3.0 g/bhp
	0.008 lb/MMBtu	1.606 lb/MMBtu	0.94 lb/MMBtu
	0.51 lb/hr	23.34 lb/hr	1.72 lb/hr
	1.15 TPY	5.84 TPY	0.43 TPY
CO	50 ppmvd @ 3% O_2	2.6 g/bhp	2.6 g/bhp
	0.037 lb/MMBtu	0.870 lb/MMBtu	0.82 lb/MMBtu
	2.22 lb/hr	12.64 lb/hr	1.49 lb/hr
	4.99 TPY	3.16 TPY	0.373 TPY
VOC	3.5 ppmvd @ 3% O_2	0.20 g/bhp	0.20 g/bhp
	0.00148 lb/MMBtu	0.067 lb/MMBtu	0.063 lb/MMBtu
	0.09 lb/hr	0.97 lb/hr	0.115 lb/hr
	0.20 TPY	0.24 TPY	0.029 TPY
$PM_{10}/PM_{2.5}$	N/A ppmvd @ 3% O_2	0.15 g/bhp	0.15 g/bhp
	0.005 lb/MMBtu	0.050 lb/MMBtu	0.047 lb/MMBtu
	0.30 lb/hr	0.73 lb/hr	0.09 lb/hr
	0.68 TPY	0.18 TPY	0.021 TPY
SO_2	0.0011 lb/MMBtu	0.0015 lb/MMBtu	0.0015 lb/MMBtu
	0.07 lb/hr	0.02 lb/hr	0.0027 lb/hr
	0.15 TPY	0.005 TPY	0.0007 TPY
H_2SO_4	0.00009 lb/MMBtu	0.00011 lb/MMBtu	0.00011 lb/MMBtu
	0.005 lb/hr	0.0017 lb/hr	0.00021 lb/hr
	0.01 TPY	0.0004 TPY	0.00005 TPY
Pb	4.9E-07 lb/MMBtu	7.7E-07 lb/MMBtu	7.7E-07 lb/MMBtu
	2.9E-05 lb/hr	1.1E-05 lb/hr	1.4E-06 lb/hr
	6.6E-05 TPY	2.8E-06 TPY	3.5E-07 TPY
CO_2	117.0 lb/MMBtu	163.1 lb/MMBtu	163.1 lb/MMBtu
	7,020 lb/hr	2,371 lb/hr	297 lb/hr
	15,795 TPY	593 TPY	74 TPY
CH_4	0.0022 lb/MMBtu	0.0066 lb/MMBtu	0.0066 lb/MMBtu
	0.1323 lb/hr	0.096 lb/hr	0.012 lb/hr
	0.30 TPY	0.0240 TPY	0.0030 TPY
N_2O	0.00022 lb/MMBtu	0.0013 lb/MMBtu	0.0013 lb/MMBtu
	0.0132 lb/hr	1.9E-02 lb/hr	0.00241 lb/hr
	0.030 TPY	4.8E-03 TPY	6.0E-04 TPY
CO_2e	7,027 lb/hr	2,379 lb/hr	298 lb/hr
	15,811 TPY	595 TPY	74 TPY

NOTES:

Natural Gas SO2 emissions based upon a sulfur content of 0.4 gr/100 dscf

ULSD SO2 emissions based upon a sulfur content of 15 ppmw

Aux Boiler criteria pollutant emission factors from BACT analysis

Emergency Generator criteria pollutant emission factors based on Tier 2 emission standards in 40 CFR 89.

Fire Pump criteria pollutant emission factors based on post -2009 emission standards in 40 CFR 60 Subpart IIII.

H2SO4 emissions assume a 5% conversion of SO2 --> SO3 (on a molar basis)

Fuel specific CO2, CH4 and N2O emission factors from 40 CFR 98, Subpart C

Pb factor for NG is from AP-42 Table 1.4-2, and Pb factor for ULSD is from "Survey of Ultra-Trace Metals in Gas Turbine Fuels", 11th Annual International Petroleum Conference, Oct 12-15, 2004.

Cricket Valley Energy Center
Potential HAP Emissions

HAP	Emission Units									
	(CT0001, CT0002, and CT0003)		AB01		EDG01		FP01		Totals	
	lb/hr/unit	tpy/3 units	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
Organic Compounds										
Acetaldehyde	9.58E-02	1.23E+00			3.66E-04	9.16E-05	1.40E-03	3.49E-04	2.90E-01	1.23E+00
Acrolein	1.53E-02	1.96E-01			1.15E-04	2.86E-05	1.68E-04	4.21E-05	4.66E-02	1.96E-01
Benzene	2.93E-02	3.73E-01	1.26E-04	2.84E-04	1.13E-02	2.82E-03	1.70E-03	4.25E-04	1.35E-01	3.76E-01
1,3-Butadiene	1.03E-03	1.32E-02					7.12E-05	1.78E-05	3.16E-03	1.32E-02
Dichlorobenzene	2.96E-04	2.90E-03	7.20E-05	1.62E-04					9.61E-04	3.06E-03
Ethylbenzene	7.67E-02	9.81E-01							2.30E-01	9.81E-01
Formaldehyde	2.82E-01	3.55E+00	4.44E-03	9.99E-03	1.15E-03	2.87E-04	2.15E-03	5.37E-04	8.57E-01	3.56E+00
Hexane	4.45E-01	4.35E+00	1.08E-01	2.43E-01					1.44E+00	4.59E+00
Propylene oxide	6.95E-02	8.89E-01			5.60E-02	1.40E-02	6.48E-03	1.62E-03	4.39E-01	9.05E-01
Toluene	3.12E-01	3.99E+00	1.98E-04	4.46E-04	4.09E-03	1.02E-03	7.44E-04	1.86E-04	9.54E-01	4.00E+00
Xylene	1.53E-01	1.96E+00			2.81E-03	7.02E-04	5.19E-04	1.30E-04	4.72E-01	1.96E+00
PAHs										
Acenaphthene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	6.80E-05	1.70E-05	2.58E-06	6.46E-07	2.76E-04	2.23E-05
Acenaphthylene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	1.34E-04	3.35E-05	9.21E-06	2.30E-06	5.47E-04	4.04E-05
Anthracene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	1.79E-05	4.47E-06	3.40E-06	8.51E-07	7.64E-05	9.92E-06
Benzo(a)anthracene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	9.04E-06	2.26E-06	3.06E-06	7.64E-07	4.07E-05	7.62E-06
Benzo(a)pyrene	2.96E-07	2.90E-06	7.20E-08	1.62E-07	3.74E-06	9.34E-07	3.42E-07	8.55E-08	1.62E-05	4.08E-06
Benzo(b)fluoranthene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	1.61E-05	4.03E-06	1.80E-07	4.51E-08	6.62E-05	8.67E-06
Benzo(g,h,i)perylene	2.96E-07	2.90E-06	7.20E-08	1.62E-07	8.08E-06	2.02E-06	8.90E-07	2.22E-07	3.42E-05	5.31E-06
Benzo(k)fluoranthene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	3.17E-06	7.92E-07	2.82E-07	7.05E-08	1.44E-05	5.46E-06
Chrysene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	2.22E-05	5.56E-06	6.42E-07	1.61E-07	9.11E-05	1.03E-05
Dibenz(a,h)anthracene	2.96E-07	2.90E-06	7.20E-08	1.62E-07	5.03E-06	1.26E-06	1.06E-06	2.65E-07	2.21E-05	4.59E-06
7,12-Dimethylbenz(a) anthracene	3.95E-06	3.87E-05	9.60E-07	2.16E-06					1.28E-05	4.08E-05
Fluoranthene	7.16E-07	7.01E-06	1.74E-07	3.92E-07	5.86E-05	1.46E-05	1.39E-05	3.46E-06	2.51E-04	2.55E-05
Fluorene	6.67E-07	6.53E-06	1.62E-07	3.65E-07	1.86E-04	4.65E-05	5.31E-05	1.33E-05	8.00E-04	6.67E-05
Indeno(1,2,3-cd)pyrene	4.45E-07	4.35E-06	1.08E-07	2.43E-07	6.02E-06	1.50E-06	6.83E-07	1.71E-07	2.62E-05	6.27E-06
3-Methylchloranthrene	4.45E-07	4.35E-06	1.08E-07	2.43E-07					1.44E-06	4.59E-06
2-Methylnaphthalene	5.93E-06	5.80E-05	1.44E-06	3.24E-06					1.92E-05	6.13E-05
Naphthalene	3.26E-03	4.13E-02	3.60E-05	8.10E-05	1.89E-03	4.73E-04	1.54E-04	3.86E-05	1.75E-02	4.19E-02
Phenanthrene	4.20E-06	4.11E-05	1.02E-06	2.30E-06			5.35E-05	1.34E-05	6.71E-05	5.68E-05
Pyrene	1.21E-06	1.18E-05	2.94E-07	6.62E-07	5.39E-05	1.35E-05	8.70E-06	2.17E-06	2.28E-04	2.82E-05
TOTAL PAH	5.44E-03	6.91E-02	4.12E-05	9.28E-05	3.08E-03	7.71E-04	3.06E-04	7.64E-05	2.90E-02	7.00E-02
Metals										
Arsenic	4.94E-05	4.84E-04	1.20E-05	2.70E-05	6.72E-07	1.68E-07	8.41E-08	2.10E-08	1.63E-04	5.11E-04
Beryllium	2.96E-06	2.90E-05	7.20E-07	1.62E-06					9.61E-06	3.06E-05
Cadmium	2.72E-04	2.66E-03	6.60E-05	1.49E-04	7.46E-08	1.86E-08	9.34E-09	2.33E-09	8.81E-04	2.81E-03
Chromium	3.46E-04	3.38E-03	8.40E-05	1.89E-04	1.80E-04	4.51E-05	2.26E-05	5.64E-06	1.87E-03	3.62E-03
Chromium VI	6.18E-05	6.04E-04	1.50E-05	3.38E-05	3.26E-05	8.14E-06	4.08E-06	1.02E-06	3.35E-04	6.47E-04
Cobalt	2.03E-05	1.98E-04	4.92E-06	1.11E-05					6.57E-05	2.09E-04
Lead	1.21E-04	1.18E-03	2.94E-05	6.62E-05	1.12E-05	2.80E-06	1.40E-06	3.50E-07	4.39E-04	1.25E-03
Manganese	9.14E-05	8.95E-04	2.22E-05	5.00E-05	4.10E-06	1.03E-06	5.13E-07	1.28E-07	3.13E-04	9.46E-04
Mercury	6.18E-05	6.04E-04	1.50E-05	3.38E-05	1.50E-07	3.74E-08	1.87E-08	4.69E-09	2.01E-04	6.38E-04
Nickel	5.19E-04	5.08E-03	1.26E-04	2.84E-04	2.15E-05	5.38E-06	2.69E-06	6.73E-07	1.77E-03	5.37E-03
Selenium	5.93E-06	5.80E-05	1.44E-06	3.24E-06	3.72E-06	9.31E-07	4.66E-07	1.16E-07	3.46E-05	6.23E-05
Max Single Hap										**4.6**
Total HAPs										**17.9**

NOTES:	
	Pound per hour rates for CTGs based upon maximum firing rate (GE Case #6).
	Ton per year rates for CTGs based upon ISO with duct firing (GE Case #14) for 8,760 hours per year.
	Pound per hour rates for auxiliary boiler, black start engines and fire pump engine based upon maximum rating rate.
	Ton per year rates for auxiliary boiler based upon max lb/hr for 4,500 hours per year.
	Ton per year rates for emergency generator and fire pump engines based upon max lb/hr for 500 hours per year.

Cricket Valley Energy Center
Combustion Turbine & Duct Burner Potential HAP Emissions (lb/hr/unit) - (CT0001, CT0002, and

AMBIENT CONDITIONS:	105°F		59°F	-8°F
GE CASE #:	Case 23	Case 26	Case 14	Case 6
Fuel	**Natural Gas**			
Turbine Load	100%	100%	100%	100%
GT Heat Input (MMBtu/hr, HHV)	2,240	2,059	2,333	2,396
DB Heat Input (MMBtu/hr, HHV)	189	233	184	247
HAP				
Organic Compounds				
Acetaldehyde	8.961E-02	8.235E-02	9.332E-02	9.583E-02
Acrolein	1.434E-02	1.318E-02	1.493E-02	1.533E-02
Benzene	2.728E-02	2.519E-02	2.838E-02	2.927E-02
1,3-Butadiene	9.633E-04	8.852E-04	1.003E-03	1.030E-03
Dichlorobenzene	2.268E-04	2.796E-04	2.208E-04	2.964E-04
Ethylbenzene	7.169E-02	6.588E-02	7.466E-02	7.666E-02
Formaldehyde	2.606E-01	2.439E-01	2.704E-01	2.821E-01
Hexane	3.402E-01	4.194E-01	3.312E-01	4.446E-01
Propylene oxide	6.497E-02	5.970E-02	6.766E-02	6.948E-02
Toluene	2.919E-01	2.684E-01	3.039E-01	3.123E-01
Xylene	1.434E-01	1.318E-01	1.493E-01	1.533E-01
PAHs				
Acenaphthene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
Acenaphthylene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
Anthracene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
Benzo(a)anthracene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
Benzo(a)pyrene	2.268E-07	2.796E-07	2.208E-07	2.964E-07
Benzo(b)fluoranthene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
Benzo(g,h,i)perylene	2.268E-07	2.796E-07	2.208E-07	2.964E-07
Benzo(k)fluoranthene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
Chrysene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
Dibenz(a,h)anthracene	2.268E-07	2.796E-07	2.208E-07	2.964E-07
7,12-Dimethylbenz(a) anthracene	3.024E-06	3.728E-06	2.944E-06	3.952E-06
Fluoranthene	5.481E-07	6.757E-07	5.336E-07	7.163E-07
Fluorene	5.103E-07	6.291E-07	4.968E-07	6.669E-07
Indeno(1,2,3-cd)pyrene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
3-Methylchloranthrene	3.402E-07	4.194E-07	3.312E-07	4.446E-07
2-Methylnaphthalene	4.536E-06	5.592E-06	4.416E-06	5.928E-06
Naphthalene	3.026E-03	2.816E-03	3.143E-03	3.263E-03
Phenanthrene	3.213E-06	3.961E-06	3.128E-06	4.199E-06
Pyrene	9.261E-07	1.142E-06	9.016E-07	1.210E-06
TOTAL PAH	5.058E-03	4.689E-03	5.259E-03	5.440E-03
Metals				
Arsenic	3.780E-05	4.660E-05	3.680E-05	4.940E-05
Beryllium	2.268E-06	2.796E-06	2.208E-06	2.964E-06
Cadmium	2.079E-04	2.563E-04	2.024E-04	2.717E-04
Chromium	2.646E-04	3.262E-04	2.576E-04	3.458E-04
Chromium VI	4.725E-05	5.825E-05	4.600E-05	6.175E-05
Cobalt	1.550E-05	1.911E-05	1.509E-05	2.025E-05
Lead	9.261E-05	1.142E-04	9.016E-05	1.210E-04
Manganese	6.993E-05	8.621E-05	6.808E-05	9.139E-05
Mercury	4.725E-05	5.825E-05	4.600E-05	6.175E-05
Nickel	3.969E-04	4.893E-04	3.864E-04	5.187E-04
Selenium	4.536E-06	5.592E-06	4.416E-06	5.928E-06
Total HAPs	**1.311E+00**	**1.317E+00**	**1.341E+00**	**1.487E+00**

Cricket Valley Energy Center
HAP Emission Factors

HAP	Emission Factors				
	CTG	Duct Burners	AB01	EDG01	FP01
	lb/MMBtu	lb/MMBtu	lb/MMBtu	lb/MMBtu	lb/MMBtu
Organic Compounds					
Acetaldehyde	4.00E-05			2.52E-05	7.67E-04
Acrolein	6.40E-06			7.88E-06	9.25E-05
Benzene	1.20E-05	2.10E-06	2.10E-06	7.76E-04	9.33E-04
1,3-Butadiene	4.30E-07				3.91E-05
Dichlorobenzene		1.20E-06	1.20E-06		
Ethylbenzene	3.20E-05				
Formaldehyde	1.10E-04	7.50E-05	7.40E-05	7.89E-05	1.18E-03
Hexane		1.80E-03	1.80E-03		
Propylene oxide	2.90E-05			3.85E-03	3.56E-03
Toluene	1.30E-04	3.40E-06	3.30E-06	2.81E-04	4.09E-04
Xylene	6.40E-05			1.93E-04	2.85E-04
PAHs					
Acenaphthene		1.80E-09	1.80E-09	4.68E-06	1.42E-06
Acenaphthylene		1.80E-09	1.80E-09	9.23E-06	5.06E-06
Anthracene		1.80E-09	1.80E-09	1.23E-06	1.87E-06
Benzo(a)anthracene		1.80E-09	1.80E-09	6.22E-07	1.68E-06
Benzo(a)pyrene		1.20E-09	1.20E-09	2.57E-07	1.88E-07
Benzo(b)fluoranthene		1.80E-09	1.80E-09	1.11E-06	9.91E-08
Benzo(g,h,i)perylene		1.20E-09	1.20E-09	5.56E-07	4.89E-07
Benzo(k)fluoranthene		1.80E-09	1.80E-09	2.18E-07	1.55E-07
Chrysene		1.80E-09	1.80E-09	1.53E-06	3.53E-07
Dibenz(a,h)anthracene		1.20E-09	1.20E-09	3.46E-07	5.83E-07
7,12-Dimethylbenz(a) anthracene		1.60E-08	1.60E-08		
Fluoranthene		2.90E-09	2.90E-09	4.03E-06	7.61E-06
Fluorene		2.70E-09	2.70E-09	1.28E-05	2.92E-05
Indeno(1,2,3-cd)pyrene		1.80E-09	1.80E-09	4.14E-07	3.75E-07
3-Methylchloranthrene		1.80E-09	1.80E-09		
2-Methylnaphthalene		2.40E-08	2.40E-08		
Naphthalene	1.30E-06	6.00E-07	6.00E-07	1.30E-04	8.48E-05
Phenanthrene		1.70E-08	1.70E-08		2.94E-05
Pyrene		4.90E-09	4.90E-09	3.71E-06	4.78E-06
TOTAL PAH	2.20E-06	6.87E-07	6.87E-07	2.12E-04	1.68E-04
Metals					
Arsenic		2.00E-07	2.00E-07	4.62E-08	4.62E-08
Beryllium		1.20E-08	1.20E-08		
Cadmium		1.10E-06	1.10E-06	5.13E-09	5.13E-09
Chromium		1.40E-06	1.40E-06	1.24E-05	1.24E-05
Chromium VI		2.50E-07	2.50E-07	2.24E-06	2.24E-06
Cobalt		8.20E-08	8.20E-08		
Lead		4.90E-07	4.90E-07	7.69E-07	7.69E-07
Manganese		3.70E-07	3.70E-07	2.82E-07	2.82E-07
Mercury		2.50E-07	2.50E-07	1.03E-08	1.03E-08
Nickel		2.10E-06	2.10E-06	1.48E-06	1.48E-06
Selenium		2.40E-08	2.40E-08	2.56E-07	2.56E-07
Total HAPs	**4.26E-04**	**1.89E-03**	**1.89E-03**	**5.48E-03**	**7.53E-03**

Notes:
1. Blank entry indicates no emission factor reported in the reference cited.
2. Organic HAP emission factors for CTGs are from Tables 3.1-3 and 3.1.4 of AP-42 except for formaldehyde which is based on the CTG formaldehyde emission factor in memo from Melanie Taylor (Alpha-Gamma Technologies, Inc.) to Sims Roy (EPA) titled "HAP Emission Factors for Stationary Combustion Turbines" 10/23/2002.
3. Emission factors for duct burners and axuliary boiler are from AP-42 Tables 1.4-3 and 1.4-4.
4. Hexavalent chrome is based on 18% of the total chrome emissions per EPA 453/R-98-004a.
5. Organic HAP emission factors for fire pump engines are from Tables 3.3-1 and 3.3-2 of AP-42.
6. Organic HAP emission factors for black start engines are from Tables 3.4-3 and 3.4-4 of AP-42.
7. Metal emission factors for the emergency generator and fire pump engine are based on the paper “Survey of Ultra-Trace Metals in Gas Turbine Fuels”, 11th Annual International Petroleum Conference, Oct 12-15, 2004. Where trace metals were detected in any of 13 samples, the average result is used. Where no metals were detected in any of 13 samples, the detection limit was used.

APPENDIX G: PROPOSED CTG STARTUP AND SHUTDOWN LIMITS

PROPOSED DEFINITIONS AND EMISSION LIMITS FOR STARTUP, SHUTDOWN, AND TUNING
EMISSION UNITS U-00001, U-00002, and U-00003

As required by Condition 24 of the Permit, the Facility has submitted proposed startup and shutdown limits for the three combustion turbines at the facility, emission units U-00001, U-00002, and U-00003.

Condition 24 requires the Facility to monitor all occurrences of startup and shutdown from the combustion turbines, including the duration of each startup and shutdown event, and the total pounds of emissions of NO_X, CO, and NH_3 during each startup and shutdown event, as measured and recorded by the CEMS for each combustion turbine.

Condition 24 also requires the Facility to submit proposed startup and shutdown limits to the Department within 60 days of recording the 15th startup and shutdown. The facility recorded its 15th startup and 15th shutdown on approximately March 22, 2020. Only startup and shutdown events that occurred after the date that each combustion turbine completed its initial performance tests and initial CEMS certification tests were used in determining when the 15th startup and shutdown event occurred.

Initial proposed limits were submitted to NYSDEC by email on May 20, 2020, based on actual startup and shutdown data through April 30, 2020. NYSDEC has agreed that the Facility may submit revisions to the proposed startup and shutdown limits as part of the Title V permit renewal application.

Analysis

The proposed startup and shutdown limits are based on actual operating and emissions data for a total of 131 startup events and 121 shutdown events, occurring between February 21 and June 30, 2020. A total of 12 startup events that exceeded the vendor-estimated duration of 60 minutes were excluded from the analysis. A total of seven shutdown events that exceeded the vendor-estimated duration of 20 minutes were also excluded from the analysis. A Microsoft Excel® workbook is being provided to NYSDEC in electronic format. The workbook contains the data evaluated and the calculations performed. A table summarizing the results the analysis is included with this appendix.

The Facility is proposing NO_x and CO mass emission limits in units of pounds emitted per event for each startup and shutdown, based on a review of actual CEMS data. The Facility is requesting that a single set of startup emission limits be considered for the purpose of simplifying recordkeeping and reporting, rather than different emission limits assigned specifically to cold, warm, and hot starts.

The Facility also proposes that NH_3 emission limits during startup and shutdown be similarly expressed in units of pounds emitted per event, based on a review of actual CEMS data, with a conservative margin applied based on engineering judgment. The Facility notes that, during startup periods when ammonia is injected while the catalyst is coming up to operating temperature, the measured NH_3 concentration is out-of-range of the instrument scale. For the purposes of performing this analysis, we assumed these out-of-range concentrations were 30 ppmvd based on an instrument scale of 20 ppmvd. To ensure no conflicts in the permit conditions, we are also requesting clarification of Item 23.2 of the existing permit to exclude startup and shutdown periods (see below).

Proposed Definitions and Emission Limits during Startup, Shutdown, and Tuning

We propose the following definitions and emission limits be added as compliance certification conditions for the following emission units and their respective processes:

Emission Unit: U-00001
Process: P01

Emission Unit: U-00002
Process: P04

Emission Unit: U-00003
Process: P05

Below are the proposed monitoring descriptions for each condition or emission limit related to startup, shutdown, and tuning.

Startup duration

Startup is defined as the period of time from when a "FLAME ON" signal is received from the Distributed Control System (DCS) until steady-state operation is attained as identified by 10 consecutive minutes of compliance with steady-state CO and NO_X emission limits. The duration of a startup shall not exceed 60 minutes.

The initial application for the Permit was based upon a maximum startup duration of 60 minutes. However, the Facility has experienced several startup events on all three units longer than 60 minutes since the Facility has achieved commercial operation. CVEC is reviewing startup procedures with GE to make every effort to limit startup duration to less than 60 minutes. However, CVEC does not want to propose a permit limit that cannot be met consistently. Therefore, CVEC reserves the right to propose a startup duration longer than 60 minutes pending the outcome of the review of startup procedures with GE. Should CVEC determine that a longer startup time is necessary, we will provide NYSDEC with a detailed analysis to document why the longer duration is necessary with supporting documentation from GE.

The owner or operator shall record the date and time of each startup event. A report consisting of the recorded information shall be submitted to the Department with the facility's required excess emissions report. All records shall be maintained and readily available for a minimum of five years.

Shutdown duration

Shutdown is defined as the period of time from initiation of shutdown by the control room operator until a "FLAME OFF" signal is received from the DCS. The duration of a shutdown shall not exceed 20 minutes.

The owner or operator shall record the date and time of each shutdown event. A report consisting of the recorded information shall be submitted to the Department with the facility's required

excess emissions report. All records shall be maintained and readily available for a minimum of five years.

Definition of "Tuning event"

In addition to the proposed startup and shutdown limits required by Condition 24 of the Permit, the Facility also requests that "tuning event" be defined as a maintenance activity for each combustion turbine, during which the emission limits for steady-state operation, startup, and shutdown do not apply. Each GE 7FA.05 combustion turbine will require seasonal tuning of the machine twice a year, once prior to the summer and once prior to the winter. Each tuning period is designed to optimize the turbine for ambient conditions during the upcoming season, while minimizing the likelihood of excessive emissions, excessive combustor dynamics, or loss of flame (due to lean blow-out). The Facility requests that an allowance be made for tuning to be performed twice a year on each combustion turbine, with each tuning event lasting up to 4 hours.

The following definition of "tuning event" is proposed to be added as a compliance condition:

> Tuning event is defined as a period of low-load operation of a combustion turbine for the purpose of tuning the turbine prior to the summer or winter season, not to exceed four hours per event, during which the emission limits for steady-state operation, startup, and shutdown do not apply. Each combustion turbine is allowed up to two tuning events per calendar year.

Startup emission limits

> The owner or operator shall limit NO_X emissions from each combustion turbine generator to 80.0 pounds per startup event. Emissions shall be monitored and recorded on a continuous basis with a CEM system.
>
> The owner or operator shall limit CO emissions from each combustion turbine generator to 330.0 pounds per startup event. Emissions shall be monitored and recorded on a continuous basis with a CEM system.
>
> The owner or operator shall limit NH_3 emissions from each combustion turbine generator to 25.0 pounds per startup event. Emissions shall be monitored and recorded on a continuous basis with a CEM system.

Shutdown emission limits

> The owner or operator shall limit NO_X emissions from each combustion turbine generator to 5.0 pounds per shutdown event. Emissions shall be monitored and recorded on a continuous basis with a CEM system.
>
> The owner or operator shall limit CO emissions from each combustion turbine generator to 5.0 pounds per shutdown event. Emissions shall be monitored and recorded on a continuous basis with a CEM system.

The owner or operator shall limit NH_3 emissions from each combustion turbine generator to 3.0 pounds per shutdown event. Emissions shall be monitored and recorded on a continuous basis with a CEM system.

Steady-State Emission Limits for NOx, CO, and NH_3

NOx ppmvd emission limit: Item 1.6-2

In addition to the proposed NOx emission limits presented above for startup and shutdown conditions, the Facility requests that Item 1.6-2 of the existing Permit be amended to include a statement that the NOx ppmvd limit does not apply to any 1-hour average that contains at least one minute of startup or shutdown, and does not apply to any 1-hour average that includes part of a tuning event, such that the monitoring description reads:

> Facility must maintain a NOx emission limit of 2.0 ppmvd at 15 percent O2 (with and without duct burning) to satisfy LAER. This will be achieved through the application of DLN burners in combination with Selective Catalytic Reduction (SCR). This limit applies at all load conditions, except that it does not apply to any 1-hour average that includes at least one minute of a startup, shutdown, or tuning event. The facility will use CEMS to monitor NOx stack emissions.

CO ppmvd emission limit: Item 46.2

In addition to the proposed CO emission limits presented above for startup and shutdown conditions, the Facility requests that Item 46.2 of the existing Permit be amended to include a statement that the CO ppmvd limit does not apply to any 1-hour average that contains at least one minute of startup or shutdown, and does not apply to any 1-hour average that includes part of a tuning event, such that the monitoring description reads:

> Each combustion turbine and associated duct burner will not exceed a CO emission rate of 2.0 ppmvd at 15% oxygen, with and without duct firing. This emission limit applies at all operating loads, except that it does not apply to any 1-hour average that includes at least one minute of a startup, shutdown, or tuning event, and will be achieved through good combustion practices and an oxidation catalyst to satisfy BACT requirements. The facility will install, operate and maintain a CEMS in order to monitor CO stack emissions.

Ammonia slip ppmvd emission limit: Item 23.2

In addition to the proposed NH_3 emission limits presented above for startup and shutdown conditions, the Facility requests that Item 23.2 of the existing Permit be amended to include a statement that the CO ppmvd limit does not apply to any 1-hour average that contains at least one minute of startup or shutdown, and does not apply to any 1-hour average that includes part of a tuning event, such that the monitoring description reads:

> The facility shall install, calibrate, maintain and operate continuous emissions monitors for ammonia. The 5.0 ppmvd corrected to 15% Oxygen limit applies during all turbine loads, all fuels being fired, and all duct burner operations, except that it does not apply to any 1-hour average that includes at least one minute of a startup, shutdown, or tuning event.

During startup, ammonia is being injected in the selective catalytic reduction (SCR) system to control NO_X as the temperature of the catalyst rises to the design temperature range. Ammonia slip is unstable and unpredictable during this time period and partial hour data validation could result in slip concentrations being greater than 5 ppmvd @ 15% O_2. If a unit starts up in the last few minutes at the top of the hour, those few minutes of initial slip concentration data are enough to validate the hour. Specifically, 40 CFR 60.13(h)(2)(iii)(B) states that only one valid data point is needed to calculate an hourly average if the unit operates only operates in one quadrant of the hour, thus necessitating the clarification. The clarification is also consistent with the exception provided for steady-state NO_X and CO emission limits listed in Items 1-6.2 and Item 46.2 of the Permit. This exclusion appears to have been inadvertently left out of the originally-issued permit, and an ammonia limit during startups and shutdowns is unusual in our experience with other power plants.

APPENDIX H: ACID RAIN PERMIT RENEWAL APPLICATION

United States
Environmental Protection Agency
Acid Rain Program

OMB No. 2060-0258
Approval expires 12/31/2021

Acid Rain Permit Application

For more information, see instructions and 40 CFR 72.30 and 72.31.

This submission is: ☐ new ☐ revised ☑ for ARP permit renewal

STEP 1

Identify the facility name, State, and plant (ORIS) code.

Facility (Source) Name	State	Plant Code
Cricket Valley Energy Center	NY	57185

STEP 2

Enter the unit ID# for every affected unit at the affected source in column "a."

a	b
Unit ID#	Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)
U001	Yes
U002	Yes
U003	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes

Cricket Valley Energy Center
Facility (Source) Name (from STEP 1)

STEP 3

Read the standard requirements.

Permit Requirements

(1) The designated representative of each affected source and each affected unit at the source shall:
- (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
- (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;

(2) The owners and operators of each affected source and each affected unit at the source shall:
- (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
- (ii) Have an Acid Rain Permit.

Monitoring Requirements

(1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.

(2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.

(3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

(1) The owners and operators of each source and each affected unit at the source shall:
- (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and
- (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.

(2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.

(3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
- (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or
- (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).

(4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.

(5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.

(6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.

(7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Cricket Valley Energy Center
Facility (Source) Name (from STEP 1)

STEP 3, Cont'd.

Excess Emissions Requirements

(1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
(2) The owners and operators of an affected source that has excess emissions in any calendar year shall:
   (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
   (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

(1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
   (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
   (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
   (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
   (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
(2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
(4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.
(5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.
(6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit.
(7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Cricket Valley Energy Center
Facility (Source) Name (from STEP 1)

STEP 3, Cont'd.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a source can hold; provided, that the number of allowances held by the source shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,

(5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4

Certification

Read the certification statement, sign, and date.

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name Marc Duquette	
Signature Marc J Duquette	Date 7/24/20

APPENDIX I: PERFORMANCE EMISSION TEST REPORTS

EMISSION COMPLIANCE TEST
FOR THE
GENERAL ELECTRIC, 7F.05, UNIT #U-00001
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 17-19 AND MARCH 6, 2020

Permit No: 3-1326-00275/00009
Facility DEC ID: 3132600275
Report Date: March 23, 2020



Corporate Headquarters
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012

AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices
Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

EMISSION COMPLIANCE TEST
FOR THE
GENERAL ELECTRIC, 7F.05, UNIT #U-00001
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 17-19 AND MARCH 6, 2020

Prepared and Reviewed by:

Logan K. Tsotsoros

Logan Tsotsoros
AHU Support Staff

Thomas K Graham

Thomas K. Graham, PE, QSTI
Director of AHU


I, R.W.C.

Rob White, QSTI
Test Manager
certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

CERTIFICATION OF INFORMATION

I certify under penalty of law that I believe the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.



Rob White, QSTI
Test Manager
Air Hygiene International, Inc.

February 23, 2020
Date


FACILITY CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attached documents and, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.

I am the responsible official with direct knowledge and overall responsibility for the information contained in this report.

Marc J. Duquette
Name

Director, EHS
Title



Signature

3/24/2020
Date

(this page intentionally left blank)

Table of Contents

1.0 INTRODUCTION 1

1.1 TEST PURPOSE AND OBJECTIVES 1

1.2 SUMMARY OF TEST PROGRAM 1

1.2.1 Participating Organizations 1
1.2.2 Industry 1
1.2.3 Air Permit Requirements 1
1.2.4 Plant Location 1
1.2.5 Equipment Tested 2
1.2.6 Emission Points 2
1.2.7 Emission Parameters Measured 2
1.2.8 Dates of Emission Test 2
1.2.9 Federal Certifications 2

1.3 KEY PERSONNEL 2

2.0 SUMMARY OF TEST RESULTS 3

3.0 SOURCE OPERATION 4

3.1 PROCESS DESCRIPTION 4

3.2 SAMPLING LOCATION 4

4.0 SAMPLING AND ANALYTICAL PROCEDURES 4

4.1 TEST METHODS 4

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS 5

APPENDICES

Appendix A Test Results and Calculations
Table A.1: Emissions Testing Schedule (Sampling Log)
Emissions Results Base Load NOx, CO, VOC, and NH_3
Emissions Results Base Load PM_{10}
Emissions Results Base Load SAM
Emissions Results Base+DB Load NOx, CO, VOC, and NH_3
Emissions Results Base+DB Load PM_{10}
Emissions Results Base+DB Load SAM

Appendix B Emission Data Records
Operating Data Base Load NOx, CO, VOC, and NH_3
Operating Data Base Load PM_{10}
Operating Data Base Load SAM
Operating Data Base Load Opacity
Operating Data Base+DB Load NOx, CO, VOC, and NH_3
Operating Data Base+DB Load PM_{10}
Operating Data Base+DB Load SAM
Operating Data Base+DB Load Opacity
Operating Data Base+DB Load and Auxiliary Boiler Opacity

Table of Contents
(continued)

APPENDICES

Appendix B Emission Data Records
- Reference Method Data Base Load NOx, CO, VOC, and NH_3
- Reference Method Data Base Load PM_{10}
- Reference Method Data Base Load SAM
- Reference Method Data Base Load Opacity
- Reference Method Data Base+DB Load NOx, CO, VOC, and NH_3
- Reference Method Data Base+DB Load PM_{10}
- Reference Method Data Base+DB Load SAM
- Reference Method Data Base+DB Load Opacity
- Reference Method Data Base+DB Load and Auxiliary Boiler Opacity

Appendix C Calibration Gas Certifications

Appendix D Quality Assurance and Quality Control Data
- Daily Reference Method Analyzer Calibration Data
- Laboratory Data Summary Base Load PM_{10}
- Laboratory Data Summary Base+DB Load PM_{10}
- Field Collection Data QA SAM
- Laboratory Data PM_{10} and SAM, BV Labs
- Supplemental Laboratory Data PM_{10} Filters, BV Labs
- Supplemental Laboratory Data SAM by IC, BV Labs
- Audit Sample Data

Appendix E Fuel Analysis Records

Appendix F Stratification Test Data
- Stratification Test Data Base Load
- Stratification Test Data Base+DB Load

Appendix G Equipment Calibration Records

Emissions Compliance Test
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center LLC
Cricket Valley Energy Center
Dover Plains, New York
February 17-19 and March 6, 2020

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Emissions Compliance Test for nitrogen oxides (NOx), carbon monoxide (CO), total hydrocarbons/volatile organic compounds (THC/VOC), sulfur dioxide (SO_2) [by fuel analysis], ammonia (NH_3), particulate matter (PM_{10}), sulfuric acid mist (SAM), opacity / visual emissions (VE), flow, moisture (H_2O), carbon dioxide (CO_2), and oxygen (O_2) from the exhaust of the General Electric, 7F.05, Unit #U-00001 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on February 17-19 and March 6, 2020.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to conduct an initial compliance emission test to document levels of selected pollutants at two test loads, base loaded with duct burners on and base loaded with duct burners off (Base+DB and Base). An additional load included opacity only with the unit operating at Base+DB and the Auxiliary Boiler operating at maximum load. Both of these units share a common stack and this run condition has the potential for maximum VE production. The information will be used to confirm compliance with the operating permit issued by the New York State Department of Environmental Conservation (NYSDEC). The specific objective was to determine the emission concentrations and rates of NOx, CO, THC/VOC, SO_2 [fuel analysis], NH_3, PM_{10}, SAM, VE, flow, H_2O, CO_2, and O_2 from the exhaust of Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00001 at Base+DB and Base.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations
- New York State Department of Environmental Conservation (NYSDEC)
- Cricket Valley Energy Center LLC
- Bechtel Corporation
- Air Hygiene

1.2.2 Industry
- Electric Utility / Electric Services

1.2.3 Air Permit Requirements
- Permit Number: 3-1326-00275/00009

1.2.4 Plant Location
- Cricket Valley Energy Center in Dover Plains, New York
  - GPS Coordinates [Latitude 41.67721, Longitude -73.57992]
  - Physical Address: 2241 ST RTE 22, Dover Plains, New York 12522
  - Federal Registry System / Facility Registry Service (FRS) No. – 110043340364
  - Source Classification Code (SCC) – 10200602

1.2.5 Equipment Tested
- General Electric, 7F.05, Unit #U-00001

1.2.6 Emission Points
- Exhaust from the General Electric, 7F.05, Unit #U-00001
- For all gases, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00001, determined after conducting a 12-point stratification test
- For all PM_{10} testing, 12 sampling points in the exhaust duct from the General Electric, 7F.05, Unit #U-00001
- For all SAM testing, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00001
- For opacity, one sample visual observation point from the exit of the exhaust duct to the atmosphere from the General Electric, 7F.05, Unit #U-00001

1.2.7 Emission Parameters Measured
- NOx
- CO
- THC/VOC
- SO_2 [fuel analysis]
- NH_3
- PM_{10}
- SAM
- Opacity
- Flow
- H_2O
- CO_2
- O_2

1.2.8 Dates of Emission Test
- February 17-19 and March 6, 2020

1.2.9 Federal Certifications
- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Cricket Valley Energy Center LLC:	Marc Duquette (mduquette@cricketvalley.com)	617-320-5219
Bechtel Corporation:	John Curran	772-678-1878
Bechtel Corporation:	Peter Carr (pcarr@bechtel.com)	571-392-6737
NYSDEC:	Alyssa Carbone	845-256-3051
Air Hygiene:	Rob White (rwhite@airhygiene.com)	918-307-8865
Air Hygiene:	Swanson Bierman (swanson@airhygiene.com)	918-307-8865
Air Hygiene:	Atlas Melchert	918-307-8865
Air Hygiene:	Michael Wilmott	918-307-8865
Air Hygiene:	Aaron Blum	918-307-8865
Air Hygiene:	Matt Jones	918-307-8865
Air Hygiene:	Jeremy Johnson	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00001 located at the Cricket Valley Energy Center on February 17-19 and March 6, 2020 are summarized in the following table and relate only to the items tested.

TABLE 2.1
SUMMARY OF GENERAL ELECTRIC, 7F.05, UNIT #U-00001 RESULTS

Parameter	Base Load	Base+DB Load	Base+DB Load and Aux Boiler	Permit Limits Base	Permit Limits Base+DB
Heat Input (MMBtu/hr)	2,306.0	2,509.8	2,428.1[1]	--	--
CT Power Output (megawatts)	240.7	241.2	236.4	--	--
Load Condition	Nominal base load, w/o DB[2]	Nominal base load, w/ DB[3]	Nominal base load, w/ DB[3]	--	--
Aux Boiler Fuel Flow (pph)	--	--	1,471.41	--	--
NOx (ppmvd)	2.40	2.52	--	--	--
NOx (ppm@15%O_2)	1.77	1.61	--	2.0	2.0
CO (ppmvd)	0.24	0.08	--	--	--
CO (ppm@15%O_2)	0.18	0.05	--	2.0	2.0
VOC (as C1) (ppmvd)	0.29	0.00	--	--	--
VOC (as C1) (ppm@15%O_2)	0.21	0.00	--	0.7	1.8
Total PM_{10} (mg)	7.63	6.47	--	--	--
Total PM_{10} (lb/MMBtu)	0.0037	0.0028	--	0.005	0.006
Fuel Sulfur (grains / 100 scf)	0.11	0.11	--	0.4	0.4
SAM (as H_2SO_4) (mg)	0.026	0.040	--	--	--
SAM (as H_2SO_4) (lb/MMBtu)	0.00003	0.00004	--	0.00065	0.00065
NH_3 (ppmvd)	1.46	2.07	--	--	--
NH_3 (ppm@15%O_2)	1.07	1.32	--	5.0	5.0
Opacity (%)	0	0	0	20	20

Notes: [1]Base+DB Load and Aux Boiler Heat Input estimated using 02/19/20 fuel gas analysis. [2]Air permit specifically indicates design capacity heat input of 2395.7 MMBtu/hr [ISO Conditions, 1 atm (29.923 in Hg), temperature 15 C or 59 F, and RH 60%] for the gas turbine. [3]Air permit specifically indicates design capacity heat input of 247 mmBtu/hr [ISO Conditions, 1 atm (29.923 in Hg), temperature 15 C or 59 F, and RH 60%] for the duct burner.

The results of all measured pollutant emissions were below the required limits. All testing was conducted according to the approved testing protocol. All testing was performed without any real or apparent errors with the following exceptions:

The PM_{10} filter weights were reported by the laboratory at the reportable detection limit (RDL), but included notes indicating negative filter weights. Supplemental laboratory data was provided (Appendix D) and additional data analysis indicated filter losses were accounted for in either the sample train section cleanup just prior to the filter or the sample train cleanup in the section just after the filter. As a result, the PM results are considered valid with accounting for all filter weight losses in other fractions of the sample train results.

The initial SAM analysis was conducted by titration, per the requirements of CTM-013 with all results reported below the reportable detection limits (RDLs). However, when reporting emission rates using the titration based RDL values, the SAM results exceeded permitted limits. To remedy, the SAM analysis was conducted by ion

chromatography (IC). The supplemental IC analysis (Appendix D) yielded lower RDLs and also all results that were below the permitted limits. Emission rates were calculated based on the supplemental IC data.

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a "test mode" (Mode 0) setting, and not the expected "natural gas mode" setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas). The combined U-00001 Base with DB fired and auxiliary boiler in operation load opacity test was performed after the fuel gas flowmeter mode operation was corrected on 2/21/2020.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

Cricket Valley Energy Center LLC owns and operates the Cricket Valley Energy Center located at 2241 ST RTE 22 in Dover Plains, New York. Located on the Cricket Valley Energy Center are three General Electric 7F.05 Combustion Turbine Generators (CTGs), designated as Emission Units U-00001, U-00002, and U-00003. The CTGs and associated heat recovery steam generators (HRSGs) which are equipped with dry low NOx burners in combination with selective catalytic reduction systems (SCRs). The CTG-HRSGs are also equipped with oxidation catalysts which reduce CO and VOC emissions.

3.2 SAMPLING LOCATION

The sample ports were located approximately vertical, circular and measures 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 265.8 ft above grade level with an exit elevation of approximately 282.5 ft above grade level. The test ports are located approximately 70.8 ft (850 inches) downstream and approximately 16.7 ft (200.4 inches) upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by Cricket Valley Energy Center LLC. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test. During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time. For PM_{10} testing, an initial velocity traverse was performed across the stack from 12 total points at each test load. All PM_{10} sampling occurred from the same 12 points. All SAM testing occurred from a simple sample point. All opacity observations were made by viewing the point where the exhaust system exited to the atmosphere at the top of the exhaust stack.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the General Electric, 7F.05, Unit #U-00001 at the Cricket Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on February 17-19 and March 6, 2020.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	S-Type Pitot Tube
Oxygen	EPA Method 3A	Paramagnetic Cell
Carbon Dioxide	EPA Method 3A	Nondispersive Infrared Analyzer
Stack Moisture Content	EPA Method 4	Gravimetric Analysis
Sulfur Dioxide	GPA 2261	Fuel Sulfur Content
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Sulfuric Acid Mist	CTM-013 (EPA Method 8A)	Wet Chemistry Solubility
Opacity	EPA Method 9	Visual Observation
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Volatile Organic Compounds	EPA Method 18/25A	Gas Chromatograph and Flame Ionization Detector
Stack Flow Rate	EPA Method 19	ASTM 5504 and Dry Oxygen F Factor
Particulate Matter	EPA Method 201A	Front Half Filterables
Particulate Matter	EPA Method 202	Back Half Condensables
Ammonia Slip	EPA Method 320	Fourier Transform Infrared

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3A, 4, 7E, 9, 10, 18, 19, 25A; 40 CFR 51, Appendix M, Methods 201A and 202; 40 CFR 63, Appendix A, Method 320; Conditional Test Method (CTM)-013 [Method 8A]; ASTM 5504; and GPA 2261.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless-steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample. Exhaust samples were routed to the wet based analyzer prior to gas conditioning.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer, interferograms consisting of 27 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations. Spectral data was analyzed by the MKS MG2000 software.

Figure 4.2 represents the sample system used for the PM_{10} tests. A heated stainless-steel probe with a glass liner and stainless-steel nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter. Glassware that is used to collect and analyze Method 202 condensable particulate samples is cleaned prior to the test with soap and water, and rinsed using tap water, deionized water, acetone, and finally, hexane. After cleaning, Air Hygiene incorporates a glassware bake at 300^{o}C for six hours rather than the alternative of collecting a field train proof blank.

Figure 4.3 represents the sample system used for the SAM tests. A heated stainless-steel probe with a glass liner was inserted into a sample port of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter.

The stack gas analysis for O_2 and CO_2 concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O_2 analyzer uses a paramagnetic cell detector and the CO_2 analyzer uses a continuous nondispersive infrared analyzer.

EPA Method 7E was used to determine concentrations of NOx. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO_2 in nitrogen certified gas cylinder was used to verify at least a 90 percent NO_2 conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

THC emission concentrations were quantified in accordance with procedures set forth in EPA Method 25A. A continuous flame ionization (FID) analyzer was used for this purpose. THC emissions concentrations were below VOC limits and all assumed as VOCs. EPA Method 18 for Tedlar bag sampling and analysis of methane and ethane content was not analyzed or subtracted from the THC concentrations to determine VOC concentrations.


An MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer, or equivalent, was used for NH_3 analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm^{-1}. The system employed a silicon carbide infrared source at 1200ºC, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to

the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191ºC. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 10.0 liters per minute, the sample gas in the cell is refreshed at least times each minute. Interferograms consisting of 27 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations.


TABLE 4.2
ANALYTICAL INSTRUMENTATION

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NOx	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO_2 to NO. Chemiluminescence of reaction of NO with O_3. Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor-based linearization.
CO_2	SERVOMEX 1440	0-20%	0.1%	Nondispersive infrared
NH_3	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
VOC	VIG 210	User may select up to 10,000 ppm	0.1 ppm	Flame Ionization Detector
O_2	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

COPYRIGHT © 2011 AIR HYGIENE INTERNATIONAL, INC.



LEGEND
- Heated Teflon Tubing (pre-conditioned sample)
- Unheated Teflon Tubing (conditioned sample)
- Diluted Calibration Gas
- Calibration Gas
- Electronic Input/Output



PROCESS INLET OR 2ND STACK

dual line heated sample umbilical

STACK EXHAUST

TEST TRAILER EXTERIOR

TEST TRAILER INTERIOR


DATA RECORDER



COMPUTER




GAS CONDITIONER



dual line heated sample umbilical

MOBILE SECONDARY ANALYZERS

MANIFOLD





GAS DILUTER

THC, VOC



O_2, CO_2, NOx, CO, SO_2



HOT/WET ANALYZERS
COLD/DRY ANALYZERS




COLD/DRY ANALYZERS HOT/WET



O_2, CO_2, NOx, CO, SO_2

FLOW CONTROL MANIFOLD





FTIR


THC, VOC



CONDITIONER

VENT

CALIBRATION/ BIAS GAS BOTTLES



VENT

FIXED PRIMARY ANALYZERS


Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.

AIR HYGIENE

Figure 4.1
EMISSIONS TESTING LAB

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

COPYRIGHT © 2009 AIR HYGIENE INTERNATIONAL, INC.




Wet Chemistry Assembly
(photo)





Figure 4.2
RM201A / 202 ASSEMBLY

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

COPYRIGHT © 2013 AIR HYGIENE INTERNATIONAL, INC.



TEST NOTES:
10 LPM SAMPLE FLOW
Delta H @ 0.35 IS ABOUT 10 LPM ON STANDARD CONSOLE
15 MIN AMBIENT AIR PURGE

Figure 4.3
METHOD 8A ASSEMBLY

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1: EMISSIONS TESTING SCHEDULE

Unit	Load	Component	Run	Date	Start	Stop	Time Sync	Duration
U-00001	Base	Stratification Test	Base-1	02/05/20	14:35	16:38	DAHS	02:03
U-00001	Base	Cyclonic Flow Check	PM U-00001 Base-V1	02/16/20	08:00	08:41	DAHS	00:41
U-00001	Base	NOx, CO, VOC, NH_3	1-1	02/17/20	13:35	14:34	DAHS	01:00
U-00001	Base	NOx, CO, VOC, NH_3	1-2	02/17/20	14:50	15:49	DAHS	01:00
U-00001	Base	NOx, CO, VOC, NH_3	1-3	02/17/20	16:00	16:59	DAHS	01:00
U-00001	Base	Opacity	Op-1-1	02/17/20	12:30	13:30	DAHS	01:00
U-00001	Base	Opacity	Op-1-2	02/17/20	13:32	14:32	DAHS	01:00
U-00001	Base	Opacity	Op-1-3	02/17/20	14:35	15:35	DAHS	01:00
U-00001	Base	PM_{10}	PM U-00001 Base-1	02/17/20	17:02	22:11	DAHS	05:09
U-00001	Base	PM_{10}	PM U-00001 Base-2	02/17/20	23:05	04:05	DAHS	05:00
U-00001	Base	PM_{10}	PM U-00001 Base-3	02/19/20	14:25	18:27	DAHS	04:02
U-00001	Base	SAM	SAM U-00001 Base-1	02/18/20	02:03	04:03	DAHS	02:00
U-00001	Base	SAM	SAM U-00001 Base-2	02/18/20	04:57	06:57	DAHS	02:00
U-00001	Base	SAM	SAM U-00001 Base-3	02/19/20	14:32	16:32	DAHS	02:00
U-00001	Base+DB	Stratification Test	BaseDB-1	02/18/20	10:19	12:01	DAHS	01:42
U-00001	Base+DB	Cyclonic Flow Check	PM U-00001 Base+DB-V1	02/18/20	13:50	14:12	DAHS	00:22
U-00001	Base+DB	NOx, CO, VOC, NH_3	2-1	02/19/20	04:25	05:24	DAHS	01:00
U-00001	Base+DB	NOx, CO, VOC, NH_3	2-2	02/19/20	05:33	06:32	DAHS	01:00
U-00001	Base+DB	NOx, CO, VOC, NH_3	2-3	02/19/20	06:41	07:40	DAHS	01:00
U-00001	Base+DB	Opacity	Op-2-1	02/19/20	11:00	12:00	DAHS	01:00
U-00001	Base+DB	Opacity	Op-2-2	02/19/20	12:02	13:02	DAHS	01:00
U-00001	Base+DB	Opacity	Op-2-3	02/19/20	13:04	14:02	DAHS	00:58
U-00001	Base+DB	PM_{10}	PM U-00001 Base+DB-1	02/18/20	14:55	19:04	DAHS	04:09
U-00001	Base+DB	PM_{10}	PM U-00001 Base+DB-2	02/19/20	04:24	08:15	DAHS	03:51
U-00001	Base+DB	PM_{10}	PM U-00001 Base+DB-3	02/19/20	09:14	13:51	DAHS	04:37
U-00001	Base+DB	SAM	SAM U-00001 Base+DB-1	02/18/20	14:40	16:40	DAHS	02:00
U-00001	Base+DB	SAM	SAM U-00001 Base+DB-2	02/19/20	04:09	06:09	DAHS	02:00
U-00001	Base+DB	SAM	SAM U-00001 Base+DB-3	02/19/20	07:26	09:26	DAHS	02:00
U-00001	Base+DB & Aux Boiler	Opacity	Op-3-1	03/06/20	12:50	13:50	DAHS	01:00
U-00001	Base+DB & Aux Boiler	Opacity	Op-3-2	03/06/20	13:50	14:50	DAHS	01:00
U-00001	Base+DB & Aux Boiler	Opacity	Op-3-3	03/06/20	14:50	15:50	DAHS	01:00

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
NOx, CO, VOC, and NH_3

GENERAL ELECTRIC, 7F.05, UNIT #U-00001 BASE LOAD DATA SUMMARY

Parameter	Base Load, Run - 1-1	Base Load, Run - 1-2	Base Load, Run - 1-3	Average
Date (mm/dd/yy)	02/17/20	02/17/20	02/17/20	02/17/20
Start Time (hh:mm:ss)	13:35:04	14:50:04	16:00:04	13:35:04
End Time (hh:mm:ss)	14:34:34	15:49:34	16:59:34	16:59:34
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	30.28	30.28	30.30	30.29
Amb. Temp. (°F)	43	43	45	44
Rel. Humidity (%)	41	40	39	40
Spec. Humidity (lb water / lb air)	0.002353	0.002295	0.002414	0.002354
NH_3 Flow Rate (lb/hr)	169.8	164.8	172.3	169.0
Turbine Fuel Flow (lb/min)	1,673	1,673	1,678	1,674
Duct Burner Fuel Flow (lb/min)	0	0	0	0
Total Fuel Flow (SCFH)	2,260,589	2,261,296	2,267,876	2,263,253
Stack Flow (RM19) (SCFH)	51,893,455	51,868,559	52,178,300	51,980,105
Stack Moisture (% Method 4)	5.8	5.8	5.8	5.8
Heat Input (MMBtu/hr)	2,303.3	2,304.0	2,310.7	2,306.0
CT Power Output (megawatts)	240.4	240.4	241.3	240.7
NOx (ppmvd)	2.45	2.34	2.43	2.40
NOx (ppm@15%O_2)	1.80	1.72	1.79	1.77
CO (ppmvd)	0.31	0.40	0.02	0.24
CO (ppm@15%O_2)	0.23	0.30	0.01	0.18
VOC (as C1) (ppmvd)	0.57	0.27	0.02	0.29
VOC (as C1) (ppm@15%O_2)	0.42	0.20	0.02	0.21
Fuel Sulfur (grains / 100 scf)	0.11	0.11	0.11	0.11
CO_2 (%)	4.82	4.81	4.79	4.80
O_2 (%)	12.88	12.88	12.90	12.89

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO_2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH_3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO_2 (lb/lb-mole) =	44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO_2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH_3 =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO_2 =	0.0000001142434

NOTE: units are lb/ppm*ft^3

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$

2. Correction to % O_2, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(T\,\mathrm{arg}\,et)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$

3. Correction to % O_2 and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_O - 0.00633))} \times \left(\frac{288}{T_a}\right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000}\right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}}\right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O_2 based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp\cdot hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \; or \; \frac{E_{lb/hr} \times 453.6}{hp}$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO_2 to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H_2O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
$\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
$\%_{CO2d}$,$\%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g.,24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO_2 rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O_2.
E_{jo},E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft^3 = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
$\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
$\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = $2x10^4$ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p,L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
$\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
$M_{\%}$ = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)[1]
NCM = net Btu per SCF (constant based on compound)
$\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
$\%_{O2d}$, $\%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO2 emissions, percent.
$\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
$\%_{Sf}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
$\%S_p$, $\%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
$t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2}=CO_2 Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

EXAMPLE CALCULATIONS (FFACTOR)

RM 19, (02-27-14),
2.0 Summary of Method,
2.1 Emission Rates. Oxygen (O_2) or carbon dioxide (CO_2) concentrations and appropriate F factors (ratios of combustion gas volumes to heat inputs) are used to calculate pollutant emission rates from pollutant concentrations.

RM 19, (02-27-14),
12.2 Emission Rates of PM, SO_2, and NOx. Select from the following sections the applicable procedure to compute the PM, SO_2, or NOx emission rate (E) in lb/MMBtu. The pollutant concentration must be in lb/scf and the F factor must be in scf/MMBtu. If the pollutant concentration (C) is not in the appropriate units, use Table 19–1 in Section 17.0 to make the proper conversion. An F factor is the ratio of the gas volume of the products of combustion to the heat content of the fuel. The dry F factor (F_d) includes all components of combustion less water, the wet F factor (F_w) includes all components of combustion, and the carbon F factor (F_c) includes only carbon dioxide.

Mark's Std Hdbk, 10th ed.,pg 4-26
High Heat Value Dry (HHV_{dry}), calc for Methane (single component for the fuel gas)

$$HHV_{dry}(Btu/SCF) = \left[\left(\frac{M_{\%}}{100}\right) \times GCM\right]$$

HHV_{dry} = 93.12 % / 100.00 x 994.85 Btu / SCF = 926.37 Btu / SCF

Mark's Std Hdbk, 10th ed., pg 4-26
Low Heat Value Dry (LHV_{dry}), calc for Methane (single component for the fuel gas)

$$LHV_{dry}(Btu/SCF) = \left[\left(\frac{M_{\%}}{100}\right) \times NCM\right]$$

LHV_{dry} = 93.12 % / 100.00 x 895.75 Btu / SCF = 834.10 Btu / SCF

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
High Heat Value Wet (HHV_{wet}), calc for entire sample (all components of the fuel gas)

$$HHV_{wet}(Btu/SCF) = \frac{HHV_{dry}}{W/D.factor}$$

HHV_{wet} = 1,018.89 Btu/SCF / 1.0236 = 995.39 Btu/SCF

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
Low Heat Value Wet (LHV_{wet}), calc for entire sample (all components of the fuel gas)

$$LHV_{wet}(Btu/SCF) = \frac{LHV_{dry}}{W/D.factor}$$

LHV_{wet} = 918.76 Btu/SCF / 1.0236 = 897.58 Btu/SCF

Lbs Component per Lb-Mol of Gas (CM), calc for Methane (single component for the fuel gas)

$$CM(lb/lb-mol) = \left[\left(\frac{M_{\%}}{100}\right) \times MW\right]$$

CM = 93.12 % / 100.00 x 16.04 lb / lb-mol = 14.94 lb/lb-mol

ASTM D 3588
Fuel Molecular Weight (MW_{Fuel})

$$MW_{Fuel}(lb/lb \cdot mol) = \left[\sum (CM)\right]$$

MW_{Fuel} = 14.94 lb/lb-mol
\+ 1.48 lb/lb-mol
+ etc. = 17.101 lb/lb-mol

Btu per Lb of Gas Gross (**GCV**)

$$GCV(Btu/lb) = \left[\frac{HHV_{dry} \times G}{MW_{Fuel}}\right]$$

GCV = 1,018.89 Btu/SCF x 385.23 ft^3/lbmol / 17.101 lb/lb-mol = 22,952.17 Btu/lb

ASTM D 3588 (SG)
Specific Gravity

$$SG = \left[\frac{MW_{Fuel}}{MW_{AIR}}\right]$$

SG = 17.10 lb/lb-mol / 28.96 lb/lb-mol = 0.5905

Btu per Lb of Gas Net (**NCV**)

$$NCV(Btu/lb) = \left[\frac{LHV_{dry} \times G}{MW_{Fuel}}\right]$$

NCV = 918.76 Btu/SCF x 385.23 ft^3/lbmol / 17.101 lb/lb-mol = 20,696.74 Btu/lb

Weight Percent of Component ($C_{\%}$), methane

$$C_{\%}(\%) = \left[\left(\frac{CM}{MW_{Fuel}}\right) \times 100\right]$$

$C_{\%}$ = 14.94 lb/lb-mol / 17.10 lb/lb-mol x 100 = 87.36 %

Weight Percent of Volatile Organic Compounds ($VOC_{\%}$)

$$VOC_{\%}(\%) = \left[\sum_{C_3H_8}^{C_8H_{18}} Wt_{\%}\right]$$

$VOC_{\%}$ = 0.53 % + 0.06 % + 0.06 % + etc. = 0.71 %

RM 19, (02-27-14), 12.3.2 Determined **F Factors**. If the fuel burned is not listed in Table 19–2 or if the owner or operator chooses to determine an F factor rather than use the values in Table 19–2, use the procedure below: 12.3.2.1 Equations. Use the eq

RM 19, (02-27-14),
12.1 Nomenclature

K (scf/lb)/%	
H	3.64
C	1.53
S	0.57
N_2	0.14
O_2	0.46

$$F_d = \frac{K(K_{hd}\%H + K_c\%C + K_s\%S + K_n\%N - K_o\%O)}{GCV} \quad \text{Eq. 19-13}$$

F_d = 10^6Btu / MMBtu x [3.64 SCF / lb · % x 23.82 % + 1.53 SCF / lb · % x 73.22 % + 0.57 SCF / lb · % x 0.00 % + 0.14 SCF / lb · % x 1.69 % - 0.46 SCF / lb · % x 1.27 %] x lb / 22,952.17 Btu = 8,643.54 SCF / MMBtu

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RHsp (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp}(lb/lb) = \left[\left(\frac{gr}{lb}\right) \times \frac{lb}{7000\,gr}\right]$$

$$RH_{sp} = \frac{16.47\ gr}{lb} \times \frac{1\ lb}{7000\ gr} = 0.002353\ \frac{lb\ H_2O}{lb\ Air}$$

Fuel Flow Conversion (Q_f)

Note: Qf(lb/min) is a value obtained from the source operator.

$$Q_f = \left[Q_f \times G \times \left(\frac{1}{MW_{Fuel}}\right)\right]$$

$$Q_f = \frac{1{,}672.52\ lb}{min} \times \frac{60\ min}{hr} \times \frac{385.23\ ft^3}{lb\text{-}mol} \times \frac{lb\text{-}mol}{17.10\ lb} = 2{,}260{,}589\ SCFH$$

Heat Rate (MMBtu/hr)

$$HR = \frac{HHV_{DRY} \times Q_f}{1{,}000{,}000}$$

$$\text{Heat Rate} = \frac{1{,}018.89\ Btu}{SCF} \times \frac{2{,}260{,}588.57\ SCF}{hr} \times \frac{MMBtu}{10^6\ Btu} = \frac{2{,}303.28\ MMBtu}{hr}$$

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100 \qquad \text{Eq. 7E-1}$$

$$ACE = \frac{8.73\ ppm - 8.90\ ppm}{17.80\ ppm} \times 100 = -0.96\ \%$$

Calibration Error and Estimated Point, RM 25A, THC/VOC Analyzer

RM 25A, (02-27-14), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC/VOC analyzer mid gas, if applicable)

$$E_P = \frac{C_{Dir(H)} - C_{Dir(Z)}}{C_{V(H)} - C_{V(Z)}} \times C_{Dir(M)} + C_{Dir(Z)}$$

Eq. of a line
y=mx+b

$$E_p = \frac{8.89\ ppm - 0.00\ ppm}{8.77\ ppm - 0.00\ ppm} \times 4.90\ ppm + 0.00 = 4.97\ ppm$$

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100 \qquad \text{Eq. 7E-1}$$

$$ACE_{VOC(} = \frac{5.12\ ppm - 4.97\ ppm}{4.90\ ppm} \times 100 = 3.12\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS}\right) \times 100$$ Eq. 7E-2

SB = $\frac{8.91 \text{ ppm} - 8.73 \text{ ppm}}{17.80 \text{ ppm}}$ x 100 = 1.01 %

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = \left|SB_{final} - SB_i\right|$$ Eq. 7E-4

D = | 1.85 % - 1.01 % | = 0.84 %

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs – Cdir| is ≤ 0.5 ppmv or if |Cs – Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = \left|C_S - C_{Dir}\right|$$ Eq. Section 13.2 and 13.3

SB / D_{Alt} = | 8.91 ppm - 8.73 ppm | = 0.18 ppm

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$ Eq. 7E-5b

C_{Gas} = $\left(2.48 \text{ ppm} - 0.02 \text{ ppm}\right)$ $\left(\frac{8.90 \text{ ppm}}{8.99 \text{ ppm} - 0.02 \text{ ppm}}\right)$ = 2.45 ppm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_W}{1 - B_{WS}}$$ Eq. 7E-10

C_D = $\frac{2.31 \text{ ppmvw}}{1 - 0.06}$ = 2.45 ppmvd or inversely, $C_W = C_D \times \left(1 - B_{WS}\right)$

C_W = 2.45 ppmvd x $\left(1 - 0.06\right)$ = 2.31 ppmvw

Diluent-Corrected Pollutant Concentration, O_2 Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O_2 Concentration. Calculate the O_2 corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$ Eq. 20-4

C_{adj} = 2.45 ppm x $\left(\frac{20.9\% - 15.00\ \%}{20.9\% - 12.88\ \%}\right)$ = 1.80 ppm@15%O_2

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Historical Data	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
Run Start Time	17:02	23:05	14:25		hh:mm	
Run Stop Time	22:11	04:05	18:27		hh:mm	
Test Date	02/17/20	02/17/20	02/19/20		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.974	0.974	0.974			
Pitot Tube Coefficient	0.7240	0.7240	0.7240			
Average Nozzle Diameter	0.156	0.156	0.156		in	
Stack Test Data	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
Initial Meter Volume	328.160	469.310	283.800		ft^3	
Final Meter Volume	433.050	572.890	386.090		ft^3	
Total Meter Volume	104.890	103.580	102.290	103.587	ft^3	
Total Sampling Time	267.75	268.75	263.25	266.58	min	
Average Meter Temperature	67.17	65.17	75.08	69.14	°F	
Average Stack Temperature	189.58	189.75	183.83	187.72	°F	
Barometric Pressure	29.98	29.88	30.12	29.99	in Hg	
Stack Static Pressure	0.95	0.95	0.95	0.95	in H_2O	
Absolute Stack Pressure	30.05	29.95	30.19	30.06	in Hg	
Average Orifice Pressure Drop	0.46	0.46	0.46	0.46	in H_2O	
Absolute Meter Pressure	30.12	30.02	30.26	30.13	in Hg	
Avg Square Root Pitot Pressure	1.16	1.16	1.14	1.15	$\sqrt{(in\ H_2O)}$	
Moisture Content Data	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	116.60	141.10	136.80	131.50	g	
Silica Gel Weight Gain	16.60	12.30	11.50	13.47	g	
Total Water Volume Collected	133.44	153.68	148.57	145.23	ml	
Standard Water Vapor Volume	6.28	7.23	6.99	6.84	scf	
Standard Meter Volume	102.6	101.4	99.1	101.0	dscf	
Standard Metric Meter Volume	2.9	2.9	2.8	2.9	dscm	
Calculated Stack Moisture	5.77	6.66	6.59	6.34	%	
Saturated Stack Moisture	62.60	63.04	55.00	60.22	%	
Reported Stack Moisture Content	5.77	6.66	6.59	6.34	%	
Gas Analysis Data	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	4.9	4.8	4.8	4.8	%	
Oxygen Content	12.7	12.8	12.8	12.8	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.4	82.4	82.4	82.4	%	
Stack Dry Molecular Weight	29.29	29.28	29.28	29.28	lb/lb-mole	
Stack Wet Molecular Weight	28.64	28.53	28.54	28.57	lb/lb-mole	
Calculated Fuel Factor	1.673	1.688	1.688	1.683		
Fuel F-Factor	8643.54	8643.54	8642.95	8643.34	dscf/MMBtu	
Percent Excess Air	140.3	143.0	143.0	142.1	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Volumetric Flow Rate Data	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
Average Stack Gas Velocity	62.27	62.69	60.79	61.92	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft²	
Actual Stack Flow Rate	1,059,379	1,066,428	1,034,195	1,053,334	acfm	
Wet Standard Stack Flow Rate	51,890	52,048	51,347	51,762	wkscfh	
Dry Standard Stack Flow Rate	48,897,988	48,582,890	47,962,021	48,480,966	dscfh	
Percent of Isokinetic Rate	100.7	99.6	100.8	100.4	%	
Gravimetric Analysis	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	ml	
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	mg	
Emission Rate Data	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
Total PM_{10} Mass	7.50	9.30	6.10	7.63	mg	--
Total PM_{10} Concentration	7.31E-05	9.17E-05	6.16E-05	7.54E-05	g/dscf	--
	1.13E-03	1.42E-03	9.50E-04	1.16E-03	gr/dscf	--
Total PM_{10} Emission Rate	3.57	4.46	2.95	3.66	kg/hr	--
	7.88	9.82	6.51	8.07	lb/hr	--
	34.50	43.02	28.51	35.35	tpy	--
	0.0035	0.0045	0.0030	0.0037	lb/MMBtu	0.005
Filterable PM_{10} Mass	3.30	4.70	3.50	3.83	mg	--
Filterable PM_{10} Concentration	3.21E-05	4.63E-05	3.53E-05	3.79E-05	g/dscf	--
	4.96E-04	7.15E-04	5.45E-04	5.86E-04	gr/dscf	--
Filterable PM_{10} Emission Rate	1.57	2.25	1.69	1.84	kg/hr	--
	3.47	4.96	3.74	4.06	lb/hr	--
	15.18	21.74	16.36	17.76	tpy	--
	0.0016	0.0023	0.0017	0.0019	lb/MMBtu	--
Condensable PM_{10} Mass	4.20	4.60	2.60	3.80	mg	--
Condensable PM_{10} Concentration	4.09E-05	4.54E-05	2.62E-05	3.75E-05	g/dscf	--
	6.31E-04	7.00E-04	4.05E-04	5.79E-04	gr/dscf	--
Condensable PM_{10} Emission Rate	2.00	2.20	1.26	1.82	kg/hr	--
	4.41	4.86	2.77	4.01	lb/hr	--
	19.32	21.28	12.15	17.58	tpy	--
	0.0020	0.0022	0.0013	0.0018	lb/MMBtu	--
RM 201A Quality Control	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	**Average**	**Units**	**Limits**
Stack Viscosity	204.09	203.35	202.01	203.15	µP	
Cyclone Flow Rate	0.498	0.497	0.487	0.494	ft³/min	
Dry Gas Sampling Rate	0.383	0.377	0.376	0.379	dscfm	
Reynolds Number	2795.22	2776.75	2786.81	2,786.26		
Recalculated Cunninham	1.079	1.079	1.077	1.079		
Dia. of 50% Prob. (D50) CI	10.49	10.50	10.56	10.52		
Recalculated D50-1 for CIV	2.32	2.33	2.35	2.33		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Δp	0	0	0	0	points	

Nomenclature

- %CO = carbon monoxide concentration (%)
- $\%CO_2$ = carbon dioxide concentration (%)
- $\%N_2$ = nitrogen concentration (%)
- $\%O_2$ = oxygen concentration (%)
- $\%O_{2,wet}$ = Oxygen content of gas stream, % by volume of wet gas. (Note: The oxygen percentage used in Method 201A, Equation 3 is on a wet gas basis. That means that since oxygen is typically measured on a dry gas basis, the measured percent O2 must be multiplied by the quantity (1 - B_{ws}) to convert to the actual volume fraction. Therefore, $\%O_{2,wet} = (1 - B_{ws}) * \%O_{2,\,dry}$)
- $(\%EA)_{avg}$ = average excess air (%)
- $(F_o)_{avg}$ = average calculated fuel factor
- $[(\Delta p)^{0.5}]_{avg}$ = Average of square roots of the velocity pressures measured during the preliminary traverse, inches W.C.
- μ = Gas viscosity, micropoise
- 12.0 = Constant calculated as 60 percent of 20.5 square inch cross-sectional area of combined cyclone head, square inches
- 17.03 = mg/milliequivalents for ammonium ion
- 22.4 = liters of ideal gas per lb-mol of substance at 0^oC and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 24.04 = liters of ideal gas per lb-mol of substance at 20^oC and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 5.02×10^4 = constant derived from the molecular weight and correcting standard temperature and pressure (ref. Bay Area Air Quality Management District, Source Test Procedure ST-1B, Ammonia Integrated Sampling, Adopted January 20, 1982, Regulation 7-303)
- A = distance upstream (in.)
- A_D = stack diameters upstream (dia.)
- An = Area of nozzle, square feet
- A_s = area of stack (ft^2)
- B = distance downstream (in.)
- B_D = stack diameters downstream (dia.)
- b_f = Average blockage factor calculated in Equation 26, dimensionless
- B_{wm} = meter moisture content (%)
- B_{ws} = stack moisture content (%)
- C = Cunningham correction factor for particle diameter, Dp, and calculated using the actual stack gas temperature, dimensionless
- C_1 = -150.3162 (micropoise)
- C_2 = 18.0614 (micropoise/$K^{0.5}$) = 13.4622 (micropoise/$R^{0.5}$)
- C_3 = 1.19183×10^6 (micropoise/K^2) = 3.86153×10^6 (micropoise/R^2)
- C_4 = 0.591123 (micropoise)
- C_5 = 91.9723 (micropoise)
- C_6 = 4.91705×10^{-5} (micropoise/K^2) = 1.51761×10^{-5} (micropoise/R^2)
- C_a = Acetone blank concentration, mg/mg
- C_b = Concentration of NH3 ion in the back half of train (breakthrough)
- C_f = Concentration of NH3 ion in the front half of train (main catch)
- C_{fPM10} = Conc. of filterable PM_{10}, gr/dscf
- $C_{fPM2.5}$ = Conc. of filterable $PM_{2.5}$, gr/dscf
- C_k = K Factor Constant, 849.8

Nomenclature

- C_n = nozzle diameter constant, 0.03575
- C_p' = Coefficient for the pitot used in the preliminary traverse, dimensionless
- C_p = Pitot coefficient for the combined cyclone pitot, dimensionless
- C_{cpm} = Concentration of the condensable PM in the stack gas, dry basis, corrected to standard conditions, milligrams/dry standard cubic foot.
- C_r = Re-estimated Cunningham correction factor for particle diameter equivalent to the actual cut size diameter and calculated using the actual stack gas temperature, dimensionless
- D_{50} = Particle cut diameter, micrometers
- $D_{50(N+1)}$ = D_{50} value for cyclone IV calculated during the N+1 iterative step, micrometers
- D_{50-1} = Re-calculated particle cut diameters based on re-estimated C_r, micrometers
- D_{50LL} = Cut diameter for cyclone I corresponding to the 2.25 micrometer cut diameter for cyclone IV, micrometer
- D_{50N} = D_{50} value for cyclone IV calculated during the Nth iterative step, micrometers
- D_{50T} = Cyclone I cut diameter corresponding to the middle of the overlap zone shown in Method 201A, Figure 10 of Section 17, micrometers
- D_e = equivalent stack diameter (in.)
- ΔH@ = ΔH @ 0.75 scfm (in. H2O)
- ΔH_{avg} = average orifice pressure (in. H_2O)
- D_n = Inner diameter of sampling nozzle mounted on Cyclone I, inches
- D_{na} = actual nozzle diameter (in.)
- D_p = Physical particle size, micrometers
- Δp = velocity head (in. H_2O)
- Δp_1 = velocity head at first current traverse point (in. H_2O)
- $\Delta p'_1$ = velocity head at first preliminary traverse point (in. H_2O)
- Δp_{avg} = average pitot tube differential pressure (in. H_2O)
- Δp_n = velocity head at subsequent current traverse point (in. H_2O)
- Δp_{RM2} = method 2 velocity head (in. H_2O)
- D_s = diameter of stack (in.)
- F_d = fuel f-factor (dscf/MMBtu)
- f_{O2} = stack gas fraction of O_2, by volume, dry basis
- I = Percent isokinetic sampling, dimensionless
- K_1 = standard volume correction, 17.65^{o}R/in. Hg
- K_4 = isokinetic conversion constant, 0.0945min•in.Hg/sec•^{o}R
- K_5 = water mass to std water vapor, 0.04715 ft^3/g
- K_p = 85.49, ((ft/sec)/(pounds/mole -^{o}R))
- L = length of stack (in.)
- L_{fw} = distance to far wall of stack (in.)
- L_{nw} = distance to near wall of stack (in.) [reference]
- $m_{\#x}$ = weight measurements (g)
- M_1 = Milligrams of PM collected on the filter, less than or equal to 2.5 micrometers
- M_2 = Milligrams of PM recovered from Container #2 (acetone blank corrected), greater than 10 micrometers
- M_3 = Milligrams of PM recovered from Container #3 (acetone blank corrected), less than or equal to 10 and greater than 2.5 micrometers
- M_4 = Milligrams of PM recovered from Container #4 (acetone blank corrected), less than or equal to 2.5 micrometers

Nomenclature

- m_a = Mass of residue of acetone after evaporation, mg
- m_c = Mass of the NH4+ added to sample to form ammonium sulfate, mg
- m_{cpm} = Mass of the total condensable PM, mg
- M_d = Molecular weight of dry gas, pounds/pound mole
- m_{fb} = Mass of total CPM in field train recovery blank, mg
- m_{fx} = final weight, avg of last two measurements (g)
- mg = Milligram
- mg/L = Milligram per liter
- m_i = Mass of inorganic CPM, mg
- m_{ib} = Mass of inorganic CPM in field train recovery blank, mg
- M_n = total particulates (mg)
- m_o = Mass of organic CPM, mg
- m_{ob} = Mass of organic CPM in field train blank, mg
- m_r = Mass of dried sample from inorganic fraction, mg
- m_{tx} = tare weight (g)
- MW = molecular weight (lb/lb-mole)
- M_w = Molecular weight of wet gas, pounds/pound mole
- N = Normality of ammonium hydroxide titrant
- N_a = null angle (deg.)
- N_{re} = Reynolds number, dimensionless
- N_{tp} = Number of iterative steps or total traverse points
- P_b = P_{bar} = barometric pressure (in. Hg)
- P_{bar} = barometric pressure (in. Hg)
- ppmCO = carbon monoxide concentration (ppm)
- ppmv = Parts per million by volume
- ppmw = Parts per million by weight
- P_s = absolute stack pressure (in. Hg)
- P_{static} = static pressure (in. H_2O)
- P_{std} = standard pressure, 29.92 in. Hg
- Θ = total sampling time (min)
- Q_{aw} = average stack wet flow rate (ascf/min)
- Q_l = Sampling rate for cyclone I to achieve specified D_{50}
- Q_m = estimated orifice flow rate, 0.750 acfm, else Vm/Q from previous run
- Q_s = Sampling rate for cyclone I to achieve specified D_{50}
- $Q_{s(std)}$ = total cyclone flow rate at standard conditions (dscf/min)
- Q_{sd} = dry standard stack flow rate (dscfm)
- Q_{sST} = Dry gas sampling rate through the sampling assembly, dscfm
- Q_{sw} = wet standard stack flow rate (ascfm)
- R_{max} = Nozzle/stack velocity ratio parameter, dimensionless
- R_{min} = Nozzle/stack velocity ratio parameter, dimensionless
- t_1 = Sampling time at point 1, min
- t_m = average gas meter temperature (^oF)
- t_m = average meter temperature (^oF)
- T_m = Meter box and orifice gas temperature, ^oR
- t_n = Sampling time at point n, min

Nomenclature

- t_r = Total projected run time, min
- T_s = Absolute stack gas temperature, ^oR
- T_{std} = standard temperature, 68^oF, 528^oR
- T_u = absolute temperature offset, 460^oR
- V_a = Volume of acetone blank, ml
- V_{aw} = Volume of acetone used in sample recovery wash, ml
- V_b = Volume of aliquot taken for IC analysis, ml
- V_c = Quantity of water captured in impingers and silica gel, ml
- V_f = final impinger volume (ml)
- V_i = initial impinger volume (ml)
- V_{ic} = Volume of impinger contents sample, ml
- V_m = Dry gas meter volume sampled, acf
- $V_{m(std)}$ = standard meter volume (dscf)
- v_{max} = Maximum gas velocity calculated from Equations 18 or 19, ft/sec
- v_{max} = maximum nozzle velocity (ft/sec)
- V_{mf} = final dry gas meter reading (dcf)
- V_{mi} = initial dry gas meter reading (dcf)
- v_{min} = Minimum gas velocity calculated from Method 201A, Equations 16 or 17, ft/sec
- V_{ms} = Dry gas meter volume sampled, corrected to standard conditions, dscf
- v_n = Sample gas velocity in the nozzle, ft/sec
- v_{org} = organics wash volume (ml)
- V_p = Volume of water added during train purge
- v_s = average stack gas velocity (ft/sec)
- v_{sl} = local velocity (ft/sec)
- V_t = total impinger volume (ml) = ;(V_f-V_i)
- V_t = Volume of NH4OH titrant, ml
- $V_{w(std)}$ = volume of water vapor in gas sample at standard conditions (scf)
- v_x = blank volume (ml)
- W = width of stack (in.)
- $W_{2,3,4}$ = Weight of PM recovered from Containers #2, #3, and #4, mg
- W_a = Weight of blank residue in acetone used to recover samples, mg
- W_f = final impinger weight (g)
- W_i = initial impinger weight (g)
- W_t = total impinger weight (g) = ;(W_f-W_i)
- w_x = blank weight of solids (g)
- Y = meter calibration factor (a.k.a gamma)
- Z = Ratio between estimated cyclone IV D_{50} values, dimensionless
- γ = Dry gas meter gamma value, dimensionless
- ΔH = Meter box orifice pressure drop, inches W.C.
- ΔH@ = Pressure drop across orifice at flow rate of 0.75 scfm at standard conditions, inches W.C. (Note: Specific to each orifice and meter box.)
- Δp_1 = Velocity pressure measured at point 1, inches W.C.
- Δp_{avg} = Average velocity pressure, inches W.C.
- Δp_m = Observed velocity pressure using S-type pitot tube in preliminary traverse, inches W.C.
- Δp_{max} = Maximum velocity pressure, inches W.C.

Nomenclature

- Δp_{min} = Minimum velocity pressure, inches W.C.
- Δp_n = Velocity pressure measured at point n during the test run, inches W.C.
- Δp_s = Velocity pressure calculated in Method 201a, Equation 25, inches W.C.
- Δp_{s1} = Velocity pressure adjusted for combined cyclone pitot tube, inches W.C.
- Δp_{s2} = Velocity pressure corrected for blockage, inches W.C.
- θ = Total run time, min
- ρ_a = Density of acetone, mg/ml (see label on bottle)
- Σ_n = total number of sampling points

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{mw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]

Carbon Monoxide Concentration (%)

$$\%CO = \frac{ppmCO}{10{,}000}$$

$$\%CO\ (\%) = \frac{0.00 \quad ppm}{10{,}000\ ppm/\%} = 0.0000\ \%$$

Nitrogen Concentration (%)

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$\%N_2$ (%) = 100 - 4.90 % - 12.70 % - 0.00 / 10,000 % = 82.4 %

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d\,(lb/lb-mol) = \sum\left(\frac{MW_{comp}}{100} \times \%component\right)$$

$$M_d\ (lb/lb\text{-}mol) = \left(\frac{44\ lb/lb\text{-}mol}{100} \times 4.90\ \%\right) +$$

$$\left(\frac{32\ lb/lb\text{-}mol}{100} \times 12.70\ \%\right) + \left(\frac{28\ lb/lb\text{-}mol}{100} \times \left[\frac{0.00}{10{,}000} + 82.40\ \right]\right) = \frac{29.29\ lb}{lb\text{-}mol}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_S\,(lb/lb-mol) = \left[M_d \times \left(1 - \frac{B_{WS}}{100}\right)\right] + \left[MW_{H_2O} \times \frac{B_{WS}}{100}\right]$$

$$M_S\ (lb/lb\text{-}mol) = \left\{\frac{29.29\ lb}{lb\text{-}mol} \times \left(1 - \frac{5.77\ \%}{100}\right)\right\} + \left\{\frac{18\ lb}{lb\text{-}mol} \times \frac{5.77\ \%}{100}\right\} = \frac{28.64\ lb}{lb\text{-}mol}$$

Average Calculated Fuel Factor (F_o)

$$F_{o(avg)} = \frac{\left[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - 12.70\ \% - (0.5 \times 0.000\ \%)}{4.90\ \% + 0.000\ \%} = 1.673$$

Average Excess Air (%)

$$\%EA_{avg}\,(\%) = \frac{100 \times \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(0.264 \times (N_2)_{avg}) - \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{\ 12.70\ \% - (0.5 \times 0.000\ \%)\ \}}{(\ 0.264 \times 82.40\ \%) - \{\ 12.70\ \% - (0.5 \times 0.000\ \%)\}} = 140.28\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]

Absolute Stack Pressure (in. Hg)

$$P_S(in.Hg) = P_b + \frac{P_{static}}{13.6}$$

P_s (in. Hg) = 29.98 in. Hg + $\frac{0.95 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.05 in. Hg

Average Stack Gas Velocity (ft/sec)

$$v_s(ft/\sec) = K_p \times C_p \times \left(\sqrt{\Delta p}\right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

v_{sl} (ft/sec) =

$\left(\frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\sec \quad (^oR)(\text{in. } H_2O)}\right)^{1/2}$ x 0.72 x 1.16 in.$H_2O^{1/2}$ x $\sqrt{\frac{189.58 + 460\ ^oR}{30.05 \text{ in. Hg x } 28.64 \text{ lb/lb-mol}}}$ = $\frac{62.2 \text{ ft}}{\sec}$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd}(dscfh) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sd} (dscf/hr) = $\frac{3600 \text{ sec}}{\text{hr}}$ x (1 - $\frac{5.77\ \%}{100}$) x $\frac{62.27 \text{ ft}}{\sec}$ x 283.53 ft^2 x $\frac{68.00 + 460\ ^oR}{189.58 + 460\ ^oR}$ x $\frac{30.05 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{48,897,988.27 \text{ dscf}}{\text{hr}}$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw}(acfm) = 60 \times v_s \times A_s$$

Q_{aw} (acf/min) = $\frac{60 \text{ sec}}{\text{min}}$ x $\frac{62.27 \text{ ft}}{\sec}$ x 283.53 ft^2 = $\frac{1,059,378.51 \text{ acf}}{\text{min}}$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw}(ascfh) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sw} (ascf/hr) = $\frac{60 \text{ min}}{\text{hr}}$ x $\frac{1,059,378.51 \text{ acf}}{\text{min}}$ x $\frac{68.00 + 460\ ^oR}{189.58 + 460\ ^oR}$ x $\frac{30.05 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{51,889,826.82 \text{ ascf}}{\text{hr}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 133.20 g x 0.04715 ft^3/g = 6.280 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65\ ^\circ R}{\text{in. Hg}} \times 0.97 \times 104.89\ \text{dcf} \times \frac{29.98\ \text{in. Hg} + \frac{0.46\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}}}{67.17\ ^\circ F + 460\ ^\circ R} = 102.65\ \text{dscf}$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{6.28\ \text{dscf}}{6.28\ \text{dscf} + 102.65\ \text{dscf}} = 5.77\ \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)}(\%) = 100 \times \frac{10^{6.691 - \frac{3144}{t_{s(avg)} + 390.86}}}{P_b + \frac{P_{static}}{13.6}} \le 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left(6.691 - \frac{3144}{189.58\ ^\circ F + 390.86}\right)}}{29.98\ \text{in. Hg} + \frac{0.95\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}}} \le 100 = 62.60\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Desired Orifice (in. H_2O) (first point)

$$\Delta H_d\,(in.H_2O) = K \times \Delta p$$

ΔH_d (in. H_2O) = x

in. H_2O = in. H_2O

Absolute Meter Pressure (in. Hg)

$$P_m\,(in.Hg) = P_b + \frac{\Delta H\,@}{13.6}$$

P_m (in. Hg) = 29.98 in. Hg + $\frac{1.88 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.12 in. Hg

Recommended Nozzle Diameter (in.)

$$D_{nt}\,(in.) = \sqrt{\frac{C_{ti} \times Q_{mi} \times P_{mi}}{(t_{mi} + T_{ti}) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}}\right)} \times \sqrt{(t_s + T_{ti}) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}{P_s \times \Delta p_{avg}}\right]}$$

$$D_{ni}\,(in.) = \sqrt{\frac{0.03575 \text{ (lb-mole•°R•in. } H_2O)^{1/2}\text{•min•in.}^2}{\text{acf•in. Hg}^{3/4}\text{•lb}^{1/2}} \text{ x } 0.75 \text{ acf x } 30.12 \text{ in. Hg } \left(1 - \frac{0.00\ \%}{100}\right) \text{ x } \left(\frac{1}{1 - \frac{5.77\ \%}{100}}\right) \text{ x } \sqrt{(189.58 \text{ °F} + 460\text{°R}) \text{ x } \frac{\frac{29.29 \text{ lb}}{\text{lb-mole}} \text{ x } \left(1 - \frac{5.77\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{5.77\ \%}{100}\right)}{30.05 \text{ in. Hg x } 1.16 \text{ in. } H_2O}}} = 0.221 \text{ in.}$$

ΔP to ΔH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H\,@ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100}\right) + \left(18 \times \frac{B_{wm}}{100}\right)}{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}\right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}}\right)^2 \times \left(\frac{t_m + T_u}{ts + T_u}\right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. } H_2O\text{•in.}^4} \text{ x } 0.72^2 \text{ x } 1.88 \text{ in. } H_2O \text{ x } 0.16^4 \text{ x } \left(\frac{1 - \frac{5.77\ \%}{100}}{1 - \frac{0.00\ \%}{100}}\right)^2 \text{ x } \frac{67.17 \text{ °F} + 460\text{°R}}{189.58 \text{ °F} + 460\text{°R}} \text{ x } \left(\frac{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{0.00\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{0.00\ \%}{100}\right)}{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{5.77\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{5.77\ \%}{100}\right)}\right) \text{ x } \frac{30.05 \text{ in. Hg}}{30.12 \text{ in. Hg}} = 0.36$$

Percent Isokinetic (%) (first point)

$$I\,(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I\,(\%) = \frac{\frac{0.0945 \text{ min•in. Hg}}{\text{sec•°R}} \text{ x } (189.00 \text{ °F} + 460\text{ °R}) \text{ x } 8.32 \text{ dscf}}{22.00 \text{ min x } \frac{61.28 \text{ ft}}{\text{sec}} \text{ x } 30.05 \text{ in. Hg x } 3.14 \text{ x } \left(\frac{0.16 \text{ in.}}{2} \text{ x } \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \text{ x } \left(1 - \frac{5.77\ \%}{100}\right)} = 100.69\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Cumulative Percent Isokinetic (%) (weighted average of all points)

$$I(\%) = \sum_{1-n} \frac{\left[I(\%) \times V_{m(std)}\right]_{1-n}}{V_{m(std)_{1-n}}}$$

Using Method 5, Eq 5-8 to determine intermediate isokinetics at each point, weighted averaging of the cumulative isokinetics is necessary since all points are not equal, and determined by using the dry standard meter volume collected at each point to weight the cumulative average. Intermediate isokinetics and dry standard meter volumes are found at each point. At each point the cumulative sum is found of each value and the quotient of the two used to determine the cumulative isokinetics for each residual point (n).

Pt	In (%)	x	Vm(std)n	=	I (%)n	∑(I (%)n)	/	∑(Vm(std)n)	=	I (%)
A-1	100.69	x	8.319	=	837.62	837.62	/	8.32	=	100.7
A-2	94.90	x	8.408	=	797.87	1635.50	/	16.73	=	97.8
A-3	99.71	x	8.238	=	821.46	2456.96	/	24.97	=	98.4
B-1	99.62	x	8.225	=	819.34	3276.30	/	33.19	=	98.7
B-2	100.03	x	8.876	=	887.85	4164.14	/	42.07	=	99.0
B-3	106.51	x	8.793	=	936.59	5100.73	/	50.86	=	100.3
C-1	106.60	x	9.460	=	1008.43	6109.16	/	60.32	=	101.3
C-2	95.14	x	8.436	=	802.54	6911.70	/	68.75	=	100.5
C-3	103.04	x	8.500	=	875.86	7787.57	/	77.25	=	100.8
D-1	105.01	x	8.657	=	909.07	8696.64	/	85.91	=	101.2
D-2	93.01	x	8.241	=	766.45	9463.09	/	94.15	=	100.5
D-3	102.73	x	8.488	=	871.93	10335.02	/	102.64	=>	100.7

Last Pt

Percent Isokinetic (%) (intermediate equation, all points)
[equivalent to taking an average of point-by-point isokinetics without weighting the average (e.g. all points equal)]

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I(\%) = \frac{\frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^{\circ}\text{R}} \times (189.58\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times 102.65 \text{ dscf}}{267.75 \text{ min} \times \frac{62.27 \text{ ft}}{\text{sec}} \times 30.05 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \times \left(1 - \frac{5.77\ \%}{100}\right)} = 100.54\ \%$$

Raw Data Percent Isokinetic (%)
[utilizes the raw data equation for isokinetics from Method 5]

$$I(\%) = \frac{100\left((t_s)_{avg} + T_u\right)\left[K_4 V_{1c} + \frac{V_m Y}{(t_m)_{avg} + T_u}\left(P_{bar} + \frac{\Delta H}{13.6}\right)\right]}{60\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right)}$$

$$I(\%) = \frac{100 \times (189.58\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times \left[\frac{0.002669 \text{ ft}^3\text{•in. Hg}}{\text{ml•}^{\circ}\text{R}} \times 133.4 \text{ ml} + \frac{104.89 \text{ dcf} \times 0.974}{67.17\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}} \left(29.98 \text{ in Hg} + \frac{1.158}{13.6}\right)\right]}{60 \times 267.75 \text{ min} \times \frac{62.27 \text{ ft}}{\text{sec}} \times 30.05 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2} = 100.65\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Gravimetric Analysis) [Values from Run 1 test]

Blank Concentration [Acetone Blank Weight of Solids] (mg/ml)

$$C_x\,(mg/ml) = \frac{1000 \times w_x}{v_x}$$

C_x (mg/ml) = $\frac{1000\ mg}{g}$ x $\frac{0.0000\ g}{200.60\ ml}$ = $\frac{0.0000\ mg}{ml}$ = $\frac{\quad mg}{ml}$

Blank Adjustment [Acetone Blank Weight of Solids and Nozzle Wash PM>10] (mg)

$$W_x\,(mg) = v_x \times C_x$$

W_x (mg) = 100 ml x 0.0000 mg/ml = 0.00 mg < Sample Gain

Sample Gain [Nozzle Wash PM>10] (mg)

$$m_x\,(mg) = \left(m_{fx} - m_{tx}\right) \times 1000$$

m_x (mg) = $\frac{1000\ mg}{g}$ x (0.0162 g - 0.00 g) = 16.20 mg

Adjusted Sample Gain [Nozzle Wash PM>10] (mg)

$$m_{xadj}\,(mg) = m_x - W_x$$

m_{xadj} (mg) = 16.2 mg - 0.00 mg = 16.20 mg

0.1N NH_4OH Correction (mg)

$$m_c\,(mg) = 17.03 \times V_t \times N$$

m_c (mg) = 17.03 x 0.00 ml x 0.1 N = 0.00 mg

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - Total PM_{10} Mass]

Stack Total Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s \text{ (g/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{7.50 mg}}{\text{102.65 dscf}} = \frac{\text{7.31E-05 g}}{\text{dscf}}$$

Stack Total Concentration (gr/dscf)

$$c_s'(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s \text{ (gr/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{7.50 mg}}{\text{102.65 dscf}} \times \frac{\text{7000 gr}}{\text{lb}} \times \frac{\text{lb}}{\text{453.592 g}} = \frac{\text{1.13E-03 gr}}{\text{dscf}}$$

Total Emissions Rate (kg/hr)

$$E(kg/hr) = c_s \times Q_{sd} \times \frac{kg}{1000\ g}$$

$$E \text{ (kg/hr)} = \frac{\text{kg}}{\text{1000 g}} \times \frac{\text{7.31E-05 g}}{\text{dscf}} \times \frac{\text{48,897,988 dscf}}{\text{hr}} = \frac{\text{3.57 kg}}{\text{hr}}$$

Total Emissions Rate (lb/hr)

$$E'(lb/hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{lb \times g}{453.592 g \times 1000 mg}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{7.50 mg}}{\text{102.65 dscf}} \times \frac{\text{48,897,988 dscf}}{\text{hr}} = \frac{\text{7.88 lb}}{\text{hr}}$$

Total Emissions Rate (tpy)

$$E''(ton/yr) = E' \times \frac{8760}{2000}$$

$$E'' \text{ (tpy)} = \frac{\text{ton}}{\text{2000 lb}} \times \frac{\text{8,760 hr}}{\text{yr}} \times \frac{\text{7.88 lb}}{\text{hr}} = \frac{\text{34.50 ton}}{\text{yr}}$$

Total Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{7.50 mg}}{\text{102.65 dscf}} \times \frac{\text{8,643.54 dscf}}{\text{MMBtu}} \times \left(\frac{\text{20.9}}{\text{20.9 - 12.7 \%}}\right) = \frac{\text{0.0035 lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Stack Gas Viscosity (μP) [based on preliminary data] [RM 201A, Eq. 3]

$$\mu(\mu P) = C_1 + C_2\sqrt{T_s} + C_3 T_s^{-2} + C4(\%O_{2,wet}) - C_5 B_{ws} + C_6 B_{ws} T_s^2$$

μ (μP) = -150.3162 μP + 13.4622 $\sqrt{\quad 185 \quad + 460}$ + 3.86153x10^{6} (185 + 460)$^{-2}$ + 0.591123 (13.0 x (1 - 8.00 /100)
- 91.9723 (8.00 /100) + 1.51761x10^{-5} (8.00 /100)(185 + 460)^2 = 201.12 μP

Cunningham Correction Factor [RM 201A, Eq. 4]
[based on preliminary data for a 2.25 micrometer diameter particle]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{201.12\ \mu P}{29.80\ \text{in Hg} \times 2.25\ \mu m}\right)\left(\frac{185 + 460\ ^{o}R}{28.40\ \text{lb / lb-mole}}\right)^{0.5} = 1.08$$

First calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}<3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 5]
[assumes N_{re}<3,162]

$$D_{50LL}(\mu m) = 9.507 C^{0.3007}\left[\frac{M_w P_s}{T_s}\right]^{0.1993}$$

$$D_{50LL}\ (\mu m) = 9.507 \times 1.08^{\,0.3007} \times \left(\frac{29.80\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{185 + 460\ ^{o}R}\right)^{0.1993} = 10.28\ \mu m$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}<3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

$$D_{50T}\ (\mu m) = \frac{11 + 10.28\ \mu m}{2} = 10.64\ \mu m$$

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}<3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu)\left[\frac{T_s}{M_w P_s}\right]^{0.2949}\left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

$$0.07296 \times 201.12\ \mu P \times \left(\frac{185 + 460\ ^{o}R}{29.80\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}\right)^{0.2949} \times \left(\frac{1}{10.64\ \mu m}\right)^{1.4102} = 0.48\ \text{acfm}$$

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5\left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

$$N_{re} = 8.64 \times 10^5 \times \frac{29.80\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{185 + 460\ ^{o}R} \times \frac{0.48\ \text{acfm}}{201.12\ \mu P} = 2720.44 < 3{,}162$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Second calculation set using Cyclone IV, assuming N_{re}<3,162

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (μm) [RM 201A, Eq. 34]
[assumes N_{re}<3,162]

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (μm) =

0.0024302 x (201.12 μP / 0.48 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (185 + 460 °R / 29.80 in Hg x 28.40 lb / lb-mole)$^{0.6790}$ = 2.38 μm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Less than 3,162 (acfm) [RM 201A, Eq. 8]

$$Q_{IV}(acfm) = 0.0060639 \left(\frac{\mu}{C^{0.4242}}\right) \left[\frac{P_s M_w}{T_s}\right]^{-.05759} \left[\frac{1}{D_{50}}\right]^{0.8481}$$

Q_{IV} (acfm) =

0.0060639 x (201.12 μP / 1.08 $^{0.4242}$) x (29.80 in Hg x 28.40 lb / lb-mole / 185 + 460 °R)$^{-0.5759}$ x (1 / 2.38 μm)$^{0.8481}$ = 0.48 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

N_{re} = 8.64 x 10^5 x 29.80 in Hg x 28.40 lb / lb-mole / 185 + 460 °R x 0.48 acfm / 201.12 μP = 2720.40 < 3,162

Third calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}≥3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 12]
[assumes N_{re}≥3,162]

$$D_{50LL}(\mu m) = 10.0959 C^{0.4400} \left[\frac{M_w P_s}{T_s}\right]^{0.0600}$$

D_{50LL} (μm) = 10.0959 x 1.08 $^{0.4400}$ x (29.80 in Hg x 28.40 lb / lb-mole / 185 + 460 °R)$^{0.0600}$ = 10.62 μm

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}≥3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

D_{50T} (μm) = (11 + 10.62 μm) / 2 = 10.81 μm

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}≥3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu) \left[\frac{T_s}{M_w P_s}\right]^{0.2949} \left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

0.07296 x 201.12 μP x (185 + 460 °R / 29.80 in Hg x 28.40 lb / lb-mole)$^{0.2949}$ x (1 / 10.81 μm)$^{1.4102}$ = 0.47 acfm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (29.80 in Hg x 28.40 lb / lb-mole) / (185 + 460 °R) x (0.47 acfm) / (201.12 µP) = 2659.02 < 3,162

Fourth calculation set using Cyclone IV, assuming N_{re}≥3,162

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]
[assumes N_{re}≥3,162]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x ((201.12 µP) / (0.47 acfm))$^{0.8058}$ x ((1) / (1.08))$^{0.5}$
x ((185 + 460 °R) / (29.80 in Hg x 28.40 lb / lb-mole))$^{0.3058}$ = 2.30 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Greater than or Equal to 3,162 (acfm) [RM 201A, Eq. 9]

$$Q_{IV}(acfm) = 0.007657 \left(\frac{\mu}{C^{0.6205}}\right)\left[\frac{P_s M_w}{T_s}\right]^{-0.3795}\left[\frac{1}{D_{50}}\right]^{1.241}$$

Q_{IV} (acfm) =

0.007657 x ((201.12 µP) / (1.08 $^{0.6205}$)) x ((29.80 in Hg x 28.40 lb / lb-mole) / (185 + 460 °R))$^{-0.3795}$
x ((1) / (2.30 µm))$^{1.241}$ = 0.47 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (29.80 in Hg x 28.40 lb / lb-mole) / (185 + 460 °R) x (0.48 acfm) / (201.12 µP) = 2720.44 < 3,162

Meter Box Orifice Pressure Drop (in H_2O) [RM 201A, Eq. 11]
As calculated using applicable calculation set 1, 2, 3, or 4

$$\Delta H(inH_2O) = \left[\frac{Q_s(1-B_{ws})P_s}{T_s}\right]^2\left[\frac{1.083 T_m M_d \Delta H_@}{P_{bar}}\right]$$

ΔH (in H_2O) = (0.48 acfm x (1 - 8.00 /100) x 29.80 in Hg) / (185 + 460 °R)^2
x (1.083 x (85.00 + 460 °R) x 29.30 lb / lb-mole x 1.878 in H_2O) / (29.73 in Hg) = 0.460 in H_2O

50 °F above stack temperature	T_{s+50} =	235	ΔH_{+50} =	0.396 in H_2O
50 °F below stack temperature	T_{s+50} =	135	ΔH_{+50} =	0.540 in H_2O

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Adjusted Velocity Pressure (in H_2O) [point A-1] [RM201A, Eq. 25]

$$\Delta p_s\,(inH_2O) = \Delta p_m \left[\frac{C_p}{C'_p}\right]^2$$

Δp_s (in H_2O) = 1.50 in H_2O x (0.7240 / 0.8198)^2 = 1.17 in H_2O

Average Probe Blockage Factor [RM201A, Eq. 26]

$$b_f = \frac{22.0}{A}$$

b_f = 22.0 / 40828.14 in^2 = 5.39E-04

Velocity Pressure Adjusted for Blockage Factor (in H_2O) [point A-1] [RM201A, Eq. 27]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$\Delta p_{s2}\,(inH_2O) = \Delta p_{s1}\left[\frac{1}{(1-b_f)}\right]^2$$

Δp_s (in H_2O) = 1.17 in H_2O x (1 / (1 - 0.00E+00))^2 = 1.17 in H_2O

Velocity of Stack Gas Adjusted for Blockage Factor and/or C_p / C'_p (ft/sec) [RM201A, Eq. 13]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$v_s = K_p C_p \left(\sqrt{(\Delta p)}\right)_{avg}\left[\sqrt{\frac{T_s}{P_s M_w}}\right]$$

v_s (ft/sec) =

85.49 ft/sec / lb/mole - °R x 0.7240 x 1.04 x (185 + 460 °R / 29.80 in Hg x 28.40 lb / lb-mole)$^{0.5}$ = 55.95 ft/sec

Calculated Nozzle Diameter for Acceptable Sampling Rate (in) [RM201A, Eq. 14]

$$D(in) = \left[\frac{3.056 Q_s}{v_s}\right]^{0.5}$$

D (in) = (3.056 x 0.48 acfm / 55.95 ft/sec)$^{0.5}$ = 0.162 in

Represents ideal diameter, which we then compare to capabilities of all nozzles from multiple sets

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Velocity of Gas in Nozzle 4b (diam. = 0.156 in), (ft/sec) [RM201A, Eq. 15]

$$v_n = \frac{\left(\frac{Q_s}{60\ \frac{\text{min}}{\text{sec}}}\right)}{A_n}$$

v_n (ft/sec) = $\frac{0.48 \text{ acfm}}{60 \text{ min / sec}}$ / 1.33E-04 ft^2 = 60.62 $\frac{ft}{sec}$

Example set of calculations for nozzle used with run 1

Minimum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 16]

Nozzle 4b (diam. = 0.156 in)

$$R_{min} = \left[0.2457 + \left(0.3072 - \frac{0.2603\ (\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{min} =

$$0.2457 + \left(0.3072 - \frac{0.2603 \times 201.12\ \mu P \times (0.48\ \text{acfm})^{0.5}}{60.62\ in^{1.5}}\right)^{0.5} = 0.73$$

Maximum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 17]

Nozzle 4b (diam. = 0.156 in)

$$R_{max} = \left[0.4457 + \left(0.5690 + \frac{0.2603\ (\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{max} =

$$0.4457 + \left(0.5690 + \frac{0.2603 \times 201.12\ \mu P \times (0.48\ \text{acfm})^{0.5}}{60.62\ in^{1.5}}\right)^{0.5} = 1.25$$

Minimum Gas Velocity for R_{min} Less than 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{min}\ (ft/sec) = v_n(0.5)$ v_{min} (ft/sec) = 0.5 x $\frac{ft}{sec}$ = $\frac{ft}{sec}$ **[RM201A, Eq. 18]**

Not Applicable

Minimum Gas Velocity for R_{min} Greater than or Equal to 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{min}\ (ft/sec) = v_n R_{min}$ v_{min} (ft/sec) = 60.62 $\frac{ft}{sec}$ x 0.73 = 43.97 $\frac{ft}{sec}$ **[RM201A, Eq. 19]**

Maximum Gas Velocity for R_{max} Less than 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{max}\ (ft/sec) = v_n R_{max}$ v_{max} (ft/sec) = 60.62 $\frac{ft}{sec}$ x 1.25 = 75.74 $\frac{ft}{sec}$ **[RM201A, Eq. 20]**

Maximum Gas Velocity for R_{max} Greater than or Equal to 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{max}\ (ft/sec) = v_n(1.5)$ v_{max} (ft/sec) = 1.5 x $\frac{ft}{sec}$ = $\frac{ft}{sec}$ **[RM201A, Eq. 21]**

Not Applicable

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Minimum Velocity Pressure (in H_2O) [RM201A, Eq. 22] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{min} below preliminary data minimum

$$\Delta p_{min}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{min}}{C_p}\right]^2$$

Δp_{min} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{29.80 \text{ in Hg} \times 28.40 \text{ lb / lb-mole}}{185 + 460\ ^{o}R}\right) \times \left(\frac{43.97 \text{ ft/sec}}{0.7240}\right)^2 =$ 0.66 in H_2O vs. 1.01

Maximum Velocity Pressure (in H_2O) [RM201A, Eq. 23] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{max} above preliminary data maximum

$$\Delta p_{max}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{max}}{C_p}\right]^2$$

Δp_{max} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{29.80 \text{ in Hg} \times 28.40 \text{ lb / lb-mole}}{185 + 460\ ^{o}R}\right) \times \left(\frac{75.74 \text{ ft/sec}}{0.7240}\right)^2 =$ 1.96 in H_2O vs. 1.17

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sampling Dwell Time at Each Point (minutes) [point A-1] [RM201A, Eq. 24]

$$t_n(\text{min}) = \left[\frac{C_p\sqrt{\Delta p_n}}{C_p'\left(\sqrt{\Delta p_n}\right)_{avg}}\right]\left[\frac{t_r}{N_{tp}}\right]$$

t_n (min) = $\left(\frac{0.7240 \times (1.30)^{0.5}}{0.7240 \times 1.04}\right) \times \left(\frac{240.00 \text{ min}}{12.00}\right) =$ 22.03 minutes

Dry Gas Volume Sampled at Standard Conditions (dscf) [point A-1] [RM201A, Eq. 28]

$$v_{ms}(dscf) = \left[\frac{528}{29.92}\right][\gamma \cdot v_m]\left[\frac{\left(P_{bar} + \frac{\Delta H}{13.6}\right)}{T_m}\right]$$

v_{ms} (dscf) = $\left(\frac{528}{29.92}\right)$ (0.974 x 8.45 dcf) x

$\left(\frac{29.98 \text{ in Hg} + 0.46 \text{ in } H_2O / 13.6}{64.00 + 460\ ^{o}R}\right) =$ 8.32 dscf

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sample Flow Rate at Standard Conditions (dscfm) [RM201A, Eq. 29]

$$Q_{sST}\,(dscfm) = \frac{v_{ms}}{\Theta}$$

Q_{sST} (dscf) = $\frac{102.65 \text{ dscf}}{267.75 \text{ min}}$ = $\frac{0.38 \text{ dscf}}{\text{min}}$

Sampling Rate (acfm) [e.g. cyclone flow rate] [RM201A, Eq. 32]

$$Q_s(acfm) = \frac{29.92}{528} Q_{sST} \left[\frac{1}{(1 - B_{ws})}\right]\left[\frac{T_s}{P_s}\right]$$

Q_s (acfm) = $\frac{29.92 \text{ in Hg}}{528\ ^{o}\text{R}}$ x $\frac{0.38 \text{ dscf}}{\text{min}}$ x $\frac{1}{(1 - 5.77 /100)}$ x $\frac{190 + 460\ ^{o}\text{R}}{30.05 \text{ in Hg}}$ = 0.50 acfm

Actual Conditions Reynolds Number (dimensionless) [RM 201A, Eq. 10]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

N_{re} = 8.64 x 10^5 x $\frac{30.05 \text{ in Hg x } 28.64 \text{ lb / lb-mole}}{190 + 460\ ^{o}\text{R}}$ x $\frac{0.50 \text{ acfm}}{204.09 \text{ µP}}$ = 2795.22

Actual Conditions Particle Cut Diameter for Cyclone I (µm) [RM201A, Eq. 33]

$$D_{50}(\mu m) = 0.15625 \left[\frac{T_s}{M_w P_s}\right]^{0.2091} \left[\frac{\mu}{Q_s}\right]^{0.7091}$$

D_{50} (µm) = 0.15625 x ($\frac{190 + 460\ ^{o}\text{R}}{30.05 \text{ in Hg x } 28.64 \text{ lb / lb-mole}}$)$^{0.2091}$ x ($\frac{204.09 \text{ µP}}{0.50 \text{ acfm}}$)$^{0.7091}$ = 10.49 µm

Actual Particle Cut Diameter for Cyclone IV is determined by:

Actual Conditions Cunningham Correction Factor [RM 201A, Eq. 4]
[for a 2.5 micrometer diameter particle (estimated size)]

$$C = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x ($\frac{204.09 \text{ µP}}{30.05 \text{ in Hg x } 2.5 \text{ µm}}$)($\frac{190 + 460\ ^{o}\text{R}}{28.64 \text{ lb / lb-mole}}$)$^{0.5}$ = 1.07

Actual Conditions Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) =

0.0024302 x ($\frac{204.09 \text{ µP}}{0.50 \text{ acfm}}$)$^{1.1791}$ x ($\frac{1}{1.07}$)$^{0.5}$

x ($\frac{190 + 460\ ^{o}\text{R}}{30.05 \text{ in Hg x } 28.64 \text{ lb / lb-mole}}$)$^{0.6790}$ = 2.33 µm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Actual Conditions Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Re-calculated Cunningham Correction Factor (dimensionless) [RM 201A, Eq. 36]

$$C_r = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x (204.09 µP / 30.05 in Hg x 2.33 µm)(190 + 460 °R / 28.64 lb / lb-mole)$^{0.5}$ = 1.08

Re-calculated Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 37]

$$D_{50-1}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50-1} (µm) =

0.0024302 x (204.09 µP / 0.50 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (190 + 460 °R / 30.05 in Hg x 28.64 lb / lb-mole)$^{0.6790}$ = 2.32 µm

Re-Calculated Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 38]

$$D_{50-1}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50-1} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Ratio (Z) Between D_{50} and D_{50-1} Values (dimensionless) [RM 201A, Eq. 39]

$$Z = \frac{D_{50-1}}{D_{50}} \qquad 0.99 \le \left[Z = \left(\frac{D_{50}}{D_{50-1}}\right)\right] \le 1.01$$

Z = 2.32 µm / 2.32 µm = 1.00

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Historical Data	SAM U-00001 Base-1	SAM U-00001 Base-2	SAM U-00001 Base-3	**Average**	**Units**	**Limits**
Run Start Time	02:03	04:57	14:32		hh:mm	
Run Stop Time	04:03	06:57	16:32		hh:mm	
Test Date	02/18/20	02/18/20	02/19/20		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.985	0.985	0.985			
Stack Test Data	SAM U-00001 Base-1	SAM U-00001 Base-2	SAM U-00001 Base-3	**Average**	**Units**	**Limits**
Initial Meter Volume	564.120	617.900	837.110		ft^3	
Final Meter Volume	606.440	660.220	879.430		ft^3	
Total Meter Volume	42.320	42.320	42.320	42.320	ft^3	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	88.63	90.31	101.31	93.42	°F	
Barometric Pressure	29.98	29.88	30.12	29.99	in Hg	
Stack Static Pressure	0.95	0.95	0.95	0.95	in H_2O	
Absolute Stack Pressure	30.05	29.95	30.19	30.06	in Hg	
Average Orifice Pressure Drop	0.34	0.34	0.34	0.34	in H_2O	
Absolute Meter Pressure	30.11	30.01	30.25	30.12	in Hg	
Moisture Content Data	SAM U-00001 Base-1	SAM U-00001 Base-2	SAM U-00001 Base-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	71.70	73.80	59.20	68.23	g	
Silica Gel Weight Gain	5.90	5.30	6.10	5.77	g	
Total Water Volume Collected	77.74	79.24	65.42	74.13	ml	
Standard Water Vapor Volume	3.66	3.73	3.08	3.49	scf	
Standard Meter Volume	40.2	40.0	39.5	39.9	dscf	
Standard Metric Meter Volume	1.1	1.1	1.1	1.1	dscm	
Calculated Stack Moisture	8.34	8.53	7.23	8.03	%	
Gas Analysis Data	SAM U-00001 Base-1	SAM U-00001 Base-2	SAM U-00001 Base-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	4.8	4.8	4.8	4.8	%	
Oxygen Content	12.7	12.7	12.7	12.7	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.5	82.5	82.5	82.5	%	
Stack Dry Molecular Weight	29.28	29.28	29.28	29.28	lb/lb-mole	
Calculated Fuel Factor	1.708	1.708	1.708	1.708		
Fuel F-Factor	8643.54	8643.54	8642.95	8643.34	dscf/MMBtu	
Sulfuric Acid Mist IC Analysis	SAM U-00001 Base-1	SAM U-00001 Base-2	SAM U-00001 Base-3	**Average**	**Units**	**Limits**
H_2SO_4 (IC) Sample Volume - Front Half Rinse	191.0	197.0	232.0	206.67	ml	--
H_2SO_4 (IC) Sample - Mass Per Volume	0.105	0.152	0.121	0.13	mg/L	--
H_2SO_4 (IC) Mass	0.02	0.03	0.03	0.03	mg	--
H_2SO_4 (IC) Concentration	4.97E-07	7.50E-07	7.09E-07	6.52E-07	g/dscf	--
	7.67E-06	1.16E-05	1.09E-05	1.01E-05	gr/dscf	--
	1.76E-08	2.65E-08	2.50E-08	2.30E-08	g/L	--
	0.00	0.01	0.01	0.01	ppmvd	--
H_2SO_4 (IC) Emission Rate	0.00002	0.00004	0.00003	0.00003	lb/MMBtu	0.00065

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 77.60 g x 0.04715 ft^3/g = 3.659 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{\frac{17.65\ ^\circ R}{in.\ Hg} \times 0.99 \times 42.32\ dcf \times \left(29.98\ in.\ Hg + \frac{0.34\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{88.63\ ^\circ F + 460\ ^\circ R} = 40.23\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{3.66\ dscf}{3.66\ dscf + 40.23\ dscf} = 8.34\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - H_2SO_4 (IC)]

Stack H_2SO_4 Mass (mg)

$$M_n(mg) = \frac{M_{n(lab)}}{V_{s(lab)}} \times V_{sample} \times \frac{L}{1000ml}$$

M_n (mg) = $\frac{\text{L}}{\text{1000 ml}}$ x 0.10 $\frac{\text{mg}}{\text{L}}$ x 191.00 ml = 0.02 mg

Stack H_2SO_4 Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

c_s (g/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{40.23 dscf}}$ = $\frac{\text{5.00E-07 g}}{\text{dscf}}$

Stack H_2SO_4 Concentration (gr/dscf)

$$c'_s(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

c'$_s$ (gr/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{40.23 dscf}}$ x $\frac{\text{7000 gr}}{\text{lb}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ = $\frac{\text{7.67E-06 gr}}{\text{dscf}}$

Stack H_2SO_4 Concentration (g/L)

$$c''_s(g/L) = c'_s \times \frac{dscf}{28.31685 dsL}$$

c'$_s$ (gr/dscf) = 4.97E-07 $\frac{\text{g}}{\text{dscf}}$ x $\frac{\text{dscf}}{\text{28.31685 dsL}}$ = $\frac{\text{2.00E-08 g}}{\text{L}}$

Stack H_2SO_4 Concentration (ppmvd)

$$c'''_s(ppmvd) = \frac{M_n}{V_{m(std)}} \times Ideal\ Gas\ Constant \times \frac{10^6 parts}{million\ parts} \times \frac{1}{Mol\ Wt}$$

c'''$_s$ (ppmvd) = 1.76E-08 $\frac{\text{g}}{\text{L}}$ x $\frac{\text{24.04 L gas}}{\text{lb-mol}}$ x $\frac{10^6 \text{ parts}}{\text{MM parts}}$ x $\frac{\text{lb-mol}}{\text{98.0790 lb}}$ = 0.004 ppmvd

H_2SO_4 Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

E''' (lb/MMBtu) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ x $\frac{\text{0.02 mg}}{\text{40.23 dscf}}$ x $\frac{\text{8,643.54 dscf}}{\text{MMBtu}}$ x ($\frac{\text{20.9}}{\text{20.9 - 12.7 \%}}$) = $\frac{\text{0.00002 lb}}{\text{MMBtu}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
NOx, CO, VOC, and NH_3

GENERAL ELECTRIC, 7F.05, UNIT #U-00001 BASE+DB LOAD DATA SUMMARY

Parameter	Base+DB Load, Run - 2-1	Base+DB Load, Run - 2-2	Base+DB Load, Run - 2-3	Average
Date (mm/dd/yy)	02/19/20	02/19/20	02/19/20	02/19/20
Start Time (hh:mm:ss)	4:25:06	5:33:06	6:41:06	4:25:06
End Time (hh:mm:ss)	5:24:36	6:32:36	7:40:36	7:40:36
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	30.07	30.11	30.15	30.11
Amb. Temp. (°F)	37	36	34	36
Rel. Humidity (%)	81	72	70	74
Spec. Humidity (lb water / lb air)	0.003714	0.003166	0.002837	0.003239
NH_3 Flow Rate (lb/hr)	199.8	204.9	206.9	203.8
Turbine Fuel Flow (lb/min)	1,668	1,669	1,673	1,670
Duct Burner Fuel Flow (lb/min)	158	158	158	158
Total Fuel Flow (SCFH)	2,468,984	2,469,676	2,474,805	2,471,155
Stack Flow (RM19) (SCFH)	49,278,069	49,219,375	48,739,716	49,079,054
Stack Moisture (% Method 4)	6.7	6.7	6.7	6.7
Heat Input (MMBtu/hr)	2,507.6	2,508.3	2,513.5	2,509.8
CT Power Output (megawatts)	240.9	241.2	241.5	241.2
NOx (ppmvd)	2.54	2.54	2.48	2.52
NOx (ppm@15%O_2)	1.63	1.63	1.57	1.61
CO (ppmvd)	0.00	0.00	0.25	0.08
CO (ppm@15%O_2)	0.00	0.00	0.16	0.05
VOC (as C1) (ppmvd)	0.00	0.00	0.00	0.00
VOC (as C1) (ppm@15%O_2)	0.00	0.00	0.00	0.00
Fuel Sulfur (grains / 100 scf)	0.11	0.11	0.11	0.11
CO_2 (%)	5.09	5.10	5.01	5.07
O_2 (%)	11.71	11.69	11.58	11.66

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Historical Data	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Run Start Time	14:55	04:24	09:14		hh:mm	
Run Stop Time	19:04	08:15	13:51		hh:mm	
Test Date	02/18/20	02/19/20	02/19/20		mm/dd/yy	
Load	Base+DB	Base+DB	Base+DB		% or w/DB	--
Meter Calibration Factor	0.974	0.974	0.974			
Pitot Tube Coefficient	0.7240	0.7240	0.7240			
Average Nozzle Diameter	0.156	0.156	0.156		in	
Stack Test Data	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Initial Meter Volume	49.090	126.000	204.310		ft^3	
Final Meter Volume	149.780	227.550	307.440		ft^3	
Total Meter Volume	100.690	101.550	103.130	101.790	ft^3	
Total Sampling Time	265.50	265.50	267.00	266.00	min	
Average Meter Temperature	70.08	68.08	73.58	70.58	°F	
Average Stack Temperature	177.08	173.58	171.75	174.14	°F	
Barometric Pressure	30.14	30.02	30.14	30.10	in Hg	
Stack Static Pressure	0.95	0.95	0.95	0.95	in H_2O	
Absolute Stack Pressure	30.21	30.09	30.21	30.17	in Hg	
Average Orifice Pressure Drop	0.44	0.44	0.44	0.44	in H_2O	
Absolute Meter Pressure	30.28	30.16	30.28	30.24	in Hg	
Avg Square Root Pitot Pressure	1.15	1.15	1.15	1.15	$\sqrt{(in\ H_2O)}$	
Moisture Content Data	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	140.20	132.90	140.60	137.90	g	
Silica Gel Weight Gain	15.60	17.30	18.00	16.97	g	
Total Water Volume Collected	156.08	150.47	158.89	155.15	ml	
Standard Water Vapor Volume	7.35	7.08	7.48	7.30	scf	
Standard Meter Volume	98.5	99.3	100.2	99.4	dscf	
Standard Metric Meter Volume	2.8	2.8	2.8	2.8	dscm	
Calculated Stack Moisture	6.94	6.66	6.94	6.85	%	
Saturated Stack Moisture	47.32	43.90	41.94	44.39	%	
Reported Stack Moisture Content	6.94	6.66	6.94	6.85	%	
Gas Analysis Data	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	5.3	5.3	5.3	5.3	%	
Oxygen Content	11.7	11.7	11.7	11.7	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	83.0	83.0	83.0	83.0	%	
Stack Dry Molecular Weight	29.32	29.31	29.31	29.31	lb/lb-mole	
Stack Wet Molecular Weight	28.53	28.56	28.53	28.54	lb/lb-mole	
Calculated Fuel Factor	1.740	1.742	1.746	1.742		
Fuel F-Factor	8643.54	8642.95	8642.95	8643.15	dscf/MMBtu	
Percent Excess Air	114.1	113.9	114.0	114.0	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Volumetric Flow Rate Data	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Average Stack Gas Velocity	61.04	60.96	61.18	61.06	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft²	
Actual Stack Flow Rate	1,038,396	1,037,023	1,040,829	1,038,749	acfm	
Wet Standard Stack Flow Rate	52,136	52,147	52,699	52,327	wkscfh	
Dry Standard Stack Flow Rate	48,518,112	48,676,456	49,040,823	48,745,130	dscfh	
Percent of Isokinetic Rate	98.1	98.6	98.2	98.3	%	
Gravimetric Analysis	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	ml	
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	mg	
Emission Rate Data	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Total PM_{10} Mass	6.80	6.30	6.30	6.47	mg	--
Total PM_{10} Concentration	6.90E-05	6.34E-05	6.29E-05	6.51E-05	g/dscf	--
	1.07E-03	9.79E-04	9.70E-04	1.00E-03	gr/dscf	--
Total PM_{10} Emission Rate	3.35	3.09	3.08	3.17	kg/hr	--
	7.38	6.81	6.80	7.00	lb/hr	--
	32.34	29.81	29.76	30.64	tpy	--
	0.0030	0.0027	0.0027	0.0028	lb/MMBtu	0.006
Filterable PM_{10} Mass	2.90	3.40	3.50	3.27	mg	--
Filterable PM_{10} Concentration	2.94E-05	3.42E-05	3.49E-05	3.29E-05	g/dscf	--
	4.54E-04	5.28E-04	5.39E-04	5.07E-04	gr/dscf	--
Filterable PM_{10} Emission Rate	1.43	1.67	1.71	1.60	kg/hr	--
	3.15	3.67	3.78	3.53	lb/hr	--
	13.79	16.09	16.54	15.47	tpy	--
	0.0013	0.0015	0.0015	0.0014	lb/MMBtu	--
Condensable PM_{10} Mass	3.90	2.90	2.80	3.20	mg	--
Condensable PM_{10} Concentration	3.96E-05	2.92E-05	2.79E-05	3.22E-05	g/dscf	--
	6.11E-04	4.51E-04	4.31E-04	4.98E-04	gr/dscf	--
Condensable PM_{10} Emission Rate	1.92	1.42	1.37	1.57	kg/hr	--
	4.23	3.13	3.02	3.46	lb/hr	--
	18.55	13.72	13.23	15.17	tpy	--
	0.0017	0.0013	0.0012	0.0014	lb/MMBtu	--
RM 201A Quality Control	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Stack Viscosity	199.46	198.89	198.19	198.84	µP	
Cyclone Flow Rate	0.476	0.478	0.478	0.478	ft³/min	
Dry Gas Sampling Rate	0.371	0.374	0.375	0.374	dscfm	
Reynolds Number	2792.15	2818.10	2843.00	2,817.75		
Recalculated Cunninham	1.076	1.076	1.076	1.076		
Dia. of 50% Prob. (D50) CI	10.61	10.55	10.51	10.56		
Recalculated D50-1 for CIV	2.36	2.33	2.32	2.33		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Δp	0	0	0	0	points	

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]

Carbon Monoxide Concentration (%)

$$\%CO = \frac{ppmCO}{10{,}000}$$

$$\%CO\ (\%) = \frac{0.00 \quad ppm}{10{,}000\ ppm/\%} = 0.0000\ \%$$

Nitrogen Concentration (%)

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$\%N_2$ (%) = 100 - 5.30 % - 11.68 % - 0.00 / 10,000 % = 83.02 %

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d\,(lb/lb-mol) = \sum\left(\frac{MW_{comp}}{100} \times \%component\right)$$

$$M_d\ (lb/lb\text{-}mol) = \left(\frac{44\ lb/lb\text{-}mol}{100} \times 5.30\ \%\right) +$$

$$\left(\frac{32\ lb/lb\text{-}mol}{100} \times 11.68\ \%\right) + \left(\frac{28\ lb/lb\text{-}mol}{100} \times \left[\frac{0.00}{10{,}000} + 83.02\ \right]\right) = \frac{29.32\ lb}{lb\text{-}mol}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_S\,(lb/lb-mol) = \left[M_d \times \left(1 - \frac{B_{WS}}{100}\right)\right] + \left[MW_{H_2O} \times \frac{B_{WS}}{100}\right]$$

$$M_S\ (lb/lb\text{-}mol) = \left\{\frac{29.32\ lb}{lb\text{-}mol} \times \left(1 - \frac{6.94\ \%}{100}\right)\right\} + \left\{\frac{18\ lb}{lb\text{-}mol} \times \frac{6.94\ \%}{100}\right\} = \frac{28.53\ lb}{lb\text{-}mol}$$

Average Calculated Fuel Factor (F_o)

$$F_{o(avg)} = \frac{\left[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - 11.68\ \% - (0.5 \times 0.000\ \%)}{5.30\ \% + 0.000\ \%} = 1.740$$

Average Excess Air (%)

$$\%EA_{avg}\,(\%) = \frac{100 \times \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(0.264 \times (N_2)_{avg}) - \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{\ 11.68\ \% - (0.5 \times 0.000\ \%)\ \}}{(\ 0.264 \times 83.02\ \%) - \{\ 11.68\ \% - (0.5 \times 0.000\ \%)\}} = 114.09\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]

Absolute Stack Pressure (in. Hg)

$$P_S\,(in.Hg) = P_b + \frac{P_{static}}{13.6}$$

P_s (in. Hg) = 30.14 in. Hg + $\frac{0.95 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.21 in. Hg

Average Stack Gas Velocity (ft/sec)

$$v_s\,(ft/\sec) = K_p \times C_p \times \left(\sqrt{\Delta p}\right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

v_{sl} (ft/sec) =

$\left(\frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\sec \quad (^oR)(\text{in. } H_2O)}\right)^{1/2}$ x 0.72 x 1.15 in.$H_2O^{1/2}$ x $\sqrt{\frac{177.08 + 460\ ^oR}{30.21 \text{ in. Hg x } 28.53 \text{ lb/lb-mol}}}$ = $\frac{61.0 \text{ ft}}{\sec}$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd}\,(dscfh) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sd} (dscf/hr) = $\frac{3600 \text{ sec}}{\text{hr}}$ x (1 - $\frac{6.94\ \%}{100}$) x $\frac{61.04 \text{ ft}}{\sec}$ x 283.53 ft^2 x $\frac{68.00 + 460\ ^oR}{177.08 + 460\ ^oR}$ x $\frac{30.21 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{48{,}518{,}112.28 \text{ dscf}}{\text{hr}}$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw}\,(acfm) = 60 \times v_s \times A_s$$

Q_{aw} (acf/min) = $\frac{60 \text{ sec}}{\text{min}}$ x $\frac{61.04 \text{ ft}}{\sec}$ x 283.53 ft^2 = $\frac{1{,}038{,}395.55 \text{ acf}}{\text{min}}$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw}\,(ascfh) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sw} (ascf/hr) = $\frac{60 \text{ min}}{\text{hr}}$ x $\frac{1{,}038{,}395.55 \text{ acf}}{\text{min}}$ x $\frac{68.00 + 460\ ^oR}{177.08 + 460\ ^oR}$ x $\frac{30.21 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{52{,}136{,}127.46 \text{ ascf}}{\text{hr}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 155.80 g x 0.04715 ft^3/g = 7.346 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{\frac{17.65\ ^\circ R}{in.\ Hg} \times 0.97 \times 100.69\ dcf \times \left(30.14\ in.\ Hg + \frac{0.44\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{70.08\ ^\circ F + 460\ ^\circ R} = 98.51\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{7.35\ dscf}{7.35\ dscf + 98.51\ dscf} = 6.94\ \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)}(\%) = 100 \times \frac{10^{\left(6.691 - \frac{3144}{t_{s(avg)} + 390.86}\right)}}{P_b + \frac{P_{static}}{13.6}} \leq 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left(6.691 - \frac{3144}{177.08\ ^\circ F + 390.86}\right)}}{30.14\ in.\ Hg + \frac{0.95\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}} \leq 100 = 47.32\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Desired Orifice (in. H_2O) (first point)

$$\Delta H_d(in.H_2O) = K \times \Delta p$$

ΔH_d (in. H_2O) = x

in. H_2O = in. H_2O

Absolute Meter Pressure (in. Hg)

$$P_m(in.Hg) = P_b + \frac{\Delta H@}{13.6}$$

P_m (in. Hg) = 30.14 in. Hg + $\frac{1.88 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.28 in. Hg

Recommended Nozzle Diameter (in.)

$$D_{ni}(in.) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}}\right)} \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}{P_s \times \Delta p_{avg}}\right]}$$

D_{ni} (in.) = $\sqrt{\frac{0.03575 \text{ (lb-mole•°R•in. } H_2O)^{1/2} \text{•min•in.}^2}{\text{acf•in. Hg}^{3/4} \text{•lb}^{1/2}} \text{ x } 0.75 \text{ acf x } 30.28 \text{ in. Hg } \left(1 - \frac{0.00\ \%}{100}\right) \text{ x } \left(\frac{1}{1 - \frac{6.94\ \%}{100}}\right) \text{ x}}$

$\sqrt{\left(70.08 \text{ °F} + 460\text{°R}\right) \text{x } 0.72 \text{ (} 177.08 \text{ °F} + 460\text{°R) x } \frac{\frac{29.32 \text{ lb}}{\text{lb-mole}} \text{ x } \left(1 - \frac{6.94\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{6.94\ \%}{100}\right)}{30.21 \text{ in. Hg x } 1.15 \text{ in. } H_2O}}$ = 0.220 in.

ΔP to ΔH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H@ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100}\right) + \left(18 \times \frac{B_{wm}}{100}\right)}{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}\right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}}\right)^2 \times \left(\frac{t_m + T_u}{ts + T_u}\right) \times \frac{P_s}{P_m}$$

K = $\frac{849.8}{\text{in. } H_2O\text{•in.}^4}$ x 0.72 ^{2} x 1.88 in. H_2O x 0.16 ^{4} x $\left(\frac{1 - \frac{6.94\ \%}{100}}{1 - \frac{0.00\ \%}{100}}\right)^2$ x $\frac{70.08 \text{ °F} + 460\text{°R}}{177.08 \text{ °F} + 460\text{°R}}$) x

$\left(\frac{\frac{29.32 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{0.00\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{0.00\ \%}{100}\right)}{\frac{29.32 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{6.94\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{6.94\ \%}{100}\right)}\right) \text{ x } \frac{30.21 \text{ in. Hg}}{30.28 \text{ in. Hg}}$ = 0.37

Percent Isokinetic (%) (first point)

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

I (%) = $\frac{0.0945 \text{ min•in. Hg}}{\text{sec•°R}}$ x (175.00 °F + 460 °R) x 8.38 dscf

22.00 min x $\frac{60.57 \text{ ft}}{\text{sec}}$ x 30.21 in. Hg x 3.14 x $\left(\frac{0.16 \text{ in.}}{2} \text{ x } \frac{\text{ft.}}{12 \text{ in.}}\right)^2$ x $\left(1 - \frac{6.94\ \%}{100}\right)$ = 101.16 %

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Cumulative Percent Isokinetic (%) (weighted average of all points)

$$I(\%) = \sum_{1-n} \frac{\left[I(\%) \times V_{m(std)}\right]_{1-n}}{V_{m(std)_{1-n}}}$$

Using Method 5, Eq 5-8 to determine intermediate isokinetics at each point, weighted averaging of the cumulative isokinetics is necessary since all points are not equal, and determined by using the dry standard meter volume collected at each point to weight the cumulative average. Intermediate isokinetics and dry standard meter volumes are found at each point. At each point the cumulative sum is found of each value and the quotient of the two used to determine the cumulative isokinetics for each residual point (n).

Pt	In (%)	x	Vm(std)n	=	I (%)n	∑(I (%)n)	/	∑(Vm(std)n)	=	I (%)
A-1	101.16	x	8.383	=	847.99	847.99	/	8.38	=	101.2
A-2	97.05	x	8.630	=	837.55	1685.54	/	17.01	=	99.1
A-3	97.24	x	8.634	=	839.51	2525.06	/	25.65	=	98.5
B-1	102.88	x	7.906	=	813.38	3338.43	/	33.55	=	99.5
B-2	99.33	x	8.212	=	815.72	4154.15	/	41.76	=	99.5
B-3	99.61	x	8.845	=	881.03	5035.18	/	50.61	=	99.5
C-1	95.56	x	7.901	=	755.04	5790.22	/	58.51	=	99.0
C-2	98.25	x	7.544	=	741.26	6531.48	/	66.05	=	98.9
C-3	99.89	x	8.259	=	824.98	7356.46	/	74.31	=	99.0
D-1	94.34	x	8.376	=	790.16	8146.61	/	82.69	=	98.5
D-2	96.89	x	8.004	=	775.54	8922.15	/	90.69	=	98.4
D-3	94.63	x	7.823	=	740.26	9662.42	/	98.52	=>	98.1

Last Pt

Percent Isokinetic (%) (intermediate equation, all points)
[equivalent to taking an average of point-by-point isokinetics without weighting the average (e.g. all points equal)]

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I(\%) = \frac{\frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^{\circ}\text{R}} \times (177.08\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times 98.51 \text{ dscf}}{265.50 \text{ min} \times \frac{61.04 \text{ ft}}{\text{sec}} \times 30.21 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \times \left(1 - \frac{6.94\ \%}{100}\right)} = 98.07\ \%$$

Raw Data Percent Isokinetic (%)
[utilizes the raw data equation for isokinetics from Method 5]

$$I(\%) = \frac{100\left((t_s)_{avg} + T_u\right)\left[K_4 V_{1c} + \frac{V_m Y}{(t_m)_{avg} + T_u}\left(P_{bar} + \frac{\Delta H}{13.6}\right)\right]}{60\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right)}$$

$$I(\%) = \frac{100 \times (177.08\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times \left[\frac{0.002669 \text{ ft}^3\text{•in. Hg}}{\text{ml•}^{\circ}\text{R}} \times 156.1 \text{ ml} + \frac{100.69 \text{ dcf} \times 0.974}{70.08\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}} \left(30.14 \text{ in Hg} + \frac{1.147}{13.6}\right)\right]}{60 \times 265.50 \text{ min} \times \frac{61.04 \text{ ft}}{\text{sec}} \times 30.21 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2} = 98.18\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Gravimetric Analysis) [Values from Run 1 test]

Blank Concentration [Acetone Blank Weight of Solids] (mg/ml)

$$C_x(mg/ml) = \frac{1000 \times w_x}{v_x}$$

C_x (mg/ml) = $\frac{1000\ mg}{g}$ x $\frac{0.0000\ g}{200.60\ ml}$ = $\frac{0.0000\ mg}{ml}$ = $\frac{\quad mg}{ml}$

Blank Adjustment [Acetone Blank Weight of Solids and Nozzle Wash PM>10] (mg)

$$W_x(mg) = v_x \times C_x$$

W_x (mg) = 140 ml x 0.0000 mg/ml = 0.00 mg < Sample Gain

Sample Gain [Nozzle Wash PM>10] (mg)

$$m_x(mg) = \left(m_{fx} - m_{tx}\right) \times 1000$$

m_x (mg) = $\frac{1000\ mg}{g}$ x (0.0011 g - 0.00 g) = 1.10 mg

Adjusted Sample Gain [Nozzle Wash PM>10] (mg)

$$m_{xadj}(mg) = m_x - W_x$$

m_{xadj} (mg) = 1.1 mg - 0.00 mg = 1.10 mg

0.1N NH_4OH Correction (mg)

$$m_c(mg) = 17.03 \times V_t \times N$$

m_c (mg) = 17.03 x 0.00 ml x 0.1 N = 0.00 mg

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - Total PM_{10} Mass]

Stack Total Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s \text{ (g/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{6.80 mg}}{\text{98.51 dscf}} = \frac{\text{6.90E-05 g}}{\text{dscf}}$$

Stack Total Concentration (gr/dscf)

$$c_s'(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s \text{ (gr/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{6.80 mg}}{\text{98.51 dscf}} \times \frac{\text{7000 gr}}{\text{lb}} \times \frac{\text{lb}}{\text{453.592 g}} = \frac{\text{1.07E-03 gr}}{\text{dscf}}$$

Total Emissions Rate (kg/hr)

$$E(kg/hr) = c_s \times Q_{sd} \times \frac{kg}{1000\ g}$$

$$E \text{ (kg/hr)} = \frac{\text{kg}}{\text{1000 g}} \times \frac{\text{6.90E-05 g}}{\text{dscf}} \times \frac{\text{48,518,112 dscf}}{\text{hr}} = \frac{\text{3.35 kg}}{\text{hr}}$$

Total Emissions Rate (lb/hr)

$$E'(lb/hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{lb \times g}{453.592g \times 1000mg}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{6.80 mg}}{\text{98.51 dscf}} \times \frac{\text{48,518,112 dscf}}{\text{hr}} = \frac{\text{7.38 lb}}{\text{hr}}$$

Total Emissions Rate (tpy)

$$E''(ton/yr) = E' \times \frac{8760}{2000}$$

$$E'' \text{ (tpy)} = \frac{\text{ton}}{\text{2000 lb}} \times \frac{\text{8,760 hr}}{\text{yr}} \times \frac{\text{7.38 lb}}{\text{hr}} = \frac{\text{32.34 ton}}{\text{yr}}$$

Total Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{6.80 mg}}{\text{98.51 dscf}} \times \frac{\text{8,643.54 dscf}}{\text{MMBtu}} \times \left(\frac{\text{20.9}}{\text{20.9 - 11.7 \%}}\right) = \frac{\text{0.0030 lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Stack Gas Viscosity (μP) [based on preliminary data] [RM 201A, Eq. 3]

$$\mu(\mu P) = C_1 + C_2\sqrt{T_s} + C_3 T_s^{-2} + C4(\%O_{2,wet}) - C_5 B_{ws} + C_6 B_{ws} T_s^2$$

μ (μP) = -150.3162 μP + 13.4622 $\sqrt{\quad 185 \quad + 460}$ + 3.86153x10^{6} (185 + 460)$^{-2}$ + 0.591123 (12.3 x (1 - 8.00 /100)
- 91.9723 (8.00 /100) + 1.51761x10^{-5} (8.00 /100)(185 + 460)^2 = 200.74 μP

Cunningham Correction Factor [RM 201A, Eq. 4]
[based on preliminary data for a 2.25 micrometer diameter particle]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{200.74\ \mu P}{30.21\ \text{in Hg} \times 2.25\ \mu m}\right)\left(\frac{185 + 460\ ^{o}R}{28.40\ \text{lb / lb-mole}}\right)^{0.5} = 1.08$$

First calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}<3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 5]
[assumes N_{re}<3,162]

$$D_{50LL}(\mu m) = 9.507 C^{0.3007}\left[\frac{M_w P_s}{T_s}\right]^{0.1993}$$

$$D_{50LL}\ (\mu m) = 9.507 \times 1.08^{\ 0.3007} \times \left(\frac{30.21\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{185 + 460\ ^{o}R}\right)^{0.1993} = 10.30\ \mu m$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}<3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

$$D_{50T}\ (\mu m) = \frac{11 + 10.30\ \mu m}{2} = 10.65\ \mu m$$

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}<3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu)\left[\frac{T_s}{M_w P_s}\right]^{0.2949}\left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

$$0.07296 \times 200.74\ \mu P \times \left(\frac{185 + 460\ ^{o}R}{30.21\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}\right)^{0.2949} \times \left(\frac{1}{10.65\ \mu m}\right)^{1.4102} = 0.48\ acfm$$

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5\left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

$$N_{re} = 8.64 \times 10^5 \times \frac{30.21\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{185 + 460\ ^{o}R} \times \frac{0.48\ acfm}{200.74\ \mu P} = 2742.55 < 3,162$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Second calculation set using Cyclone IV, assuming N_{re}<3,162

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]
[assumes N_{re}<3,162]

D_{50} (µm) =

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

0.0024302 x (200.74 µP / 0.48 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (185 + 460 °R / 30.21 in Hg x 28.40 lb / lb-mole)$^{0.6790}$ = 2.38 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Less than 3,162 (acfm) [RM 201A, Eq. 8]

Q_{IV} (acfm) =

$$Q_{IV}(acfm) = 0.0060639 \left(\frac{\mu}{C^{0.4242}}\right) \left[\frac{P_s M_w}{T_s}\right]^{-.05759} \left[\frac{1}{D_{50}}\right]^{0.8481}$$

0.0060639 x (200.74 µP / 1.08 $^{0.4242}$) x (30.21 in Hg x 28.40 lb / lb-mole / 185 + 460 °R)$^{-0.5759}$ x (1 / 2.38 µm)$^{0.8481}$ = 0.48 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

N_{re} = 8.64 x 10^5 x 30.21 in Hg x 28.40 lb / lb-mole / 185 + 460 °R x 0.48 acfm / 200.74 µP = 2742.50 < 3,162

Third calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}≥3,162

Lower Limit Cut Diameter for Cyclone I (µm) [RM 201A, Eq. 12]
[assumes N_{re}≥3,162]

$$D_{50LL}(\mu m) = 10.0959 C^{0.4400} \left[\frac{M_w P_s}{T_s}\right]^{0.0600}$$

D_{50LL} (µm) = 10.0959 x 1.08 $^{0.4400}$ x (30.21 in Hg x 28.40 lb / lb-mole / 185 + 460 °R)$^{0.0600}$ = 10.63 µm

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (µm) [RM 201A, Eq. 6]
[assumes N_{re}≥3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

D_{50T} (µm) = (11 + 10.63 µm) / 2 = 10.81 µm

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}≥3,162]

Qs (acfm) =

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu) \left[\frac{T_s}{M_w P_s}\right]^{0.2949} \left[\frac{1}{D_{50T}}\right]^{1.4102}$$

0.07296 x 200.74 µP x (185 + 460 °R / 30.21 in Hg x 28.40 lb / lb-mole)$^{0.2949}$ x (1 / 10.81 µm)$^{1.4102}$ = 0.47 acfm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (30.21 in Hg x 28.40 lb / lb-mole) / (185 + 460 °R) x (0.47 acfm) / (200.74 µP) = 2684.42 < 3,162

Fourth calculation set using Cyclone IV, assuming N_{re}≥3,162

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]
[assumes N_{re}≥3,162]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x ((200.74 µP) / (0.47 acfm))$^{0.8058}$ x ((1) / (1.08))$^{0.5}$
x ((185 + 460 °R) / (30.21 in Hg x 28.40 lb / lb-mole))$^{0.3058}$ = 2.29 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Greater than or Equal to 3,162 (acfm) [RM 201A, Eq. 9]

$$Q_{IV}(acfm) = 0.007657 \left(\frac{\mu}{C^{0.6205}}\right)\left[\frac{P_s M_w}{T_s}\right]^{-0.3795}\left[\frac{1}{D_{50}}\right]^{1.241}$$

Q_{IV} (acfm) =

0.007657 x (200.74 µP) / (1.08 $^{0.6205}$) x (30.21 in Hg x 28.40 lb / lb-mole) / (185 + 460 °R)$^{-0.3795}$
x (1) / (2.29 µm)$^{1.241}$ = 0.47 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (30.21 in Hg x 28.40 lb / lb-mole) / (185 + 460 °R) x (0.48 acfm) / (200.74 µP) = 2742.55 < 3,162

Meter Box Orifice Pressure Drop (in H_2O) [RM 201A, Eq. 11]
As calculated using applicable calculation set 1, 2, 3, or 4

$$\Delta H(inH_2O) = \left[\frac{Q_s(1 - B_{ws})P_s}{T_s}\right]^2 \left[\frac{1.083 T_m M_d \Delta H_@}{P_{bar}}\right]$$

ΔH (in H_2O) = (0.48 acfm x (1 - 8.00 /100) x 30.21 in Hg) / (185 + 460 °R)^2
x (1.083 x (85.00 + 460 °R) x 29.31 lb / lb-mole x 1.878 in H_2O) / (30.14 in Hg) = 0.459 in H_2O

50 °F above stack temperature	T_{s+50} =	235	ΔH_{+50} =	0.395 in H_2O
50 °F below stack temperature	T_{s+50} =	135	ΔH_{+50} =	0.540 in H_2O

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Adjusted Velocity Pressure (in H_2O) [point A-1] [RM201A, Eq. 25]

$$\Delta p_s(inH_2O) = \Delta p_m\left[\frac{C_p}{C'_p}\right]^2$$

Δp_s (in H_2O) = 1.50 in H_2O x (0.7240 / 0.8198)^2 = 1.17 in H_2O

Average Probe Blockage Factor [RM201A, Eq. 26]

$$b_f = \frac{22.0}{A}$$

b_f = 22.0 / 40828.14 in^2 = 5.39E-04

Velocity Pressure Adjusted for Blockage Factor (in H_2O) [point A-1] [RM201A, Eq. 27]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$\Delta p_{s2}(inH_2O) = \Delta p_{s1}\left[\frac{1}{(1-b_f)}\right]^2$$

Δp_s (in H_2O) = 1.17 in H_2O x (1 / (1 - 0.00E+00))^2 = 1.17 in H_2O

Velocity of Stack Gas Adjusted for Blockage Factor and/or C_p / C'_p (ft/sec) [RM201A, Eq. 13]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$v_s = K_p C_p \left(\sqrt{(\Delta p)}\right)_{avg}\left[\sqrt{\frac{T_s}{P_s M_w}}\right]$$

v_s (ft/sec) =

85.49 ft/sec / lb/mole - °R x 0.7240 x 1.04 x (185 + 460 °R / 30.21 in Hg x 28.40 lb / lb-mole)$^{0.5}$ = 55.57 ft/sec

Calculated Nozzle Diameter for Acceptable Sampling Rate (in) [RM201A, Eq. 14]

$$D(in) = \left[\frac{3.056 Q_s}{v_s}\right]^{0.5}$$

D (in) = (3.056 x 0.48 acfm / 55.57 ft/sec)$^{0.5}$ = 0.162 in

Represents ideal diameter, which we then compare to capabilities of all nozzles from multiple sets

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Velocity of Gas in Nozzle 4b (diam. = 0.156 in), (ft/sec) [RM201A, Eq. 15]

v_n (ft/sec) = $\frac{0.48 \text{ acfm}}{60 \text{ min/sec}} \div 1.33\text{E-}04 \text{ ft}^2$ = 60.16 $\frac{\text{ft}}{\text{sec}}$

Example set of calculations for nozzle used with run 1

$$v_n = \frac{\left(\frac{Q_s}{60\frac{\text{min}}{\text{sec}}}\right)}{A_n}$$

Minimum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 16]

Nozzle 4b (diam. = 0.156 in)

$$R_{\min} = \left[0.2457 + \left(0.3072 - \frac{0.2603\,(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{min} =

$0.2457 + (0.3072 - \frac{0.2603 \times 200.74 \text{ µP} \times (0.48 \text{ acfm})^{0.5}}{60.16 \text{ in}^{1.5}})^{0.5}$ = 0.72

Maximum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 17]

Nozzle 4b (diam. = 0.156 in)

$$R_{\max} = \left[0.4457 + \left(0.5690 + \frac{0.2603\,(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{max} =

$0.4457 + (0.5690 + \frac{0.2603 \times 200.74 \text{ µP} \times (0.48 \text{ acfm})^{0.5}}{60.16 \text{ in}^{1.5}})^{0.5}$ = 1.25

Minimum Gas Velocity for R_{min} Less than 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{\min}\,(ft/\text{sec}) = v_n(0.5)$ v_{min} (ft/sec) = 0.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 18]**

Not Applicable

Minimum Gas Velocity for R_{min} Greater than or Equal to 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{\min}\,(ft/\text{sec}) = v_n R_{\min}$ v_{min} (ft/sec) = 60.16 $\frac{\text{ft}}{\text{sec}}$ x 0.72 = 43.61 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 19]**

Maximum Gas Velocity for R_{max} Less than 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{\max}\,(ft/\text{sec}) = v_n R_{\max}$ v_{max} (ft/sec) = 60.16 $\frac{\text{ft}}{\text{sec}}$ x 1.25 = 75.18 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 20]**

Maximum Gas Velocity for R_{max} Greater than or Equal to 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{\max}\,(ft/\text{sec}) = v_n(1.5)$ v_{max} (ft/sec) = 1.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 21]**

Not Applicable

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Minimum Velocity Pressure (in H_2O) [RM201A, Eq. 22] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{min} below preliminary data minimum

$$\Delta p_{min}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{min}}{C_p}\right]^2$$

Δp_{min} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{30.21\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{185 + 460\ ^{o}\text{R}}\right) \times \left(\frac{43.61\ \text{ft/sec}}{0.7240}\right)^2 =$ 0.66 in H_2O vs. 1.01

Maximum Velocity Pressure (in H_2O) [RM201A, Eq. 23] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{max} above preliminary data maximum

$$\Delta p_{max}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{max}}{C_p}\right]^2$$

Δp_{max} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{30.21\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{185 + 460\ ^{o}\text{R}}\right) \times \left(\frac{75.18\ \text{ft/sec}}{0.7240}\right)^2 =$ 1.96 in H_2O vs. 1.17

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sampling Dwell Time at Each Point (minutes) [point A-1] [RM201A, Eq. 24]

$$t_n\,(\text{min}) = \left[\frac{C_p\sqrt{\Delta p_n}}{C_p'\left(\sqrt{\Delta p_n}\right)_{avg}}\right]\left[\frac{t_r}{N_{tp}}\right]$$

t_n (min) = $\left(\frac{0.7240 \times \left(\frac{1.30}{1.04}\right)^{0.5}}{0.7240}\right) \times \left(\frac{240.00\ \text{min}}{12.00}\right) =$ 22.03 minutes

Dry Gas Volume Sampled at Standard Conditions (dscf) [point A-1] [RM201A, Eq. 28]

$$v_{ms}\,(dscf) = \left[\frac{528}{29.92}\right]\left[\gamma \cdot v_m\right]\left[\frac{\left(P_{bar} + \frac{\Delta H}{13.6}\right)}{T_m}\right]$$

v_{ms} (dscf) = $\left(\frac{528}{29.92}\right)$ (0.974 x 8.47 dcf) x

$\left(\frac{30.14\ \text{in Hg} + 0.44\ \text{in } H_2O / 13.6}{64.00 + 460\ ^{o}\text{R}}\right) =$ 8.38 dscf

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sample Flow Rate at Standard Conditions (dscfm) [RM201A, Eq. 29]

$$Q_{sST}\,(dscfm) = \frac{v_{ms}}{\Theta}$$

Q_{sST} (dscfm) = $\frac{98.51 \text{ dscf}}{265.50 \text{ min}}$ = $\frac{0.37 \text{ dscf}}{\text{min}}$

Sampling Rate (acfm) [e.g. cyclone flow rate] [RM201A, Eq. 32]

$$Q_s(acfm) = \frac{29.92}{528} Q_{sST} \left[\frac{1}{(1 - B_{ws})}\right]\left[\frac{T_s}{P_s}\right]$$

Q_s (acfm) = $\frac{29.92 \text{ in Hg}}{528\ ^{o}\text{R}}$ x $\frac{0.37 \text{ dscf}}{\text{min}}$ x $\frac{1}{(1 - 6.94 /100)}$ x $\frac{177 + 460\ ^{o}\text{R}}{30.21 \text{ in Hg}}$ = 0.48 acfm

Actual Conditions Reynolds Number (dimensionless) [RM 201A, Eq. 10]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

N_{re} = 8.64 x 10^5 x $\frac{30.21 \text{ in Hg x } 28.53 \text{ lb / lb-mole}}{177 + 460\ ^{o}\text{R}}$ x $\frac{0.48 \text{ acfm}}{199.46 \text{ µP}}$ = 2792.15

Actual Conditions Particle Cut Diameter for Cyclone I (µm) [RM201A, Eq. 33]

$$D_{50}(\mu m) = 0.15625 \left[\frac{T_s}{M_w P_s}\right]^{0.2091} \left[\frac{\mu}{Q_s}\right]^{0.7091}$$

D_{50} (µm) = 0.15625 x ($\frac{177 + 460\ ^{o}\text{R}}{30.21 \text{ in Hg x } 28.53 \text{ lb / lb-mole}}$)$^{0.2091}$ x ($\frac{199.46 \text{ µP}}{0.48 \text{ acfm}}$)$^{0.7091}$ = 10.61 µm

Actual Particle Cut Diameter for Cyclone IV is determined by:

Actual Conditions Cunningham Correction Factor [RM 201A, Eq. 4]
[for a 2.5 micrometer diameter particle (estimated size)]

$$C = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x ($\frac{199.46 \text{ µP}}{30.21 \text{ in Hg x } 2.5 \text{ µm}}$)($\frac{177 + 460\ ^{o}\text{R}}{28.53 \text{ lb / lb-mole}}$)$^{0.5}$ = 1.07

Actual Conditions Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) =

0.0024302 x ($\frac{199.46 \text{ µP}}{0.48 \text{ acfm}}$)$^{1.1791}$ x ($\frac{1}{1.07}$)$^{0.5}$

x ($\frac{177 + 460\ ^{o}\text{R}}{30.21 \text{ in Hg x } 28.53 \text{ lb / lb-mole}}$)$^{0.6790}$ = 2.36 µm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Actual Conditions Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Re-calculated Cunningham Correction Factor (dimensionless) [RM 201A, Eq. 36]

$$C_r = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x (199.46 µP / 30.21 in Hg x 2.36 µm)(177 + 460 °R / 28.53 lb / lb-mole)$^{0.5}$ = 1.08

Re-calculated Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 37]

$$D_{50-1}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50-1} (µm) =

0.0024302 x (199.46 µP / 0.48 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (177 + 460 °R / 30.21 in Hg x 28.53 lb / lb-mole)$^{0.6790}$ = 2.36 µm

Re-Calculated Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 38]

$$D_{50-1}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50-1} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Ratio (Z) Between D_{50} and D_{50-1} Values (dimensionless) [RM 201A, Eq. 39]

$$Z = \frac{D_{50-1}}{D_{50}} \qquad 0.99 \le \left[Z = \left(\frac{D_{50}}{D_{50-1}}\right)\right] \le 1.01$$

Z = 2.36 µm / 2.36 µm = 1.00

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	U-00001 Base+DB

Historical Data	SAM U-00001 Base+DB-1	SAM U-00001 Base+DB-2	SAM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Run Start Time	14:40	04:09	07:26		hh:mm	
Run Stop Time	16:40	06:09	09:26		hh:mm	
Test Date	02/18/20	02/19/20	02/19/20		mm/dd/yy	
Load	Base+DB	Base+DB	Base+DB		% or w/DB	--
Meter Calibration Factor	0.985	0.985	0.985			
Stack Test Data	SAM U-00001 Base+DB-1	SAM U-00001 Base+DB-2	SAM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Initial Meter Volume	671.410	SAM U-0001 Base+DB	782.510		ft³	
Final Meter Volume	713.730	769.230	824.830		ft³	
Total Meter Volume	42.320	42.320	42.320	42.320	ft³	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	95.69	100.50	101.38	99.19	°F	
Barometric Pressure	30.14	30.02	30.14	30.10	in Hg	
Stack Static Pressure	0.95	0.95	0.95	0.95	in H_2O	
Absolute Stack Pressure	30.21	43878.00	30.21	14646.14	in Hg	
Average Orifice Pressure Drop	0.34	0.34	0.34	0.34	in H_2O	
Absolute Meter Pressure	30.27	30.15	30.27	30.23	in Hg	
Moisture Content Data	SAM U-00001 Base+DB-1	SAM U-00001 Base+DB-2	SAM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	81.80	73.00	76.00	76.93	g	
Silica Gel Weight Gain	7.10	7.30	5.50	6.63	g	
Total Water Volume Collected	89.06	80.44	81.65	83.72	ml	
Standard Water Vapor Volume	4.19	3.79	3.84	3.94	scf	
Standard Meter Volume	39.9	39.4	39.5	39.6	dscf	
Standard Metric Meter Volume	1.1	1.1	1.1	1.1	dscm	
Calculated Stack Moisture	9.50	8.76	8.86	9.04	%	
Gas Analysis Data	SAM U-00001 Base+DB-1	SAM U-00001 Base+DB-2	SAM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	5.3	5.3	5.3	5.3	%	
Oxygen Content	11.7	11.7	11.7	11.7	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	83.0	83.0	83.0	83.0	%	
Stack Dry Molecular Weight	29.32	29.32	29.32	29.32	lb/lb-mole	
Calculated Fuel Factor	1.736	1.736	1.736	1.736		
Fuel F-Factor	8643.54	8642.95	8642.95	8643.15	dscf/MMBtu	
Sulfuric Acid Mist IC Analysis	SAM U-00001 Base+DB-1	SAM U-00001 Base+DB-2	SAM U-00001 Base+DB-3	**Average**	**Units**	**Limits**
H_2SO_4 (IC) Sample Volume - Front Half Rinse	232.0	194.0	254.0	226.67	ml	--
H_2SO_4 (IC) Sample - Mass Per Volume	0.103	0.206	0.220	0.18	mg/L	--
H_2SO_4 (IC) Mass	0.02	0.04	0.06	0.04	mg	--
H_2SO_4 (IC) Concentration	6.01E-07	1.01E-06	1.42E-06	1.01E-06	g/dscf	--
	9.28E-06	1.57E-05	2.19E-05	1.56E-05	gr/dscf	--
	2.12E-08	3.58E-08	5.00E-08	3.57E-08	g/L	--
	0.01	0.01	0.01	0.01	ppmvd	--
H_2SO_4 (IC) Emission Rate	0.00003	0.00004	0.00006	0.00004	lb/MMBtu	0.00065

Note: Run 1 reported at the RDL (0.024 mg)

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12 \text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 88.90 g x 0.04715 ft^3/g = 4.192 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{\frac{17.65\ ^\circ R}{in.\ Hg} \times 0.99 \times 42.32\ dcf \times \left(30.14\ in.\ Hg + \frac{0.34\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{95.69\ ^\circ F + 460\ ^\circ R} = 39.93\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{4.19\ dscf}{4.19\ dscf + 39.93\ dscf} = 9.50\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - H_2SO_4 (IC)]

Stack H_2SO_4 Mass (mg)

$$M_n(mg) = \frac{M_{n(lab)}}{V_{s(lab)}} \times V_{sample} \times \frac{L}{1000ml}$$

M_n (mg) = $\frac{\text{L}}{\text{1000 ml}}$ x 0.10 $\frac{\text{mg}}{\text{L}}$ x 232.00 ml = 0.02 mg

Stack H_2SO_4 Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

c_s (g/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{39.93 dscf}}$ = $\frac{\text{6.00E-07 g}}{\text{dscf}}$

Stack H_2SO_4 Concentration (gr/dscf)

$$c'_s(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

c'$_s$ (gr/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{39.93 dscf}}$ x $\frac{\text{7000 gr}}{\text{lb}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ = $\frac{\text{9.28E-06 gr}}{\text{dscf}}$

Stack H_2SO_4 Concentration (g/L)

$$c''_s(g/L) = c'_s \times \frac{dscf}{28.31685 dsL}$$

c'$_s$ (gr/dscf) = 6.01E-07 $\frac{\text{g}}{\text{dscf}}$ x $\frac{\text{dscf}}{\text{28.31685 dsL}}$ = $\frac{\text{2.00E-08 g}}{\text{L}}$

Stack H_2SO_4 Concentration (ppmvd)

$$c'''_s(ppmvd) = \frac{M_n}{V_{m(std)}} \times Ideal\ Gas\ Constant \times \frac{10^6 parts}{million\ parts} \times \frac{1}{Mol\ Wt}$$

c'''$_s$ (ppmvd) = 2.12E-08 $\frac{\text{g}}{\text{L}}$ x $\frac{\text{24.04 L gas}}{\text{lb-mol}}$ x $\frac{10^6 \text{ parts}}{\text{MM parts}}$ x $\frac{\text{lb-mol}}{\text{98.0790 lb}}$ = 0.005 ppmvd

H_2SO_4 Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

E''' (lb/MMBtu) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ x $\frac{\text{0.02 mg}}{\text{39.93 dscf}}$ x $\frac{\text{8,643.54 dscf}}{\text{MMBtu}}$ x ($\frac{\text{20.9}}{\text{20.9 - 11.7 \%}}$) = $\frac{\text{0.00003 lb}}{\text{MMBtu}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B

EMISSION DATA RECORDS

Cricket Valley Energy Center LLC

Air Permit Number:	3-1326-00275/00009
Plant Name or Location:	Cricket Valley Energy Center
Date:	February 17, 2020
Project Number:	bec-19-cricketvalley.ny-start#1
Manufacturer & Equipment:	General Electric
Model:	7F.05
Unit Number:	U-00001
Test Load:	Multiiple
Tester(s) / Test Unit(s):	RW/AB/220/213

		RUN					
	UNITS	**1-1**	**1-2**	**1-3**	**2-1**	**2-2**	**2-3**
Start Time	hh:mm:ss	13:35:04	14:50:04	16:00:04	04:25:06	05:33:06	06:41:06
End Time	hh:mm:ss	14:34:34	15:49:34	16:59:34	05:24:36	06:32:36	07:40:36
Bar. Pressure	in. Hg	30.28	30.28	30.30	30.07	30.11	30.15
Amb. Temp.	°F	43	43	45	37	36	34
Rel. Humidity	%	41	40	39	81	72	70
Spec. Humidity	lb water / lb air	0.002353	0.002295	0.002414	0.003714	0.003166	0.002837
Date	mm/dd/yy	02/17/20	02/17/20	02/17/20	02/19/20	02/19/20	02/19/20
Load Designator		Base	Base	Base	Base+DB	Base+DB	Base+DB
NH_3 Flow Rate	lb/hr	169.8	164.8	172.3	199.8	204.9	206.9
Turbine Fuel Flow	lb/min	1,673	1,673	1,678	1,668	1,669	1,673
Duct Burner Fuel Flow	lb/min	0	0	0	158	158	158
Total Fuel Flow	SCFH	2,260,589	2,261,296	2,267,876	2,468,984	2,469,676	2,474,805
Stack Moisture	% Method 4	5.77	5.77	5.77	6.66	6.66	6.66
Heat Input	MMBtu/hr	2303.3	2304.0	2310.7	2507.6	2508.3	2513.5
CT Power Output	megawatts	240.4	240.4	241.3	240.9	241.2	241.5

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Created with Comp&RATA&Eng-AHI v20190529

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
NOx, CO, VOC, and NH_3

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 13:35 - 2/17 14:34)	240.41	28.30	0.00	13.46	169.84	1166.47
COUNT = 60						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 13:35	240.85	28.35	0.00	13.45	180.02	1166.78
2/17/20 13:36	240.50	28.42	0.00	13.75	167.80	1166.89
2/17/20 13:37	240.59	28.25	0.00	13.43	163.91	1166.52
2/17/20 13:38	240.51	28.37	0.00	13.11	162.58	1166.43
2/17/20 13:39	240.28	28.46	0.00	13.47	163.85	1166.73
2/17/20 13:40	240.77	28.36	0.00	13.53	172.70	1166.80
2/17/20 13:41	240.28	28.16	0.00	13.26	170.20	1166.60
2/17/20 13:42	240.32	28.25	0.00	13.62	171.57	1166.24
2/17/20 13:43	240.87	28.30	0.00	13.42	174.44	1166.58
2/17/20 13:44	240.42	28.43	0.00	13.74	172.60	1166.63
2/17/20 13:45	240.14	28.34	0.00	13.12	169.26	1165.92
2/17/20 13:46	240.18	28.37	0.00	13.39	165.89	1166.43
2/17/20 13:47	240.29	28.33	0.00	13.79	163.65	1166.68
2/17/20 13:48	239.98	28.18	0.00	13.27	163.23	1165.44
2/17/20 13:49	240.34	28.21	0.00	13.42	167.55	1165.81
2/17/20 13:50	240.38	28.33	0.00	13.39	169.94	1165.77
2/17/20 13:51	240.36	28.20	0.00	13.48	169.17	1166.67
2/17/20 13:52	240.24	28.26	0.00	12.99	166.11	1165.86
2/17/20 13:53	240.02	28.30	0.00	13.45	168.25	1165.78
2/17/20 13:54	240.57	28.21	0.00	13.59	168.96	1166.08
2/17/20 13:55	239.89	28.37	0.00	13.36	171.72	1165.96
2/17/20 13:56	240.49	28.16	0.00	13.45	171.24	1166.65
2/17/20 13:57	240.35	28.20	0.00	13.52	176.20	1165.76
2/17/20 13:58	240.72	28.28	0.00	13.20	178.94	1166.85
2/17/20 13:59	240.15	28.10	0.00	13.43	180.49	1166.26
2/17/20 14:00	240.05	28.21	0.00	13.48	172.39	1166.19
2/17/20 14:01	240.38	28.34	0.00	13.46	163.05	1166.24
2/17/20 14:02	240.28	28.16	0.00	13.44	153.92	1166.62
2/17/20 14:03	240.53	28.51	0.00	13.70	155.73	1166.91
2/17/20 14:04	240.56	28.30	0.00	13.75	166.93	1167.75
2/17/20 14:05	240.53	28.41	0.00	13.44	175.29	1166.16
2/17/20 14:06	240.58	28.36	0.00	13.47	180.64	1167.15
2/17/20 14:07	240.89	28.37	0.00	13.32	180.48	1166.70
2/17/20 14:08	240.49	28.31	0.00	13.45	185.65	1166.65
2/17/20 14:09	240.39	28.17	0.00	13.40	177.23	1166.55
2/17/20 14:10	240.00	28.39	0.00	13.34	162.39	1166.32
2/17/20 14:11	240.16	28.26	0.00	13.25	150.38	1166.67
2/17/20 14:12	240.41	28.29	0.00	13.53	150.65	1165.95
2/17/20 14:13	240.27	28.23	0.00	13.75	159.72	1165.94
2/17/20 14:14	239.98	28.20	0.00	13.44	170.99	1166.02
2/17/20 14:15	240.37	28.28	0.00	13.51	182.39	1166.47
2/17/20 14:16	240.14	28.25	0.00	13.55	184.32	1165.87
2/17/20 14:17	240.55	28.14	0.00	13.79	184.28	1167.01
2/17/20 14:18	240.26	28.22	0.00	13.21	166.36	1166.33
2/17/20 14:19	240.52	28.50	0.00	13.31	148.80	1166.16
2/17/20 14:20	240.36	28.37	0.00	13.46	141.83	1166.54
2/17/20 14:21	240.52	28.06	0.00	13.68	147.32	1167.15
2/17/20 14:22	240.40	28.27	0.00	13.86	163.21	1166.74
2/17/20 14:23	240.46	28.28	0.00	13.86	178.54	1166.30
2/17/20 14:24	240.77	28.42	0.00	13.30	190.13	1166.68
2/17/20 14:25	240.76	28.18	0.00	13.31	193.53	1166.38
2/17/20 14:26	240.48	28.49	0.00	13.43	178.37	1166.53
2/17/20 14:27	240.54	28.21	0.00	13.64	155.73	1165.87
2/17/20 14:28	239.98	28.40	0.00	13.62	148.97	1167.34
2/17/20 14:29	240.41	28.42	0.00	13.37	152.87	1166.31
2/17/20 14:30	240.57	28.28	0.00	13.31	167.52	1167.10
2/17/20 14:31	240.42	28.44	0.00	13.39	183.94	1167.45
2/17/20 14:32	240.64	28.39	0.00	13.41	198.05	1166.58
2/17/20 14:33	240.74	28.34	0.00	13.37	188.93	1167.06
2/17/20 14:34	240.59	28.33	0.00	13.37	179.46	1166.54

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 14:50 - 2/17 15:49)	240.38	28.31	0.00	13.43	164.81	1167.24
COUNT = 60						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 14:50	240.75	28.13	0.00	13.64	181.05	1168.05
2/17/20 14:51	240.38	28.24	0.00	13.35	172.31	1166.51
2/17/20 14:52	240.51	28.60	0.00	13.39	160.13	1166.96
2/17/20 14:53	240.30	28.24	0.00	13.46	154.25	1166.43
2/17/20 14:54	240.66	28.26	0.00	13.32	150.16	1167.57
2/17/20 14:55	239.91	28.36	0.00	13.42	158.48	1166.25
2/17/20 14:56	240.07	28.27	0.00	13.63	166.97	1167.48
2/17/20 14:57	240.60	28.16	0.00	13.63	173.03	1167.56
2/17/20 14:58	240.64	28.32	0.00	13.78	170.04	1167.90
2/17/20 14:59	240.36	28.32	0.00	13.43	173.62	1167.49
2/17/20 15:00	240.20	28.18	0.00	13.29	167.71	1166.93
2/17/20 15:01	240.29	28.37	0.00	13.67	164.87	1167.14
2/17/20 15:02	240.27	28.28	0.00	13.27	158.49	1166.37
2/17/20 15:03	239.64	28.37	0.00	13.40	161.23	1166.64
2/17/20 15:04	240.40	28.19	0.00	13.30	169.18	1168.09
2/17/20 15:05	239.93	28.32	0.00	13.46	164.44	1166.86
2/17/20 15:06	240.51	28.28	0.00	13.42	166.61	1166.69
2/17/20 15:07	240.48	28.31	0.00	13.32	165.60	1167.22
2/17/20 15:08	240.32	28.35	0.00	13.85	162.77	1167.44
2/17/20 15:09	240.15	28.30	0.00	13.24	163.13	1167.46
2/17/20 15:10	240.50	28.25	0.00	13.44	156.00	1167.46
2/17/20 15:11	240.25	28.35	0.00	13.22	154.94	1166.60
2/17/20 15:12	239.87	28.34	0.00	13.48	156.38	1166.66
2/17/20 15:13	240.18	28.13	0.00	13.48	165.17	1166.88
2/17/20 15:14	240.25	28.29	0.00	13.55	173.05	1167.29
2/17/20 15:15	240.45	28.27	0.00	13.68	181.03	1167.48
2/17/20 15:16	240.16	28.26	0.00	13.36	176.39	1166.77
2/17/20 15:17	240.10	28.21	0.00	13.19	168.79	1167.22
2/17/20 15:18	239.90	28.12	0.00	13.23	154.45	1167.03
2/17/20 15:19	240.09	28.27	0.00	13.55	150.45	1167.43
2/17/20 15:20	240.16	28.22	0.00	13.52	146.10	1167.39
2/17/20 15:21	239.74	28.45	0.00	13.53	149.91	1166.83
2/17/20 15:22	240.09	28.27	0.00	13.51	158.03	1167.62
2/17/20 15:23	240.06	28.33	0.00	13.56	163.68	1168.21
2/17/20 15:24	240.50	28.29	0.00	13.46	167.64	1167.55
2/17/20 15:25	240.76	28.32	0.00	13.48	170.84	1167.74
2/17/20 15:26	240.32	28.47	0.00	13.56	164.96	1167.54
2/17/20 15:27	240.49	28.37	0.00	13.31	158.96	1166.92
2/17/20 15:28	240.96	28.31	0.00	13.21	152.82	1167.40
2/17/20 15:29	240.81	28.30	0.00	13.53	146.28	1167.96
2/17/20 15:30	240.57	28.10	0.00	13.35	147.16	1167.08
2/17/20 15:31	240.27	28.56	0.00	13.41	161.50	1167.53
2/17/20 15:32	240.82	28.40	0.00	13.27	175.76	1167.35
2/17/20 15:33	240.18	28.17	0.00	13.46	186.50	1167.19
2/17/20 15:34	240.95	28.49	0.00	13.77	184.30	1168.32
2/17/20 15:35	240.89	28.31	0.00	13.40	173.98	1167.64
2/17/20 15:36	240.06	28.30	0.00	13.58	157.89	1167.23
2/17/20 15:37	240.39	28.21	0.00	13.41	142.03	1166.65
2/17/20 15:38	240.42	28.30	0.00	13.15	135.35	1167.42
2/17/20 15:39	240.77	28.43	0.00	13.50	140.96	1168.18
2/17/20 15:40	240.19	28.23	0.00	13.50	159.08	1166.45
2/17/20 15:41	240.82	28.45	0.00	13.23	192.90	1168.06
2/17/20 15:42	240.68	28.46	0.00	13.40	211.21	1167.38
2/17/20 15:43	240.45	28.40	0.00	13.49	205.09	1167.56
2/17/20 15:44	240.79	28.36	0.00	13.20	185.05	1167.31
2/17/20 15:45	240.16	28.41	0.00	13.47	161.20	1166.29
2/17/20 15:46	240.64	28.34	0.00	13.14	150.11	1166.57
2/17/20 15:47	240.52	28.40	0.00	13.22	146.35	1166.79
2/17/20 15:48	240.78	28.19	0.00	13.33	173.90	1166.71
2/17/20 15:49	240.53	28.38	0.00	13.38	178.06	1167.48

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 16:0 - 2/17 16:59)	241.29	28.39	0.00	13.32	172.35	1167.99
COUNT = 60						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 16:00	240.75	28.45	0.00	13.14	182.18	1166.82
2/17/20 16:01	240.62	28.46	0.00	13.10	177.82	1166.84
2/17/20 16:02	240.65	28.19	0.00	13.19	167.64	1167.68
2/17/20 16:03	241.18	28.37	0.00	13.34	168.67	1167.91
2/17/20 16:04	240.80	28.35	0.00	13.34	167.70	1167.38
2/17/20 16:05	241.02	28.32	0.00	13.50	164.91	1167.99
2/17/20 16:06	241.26	28.40	0.00	13.31	164.98	1167.70
2/17/20 16:07	240.88	28.34	0.00	13.37	166.54	1168.14
2/17/20 16:08	241.07	28.49	0.00	13.34	158.90	1167.93
2/17/20 16:09	241.07	28.39	0.00	13.46	162.54	1167.76
2/17/20 16:10	240.61	28.41	0.00	13.21	157.56	1166.90
2/17/20 16:11	240.89	28.39	0.00	13.19	156.86	1167.69
2/17/20 16:12	241.21	28.32	0.00	13.44	165.51	1167.79
2/17/20 16:13	241.41	28.53	0.00	13.48	176.71	1167.66
2/17/20 16:14	241.09	28.40	0.00	13.45	186.99	1167.99
2/17/20 16:15	241.04	28.29	0.00	13.23	187.18	1167.88
2/17/20 16:16	241.44	28.30	0.00	13.63	179.53	1168.27
2/17/20 16:17	240.70	28.17	0.00	13.38	164.06	1167.70
2/17/20 16:18	240.95	28.24	0.00	13.10	151.25	1167.04
2/17/20 16:19	241.07	28.23	0.00	13.26	154.91	1167.69
2/17/20 16:20	241.06	28.35	0.00	13.49	165.49	1167.80
2/17/20 16:21	241.01	28.40	0.00	13.06	179.29	1167.72
2/17/20 16:22	241.11	28.26	0.00	13.57	184.52	1168.33
2/17/20 16:23	241.05	28.33	0.00	13.31	187.59	1167.92
2/17/20 16:24	241.10	28.46	0.00	13.50	186.07	1168.35
2/17/20 16:25	241.12	28.33	0.00	13.30	173.20	1168.20
2/17/20 16:26	241.19	28.41	0.00	13.37	165.98	1167.76
2/17/20 16:27	241.28	28.47	0.00	13.29	162.09	1167.66
2/17/20 16:28	241.34	28.45	0.00	12.92	167.42	1167.77
2/17/20 16:29	241.59	28.30	0.00	13.28	178.57	1167.78
2/17/20 16:30	241.29	28.34	0.00	13.29	186.13	1167.30
2/17/20 16:31	241.49	28.32	0.00	13.33	180.47	1168.14
2/17/20 16:32	241.78	28.53	0.00	13.57	170.51	1168.14
2/17/20 16:33	241.54	28.39	0.00	13.15	161.31	1168.55
2/17/20 16:34	241.20	28.47	0.00	13.41	157.40	1167.23
2/17/20 16:35	241.33	28.48	0.00	13.39	163.18	1167.82
2/17/20 16:36	241.98	28.50	0.00	13.11	178.82	1168.90
2/17/20 16:37	241.61	28.49	0.00	13.51	194.94	1168.84
2/17/20 16:38	241.87	28.23	0.00	13.14	192.93	1168.52
2/17/20 16:39	241.39	28.65	0.00	13.38	183.09	1168.61
2/17/20 16:40	241.65	28.47	0.00	13.11	173.96	1167.61
2/17/20 16:41	241.97	28.36	0.00	13.39	167.06	1169.19
2/17/20 16:42	241.06	28.29	0.00	13.37	162.99	1167.66
2/17/20 16:43	241.17	28.37	0.00	13.25	165.15	1167.86
2/17/20 16:44	241.45	28.37	0.00	13.39	168.56	1167.71
2/17/20 16:45	241.78	28.38	0.00	13.40	171.89	1168.86
2/17/20 16:46	241.72	28.44	0.00	13.62	176.30	1169.42
2/17/20 16:47	241.42	28.34	0.00	13.14	181.04	1168.16
2/17/20 16:48	241.48	28.39	0.00	13.45	186.81	1168.52
2/17/20 16:49	241.37	28.39	0.00	13.35	180.18	1167.87
2/17/20 16:50	241.47	28.45	0.00	13.34	175.22	1168.71
2/17/20 16:51	241.49	28.39	0.00	13.36	165.90	1168.06
2/17/20 16:52	241.57	28.39	0.00	13.08	161.44	1167.98
2/17/20 16:53	241.38	28.40	0.00	13.29	161.18	1167.82
2/17/20 16:54	241.32	28.44	0.00	13.41	161.44	1168.24
2/17/20 16:55	241.49	28.26	0.00	13.40	172.29	1168.34
2/17/20 16:56	241.69	28.52	0.00	13.36	183.00	1167.62
2/17/20 16:57	241.74	28.47	0.00	13.14	186.04	1168.75
2/17/20 16:58	241.93	28.54	0.00	13.35	182.85	1168.84
2/17/20 16:59	241.39	28.57	0.00	13.39	176.24	1167.92

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
PM_{10}

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 17:2 - 2/17 22:11)	243.96	28.62	0.00	13.37	202.19	1171.09
COUNT = 310						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 17:02	242.07	28.42	0.00	13.15	167.39	1168.74
2/17/20 17:03	242.05	28.34	0.00	13.40	169.04	1169.15
2/17/20 17:04	241.75	28.36	0.00	13.67	177.64	1169.24
2/17/20 17:05	242.25	28.48	0.00	13.64	173.56	1169.66
2/17/20 17:06	242.12	28.60	0.00	13.39	170.73	1169.46
2/17/20 17:07	241.62	28.26	0.00	13.14	174.37	1168.15
2/17/20 17:08	241.60	28.41	0.00	13.29	180.88	1168.67
2/17/20 17:09	242.11	28.42	0.00	13.28	187.51	1169.75
2/17/20 17:10	242.11	28.36	0.00	13.49	190.39	1169.40
2/17/20 17:11	241.94	28.25	0.00	13.36	189.97	1168.31
2/17/20 17:12	241.94	28.26	0.00	13.51	188.19	1168.98
2/17/20 17:13	241.91	28.45	0.00	13.38	183.43	1169.04
2/17/20 17:14	242.35	28.42	0.00	13.29	187.65	1168.89
2/17/20 17:15	242.37	28.36	0.00	13.36	184.92	1169.09
2/17/20 17:16	241.98	28.36	0.00	13.29	182.25	1168.31
2/17/20 17:17	242.32	28.58	0.00	13.29	183.88	1169.86
2/17/20 17:18	242.15	28.48	0.00	13.36	176.03	1169.27
2/17/20 17:19	242.10	28.29	0.00	13.35	175.47	1168.36
2/17/20 17:20	242.51	28.46	0.00	13.40	176.40	1169.70
2/17/20 17:21	242.50	28.41	0.00	13.18	181.61	1169.62
2/17/20 17:22	242.01	28.45	0.00	13.19	185.77	1168.78
2/17/20 17:23	242.28	28.42	0.00	13.47	186.57	1169.82
2/17/20 17:24	242.33	28.48	0.00	13.18	175.89	1168.96
2/17/20 17:25	242.25	28.54	0.00	13.42	180.89	1169.36
2/17/20 17:26	242.30	28.49	0.00	13.66	184.79	1170.01
2/17/20 17:27	242.21	28.67	0.00	13.40	191.42	1169.40
2/17/20 17:28	242.43	28.56	0.00	13.38	200.32	1169.32
2/17/20 17:29	242.43	28.48	0.00	13.38	192.82	1169.22
2/17/20 17:30	242.62	28.49	0.00	12.98	189.58	1169.67
2/17/20 17:31	242.50	28.45	0.00	13.30	191.04	1169.63
2/17/20 17:32	242.48	28.52	0.00	13.27	196.38	1168.79
2/17/20 17:33	242.48	28.56	0.00	13.26	186.87	1168.84
2/17/20 17:34	242.59	28.59	0.00	13.11	180.74	1169.58
2/17/20 17:35	242.64	28.42	0.00	13.25	177.24	1169.64
2/17/20 17:36	242.16	28.54	0.00	13.64	180.37	1168.84
2/17/20 17:37	242.40	28.41	0.00	13.31	181.11	1168.31
2/17/20 17:38	242.94	28.50	0.00	13.33	180.04	1170.17
2/17/20 17:39	242.53	28.46	0.00	13.22	182.19	1169.60
2/17/20 17:40	242.67	28.41	0.00	13.52	188.03	1170.03
2/17/20 17:41	242.68	28.44	0.00	13.11	193.90	1169.47
2/17/20 17:42	243.21	28.40	0.00	13.27	201.30	1169.89
2/17/20 17:43	242.78	28.47	0.00	13.27	197.02	1170.54
2/17/20 17:44	242.38	28.44	0.00	13.37	182.43	1168.58
2/17/20 17:45	242.68	28.56	0.00	13.31	175.24	1170.14
2/17/20 17:46	243.17	28.64	0.00	13.37	173.75	1170.08
2/17/20 17:47	243.00	28.50	0.00	13.24	177.43	1169.79
2/17/20 17:48	242.66	28.43	0.00	13.16	194.25	1169.60
2/17/20 17:49	243.20	28.31	0.00	13.37	197.27	1169.84
2/17/20 17:50	242.44	28.35	0.00	13.12	201.11	1168.80
2/17/20 17:51	243.03	28.50	0.00	13.57	194.62	1170.03
2/17/20 17:52	242.95	28.57	0.00	13.11	186.49	1169.67
2/17/20 17:53	242.32	28.36	0.00	13.55	183.42	1169.22
2/17/20 17:54	242.78	28.47	0.00	13.41	181.63	1169.20
2/17/20 17:55	242.80	28.53	0.00	13.15	184.27	1169.20
2/17/20 17:56	243.23	28.42	0.00	13.25	183.66	1169.89
2/17/20 17:57	243.04	28.57	0.00	13.19	181.81	1170.18
2/17/20 17:58	242.58	28.58	0.00	13.46	185.56	1169.18
2/17/20 17:59	242.96	28.54	0.00	13.38	189.62	1169.25
2/17/20 18:00	242.97	28.63	0.00	13.34	193.33	1170.53
2/17/20 18:01	243.01	28.51	0.00	13.40	191.53	1169.34
2/17/20 18:02	242.38	28.62	0.00	13.34	191.84	1169.88
2/17/20 18:03	243.10	28.48	0.00	13.24	178.98	1169.48
2/17/20 18:04	243.15	28.52	0.00	13.22	175.60	1169.68
2/17/20 18:05	242.90	28.62	0.00	13.25	182.78	1170.15
2/17/20 18:06	243.03	28.38	0.00	13.26	188.01	1169.88
2/17/20 18:07	243.12	28.50	0.00	13.37	192.69	1170.26
2/17/20 18:08	242.99	28.48	0.00	13.42	194.08	1169.96

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 17:2 - 2/17 22:11)	243.96	28.62	0.00	13.37	202.19	1171.09
COUNT = 310						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 18:09	242.97	28.63	0.00	13.48	196.39	1170.20
2/17/20 18:10	242.71	28.58	0.00	13.41	192.70	1169.54
2/17/20 18:11	242.91	28.64	0.00	13.50	182.24	1170.67
2/17/20 18:12	242.75	28.56	0.00	13.56	184.91	1169.63
2/17/20 18:13	243.15	28.55	0.00	13.33	177.20	1169.89
2/17/20 18:14	243.25	28.57	0.00	13.42	176.92	1170.59
2/17/20 18:15	243.38	28.40	0.00	13.20	181.45	1170.17
2/17/20 18:16	243.18	28.45	0.00	13.32	188.55	1170.04
2/17/20 18:17	243.31	28.47	0.00	13.49	189.41	1170.07
2/17/20 18:18	242.63	28.42	0.00	13.67	195.06	1169.43
2/17/20 18:19	243.29	28.57	0.00	13.51	188.70	1169.84
2/17/20 18:20	243.34	28.46	0.00	13.17	184.73	1169.89
2/17/20 18:21	243.23	28.67	0.00	13.62	191.47	1170.60
2/17/20 18:22	243.10	28.75	0.00	13.27	195.13	1169.72
2/17/20 18:23	243.54	28.53	0.00	13.19	197.61	1170.54
2/17/20 18:24	243.24	28.43	0.00	13.40	196.66	1170.30
2/17/20 18:25	243.41	28.59	0.00	13.32	194.46	1170.14
2/17/20 18:26	243.53	28.61	0.00	13.35	191.91	1171.17
2/17/20 18:27	243.27	28.53	0.00	13.21	193.18	1169.57
2/17/20 18:28	243.02	28.54	0.00	13.44	202.24	1169.42
2/17/20 18:29	243.68	28.59	0.00	13.27	196.50	1170.78
2/17/20 18:30	243.74	28.55	0.00	13.20	190.79	1170.13
2/17/20 18:31	243.28	28.53	0.00	13.38	181.24	1169.65
2/17/20 18:32	243.44	28.48	0.00	13.34	180.23	1170.91
2/17/20 18:33	243.25	28.48	0.00	13.51	178.13	1170.23
2/17/20 18:34	243.31	28.66	0.00	13.32	188.40	1170.54
2/17/20 18:35	243.18	28.50	0.00	13.20	193.94	1170.12
2/17/20 18:36	243.59	28.59	0.00	13.35	207.68	1169.91
2/17/20 18:37	243.30	28.57	0.00	13.20	213.53	1169.63
2/17/20 18:38	243.30	28.56	0.00	13.31	206.12	1169.85
2/17/20 18:39	243.11	28.63	0.00	13.39	191.56	1169.12
2/17/20 18:40	243.64	28.49	0.00	13.51	190.12	1171.30
2/17/20 18:41	243.75	28.63	0.00	13.36	192.51	1170.86
2/17/20 18:42	243.07	28.50	0.00	13.34	189.05	1169.94
2/17/20 18:43	243.72	28.58	0.00	13.22	194.10	1170.96
2/17/20 18:44	243.81	28.43	0.00	13.38	203.06	1171.04
2/17/20 18:45	243.59	28.53	0.00	13.35	209.90	1169.53
2/17/20 18:46	243.44	28.69	0.00	13.42	205.18	1170.68
2/17/20 18:47	244.14	28.66	0.00	13.52	196.14	1171.37
2/17/20 18:48	243.39	28.91	0.00	13.24	189.93	1170.79
2/17/20 18:49	243.61	28.40	0.00	13.31	188.46	1170.66
2/17/20 18:50	243.77	28.55	0.00	13.51	183.65	1170.44
2/17/20 18:51	243.58	28.62	0.00	13.26	193.41	1170.04
2/17/20 18:52	243.74	28.56	0.00	13.39	202.58	1171.29
2/17/20 18:53	243.70	28.55	0.00	13.44	213.63	1171.20
2/17/20 18:54	243.57	28.52	0.00	13.50	216.85	1170.61
2/17/20 18:55	243.59	28.66	0.00	13.34	213.97	1171.06
2/17/20 18:56	243.79	28.38	0.00	13.61	207.90	1171.25
2/17/20 18:57	243.80	28.58	0.00	13.38	195.43	1170.49
2/17/20 18:58	243.79	28.38	0.00	13.13	189.25	1170.91
2/17/20 18:59	243.48	28.65	0.00	13.34	190.61	1170.41
2/17/20 19:00	243.79	28.56	0.00	13.10	192.78	1169.87
2/17/20 19:01	244.12	28.63	0.00	13.24	198.55	1170.71
2/17/20 19:02	243.79	28.59	0.00	13.40	201.63	1170.38
2/17/20 19:03	244.07	28.69	0.00	13.53	209.59	1171.09
2/17/20 19:04	243.85	28.65	0.00	13.21	211.13	1170.67
2/17/20 19:05	243.94	28.67	0.00	13.64	204.77	1171.36
2/17/20 19:06	243.73	28.38	0.00	13.20	201.56	1170.36
2/17/20 19:07	243.99	28.58	0.00	13.62	207.43	1171.78
2/17/20 19:08	244.05	28.54	0.00	13.51	211.14	1171.06
2/17/20 19:09	244.05	28.71	0.00	13.42	210.44	1171.42
2/17/20 19:10	244.13	28.75	0.00	13.59	201.05	1170.61
2/17/20 19:11	244.09	28.69	0.00	13.19	190.89	1171.40
2/17/20 19:12	243.98	28.66	0.00	13.47	191.06	1171.60
2/17/20 19:13	244.08	28.69	0.00	13.24	190.06	1171.01
2/17/20 19:14	243.70	28.62	0.00	13.50	193.25	1171.82
2/17/20 19:15	244.14	28.60	0.00	13.31	205.03	1170.57

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 17:2 - 2/17 22:11)	243.96	28.62	0.00	13.37	202.19	1171.09
COUNT = 310						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 19:16	243.64	28.59	0.00	13.42	213.69	1170.39
2/17/20 19:17	243.59	28.71	0.00	13.36	215.20	1170.25
2/17/20 19:18	244.27	28.49	0.00	13.60	214.39	1170.84
2/17/20 19:19	243.56	28.66	0.00	13.83	214.18	1170.52
2/17/20 19:20	243.57	28.51	0.00	13.31	213.96	1170.42
2/17/20 19:21	243.62	28.64	0.00	13.35	211.84	1170.86
2/17/20 19:22	243.82	28.65	0.00	13.72	211.49	1171.15
2/17/20 19:23	244.29	28.60	0.00	13.41	211.12	1171.47
2/17/20 19:24	244.13	28.46	0.00	13.34	203.86	1170.94
2/17/20 19:25	244.00	28.77	0.00	13.18	204.20	1171.39
2/17/20 19:26	243.84	28.49	0.00	13.22	200.40	1170.67
2/17/20 19:27	243.80	28.58	0.00	13.75	205.65	1170.83
2/17/20 19:28	244.12	28.85	0.00	13.43	205.12	1170.48
2/17/20 19:29	244.39	28.59	0.00	13.42	200.69	1171.89
2/17/20 19:30	243.53	28.59	0.00	13.41	194.28	1170.85
2/17/20 19:31	243.77	28.76	0.00	13.46	201.47	1171.53
2/17/20 19:32	243.90	28.76	0.00	13.42	204.03	1170.26
2/17/20 19:33	243.86	28.71	0.00	13.45	210.79	1171.30
2/17/20 19:34	243.99	28.61	0.00	13.45	212.77	1171.40
2/17/20 19:35	244.17	28.52	0.00	13.28	202.89	1170.29
2/17/20 19:36	244.14	28.63	0.00	13.38	197.58	1170.87
2/17/20 19:37	243.83	28.57	0.00	13.30	186.88	1171.30
2/17/20 19:38	243.76	28.60	0.00	13.42	185.90	1171.21
2/17/20 19:39	243.81	28.58	0.00	13.31	190.08	1171.70
2/17/20 19:40	244.10	28.68	0.00	13.21	200.56	1170.94
2/17/20 19:41	243.98	28.47	0.00	13.14	204.10	1171.00
2/17/20 19:42	244.18	28.61	0.00	13.35	205.51	1170.87
2/17/20 19:43	243.60	28.61	0.00	13.25	203.43	1170.24
2/17/20 19:44	244.34	28.68	0.00	13.32	195.98	1170.29
2/17/20 19:45	244.26	28.59	0.00	13.16	197.42	1170.58
2/17/20 19:46	244.08	28.47	0.00	13.18	193.14	1170.61
2/17/20 19:47	244.04	28.67	0.00	13.30	202.60	1171.82
2/17/20 19:48	244.14	28.80	0.00	13.38	203.32	1171.84
2/17/20 19:49	244.02	28.54	0.00	13.57	204.03	1171.16
2/17/20 19:50	244.00	28.51	0.00	13.44	204.76	1171.65
2/17/20 19:51	244.18	28.49	0.00	13.14	202.15	1170.70
2/17/20 19:52	244.20	28.57	0.00	13.56	196.64	1171.63
2/17/20 19:53	244.38	28.55	0.00	13.50	197.65	1170.99
2/17/20 19:54	244.30	28.63	0.00	13.32	202.03	1171.47
2/17/20 19:55	243.99	28.57	0.00	13.17	202.15	1171.28
2/17/20 19:56	244.10	28.81	0.00	13.32	207.92	1170.65
2/17/20 19:57	244.08	28.70	0.00	13.38	206.17	1171.02
2/17/20 19:58	244.65	28.68	0.00	13.34	203.54	1171.58
2/17/20 19:59	244.00	28.62	0.00	13.21	200.27	1170.33
2/17/20 20:00	244.34	28.91	0.00	13.24	196.97	1171.45
2/17/20 20:01	244.10	28.65	0.00	13.77	200.29	1171.02
2/17/20 20:02	244.64	28.60	0.00	13.24	202.60	1171.63
2/17/20 20:03	244.27	28.68	0.00	13.43	203.27	1172.06
2/17/20 20:04	244.58	28.65	0.00	13.54	212.45	1172.45
2/17/20 20:05	244.40	28.83	0.00	13.25	224.12	1171.29
2/17/20 20:06	244.66	28.69	0.00	13.55	234.64	1172.25
2/17/20 20:07	244.87	28.48	0.00	13.58	224.82	1172.55
2/17/20 20:08	244.33	28.67	0.00	13.32	214.01	1171.99
2/17/20 20:09	244.76	28.78	0.00	13.18	211.79	1172.68
2/17/20 20:10	244.57	28.83	0.00	13.34	209.85	1171.63
2/17/20 20:11	244.11	28.74	0.00	13.41	209.55	1170.58
2/17/20 20:12	244.39	28.61	0.00	13.86	208.15	1172.20
2/17/20 20:13	244.26	28.70	0.00	13.18	208.45	1171.83
2/17/20 20:14	244.13	28.75	0.00	13.19	211.45	1171.72
2/17/20 20:15	244.87	28.74	0.00	13.41	212.87	1173.05
2/17/20 20:16	244.54	28.93	0.00	13.35	208.14	1170.24
2/17/20 20:17	244.33	28.61	0.00	13.17	206.50	1171.13
2/17/20 20:18	244.41	28.51	0.00	13.31	204.92	1171.25
2/17/20 20:19	244.67	28.76	0.00	13.36	199.53	1171.92
2/17/20 20:20	244.62	28.52	0.00	13.63	193.31	1172.29
2/17/20 20:21	244.65	28.65	0.00	13.36	199.74	1171.95
2/17/20 20:22	244.64	28.52	0.00	13.29	193.82	1171.57

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 17:2 - 2/17 22:11)	243.96	28.62	0.00	13.37	202.19	1171.09
COUNT = 310						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 20:23	244.72	28.62	0.00	13.39	204.34	1171.91
2/17/20 20:24	244.79	28.73	0.00	13.48	208.20	1171.37
2/17/20 20:25	245.05	28.60	0.00	13.36	210.02	1171.93
2/17/20 20:26	244.33	28.64	0.00	13.24	213.05	1171.01
2/17/20 20:27	244.60	28.64	0.00	13.35	214.85	1171.47
2/17/20 20:28	244.52	28.70	0.00	13.42	219.55	1171.80
2/17/20 20:29	245.07	28.72	0.00	13.32	217.09	1172.69
2/17/20 20:30	245.05	28.55	0.00	13.13	209.86	1172.13
2/17/20 20:31	244.63	28.82	0.00	13.34	197.56	1171.83
2/17/20 20:32	244.44	28.68	0.00	13.26	198.88	1171.70
2/17/20 20:33	244.01	28.71	0.00	13.23	201.87	1171.33
2/17/20 20:34	244.74	28.60	0.00	13.32	204.86	1171.78
2/17/20 20:35	245.12	28.51	0.00	13.37	212.76	1172.36
2/17/20 20:36	245.13	28.79	0.00	13.20	217.97	1171.95
2/17/20 20:37	244.14	28.67	0.00	13.36	216.72	1170.94
2/17/20 20:38	245.08	28.75	0.00	13.57	214.55	1172.19
2/17/20 20:39	244.50	28.73	0.00	13.29	211.33	1171.70
2/17/20 20:40	244.61	28.91	0.00	13.60	200.99	1172.27
2/17/20 20:41	244.63	28.83	0.00	13.46	194.33	1172.44
2/17/20 20:42	244.68	28.59	0.00	13.30	192.53	1172.08
2/17/20 20:43	244.56	28.77	0.00	13.53	198.61	1172.40
2/17/20 20:44	245.08	28.67	0.00	13.60	195.51	1172.74
2/17/20 20:45	244.67	28.54	0.00	13.07	205.54	1171.33
2/17/20 20:46	244.44	28.85	0.00	13.52	214.13	1172.46
2/17/20 20:47	244.85	28.67	0.00	13.35	222.19	1172.12
2/17/20 20:48	244.43	28.82	0.00	13.24	231.97	1171.15
2/17/20 20:49	244.89	28.76	0.00	13.68	236.38	1172.54
2/17/20 20:50	245.18	28.79	0.00	13.18	233.54	1171.99
2/17/20 20:51	244.62	28.66	0.00	13.50	218.76	1172.29
2/17/20 20:52	244.64	28.68	0.00	13.36	206.72	1172.21
2/17/20 20:53	244.70	28.53	0.00	13.49	202.11	1171.86
2/17/20 20:54	244.89	28.92	0.00	13.45	198.50	1171.30
2/17/20 20:55	245.10	28.66	0.00	13.42	205.99	1172.04
2/17/20 20:56	244.27	28.77	0.00	13.35	209.18	1170.91
2/17/20 20:57	244.85	28.85	0.00	13.28	210.92	1171.92
2/17/20 20:58	245.02	28.82	0.00	13.15	210.39	1172.01
2/17/20 20:59	245.05	28.74	0.00	13.52	215.23	1172.09
2/17/20 21:00	245.30	28.68	0.00	13.36	218.98	1172.83
2/17/20 21:01	244.90	28.70	0.00	13.36	212.71	1172.37
2/17/20 21:02	244.94	28.65	0.00	13.53	207.79	1172.83
2/17/20 21:03	245.16	28.55	0.00	13.28	206.88	1172.06
2/17/20 21:04	244.87	28.65	0.00	13.51	201.60	1171.55
2/17/20 21:05	244.58	28.70	0.00	13.39	209.01	1172.70
2/17/20 21:06	244.69	28.68	0.00	13.22	211.97	1171.93
2/17/20 21:07	244.87	28.86	0.00	13.21	214.99	1171.87
2/17/20 21:08	244.75	28.73	0.00	13.22	215.85	1172.03
2/17/20 21:09	245.19	28.76	0.00	13.64	209.74	1172.82
2/17/20 21:10	245.07	28.64	0.00	13.21	206.46	1172.47
2/17/20 21:11	244.93	28.69	0.00	13.37	212.34	1171.91
2/17/20 21:12	245.26	28.55	0.00	13.27	223.11	1172.63
2/17/20 21:13	244.87	28.56	0.00	13.44	228.00	1172.64
2/17/20 21:14	245.23	28.64	0.00	13.33	226.51	1172.91
2/17/20 21:15	244.79	28.62	0.00	13.19	224.81	1172.12
2/17/20 21:16	244.99	28.89	0.00	13.35	221.89	1172.99
2/17/20 21:17	245.36	28.67	0.00	13.26	217.37	1172.06
2/17/20 21:18	244.74	28.85	0.00	13.43	216.10	1172.48
2/17/20 21:19	245.34	28.75	0.00	13.59	213.58	1172.55
2/17/20 21:20	244.59	28.44	0.00	13.39	215.97	1171.48
2/17/20 21:21	245.34	28.98	0.00	13.43	219.73	1172.78
2/17/20 21:22	245.33	28.67	0.00	13.33	213.51	1171.97
2/17/20 21:23	244.94	28.80	0.00	13.28	207.25	1172.36
2/17/20 21:24	245.09	28.68	0.00	13.23	206.20	1172.40
2/17/20 21:25	245.14	28.61	0.00	13.84	206.54	1172.28
2/17/20 21:26	244.91	28.70	0.00	13.23	210.13	1171.46
2/17/20 21:27	244.38	28.81	0.00	13.49	215.88	1171.78
2/17/20 21:28	244.90	28.85	0.00	13.63	219.66	1173.12
2/17/20 21:29	245.61	28.74	0.00	13.43	225.11	1172.61

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 17:2 - 2/17 22:11)		243.96	28.62	0.00	13.37	202.19	1171.09
COUNT = 310							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/17/20 21:30	244.87	29.01	0.00	13.44	231.37	1172.33
	2/17/20 21:31	244.72	28.81	0.00	13.36	231.71	1172.68
	2/17/20 21:32	244.82	28.66	0.00	13.49	228.14	1172.30
	2/17/20 21:33	245.43	28.80	0.00	13.60	218.87	1173.05
	2/17/20 21:34	244.82	28.78	0.00	13.31	209.77	1172.30
	2/17/20 21:35	244.84	28.67	0.00	13.40	203.56	1172.36
	2/17/20 21:36	244.72	28.75	0.00	13.55	197.39	1172.93
	2/17/20 21:37	244.89	28.78	0.00	13.26	197.97	1172.38
	2/17/20 21:38	244.73	28.80	0.00	13.27	202.35	1172.19
	2/17/20 21:39	245.06	28.89	0.00	13.48	206.21	1172.79
	2/17/20 21:40	245.00	28.81	0.00	13.47	210.38	1173.03
	2/17/20 21:41	245.13	28.69	0.00	13.31	212.19	1172.32
	2/17/20 21:42	244.90	28.76	0.00	13.33	213.78	1172.24
	2/17/20 21:43	245.11	28.85	0.00	13.33	214.61	1172.47
	2/17/20 21:44	245.20	28.83	0.00	13.65	215.04	1173.16
	2/17/20 21:45	244.94	28.64	0.00	13.47	213.57	1172.95
	2/17/20 21:46	245.29	28.66	0.00	13.47	214.72	1173.03
	2/17/20 21:47	245.12	28.93	0.00	13.30	219.54	1172.38
	2/17/20 21:48	244.89	28.76	0.00	13.38	217.00	1171.91
	2/17/20 21:49	245.26	28.77	0.00	13.45	219.13	1172.73
	2/17/20 21:50	244.81	28.65	0.00	13.32	214.11	1172.37
	2/17/20 21:51	245.03	28.70	0.00	13.39	209.33	1172.53
	2/17/20 21:52	245.00	28.74	0.00	13.33	204.29	1172.60
	2/17/20 21:53	245.02	28.80	0.00	13.32	207.03	1172.47
	2/17/20 21:54	245.20	28.77	0.00	13.77	209.64	1172.75
	2/17/20 21:55	245.13	28.66	0.00	13.66	213.20	1173.11
	2/17/20 21:56	244.87	28.72	0.00	13.41	222.76	1172.82
	2/17/20 21:57	245.35	28.65	0.00	13.29	230.77	1173.17
	2/17/20 21:58	244.85	28.66	0.00	13.49	238.36	1173.36
	2/17/20 21:59	245.34	28.54	0.00	13.53	231.07	1173.23
	2/17/20 22:00	245.46	28.88	0.00	13.53	226.48	1173.12
	2/17/20 22:01	245.31	28.75	0.00	13.45	220.51	1173.41
	2/17/20 22:02	246.00	28.67	0.00	13.47	221.53	1173.72
	2/17/20 22:03	245.69	28.68	0.00	13.53	227.02	1174.00
	2/17/20 22:04	245.74	28.59	0.00	13.42	229.88	1172.90
	2/17/20 22:05	245.45	28.85	0.00	13.42	233.33	1172.08
	2/17/20 22:06	245.55	28.96	0.00	13.63	231.46	1173.16
	2/17/20 22:07	245.93	28.70	0.00	13.47	235.90	1173.46
	2/17/20 22:08	245.85	28.91	0.00	13.68	234.03	1173.47
	2/17/20 22:09	245.55	28.85	0.00	13.24	235.37	1173.08
	2/17/20 22:10	245.62	28.82	0.00	13.39	235.66	1172.68
	2/17/20 22:11	245.90	28.65	0.00	13.39	234.77	1173.09

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 23:5 - 2/18 4:5)	245.71	28.75	0.00	13.42	225.55	1172.81
COUNT = 301						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 23:05	246.29	28.70	0.00	13.32	232.74	1173.25
2/17/20 23:06	245.59	28.61	0.00	13.35	232.95	1172.31
2/17/20 23:07	245.54	28.77	0.00	13.62	231.80	1173.00
2/17/20 23:08	245.98	28.75	0.00	13.48	233.26	1173.50
2/17/20 23:09	246.01	28.83	0.00	13.40	233.21	1173.05
2/17/20 23:10	246.16	28.76	0.00	13.38	233.31	1172.99
2/17/20 23:11	245.68	28.74	0.00	13.54	231.62	1172.82
2/17/20 23:12	245.99	28.68	0.00	13.38	229.73	1172.03
2/17/20 23:13	246.24	28.83	0.00	13.48	227.94	1173.67
2/17/20 23:14	246.17	28.46	0.00	13.29	228.40	1173.93
2/17/20 23:15	246.13	28.61	0.00	13.15	229.09	1172.78
2/17/20 23:16	246.21	28.78	0.00	13.57	229.64	1173.96
2/17/20 23:17	245.91	28.85	0.00	13.28	230.21	1172.57
2/17/20 23:18	245.92	28.63	0.00	13.41	230.86	1173.29
2/17/20 23:19	245.54	28.65	0.00	13.46	225.83	1172.32
2/17/20 23:20	246.13	28.60	0.00	13.43	231.79	1173.30
2/17/20 23:21	246.30	28.70	0.00	13.77	227.73	1174.19
2/17/20 23:22	245.16	28.60	0.00	13.34	229.39	1172.56
2/17/20 23:23	245.78	28.88	0.00	13.44	229.38	1174.29
2/17/20 23:24	245.61	28.80	0.00	13.49	233.72	1172.65
2/17/20 23:25	245.83	28.81	0.00	13.65	234.27	1172.87
2/17/20 23:26	246.34	28.69	0.00	13.19	234.76	1174.00
2/17/20 23:27	246.08	28.73	0.00	13.50	236.05	1173.01
2/17/20 23:28	245.88	28.52	0.00	13.52	235.28	1172.77
2/17/20 23:29	245.81	28.87	0.00	13.57	237.42	1173.01
2/17/20 23:30	246.13	28.78	0.00	13.40	232.19	1173.27
2/17/20 23:31	246.07	28.55	0.00	13.55	228.96	1173.08
2/17/20 23:32	245.77	28.80	0.00	13.47	228.06	1172.54
2/17/20 23:33	245.80	28.69	0.00	13.39	234.50	1174.06
2/17/20 23:34	246.14	28.73	0.00	13.36	237.00	1173.39
2/17/20 23:35	245.74	28.93	0.00	13.34	240.34	1172.92
2/17/20 23:36	246.22	28.79	0.00	13.68	240.45	1174.19
2/17/20 23:37	245.86	28.66	0.00	13.61	238.21	1173.13
2/17/20 23:38	246.30	28.87	0.00	13.51	237.13	1173.67
2/17/20 23:39	245.60	28.63	0.00	13.33	231.57	1172.93
2/17/20 23:40	245.74	28.71	0.00	13.43	225.42	1173.52
2/17/20 23:41	245.58	28.77	0.00	13.42	221.14	1172.65
2/17/20 23:42	245.85	28.74	0.00	13.26	218.89	1173.62
2/17/20 23:43	245.86	28.81	0.00	13.39	212.17	1172.57
2/17/20 23:44	246.23	28.96	0.00	13.17	214.32	1173.20
2/17/20 23:45	245.86	28.53	0.00	13.45	220.20	1173.58
2/17/20 23:46	246.09	28.84	0.00	13.43	225.72	1174.03
2/17/20 23:47	246.38	28.76	0.00	13.14	230.23	1173.09
2/17/20 23:48	246.35	28.82	0.00	13.49	235.68	1173.38
2/17/20 23:49	245.92	28.90	0.00	13.33	236.95	1173.91
2/17/20 23:50	245.62	28.65	0.00	13.27	235.66	1172.58
2/17/20 23:51	246.34	28.69	0.00	13.73	229.10	1173.81
2/17/20 23:52	245.60	28.63	0.00	13.54	226.28	1172.49
2/17/20 23:53	245.99	28.96	0.00	13.25	220.83	1173.30
2/17/20 23:54	245.88	29.00	0.00	13.33	220.96	1172.88
2/17/20 23:55	245.88	28.77	0.00	13.22	225.04	1173.63
2/17/20 23:56	246.11	28.74	0.00	13.55	231.86	1174.62
2/17/20 23:57	245.96	28.61	0.00	13.51	235.47	1173.67
2/17/20 23:58	245.91	28.80	0.00	13.53	236.47	1172.81
2/17/20 23:59	246.12	28.89	0.00	13.37	236.32	1173.12
2/18/20 0:00	245.71	28.87	0.00	13.50	232.71	1172.80
2/18/20 0:01	246.72	28.68	0.00	13.71	228.75	1174.12
2/18/20 0:02	246.55	28.87	0.00	13.16	226.22	1173.24
2/18/20 0:03	246.05	28.95	0.00	13.45	228.23	1172.61
2/18/20 0:04	245.89	28.80	0.00	13.38	233.87	1173.18
2/18/20 0:05	246.21	28.78	0.00	13.71	234.64	1173.86
2/18/20 0:06	246.18	28.63	0.00	13.43	233.86	1173.02
2/18/20 0:07	245.84	28.80	0.00	13.27	231.49	1173.05
2/18/20 0:08	246.16	28.99	0.00	13.35	229.19	1173.14
2/18/20 0:09	246.30	28.80	0.00	13.34	228.27	1172.83
2/18/20 0:10	246.67	28.71	0.00	13.75	232.68	1174.80
2/18/20 0:11	245.61	28.77	0.00	13.51	232.48	1172.48

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 23:5 - 2/18 4:5)	245.71	28.75	0.00	13.42	225.55	1172.81
COUNT = 301						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 0:12	246.30	28.80	0.00	13.17	233.96	1173.99
2/18/20 0:13	246.52	28.94	0.00	13.37	234.51	1173.69
2/18/20 0:14	246.17	28.78	0.00	13.27	231.64	1173.75
2/18/20 0:15	245.81	28.74	0.00	13.48	234.86	1172.48
2/18/20 0:16	246.15	28.70	0.00	13.32	236.23	1173.08
2/18/20 0:17	246.76	28.59	0.00	13.48	238.79	1173.39
2/18/20 0:18	245.59	28.86	0.00	13.25	243.92	1172.47
2/18/20 0:19	246.13	28.65	0.00	13.30	247.90	1173.04
2/18/20 0:20	246.28	28.93	0.00	13.34	245.52	1173.13
2/18/20 0:21	246.52	28.76	0.00	13.47	236.17	1173.37
2/18/20 0:22	246.10	28.73	0.00	13.56	231.29	1173.65
2/18/20 0:23	245.96	28.84	0.00	13.54	231.30	1173.08
2/18/20 0:24	246.57	28.83	0.00	13.34	226.45	1173.12
2/18/20 0:25	245.98	28.64	0.00	13.33	226.37	1172.40
2/18/20 0:26	246.48	28.83	0.00	13.70	234.34	1174.07
2/18/20 0:27	245.68	28.76	0.00	13.24	237.37	1172.43
2/18/20 0:28	246.47	28.77	0.00	13.68	239.01	1173.17
2/18/20 0:29	246.28	28.80	0.00	13.80	240.92	1173.30
2/18/20 0:30	246.36	28.82	0.00	13.49	239.69	1173.61
2/18/20 0:31	246.21	28.99	0.00	13.52	232.01	1173.49
2/18/20 0:32	246.56	28.62	0.00	13.39	227.53	1173.53
2/18/20 0:33	245.71	28.64	0.00	13.34	231.71	1173.12
2/18/20 0:34	246.42	28.75	0.00	13.38	234.41	1174.01
2/18/20 0:35	246.18	28.86	0.00	13.37	237.00	1172.54
2/18/20 0:36	245.85	28.65	0.00	13.51	237.35	1173.32
2/18/20 0:37	246.51	28.69	0.00	13.36	241.35	1173.93
2/18/20 0:38	246.31	29.01	0.00	13.52	236.73	1173.21
2/18/20 0:39	245.76	28.75	0.00	13.50	234.88	1172.54
2/18/20 0:40	246.72	28.64	0.00	13.32	228.23	1172.13
2/18/20 0:41	246.34	28.67	0.00	13.49	228.41	1173.81
2/18/20 0:42	246.09	28.92	0.00	13.94	223.68	1173.09
2/18/20 0:43	245.88	28.85	0.00	13.45	226.34	1172.86
2/18/20 0:44	246.40	28.91	0.00	13.48	225.96	1174.00
2/18/20 0:45	246.27	28.81	0.00	13.46	222.82	1173.12
2/18/20 0:46	245.94	28.81	0.00	13.54	223.01	1172.31
2/18/20 0:47	246.25	28.79	0.00	13.71	228.87	1172.51
2/18/20 0:48	246.62	28.84	0.00	13.80	235.27	1173.96
2/18/20 0:49	246.17	28.82	0.00	13.47	243.09	1172.64
2/18/20 0:50	245.97	28.93	0.00	13.42	246.75	1172.12
2/18/20 0:51	246.37	28.77	0.00	13.32	245.72	1172.30
2/18/20 0:52	246.52	28.66	0.00	13.24	239.31	1172.78
2/18/20 0:53	245.93	28.92	0.00	13.27	237.43	1172.79
2/18/20 0:54	246.15	28.99	0.00	13.50	236.85	1173.82
2/18/20 0:55	246.02	28.75	0.00	13.44	239.18	1172.77
2/18/20 0:56	246.11	28.91	0.00	13.53	245.44	1173.47
2/18/20 0:57	246.65	28.89	0.00	13.36	247.78	1173.20
2/18/20 0:58	246.03	28.75	0.00	13.53	242.34	1173.47
2/18/20 0:59	245.78	28.53	0.00	13.44	239.25	1173.04
2/18/20 1:00	246.00	28.87	0.00	13.34	231.56	1173.41
2/18/20 1:01	245.88	28.90	0.00	13.86	236.00	1173.31
2/18/20 1:02	246.18	28.76	0.00	13.24	235.85	1173.02
2/18/20 1:03	246.38	28.81	0.00	13.22	230.80	1173.14
2/18/20 1:04	245.67	28.72	0.00	13.40	229.26	1172.91
2/18/20 1:05	246.53	28.94	0.00	13.22	226.59	1173.29
2/18/20 1:06	246.22	28.74	0.00	13.56	229.57	1174.36
2/18/20 1:07	246.21	28.88	0.00	13.55	233.69	1174.12
2/18/20 1:08	246.27	28.80	0.00	13.34	233.74	1173.68
2/18/20 1:09	246.31	28.59	0.00	13.26	234.92	1172.77
2/18/20 1:10	245.96	28.88	0.00	13.14	233.68	1172.94
2/18/20 1:11	245.57	28.67	0.00	13.32	228.65	1173.27
2/18/20 1:12	246.40	28.97	0.00	13.44	223.91	1174.04
2/18/20 1:13	246.41	28.74	0.00	13.34	222.14	1173.08
2/18/20 1:14	246.36	28.61	0.00	13.51	228.57	1173.43
2/18/20 1:15	245.99	28.83	0.00	13.26	234.13	1172.96
2/18/20 1:16	246.81	28.80	0.00	13.30	236.14	1173.04
2/18/20 1:17	246.33	28.68	0.00	13.38	238.67	1173.45
2/18/20 1:18	245.97	28.67	0.00	13.57	233.45	1172.49

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 23:5 - 2/18 4:5)	245.71	28.75	0.00	13.42	225.55	1172.81
COUNT = 301						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 1:19	245.85	28.69	0.00	13.36	231.39	1173.10
2/18/20 1:20	246.10	28.66	0.00	13.64	233.48	1174.82
2/18/20 1:21	246.25	28.79	0.00	13.46	232.79	1174.09
2/18/20 1:22	246.08	28.83	0.00	13.36	236.65	1173.04
2/18/20 1:23	246.21	29.14	0.00	13.33	241.64	1173.30
2/18/20 1:24	245.80	28.62	0.00	13.36	245.83	1172.80
2/18/20 1:25	246.55	28.62	0.00	13.31	245.14	1172.70
2/18/20 1:26	246.59	28.76	0.00	13.46	237.55	1174.00
2/18/20 1:27	246.34	28.66	0.00	13.29	228.23	1173.33
2/18/20 1:28	245.92	28.62	0.00	13.48	229.84	1172.90
2/18/20 1:29	245.91	28.90	0.00	13.31	232.06	1173.70
2/18/20 1:30	245.65	28.73	0.00	13.32	234.08	1172.58
2/18/20 1:31	246.26	28.77	0.00	13.23	235.42	1173.41
2/18/20 1:32	245.91	28.78	0.00	13.76	237.66	1173.65
2/18/20 1:33	245.74	28.72	0.00	13.53	237.32	1173.05
2/18/20 1:34	245.77	28.72	0.00	13.78	237.44	1172.39
2/18/20 1:35	246.56	28.87	0.00	13.26	243.14	1173.09
2/18/20 1:36	246.40	29.03	0.00	13.34	250.32	1172.90
2/18/20 1:37	246.49	28.77	0.00	13.41	248.25	1173.18
2/18/20 1:38	246.11	28.99	0.00	13.38	242.39	1173.35
2/18/20 1:39	245.97	28.62	0.00	13.15	238.16	1172.10
2/18/20 1:40	246.50	28.67	0.00	13.20	232.61	1173.22
2/18/20 1:41	246.56	28.95	0.00	13.42	232.36	1172.69
2/18/20 1:42	246.19	28.69	0.00	13.51	226.62	1172.97
2/18/20 1:43	246.11	28.87	0.00	13.57	229.28	1173.80
2/18/20 1:44	246.02	29.03	0.00	13.36	234.49	1172.41
2/18/20 1:45	245.97	28.79	0.00	13.31	241.50	1172.93
2/18/20 1:46	246.24	28.89	0.00	13.46	245.20	1173.42
2/18/20 1:47	246.28	28.84	0.00	13.45	242.97	1173.61
2/18/20 1:48	246.13	28.71	0.00	13.31	237.98	1173.05
2/18/20 1:49	246.02	28.85	0.00	13.54	235.63	1173.45
2/18/20 1:50	246.07	28.72	0.00	13.41	234.43	1173.89
2/18/20 1:51	246.27	28.67	0.00	13.21	236.89	1172.56
2/18/20 1:52	245.71	28.77	0.00	13.28	235.49	1172.01
2/18/20 1:53	245.51	28.77	0.00	13.19	228.81	1172.20
2/18/20 1:54	246.01	28.92	0.00	13.34	223.41	1173.08
2/18/20 1:55	246.14	28.93	0.00	13.53	217.44	1174.00
2/18/20 1:56	246.04	28.69	0.00	13.61	215.76	1173.70
2/18/20 1:57	245.90	28.80	0.00	13.40	221.37	1173.27
2/18/20 1:58	245.28	28.72	0.00	13.30	221.34	1173.07
2/18/20 1:59	245.74	28.79	0.00	13.45	227.44	1173.60
2/18/20 2:00	245.43	28.80	0.00	13.40	232.51	1172.94
2/18/20 2:01	245.42	28.83	0.00	13.36	229.03	1172.08
2/18/20 2:02	245.87	28.76	0.00	13.22	221.58	1173.07
2/18/20 2:03	245.23	28.79	0.00	13.41	212.09	1172.98
2/18/20 2:04	245.45	28.75	0.00	13.34	208.42	1173.67
2/18/20 2:05	245.49	28.73	0.00	13.55	205.78	1172.59
2/18/20 2:06	245.96	28.95	0.00	13.31	206.85	1172.62
2/18/20 2:07	245.85	28.70	0.00	13.32	206.98	1172.47
2/18/20 2:08	245.62	28.87	0.00	13.37	218.99	1172.92
2/18/20 2:09	245.37	28.67	0.00	13.29	230.60	1172.93
2/18/20 2:10	246.13	28.72	0.00	13.44	238.82	1173.50
2/18/20 2:11	245.76	28.86	0.00	13.65	236.32	1173.53
2/18/20 2:12	245.11	28.61	0.00	13.72	234.02	1172.37
2/18/20 2:13	245.61	29.06	0.00	13.41	229.84	1173.01
2/18/20 2:14	245.08	28.48	0.00	13.65	226.53	1172.51
2/18/20 2:15	245.64	28.89	0.00	13.22	213.23	1172.86
2/18/20 2:16	245.66	28.74	0.00	13.41	206.79	1172.80
2/18/20 2:17	245.03	28.94	0.00	13.45	205.63	1172.90
2/18/20 2:18	245.07	28.82	0.00	13.38	208.63	1172.68
2/18/20 2:19	245.47	28.69	0.00	13.36	210.16	1172.70
2/18/20 2:20	245.63	28.61	0.00	13.32	215.71	1172.57
2/18/20 2:21	245.64	28.95	0.00	13.21	220.24	1173.25
2/18/20 2:22	245.50	28.62	0.00	13.36	216.07	1172.42
2/18/20 2:23	246.17	28.54	0.00	13.82	221.39	1173.32
2/18/20 2:24	245.57	28.71	0.00	13.38	216.47	1172.97
2/18/20 2:25	245.28	28.84	0.00	13.85	217.45	1173.45

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 23:5 - 2/18 4:5)	245.71	28.75	0.00	13.42	225.55	1172.81
COUNT = 301						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 2:26	245.00	28.59	0.00	13.31	217.56	1171.66
2/18/20 2:27	245.91	28.67	0.00	13.41	218.84	1173.25
2/18/20 2:28	245.64	28.78	0.00	13.29	225.89	1172.35
2/18/20 2:29	245.24	28.76	0.00	13.43	226.27	1172.90
2/18/20 2:30	245.67	29.09	0.00	13.11	223.53	1172.06
2/18/20 2:31	245.38	28.38	0.00	13.45	220.56	1172.67
2/18/20 2:32	245.50	28.64	0.00	13.44	222.54	1172.61
2/18/20 2:33	245.44	28.66	0.00	13.22	223.90	1171.93
2/18/20 2:34	245.85	28.75	0.00	13.52	224.53	1172.47
2/18/20 2:35	244.85	28.81	0.00	13.49	223.27	1171.88
2/18/20 2:36	245.46	28.69	0.00	13.57	226.81	1172.12
2/18/20 2:37	245.56	28.67	0.00	13.57	228.67	1172.46
2/18/20 2:38	245.40	28.64	0.00	13.27	226.94	1172.85
2/18/20 2:39	245.07	28.65	0.00	13.32	220.96	1172.24
2/18/20 2:40	244.99	28.58	0.00	13.36	217.60	1172.17
2/18/20 2:41	245.55	28.65	0.00	13.42	216.59	1172.24
2/18/20 2:42	245.33	28.69	0.00	13.38	220.83	1172.25
2/18/20 2:43	245.66	28.81	0.00	13.45	219.61	1172.98
2/18/20 2:44	245.61	28.61	0.00	13.67	210.53	1173.07
2/18/20 2:45	245.29	28.68	0.00	13.43	213.87	1172.59
2/18/20 2:46	245.21	28.73	0.00	13.32	212.54	1172.04
2/18/20 2:47	245.24	28.76	0.00	13.31	214.01	1172.43
2/18/20 2:48	244.97	28.68	0.00	13.49	215.03	1172.48
2/18/20 2:49	245.16	28.73	0.00	13.32	209.66	1172.61
2/18/20 2:50	244.60	28.75	0.00	13.36	208.46	1172.14
2/18/20 2:51	245.33	28.67	0.00	13.86	206.97	1173.20
2/18/20 2:52	245.19	28.66	0.00	13.27	215.05	1173.35
2/18/20 2:53	244.62	28.74	0.00	13.38	217.73	1171.72
2/18/20 2:54	245.08	28.73	0.00	13.47	225.71	1172.27
2/18/20 2:55	245.08	28.41	0.00	13.57	228.50	1172.63
2/18/20 2:56	244.86	28.53	0.00	13.39	222.20	1171.17
2/18/20 2:57	245.12	28.79	0.00	13.44	219.23	1172.67
2/18/20 2:58	244.82	28.76	0.00	13.59	211.09	1172.60
2/18/20 2:59	245.04	28.88	0.00	13.79	206.94	1172.62
2/18/20 3:00	244.85	28.61	0.00	13.37	209.13	1171.80
2/18/20 3:01	245.35	28.81	0.00	13.33	205.04	1172.96
2/18/20 3:02	245.21	28.83	0.00	13.44	205.13	1172.77
2/18/20 3:03	244.93	28.74	0.00	13.49	209.35	1171.98
2/18/20 3:04	245.30	28.71	0.00	13.52	215.79	1173.65
2/18/20 3:05	245.58	28.69	0.00	13.27	219.88	1172.13
2/18/20 3:06	245.02	28.89	0.00	13.29	213.34	1171.86
2/18/20 3:07	245.75	28.65	0.00	13.63	209.66	1172.71
2/18/20 3:08	245.88	28.78	0.00	13.37	208.52	1171.98
2/18/20 3:09	244.95	28.63	0.00	13.43	209.87	1171.98
2/18/20 3:10	245.05	28.70	0.00	13.30	216.60	1171.91
2/18/20 3:11	244.55	28.96	0.00	13.48	218.10	1172.28
2/18/20 3:12	245.38	28.86	0.00	13.32	218.53	1172.14
2/18/20 3:13	244.75	28.70	0.00	13.30	217.45	1170.92
2/18/20 3:14	245.43	28.56	0.00	13.42	217.72	1172.80
2/18/20 3:15	245.20	28.77	0.00	13.25	214.16	1172.22
2/18/20 3:16	244.71	28.65	0.00	13.53	215.28	1172.14
2/18/20 3:17	245.15	28.72	0.00	13.37	213.46	1171.15
2/18/20 3:18	245.10	28.77	0.00	13.40	216.66	1172.26
2/18/20 3:19	245.51	28.76	0.00	13.45	218.84	1171.84
2/18/20 3:20	245.00	28.61	0.00	13.36	215.88	1172.30
2/18/20 3:21	245.41	28.72	0.00	13.38	212.55	1172.42
2/18/20 3:22	245.13	28.75	0.00	13.37	206.59	1172.22
2/18/20 3:23	244.36	28.87	0.00	13.26	204.42	1171.73
2/18/20 3:24	245.12	28.62	0.00	13.39	204.11	1171.50
2/18/20 3:25	244.70	28.78	0.00	13.40	206.73	1172.86
2/18/20 3:26	244.67	28.66	0.00	13.58	211.59	1172.11
2/18/20 3:27	245.26	28.53	0.00	13.40	220.61	1172.17
2/18/20 3:28	244.74	28.75	0.00	13.18	224.43	1170.52
2/18/20 3:29	245.03	28.61	0.00	13.43	223.71	1171.93
2/18/20 3:30	244.48	28.67	0.00	13.62	214.16	1171.74
2/18/20 3:31	244.69	28.85	0.00	13.41	209.13	1172.17
2/18/20 3:32	244.91	28.86	0.00	13.28	207.82	1171.24

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 23:5 - 2/18 4:5) COUNT = 301		245.71	28.75	0.00	13.42	225.55	1172.81
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/18/20 3:33	244.96	28.74	0.00	13.34	210.34	1171.89
	2/18/20 3:34	244.79	28.71	0.00	13.38	208.77	1171.55
	2/18/20 3:35	245.22	28.79	0.00	13.74	208.37	1172.31
	2/18/20 3:36	245.08	28.85	0.00	13.34	205.79	1172.12
	2/18/20 3:37	245.05	28.50	0.00	13.24	209.37	1171.92
	2/18/20 3:38	245.00	28.70	0.00	13.54	205.44	1172.06
	2/18/20 3:39	244.95	28.63	0.00	13.66	207.12	1172.03
	2/18/20 3:40	244.67	28.51	0.00	13.26	212.91	1171.29
	2/18/20 3:41	244.88	28.75	0.00	13.54	218.98	1172.25
	2/18/20 3:42	245.15	28.56	0.00	13.52	219.42	1172.24
	2/18/20 3:43	245.69	28.76	0.00	13.60	218.42	1173.05
	2/18/20 3:44	244.84	28.79	0.00	13.48	215.98	1171.97
	2/18/20 3:45	244.80	28.45	0.00	13.48	213.92	1171.43
	2/18/20 3:46	244.66	28.65	0.00	13.28	215.07	1171.26
	2/18/20 3:47	245.04	28.64	0.00	13.47	213.01	1171.85
	2/18/20 3:48	244.56	28.64	0.00	13.32	212.01	1170.93
	2/18/20 3:49	245.38	28.68	0.00	13.28	209.76	1172.17
	2/18/20 3:50	244.90	28.53	0.00	13.44	210.99	1171.09
	2/18/20 3:51	244.77	28.47	0.00	13.42	213.79	1172.04
	2/18/20 3:52	244.71	28.68	0.00	13.26	214.50	1170.96
	2/18/20 3:53	244.98	28.78	0.00	13.42	220.32	1172.11
	2/18/20 3:54	244.89	28.58	0.00	13.33	214.70	1171.36
	2/18/20 3:55	244.81	28.59	0.00	13.79	204.14	1172.07
	2/18/20 3:56	245.14	28.68	0.00	13.52	198.82	1171.99
	2/18/20 3:57	244.77	28.74	0.00	13.35	195.48	1171.97
	2/18/20 3:58	244.61	28.67	0.00	13.41	200.81	1171.39
	2/18/20 3:59	245.30	28.65	0.00	13.36	202.54	1172.36
	2/18/20 4:00	244.95	28.63	0.00	13.62	203.94	1171.07
	2/18/20 4:01	245.24	28.67	0.00	13.48	207.75	1171.92
	2/18/20 4:02	244.42	28.66	0.00	13.36	213.41	1171.42
	2/18/20 4:03	244.84	28.54	0.00	13.27	213.92	1172.10
	2/18/20 4:04	244.87	28.67	0.00	13.44	213.96	1171.29
	2/18/20 4:05	244.55	28.59	0.00	13.51	209.07	1171.85

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 14:25 - 2/19 18:27)		242.72	28.40	1.99	13.37	194.48	1168.05
COUNT = 243							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 14:25	242.07	28.32	4.39	13.43	190.66	1167.02
	2/19/20 14:26	242.07	28.32	4.37	13.43	190.69	1167.03
	2/19/20 14:27	242.08	28.32	4.35	13.43	190.72	1167.03
	2/19/20 14:28	242.08	28.32	4.33	13.43	190.75	1167.04
	2/19/20 14:29	242.09	28.32	4.31	13.43	190.78	1167.05
	2/19/20 14:30	242.09	28.32	4.29	13.43	190.81	1167.06
	2/19/20 14:31	242.10	28.32	4.27	13.43	190.84	1167.07
	2/19/20 14:32	242.10	28.32	4.25	13.43	190.87	1167.08
	2/19/20 14:33	242.11	28.32	4.23	13.43	190.90	1167.09
	2/19/20 14:34	242.12	28.32	4.21	13.43	190.93	1167.10
	2/19/20 14:35	242.12	28.32	4.19	13.43	190.96	1167.11
	2/19/20 14:36	242.13	28.32	4.17	13.43	190.99	1167.12
	2/19/20 14:37	242.13	28.33	4.15	13.43	191.02	1167.12
	2/19/20 14:38	242.14	28.33	4.13	13.43	191.05	1167.13
	2/19/20 14:39	242.14	28.33	4.11	13.43	191.08	1167.14
	2/19/20 14:40	242.15	28.33	4.09	13.43	191.11	1167.15
	2/19/20 14:41	242.15	28.33	4.07	13.43	191.14	1167.16
	2/19/20 14:42	242.16	28.33	4.05	13.43	191.17	1167.17
	2/19/20 14:43	242.16	28.33	4.03	13.43	191.20	1167.18
	2/19/20 14:44	242.17	28.33	4.01	13.43	191.23	1167.19
	2/19/20 14:45	242.17	28.33	3.99	13.43	191.26	1167.20
	2/19/20 14:46	242.18	28.33	3.97	13.42	191.29	1167.20
	2/19/20 14:47	242.18	28.33	3.95	13.42	191.32	1167.21
	2/19/20 14:48	242.19	28.33	3.93	13.42	191.35	1167.22
	2/19/20 14:49	242.19	28.33	3.91	13.42	191.38	1167.23
	2/19/20 14:50	242.20	28.33	3.89	13.42	191.41	1167.24
	2/19/20 14:51	242.20	28.33	3.87	13.42	191.45	1167.25
	2/19/20 14:52	242.21	28.33	3.85	13.42	191.48	1167.26
	2/19/20 14:53	242.22	28.33	3.83	13.42	191.51	1167.27
	2/19/20 14:54	242.22	28.34	3.81	13.42	191.54	1167.28
	2/19/20 14:55	242.23	28.34	3.79	13.42	191.57	1167.28
	2/19/20 14:56	242.23	28.34	3.77	13.42	191.60	1167.29
	2/19/20 14:57	242.24	28.34	3.75	13.42	191.63	1167.30
	2/19/20 14:58	242.24	28.34	3.73	13.42	191.66	1167.31
	2/19/20 14:59	242.25	28.34	3.71	13.42	191.69	1167.32
	2/19/20 15:00	242.25	28.34	3.69	13.42	191.72	1167.33
	2/19/20 15:01	242.26	28.34	3.67	13.42	191.75	1167.34
	2/19/20 15:02	242.26	28.34	3.65	13.42	191.78	1167.35
	2/19/20 15:03	242.27	28.34	3.63	13.42	191.81	1167.36
	2/19/20 15:04	242.27	28.34	3.61	13.42	191.84	1167.36
	2/19/20 15:05	242.28	28.34	3.59	13.42	191.87	1167.37
	2/19/20 15:06	242.28	28.34	3.57	13.42	191.90	1167.38
	2/19/20 15:07	242.29	28.34	3.55	13.42	191.93	1167.39
	2/19/20 15:08	242.29	28.34	3.53	13.41	191.96	1167.40
	2/19/20 15:09	242.30	28.34	3.51	13.41	191.99	1167.41
	2/19/20 15:10	242.31	28.34	3.49	13.41	192.02	1167.42
	2/19/20 15:11	242.31	28.35	3.47	13.41	192.05	1167.43
	2/19/20 15:12	242.32	28.35	3.45	13.41	192.08	1167.44
	2/19/20 15:13	242.32	28.35	3.43	13.41	192.11	1167.45
	2/19/20 15:14	242.33	28.35	3.41	13.41	192.14	1167.45
	2/19/20 15:15	242.33	28.35	3.39	13.41	192.17	1167.46
	2/19/20 15:16	242.34	28.35	3.37	13.41	192.20	1167.47
	2/19/20 15:17	242.34	28.35	3.35	13.41	192.23	1167.48
	2/19/20 15:18	242.35	28.35	3.33	13.41	192.26	1167.49
	2/19/20 15:19	242.35	28.35	3.31	13.41	192.29	1167.50
	2/19/20 15:20	242.36	28.35	3.29	13.41	192.32	1167.51
	2/19/20 15:21	242.36	28.35	3.27	13.41	192.36	1167.52
	2/19/20 15:22	242.37	28.35	3.25	13.41	192.39	1167.53
	2/19/20 15:23	242.37	28.35	3.23	13.41	192.42	1167.53
	2/19/20 15:24	242.38	28.35	3.21	13.41	192.45	1167.54
	2/19/20 15:25	242.38	28.35	3.19	13.41	192.48	1167.55
	2/19/20 15:26	242.39	28.35	3.17	13.41	192.51	1167.56
	2/19/20 15:27	242.40	28.36	3.15	13.41	192.54	1167.57
	2/19/20 15:28	242.40	28.36	3.13	13.41	192.57	1167.58
	2/19/20 15:29	242.41	28.36	3.11	13.41	192.60	1167.59
	2/19/20 15:30	242.41	28.36	3.09	13.40	192.63	1167.60
	2/19/20 15:31	242.42	28.36	3.07	13.40	192.66	1167.61

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 14:25 - 2/19 18:27)	242.72	28.40	1.99	13.37	194.48	1168.05
COUNT = 243						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 15:32	242.42	28.36	3.05	13.40	192.69	1167.61
2/19/20 15:33	242.43	28.36	3.03	13.40	192.72	1167.62
2/19/20 15:34	242.43	28.36	3.01	13.40	192.75	1167.63
2/19/20 15:35	242.44	28.36	2.99	13.40	192.78	1167.64
2/19/20 15:36	242.44	28.36	2.97	13.40	192.81	1167.65
2/19/20 15:37	242.45	28.36	2.95	13.40	192.84	1167.66
2/19/20 15:38	242.45	28.36	2.93	13.40	192.87	1167.67
2/19/20 15:39	242.46	28.36	2.91	13.40	192.90	1167.68
2/19/20 15:40	242.46	28.36	2.89	13.40	192.93	1167.69
2/19/20 15:41	242.47	28.36	2.87	13.40	192.96	1167.69
2/19/20 15:42	242.47	28.36	2.85	13.40	192.99	1167.70
2/19/20 15:43	242.48	28.36	2.83	13.40	193.02	1167.71
2/19/20 15:44	242.49	28.37	2.81	13.40	193.05	1167.72
2/19/20 15:45	242.49	28.37	2.79	13.40	193.08	1167.73
2/19/20 15:46	242.50	28.37	2.77	13.40	193.11	1167.74
2/19/20 15:47	242.50	28.37	2.75	13.40	193.14	1167.75
2/19/20 15:48	242.51	28.37	2.73	13.40	193.17	1167.76
2/19/20 15:49	242.51	28.37	2.71	13.40	193.20	1167.77
2/19/20 15:50	242.52	28.37	2.69	13.40	193.23	1167.78
2/19/20 15:51	242.52	28.37	2.67	13.40	193.27	1167.78
2/19/20 15:52	242.53	28.37	2.65	13.39	193.30	1167.79
2/19/20 15:53	242.53	28.37	2.63	13.39	193.33	1167.80
2/19/20 15:54	242.54	28.37	2.61	13.39	193.36	1167.81
2/19/20 15:55	242.54	28.37	2.59	13.39	193.39	1167.82
2/19/20 15:56	242.55	28.37	2.57	13.39	193.42	1167.83
2/19/20 15:57	242.55	28.37	2.55	13.39	193.45	1167.84
2/19/20 15:58	242.56	28.37	2.53	13.39	193.48	1167.85
2/19/20 15:59	242.56	28.37	2.51	13.39	193.51	1167.86
2/19/20 16:00	242.57	28.37	2.49	13.39	193.54	1167.86
2/19/20 16:01	242.58	28.38	2.47	13.39	193.57	1167.87
2/19/20 16:02	242.58	28.38	2.45	13.39	193.60	1167.88
2/19/20 16:03	242.59	28.38	2.43	13.39	193.63	1167.89
2/19/20 16:04	242.59	28.38	2.41	13.39	193.66	1167.90
2/19/20 16:05	242.60	28.38	2.39	13.39	193.69	1167.91
2/19/20 16:06	242.60	28.38	2.37	13.39	193.72	1167.92
2/19/20 16:07	242.61	28.38	2.35	13.39	193.75	1167.93
2/19/20 16:08	242.61	28.38	2.33	13.39	193.78	1167.94
2/19/20 16:09	242.62	28.38	2.31	13.39	193.81	1167.94
2/19/20 16:10	242.62	28.38	2.29	13.39	193.84	1167.95
2/19/20 16:11	242.63	28.38	2.27	13.39	193.87	1167.96
2/19/20 16:12	242.63	28.38	2.25	13.39	193.90	1167.97
2/19/20 16:13	242.64	28.38	2.23	13.39	193.93	1167.98
2/19/20 16:14	242.64	28.38	2.21	13.38	193.96	1167.99
2/19/20 16:15	242.65	28.38	2.19	13.38	193.99	1168.00
2/19/20 16:16	242.65	28.38	2.17	13.38	194.02	1168.01
2/19/20 16:17	242.66	28.38	2.15	13.38	194.05	1168.02
2/19/20 16:18	242.67	28.39	2.13	13.38	194.08	1168.03
2/19/20 16:19	242.67	28.39	2.11	13.38	194.11	1168.03
2/19/20 16:20	242.68	28.39	2.09	13.38	194.14	1168.04
2/19/20 16:21	242.68	28.39	2.07	13.38	194.18	1168.05
2/19/20 16:22	242.69	28.39	2.05	13.38	194.21	1168.06
2/19/20 16:23	242.69	28.39	2.03	13.38	194.24	1168.07
2/19/20 16:24	242.70	28.39	2.01	13.38	194.27	1168.08
2/19/20 16:25	242.70	28.39	1.99	13.38	194.30	1168.09
2/19/20 16:26	242.71	28.39	1.97	13.38	194.33	1168.10
2/19/20 16:27	242.71	28.39	1.95	13.38	194.36	1168.11
2/19/20 16:28	242.72	28.39	1.93	13.38	194.39	1168.11
2/19/20 16:29	242.72	28.39	1.91	13.38	194.42	1168.12
2/19/20 16:30	242.73	28.39	1.89	13.38	194.45	1168.13
2/19/20 16:31	242.73	28.39	1.87	13.38	194.48	1168.14
2/19/20 16:32	242.74	28.39	1.85	13.38	194.51	1168.15
2/19/20 16:33	242.74	28.39	1.83	13.38	194.54	1168.16
2/19/20 16:34	242.75	28.40	1.81	13.38	194.57	1168.17
2/19/20 16:35	242.76	28.40	1.79	13.38	194.60	1168.18
2/19/20 16:36	242.76	28.40	1.77	13.37	194.63	1168.19
2/19/20 16:37	242.77	28.40	1.75	13.37	194.66	1168.19
2/19/20 16:38	242.77	28.40	1.73	13.37	194.69	1168.20

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 14:25 - 2/19 18:27)	242.72	28.40	1.99	13.37	194.48	1168.05
COUNT = 243						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 16:39	242.78	28.40	1.71	13.37	194.72	1168.21
2/19/20 16:40	242.78	28.40	1.69	13.37	194.75	1168.22
2/19/20 16:41	242.79	28.40	1.67	13.37	194.78	1168.23
2/19/20 16:42	242.79	28.40	1.65	13.37	194.81	1168.24
2/19/20 16:43	242.80	28.40	1.63	13.37	194.84	1168.25
2/19/20 16:44	242.80	28.40	1.61	13.37	194.87	1168.26
2/19/20 16:45	242.81	28.40	1.59	13.37	194.90	1168.27
2/19/20 16:46	242.81	28.40	1.57	13.37	194.93	1168.27
2/19/20 16:47	242.82	28.40	1.55	13.37	194.96	1168.28
2/19/20 16:48	242.82	28.40	1.53	13.37	194.99	1168.29
2/19/20 16:49	242.83	28.40	1.51	13.37	195.02	1168.30
2/19/20 16:50	242.83	28.40	1.49	13.37	195.05	1168.31
2/19/20 16:51	242.84	28.41	1.47	13.37	195.08	1168.32
2/19/20 16:52	242.85	28.41	1.45	13.37	195.12	1168.33
2/19/20 16:53	242.85	28.41	1.43	13.37	195.15	1168.34
2/19/20 16:54	242.86	28.41	1.41	13.37	195.18	1168.35
2/19/20 16:55	242.86	28.41	1.39	13.37	195.21	1168.36
2/19/20 16:56	242.87	28.41	1.37	13.37	195.24	1168.36
2/19/20 16:57	242.87	28.41	1.35	13.37	195.27	1168.37
2/19/20 16:58	242.88	28.41	1.33	13.37	195.30	1168.38
2/19/20 16:59	242.88	28.41	1.31	13.36	195.33	1168.39
2/19/20 17:00	242.89	28.41	1.29	13.36	195.36	1168.40
2/19/20 17:01	242.89	28.41	1.27	13.36	195.39	1168.41
2/19/20 17:02	242.90	28.41	1.25	13.36	195.42	1168.42
2/19/20 17:03	242.90	28.41	1.23	13.36	195.45	1168.43
2/19/20 17:04	242.91	28.41	1.21	13.36	195.48	1168.44
2/19/20 17:05	242.91	28.41	1.19	13.36	195.51	1168.44
2/19/20 17:06	242.92	28.41	1.17	13.36	195.54	1168.45
2/19/20 17:07	242.92	28.41	1.15	13.36	195.57	1168.46
2/19/20 17:08	242.93	28.42	1.13	13.36	195.60	1168.47
2/19/20 17:09	242.93	28.42	1.11	13.36	195.63	1168.48
2/19/20 17:10	242.94	28.42	1.09	13.36	195.66	1168.49
2/19/20 17:11	242.95	28.42	1.07	13.36	195.69	1168.50
2/19/20 17:12	242.95	28.42	1.05	13.36	195.72	1168.51
2/19/20 17:13	242.96	28.42	1.03	13.36	195.75	1168.52
2/19/20 17:14	242.96	28.42	1.01	13.36	195.78	1168.52
2/19/20 17:15	242.97	28.42	0.99	13.36	195.81	1168.53
2/19/20 17:16	242.97	28.42	0.97	13.36	195.84	1168.54
2/19/20 17:17	242.98	28.42	0.95	13.36	195.87	1168.55
2/19/20 17:18	242.98	28.42	0.93	13.36	195.90	1168.56
2/19/20 17:19	242.99	28.42	0.91	13.36	195.93	1168.57
2/19/20 17:20	242.99	28.42	0.89	13.36	195.96	1168.58
2/19/20 17:21	243.00	28.42	0.87	13.35	195.99	1168.59
2/19/20 17:22	243.00	28.42	0.85	13.35	196.03	1168.60
2/19/20 17:23	243.01	28.42	0.83	13.35	196.06	1168.60
2/19/20 17:24	243.01	28.42	0.81	13.35	196.09	1168.61
2/19/20 17:25	243.02	28.43	0.79	13.35	196.12	1168.62
2/19/20 17:26	243.02	28.43	0.77	13.35	196.15	1168.63
2/19/20 17:27	243.03	28.43	0.75	13.35	196.18	1168.64
2/19/20 17:28	243.04	28.43	0.73	13.35	196.21	1168.65
2/19/20 17:29	243.04	28.43	0.71	13.35	196.24	1168.66
2/19/20 17:30	243.05	28.43	0.69	13.35	196.27	1168.67
2/19/20 17:31	243.05	28.43	0.67	13.35	196.30	1168.68
2/19/20 17:32	243.06	28.43	0.65	13.35	196.33	1168.69
2/19/20 17:33	243.06	28.43	0.63	13.35	196.36	1168.69
2/19/20 17:34	243.07	28.43	0.61	13.35	196.39	1168.70
2/19/20 17:35	243.07	28.43	0.59	13.35	196.42	1168.71
2/19/20 17:36	243.08	28.43	0.57	13.35	196.45	1168.72
2/19/20 17:37	243.08	28.43	0.55	13.35	196.48	1168.73
2/19/20 17:38	243.09	28.43	0.53	13.35	196.51	1168.74
2/19/20 17:39	243.09	28.43	0.51	13.35	196.54	1168.75
2/19/20 17:40	243.10	28.43	0.49	13.35	196.57	1168.76
2/19/20 17:41	243.10	28.44	0.47	13.35	196.60	1168.77
2/19/20 17:42	243.11	28.44	0.45	13.35	196.63	1168.77
2/19/20 17:43	243.11	28.44	0.43	13.34	196.66	1168.78
2/19/20 17:44	243.12	28.44	0.41	13.34	196.69	1168.79
2/19/20 17:45	243.13	28.44	0.39	13.34	196.72	1168.80

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 14:25 - 2/19 18:27)	242.72	28.40	1.99	13.37	194.48	1168.05
COUNT = 243						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 17:46	243.13	28.44	0.37	13.34	196.75	1168.81
2/19/20 17:47	243.14	28.44	0.35	13.34	196.78	1168.82
2/19/20 17:48	243.14	28.44	0.33	13.34	196.81	1168.83
2/19/20 17:49	243.15	28.44	0.31	13.34	196.84	1168.84
2/19/20 17:50	243.15	28.44	0.29	13.34	196.87	1168.85
2/19/20 17:51	243.16	28.44	0.27	13.34	196.90	1168.85
2/19/20 17:52	243.16	28.44	0.25	13.34	196.94	1168.86
2/19/20 17:53	243.17	28.44	0.23	13.34	196.97	1168.87
2/19/20 17:54	243.17	28.44	0.21	13.34	197.00	1168.88
2/19/20 17:55	243.18	28.44	0.19	13.34	197.03	1168.89
2/19/20 17:56	243.18	28.44	0.17	13.34	197.06	1168.90
2/19/20 17:57	243.19	28.44	0.15	13.34	197.09	1168.91
2/19/20 17:58	243.19	28.45	0.13	13.34	197.12	1168.92
2/19/20 17:59	243.20	28.45	0.11	13.34	197.15	1168.93
2/19/20 18:00	243.20	28.45	0.09	13.34	197.18	1168.93
2/19/20 18:01	243.21	28.45	0.07	13.34	197.21	1168.94
2/19/20 18:02	243.22	28.45	0.05	13.34	197.24	1168.95
2/19/20 18:03	243.22	28.45	0.03	13.34	197.27	1168.96
2/19/20 18:04	243.23	28.45	0.01	13.34	197.30	1168.97
2/19/20 18:05	243.23	28.45	0.00	13.33	197.33	1168.98
2/19/20 18:06	243.24	28.45	0.00	13.33	197.36	1168.99
2/19/20 18:07	243.24	28.45	0.00	13.33	197.39	1169.00
2/19/20 18:08	243.25	28.45	0.00	13.33	197.42	1169.01
2/19/20 18:09	243.25	28.45	0.00	13.33	197.45	1169.02
2/19/20 18:10	243.26	28.45	0.00	13.33	197.48	1169.02
2/19/20 18:11	242.83	28.36	0.00	13.09	198.53	1167.30
2/19/20 18:12	243.45	28.54	0.00	13.05	198.29	1168.17
2/19/20 18:13	243.43	28.74	0.00	13.21	191.20	1168.55
2/19/20 18:14	243.67	28.42	0.00	13.26	190.86	1168.46
2/19/20 18:15	243.33	28.60	0.00	13.22	196.30	1167.89
2/19/20 18:16	243.43	28.38	0.00	13.35	202.09	1168.12
2/19/20 18:17	243.38	28.66	0.00	13.58	205.17	1168.71
2/19/20 18:18	243.75	28.61	0.00	13.20	203.97	1168.76
2/19/20 18:19	243.55	28.61	0.00	13.27	201.38	1167.82
2/19/20 18:20	243.35	28.54	0.00	13.19	192.58	1168.62
2/19/20 18:21	243.70	28.71	0.00	13.40	188.89	1169.23
2/19/20 18:22	243.72	28.53	0.00	13.27	195.37	1168.88
2/19/20 18:23	243.56	28.51	0.00	13.39	195.69	1168.56
2/19/20 18:24	243.82	28.54	0.00	13.32	201.39	1168.71
2/19/20 18:25	243.48	28.44	0.00	13.25	206.32	1169.39
2/19/20 18:26	243.72	28.48	0.00	13.12	211.43	1168.67
2/19/20 18:27	243.72	28.55	0.00	13.10	219.63	1168.22

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
SAM

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 2:3 - 2/18 4:3)	245.18	28.71	0.00	13.43	214.90	1172.27
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 2:03	245.23	28.79	0.00	13.41	212.09	1172.98
2/18/20 2:04	245.45	28.75	0.00	13.34	208.42	1173.67
2/18/20 2:05	245.49	28.73	0.00	13.55	205.78	1172.59
2/18/20 2:06	245.96	28.95	0.00	13.31	206.85	1172.62
2/18/20 2:07	245.85	28.70	0.00	13.32	206.98	1172.47
2/18/20 2:08	245.62	28.87	0.00	13.37	218.99	1172.92
2/18/20 2:09	245.37	28.67	0.00	13.29	230.60	1172.93
2/18/20 2:10	246.13	28.72	0.00	13.44	238.82	1173.50
2/18/20 2:11	245.76	28.86	0.00	13.65	236.32	1173.53
2/18/20 2:12	245.11	28.61	0.00	13.72	234.02	1172.37
2/18/20 2:13	245.61	29.06	0.00	13.41	229.84	1173.01
2/18/20 2:14	245.08	28.48	0.00	13.65	226.53	1172.51
2/18/20 2:15	245.64	28.89	0.00	13.22	213.23	1172.86
2/18/20 2:16	245.66	28.74	0.00	13.41	206.79	1172.80
2/18/20 2:17	245.03	28.94	0.00	13.45	205.63	1172.90
2/18/20 2:18	245.07	28.82	0.00	13.38	208.63	1172.68
2/18/20 2:19	245.47	28.69	0.00	13.36	210.16	1172.70
2/18/20 2:20	245.63	28.61	0.00	13.32	215.71	1172.57
2/18/20 2:21	245.64	28.95	0.00	13.21	220.24	1173.25
2/18/20 2:22	245.50	28.62	0.00	13.36	216.07	1172.42
2/18/20 2:23	246.17	28.54	0.00	13.82	221.39	1173.32
2/18/20 2:24	245.57	28.71	0.00	13.38	216.47	1172.97
2/18/20 2:25	245.28	28.84	0.00	13.85	217.45	1173.45
2/18/20 2:26	245.00	28.59	0.00	13.31	217.56	1171.66
2/18/20 2:27	245.91	28.67	0.00	13.41	218.84	1173.25
2/18/20 2:28	245.64	28.78	0.00	13.29	225.89	1172.35
2/18/20 2:29	245.24	28.76	0.00	13.43	226.27	1172.90
2/18/20 2:30	245.67	29.09	0.00	13.11	223.53	1172.06
2/18/20 2:31	245.38	28.38	0.00	13.45	220.56	1172.67
2/18/20 2:32	245.50	28.64	0.00	13.44	222.54	1172.61
2/18/20 2:33	245.44	28.66	0.00	13.22	223.90	1171.93
2/18/20 2:34	245.85	28.75	0.00	13.52	224.53	1172.47
2/18/20 2:35	244.85	28.81	0.00	13.49	223.27	1171.88
2/18/20 2:36	245.46	28.69	0.00	13.57	226.81	1172.12
2/18/20 2:37	245.56	28.67	0.00	13.57	228.67	1172.46
2/18/20 2:38	245.40	28.64	0.00	13.27	226.94	1172.85
2/18/20 2:39	245.07	28.65	0.00	13.32	220.96	1172.24
2/18/20 2:40	244.99	28.58	0.00	13.36	217.60	1172.17
2/18/20 2:41	245.55	28.65	0.00	13.42	216.59	1172.24
2/18/20 2:42	245.33	28.69	0.00	13.38	220.83	1172.25
2/18/20 2:43	245.66	28.81	0.00	13.45	219.61	1172.98
2/18/20 2:44	245.61	28.61	0.00	13.67	210.53	1173.07
2/18/20 2:45	245.29	28.68	0.00	13.43	213.87	1172.59
2/18/20 2:46	245.21	28.73	0.00	13.32	212.54	1172.04
2/18/20 2:47	245.24	28.76	0.00	13.31	214.01	1172.43
2/18/20 2:48	244.97	28.68	0.00	13.49	215.03	1172.48
2/18/20 2:49	245.16	28.73	0.00	13.32	209.66	1172.61
2/18/20 2:50	244.60	28.75	0.00	13.36	208.46	1172.14
2/18/20 2:51	245.33	28.67	0.00	13.86	206.97	1173.20
2/18/20 2:52	245.19	28.66	0.00	13.27	215.05	1173.35
2/18/20 2:53	244.62	28.74	0.00	13.38	217.73	1171.72
2/18/20 2:54	245.08	28.73	0.00	13.47	225.71	1172.27
2/18/20 2:55	245.08	28.41	0.00	13.57	228.50	1172.63
2/18/20 2:56	244.86	28.53	0.00	13.39	222.20	1171.17
2/18/20 2:57	245.12	28.79	0.00	13.44	219.23	1172.67
2/18/20 2:58	244.82	28.76	0.00	13.59	211.09	1172.60
2/18/20 2:59	245.04	28.88	0.00	13.79	206.94	1172.62
2/18/20 3:00	244.85	28.61	0.00	13.37	209.13	1171.80
2/18/20 3:01	245.35	28.81	0.00	13.33	205.04	1172.96
2/18/20 3:02	245.21	28.83	0.00	13.44	205.13	1172.77
2/18/20 3:03	244.93	28.74	0.00	13.49	209.35	1171.98
2/18/20 3:04	245.30	28.71	0.00	13.52	215.79	1173.65
2/18/20 3:05	245.58	28.69	0.00	13.27	219.88	1172.13
2/18/20 3:06	245.02	28.89	0.00	13.29	213.34	1171.86
2/18/20 3:07	245.75	28.65	0.00	13.63	209.66	1172.71
2/18/20 3:08	245.88	28.78	0.00	13.37	208.52	1171.98
2/18/20 3:09	244.95	28.63	0.00	13.43	209.87	1171.98

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 2:3 - 2/18 4:3)	245.18	28.71	0.00	13.43	214.90	1172.27
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 3:10	245.05	28.70	0.00	13.30	216.60	1171.91
2/18/20 3:11	244.55	28.96	0.00	13.48	218.10	1172.28
2/18/20 3:12	245.38	28.86	0.00	13.32	218.53	1172.14
2/18/20 3:13	244.75	28.70	0.00	13.30	217.45	1170.92
2/18/20 3:14	245.43	28.56	0.00	13.42	217.72	1172.80
2/18/20 3:15	245.20	28.77	0.00	13.25	214.16	1172.22
2/18/20 3:16	244.71	28.65	0.00	13.53	215.28	1172.14
2/18/20 3:17	245.15	28.72	0.00	13.37	213.46	1171.15
2/18/20 3:18	245.10	28.77	0.00	13.40	216.66	1172.26
2/18/20 3:19	245.51	28.76	0.00	13.45	218.84	1171.84
2/18/20 3:20	245.00	28.61	0.00	13.36	215.88	1172.30
2/18/20 3:21	245.41	28.72	0.00	13.38	212.55	1172.42
2/18/20 3:22	245.13	28.75	0.00	13.37	206.59	1172.22
2/18/20 3:23	244.36	28.87	0.00	13.26	204.42	1171.73
2/18/20 3:24	245.12	28.62	0.00	13.39	204.11	1171.50
2/18/20 3:25	244.70	28.78	0.00	13.40	206.73	1172.86
2/18/20 3:26	244.67	28.66	0.00	13.58	211.59	1172.11
2/18/20 3:27	245.26	28.53	0.00	13.40	220.61	1172.17
2/18/20 3:28	244.74	28.75	0.00	13.18	224.43	1170.52
2/18/20 3:29	245.03	28.61	0.00	13.43	223.71	1171.93
2/18/20 3:30	244.48	28.67	0.00	13.62	214.16	1171.74
2/18/20 3:31	244.69	28.85	0.00	13.41	209.13	1172.17
2/18/20 3:32	244.91	28.86	0.00	13.28	207.82	1171.24
2/18/20 3:33	244.96	28.74	0.00	13.34	210.34	1171.89
2/18/20 3:34	244.79	28.71	0.00	13.38	208.77	1171.55
2/18/20 3:35	245.22	28.79	0.00	13.74	208.37	1172.31
2/18/20 3:36	245.08	28.85	0.00	13.34	205.79	1172.12
2/18/20 3:37	245.05	28.50	0.00	13.24	209.37	1171.92
2/18/20 3:38	245.00	28.70	0.00	13.54	205.44	1172.06
2/18/20 3:39	244.95	28.63	0.00	13.66	207.12	1172.03
2/18/20 3:40	244.67	28.51	0.00	13.26	212.91	1171.29
2/18/20 3:41	244.88	28.75	0.00	13.54	218.98	1172.25
2/18/20 3:42	245.15	28.56	0.00	13.52	219.42	1172.24
2/18/20 3:43	245.69	28.76	0.00	13.60	218.42	1173.05
2/18/20 3:44	244.84	28.79	0.00	13.48	215.98	1171.97
2/18/20 3:45	244.80	28.45	0.00	13.48	213.92	1171.43
2/18/20 3:46	244.66	28.65	0.00	13.28	215.07	1171.26
2/18/20 3:47	245.04	28.64	0.00	13.47	213.01	1171.85
2/18/20 3:48	244.56	28.64	0.00	13.32	212.01	1170.93
2/18/20 3:49	245.38	28.68	0.00	13.28	209.76	1172.17
2/18/20 3:50	244.90	28.53	0.00	13.44	210.99	1171.09
2/18/20 3:51	244.77	28.47	0.00	13.42	213.79	1172.04
2/18/20 3:52	244.71	28.68	0.00	13.26	214.50	1170.96
2/18/20 3:53	244.98	28.78	0.00	13.42	220.32	1172.11
2/18/20 3:54	244.89	28.58	0.00	13.33	214.70	1171.36
2/18/20 3:55	244.81	28.59	0.00	13.79	204.14	1172.07
2/18/20 3:56	245.14	28.68	0.00	13.52	198.82	1171.99
2/18/20 3:57	244.77	28.74	0.00	13.35	195.48	1171.97
2/18/20 3:58	244.61	28.67	0.00	13.41	200.81	1171.39
2/18/20 3:59	245.30	28.65	0.00	13.36	202.54	1172.36
2/18/20 4:00	244.95	28.63	0.00	13.62	203.94	1171.07
2/18/20 4:01	245.24	28.67	0.00	13.48	207.75	1171.92
2/18/20 4:02	244.42	28.66	0.00	13.36	213.41	1171.42
2/18/20 4:03	244.84	28.54	0.00	13.27	213.92	1172.10

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 4:57 - 2/18 6:57)	244.65	28.64	0.10	13.31	206.46	1171.18
COUNT = 121						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 4:57	244.47	28.84	0.00	13.24	214.04	1170.81
2/18/20 4:58	244.93	28.49	0.00	13.25	211.85	1171.50
2/18/20 4:59	244.50	28.63	0.00	13.13	202.84	1171.12
2/18/20 5:00	244.56	28.60	0.00	13.54	195.66	1171.37
2/18/20 5:01	244.68	28.63	0.00	13.22	190.16	1171.16
2/18/20 5:02	244.93	28.63	0.00	13.54	197.15	1171.14
2/18/20 5:03	244.99	28.67	0.00	13.17	200.13	1171.05
2/18/20 5:04	244.47	28.70	0.00	13.33	209.04	1170.73
2/18/20 5:05	244.25	28.66	0.00	13.31	212.84	1170.44
2/18/20 5:06	244.55	28.55	0.00	13.08	215.44	1170.50
2/18/20 5:07	243.90	28.67	0.00	13.01	213.75	1169.13
2/18/20 5:08	244.44	28.80	0.00	13.11	208.17	1170.58
2/18/20 5:09	244.06	28.68	0.00	13.30	201.48	1170.18
2/18/20 5:10	244.71	28.75	0.00	13.14	201.32	1171.21
2/18/20 5:11	244.20	28.72	0.00	13.33	206.73	1171.36
2/18/20 5:12	244.61	28.48	0.00	13.71	210.55	1171.67
2/18/20 5:13	244.84	28.80	0.00	13.60	215.88	1171.30
2/18/20 5:14	245.01	28.50	0.00	13.50	214.18	1171.86
2/18/20 5:15	244.74	28.75	0.00	13.32	214.23	1171.18
2/18/20 5:16	244.39	28.65	0.00	13.39	208.31	1170.73
2/18/20 5:17	244.86	28.63	0.00	13.19	206.50	1171.54
2/18/20 5:18	244.29	28.87	0.00	13.32	201.96	1170.77
2/18/20 5:19	244.93	28.53	0.00	13.36	200.41	1171.21
2/18/20 5:20	245.01	28.78	0.00	13.32	198.02	1171.99
2/18/20 5:21	244.13	28.55	0.00	13.22	197.14	1170.41
2/18/20 5:22	244.51	28.77	0.00	13.06	198.74	1171.83
2/18/20 5:23	244.27	28.56	0.00	13.40	205.92	1171.29
2/18/20 5:24	244.64	28.76	0.00	13.51	212.33	1171.38
2/18/20 5:25	244.65	28.50	0.00	13.46	212.98	1171.71
2/18/20 5:26	244.65	28.81	0.00	13.22	208.21	1171.50
2/18/20 5:27	245.11	28.63	0.00	13.69	202.12	1171.93
2/18/20 5:28	244.68	28.44	0.00	12.99	198.22	1171.86
2/18/20 5:29	244.67	28.81	0.00	13.42	196.38	1171.14
2/18/20 5:30	244.44	28.77	0.00	13.29	196.37	1170.90
2/18/20 5:31	244.48	28.80	0.00	13.25	196.41	1171.07
2/18/20 5:32	244.76	28.48	0.00	13.32	195.81	1171.54
2/18/20 5:33	245.01	28.77	0.00	13.29	202.15	1171.72
2/18/20 5:34	244.32	28.57	0.00	13.29	207.75	1171.05
2/18/20 5:35	244.60	28.73	0.00	13.30	216.34	1171.79
2/18/20 5:36	244.83	28.84	0.00	13.26	219.71	1171.58
2/18/20 5:37	245.07	28.57	0.00	13.40	219.00	1171.84
2/18/20 5:38	244.81	28.55	0.00	13.13	211.69	1171.30
2/18/20 5:39	244.56	28.76	0.00	13.20	202.92	1171.52
2/18/20 5:40	244.81	28.62	0.00	13.58	196.27	1171.60
2/18/20 5:41	244.67	28.69	0.00	13.19	193.05	1171.05
2/18/20 5:42	243.97	28.68	0.00	13.39	191.53	1171.31
2/18/20 5:43	244.60	28.84	0.00	13.48	194.54	1171.57
2/18/20 5:44	244.10	28.56	0.00	13.43	196.55	1170.68
2/18/20 5:45	244.78	28.47	0.00	13.38	202.22	1171.82
2/18/20 5:46	244.67	28.54	0.00	13.45	206.92	1172.39
2/18/20 5:47	244.24	28.67	0.00	13.29	208.71	1171.24
2/18/20 5:48	245.24	28.67	0.00	13.36	210.41	1172.19
2/18/20 5:49	244.15	28.61	0.00	13.25	207.46	1169.93
2/18/20 5:50	244.37	28.84	0.00	13.43	206.58	1171.03
2/18/20 5:51	244.59	28.70	0.00	13.40	204.32	1171.53
2/18/20 5:52	244.59	28.53	0.00	13.46	206.55	1171.82
2/18/20 5:53	244.20	28.77	0.00	13.29	207.34	1170.15
2/18/20 5:54	244.38	28.35	0.00	13.32	203.20	1170.16
2/18/20 5:55	244.20	28.54	0.00	13.19	203.33	1170.40
2/18/20 5:56	244.52	28.67	0.00	13.31	206.51	1170.78
2/18/20 5:57	243.94	28.63	0.00	13.29	209.47	1169.50
2/18/20 5:58	244.49	28.86	0.00	13.42	213.46	1171.43
2/18/20 5:59	244.93	28.61	0.00	13.22	213.85	1171.02
2/18/20 6:00	244.48	28.88	0.00	13.42	214.64	1170.75
2/18/20 6:01	244.81	28.61	0.00	13.34	211.10	1170.92
2/18/20 6:02	244.37	28.49	0.00	13.21	211.77	1170.39
2/18/20 6:03	244.60	28.32	0.00	13.25	206.53	1170.32

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 4:57 - 2/18 6:57)	244.65	28.64	0.10	13.31	206.46	1171.18
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 6:04	244.80	28.56	0.00	13.25	207.35	1171.37
2/18/20 6:05	244.62	28.53	0.00	13.25	207.14	1171.08
2/18/20 6:06	245.05	28.91	0.00	13.22	209.87	1171.41
2/18/20 6:07	244.80	28.48	0.00	13.26	213.25	1171.23
2/18/20 6:08	244.99	28.70	0.00	13.20	213.67	1172.35
2/18/20 6:09	244.97	28.56	0.00	13.42	206.84	1171.62
2/18/20 6:10	244.85	28.91	0.00	13.41	202.96	1171.63
2/18/20 6:11	244.77	28.74	0.00	13.60	201.43	1172.20
2/18/20 6:12	244.38	28.63	0.00	13.40	195.21	1171.35
2/18/20 6:13	244.64	28.55	0.00	13.25	202.99	1171.13
2/18/20 6:14	244.81	28.81	0.00	13.33	206.99	1171.22
2/18/20 6:15	244.64	28.56	0.00	13.25	209.47	1171.38
2/18/20 6:16	244.89	28.37	0.00	13.13	210.43	1171.70
2/18/20 6:17	244.76	28.57	0.00	13.50	207.96	1171.56
2/18/20 6:18	244.98	28.35	0.00	13.26	207.60	1170.70
2/18/20 6:19	244.89	28.64	0.00	13.46	201.97	1171.92
2/18/20 6:20	245.22	28.67	0.02	13.07	204.18	1171.24
2/18/20 6:21	244.44	28.53	0.03	13.19	203.96	1170.43
2/18/20 6:22	244.19	28.50	0.05	13.10	202.14	1170.14
2/18/20 6:23	244.56	28.63	0.07	13.24	202.09	1170.89
2/18/20 6:24	244.58	28.46	0.08	13.45	205.57	1170.16
2/18/20 6:25	245.07	28.62	0.10	13.01	210.69	1170.83
2/18/20 6:26	244.94	28.57	0.11	13.21	214.53	1171.23
2/18/20 6:27	244.25	28.69	0.13	13.20	217.95	1170.00
2/18/20 6:28	244.82	29.03	0.15	13.38	215.17	1171.81
2/18/20 6:29	244.33	28.52	0.16	13.24	210.40	1170.42
2/18/20 6:30	244.48	28.78	0.18	13.12	204.89	1170.99
2/18/20 6:31	245.07	28.60	0.20	13.48	198.86	1171.48
2/18/20 6:32	244.36	28.88	0.21	13.26	201.87	1170.62
2/18/20 6:33	244.51	28.73	0.23	13.08	209.08	1170.90
2/18/20 6:34	245.07	28.71	0.24	13.52	216.63	1171.43
2/18/20 6:35	244.63	28.58	0.26	13.51	221.19	1171.80
2/18/20 6:36	245.15	28.70	0.28	13.25	217.02	1171.62
2/18/20 6:37	244.59	28.60	0.29	13.10	213.23	1170.66
2/18/20 6:38	244.62	28.58	0.31	13.47	204.73	1171.64
2/18/20 6:39	244.37	28.74	0.32	13.13	200.27	1171.07
2/18/20 6:40	244.84	28.66	0.34	13.82	200.99	1172.37
2/18/20 6:41	244.98	28.58	0.36	13.47	205.87	1171.08
2/18/20 6:42	244.79	28.50	0.37	13.33	215.26	1171.41
2/18/20 6:43	244.94	28.56	0.39	13.25	217.21	1171.74
2/18/20 6:44	244.57	28.66	0.41	13.45	215.89	1170.84
2/18/20 6:45	244.69	28.57	0.42	13.50	207.97	1171.16
2/18/20 6:46	244.81	28.58	0.44	13.27	198.77	1171.02
2/18/20 6:47	245.13	28.55	0.45	13.11	197.42	1170.65
2/18/20 6:48	244.74	28.57	0.47	13.08	196.60	1171.22
2/18/20 6:49	245.07	28.56	0.49	13.56	201.89	1171.95
2/18/20 6:50	244.80	28.74	0.50	13.32	211.10	1170.97
2/18/20 6:51	244.63	28.56	0.52	13.40	215.48	1171.07
2/18/20 6:52	244.95	28.61	0.53	13.47	217.18	1171.71
2/18/20 6:53	245.29	28.82	0.55	13.16	208.71	1171.17
2/18/20 6:54	244.29	28.63	0.57	13.18	204.44	1171.22
2/18/20 6:55	244.52	28.63	0.58	13.25	202.89	1171.34
2/18/20 6:56	244.63	28.47	0.60	13.20	202.50	1171.29
2/18/20 6:57	244.52	28.54	0.62	13.25	205.17	1171.82

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 14:32 - 2/19 16:32)	242.42	28.36	3.05	13.40	192.69	1167.61
COUNT = 121						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 14:32	242.10	28.32	4.25	13.43	190.87	1167.08
2/19/20 14:33	242.11	28.32	4.23	13.43	190.90	1167.09
2/19/20 14:34	242.12	28.32	4.21	13.43	190.93	1167.10
2/19/20 14:35	242.12	28.32	4.19	13.43	190.96	1167.11
2/19/20 14:36	242.13	28.32	4.17	13.43	190.99	1167.12
2/19/20 14:37	242.13	28.33	4.15	13.43	191.02	1167.12
2/19/20 14:38	242.14	28.33	4.13	13.43	191.05	1167.13
2/19/20 14:39	242.14	28.33	4.11	13.43	191.08	1167.14
2/19/20 14:40	242.15	28.33	4.09	13.43	191.11	1167.15
2/19/20 14:41	242.15	28.33	4.07	13.43	191.14	1167.16
2/19/20 14:42	242.16	28.33	4.05	13.43	191.17	1167.17
2/19/20 14:43	242.16	28.33	4.03	13.43	191.20	1167.18
2/19/20 14:44	242.17	28.33	4.01	13.43	191.23	1167.19
2/19/20 14:45	242.17	28.33	3.99	13.43	191.26	1167.20
2/19/20 14:46	242.18	28.33	3.97	13.42	191.29	1167.20
2/19/20 14:47	242.18	28.33	3.95	13.42	191.32	1167.21
2/19/20 14:48	242.19	28.33	3.93	13.42	191.35	1167.22
2/19/20 14:49	242.19	28.33	3.91	13.42	191.38	1167.23
2/19/20 14:50	242.20	28.33	3.89	13.42	191.41	1167.24
2/19/20 14:51	242.20	28.33	3.87	13.42	191.45	1167.25
2/19/20 14:52	242.21	28.33	3.85	13.42	191.48	1167.26
2/19/20 14:53	242.22	28.33	3.83	13.42	191.51	1167.27
2/19/20 14:54	242.22	28.34	3.81	13.42	191.54	1167.28
2/19/20 14:55	242.23	28.34	3.79	13.42	191.57	1167.28
2/19/20 14:56	242.23	28.34	3.77	13.42	191.60	1167.29
2/19/20 14:57	242.24	28.34	3.75	13.42	191.63	1167.30
2/19/20 14:58	242.24	28.34	3.73	13.42	191.66	1167.31
2/19/20 14:59	242.25	28.34	3.71	13.42	191.69	1167.32
2/19/20 15:00	242.25	28.34	3.69	13.42	191.72	1167.33
2/19/20 15:01	242.26	28.34	3.67	13.42	191.75	1167.34
2/19/20 15:02	242.26	28.34	3.65	13.42	191.78	1167.35
2/19/20 15:03	242.27	28.34	3.63	13.42	191.81	1167.36
2/19/20 15:04	242.27	28.34	3.61	13.42	191.84	1167.36
2/19/20 15:05	242.28	28.34	3.59	13.42	191.87	1167.37
2/19/20 15:06	242.28	28.34	3.57	13.42	191.90	1167.38
2/19/20 15:07	242.29	28.34	3.55	13.42	191.93	1167.39
2/19/20 15:08	242.29	28.34	3.53	13.41	191.96	1167.40
2/19/20 15:09	242.30	28.34	3.51	13.41	191.99	1167.41
2/19/20 15:10	242.31	28.34	3.49	13.41	192.02	1167.42
2/19/20 15:11	242.31	28.35	3.47	13.41	192.05	1167.43
2/19/20 15:12	242.32	28.35	3.45	13.41	192.08	1167.44
2/19/20 15:13	242.32	28.35	3.43	13.41	192.11	1167.45
2/19/20 15:14	242.33	28.35	3.41	13.41	192.14	1167.45
2/19/20 15:15	242.33	28.35	3.39	13.41	192.17	1167.46
2/19/20 15:16	242.34	28.35	3.37	13.41	192.20	1167.47
2/19/20 15:17	242.34	28.35	3.35	13.41	192.23	1167.48
2/19/20 15:18	242.35	28.35	3.33	13.41	192.26	1167.49
2/19/20 15:19	242.35	28.35	3.31	13.41	192.29	1167.50
2/19/20 15:20	242.36	28.35	3.29	13.41	192.32	1167.51
2/19/20 15:21	242.36	28.35	3.27	13.41	192.36	1167.52
2/19/20 15:22	242.37	28.35	3.25	13.41	192.39	1167.53
2/19/20 15:23	242.37	28.35	3.23	13.41	192.42	1167.53
2/19/20 15:24	242.38	28.35	3.21	13.41	192.45	1167.54
2/19/20 15:25	242.38	28.35	3.19	13.41	192.48	1167.55
2/19/20 15:26	242.39	28.35	3.17	13.41	192.51	1167.56
2/19/20 15:27	242.40	28.36	3.15	13.41	192.54	1167.57
2/19/20 15:28	242.40	28.36	3.13	13.41	192.57	1167.58
2/19/20 15:29	242.41	28.36	3.11	13.41	192.60	1167.59
2/19/20 15:30	242.41	28.36	3.09	13.40	192.63	1167.60
2/19/20 15:31	242.42	28.36	3.07	13.40	192.66	1167.61
2/19/20 15:32	242.42	28.36	3.05	13.40	192.69	1167.61
2/19/20 15:33	242.43	28.36	3.03	13.40	192.72	1167.62
2/19/20 15:34	242.43	28.36	3.01	13.40	192.75	1167.63
2/19/20 15:35	242.44	28.36	2.99	13.40	192.78	1167.64
2/19/20 15:36	242.44	28.36	2.97	13.40	192.81	1167.65
2/19/20 15:37	242.45	28.36	2.95	13.40	192.84	1167.66
2/19/20 15:38	242.45	28.36	2.93	13.40	192.87	1167.67

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 14:32 - 2/19 16:32)	242.42	28.36	3.05	13.40	192.69	1167.61
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 15:39	242.46	28.36	2.91	13.40	192.90	1167.68
2/19/20 15:40	242.46	28.36	2.89	13.40	192.93	1167.69
2/19/20 15:41	242.47	28.36	2.87	13.40	192.96	1167.69
2/19/20 15:42	242.47	28.36	2.85	13.40	192.99	1167.70
2/19/20 15:43	242.48	28.36	2.83	13.40	193.02	1167.71
2/19/20 15:44	242.49	28.37	2.81	13.40	193.05	1167.72
2/19/20 15:45	242.49	28.37	2.79	13.40	193.08	1167.73
2/19/20 15:46	242.50	28.37	2.77	13.40	193.11	1167.74
2/19/20 15:47	242.50	28.37	2.75	13.40	193.14	1167.75
2/19/20 15:48	242.51	28.37	2.73	13.40	193.17	1167.76
2/19/20 15:49	242.51	28.37	2.71	13.40	193.20	1167.77
2/19/20 15:50	242.52	28.37	2.69	13.40	193.23	1167.78
2/19/20 15:51	242.52	28.37	2.67	13.40	193.27	1167.78
2/19/20 15:52	242.53	28.37	2.65	13.39	193.30	1167.79
2/19/20 15:53	242.53	28.37	2.63	13.39	193.33	1167.80
2/19/20 15:54	242.54	28.37	2.61	13.39	193.36	1167.81
2/19/20 15:55	242.54	28.37	2.59	13.39	193.39	1167.82
2/19/20 15:56	242.55	28.37	2.57	13.39	193.42	1167.83
2/19/20 15:57	242.55	28.37	2.55	13.39	193.45	1167.84
2/19/20 15:58	242.56	28.37	2.53	13.39	193.48	1167.85
2/19/20 15:59	242.56	28.37	2.51	13.39	193.51	1167.86
2/19/20 16:00	242.57	28.37	2.49	13.39	193.54	1167.86
2/19/20 16:01	242.58	28.38	2.47	13.39	193.57	1167.87
2/19/20 16:02	242.58	28.38	2.45	13.39	193.60	1167.88
2/19/20 16:03	242.59	28.38	2.43	13.39	193.63	1167.89
2/19/20 16:04	242.59	28.38	2.41	13.39	193.66	1167.90
2/19/20 16:05	242.60	28.38	2.39	13.39	193.69	1167.91
2/19/20 16:06	242.60	28.38	2.37	13.39	193.72	1167.92
2/19/20 16:07	242.61	28.38	2.35	13.39	193.75	1167.93
2/19/20 16:08	242.61	28.38	2.33	13.39	193.78	1167.94
2/19/20 16:09	242.62	28.38	2.31	13.39	193.81	1167.94
2/19/20 16:10	242.62	28.38	2.29	13.39	193.84	1167.95
2/19/20 16:11	242.63	28.38	2.27	13.39	193.87	1167.96
2/19/20 16:12	242.63	28.38	2.25	13.39	193.90	1167.97
2/19/20 16:13	242.64	28.38	2.23	13.39	193.93	1167.98
2/19/20 16:14	242.64	28.38	2.21	13.38	193.96	1167.99
2/19/20 16:15	242.65	28.38	2.19	13.38	193.99	1168.00
2/19/20 16:16	242.65	28.38	2.17	13.38	194.02	1168.01
2/19/20 16:17	242.66	28.38	2.15	13.38	194.05	1168.02
2/19/20 16:18	242.67	28.39	2.13	13.38	194.08	1168.03
2/19/20 16:19	242.67	28.39	2.11	13.38	194.11	1168.03
2/19/20 16:20	242.68	28.39	2.09	13.38	194.14	1168.04
2/19/20 16:21	242.68	28.39	2.07	13.38	194.18	1168.05
2/19/20 16:22	242.69	28.39	2.05	13.38	194.21	1168.06
2/19/20 16:23	242.69	28.39	2.03	13.38	194.24	1168.07
2/19/20 16:24	242.70	28.39	2.01	13.38	194.27	1168.08
2/19/20 16:25	242.70	28.39	1.99	13.38	194.30	1168.09
2/19/20 16:26	242.71	28.39	1.97	13.38	194.33	1168.10
2/19/20 16:27	242.71	28.39	1.95	13.38	194.36	1168.11
2/19/20 16:28	242.72	28.39	1.93	13.38	194.39	1168.11
2/19/20 16:29	242.72	28.39	1.91	13.38	194.42	1168.12
2/19/20 16:30	242.73	28.39	1.89	13.38	194.45	1168.13
2/19/20 16:31	242.73	28.39	1.87	13.38	194.48	1168.14
2/19/20 16:32	242.74	28.39	1.85	13.38	194.51	1168.15

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
Opacity

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 12:30 - 2/17 13:30)	240.76	28.31	0.00	13.41	172.67	1166.35
COUNT = 61						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 12:30	240.67	28.37	0.00	13.33	194.44	1166.05
2/17/20 12:31	240.75	28.34	0.00	13.47	192.38	1166.64
2/17/20 12:32	241.22	28.31	0.00	13.27	180.61	1166.83
2/17/20 12:33	241.24	28.24	0.00	13.49	162.25	1167.14
2/17/20 12:34	241.33	28.25	0.00	13.46	159.46	1166.86
2/17/20 12:35	240.97	28.30	0.00	13.34	159.67	1166.17
2/17/20 12:36	241.02	28.33	0.00	13.50	177.19	1167.84
2/17/20 12:37	240.80	28.29	0.00	13.46	182.06	1166.39
2/17/20 12:38	241.18	28.38	0.00	13.64	189.33	1167.03
2/17/20 12:39	240.59	28.40	0.00	13.54	186.44	1166.31
2/17/20 12:40	240.73	28.33	0.00	13.32	172.27	1167.23
2/17/20 12:41	240.71	28.23	0.00	13.29	166.11	1167.11
2/17/20 12:42	240.62	28.28	0.00	13.57	156.94	1166.52
2/17/20 12:43	240.86	28.30	0.00	13.40	158.51	1167.14
2/17/20 12:44	240.72	28.25	0.00	13.47	166.87	1166.74
2/17/20 12:45	240.78	28.43	0.00	13.52	175.05	1166.35
2/17/20 12:46	240.33	28.40	0.00	13.75	181.62	1165.76
2/17/20 12:47	241.04	28.30	0.00	13.11	184.64	1166.52
2/17/20 12:48	240.87	28.34	0.00	13.28	172.23	1166.27
2/17/20 12:49	241.33	28.21	0.00	13.59	171.26	1166.80
2/17/20 12:50	240.75	28.24	0.00	13.34	172.64	1166.37
2/17/20 12:51	241.44	28.10	0.00	13.39	173.93	1166.79
2/17/20 12:52	240.80	28.35	0.00	13.46	176.20	1165.72
2/17/20 12:53	241.27	28.48	0.00	13.46	178.60	1166.00
2/17/20 12:54	241.41	28.41	0.00	13.40	176.88	1167.08
2/17/20 12:55	241.25	28.45	0.00	13.71	176.16	1167.03
2/17/20 12:56	241.03	28.37	0.00	13.42	179.87	1166.18
2/17/20 12:57	240.43	28.25	0.00	13.38	173.63	1166.22
2/17/20 12:58	241.03	28.31	0.00	13.14	167.37	1166.02
2/17/20 12:59	240.62	28.38	0.00	13.26	157.78	1165.86
2/17/20 13:00	240.67	28.20	0.00	13.39	159.08	1166.13
2/17/20 13:01	240.78	28.51	0.00	13.15	172.03	1166.29
2/17/20 13:02	240.71	28.27	0.00	13.56	186.00	1166.09
2/17/20 13:03	240.63	28.41	0.00	13.50	194.64	1166.47
2/17/20 13:04	240.79	28.32	0.00	13.23	177.44	1166.46
2/17/20 13:05	240.76	28.47	0.00	13.48	166.84	1165.82
2/17/20 13:06	240.80	28.30	0.00	13.53	164.95	1165.40
2/17/20 13:07	240.59	28.45	0.00	13.25	177.13	1165.82
2/17/20 13:08	240.91	28.29	0.00	13.41	183.60	1166.42
2/17/20 13:09	240.93	28.31	0.00	13.42	176.86	1166.19
2/17/20 13:10	240.45	28.26	0.00	13.17	167.09	1166.07
2/17/20 13:11	241.13	28.39	0.00	13.47	164.46	1166.08
2/17/20 13:12	240.33	28.19	0.00	13.41	159.89	1165.50
2/17/20 13:13	240.76	28.11	0.00	13.26	160.85	1165.54
2/17/20 13:14	240.36	28.33	0.00	13.46	170.93	1166.04
2/17/20 13:15	240.42	28.37	0.00	13.39	175.51	1165.99
2/17/20 13:16	240.56	28.25	0.00	13.17	184.26	1166.96
2/17/20 13:17	240.23	28.38	0.00	13.28	182.09	1165.56
2/17/20 13:18	240.09	28.31	0.00	13.40	173.76	1165.54
2/17/20 13:19	240.67	28.25	0.00	13.34	159.67	1165.35
2/17/20 13:20	240.79	28.30	0.00	13.36	149.85	1165.76
2/17/20 13:21	240.32	28.17	0.00	13.23	152.03	1165.74
2/17/20 13:22	240.52	28.25	0.00	13.48	159.76	1166.34
2/17/20 13:23	240.49	28.25	0.00	13.46	172.36	1166.60
2/17/20 13:24	240.90	28.15	0.00	13.62	182.92	1166.73
2/17/20 13:25	240.73	28.31	0.00	13.37	187.47	1167.14
2/17/20 13:26	240.73	28.19	0.00	13.72	185.96	1167.09
2/17/20 13:27	240.49	28.35	0.00	13.44	174.87	1166.69
2/17/20 13:28	240.57	28.29	0.00	13.23	167.59	1166.04
2/17/20 13:29	240.11	28.15	0.00	13.37	159.11	1165.83
2/17/20 13:30	240.42	28.25	0.00	13.65	161.26	1166.81

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 13:32 - 2/17 14:32)		240.40	28.30	0.00	13.47	169.80	1166.47
COUNT = 61							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/17/20 13:32	240.13	28.38	0.00	13.66	177.42	1166.51
	2/17/20 13:33	240.29	28.23	0.00	13.59	182.03	1166.45
	2/17/20 13:34	240.73	28.25	0.00	13.43	176.72	1167.05
	2/17/20 13:35	240.85	28.35	0.00	13.45	180.02	1166.78
	2/17/20 13:36	240.50	28.42	0.00	13.75	167.80	1166.89
	2/17/20 13:37	240.59	28.25	0.00	13.43	163.91	1166.52
	2/17/20 13:38	240.51	28.37	0.00	13.11	162.58	1166.43
	2/17/20 13:39	240.28	28.46	0.00	13.47	163.85	1166.73
	2/17/20 13:40	240.77	28.36	0.00	13.53	172.70	1166.80
	2/17/20 13:41	240.28	28.16	0.00	13.26	170.20	1166.60
	2/17/20 13:42	240.32	28.25	0.00	13.62	171.57	1166.24
	2/17/20 13:43	240.87	28.30	0.00	13.42	174.44	1166.58
	2/17/20 13:44	240.42	28.43	0.00	13.74	172.60	1166.63
	2/17/20 13:45	240.14	28.34	0.00	13.12	169.26	1165.92
	2/17/20 13:46	240.18	28.37	0.00	13.39	165.89	1166.43
	2/17/20 13:47	240.29	28.33	0.00	13.79	163.65	1166.68
	2/17/20 13:48	239.98	28.18	0.00	13.27	163.23	1165.44
	2/17/20 13:49	240.34	28.21	0.00	13.42	167.55	1165.81
	2/17/20 13:50	240.38	28.33	0.00	13.39	169.94	1165.77
	2/17/20 13:51	240.36	28.20	0.00	13.48	169.17	1166.67
	2/17/20 13:52	240.24	28.26	0.00	12.99	166.11	1165.86
	2/17/20 13:53	240.02	28.30	0.00	13.45	168.25	1165.78
	2/17/20 13:54	240.57	28.21	0.00	13.59	168.96	1166.08
	2/17/20 13:55	239.89	28.37	0.00	13.36	171.72	1165.96
	2/17/20 13:56	240.49	28.16	0.00	13.45	171.24	1166.65
	2/17/20 13:57	240.35	28.20	0.00	13.52	176.20	1165.76
	2/17/20 13:58	240.72	28.28	0.00	13.20	178.94	1166.85
	2/17/20 13:59	240.15	28.10	0.00	13.43	180.49	1166.26
	2/17/20 14:00	240.05	28.21	0.00	13.48	172.39	1166.19
	2/17/20 14:01	240.38	28.34	0.00	13.46	163.05	1166.24
	2/17/20 14:02	240.28	28.16	0.00	13.44	153.92	1166.62
	2/17/20 14:03	240.53	28.51	0.00	13.70	155.73	1166.91
	2/17/20 14:04	240.56	28.30	0.00	13.75	166.93	1167.75
	2/17/20 14:05	240.53	28.41	0.00	13.44	175.29	1166.16
	2/17/20 14:06	240.58	28.36	0.00	13.47	180.64	1167.15
	2/17/20 14:07	240.89	28.37	0.00	13.32	180.48	1166.70
	2/17/20 14:08	240.49	28.31	0.00	13.45	185.65	1166.65
	2/17/20 14:09	240.39	28.17	0.00	13.40	177.23	1166.55
	2/17/20 14:10	240.00	28.39	0.00	13.34	162.39	1166.32
	2/17/20 14:11	240.16	28.26	0.00	13.25	150.38	1166.67
	2/17/20 14:12	240.41	28.29	0.00	13.53	150.65	1165.95
	2/17/20 14:13	240.27	28.23	0.00	13.75	159.72	1165.94
	2/17/20 14:14	239.98	28.20	0.00	13.44	170.99	1166.02
	2/17/20 14:15	240.37	28.28	0.00	13.51	182.39	1166.47
	2/17/20 14:16	240.14	28.25	0.00	13.55	184.32	1165.87
	2/17/20 14:17	240.55	28.14	0.00	13.79	184.28	1167.01
	2/17/20 14:18	240.26	28.22	0.00	13.21	166.36	1166.33
	2/17/20 14:19	240.52	28.50	0.00	13.31	148.80	1166.16
	2/17/20 14:20	240.36	28.37	0.00	13.46	141.83	1166.54
	2/17/20 14:21	240.52	28.06	0.00	13.68	147.32	1167.15
	2/17/20 14:22	240.40	28.27	0.00	13.86	163.21	1166.74
	2/17/20 14:23	240.46	28.28	0.00	13.86	178.54	1166.30
	2/17/20 14:24	240.77	28.42	0.00	13.30	190.13	1166.68
	2/17/20 14:25	240.76	28.18	0.00	13.31	193.53	1166.38
	2/17/20 14:26	240.48	28.49	0.00	13.43	178.37	1166.53
	2/17/20 14:27	240.54	28.21	0.00	13.64	155.73	1165.87
	2/17/20 14:28	239.98	28.40	0.00	13.62	148.97	1167.34
	2/17/20 14:29	240.41	28.42	0.00	13.37	152.87	1166.31
	2/17/20 14:30	240.57	28.28	0.00	13.31	167.52	1167.10
	2/17/20 14:31	240.42	28.44	0.00	13.39	183.94	1167.45
	2/17/20 14:32	240.64	28.39	0.00	13.41	198.05	1166.58

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/17 14:35 - 2/17 15:35)	240.33	28.30	0.00	13.43	164.87	1167.10
COUNT = 61						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/17/20 14:35	239.98	28.13	0.00	13.44	162.96	1165.93
2/17/20 14:36	240.61	28.35	0.00	13.25	152.60	1166.14
2/17/20 14:37	240.14	28.29	0.00	13.47	155.00	1166.98
2/17/20 14:38	240.23	28.26	0.00	13.47	159.57	1166.53
2/17/20 14:39	240.14	28.29	0.00	13.13	163.79	1167.01
2/17/20 14:40	240.25	28.32	0.00	13.60	179.81	1166.42
2/17/20 14:41	240.71	28.42	0.00	13.36	189.43	1167.12
2/17/20 14:42	240.35	28.25	0.00	13.44	188.42	1166.65
2/17/20 14:43	240.09	28.55	0.00	13.20	174.54	1166.63
2/17/20 14:44	240.76	28.27	0.00	13.34	163.56	1166.85
2/17/20 14:45	240.41	28.28	0.00	13.51	158.00	1166.72
2/17/20 14:46	240.76	28.27	0.00	13.15	154.74	1166.69
2/17/20 14:47	239.86	28.11	0.00	13.21	159.73	1165.85
2/17/20 14:48	240.16	28.29	0.00	13.39	170.18	1166.85
2/17/20 14:49	240.25	28.46	0.00	13.43	175.47	1166.29
2/17/20 14:50	240.75	28.13	0.00	13.64	181.05	1168.05
2/17/20 14:51	240.38	28.24	0.00	13.35	172.31	1166.51
2/17/20 14:52	240.51	28.60	0.00	13.39	160.13	1166.96
2/17/20 14:53	240.30	28.24	0.00	13.46	154.25	1166.43
2/17/20 14:54	240.66	28.26	0.00	13.32	150.16	1167.57
2/17/20 14:55	239.91	28.36	0.00	13.42	158.48	1166.25
2/17/20 14:56	240.07	28.27	0.00	13.63	166.97	1167.48
2/17/20 14:57	240.60	28.16	0.00	13.63	173.03	1167.56
2/17/20 14:58	240.64	28.32	0.00	13.78	170.04	1167.90
2/17/20 14:59	240.36	28.32	0.00	13.43	173.62	1167.49
2/17/20 15:00	240.20	28.18	0.00	13.29	167.71	1166.93
2/17/20 15:01	240.29	28.37	0.00	13.67	164.87	1167.14
2/17/20 15:02	240.27	28.28	0.00	13.27	158.49	1166.37
2/17/20 15:03	239.64	28.37	0.00	13.40	161.23	1166.64
2/17/20 15:04	240.40	28.19	0.00	13.30	169.18	1168.09
2/17/20 15:05	239.93	28.32	0.00	13.46	164.44	1166.86
2/17/20 15:06	240.51	28.28	0.00	13.42	166.61	1166.69
2/17/20 15:07	240.48	28.31	0.00	13.32	165.60	1167.22
2/17/20 15:08	240.32	28.35	0.00	13.85	162.77	1167.44
2/17/20 15:09	240.15	28.30	0.00	13.24	163.13	1167.46
2/17/20 15:10	240.50	28.25	0.00	13.44	156.00	1167.46
2/17/20 15:11	240.25	28.35	0.00	13.22	154.94	1166.60
2/17/20 15:12	239.87	28.34	0.00	13.48	156.38	1166.66
2/17/20 15:13	240.18	28.13	0.00	13.48	165.17	1166.88
2/17/20 15:14	240.25	28.29	0.00	13.55	173.05	1167.29
2/17/20 15:15	240.45	28.27	0.00	13.68	181.03	1167.48
2/17/20 15:16	240.16	28.26	0.00	13.36	176.39	1166.77
2/17/20 15:17	240.10	28.21	0.00	13.19	168.79	1167.22
2/17/20 15:18	239.90	28.12	0.00	13.23	154.45	1167.03
2/17/20 15:19	240.09	28.27	0.00	13.55	150.45	1167.43
2/17/20 15:20	240.16	28.22	0.00	13.52	146.10	1167.39
2/17/20 15:21	239.74	28.45	0.00	13.53	149.91	1166.83
2/17/20 15:22	240.09	28.27	0.00	13.51	158.03	1167.62
2/17/20 15:23	240.06	28.33	0.00	13.56	163.68	1168.21
2/17/20 15:24	240.50	28.29	0.00	13.46	167.64	1167.55
2/17/20 15:25	240.76	28.32	0.00	13.48	170.84	1167.74
2/17/20 15:26	240.32	28.47	0.00	13.56	164.96	1167.54
2/17/20 15:27	240.49	28.37	0.00	13.31	158.96	1166.92
2/17/20 15:28	240.96	28.31	0.00	13.21	152.82	1167.40
2/17/20 15:29	240.81	28.30	0.00	13.53	146.28	1167.96
2/17/20 15:30	240.57	28.10	0.00	13.35	147.16	1167.08
2/17/20 15:31	240.27	28.56	0.00	13.41	161.50	1167.53
2/17/20 15:32	240.82	28.40	0.00	13.27	175.76	1167.35
2/17/20 15:33	240.18	28.17	0.00	13.46	186.50	1167.19
2/17/20 15:34	240.95	28.49	0.00	13.77	184.30	1168.32
2/17/20 15:35	240.89	28.31	0.00	13.40	173.98	1167.64

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
NOx, CO, VOC, and NH_3

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 4:25 - 2/19 5:24)	240.87	28.23	9.49	13.56	199.76	1159.30
COUNT = 60						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 4:25	240.66	28.40	9.49	13.54	197.10	1158.57
2/19/20 4:26	240.50	28.16	9.49	13.27	200.55	1159.07
2/19/20 4:27	241.11	28.36	9.49	13.53	201.59	1158.82
2/19/20 4:28	240.29	28.53	9.49	13.55	203.16	1157.94
2/19/20 4:29	241.28	28.03	9.49	13.33	198.93	1158.74
2/19/20 4:30	240.36	28.14	9.49	13.38	201.38	1157.96
2/19/20 4:31	240.64	28.26	9.49	13.94	201.35	1158.66
2/19/20 4:32	240.87	28.22	9.49	13.29	202.89	1158.19
2/19/20 4:33	241.02	27.90	9.49	13.35	198.59	1158.77
2/19/20 4:34	240.31	28.09	9.49	13.38	202.83	1158.64
2/19/20 4:35	240.89	28.17	9.49	13.99	198.78	1159.56
2/19/20 4:36	241.17	28.13	9.49	13.89	198.70	1158.90
2/19/20 4:37	240.74	28.21	9.49	13.68	198.66	1158.79
2/19/20 4:38	240.78	28.04	9.49	13.61	197.53	1158.82
2/19/20 4:39	240.60	28.26	9.49	13.64	200.11	1158.90
2/19/20 4:40	240.82	28.15	9.49	13.67	202.61	1159.26
2/19/20 4:41	240.82	28.29	9.49	13.38	200.17	1158.67
2/19/20 4:42	241.41	28.27	9.49	13.49	200.40	1159.02
2/19/20 4:43	240.93	28.28	9.49	13.45	201.18	1158.67
2/19/20 4:44	240.50	28.24	9.49	13.37	203.20	1158.37
2/19/20 4:45	241.27	28.31	9.49	13.42	202.06	1159.12
2/19/20 4:46	240.88	28.07	9.49	13.69	202.51	1159.86
2/19/20 4:47	240.51	28.38	9.49	13.52	204.26	1159.02
2/19/20 4:48	240.87	28.05	9.49	13.82	201.89	1159.21
2/19/20 4:49	240.90	28.24	9.49	13.73	192.21	1159.20
2/19/20 4:50	240.88	28.20	9.49	13.64	195.61	1158.71
2/19/20 4:51	240.92	28.48	9.49	13.52	195.93	1159.36
2/19/20 4:52	240.43	28.15	9.49	13.70	191.80	1158.96
2/19/20 4:53	241.13	28.11	9.49	13.50	196.95	1159.26
2/19/20 4:54	241.02	28.24	9.49	13.77	196.12	1160.02
2/19/20 4:55	240.73	28.19	9.49	13.52	194.10	1159.37
2/19/20 4:56	240.73	28.23	9.49	13.33	193.63	1158.85
2/19/20 4:57	241.02	28.28	9.49	13.46	194.81	1160.21
2/19/20 4:58	240.84	28.30	9.49	13.97	195.51	1159.54
2/19/20 4:59	241.17	28.19	9.49	13.52	197.80	1160.06
2/19/20 5:00	240.84	28.28	9.49	13.27	200.95	1160.45
2/19/20 5:01	240.81	28.23	9.49	13.27	203.35	1159.38
2/19/20 5:02	241.00	28.40	9.49	13.60	198.75	1159.36
2/19/20 5:03	240.59	28.31	9.49	13.65	201.61	1159.00
2/19/20 5:04	241.06	28.51	9.49	13.49	201.74	1159.78
2/19/20 5:05	241.37	28.33	9.49	13.64	197.50	1160.22
2/19/20 5:06	240.80	28.07	9.49	13.51	192.35	1159.07
2/19/20 5:07	241.24	28.08	9.49	13.64	189.82	1160.38
2/19/20 5:08	240.68	28.13	9.49	13.40	191.88	1159.25
2/19/20 5:09	240.71	28.15	9.49	13.52	196.47	1159.17
2/19/20 5:10	240.88	28.15	9.49	13.86	197.81	1159.87
2/19/20 5:11	240.84	28.43	9.49	13.53	209.86	1159.51
2/19/20 5:12	241.07	28.34	9.49	13.43	202.33	1159.52
2/19/20 5:13	240.98	28.43	9.49	13.62	192.02	1159.80
2/19/20 5:14	240.46	27.97	9.49	13.21	192.02	1158.73
2/19/20 5:15	241.30	28.15	9.49	13.67	190.38	1160.14
2/19/20 5:16	240.96	28.24	9.49	13.63	197.56	1159.50
2/19/20 5:17	240.68	28.28	9.49	13.65	208.36	1160.09
2/19/20 5:18	240.83	28.15	9.49	13.61	217.47	1158.97
2/19/20 5:19	241.07	28.35	9.49	13.50	220.17	1160.26
2/19/20 5:20	240.83	28.10	9.49	13.76	215.82	1159.82
2/19/20 5:21	240.89	28.24	9.49	13.70	203.41	1159.98
2/19/20 5:22	241.22	28.48	9.49	13.65	198.61	1159.86
2/19/20 5:23	240.95	28.21	9.49	13.42	200.32	1160.44
2/19/20 5:24	241.09	28.33	9.49	13.74	200.00	1160.38

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 5:33 - 2/19 6:32)		241.20	28.24	9.50	13.59	204.90	1160.27
COUNT = 60							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 5:33	241.01	28.34	9.50	13.57	198.16	1160.15
	2/19/20 5:34	240.89	28.07	9.50	13.49	200.44	1159.56
	2/19/20 5:35	241.51	28.32	9.50	13.57	206.34	1159.91
	2/19/20 5:36	241.43	28.09	9.50	13.77	200.84	1161.24
	2/19/20 5:37	240.83	28.38	9.50	13.70	198.29	1159.42
	2/19/20 5:38	241.14	28.11	9.50	13.67	200.03	1160.54
	2/19/20 5:39	240.91	28.24	9.50	13.49	191.49	1159.43
	2/19/20 5:40	240.79	28.39	9.50	13.51	194.51	1160.25
	2/19/20 5:41	241.58	28.31	9.50	13.89	197.51	1160.55
	2/19/20 5:42	241.22	28.24	9.50	13.60	202.12	1159.80
	2/19/20 5:43	241.09	28.25	9.50	13.41	209.53	1160.48
	2/19/20 5:44	240.88	28.19	9.50	13.41	208.57	1159.21
	2/19/20 5:45	241.40	28.16	9.50	13.35	203.93	1160.34
	2/19/20 5:46	240.61	28.05	9.50	13.81	200.65	1159.77
	2/19/20 5:47	241.22	28.26	9.50	13.18	196.89	1159.87
	2/19/20 5:48	241.12	28.22	9.50	13.58	208.99	1159.48
	2/19/20 5:49	240.97	28.30	9.50	13.58	218.56	1160.26
	2/19/20 5:50	240.82	28.21	9.50	13.43	220.27	1159.45
	2/19/20 5:51	240.86	28.30	9.50	13.86	210.82	1160.81
	2/19/20 5:52	240.66	28.12	9.50	13.59	204.55	1159.76
	2/19/20 5:53	241.02	28.17	9.50	13.68	184.02	1159.85
	2/19/20 5:54	241.03	28.53	9.50	13.47	181.84	1159.99
	2/19/20 5:55	241.16	28.21	9.50	13.68	190.34	1160.69
	2/19/20 5:56	241.04	28.25	9.50	13.59	205.19	1160.60
	2/19/20 5:57	241.15	28.09	9.50	13.74	214.41	1161.02
	2/19/20 5:58	241.12	28.38	9.50	13.49	214.54	1160.40
	2/19/20 5:59	241.39	28.09	9.50	13.68	204.76	1161.73
	2/19/20 6:00	241.50	28.21	9.50	13.88	201.13	1161.04
	2/19/20 6:01	241.31	28.30	9.50	13.61	200.43	1159.86
	2/19/20 6:02	241.22	28.11	9.50	13.52	193.57	1160.72
	2/19/20 6:03	241.13	28.26	9.50	13.50	204.80	1159.54
	2/19/20 6:04	241.13	28.22	9.50	13.65	213.40	1160.83
	2/19/20 6:05	241.11	28.10	9.50	13.54	213.82	1159.61
	2/19/20 6:06	241.15	28.26	9.50	13.54	208.16	1159.77
	2/19/20 6:07	241.15	28.42	9.50	13.58	203.94	1160.04
	2/19/20 6:08	240.93	28.03	9.50	13.76	195.81	1160.13
	2/19/20 6:09	240.84	28.18	9.50	13.57	191.64	1160.08
	2/19/20 6:10	241.36	28.34	9.50	13.34	202.31	1160.22
	2/19/20 6:11	241.37	28.06	9.50	13.66	207.29	1160.57
	2/19/20 6:12	241.24	27.98	9.50	13.67	216.89	1160.90
	2/19/20 6:13	241.05	28.11	9.50	13.44	216.57	1159.64
	2/19/20 6:14	241.04	28.15	9.50	13.61	205.89	1160.43
	2/19/20 6:15	241.50	28.17	9.50	13.82	192.92	1160.40
	2/19/20 6:16	241.10	28.56	9.50	13.44	192.11	1159.62
	2/19/20 6:17	241.06	28.13	9.50	13.63	199.93	1160.38
	2/19/20 6:18	241.54	28.42	9.50	13.50	211.23	1160.50
	2/19/20 6:19	241.35	28.34	9.50	13.72	222.51	1160.37
	2/19/20 6:20	241.53	28.30	9.50	13.76	225.21	1160.86
	2/19/20 6:21	241.45	28.20	9.50	13.82	218.83	1160.96
	2/19/20 6:22	241.62	28.17	9.50	13.53	211.04	1160.63
	2/19/20 6:23	241.49	28.35	9.50	13.61	199.73	1160.35
	2/19/20 6:24	241.50	28.34	9.50	13.52	193.62	1160.75
	2/19/20 6:25	241.57	28.29	9.50	13.65	203.08	1160.16
	2/19/20 6:26	241.49	28.43	9.50	13.48	214.62	1160.69
	2/19/20 6:27	241.39	28.31	9.50	13.65	224.92	1160.25
	2/19/20 6:28	241.16	28.14	9.50	13.76	227.57	1159.41
	2/19/20 6:29	241.28	28.42	9.50	13.33	223.33	1160.61
	2/19/20 6:30	241.66	28.42	9.50	13.67	208.20	1161.29
	2/19/20 6:31	241.21	28.03	9.50	13.45	194.63	1160.66
	2/19/20 6:32	241.63	28.32	9.50	13.40	187.39	1160.47

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 6:41 - 2/19 7:40)		241.54	28.30	9.50	13.52	206.89	1161.26
COUNT = 60							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 6:41	241.84	28.15	9.50	13.64	203.36	1161.32
	2/19/20 6:42	241.55	28.36	9.50	13.38	205.17	1160.73
	2/19/20 6:43	241.74	28.03	9.50	13.64	204.46	1160.98
	2/19/20 6:44	241.54	28.35	9.50	13.43	205.80	1160.97
	2/19/20 6:45	241.66	28.21	9.50	13.43	208.05	1160.40
	2/19/20 6:46	241.38	28.29	9.50	13.62	211.45	1160.36
	2/19/20 6:47	241.49	28.30	9.50	13.41	213.17	1160.97
	2/19/20 6:48	241.38	28.42	9.50	13.32	211.50	1159.96
	2/19/20 6:49	241.62	28.37	9.50	13.35	202.97	1160.61
	2/19/20 6:50	241.65	28.22	9.50	13.36	204.12	1160.53
	2/19/20 6:51	241.40	28.27	9.50	13.31	200.14	1160.01
	2/19/20 6:52	241.23	28.38	9.50	13.38	206.52	1160.22
	2/19/20 6:53	241.41	28.33	9.50	13.29	206.63	1160.07
	2/19/20 6:54	241.54	28.43	9.50	13.85	208.23	1160.88
	2/19/20 6:55	241.67	28.41	9.50	13.60	204.84	1160.46
	2/19/20 6:56	241.83	28.35	9.50	13.50	201.92	1160.18
	2/19/20 6:57	241.52	28.42	9.50	13.46	206.85	1161.04
	2/19/20 6:58	241.84	28.34	9.50	13.45	206.81	1160.83
	2/19/20 6:59	241.86	28.38	9.50	13.61	209.40	1160.88
	2/19/20 7:00	241.65	28.27	9.50	13.38	210.79	1161.11
	2/19/20 7:01	241.34	28.19	9.50	13.40	204.88	1160.35
	2/19/20 7:02	241.11	28.18	9.50	13.73	208.34	1160.72
	2/19/20 7:03	241.34	28.21	9.50	13.50	203.70	1160.74
	2/19/20 7:04	241.45	28.36	9.50	13.33	201.99	1160.67
	2/19/20 7:05	241.38	28.13	9.50	13.51	201.02	1161.18
	2/19/20 7:06	241.34	28.31	9.50	13.53	207.34	1161.50
	2/19/20 7:07	241.85	28.20	9.50	13.69	200.97	1161.73
	2/19/20 7:08	241.33	28.32	9.50	13.46	201.11	1161.52
	2/19/20 7:09	241.63	28.27	9.50	13.37	199.37	1161.15
	2/19/20 7:10	241.48	28.56	9.50	13.52	198.75	1160.59
	2/19/20 7:11	241.67	28.29	9.50	13.50	203.77	1161.72
	2/19/20 7:12	241.51	28.06	9.50	13.81	212.79	1161.69
	2/19/20 7:13	241.66	28.35	9.50	13.88	216.89	1162.33
	2/19/20 7:14	241.74	28.44	9.50	13.79	220.52	1161.69
	2/19/20 7:15	241.64	28.23	9.50	13.39	214.70	1161.88
	2/19/20 7:16	241.17	28.24	9.50	13.55	208.01	1161.04
	2/19/20 7:17	241.87	28.42	9.50	13.50	202.55	1161.88
	2/19/20 7:18	241.23	28.30	9.50	13.47	208.45	1161.16
	2/19/20 7:19	241.85	28.33	9.50	13.50	209.38	1161.83
	2/19/20 7:20	241.32	28.34	9.50	13.76	208.90	1161.29
	2/19/20 7:21	241.56	28.28	9.50	13.58	206.68	1161.79
	2/19/20 7:22	241.53	28.20	9.50	13.71	207.12	1161.43
	2/19/20 7:23	241.27	28.21	9.50	13.68	209.84	1161.96
	2/19/20 7:24	241.63	28.35	9.50	13.53	208.62	1160.95
	2/19/20 7:25	241.91	28.37	9.50	13.57	209.80	1162.23
	2/19/20 7:26	241.28	28.34	9.50	13.43	207.84	1161.46
	2/19/20 7:27	241.50	28.31	9.50	13.66	208.29	1161.60
	2/19/20 7:28	241.44	28.43	9.50	13.44	212.68	1161.82
	2/19/20 7:29	241.36	28.34	9.50	13.60	213.08	1162.36
	2/19/20 7:30	241.59	28.34	9.50	13.46	212.17	1161.79
	2/19/20 7:31	241.30	28.45	9.50	13.58	208.52	1161.93
	2/19/20 7:32	241.66	28.06	9.50	13.56	205.66	1162.62
	2/19/20 7:33	241.87	28.37	9.50	13.56	195.90	1161.87
	2/19/20 7:34	241.44	28.14	9.50	13.57	196.03	1161.81
	2/19/20 7:35	241.77	28.20	9.50	13.32	204.28	1161.73
	2/19/20 7:36	241.77	28.34	9.50	13.54	209.93	1162.19
	2/19/20 7:37	241.66	28.28	9.50	13.57	212.14	1161.85
	2/19/20 7:38	241.31	28.29	9.50	13.40	212.54	1161.77
	2/19/20 7:39	241.66	28.37	9.50	13.43	208.61	1161.87
	2/19/20 7:40	241.13	28.46	9.50	13.53	197.81	1161.19

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
PM_{10}

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 14:55 - 2/18 19:4)	240.69	28.26	9.56	13.59	192.08	1158.39
COUNT = 250						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 14:55	240.74	28.41	9.63	13.52	181.40	1160.47
2/18/20 14:56	240.83	28.29	9.63	13.87	181.53	1160.50
2/18/20 14:57	240.78	28.51	9.63	13.79	201.33	1159.58
2/18/20 14:58	240.61	28.37	9.63	13.29	207.73	1160.63
2/18/20 14:59	241.35	28.29	9.63	13.58	204.59	1161.06
2/18/20 15:00	241.30	28.27	9.63	13.55	189.41	1160.29
2/18/20 15:01	241.23	28.33	9.63	13.93	177.01	1161.43
2/18/20 15:02	240.91	28.25	9.63	13.77	178.37	1160.44
2/18/20 15:03	241.21	28.48	9.63	13.62	183.60	1161.54
2/18/20 15:04	241.03	28.31	9.63	13.62	199.15	1160.71
2/18/20 15:05	240.81	28.09	9.63	13.46	207.52	1160.64
2/18/20 15:06	241.28	28.43	9.63	13.81	201.39	1161.34
2/18/20 15:07	241.09	28.35	9.63	13.61	190.01	1160.68
2/18/20 15:08	240.64	28.41	9.63	13.35	182.64	1160.30
2/18/20 15:09	241.41	28.27	9.63	13.81	182.92	1160.76
2/18/20 15:10	241.43	28.31	9.62	13.62	196.27	1160.90
2/18/20 15:11	241.05	28.22	9.62	13.76	211.40	1160.52
2/18/20 15:12	241.30	28.41	9.62	13.31	211.27	1160.58
2/18/20 15:13	241.13	28.30	9.62	13.55	200.07	1160.90
2/18/20 15:14	240.93	28.34	9.62	13.71	186.93	1160.35
2/18/20 15:15	240.99	28.55	9.62	13.72	187.63	1160.61
2/18/20 15:16	240.78	28.20	9.62	13.59	183.63	1160.04
2/18/20 15:17	241.08	28.19	9.62	13.55	198.09	1159.68
2/18/20 15:18	240.91	28.19	9.62	13.78	195.21	1160.01
2/18/20 15:19	241.27	28.36	9.62	13.65	194.06	1160.41
2/18/20 15:20	240.77	28.38	9.62	13.59	191.84	1160.21
2/18/20 15:21	240.51	28.34	9.62	13.54	188.91	1160.14
2/18/20 15:22	240.82	28.28	9.62	14.02	186.78	1160.27
2/18/20 15:23	241.16	28.22	9.62	13.53	189.81	1160.03
2/18/20 15:24	240.73	28.33	9.62	13.64	190.23	1159.95
2/18/20 15:25	240.77	28.18	9.62	13.56	191.24	1159.24
2/18/20 15:26	241.35	28.42	9.62	13.45	192.26	1161.38
2/18/20 15:27	240.78	28.28	9.61	13.44	196.76	1160.36
2/18/20 15:28	240.62	28.22	9.61	13.38	202.53	1159.05
2/18/20 15:29	240.89	28.31	9.61	13.76	204.47	1159.52
2/18/20 15:30	241.04	28.35	9.61	13.83	204.28	1160.92
2/18/20 15:31	241.06	28.33	9.61	13.79	192.71	1161.47
2/18/20 15:32	240.75	28.54	9.61	13.67	180.49	1160.27
2/18/20 15:33	240.92	28.22	9.61	13.61	178.31	1160.08
2/18/20 15:34	240.90	28.33	9.61	13.51	187.66	1160.00
2/18/20 15:35	241.18	28.30	9.61	13.52	200.31	1160.43
2/18/20 15:36	240.62	28.26	9.61	13.54	205.97	1159.51
2/18/20 15:37	240.69	28.24	9.61	13.34	198.74	1159.36
2/18/20 15:38	241.21	28.36	9.61	13.43	185.75	1160.07
2/18/20 15:39	240.61	28.08	9.61	13.74	180.33	1159.65
2/18/20 15:40	240.43	28.24	9.61	13.53	182.20	1158.99
2/18/20 15:41	241.16	28.17	9.61	13.65	186.18	1160.17
2/18/20 15:42	240.68	28.25	9.61	13.49	193.53	1159.18
2/18/20 15:43	240.91	28.29	9.61	13.51	203.85	1160.01
2/18/20 15:44	240.49	28.21	9.60	13.45	205.07	1158.50
2/18/20 15:45	241.31	28.23	9.60	13.90	200.68	1160.18
2/18/20 15:46	240.66	28.14	9.60	13.56	193.71	1159.12
2/18/20 15:47	241.08	28.66	9.60	13.46	182.32	1160.33
2/18/20 15:48	241.05	28.27	9.60	13.63	183.97	1159.94
2/18/20 15:49	240.87	28.49	9.60	13.61	183.20	1159.42
2/18/20 15:50	240.58	28.27	9.60	13.42	187.49	1158.83
2/18/20 15:51	240.98	28.32	9.60	13.58	190.00	1159.35
2/18/20 15:52	240.75	28.07	9.60	13.54	186.74	1159.61
2/18/20 15:53	240.30	28.37	9.60	13.60	188.50	1159.54
2/18/20 15:54	240.91	28.31	9.60	13.60	185.42	1159.77
2/18/20 15:55	241.08	28.39	9.60	13.73	188.98	1159.88
2/18/20 15:56	240.97	28.35	9.60	13.42	189.42	1159.26
2/18/20 15:57	241.01	28.26	9.60	13.51	189.06	1159.67
2/18/20 15:58	241.06	28.25	9.60	13.82	187.29	1159.73
2/18/20 15:59	240.82	28.28	9.60	13.47	187.80	1159.06
2/18/20 16:00	240.53	28.52	9.60	13.79	195.29	1159.24
2/18/20 16:01	240.82	28.19	9.59	13.70	201.40	1158.99

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 14:55 - 2/18 19:4)	240.69	28.26	9.56	13.59	192.08	1158.39
COUNT = 250						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 16:02	240.89	28.43	9.59	13.79	205.92	1159.15
2/18/20 16:03	240.75	28.37	9.59	13.41	203.41	1159.21
2/18/20 16:04	240.54	28.30	9.59	13.59	195.69	1159.27
2/18/20 16:05	240.45	28.19	9.59	13.36	187.96	1159.17
2/18/20 16:06	240.67	28.17	9.59	13.63	189.53	1160.16
2/18/20 16:07	240.67	28.40	9.59	13.49	191.59	1159.46
2/18/20 16:08	240.75	28.24	9.59	13.43	193.88	1158.80
2/18/20 16:09	240.59	28.27	9.59	13.61	196.99	1159.83
2/18/20 16:10	241.13	28.17	9.59	13.45	200.53	1160.19
2/18/20 16:11	241.34	28.24	9.59	13.76	198.64	1159.73
2/18/20 16:12	241.01	28.25	9.59	13.43	197.62	1158.45
2/18/20 16:13	240.10	28.27	9.59	13.65	189.23	1158.42
2/18/20 16:14	240.96	28.42	9.59	13.64	184.30	1159.44
2/18/20 16:15	240.39	28.46	9.59	13.76	184.04	1158.71
2/18/20 16:16	240.85	28.25	9.59	13.66	187.62	1158.76
2/18/20 16:17	240.87	28.30	9.59	13.50	190.27	1158.35
2/18/20 16:18	240.55	28.41	9.58	13.44	192.77	1158.35
2/18/20 16:19	240.89	28.34	9.58	13.81	193.29	1159.31
2/18/20 16:20	240.74	28.27	9.58	13.82	191.38	1159.52
2/18/20 16:21	240.40	28.38	9.58	13.71	190.51	1159.39
2/18/20 16:22	240.56	28.08	9.58	13.78	196.37	1159.51
2/18/20 16:23	240.92	28.36	9.58	13.50	198.89	1158.44
2/18/20 16:24	240.27	28.40	9.58	13.65	199.62	1158.25
2/18/20 16:25	241.14	28.34	9.58	13.67	193.80	1159.04
2/18/20 16:26	240.69	28.09	9.58	13.37	195.69	1158.07
2/18/20 16:27	240.29	28.38	9.58	13.43	191.35	1157.92
2/18/20 16:28	240.37	28.34	9.58	13.68	192.11	1158.57
2/18/20 16:29	240.59	28.42	9.58	13.54	189.90	1158.18
2/18/20 16:30	240.62	28.37	9.58	13.51	186.52	1158.57
2/18/20 16:31	240.47	28.40	9.58	13.46	189.41	1158.69
2/18/20 16:32	240.35	28.23	9.58	13.67	190.87	1157.90
2/18/20 16:33	241.01	28.12	9.58	13.64	196.76	1158.27
2/18/20 16:34	240.83	28.38	9.58	13.64	191.19	1158.82
2/18/20 16:35	240.90	28.24	9.57	13.59	192.85	1159.05
2/18/20 16:36	240.78	28.39	9.57	13.55	191.43	1158.51
2/18/20 16:37	240.55	28.25	9.57	13.87	195.05	1158.60
2/18/20 16:38	240.69	28.49	9.57	13.52	199.27	1158.41
2/18/20 16:39	240.49	28.09	9.57	13.52	202.39	1157.51
2/18/20 16:40	240.70	28.18	9.57	13.52	195.89	1158.07
2/18/20 16:41	240.91	28.14	9.57	13.43	188.08	1159.46
2/18/20 16:42	240.52	28.14	9.57	13.63	185.50	1158.18
2/18/20 16:43	241.12	28.12	9.57	13.48	182.04	1157.94
2/18/20 16:44	240.56	28.41	9.57	13.58	188.80	1158.16
2/18/20 16:45	240.45	28.14	9.57	13.68	195.98	1157.87
2/18/20 16:46	240.53	28.27	9.57	13.84	197.85	1158.32
2/18/20 16:47	240.60	28.14	9.57	13.53	194.81	1158.48
2/18/20 16:48	240.41	28.23	9.57	13.62	184.19	1158.36
2/18/20 16:49	240.67	28.26	9.57	13.47	183.03	1158.16
2/18/20 16:50	240.54	28.30	9.57	13.55	185.10	1158.20
2/18/20 16:51	240.95	28.08	9.57	13.45	203.50	1158.27
2/18/20 16:52	240.66	28.12	9.56	13.58	208.31	1158.43
2/18/20 16:53	240.17	28.30	9.56	13.40	193.33	1157.78
2/18/20 16:54	240.35	28.24	9.56	13.68	187.11	1157.23
2/18/20 16:55	240.63	28.51	9.56	13.55	179.03	1158.49
2/18/20 16:56	240.38	28.49	9.56	13.48	178.42	1158.13
2/18/20 16:57	240.15	28.13	9.56	13.58	193.44	1158.27
2/18/20 16:58	240.66	28.31	9.56	13.57	209.28	1157.82
2/18/20 16:59	240.85	28.26	9.56	13.60	209.95	1158.04
2/18/20 17:00	240.62	28.28	9.56	13.73	199.09	1158.02
2/18/20 17:01	240.70	28.24	9.56	13.47	192.53	1158.14
2/18/20 17:02	240.32	28.31	9.56	13.98	186.97	1158.16
2/18/20 17:03	241.13	28.20	9.56	13.57	187.72	1158.40
2/18/20 17:04	240.60	28.40	9.56	13.78	197.96	1158.58
2/18/20 17:05	240.99	28.11	9.56	13.81	206.39	1158.68
2/18/20 17:06	240.71	28.29	9.56	13.38	206.41	1157.69
2/18/20 17:07	240.33	28.27	9.56	13.75	201.01	1158.32
2/18/20 17:08	240.82	28.26	9.56	13.72	196.37	1157.86

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 14:55 - 2/18 19:4)	240.69	28.26	9.56	13.59	192.08	1158.39
COUNT = 250						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 17:09	240.61	28.17	9.55	13.60	190.75	1158.32
2/18/20 17:10	240.12	28.47	9.55	13.55	189.71	1157.14
2/18/20 17:11	240.49	28.22	9.55	13.56	191.40	1157.86
2/18/20 17:12	240.67	28.36	9.55	13.63	200.07	1158.06
2/18/20 17:13	240.30	28.34	9.55	13.54	198.17	1156.68
2/18/20 17:14	240.63	28.40	9.55	13.48	196.49	1158.05
2/18/20 17:15	240.45	28.23	9.55	13.34	192.94	1157.21
2/18/20 17:16	240.00	28.39	9.55	13.36	194.51	1156.87
2/18/20 17:17	240.44	28.09	9.55	13.38	189.08	1157.59
2/18/20 17:18	240.74	28.44	9.55	13.52	188.18	1157.80
2/18/20 17:19	240.48	28.28	9.55	13.32	188.20	1157.81
2/18/20 17:20	240.69	28.41	9.55	13.61	186.88	1158.09
2/18/20 17:21	240.92	28.15	9.55	13.61	183.77	1158.60
2/18/20 17:22	240.52	28.30	9.55	13.78	182.97	1158.27
2/18/20 17:23	240.67	28.15	9.55	13.41	183.45	1157.57
2/18/20 17:24	240.48	28.23	9.55	13.55	184.08	1157.90
2/18/20 17:25	240.72	28.30	9.55	13.67	185.12	1158.64
2/18/20 17:26	240.57	28.20	9.54	13.34	182.70	1157.67
2/18/20 17:27	240.42	28.25	9.54	13.60	182.85	1157.48
2/18/20 17:28	240.62	28.31	9.54	13.49	184.86	1157.47
2/18/20 17:29	240.68	28.11	9.54	13.63	188.17	1158.32
2/18/20 17:30	240.67	28.17	9.54	13.66	183.81	1158.06
2/18/20 17:31	240.49	28.13	9.54	13.66	181.48	1156.58
2/18/20 17:32	240.59	28.40	9.54	13.64	186.68	1157.72
2/18/20 17:33	240.81	28.31	9.54	13.42	181.34	1157.31
2/18/20 17:34	240.58	28.24	9.54	13.75	187.77	1158.11
2/18/20 17:35	240.46	28.21	9.54	13.43	187.41	1157.65
2/18/20 17:36	240.34	28.34	9.54	13.45	186.40	1156.42
2/18/20 17:37	240.81	28.20	9.54	13.44	185.26	1157.31
2/18/20 17:38	240.69	28.23	9.54	13.48	181.49	1157.15
2/18/20 17:39	240.66	28.01	9.54	13.57	187.01	1157.23
2/18/20 17:40	240.71	28.26	9.54	13.46	187.77	1157.50
2/18/20 17:41	240.78	28.39	9.54	13.73	182.92	1158.23
2/18/20 17:42	239.93	28.04	9.54	13.49	187.15	1156.77
2/18/20 17:43	240.53	28.35	9.53	13.72	186.72	1158.94
2/18/20 17:44	240.83	28.18	9.53	13.42	183.03	1158.72
2/18/20 17:45	240.47	28.57	9.53	13.37	186.72	1157.16
2/18/20 17:46	240.72	28.57	9.53	13.67	182.03	1158.11
2/18/20 17:47	241.07	28.32	9.53	13.37	186.38	1157.57
2/18/20 17:48	240.71	28.14	9.53	13.60	188.30	1157.34
2/18/20 17:49	240.61	28.19	9.53	13.53	183.64	1157.10
2/18/20 17:50	240.28	28.24	9.53	13.38	187.10	1157.03
2/18/20 17:51	240.32	28.14	9.53	13.52	181.93	1156.92
2/18/20 17:52	240.76	28.29	9.53	13.40	185.70	1157.45
2/18/20 17:53	240.68	28.29	9.53	13.37	184.23	1157.75
2/18/20 17:54	241.05	28.43	9.53	13.91	185.78	1158.65
2/18/20 17:55	240.84	28.24	9.53	13.53	187.42	1158.04
2/18/20 17:56	240.51	28.14	9.53	13.58	186.21	1157.51
2/18/20 17:57	240.66	28.17	9.53	13.97	187.29	1158.35
2/18/20 17:58	240.59	28.05	9.53	13.56	181.49	1157.63
2/18/20 17:59	241.19	28.17	9.53	13.67	180.83	1158.88
2/18/20 18:00	241.02	28.26	9.52	13.62	185.34	1157.84
2/18/20 18:01	240.73	28.21	9.52	13.48	188.21	1158.10
2/18/20 18:02	240.92	28.45	9.52	13.44	188.08	1158.12
2/18/20 18:03	240.74	28.31	9.52	13.70	182.23	1157.88
2/18/20 18:04	240.52	28.34	9.52	13.47	187.31	1157.64
2/18/20 18:05	240.53	28.35	9.52	13.41	187.27	1157.17
2/18/20 18:06	240.29	27.95	9.52	13.80	182.18	1157.50
2/18/20 18:07	240.90	28.25	9.52	13.80	185.60	1158.01
2/18/20 18:08	240.55	27.96	9.52	13.50	187.25	1157.09
2/18/20 18:09	240.80	28.31	9.52	13.42	189.75	1156.82
2/18/20 18:10	240.53	28.39	9.52	13.47	197.75	1156.88
2/18/20 18:11	240.51	28.06	9.52	13.58	208.57	1157.11
2/18/20 18:12	240.46	28.17	9.52	13.45	206.40	1157.14
2/18/20 18:13	240.50	28.17	9.52	13.55	197.07	1156.54
2/18/20 18:14	240.36	28.14	9.52	13.59	186.89	1156.71
2/18/20 18:15	240.48	28.02	9.52	13.34	182.45	1156.95

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 14:55 - 2/18 19:4)	240.69	28.26	9.56	13.59	192.08	1158.39
COUNT = 250						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 18:16	240.30	28.01	9.51	13.95	186.79	1157.65
2/18/20 18:17	241.02	28.17	9.51	13.65	198.85	1156.92
2/18/20 18:18	240.41	28.22	9.51	13.80	204.26	1156.85
2/18/20 18:19	240.51	27.99	9.51	13.79	200.77	1156.77
2/18/20 18:20	241.00	28.07	9.51	13.69	195.52	1157.36
2/18/20 18:21	240.85	28.25	9.51	13.40	188.79	1157.57
2/18/20 18:22	240.31	27.97	9.51	13.44	190.47	1156.09
2/18/20 18:23	241.01	28.05	9.51	13.95	194.42	1156.77
2/18/20 18:24	240.40	28.01	9.51	13.60	199.91	1156.85
2/18/20 18:25	240.34	28.12	9.51	13.65	207.05	1156.45
2/18/20 18:26	240.60	28.33	9.51	13.78	211.06	1157.47
2/18/20 18:27	240.30	28.27	9.51	13.56	203.10	1156.79
2/18/20 18:28	241.05	28.12	9.51	13.49	191.98	1157.36
2/18/20 18:29	240.64	28.30	9.51	13.54	190.46	1156.88
2/18/20 18:30	240.37	28.34	9.51	13.59	190.56	1156.55
2/18/20 18:31	240.38	28.25	9.51	13.46	196.86	1156.53
2/18/20 18:32	240.77	28.17	9.51	13.64	203.94	1156.50
2/18/20 18:33	240.41	28.21	9.51	13.77	207.41	1156.76
2/18/20 18:34	240.92	28.07	9.51	13.57	203.77	1157.04
2/18/20 18:35	239.91	28.31	9.51	13.45	198.33	1155.81
2/18/20 18:36	241.01	28.22	9.51	13.40	193.78	1157.48
2/18/20 18:37	240.55	28.27	9.51	13.62	190.28	1156.84
2/18/20 18:38	240.07	28.09	9.51	13.51	195.73	1156.60
2/18/20 18:39	240.29	28.29	9.51	13.68	201.96	1157.24
2/18/20 18:40	240.98	28.20	9.51	13.45	204.54	1156.93
2/18/20 18:41	240.69	28.33	9.51	13.70	199.17	1156.77
2/18/20 18:42	240.52	28.35	9.51	13.91	199.12	1156.80
2/18/20 18:43	240.18	28.00	9.51	13.63	190.08	1156.66
2/18/20 18:44	240.50	28.09	9.51	13.65	189.12	1157.64
2/18/20 18:45	240.86	28.13	9.51	13.77	186.73	1157.07
2/18/20 18:46	240.48	28.36	9.51	13.74	185.94	1156.75
2/18/20 18:47	240.46	28.36	9.51	13.74	196.18	1157.53
2/18/20 18:48	240.57	28.28	9.51	13.62	195.83	1158.07
2/18/20 18:49	240.23	28.05	9.51	13.63	196.07	1156.98
2/18/20 18:50	240.41	28.20	9.51	13.52	196.63	1157.11
2/18/20 18:51	240.55	28.24	9.51	13.53	194.81	1157.32
2/18/20 18:52	240.68	28.25	9.51	13.48	190.79	1156.78
2/18/20 18:53	240.72	27.98	9.51	13.64	189.89	1157.31
2/18/20 18:54	240.82	28.17	9.51	13.60	189.98	1157.29
2/18/20 18:55	240.27	28.08	9.51	13.79	192.54	1157.16
2/18/20 18:56	240.72	28.23	9.51	13.55	188.68	1156.75
2/18/20 18:57	240.66	28.10	9.51	13.78	194.43	1156.81
2/18/20 18:58	240.39	28.22	9.51	13.50	200.87	1156.81
2/18/20 18:59	240.12	28.17	9.51	13.40	200.02	1156.10
2/18/20 19:00	240.04	28.08	9.51	13.44	198.49	1155.79
2/18/20 19:01	240.95	28.24	9.51	13.63	199.88	1157.38
2/18/20 19:02	240.35	28.17	9.51	13.54	193.28	1156.46
2/18/20 19:03	240.24	28.30	9.51	13.71	195.39	1157.43
2/18/20 19:04	240.98	28.07	9.51	13.63	197.15	1157.14

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 4:24 - 2/19 8:15)		241.27	28.26	9.50	13.56	204.38	1160.59
COUNT = 232							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 4:24	240.84	28.23	9.49	13.38	202.74	1158.93
	2/19/20 4:25	240.66	28.40	9.49	13.54	197.10	1158.57
	2/19/20 4:26	240.50	28.16	9.49	13.27	200.55	1159.07
	2/19/20 4:27	241.11	28.36	9.49	13.53	201.59	1158.82
	2/19/20 4:28	240.29	28.53	9.49	13.55	203.16	1157.94
	2/19/20 4:29	241.28	28.03	9.49	13.33	198.93	1158.74
	2/19/20 4:30	240.36	28.14	9.49	13.38	201.38	1157.96
	2/19/20 4:31	240.64	28.26	9.49	13.94	201.35	1158.66
	2/19/20 4:32	240.87	28.22	9.49	13.29	202.89	1158.19
	2/19/20 4:33	241.02	27.90	9.49	13.35	198.59	1158.77
	2/19/20 4:34	240.31	28.09	9.49	13.38	202.83	1158.64
	2/19/20 4:35	240.89	28.17	9.49	13.99	198.78	1159.56
	2/19/20 4:36	241.17	28.13	9.49	13.89	198.70	1158.90
	2/19/20 4:37	240.74	28.21	9.49	13.68	198.66	1158.79
	2/19/20 4:38	240.78	28.04	9.49	13.61	197.53	1158.82
	2/19/20 4:39	240.60	28.26	9.49	13.64	200.11	1158.90
	2/19/20 4:40	240.82	28.15	9.49	13.67	202.61	1159.26
	2/19/20 4:41	240.82	28.29	9.49	13.38	200.17	1158.67
	2/19/20 4:42	241.41	28.27	9.49	13.49	200.40	1159.02
	2/19/20 4:43	240.93	28.28	9.49	13.45	201.18	1158.67
	2/19/20 4:44	240.50	28.24	9.49	13.37	203.20	1158.37
	2/19/20 4:45	241.27	28.31	9.49	13.42	202.06	1159.12
	2/19/20 4:46	240.88	28.07	9.49	13.69	202.51	1159.86
	2/19/20 4:47	240.51	28.38	9.49	13.52	204.26	1159.02
	2/19/20 4:48	240.87	28.05	9.49	13.82	201.89	1159.21
	2/19/20 4:49	240.90	28.24	9.49	13.73	192.21	1159.20
	2/19/20 4:50	240.88	28.20	9.49	13.64	195.61	1158.71
	2/19/20 4:51	240.92	28.48	9.49	13.52	195.93	1159.36
	2/19/20 4:52	240.43	28.15	9.49	13.70	191.80	1158.96
	2/19/20 4:53	241.13	28.11	9.49	13.50	196.95	1159.26
	2/19/20 4:54	241.02	28.24	9.49	13.77	196.12	1160.02
	2/19/20 4:55	240.73	28.19	9.49	13.52	194.10	1159.37
	2/19/20 4:56	240.73	28.23	9.49	13.33	193.63	1158.85
	2/19/20 4:57	241.02	28.28	9.49	13.46	194.81	1160.21
	2/19/20 4:58	240.84	28.30	9.49	13.97	195.51	1159.54
	2/19/20 4:59	241.17	28.19	9.49	13.52	197.80	1160.06
	2/19/20 5:00	240.84	28.28	9.49	13.27	200.95	1160.45
	2/19/20 5:01	240.81	28.23	9.49	13.27	203.35	1159.38
	2/19/20 5:02	241.00	28.40	9.49	13.60	198.75	1159.36
	2/19/20 5:03	240.59	28.31	9.49	13.65	201.61	1159.00
	2/19/20 5:04	241.06	28.51	9.49	13.49	201.74	1159.78
	2/19/20 5:05	241.37	28.33	9.49	13.64	197.50	1160.22
	2/19/20 5:06	240.80	28.07	9.49	13.51	192.35	1159.07
	2/19/20 5:07	241.24	28.08	9.49	13.64	189.82	1160.38
	2/19/20 5:08	240.68	28.13	9.49	13.40	191.88	1159.25
	2/19/20 5:09	240.71	28.15	9.49	13.52	196.47	1159.17
	2/19/20 5:10	240.88	28.15	9.49	13.86	197.81	1159.87
	2/19/20 5:11	240.84	28.43	9.49	13.53	209.86	1159.51
	2/19/20 5:12	241.07	28.34	9.49	13.43	202.33	1159.52
	2/19/20 5:13	240.98	28.43	9.49	13.62	192.02	1159.80
	2/19/20 5:14	240.46	27.97	9.49	13.21	192.02	1158.73
	2/19/20 5:15	241.30	28.15	9.49	13.67	190.38	1160.14
	2/19/20 5:16	240.96	28.24	9.49	13.63	197.56	1159.50
	2/19/20 5:17	240.68	28.28	9.49	13.65	208.36	1160.09
	2/19/20 5:18	240.83	28.15	9.49	13.61	217.47	1158.97
	2/19/20 5:19	241.07	28.35	9.49	13.50	220.17	1160.26
	2/19/20 5:20	240.83	28.10	9.49	13.76	215.82	1159.82
	2/19/20 5:21	240.89	28.24	9.49	13.70	203.41	1159.98
	2/19/20 5:22	241.22	28.48	9.49	13.65	198.61	1159.86
	2/19/20 5:23	240.95	28.21	9.49	13.42	200.32	1160.44
	2/19/20 5:24	241.09	28.33	9.49	13.74	200.00	1160.38
	2/19/20 5:25	240.53	28.25	9.49	13.34	208.98	1159.48
	2/19/20 5:26	241.34	28.20	9.49	13.50	210.52	1159.92
	2/19/20 5:27	241.07	28.23	9.49	13.61	213.65	1160.04
	2/19/20 5:28	240.79	28.10	9.49	13.47	211.06	1159.03
	2/19/20 5:29	241.45	28.15	9.49	13.64	201.91	1160.17
	2/19/20 5:30	241.21	28.30	9.49	13.71	197.97	1159.92

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 4:24 - 2/19 8:15)	241.27	28.26	9.50	13.56	204.38	1160.59
COUNT = 232						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 5:31	241.18	28.15	9.49	13.63	190.09	1159.43
2/19/20 5:32	241.22	28.36	9.49	13.58	196.91	1159.98
2/19/20 5:33	241.01	28.34	9.50	13.57	198.16	1160.15
2/19/20 5:34	240.89	28.07	9.50	13.49	200.44	1159.56
2/19/20 5:35	241.51	28.32	9.50	13.57	206.34	1159.91
2/19/20 5:36	241.43	28.09	9.50	13.77	200.84	1161.24
2/19/20 5:37	240.83	28.38	9.50	13.70	198.29	1159.42
2/19/20 5:38	241.14	28.11	9.50	13.67	200.03	1160.54
2/19/20 5:39	240.91	28.24	9.50	13.49	191.49	1159.43
2/19/20 5:40	240.79	28.39	9.50	13.51	194.51	1160.25
2/19/20 5:41	241.58	28.31	9.50	13.89	197.51	1160.55
2/19/20 5:42	241.22	28.24	9.50	13.60	202.12	1159.80
2/19/20 5:43	241.09	28.25	9.50	13.41	209.53	1160.48
2/19/20 5:44	240.88	28.19	9.50	13.41	208.57	1159.21
2/19/20 5:45	241.40	28.16	9.50	13.35	203.93	1160.34
2/19/20 5:46	240.61	28.05	9.50	13.81	200.65	1159.77
2/19/20 5:47	241.22	28.26	9.50	13.18	196.89	1159.87
2/19/20 5:48	241.12	28.22	9.50	13.58	208.99	1159.48
2/19/20 5:49	240.97	28.30	9.50	13.58	218.56	1160.26
2/19/20 5:50	240.82	28.21	9.50	13.43	220.27	1159.45
2/19/20 5:51	240.86	28.30	9.50	13.86	210.82	1160.81
2/19/20 5:52	240.66	28.12	9.50	13.59	204.55	1159.76
2/19/20 5:53	241.02	28.17	9.50	13.68	184.02	1159.85
2/19/20 5:54	241.03	28.53	9.50	13.47	181.84	1159.99
2/19/20 5:55	241.16	28.21	9.50	13.68	190.34	1160.69
2/19/20 5:56	241.04	28.25	9.50	13.59	205.19	1160.60
2/19/20 5:57	241.15	28.09	9.50	13.74	214.41	1161.02
2/19/20 5:58	241.12	28.38	9.50	13.49	214.54	1160.40
2/19/20 5:59	241.39	28.09	9.50	13.68	204.76	1161.73
2/19/20 6:00	241.50	28.21	9.50	13.88	201.13	1161.04
2/19/20 6:01	241.31	28.30	9.50	13.61	200.43	1159.86
2/19/20 6:02	241.22	28.11	9.50	13.52	193.57	1160.72
2/19/20 6:03	241.13	28.26	9.50	13.50	204.80	1159.54
2/19/20 6:04	241.13	28.22	9.50	13.65	213.40	1160.83
2/19/20 6:05	241.11	28.10	9.50	13.54	213.82	1159.61
2/19/20 6:06	241.15	28.26	9.50	13.54	208.16	1159.77
2/19/20 6:07	241.15	28.42	9.50	13.58	203.94	1160.04
2/19/20 6:08	240.93	28.03	9.50	13.76	195.81	1160.13
2/19/20 6:09	240.84	28.18	9.50	13.57	191.64	1160.08
2/19/20 6:10	241.36	28.34	9.50	13.34	202.31	1160.22
2/19/20 6:11	241.37	28.06	9.50	13.66	207.29	1160.57
2/19/20 6:12	241.24	27.98	9.50	13.67	216.89	1160.90
2/19/20 6:13	241.05	28.11	9.50	13.44	216.57	1159.64
2/19/20 6:14	241.04	28.15	9.50	13.61	205.89	1160.43
2/19/20 6:15	241.50	28.17	9.50	13.82	192.92	1160.40
2/19/20 6:16	241.10	28.56	9.50	13.44	192.11	1159.62
2/19/20 6:17	241.06	28.13	9.50	13.63	199.93	1160.38
2/19/20 6:18	241.54	28.42	9.50	13.50	211.23	1160.50
2/19/20 6:19	241.35	28.34	9.50	13.72	222.51	1160.37
2/19/20 6:20	241.53	28.30	9.50	13.76	225.21	1160.86
2/19/20 6:21	241.45	28.20	9.50	13.82	218.83	1160.96
2/19/20 6:22	241.62	28.17	9.50	13.53	211.04	1160.63
2/19/20 6:23	241.49	28.35	9.50	13.61	199.73	1160.35
2/19/20 6:24	241.50	28.34	9.50	13.52	193.62	1160.75
2/19/20 6:25	241.57	28.29	9.50	13.65	203.08	1160.16
2/19/20 6:26	241.49	28.43	9.50	13.48	214.62	1160.69
2/19/20 6:27	241.39	28.31	9.50	13.65	224.92	1160.25
2/19/20 6:28	241.16	28.14	9.50	13.76	227.57	1159.41
2/19/20 6:29	241.28	28.42	9.50	13.33	223.33	1160.61
2/19/20 6:30	241.66	28.42	9.50	13.67	208.20	1161.29
2/19/20 6:31	241.21	28.03	9.50	13.45	194.63	1160.66
2/19/20 6:32	241.63	28.32	9.50	13.40	187.39	1160.47
2/19/20 6:33	241.64	28.27	9.50	13.72	191.69	1160.65
2/19/20 6:34	241.18	28.30	9.50	13.58	204.22	1159.61
2/19/20 6:35	242.05	28.12	9.50	13.63	215.74	1161.01
2/19/20 6:36	242.13	28.36	9.50	13.61	225.14	1160.66
2/19/20 6:37	241.84	28.07	9.50	13.31	220.27	1160.25

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 4:24 - 2/19 8:15)		241.27	28.26	9.50	13.56	204.38	1160.59
COUNT = 232							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 6:38	241.86	28.22	9.50	13.75	211.06	1161.38
	2/19/20 6:39	241.75	28.24	9.50	13.57	205.59	1161.01
	2/19/20 6:40	241.10	28.31	9.50	13.53	203.72	1160.43
	2/19/20 6:41	241.84	28.15	9.50	13.64	203.36	1161.32
	2/19/20 6:42	241.55	28.36	9.50	13.38	205.17	1160.73
	2/19/20 6:43	241.74	28.03	9.50	13.64	204.46	1160.98
	2/19/20 6:44	241.54	28.35	9.50	13.43	205.80	1160.97
	2/19/20 6:45	241.66	28.21	9.50	13.43	208.05	1160.40
	2/19/20 6:46	241.38	28.29	9.50	13.62	211.45	1160.36
	2/19/20 6:47	241.49	28.30	9.50	13.41	213.17	1160.97
	2/19/20 6:48	241.38	28.42	9.50	13.32	211.50	1159.96
	2/19/20 6:49	241.62	28.37	9.50	13.35	202.97	1160.61
	2/19/20 6:50	241.65	28.22	9.50	13.36	204.12	1160.53
	2/19/20 6:51	241.40	28.27	9.50	13.31	200.14	1160.01
	2/19/20 6:52	241.23	28.38	9.50	13.38	206.52	1160.22
	2/19/20 6:53	241.41	28.33	9.50	13.29	206.63	1160.07
	2/19/20 6:54	241.54	28.43	9.50	13.85	208.23	1160.88
	2/19/20 6:55	241.67	28.41	9.50	13.60	204.84	1160.46
	2/19/20 6:56	241.83	28.35	9.50	13.50	201.92	1160.18
	2/19/20 6:57	241.52	28.42	9.50	13.46	206.85	1161.04
	2/19/20 6:58	241.84	28.34	9.50	13.45	206.81	1160.83
	2/19/20 6:59	241.86	28.38	9.50	13.61	209.40	1160.88
	2/19/20 7:00	241.65	28.27	9.50	13.38	210.79	1161.11
	2/19/20 7:01	241.34	28.19	9.50	13.40	204.88	1160.35
	2/19/20 7:02	241.11	28.18	9.50	13.73	208.34	1160.72
	2/19/20 7:03	241.34	28.21	9.50	13.50	203.70	1160.74
	2/19/20 7:04	241.45	28.36	9.50	13.33	201.99	1160.67
	2/19/20 7:05	241.38	28.13	9.50	13.51	201.02	1161.18
	2/19/20 7:06	241.34	28.31	9.50	13.53	207.34	1161.50
	2/19/20 7:07	241.85	28.20	9.50	13.69	200.97	1161.73
	2/19/20 7:08	241.33	28.32	9.50	13.46	201.11	1161.52
	2/19/20 7:09	241.63	28.27	9.50	13.37	199.37	1161.15
	2/19/20 7:10	241.48	28.56	9.50	13.52	198.75	1160.59
	2/19/20 7:11	241.67	28.29	9.50	13.50	203.77	1161.72
	2/19/20 7:12	241.51	28.06	9.50	13.81	212.79	1161.69
	2/19/20 7:13	241.66	28.35	9.50	13.88	216.89	1162.33
	2/19/20 7:14	241.74	28.44	9.50	13.79	220.52	1161.69
	2/19/20 7:15	241.64	28.23	9.50	13.39	214.70	1161.88
	2/19/20 7:16	241.17	28.24	9.50	13.55	208.01	1161.04
	2/19/20 7:17	241.87	28.42	9.50	13.50	202.55	1161.88
	2/19/20 7:18	241.23	28.30	9.50	13.47	208.45	1161.16
	2/19/20 7:19	241.85	28.33	9.50	13.50	209.38	1161.83
	2/19/20 7:20	241.32	28.34	9.50	13.76	208.90	1161.29
	2/19/20 7:21	241.56	28.28	9.50	13.58	206.68	1161.79
	2/19/20 7:22	241.53	28.20	9.50	13.71	207.12	1161.43
	2/19/20 7:23	241.27	28.21	9.50	13.68	209.84	1161.96
	2/19/20 7:24	241.63	28.35	9.50	13.53	208.62	1160.95
	2/19/20 7:25	241.91	28.37	9.50	13.57	209.80	1162.23
	2/19/20 7:26	241.28	28.34	9.50	13.43	207.84	1161.46
	2/19/20 7:27	241.50	28.31	9.50	13.66	208.29	1161.60
	2/19/20 7:28	241.44	28.43	9.50	13.44	212.68	1161.82
	2/19/20 7:29	241.36	28.34	9.50	13.60	213.08	1162.36
	2/19/20 7:30	241.59	28.34	9.50	13.46	212.17	1161.79
	2/19/20 7:31	241.30	28.45	9.50	13.58	208.52	1161.93
	2/19/20 7:32	241.66	28.06	9.50	13.56	205.66	1162.62
	2/19/20 7:33	241.87	28.37	9.50	13.56	195.90	1161.87
	2/19/20 7:34	241.44	28.14	9.50	13.57	196.03	1161.81
	2/19/20 7:35	241.77	28.20	9.50	13.32	204.28	1161.73
	2/19/20 7:36	241.77	28.34	9.50	13.54	209.93	1162.19
	2/19/20 7:37	241.66	28.28	9.50	13.57	212.14	1161.85
	2/19/20 7:38	241.31	28.29	9.50	13.40	212.54	1161.77
	2/19/20 7:39	241.66	28.37	9.50	13.43	208.61	1161.87
	2/19/20 7:40	241.13	28.46	9.50	13.53	197.81	1161.19
	2/19/20 7:41	241.46	27.99	9.50	13.50	199.36	1161.93
	2/19/20 7:42	241.59	28.15	9.50	13.46	204.99	1162.02
	2/19/20 7:43	241.75	28.33	9.50	13.68	212.34	1162.46
	2/19/20 7:44	241.31	28.40	9.50	13.40	214.35	1161.90

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 4:24 - 2/19 8:15)	241.27	28.26	9.50	13.56	204.38	1160.59
COUNT = 232						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 7:45	241.50	28.13	9.50	13.58	206.01	1161.74
2/19/20 7:46	241.75	27.94	9.50	13.47	201.96	1162.65
2/19/20 7:47	241.70	28.22	9.50	13.72	200.54	1161.82
2/19/20 7:48	241.39	28.51	9.50	13.54	200.18	1161.61
2/19/20 7:49	241.95	28.22	9.50	13.79	210.77	1163.14
2/19/20 7:50	241.61	28.36	9.50	13.42	214.10	1162.09
2/19/20 7:51	241.73	28.39	9.50	13.49	209.45	1162.48
2/19/20 7:52	241.31	28.42	9.50	13.49	199.49	1162.03
2/19/20 7:53	241.24	28.34	9.50	13.52	200.16	1161.91
2/19/20 7:54	241.75	28.46	9.50	13.22	200.34	1161.97
2/19/20 7:55	241.71	28.22	9.50	13.44	210.48	1162.99
2/19/20 7:56	241.72	28.38	9.50	13.78	213.15	1162.65
2/19/20 7:57	241.16	28.44	9.50	13.88	200.81	1162.55
2/19/20 7:58	241.48	28.09	9.50	13.57	201.69	1162.10
2/19/20 7:59	241.66	28.33	9.50	13.77	199.64	1162.75
2/19/20 8:00	241.71	28.01	9.50	13.69	207.44	1162.54
2/19/20 8:01	241.62	28.09	9.50	13.54	211.56	1162.59
2/19/20 8:02	241.61	28.08	9.50	13.41	210.17	1162.18
2/19/20 8:03	241.46	28.26	9.50	13.64	202.12	1162.31
2/19/20 8:04	241.39	28.40	9.50	13.47	198.49	1162.67
2/19/20 8:05	241.65	28.56	9.50	13.40	196.92	1162.82
2/19/20 8:06	241.70	28.47	9.50	13.50	209.17	1162.45
2/19/20 8:07	241.37	28.14	9.50	13.73	216.29	1162.22
2/19/20 8:08	241.65	28.26	9.50	13.53	220.10	1162.21
2/19/20 8:09	241.65	28.17	9.51	14.00	214.66	1163.00
2/19/20 8:10	241.56	28.49	9.51	13.47	207.77	1162.81
2/19/20 8:11	241.48	28.30	9.51	13.82	206.92	1162.79
2/19/20 8:12	241.34	28.44	9.51	13.52	205.37	1162.38
2/19/20 8:13	241.66	28.25	9.51	13.78	202.19	1164.02
2/19/20 8:14	241.51	28.31	9.51	13.50	198.51	1162.91
2/19/20 8:15	241.45	28.08	9.51	13.43	204.02	1162.06

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 9:14 - 2/19 13:51)	241.24	28.24	7.73	13.52	188.50	1165.39
COUNT = 278						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 9:14	240.89	28.32	9.51	13.64	198.23	1163.69
2/19/20 9:15	240.98	28.39	9.51	13.40	196.64	1164.31
2/19/20 9:16	241.21	28.34	9.51	13.45	196.90	1164.08
2/19/20 9:17	240.87	28.33	9.51	13.64	196.12	1162.73
2/19/20 9:18	240.98	28.47	9.51	13.26	195.77	1162.73
2/19/20 9:19	240.71	28.22	9.51	13.68	204.38	1163.32
2/19/20 9:20	240.89	28.28	9.51	13.66	202.19	1163.63
2/19/20 9:21	240.83	28.38	9.51	13.30	196.47	1162.89
2/19/20 9:22	240.98	28.27	9.51	13.51	193.56	1163.72
2/19/20 9:23	240.88	28.21	9.51	13.77	187.97	1163.28
2/19/20 9:24	241.11	28.06	9.51	13.56	189.72	1163.43
2/19/20 9:25	241.14	28.23	9.51	13.56	197.37	1163.94
2/19/20 9:26	241.34	28.45	9.51	13.47	206.19	1163.73
2/19/20 9:27	241.24	28.44	9.51	13.43	206.69	1164.86
2/19/20 9:28	241.25	28.19	9.51	13.68	205.76	1164.45
2/19/20 9:29	240.93	28.49	9.51	14.03	203.01	1164.19
2/19/20 9:30	240.90	28.24	9.51	13.45	197.64	1164.19
2/19/20 9:31	241.19	28.17	9.51	13.70	194.33	1164.29
2/19/20 9:32	241.02	28.18	9.51	13.41	184.74	1163.62
2/19/20 9:33	240.89	28.47	9.51	13.50	185.91	1163.39
2/19/20 9:34	241.15	28.34	9.51	13.74	196.98	1164.72
2/19/20 9:35	241.10	28.16	9.51	13.60	203.33	1164.80
2/19/20 9:36	241.01	28.42	9.51	13.39	204.80	1164.10
2/19/20 9:37	240.93	28.43	9.51	13.67	205.62	1163.61
2/19/20 9:38	241.08	28.26	9.51	13.61	201.32	1164.29
2/19/20 9:39	240.76	28.12	9.51	13.35	197.91	1163.51
2/19/20 9:40	240.96	28.21	9.51	13.60	193.97	1164.07
2/19/20 9:41	241.16	28.37	9.51	13.59	196.25	1164.58
2/19/20 9:42	241.09	28.23	9.51	13.62	193.77	1164.42
2/19/20 9:43	241.05	28.26	9.51	13.49	196.98	1164.09
2/19/20 9:44	241.08	28.44	9.51	13.77	197.76	1164.56
2/19/20 9:45	240.98	28.17	9.51	13.50	206.41	1164.79
2/19/20 9:46	240.61	28.26	9.51	13.53	200.44	1163.99
2/19/20 9:47	240.98	28.31	9.51	13.55	194.01	1164.26
2/19/20 9:48	240.87	28.22	9.51	13.56	186.43	1163.83
2/19/20 9:49	241.02	28.19	9.51	13.49	183.10	1163.80
2/19/20 9:50	241.41	28.36	9.51	13.81	189.59	1164.92
2/19/20 9:51	241.29	28.28	9.51	13.72	198.75	1164.63
2/19/20 9:52	240.75	28.13	9.51	13.75	205.79	1163.96
2/19/20 9:53	240.19	27.87	9.51	13.66	206.80	1163.88
2/19/20 9:54	241.08	28.10	9.51	13.52	192.24	1165.00
2/19/20 9:55	240.86	28.34	9.51	13.61	180.81	1164.53
2/19/20 9:56	240.92	28.45	9.51	13.44	171.14	1163.91
2/19/20 9:57	240.82	28.03	9.51	13.64	190.27	1164.00
2/19/20 9:58	240.96	28.23	9.51	13.47	208.23	1164.46
2/19/20 9:59	240.68	28.32	9.51	13.72	220.82	1163.77
2/19/20 10:00	241.05	28.09	9.51	13.25	214.14	1164.43
2/19/20 10:01	240.79	28.23	9.51	13.68	193.76	1164.27
2/19/20 10:02	241.03	28.26	9.51	13.75	185.70	1165.08
2/19/20 10:03	241.02	28.40	9.51	13.41	190.57	1163.73
2/19/20 10:04	240.69	28.19	9.51	13.54	200.51	1164.35
2/19/20 10:05	240.94	28.47	9.51	13.84	212.80	1164.71
2/19/20 10:06	241.32	28.38	9.51	13.57	212.01	1164.38
2/19/20 10:07	241.09	28.33	9.51	13.72	203.78	1164.15
2/19/20 10:08	240.45	28.31	9.51	13.52	190.25	1164.07
2/19/20 10:09	241.29	28.07	9.50	13.47	182.51	1164.47
2/19/20 10:10	240.80	27.92	9.48	13.67	183.17	1164.27
2/19/20 10:11	240.72	28.17	9.46	13.55	182.95	1164.75
2/19/20 10:12	240.73	28.17	9.44	13.55	182.98	1164.76
2/19/20 10:13	240.73	28.17	9.42	13.55	183.01	1164.77
2/19/20 10:14	240.74	28.17	9.40	13.55	183.04	1164.78
2/19/20 10:15	240.74	28.17	9.38	13.55	183.07	1164.79
2/19/20 10:16	240.75	28.17	9.36	13.55	183.10	1164.80
2/19/20 10:17	240.76	28.17	9.34	13.55	183.13	1164.80
2/19/20 10:18	240.76	28.17	9.32	13.55	183.16	1164.81
2/19/20 10:19	240.77	28.17	9.30	13.54	183.19	1164.82
2/19/20 10:20	240.77	28.17	9.28	13.54	183.22	1164.83

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 9:14 - 2/19 13:51)	241.24	28.24	7.73	13.52	188.50	1165.39
COUNT = 278						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 10:21	240.78	28.17	9.26	13.54	183.26	1164.84
2/19/20 10:22	240.78	28.17	9.24	13.54	183.29	1164.85
2/19/20 10:23	240.79	28.17	9.22	13.54	183.32	1164.86
2/19/20 10:24	240.79	28.17	9.20	13.54	183.35	1164.87
2/19/20 10:25	240.80	28.17	9.18	13.54	183.38	1164.88
2/19/20 10:26	240.80	28.18	9.16	13.54	183.41	1164.88
2/19/20 10:27	240.81	28.18	9.14	13.54	183.44	1164.89
2/19/20 10:28	240.81	28.18	9.12	13.54	183.47	1164.90
2/19/20 10:29	240.82	28.18	9.10	13.54	183.50	1164.91
2/19/20 10:30	240.82	28.18	9.08	13.54	183.53	1164.92
2/19/20 10:31	240.83	28.18	9.06	13.54	183.56	1164.93
2/19/20 10:32	240.83	28.18	9.04	13.54	183.59	1164.94
2/19/20 10:33	240.84	28.18	9.02	13.54	183.62	1164.95
2/19/20 10:34	240.85	28.18	9.00	13.54	183.65	1164.96
2/19/20 10:35	240.85	28.18	8.98	13.54	183.68	1164.97
2/19/20 10:36	240.86	28.18	8.96	13.54	183.71	1164.97
2/19/20 10:37	240.86	28.18	8.94	13.54	183.74	1164.98
2/19/20 10:38	240.87	28.18	8.92	13.54	183.77	1164.99
2/19/20 10:39	240.87	28.18	8.91	13.54	183.80	1165.00
2/19/20 10:40	240.88	28.18	8.89	13.54	183.83	1165.01
2/19/20 10:41	240.88	28.18	8.87	13.54	183.86	1165.02
2/19/20 10:42	240.89	28.18	8.85	13.53	183.89	1165.03
2/19/20 10:43	240.89	28.19	8.83	13.53	183.92	1165.04
2/19/20 10:44	240.90	28.19	8.81	13.53	183.95	1165.05
2/19/20 10:45	240.90	28.19	8.79	13.53	183.98	1165.05
2/19/20 10:46	240.91	28.19	8.77	13.53	184.01	1165.06
2/19/20 10:47	240.91	28.19	8.75	13.53	184.04	1165.07
2/19/20 10:48	240.92	28.19	8.73	13.53	184.07	1165.08
2/19/20 10:49	240.92	28.19	8.71	13.53	184.10	1165.09
2/19/20 10:50	240.93	28.19	8.69	13.53	184.13	1165.10
2/19/20 10:51	240.94	28.19	8.67	13.53	184.17	1165.11
2/19/20 10:52	240.94	28.19	8.65	13.53	184.20	1165.12
2/19/20 10:53	240.95	28.19	8.63	13.53	184.23	1165.13
2/19/20 10:54	240.95	28.19	8.61	13.53	184.26	1165.13
2/19/20 10:55	240.96	28.19	8.59	13.53	184.29	1165.14
2/19/20 10:56	240.96	28.19	8.57	13.53	184.32	1165.15
2/19/20 10:57	240.97	28.19	8.55	13.53	184.35	1165.16
2/19/20 10:58	240.97	28.19	8.53	13.53	184.38	1165.17
2/19/20 10:59	240.98	28.20	8.51	13.53	184.41	1165.18
2/19/20 11:00	240.98	28.20	8.49	13.53	184.44	1165.19
2/19/20 11:01	240.99	28.20	8.47	13.53	184.47	1165.20
2/19/20 11:02	240.99	28.20	8.45	13.53	184.50	1165.21
2/19/20 11:03	241.00	28.20	8.43	13.53	184.53	1165.21
2/19/20 11:04	241.00	28.20	8.41	13.52	184.56	1165.22
2/19/20 11:05	241.01	28.20	8.39	13.52	184.59	1165.23
2/19/20 11:06	241.01	28.20	8.37	13.52	184.62	1165.24
2/19/20 11:07	241.02	28.20	8.35	13.52	184.65	1165.25
2/19/20 11:08	241.03	28.20	8.33	13.52	184.68	1165.26
2/19/20 11:09	241.03	28.20	8.31	13.52	184.71	1165.27
2/19/20 11:10	241.04	28.20	8.29	13.52	184.74	1165.28
2/19/20 11:11	241.04	28.20	8.27	13.52	184.77	1165.29
2/19/20 11:12	241.05	28.20	8.25	13.52	184.80	1165.30
2/19/20 11:13	241.05	28.20	8.23	13.52	184.83	1165.30
2/19/20 11:14	241.06	28.20	8.21	13.52	184.86	1165.31
2/19/20 11:15	241.06	28.20	8.19	13.52	184.89	1165.32
2/19/20 11:16	241.07	28.21	8.17	13.52	184.92	1165.33
2/19/20 11:17	241.07	28.21	8.15	13.52	184.95	1165.34
2/19/20 11:18	241.08	28.21	8.13	13.52	184.98	1165.35
2/19/20 11:19	241.08	28.21	8.11	13.52	185.01	1165.36
2/19/20 11:20	241.09	28.21	8.09	13.52	185.04	1165.37
2/19/20 11:21	241.09	28.21	8.07	13.52	185.08	1165.38
2/19/20 11:22	241.10	28.21	8.05	13.52	185.11	1165.38
2/19/20 11:23	241.10	28.21	8.03	13.52	185.14	1165.39
2/19/20 11:24	241.11	28.21	8.01	13.52	185.17	1165.40
2/19/20 11:25	241.12	28.21	7.99	13.52	185.20	1165.41
2/19/20 11:26	241.12	28.21	7.97	13.51	185.23	1165.42
2/19/20 11:27	241.13	28.21	7.95	13.51	185.26	1165.43

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 9:14 - 2/19 13:51)	241.24	28.24	7.73	13.52	188.50	1165.39
COUNT = 278						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 11:28	241.13	28.21	7.93	13.51	185.29	1165.44
2/19/20 11:29	241.14	28.21	7.91	13.51	185.32	1165.45
2/19/20 11:30	241.14	28.21	7.89	13.51	185.35	1165.46
2/19/20 11:31	241.15	28.21	7.87	13.51	185.38	1165.46
2/19/20 11:32	241.15	28.21	7.85	13.51	185.41	1165.47
2/19/20 11:33	241.16	28.22	7.83	13.51	185.44	1165.48
2/19/20 11:34	241.16	28.22	7.81	13.51	185.47	1165.49
2/19/20 11:35	241.17	28.22	7.79	13.51	185.50	1165.50
2/19/20 11:36	241.17	28.22	7.77	13.51	185.53	1165.51
2/19/20 11:37	241.18	28.22	7.75	13.51	185.56	1165.52
2/19/20 11:38	241.18	28.22	7.73	13.51	185.59	1165.53
2/19/20 11:39	241.19	28.22	7.71	13.51	185.62	1165.54
2/19/20 11:40	241.19	28.22	7.69	13.51	185.65	1165.55
2/19/20 11:41	241.20	28.22	7.67	13.51	185.68	1165.55
2/19/20 11:42	241.21	28.22	7.65	13.51	185.71	1165.56
2/19/20 11:43	241.21	28.22	7.63	13.51	185.74	1165.57
2/19/20 11:44	241.22	28.22	7.61	13.51	185.77	1165.58
2/19/20 11:45	241.22	28.22	7.59	13.51	185.80	1165.59
2/19/20 11:46	241.23	28.22	7.57	13.51	185.83	1165.60
2/19/20 11:47	241.23	28.22	7.55	13.51	185.86	1165.61
2/19/20 11:48	241.24	28.22	7.53	13.50	185.89	1165.62
2/19/20 11:49	241.24	28.22	7.51	13.50	185.92	1165.63
2/19/20 11:50	241.25	28.23	7.49	13.50	185.95	1165.63
2/19/20 11:51	241.25	28.23	7.47	13.50	185.99	1165.64
2/19/20 11:52	241.26	28.23	7.45	13.50	186.02	1165.65
2/19/20 11:53	241.26	28.23	7.43	13.50	186.05	1165.66
2/19/20 11:54	241.27	28.23	7.41	13.50	186.08	1165.67
2/19/20 11:55	241.27	28.23	7.39	13.50	186.11	1165.68
2/19/20 11:56	241.28	28.23	7.37	13.50	186.14	1165.69
2/19/20 11:57	241.28	28.23	7.35	13.50	186.17	1165.70
2/19/20 11:58	241.29	28.23	7.33	13.50	186.20	1165.71
2/19/20 11:59	241.30	28.23	7.31	13.50	186.23	1165.71
2/19/20 12:00	241.30	28.23	7.29	13.50	186.26	1165.72
2/19/20 12:01	241.31	28.23	7.27	13.50	186.29	1165.73
2/19/20 12:02	241.31	28.23	7.25	13.50	186.32	1165.74
2/19/20 12:03	241.32	28.23	7.23	13.50	186.35	1165.75
2/19/20 12:04	241.32	28.23	7.21	13.50	186.38	1165.76
2/19/20 12:05	241.33	28.23	7.19	13.50	186.41	1165.77
2/19/20 12:06	241.33	28.24	7.17	13.50	186.44	1165.78
2/19/20 12:07	241.34	28.24	7.15	13.50	186.47	1165.79
2/19/20 12:08	241.34	28.24	7.13	13.50	186.50	1165.79
2/19/20 12:09	241.35	28.24	7.11	13.50	186.53	1165.80
2/19/20 12:10	241.35	28.24	7.09	13.49	186.56	1165.81
2/19/20 12:11	241.36	28.24	7.07	13.49	186.59	1165.82
2/19/20 12:12	241.36	28.24	7.05	13.49	186.62	1165.83
2/19/20 12:13	241.37	28.24	7.03	13.49	186.65	1165.84
2/19/20 12:14	241.37	28.24	7.01	13.49	186.68	1165.85
2/19/20 12:15	241.38	28.24	6.99	13.49	186.71	1165.86
2/19/20 12:16	241.38	28.24	6.97	13.49	186.74	1165.87
2/19/20 12:17	241.39	28.24	6.95	13.49	186.77	1165.88
2/19/20 12:18	241.40	28.24	6.93	13.49	186.80	1165.88
2/19/20 12:19	241.40	28.24	6.91	13.49	186.83	1165.89
2/19/20 12:20	241.41	28.24	6.89	13.49	186.86	1165.90
2/19/20 12:21	241.41	28.24	6.87	13.49	186.90	1165.91
2/19/20 12:22	241.42	28.24	6.85	13.49	186.93	1165.92
2/19/20 12:23	241.42	28.25	6.83	13.49	186.96	1165.93
2/19/20 12:24	241.43	28.25	6.81	13.49	186.99	1165.94
2/19/20 12:25	241.43	28.25	6.79	13.49	187.02	1165.95
2/19/20 12:26	241.44	28.25	6.77	13.49	187.05	1165.96
2/19/20 12:27	241.44	28.25	6.75	13.49	187.08	1165.96
2/19/20 12:28	241.45	28.25	6.73	13.49	187.11	1165.97
2/19/20 12:29	241.45	28.25	6.71	13.49	187.14	1165.98
2/19/20 12:30	241.46	28.25	6.69	13.49	187.17	1165.99
2/19/20 12:31	241.46	28.25	6.67	13.49	187.20	1166.00
2/19/20 12:32	241.47	28.25	6.65	13.49	187.23	1166.01
2/19/20 12:33	241.47	28.25	6.63	13.48	187.26	1166.02
2/19/20 12:34	241.48	28.25	6.61	13.48	187.29	1166.03

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 9:14 - 2/19 13:51)	241.24	28.24	7.73	13.52	188.50	1165.39
COUNT = 278						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 12:35	241.49	28.25	6.59	13.48	187.32	1166.04
2/19/20 12:36	241.49	28.25	6.57	13.48	187.35	1166.04
2/19/20 12:37	241.50	28.25	6.55	13.48	187.38	1166.05
2/19/20 12:38	241.50	28.25	6.53	13.48	187.41	1166.06
2/19/20 12:39	241.51	28.25	6.51	13.48	187.44	1166.07
2/19/20 12:40	241.51	28.26	6.49	13.48	187.47	1166.08
2/19/20 12:41	241.52	28.26	6.47	13.48	187.50	1166.09
2/19/20 12:42	241.52	28.26	6.45	13.48	187.53	1166.10
2/19/20 12:43	241.53	28.26	6.43	13.48	187.56	1166.11
2/19/20 12:44	241.53	28.26	6.41	13.48	187.59	1166.12
2/19/20 12:45	241.54	28.26	6.39	13.48	187.62	1166.12
2/19/20 12:46	241.54	28.26	6.37	13.48	187.65	1166.13
2/19/20 12:47	241.55	28.26	6.35	13.48	187.68	1166.14
2/19/20 12:48	241.55	28.26	6.33	13.48	187.71	1166.15
2/19/20 12:49	241.56	28.26	6.31	13.48	187.74	1166.16
2/19/20 12:50	241.56	28.26	6.29	13.48	187.77	1166.17
2/19/20 12:51	241.57	28.26	6.27	13.48	187.81	1166.18
2/19/20 12:52	241.58	28.26	6.25	13.48	187.84	1166.19
2/19/20 12:53	241.58	28.26	6.23	13.48	187.87	1166.20
2/19/20 12:54	241.59	28.26	6.21	13.48	187.90	1166.21
2/19/20 12:55	241.59	28.26	6.19	13.47	187.93	1166.21
2/19/20 12:56	241.60	28.26	6.17	13.47	187.96	1166.22
2/19/20 12:57	241.60	28.27	6.15	13.47	187.99	1166.23
2/19/20 12:58	241.61	28.27	6.13	13.47	188.02	1166.24
2/19/20 12:59	241.61	28.27	6.11	13.47	188.05	1166.25
2/19/20 13:00	241.62	28.27	6.09	13.47	188.08	1166.26
2/19/20 13:01	241.62	28.27	6.07	13.47	188.11	1166.27
2/19/20 13:02	241.63	28.27	6.05	13.47	188.14	1166.28
2/19/20 13:03	241.63	28.27	6.03	13.47	188.17	1166.29
2/19/20 13:04	241.64	28.27	6.01	13.47	188.20	1166.29
2/19/20 13:05	241.64	28.27	5.99	13.47	188.23	1166.30
2/19/20 13:06	241.65	28.27	5.97	13.47	188.26	1166.31
2/19/20 13:07	241.65	28.27	5.95	13.47	188.29	1166.32
2/19/20 13:08	241.66	28.27	5.93	13.47	188.32	1166.33
2/19/20 13:09	241.67	28.27	5.91	13.47	188.35	1166.34
2/19/20 13:10	241.67	28.27	5.89	13.47	188.38	1166.35
2/19/20 13:11	241.68	28.27	5.87	13.47	188.41	1166.36
2/19/20 13:12	241.68	28.27	5.85	13.47	188.44	1166.37
2/19/20 13:13	241.69	28.28	5.83	13.47	188.47	1166.37
2/19/20 13:14	241.69	28.28	5.81	13.47	188.50	1166.38
2/19/20 13:15	241.70	28.28	5.79	13.47	188.53	1166.39
2/19/20 13:16	241.70	28.28	5.77	13.47	188.56	1166.40
2/19/20 13:17	241.71	28.28	5.75	13.46	188.59	1166.41
2/19/20 13:18	241.71	28.28	5.73	13.46	188.62	1166.42
2/19/20 13:19	241.72	28.28	5.71	13.46	188.65	1166.43
2/19/20 13:20	241.72	28.28	5.69	13.46	188.68	1166.44
2/19/20 13:21	241.73	28.28	5.67	13.46	188.72	1166.45
2/19/20 13:22	241.73	28.28	5.65	13.46	188.75	1166.45
2/19/20 13:23	241.74	28.28	5.63	13.46	188.78	1166.46
2/19/20 13:24	241.74	28.28	5.61	13.46	188.81	1166.47
2/19/20 13:25	241.75	28.28	5.59	13.46	188.84	1166.48
2/19/20 13:26	241.76	28.28	5.57	13.46	188.87	1166.49
2/19/20 13:27	241.76	28.28	5.55	13.46	188.90	1166.50
2/19/20 13:28	241.77	28.28	5.53	13.46	188.93	1166.51
2/19/20 13:29	241.77	28.28	5.51	13.46	188.96	1166.52
2/19/20 13:30	241.78	28.29	5.49	13.46	188.99	1166.53
2/19/20 13:31	241.78	28.29	5.47	13.46	189.02	1166.54
2/19/20 13:32	241.79	28.29	5.45	13.46	189.05	1166.54
2/19/20 13:33	241.79	28.29	5.43	13.46	189.08	1166.55
2/19/20 13:34	241.80	28.29	5.41	13.46	189.11	1166.56
2/19/20 13:35	241.80	28.29	5.39	13.46	189.14	1166.57
2/19/20 13:36	241.81	28.29	5.37	13.46	189.17	1166.58
2/19/20 13:37	241.81	28.29	5.35	13.46	189.20	1166.59
2/19/20 13:38	241.82	28.29	5.33	13.46	189.23	1166.60
2/19/20 13:39	241.82	28.29	5.31	13.45	189.26	1166.61
2/19/20 13:40	241.83	28.29	5.29	13.45	189.29	1166.62
2/19/20 13:41	241.83	28.29	5.27	13.45	189.32	1166.62

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 9:14 - 2/19 13:51)	241.24	28.24	7.73	13.52	188.50	1165.39
COUNT = 278						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 13:42	241.84	28.29	5.25	13.45	189.35	1166.63
2/19/20 13:43	241.85	28.29	5.23	13.45	189.38	1166.64
2/19/20 13:44	241.85	28.29	5.21	13.45	189.41	1166.65
2/19/20 13:45	241.86	28.29	5.19	13.45	189.44	1166.66
2/19/20 13:46	241.86	28.29	5.17	13.45	189.47	1166.67
2/19/20 13:47	241.87	28.30	5.15	13.45	189.50	1166.68
2/19/20 13:48	241.87	28.30	5.13	13.45	189.53	1166.69
2/19/20 13:49	241.88	28.30	5.11	13.45	189.56	1166.70
2/19/20 13:50	241.88	28.30	5.09	13.45	189.59	1166.70
2/19/20 13:51	241.89	28.30	5.07	13.45	189.63	1166.71

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
SAM

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 14:40 - 2/18 16:40)	240.86	28.30	9.61	13.60	192.60	1159.76
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 14:40	241.02	28.34	9.64	13.52	185.72	1160.51
2/18/20 14:41	240.91	28.03	9.64	13.61	178.60	1160.70
2/18/20 14:42	241.06	28.37	9.64	13.83	180.67	1161.11
2/18/20 14:43	241.21	28.28	9.64	13.66	190.73	1161.31
2/18/20 14:44	241.33	28.40	9.64	13.46	204.69	1161.25
2/18/20 14:45	240.80	28.37	9.64	13.87	208.27	1161.16
2/18/20 14:46	240.96	28.35	9.64	13.34	196.76	1160.64
2/18/20 14:47	240.86	28.35	9.64	13.45	185.20	1160.25
2/18/20 14:48	241.07	28.30	9.64	13.68	180.37	1160.71
2/18/20 14:49	241.36	28.37	9.64	13.46	176.77	1160.68
2/18/20 14:50	240.99	28.24	9.64	13.34	193.84	1160.00
2/18/20 14:51	241.39	28.28	9.64	13.57	206.21	1161.30
2/18/20 14:52	240.98	28.18	9.64	13.58	206.41	1161.00
2/18/20 14:53	240.89	28.44	9.63	13.41	193.76	1161.01
2/18/20 14:54	240.96	28.18	9.63	13.63	187.66	1160.44
2/18/20 14:55	240.74	28.41	9.63	13.52	181.40	1160.47
2/18/20 14:56	240.83	28.29	9.63	13.87	181.53	1160.50
2/18/20 14:57	240.78	28.51	9.63	13.79	201.33	1159.58
2/18/20 14:58	240.61	28.37	9.63	13.29	207.73	1160.63
2/18/20 14:59	241.35	28.29	9.63	13.58	204.59	1161.06
2/18/20 15:00	241.30	28.27	9.63	13.55	189.41	1160.29
2/18/20 15:01	241.23	28.33	9.63	13.93	177.01	1161.43
2/18/20 15:02	240.91	28.25	9.63	13.77	178.37	1160.44
2/18/20 15:03	241.21	28.48	9.63	13.62	183.60	1161.54
2/18/20 15:04	241.03	28.31	9.63	13.62	199.15	1160.71
2/18/20 15:05	240.81	28.09	9.63	13.46	207.52	1160.64
2/18/20 15:06	241.28	28.43	9.63	13.81	201.39	1161.34
2/18/20 15:07	241.09	28.35	9.63	13.61	190.01	1160.68
2/18/20 15:08	240.64	28.41	9.63	13.35	182.64	1160.30
2/18/20 15:09	241.41	28.27	9.63	13.81	182.92	1160.76
2/18/20 15:10	241.43	28.31	9.62	13.62	196.27	1160.90
2/18/20 15:11	241.05	28.22	9.62	13.76	211.40	1160.52
2/18/20 15:12	241.30	28.41	9.62	13.31	211.27	1160.58
2/18/20 15:13	241.13	28.30	9.62	13.55	200.07	1160.90
2/18/20 15:14	240.93	28.34	9.62	13.71	186.93	1160.35
2/18/20 15:15	240.99	28.55	9.62	13.72	187.63	1160.61
2/18/20 15:16	240.78	28.20	9.62	13.59	183.63	1160.04
2/18/20 15:17	241.08	28.19	9.62	13.55	198.09	1159.68
2/18/20 15:18	240.91	28.19	9.62	13.78	195.21	1160.01
2/18/20 15:19	241.27	28.36	9.62	13.65	194.06	1160.41
2/18/20 15:20	240.77	28.38	9.62	13.59	191.84	1160.21
2/18/20 15:21	240.51	28.34	9.62	13.54	188.91	1160.14
2/18/20 15:22	240.82	28.28	9.62	14.02	186.78	1160.27
2/18/20 15:23	241.16	28.22	9.62	13.53	189.81	1160.03
2/18/20 15:24	240.73	28.33	9.62	13.64	190.23	1159.95
2/18/20 15:25	240.77	28.18	9.62	13.56	191.24	1159.24
2/18/20 15:26	241.35	28.42	9.62	13.45	192.26	1161.38
2/18/20 15:27	240.78	28.28	9.61	13.44	196.76	1160.36
2/18/20 15:28	240.62	28.22	9.61	13.38	202.53	1159.05
2/18/20 15:29	240.89	28.31	9.61	13.76	204.47	1159.52
2/18/20 15:30	241.04	28.35	9.61	13.83	204.28	1160.92
2/18/20 15:31	241.06	28.33	9.61	13.79	192.71	1161.47
2/18/20 15:32	240.75	28.54	9.61	13.67	180.49	1160.27
2/18/20 15:33	240.92	28.22	9.61	13.61	178.31	1160.08
2/18/20 15:34	240.90	28.33	9.61	13.51	187.66	1160.00
2/18/20 15:35	241.18	28.30	9.61	13.52	200.31	1160.43
2/18/20 15:36	240.62	28.26	9.61	13.54	205.97	1159.51
2/18/20 15:37	240.69	28.24	9.61	13.34	198.74	1159.36
2/18/20 15:38	241.21	28.36	9.61	13.43	185.75	1160.07
2/18/20 15:39	240.61	28.08	9.61	13.74	180.33	1159.65
2/18/20 15:40	240.43	28.24	9.61	13.53	182.20	1158.99
2/18/20 15:41	241.16	28.17	9.61	13.65	186.18	1160.17
2/18/20 15:42	240.68	28.25	9.61	13.49	193.53	1159.18
2/18/20 15:43	240.91	28.29	9.61	13.51	203.85	1160.01
2/18/20 15:44	240.49	28.21	9.60	13.45	205.07	1158.50
2/18/20 15:45	241.31	28.23	9.60	13.90	200.68	1160.18
2/18/20 15:46	240.66	28.14	9.60	13.56	193.71	1159.12

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/18 14:40 - 2/18 16:40)	240.86	28.30	9.61	13.60	192.60	1159.76
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/18/20 15:47	241.08	28.66	9.60	13.46	182.32	1160.33
2/18/20 15:48	241.05	28.27	9.60	13.63	183.97	1159.94
2/18/20 15:49	240.87	28.49	9.60	13.61	183.20	1159.42
2/18/20 15:50	240.58	28.27	9.60	13.42	187.49	1158.83
2/18/20 15:51	240.98	28.32	9.60	13.58	190.00	1159.35
2/18/20 15:52	240.75	28.07	9.60	13.54	186.74	1159.61
2/18/20 15:53	240.30	28.37	9.60	13.60	188.50	1159.54
2/18/20 15:54	240.91	28.31	9.60	13.60	185.42	1159.77
2/18/20 15:55	241.08	28.39	9.60	13.73	188.98	1159.88
2/18/20 15:56	240.97	28.35	9.60	13.42	189.42	1159.26
2/18/20 15:57	241.01	28.26	9.60	13.51	189.06	1159.67
2/18/20 15:58	241.06	28.25	9.60	13.82	187.29	1159.73
2/18/20 15:59	240.82	28.28	9.60	13.47	187.80	1159.06
2/18/20 16:00	240.53	28.52	9.60	13.79	195.29	1159.24
2/18/20 16:01	240.82	28.19	9.59	13.70	201.40	1158.99
2/18/20 16:02	240.89	28.43	9.59	13.79	205.92	1159.15
2/18/20 16:03	240.75	28.37	9.59	13.41	203.41	1159.21
2/18/20 16:04	240.54	28.30	9.59	13.59	195.69	1159.27
2/18/20 16:05	240.45	28.19	9.59	13.36	187.96	1159.17
2/18/20 16:06	240.67	28.17	9.59	13.63	189.53	1160.16
2/18/20 16:07	240.67	28.40	9.59	13.49	191.59	1159.46
2/18/20 16:08	240.75	28.24	9.59	13.43	193.88	1158.80
2/18/20 16:09	240.59	28.27	9.59	13.61	196.99	1159.83
2/18/20 16:10	241.13	28.17	9.59	13.45	200.53	1160.19
2/18/20 16:11	241.34	28.24	9.59	13.76	198.64	1159.73
2/18/20 16:12	241.01	28.25	9.59	13.43	197.62	1158.45
2/18/20 16:13	240.10	28.27	9.59	13.65	189.23	1158.42
2/18/20 16:14	240.96	28.42	9.59	13.64	184.30	1159.44
2/18/20 16:15	240.39	28.46	9.59	13.76	184.04	1158.71
2/18/20 16:16	240.85	28.25	9.59	13.66	187.62	1158.76
2/18/20 16:17	240.87	28.30	9.59	13.50	190.27	1158.35
2/18/20 16:18	240.55	28.41	9.58	13.44	192.77	1158.35
2/18/20 16:19	240.89	28.34	9.58	13.81	193.29	1159.31
2/18/20 16:20	240.74	28.27	9.58	13.82	191.38	1159.52
2/18/20 16:21	240.40	28.38	9.58	13.71	190.51	1159.39
2/18/20 16:22	240.56	28.08	9.58	13.78	196.37	1159.51
2/18/20 16:23	240.92	28.36	9.58	13.50	198.89	1158.44
2/18/20 16:24	240.27	28.40	9.58	13.65	199.62	1158.25
2/18/20 16:25	241.14	28.34	9.58	13.67	193.80	1159.04
2/18/20 16:26	240.69	28.09	9.58	13.37	195.69	1158.07
2/18/20 16:27	240.29	28.38	9.58	13.43	191.35	1157.92
2/18/20 16:28	240.37	28.34	9.58	13.68	192.11	1158.57
2/18/20 16:29	240.59	28.42	9.58	13.54	189.90	1158.18
2/18/20 16:30	240.62	28.37	9.58	13.51	186.52	1158.57
2/18/20 16:31	240.47	28.40	9.58	13.46	189.41	1158.69
2/18/20 16:32	240.35	28.23	9.58	13.67	190.87	1157.90
2/18/20 16:33	241.01	28.12	9.58	13.64	196.76	1158.27
2/18/20 16:34	240.83	28.38	9.58	13.64	191.19	1158.82
2/18/20 16:35	240.90	28.24	9.57	13.59	192.85	1159.05
2/18/20 16:36	240.78	28.39	9.57	13.55	191.43	1158.51
2/18/20 16:37	240.55	28.25	9.57	13.87	195.05	1158.60
2/18/20 16:38	240.69	28.49	9.57	13.52	199.27	1158.41
2/18/20 16:39	240.49	28.09	9.57	13.52	202.39	1157.51
2/18/20 16:40	240.70	28.18	9.57	13.52	195.89	1158.07

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 4:9 - 2/19 6:9)	240.93	28.22	9.49	13.57	200.92	1159.48
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 4:09	240.45	28.14	9.49	13.63	191.62	1157.58
2/19/20 4:10	240.61	28.04	9.49	13.58	194.21	1157.89
2/19/20 4:11	241.09	27.97	9.49	13.61	202.03	1158.89
2/19/20 4:12	240.89	28.38	9.49	13.44	201.54	1158.20
2/19/20 4:13	240.48	28.33	9.49	13.48	207.33	1158.10
2/19/20 4:14	241.10	28.22	9.49	13.31	207.06	1158.41
2/19/20 4:15	240.61	28.13	9.49	13.63	197.29	1158.23
2/19/20 4:16	241.08	28.21	9.49	13.56	197.12	1160.06
2/19/20 4:17	240.76	28.01	9.49	13.91	198.90	1158.80
2/19/20 4:18	241.03	28.33	9.49	13.43	198.44	1159.20
2/19/20 4:19	240.91	28.14	9.49	13.64	199.86	1158.64
2/19/20 4:20	240.87	28.02	9.49	13.73	200.27	1157.70
2/19/20 4:21	240.30	28.31	9.49	13.56	202.60	1157.14
2/19/20 4:22	240.34	28.17	9.49	13.52	199.37	1157.95
2/19/20 4:23	240.33	28.08	9.49	13.37	199.75	1158.62
2/19/20 4:24	240.84	28.23	9.49	13.38	202.74	1158.93
2/19/20 4:25	240.66	28.40	9.49	13.54	197.10	1158.57
2/19/20 4:26	240.50	28.16	9.49	13.27	200.55	1159.07
2/19/20 4:27	241.11	28.36	9.49	13.53	201.59	1158.82
2/19/20 4:28	240.29	28.53	9.49	13.55	203.16	1157.94
2/19/20 4:29	241.28	28.03	9.49	13.33	198.93	1158.74
2/19/20 4:30	240.36	28.14	9.49	13.38	201.38	1157.96
2/19/20 4:31	240.64	28.26	9.49	13.94	201.35	1158.66
2/19/20 4:32	240.87	28.22	9.49	13.29	202.89	1158.19
2/19/20 4:33	241.02	27.90	9.49	13.35	198.59	1158.77
2/19/20 4:34	240.31	28.09	9.49	13.38	202.83	1158.64
2/19/20 4:35	240.89	28.17	9.49	13.99	198.78	1159.56
2/19/20 4:36	241.17	28.13	9.49	13.89	198.70	1158.90
2/19/20 4:37	240.74	28.21	9.49	13.68	198.66	1158.79
2/19/20 4:38	240.78	28.04	9.49	13.61	197.53	1158.82
2/19/20 4:39	240.60	28.26	9.49	13.64	200.11	1158.90
2/19/20 4:40	240.82	28.15	9.49	13.67	202.61	1159.26
2/19/20 4:41	240.82	28.29	9.49	13.38	200.17	1158.67
2/19/20 4:42	241.41	28.27	9.49	13.49	200.40	1159.02
2/19/20 4:43	240.93	28.28	9.49	13.45	201.18	1158.67
2/19/20 4:44	240.50	28.24	9.49	13.37	203.20	1158.37
2/19/20 4:45	241.27	28.31	9.49	13.42	202.06	1159.12
2/19/20 4:46	240.88	28.07	9.49	13.69	202.51	1159.86
2/19/20 4:47	240.51	28.38	9.49	13.52	204.26	1159.02
2/19/20 4:48	240.87	28.05	9.49	13.82	201.89	1159.21
2/19/20 4:49	240.90	28.24	9.49	13.73	192.21	1159.20
2/19/20 4:50	240.88	28.20	9.49	13.64	195.61	1158.71
2/19/20 4:51	240.92	28.48	9.49	13.52	195.93	1159.36
2/19/20 4:52	240.43	28.15	9.49	13.70	191.80	1158.96
2/19/20 4:53	241.13	28.11	9.49	13.50	196.95	1159.26
2/19/20 4:54	241.02	28.24	9.49	13.77	196.12	1160.02
2/19/20 4:55	240.73	28.19	9.49	13.52	194.10	1159.37
2/19/20 4:56	240.73	28.23	9.49	13.33	193.63	1158.85
2/19/20 4:57	241.02	28.28	9.49	13.46	194.81	1160.21
2/19/20 4:58	240.84	28.30	9.49	13.97	195.51	1159.54
2/19/20 4:59	241.17	28.19	9.49	13.52	197.80	1160.06
2/19/20 5:00	240.84	28.28	9.49	13.27	200.95	1160.45
2/19/20 5:01	240.81	28.23	9.49	13.27	203.35	1159.38
2/19/20 5:02	241.00	28.40	9.49	13.60	198.75	1159.36
2/19/20 5:03	240.59	28.31	9.49	13.65	201.61	1159.00
2/19/20 5:04	241.06	28.51	9.49	13.49	201.74	1159.78
2/19/20 5:05	241.37	28.33	9.49	13.64	197.50	1160.22
2/19/20 5:06	240.80	28.07	9.49	13.51	192.35	1159.07
2/19/20 5:07	241.24	28.08	9.49	13.64	189.82	1160.38
2/19/20 5:08	240.68	28.13	9.49	13.40	191.88	1159.25
2/19/20 5:09	240.71	28.15	9.49	13.52	196.47	1159.17
2/19/20 5:10	240.88	28.15	9.49	13.86	197.81	1159.87
2/19/20 5:11	240.84	28.43	9.49	13.53	209.86	1159.51
2/19/20 5:12	241.07	28.34	9.49	13.43	202.33	1159.52
2/19/20 5:13	240.98	28.43	9.49	13.62	192.02	1159.80
2/19/20 5:14	240.46	27.97	9.49	13.21	192.02	1158.73
2/19/20 5:15	241.30	28.15	9.49	13.67	190.38	1160.14

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 4:9 - 2/19 6:9)	240.93	28.22	9.49	13.57	200.92	1159.48
COUNT = 121						
Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 5:16	240.96	28.24	9.49	13.63	197.56	1159.50
2/19/20 5:17	240.68	28.28	9.49	13.65	208.36	1160.09
2/19/20 5:18	240.83	28.15	9.49	13.61	217.47	1158.97
2/19/20 5:19	241.07	28.35	9.49	13.50	220.17	1160.26
2/19/20 5:20	240.83	28.10	9.49	13.76	215.82	1159.82
2/19/20 5:21	240.89	28.24	9.49	13.70	203.41	1159.98
2/19/20 5:22	241.22	28.48	9.49	13.65	198.61	1159.86
2/19/20 5:23	240.95	28.21	9.49	13.42	200.32	1160.44
2/19/20 5:24	241.09	28.33	9.49	13.74	200.00	1160.38
2/19/20 5:25	240.53	28.25	9.49	13.34	208.98	1159.48
2/19/20 5:26	241.34	28.20	9.49	13.50	210.52	1159.92
2/19/20 5:27	241.07	28.23	9.49	13.61	213.65	1160.04
2/19/20 5:28	240.79	28.10	9.49	13.47	211.06	1159.03
2/19/20 5:29	241.45	28.15	9.49	13.64	201.91	1160.17
2/19/20 5:30	241.21	28.30	9.49	13.71	197.97	1159.92
2/19/20 5:31	241.18	28.15	9.49	13.63	190.09	1159.43
2/19/20 5:32	241.22	28.36	9.49	13.58	196.91	1159.98
2/19/20 5:33	241.01	28.34	9.50	13.57	198.16	1160.15
2/19/20 5:34	240.89	28.07	9.50	13.49	200.44	1159.56
2/19/20 5:35	241.51	28.32	9.50	13.57	206.34	1159.91
2/19/20 5:36	241.43	28.09	9.50	13.77	200.84	1161.24
2/19/20 5:37	240.83	28.38	9.50	13.70	198.29	1159.42
2/19/20 5:38	241.14	28.11	9.50	13.67	200.03	1160.54
2/19/20 5:39	240.91	28.24	9.50	13.49	191.49	1159.43
2/19/20 5:40	240.79	28.39	9.50	13.51	194.51	1160.25
2/19/20 5:41	241.58	28.31	9.50	13.89	197.51	1160.55
2/19/20 5:42	241.22	28.24	9.50	13.60	202.12	1159.80
2/19/20 5:43	241.09	28.25	9.50	13.41	209.53	1160.48
2/19/20 5:44	240.88	28.19	9.50	13.41	208.57	1159.21
2/19/20 5:45	241.40	28.16	9.50	13.35	203.93	1160.34
2/19/20 5:46	240.61	28.05	9.50	13.81	200.65	1159.77
2/19/20 5:47	241.22	28.26	9.50	13.18	196.89	1159.87
2/19/20 5:48	241.12	28.22	9.50	13.58	208.99	1159.48
2/19/20 5:49	240.97	28.30	9.50	13.58	218.56	1160.26
2/19/20 5:50	240.82	28.21	9.50	13.43	220.27	1159.45
2/19/20 5:51	240.86	28.30	9.50	13.86	210.82	1160.81
2/19/20 5:52	240.66	28.12	9.50	13.59	204.55	1159.76
2/19/20 5:53	241.02	28.17	9.50	13.68	184.02	1159.85
2/19/20 5:54	241.03	28.53	9.50	13.47	181.84	1159.99
2/19/20 5:55	241.16	28.21	9.50	13.68	190.34	1160.69
2/19/20 5:56	241.04	28.25	9.50	13.59	205.19	1160.60
2/19/20 5:57	241.15	28.09	9.50	13.74	214.41	1161.02
2/19/20 5:58	241.12	28.38	9.50	13.49	214.54	1160.40
2/19/20 5:59	241.39	28.09	9.50	13.68	204.76	1161.73
2/19/20 6:00	241.50	28.21	9.50	13.88	201.13	1161.04
2/19/20 6:01	241.31	28.30	9.50	13.61	200.43	1159.86
2/19/20 6:02	241.22	28.11	9.50	13.52	193.57	1160.72
2/19/20 6:03	241.13	28.26	9.50	13.50	204.80	1159.54
2/19/20 6:04	241.13	28.22	9.50	13.65	213.40	1160.83
2/19/20 6:05	241.11	28.10	9.50	13.54	213.82	1159.61
2/19/20 6:06	241.15	28.26	9.50	13.54	208.16	1159.77
2/19/20 6:07	241.15	28.42	9.50	13.58	203.94	1160.04
2/19/20 6:08	240.93	28.03	9.50	13.76	195.81	1160.13
2/19/20 6:09	240.84	28.18	9.50	13.57	191.64	1160.08

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 7:26 - 2/19 9:26)	241.38	28.28	9.51	13.55	203.78	1162.85
COUNT = 121						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 7:26	241.28	28.34	9.50	13.43	207.84	1161.46
2/19/20 7:27	241.50	28.31	9.50	13.66	208.29	1161.60
2/19/20 7:28	241.44	28.43	9.50	13.44	212.68	1161.82
2/19/20 7:29	241.36	28.34	9.50	13.60	213.08	1162.36
2/19/20 7:30	241.59	28.34	9.50	13.46	212.17	1161.79
2/19/20 7:31	241.30	28.45	9.50	13.58	208.52	1161.93
2/19/20 7:32	241.66	28.06	9.50	13.56	205.66	1162.62
2/19/20 7:33	241.87	28.37	9.50	13.56	195.90	1161.87
2/19/20 7:34	241.44	28.14	9.50	13.57	196.03	1161.81
2/19/20 7:35	241.77	28.20	9.50	13.32	204.28	1161.73
2/19/20 7:36	241.77	28.34	9.50	13.54	209.93	1162.19
2/19/20 7:37	241.66	28.28	9.50	13.57	212.14	1161.85
2/19/20 7:38	241.31	28.29	9.50	13.40	212.54	1161.77
2/19/20 7:39	241.66	28.37	9.50	13.43	208.61	1161.87
2/19/20 7:40	241.13	28.46	9.50	13.53	197.81	1161.19
2/19/20 7:41	241.46	27.99	9.50	13.50	199.36	1161.93
2/19/20 7:42	241.59	28.15	9.50	13.46	204.99	1162.02
2/19/20 7:43	241.75	28.33	9.50	13.68	212.34	1162.46
2/19/20 7:44	241.31	28.40	9.50	13.40	214.35	1161.90
2/19/20 7:45	241.50	28.13	9.50	13.58	206.01	1161.74
2/19/20 7:46	241.75	27.94	9.50	13.47	201.96	1162.65
2/19/20 7:47	241.70	28.22	9.50	13.72	200.54	1161.82
2/19/20 7:48	241.39	28.51	9.50	13.54	200.18	1161.61
2/19/20 7:49	241.95	28.22	9.50	13.79	210.77	1163.14
2/19/20 7:50	241.61	28.36	9.50	13.42	214.10	1162.09
2/19/20 7:51	241.73	28.39	9.50	13.49	209.45	1162.48
2/19/20 7:52	241.31	28.42	9.50	13.49	199.49	1162.03
2/19/20 7:53	241.24	28.34	9.50	13.52	200.16	1161.91
2/19/20 7:54	241.75	28.46	9.50	13.22	200.34	1161.97
2/19/20 7:55	241.71	28.22	9.50	13.44	210.48	1162.99
2/19/20 7:56	241.72	28.38	9.50	13.78	213.15	1162.65
2/19/20 7:57	241.16	28.44	9.50	13.88	200.81	1162.55
2/19/20 7:58	241.48	28.09	9.50	13.57	201.69	1162.10
2/19/20 7:59	241.66	28.33	9.50	13.77	199.64	1162.75
2/19/20 8:00	241.71	28.01	9.50	13.69	207.44	1162.54
2/19/20 8:01	241.62	28.09	9.50	13.54	211.56	1162.59
2/19/20 8:02	241.61	28.08	9.50	13.41	210.17	1162.18
2/19/20 8:03	241.46	28.26	9.50	13.64	202.12	1162.31
2/19/20 8:04	241.39	28.40	9.50	13.47	198.49	1162.67
2/19/20 8:05	241.65	28.56	9.50	13.40	196.92	1162.82
2/19/20 8:06	241.70	28.47	9.50	13.50	209.17	1162.45
2/19/20 8:07	241.37	28.14	9.50	13.73	216.29	1162.22
2/19/20 8:08	241.65	28.26	9.50	13.53	220.10	1162.21
2/19/20 8:09	241.65	28.17	9.51	14.00	214.66	1163.00
2/19/20 8:10	241.56	28.49	9.51	13.47	207.77	1162.81
2/19/20 8:11	241.48	28.30	9.51	13.82	206.92	1162.79
2/19/20 8:12	241.34	28.44	9.51	13.52	205.37	1162.38
2/19/20 8:13	241.66	28.25	9.51	13.78	202.19	1164.02
2/19/20 8:14	241.51	28.31	9.51	13.50	198.51	1162.91
2/19/20 8:15	241.45	28.08	9.51	13.43	204.02	1162.06
2/19/20 8:16	241.72	28.20	9.51	13.39	204.79	1162.22
2/19/20 8:17	241.48	28.33	9.51	13.25	215.17	1162.65
2/19/20 8:18	241.41	28.35	9.51	13.97	220.32	1163.21
2/19/20 8:19	241.45	28.06	9.51	13.49	209.15	1162.70
2/19/20 8:20	241.91	28.28	9.51	13.38	200.31	1163.93
2/19/20 8:21	241.29	28.43	9.51	13.66	192.96	1163.18
2/19/20 8:22	241.78	28.51	9.51	13.34	194.40	1163.13
2/19/20 8:23	241.62	28.48	9.51	13.88	198.30	1163.33
2/19/20 8:24	241.37	28.10	9.51	13.84	201.00	1163.35
2/19/20 8:25	241.43	28.27	9.51	13.42	207.22	1162.90
2/19/20 8:26	241.11	28.35	9.51	13.39	206.28	1162.49
2/19/20 8:27	241.95	28.29	9.51	13.64	204.23	1163.60
2/19/20 8:28	241.47	28.45	9.51	13.66	193.74	1163.25
2/19/20 8:29	241.00	28.27	9.51	13.51	196.66	1162.39
2/19/20 8:30	241.29	28.38	9.51	13.43	206.04	1162.46
2/19/20 8:31	241.67	28.15	9.51	13.35	219.07	1162.87
2/19/20 8:32	241.33	28.11	9.51	13.32	224.89	1162.91

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 7:26 - 2/19 9:26)		241.38	28.28	9.51	13.55	203.78	1162.85
COUNT = 121							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 8:33	241.47	28.39	9.51	13.61	217.97	1162.84
	2/19/20 8:34	241.48	28.19	9.51	13.71	208.36	1162.99
	2/19/20 8:35	241.56	28.35	9.51	13.42	197.57	1162.18
	2/19/20 8:36	241.47	28.36	9.51	13.53	196.40	1162.63
	2/19/20 8:37	241.11	28.26	9.51	13.44	205.52	1163.00
	2/19/20 8:38	241.24	28.54	9.51	13.57	207.39	1162.59
	2/19/20 8:39	241.78	28.42	9.51	13.45	205.71	1163.35
	2/19/20 8:40	241.44	27.90	9.51	13.66	200.20	1163.73
	2/19/20 8:41	241.37	28.33	9.51	13.82	198.00	1162.99
	2/19/20 8:42	241.25	28.08	9.51	13.62	194.17	1163.49
	2/19/20 8:43	241.14	28.26	9.51	13.69	201.25	1162.95
	2/19/20 8:44	241.59	28.28	9.51	13.82	207.95	1163.71
	2/19/20 8:45	241.06	28.24	9.51	13.42	216.01	1162.64
	2/19/20 8:46	241.27	28.18	9.51	13.56	221.99	1162.97
	2/19/20 8:47	241.14	28.23	9.51	13.83	217.08	1163.71
	2/19/20 8:48	241.16	28.42	9.51	13.53	208.36	1163.37
	2/19/20 8:49	241.41	28.34	9.51	13.49	197.72	1163.70
	2/19/20 8:50	241.12	28.24	9.51	13.43	196.40	1162.18
	2/19/20 8:51	241.19	28.22	9.51	13.28	196.57	1163.20
	2/19/20 8:52	241.27	28.34	9.51	13.45	201.35	1163.45
	2/19/20 8:53	241.31	28.19	9.51	13.40	206.15	1162.69
	2/19/20 8:54	241.11	28.14	9.51	13.39	200.31	1163.42
	2/19/20 8:55	241.10	28.28	9.51	13.58	200.94	1163.36
	2/19/20 8:56	241.11	28.18	9.51	13.41	203.62	1162.82
	2/19/20 8:57	241.60	28.41	9.51	13.53	202.19	1164.07
	2/19/20 8:58	241.01	28.18	9.51	13.64	210.61	1163.44
	2/19/20 8:59	241.34	28.23	9.51	13.27	211.61	1163.24
	2/19/20 9:00	240.87	28.06	9.51	13.33	205.47	1162.92
	2/19/20 9:01	241.35	28.26	9.51	13.59	189.99	1163.37
	2/19/20 9:02	241.62	28.11	9.51	13.59	179.94	1164.10
	2/19/20 9:03	241.04	28.61	9.51	13.52	185.44	1163.80
	2/19/20 9:04	241.44	28.59	9.51	13.59	200.43	1163.68
	2/19/20 9:05	241.20	28.12	9.51	13.77	209.64	1164.20
	2/19/20 9:06	241.05	28.09	9.51	13.68	212.01	1164.54
	2/19/20 9:07	240.87	28.35	9.51	13.44	199.06	1163.32
	2/19/20 9:08	240.93	28.30	9.51	13.58	186.57	1163.88
	2/19/20 9:09	241.04	28.29	9.51	13.52	184.23	1162.95
	2/19/20 9:10	241.18	28.45	9.51	13.71	190.03	1164.24
	2/19/20 9:11	241.06	28.18	9.51	13.61	200.46	1163.74
	2/19/20 9:12	241.19	28.30	9.51	13.96	206.47	1163.75
	2/19/20 9:13	241.20	28.28	9.51	13.67	202.95	1163.41
	2/19/20 9:14	240.89	28.32	9.51	13.64	198.23	1163.69
	2/19/20 9:15	240.98	28.39	9.51	13.40	196.64	1164.31
	2/19/20 9:16	241.21	28.34	9.51	13.45	196.90	1164.08
	2/19/20 9:17	240.87	28.33	9.51	13.64	196.12	1162.73
	2/19/20 9:18	240.98	28.47	9.51	13.26	195.77	1162.73
	2/19/20 9:19	240.71	28.22	9.51	13.68	204.38	1163.32
	2/19/20 9:20	240.89	28.28	9.51	13.66	202.19	1163.63
	2/19/20 9:21	240.83	28.38	9.51	13.30	196.47	1162.89
	2/19/20 9:22	240.98	28.27	9.51	13.51	193.56	1163.72
	2/19/20 9:23	240.88	28.21	9.51	13.77	187.97	1163.28
	2/19/20 9:24	241.11	28.06	9.51	13.56	189.72	1163.43
	2/19/20 9:25	241.14	28.23	9.51	13.56	197.37	1163.94
	2/19/20 9:26	241.34	28.45	9.51	13.47	206.19	1163.73

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
Opacity

The U-00001 fuel flow rates (lbm/s) shown on the following pages are uncorrected values.

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 11:0 - 2/19 12:0)		241.14	28.21	7.89	13.51	185.35	1165.46
COUNT = 61							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 11:00	240.98	28.20	8.49	13.53	184.44	1165.19
	2/19/20 11:01	240.99	28.20	8.47	13.53	184.47	1165.20
	2/19/20 11:02	240.99	28.20	8.45	13.53	184.50	1165.21
	2/19/20 11:03	241.00	28.20	8.43	13.53	184.53	1165.21
	2/19/20 11:04	241.00	28.20	8.41	13.52	184.56	1165.22
	2/19/20 11:05	241.01	28.20	8.39	13.52	184.59	1165.23
	2/19/20 11:06	241.01	28.20	8.37	13.52	184.62	1165.24
	2/19/20 11:07	241.02	28.20	8.35	13.52	184.65	1165.25
	2/19/20 11:08	241.03	28.20	8.33	13.52	184.68	1165.26
	2/19/20 11:09	241.03	28.20	8.31	13.52	184.71	1165.27
	2/19/20 11:10	241.04	28.20	8.29	13.52	184.74	1165.28
	2/19/20 11:11	241.04	28.20	8.27	13.52	184.77	1165.29
	2/19/20 11:12	241.05	28.20	8.25	13.52	184.80	1165.30
	2/19/20 11:13	241.05	28.20	8.23	13.52	184.83	1165.30
	2/19/20 11:14	241.06	28.20	8.21	13.52	184.86	1165.31
	2/19/20 11:15	241.06	28.20	8.19	13.52	184.89	1165.32
	2/19/20 11:16	241.07	28.21	8.17	13.52	184.92	1165.33
	2/19/20 11:17	241.07	28.21	8.15	13.52	184.95	1165.34
	2/19/20 11:18	241.08	28.21	8.13	13.52	184.98	1165.35
	2/19/20 11:19	241.08	28.21	8.11	13.52	185.01	1165.36
	2/19/20 11:20	241.09	28.21	8.09	13.52	185.04	1165.37
	2/19/20 11:21	241.09	28.21	8.07	13.52	185.08	1165.38
	2/19/20 11:22	241.10	28.21	8.05	13.52	185.11	1165.38
	2/19/20 11:23	241.10	28.21	8.03	13.52	185.14	1165.39
	2/19/20 11:24	241.11	28.21	8.01	13.52	185.17	1165.40
	2/19/20 11:25	241.12	28.21	7.99	13.52	185.20	1165.41
	2/19/20 11:26	241.12	28.21	7.97	13.51	185.23	1165.42
	2/19/20 11:27	241.13	28.21	7.95	13.51	185.26	1165.43
	2/19/20 11:28	241.13	28.21	7.93	13.51	185.29	1165.44
	2/19/20 11:29	241.14	28.21	7.91	13.51	185.32	1165.45
	2/19/20 11:30	241.14	28.21	7.89	13.51	185.35	1165.46
	2/19/20 11:31	241.15	28.21	7.87	13.51	185.38	1165.46
	2/19/20 11:32	241.15	28.21	7.85	13.51	185.41	1165.47
	2/19/20 11:33	241.16	28.22	7.83	13.51	185.44	1165.48
	2/19/20 11:34	241.16	28.22	7.81	13.51	185.47	1165.49
	2/19/20 11:35	241.17	28.22	7.79	13.51	185.50	1165.50
	2/19/20 11:36	241.17	28.22	7.77	13.51	185.53	1165.51
	2/19/20 11:37	241.18	28.22	7.75	13.51	185.56	1165.52
	2/19/20 11:38	241.18	28.22	7.73	13.51	185.59	1165.53
	2/19/20 11:39	241.19	28.22	7.71	13.51	185.62	1165.54
	2/19/20 11:40	241.19	28.22	7.69	13.51	185.65	1165.55
	2/19/20 11:41	241.20	28.22	7.67	13.51	185.68	1165.55
	2/19/20 11:42	241.21	28.22	7.65	13.51	185.71	1165.56
	2/19/20 11:43	241.21	28.22	7.63	13.51	185.74	1165.57
	2/19/20 11:44	241.22	28.22	7.61	13.51	185.77	1165.58
	2/19/20 11:45	241.22	28.22	7.59	13.51	185.80	1165.59
	2/19/20 11:46	241.23	28.22	7.57	13.51	185.83	1165.60
	2/19/20 11:47	241.23	28.22	7.55	13.51	185.86	1165.61
	2/19/20 11:48	241.24	28.22	7.53	13.50	185.89	1165.62
	2/19/20 11:49	241.24	28.22	7.51	13.50	185.92	1165.63
	2/19/20 11:50	241.25	28.23	7.49	13.50	185.95	1165.63
	2/19/20 11:51	241.25	28.23	7.47	13.50	185.99	1165.64
	2/19/20 11:52	241.26	28.23	7.45	13.50	186.02	1165.65
	2/19/20 11:53	241.26	28.23	7.43	13.50	186.05	1165.66
	2/19/20 11:54	241.27	28.23	7.41	13.50	186.08	1165.67
	2/19/20 11:55	241.27	28.23	7.39	13.50	186.11	1165.68
	2/19/20 11:56	241.28	28.23	7.37	13.50	186.14	1165.69
	2/19/20 11:57	241.28	28.23	7.35	13.50	186.17	1165.70
	2/19/20 11:58	241.29	28.23	7.33	13.50	186.20	1165.71
	2/19/20 11:59	241.30	28.23	7.31	13.50	186.23	1165.71
	2/19/20 12:00	241.30	28.23	7.29	13.50	186.26	1165.72

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 12:2 - 2/19 13:2)		241.47	28.25	6.65	13.49	187.23	1166.01
COUNT = 61							
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
	2/19/20 12:02	241.31	28.23	7.25	13.50	186.32	1165.74
	2/19/20 12:03	241.32	28.23	7.23	13.50	186.35	1165.75
	2/19/20 12:04	241.32	28.23	7.21	13.50	186.38	1165.76
	2/19/20 12:05	241.33	28.23	7.19	13.50	186.41	1165.77
	2/19/20 12:06	241.33	28.24	7.17	13.50	186.44	1165.78
	2/19/20 12:07	241.34	28.24	7.15	13.50	186.47	1165.79
	2/19/20 12:08	241.34	28.24	7.13	13.50	186.50	1165.79
	2/19/20 12:09	241.35	28.24	7.11	13.50	186.53	1165.80
	2/19/20 12:10	241.35	28.24	7.09	13.49	186.56	1165.81
	2/19/20 12:11	241.36	28.24	7.07	13.49	186.59	1165.82
	2/19/20 12:12	241.36	28.24	7.05	13.49	186.62	1165.83
	2/19/20 12:13	241.37	28.24	7.03	13.49	186.65	1165.84
	2/19/20 12:14	241.37	28.24	7.01	13.49	186.68	1165.85
	2/19/20 12:15	241.38	28.24	6.99	13.49	186.71	1165.86
	2/19/20 12:16	241.38	28.24	6.97	13.49	186.74	1165.87
	2/19/20 12:17	241.39	28.24	6.95	13.49	186.77	1165.88
	2/19/20 12:18	241.40	28.24	6.93	13.49	186.80	1165.88
	2/19/20 12:19	241.40	28.24	6.91	13.49	186.83	1165.89
	2/19/20 12:20	241.41	28.24	6.89	13.49	186.86	1165.90
	2/19/20 12:21	241.41	28.24	6.87	13.49	186.90	1165.91
	2/19/20 12:22	241.42	28.24	6.85	13.49	186.93	1165.92
	2/19/20 12:23	241.42	28.25	6.83	13.49	186.96	1165.93
	2/19/20 12:24	241.43	28.25	6.81	13.49	186.99	1165.94
	2/19/20 12:25	241.43	28.25	6.79	13.49	187.02	1165.95
	2/19/20 12:26	241.44	28.25	6.77	13.49	187.05	1165.96
	2/19/20 12:27	241.44	28.25	6.75	13.49	187.08	1165.96
	2/19/20 12:28	241.45	28.25	6.73	13.49	187.11	1165.97
	2/19/20 12:29	241.45	28.25	6.71	13.49	187.14	1165.98
	2/19/20 12:30	241.46	28.25	6.69	13.49	187.17	1165.99
	2/19/20 12:31	241.46	28.25	6.67	13.49	187.20	1166.00
	2/19/20 12:32	241.47	28.25	6.65	13.49	187.23	1166.01
	2/19/20 12:33	241.47	28.25	6.63	13.48	187.26	1166.02
	2/19/20 12:34	241.48	28.25	6.61	13.48	187.29	1166.03
	2/19/20 12:35	241.49	28.25	6.59	13.48	187.32	1166.04
	2/19/20 12:36	241.49	28.25	6.57	13.48	187.35	1166.04
	2/19/20 12:37	241.50	28.25	6.55	13.48	187.38	1166.05
	2/19/20 12:38	241.50	28.25	6.53	13.48	187.41	1166.06
	2/19/20 12:39	241.51	28.25	6.51	13.48	187.44	1166.07
	2/19/20 12:40	241.51	28.26	6.49	13.48	187.47	1166.08
	2/19/20 12:41	241.52	28.26	6.47	13.48	187.50	1166.09
	2/19/20 12:42	241.52	28.26	6.45	13.48	187.53	1166.10
	2/19/20 12:43	241.53	28.26	6.43	13.48	187.56	1166.11
	2/19/20 12:44	241.53	28.26	6.41	13.48	187.59	1166.12
	2/19/20 12:45	241.54	28.26	6.39	13.48	187.62	1166.12
	2/19/20 12:46	241.54	28.26	6.37	13.48	187.65	1166.13
	2/19/20 12:47	241.55	28.26	6.35	13.48	187.68	1166.14
	2/19/20 12:48	241.55	28.26	6.33	13.48	187.71	1166.15
	2/19/20 12:49	241.56	28.26	6.31	13.48	187.74	1166.16
	2/19/20 12:50	241.56	28.26	6.29	13.48	187.77	1166.17
	2/19/20 12:51	241.57	28.26	6.27	13.48	187.81	1166.18
	2/19/20 12:52	241.58	28.26	6.25	13.48	187.84	1166.19
	2/19/20 12:53	241.58	28.26	6.23	13.48	187.87	1166.20
	2/19/20 12:54	241.59	28.26	6.21	13.48	187.90	1166.21
	2/19/20 12:55	241.59	28.26	6.19	13.47	187.93	1166.21
	2/19/20 12:56	241.60	28.26	6.17	13.47	187.96	1166.22
	2/19/20 12:57	241.60	28.27	6.15	13.47	187.99	1166.23
	2/19/20 12:58	241.61	28.27	6.13	13.47	188.02	1166.24
	2/19/20 12:59	241.61	28.27	6.11	13.47	188.05	1166.25
	2/19/20 13:00	241.62	28.27	6.09	13.47	188.08	1166.26
	2/19/20 13:01	241.62	28.27	6.07	13.47	188.11	1166.27
	2/19/20 13:02	241.63	28.27	6.05	13.47	188.14	1166.28

Description	CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s
AVERAGE (2/19 13:4 - 2/19 14:2)	241.79	28.29	5.43	13.46	189.08	1166.55
COUNT = 59						

Signal Tagname	G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH
2/19/20 13:04	241.64	28.27	6.01	13.47	188.20	1166.29
2/19/20 13:05	241.64	28.27	5.99	13.47	188.23	1166.30
2/19/20 13:06	241.65	28.27	5.97	13.47	188.26	1166.31
2/19/20 13:07	241.65	28.27	5.95	13.47	188.29	1166.32
2/19/20 13:08	241.66	28.27	5.93	13.47	188.32	1166.33
2/19/20 13:09	241.67	28.27	5.91	13.47	188.35	1166.34
2/19/20 13:10	241.67	28.27	5.89	13.47	188.38	1166.35
2/19/20 13:11	241.68	28.27	5.87	13.47	188.41	1166.36
2/19/20 13:12	241.68	28.27	5.85	13.47	188.44	1166.37
2/19/20 13:13	241.69	28.28	5.83	13.47	188.47	1166.37
2/19/20 13:14	241.69	28.28	5.81	13.47	188.50	1166.38
2/19/20 13:15	241.70	28.28	5.79	13.47	188.53	1166.39
2/19/20 13:16	241.70	28.28	5.77	13.47	188.56	1166.40
2/19/20 13:17	241.71	28.28	5.75	13.46	188.59	1166.41
2/19/20 13:18	241.71	28.28	5.73	13.46	188.62	1166.42
2/19/20 13:19	241.72	28.28	5.71	13.46	188.65	1166.43
2/19/20 13:20	241.72	28.28	5.69	13.46	188.68	1166.44
2/19/20 13:21	241.73	28.28	5.67	13.46	188.72	1166.45
2/19/20 13:22	241.73	28.28	5.65	13.46	188.75	1166.45
2/19/20 13:23	241.74	28.28	5.63	13.46	188.78	1166.46
2/19/20 13:24	241.74	28.28	5.61	13.46	188.81	1166.47
2/19/20 13:25	241.75	28.28	5.59	13.46	188.84	1166.48
2/19/20 13:26	241.76	28.28	5.57	13.46	188.87	1166.49
2/19/20 13:27	241.76	28.28	5.55	13.46	188.90	1166.50
2/19/20 13:28	241.77	28.28	5.53	13.46	188.93	1166.51
2/19/20 13:29	241.77	28.28	5.51	13.46	188.96	1166.52
2/19/20 13:30	241.78	28.29	5.49	13.46	188.99	1166.53
2/19/20 13:31	241.78	28.29	5.47	13.46	189.02	1166.54
2/19/20 13:32	241.79	28.29	5.45	13.46	189.05	1166.54
2/19/20 13:33	241.79	28.29	5.43	13.46	189.08	1166.55
2/19/20 13:34	241.80	28.29	5.41	13.46	189.11	1166.56
2/19/20 13:35	241.80	28.29	5.39	13.46	189.14	1166.57
2/19/20 13:36	241.81	28.29	5.37	13.46	189.17	1166.58
2/19/20 13:37	241.81	28.29	5.35	13.46	189.20	1166.59
2/19/20 13:38	241.82	28.29	5.33	13.46	189.23	1166.60
2/19/20 13:39	241.82	28.29	5.31	13.45	189.26	1166.61
2/19/20 13:40	241.83	28.29	5.29	13.45	189.29	1166.62
2/19/20 13:41	241.83	28.29	5.27	13.45	189.32	1166.62
2/19/20 13:42	241.84	28.29	5.25	13.45	189.35	1166.63
2/19/20 13:43	241.85	28.29	5.23	13.45	189.38	1166.64
2/19/20 13:44	241.85	28.29	5.21	13.45	189.41	1166.65
2/19/20 13:45	241.86	28.29	5.19	13.45	189.44	1166.66
2/19/20 13:46	241.86	28.29	5.17	13.45	189.47	1166.67
2/19/20 13:47	241.87	28.30	5.15	13.45	189.50	1166.68
2/19/20 13:48	241.87	28.30	5.13	13.45	189.53	1166.69
2/19/20 13:49	241.88	28.30	5.11	13.45	189.56	1166.70
2/19/20 13:50	241.88	28.30	5.09	13.45	189.59	1166.70
2/19/20 13:51	241.89	28.30	5.07	13.45	189.63	1166.71
2/19/20 13:52	241.89	28.30	5.05	13.45	189.66	1166.72
2/19/20 13:53	241.90	28.30	5.03	13.45	189.69	1166.73
2/19/20 13:54	241.90	28.30	5.01	13.45	189.72	1166.74
2/19/20 13:55	241.91	28.30	4.99	13.45	189.75	1166.75
2/19/20 13:56	241.91	28.30	4.97	13.45	189.78	1166.76
2/19/20 13:57	241.92	28.30	4.95	13.45	189.81	1166.77
2/19/20 13:58	241.92	28.30	4.93	13.45	189.84	1166.78
2/19/20 13:59	241.93	28.30	4.91	13.45	189.87	1166.79
2/19/20 14:00	241.94	28.30	4.89	13.45	189.90	1166.79
2/19/20 14:01	241.94	28.30	4.87	13.44	189.93	1166.80
2/19/20 14:02	241.95	28.30	4.85	13.44	189.96	1166.81

EMISSION DATA RECORDS

Operating Data Base+DB Load and Auxiliary Boiler (provided by Cricket Valley Energy Center LLC) Opacity

Opacity testing was pursued after the fuel gas flow meter mode of operation was corrected to Mode 1 (natural gas). No corrections necessary for measured fuel flow rate values.

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/6 12:50 - 3/6 13:50)		236.93	27.44	7.05	13.61	165.62	1154.20	1453.41
COUNT = 61								
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH	BOPC2.00SBFY061
	3/6/20 12:50	236.89	27.44	5.56	13.78	165.20	1154.52	1567.70
	3/6/20 12:51	237.12	27.52	5.61	13.58	164.59	1154.57	1610.60
	3/6/20 12:52	237.37	27.54	5.67	13.86	166.01	1155.33	1420.15
	3/6/20 12:53	237.30	27.73	5.73	13.59	168.86	1154.22	1358.27
	3/6/20 12:54	237.10	27.28	5.79	13.38	167.59	1153.74	1305.52
	3/6/20 12:55	237.35	27.22	5.85	13.65	169.52	1154.63	1275.00
	3/6/20 12:56	237.41	27.39	5.91	13.41	168.84	1155.15	1206.54
	3/6/20 12:57	237.07	27.33	5.96	13.63	169.54	1154.48	1136.69
	3/6/20 12:58	236.95	27.16	6.02	13.48	169.58	1154.03	1256.71
	3/6/20 12:59	237.00	27.32	6.08	13.74	169.50	1153.96	1318.34
	3/6/20 13:00	236.82	27.60	6.14	14.02	169.67	1153.74	1399.26
	3/6/20 13:01	237.17	27.66	6.20	13.78	169.21	1154.78	1443.68
	3/6/20 13:02	236.66	27.47	6.26	13.61	168.49	1153.96	1483.50
	3/6/20 13:03	236.61	27.53	6.31	13.53	167.11	1153.78	1462.16
	3/6/20 13:04	237.01	27.39	6.37	13.73	167.10	1154.46	1421.55
	3/6/20 13:05	236.78	27.41	6.43	13.81	167.52	1154.55	1349.85
	3/6/20 13:06	237.05	27.50	6.49	13.55	162.45	1154.14	1350.79
	3/6/20 13:07	237.02	27.52	6.55	13.62	165.83	1153.66	1335.16
	3/6/20 13:08	236.87	27.40	6.61	13.46	166.87	1153.85	1375.63
	3/6/20 13:09	237.18	27.45	6.66	13.60	166.64	1153.58	1352.80
	3/6/20 13:10	236.89	27.54	6.72	13.56	167.34	1154.63	1354.24
	3/6/20 13:11	236.97	27.20	6.78	13.54	166.16	1153.67	1371.20
	3/6/20 13:12	237.14	27.45	6.84	13.54	166.76	1153.93	1382.20
	3/6/20 13:13	236.80	27.46	6.90	13.56	167.28	1153.87	1357.03
	3/6/20 13:14	236.71	27.44	6.96	13.58	164.13	1155.11	1366.82
	3/6/20 13:15	236.84	27.49	7.01	13.49	163.65	1154.00	1372.85
	3/6/20 13:16	237.07	27.39	7.07	13.62	165.18	1154.57	1343.49
	3/6/20 13:17	237.04	27.56	7.13	13.99	164.63	1154.83	1374.69
	3/6/20 13:18	236.88	27.55	7.19	13.99	163.88	1155.03	1368.06
	3/6/20 13:19	236.59	27.59	7.25	13.66	161.01	1154.23	1344.18
	3/6/20 13:20	236.70	27.56	7.31	13.59	161.28	1154.39	1363.85
	3/6/20 13:21	236.95	27.56	7.36	13.67	164.57	1154.45	1464.87
	3/6/20 13:22	237.12	27.25	7.42	13.75	165.10	1154.20	1493.21
	3/6/20 13:23	236.67	27.34	7.48	13.61	162.53	1153.25	1544.09
	3/6/20 13:24	236.63	27.28	7.54	13.61	164.94	1154.55	1578.78
	3/6/20 13:25	236.93	27.48	7.60	13.71	163.05	1154.33	1542.49
	3/6/20 13:26	236.79	27.32	7.66	13.20	165.72	1153.65	1562.23
	3/6/20 13:27	236.74	27.51	7.71	13.67	166.53	1154.17	1551.00
	3/6/20 13:28	236.73	27.40	7.73	13.54	164.63	1153.39	1567.78
	3/6/20 13:29	237.16	27.43	7.73	13.52	166.03	1153.31	1552.55
	3/6/20 13:30	237.33	27.47	7.73	13.74	167.06	1154.60	1517.80
	3/6/20 13:31	236.57	27.41	7.73	13.77	167.80	1153.66	1518.78
	3/6/20 13:32	237.01	27.50	7.73	13.77	167.08	1154.99	1570.09
	3/6/20 13:33	236.64	27.33	7.73	13.70	167.41	1153.68	1526.05
	3/6/20 13:34	237.23	27.38	7.73	13.38	162.35	1154.69	1527.35
	3/6/20 13:35	237.17	27.44	7.73	13.80	166.83	1153.82	1558.37
	3/6/20 13:36	236.84	27.30	7.73	13.48	163.46	1154.57	1547.52
	3/6/20 13:37	236.80	27.59	7.73	13.48	165.69	1154.05	1563.25
	3/6/20 13:38	236.70	27.47	7.73	13.61	164.12	1154.12	1526.21
	3/6/20 13:39	236.71	27.48	7.73	13.41	162.57	1154.32	1532.59
	3/6/20 13:40	236.77	27.45	7.73	13.64	163.57	1153.88	1561.51
	3/6/20 13:41	237.05	27.52	7.73	13.51	161.50	1155.18	1530.66
	3/6/20 13:42	236.73	27.40	7.73	13.52	162.05	1154.11	1564.81
	3/6/20 13:43	236.93	27.36	7.73	13.52	161.21	1154.31	1526.04
	3/6/20 13:44	237.04	27.44	7.73	13.59	163.97	1154.50	1548.29
	3/6/20 13:45	236.71	27.35	7.73	13.53	164.56	1153.42	1565.93
	3/6/20 13:46	236.90	27.63	7.73	13.65	164.62	1154.87	1528.97
	3/6/20 13:47	236.82	27.55	7.72	13.46	162.04	1153.96	1555.57
	3/6/20 13:48	236.62	27.40	7.72	13.53	167.83	1153.04	1525.03
	3/6/20 13:49	236.81	27.47	7.72	13.56	165.54	1153.28	1521.90
	3/6/20 13:50	237.13	27.41	7.72	13.44	166.85	1154.75	1556.00

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/6 13:50 - 3/6 14:50)		236.02	27.36	7.71	13.63	161.06	1153.84	1552.31
COUNT = 61								
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH	BOPC2.00SBFY061
	3/6/20 13:50	237.13	27.41	7.72	13.44	166.85	1154.75	1556.00
	3/6/20 13:51	237.01	27.31	7.72	13.56	164.34	1154.13	1558.38
	3/6/20 13:52	236.89	27.50	7.72	13.56	167.52	1153.35	1587.38
	3/6/20 13:53	236.73	27.53	7.72	13.64	167.07	1153.28	1535.65
	3/6/20 13:54	237.24	27.26	7.72	14.14	167.23	1154.32	1572.04
	3/6/20 13:55	236.97	27.41	7.72	13.55	166.83	1154.43	1534.44
	3/6/20 13:56	236.63	27.35	7.72	13.52	166.85	1152.59	1562.48
	3/6/20 13:57	236.91	27.55	7.72	13.77	167.84	1153.73	1549.45
	3/6/20 13:58	236.66	27.31	7.72	13.55	169.63	1153.87	1537.73
	3/6/20 13:59	236.50	27.28	7.72	13.59	167.36	1153.44	1538.19
	3/6/20 14:00	237.19	27.55	7.72	13.48	167.38	1153.93	1560.38
	3/6/20 14:01	236.88	27.46	7.72	13.72	167.69	1153.76	1545.39
	3/6/20 14:02	236.57	27.34	7.72	13.63	166.18	1153.13	1553.82
	3/6/20 14:03	236.58	27.45	7.72	13.53	164.07	1153.28	1543.44
	3/6/20 14:04	236.66	27.47	7.72	13.51	167.01	1153.47	1558.18
	3/6/20 14:05	236.95	27.38	7.71	13.50	166.26	1153.46	1541.24
	3/6/20 14:06	236.39	27.64	7.71	13.65	165.16	1153.09	1564.89
	3/6/20 14:07	236.18	27.33	7.71	13.55	163.32	1152.61	1527.62
	3/6/20 14:08	236.72	27.29	7.71	13.66	162.27	1153.50	1556.46
	3/6/20 14:09	236.54	27.37	7.71	13.54	162.19	1153.45	1542.90
	3/6/20 14:10	236.39	27.35	7.71	13.53	161.25	1152.74	1563.22
	3/6/20 14:11	236.69	27.45	7.71	13.61	164.12	1153.21	1548.86
	3/6/20 14:12	236.61	27.27	7.71	13.54	166.34	1153.11	1584.11
	3/6/20 14:13	236.50	27.50	7.71	13.59	166.35	1153.04	1538.08
	3/6/20 14:14	236.83	27.35	7.71	13.86	164.94	1153.81	1555.70
	3/6/20 14:15	236.51	27.65	7.71	13.37	167.39	1153.37	1551.40
	3/6/20 14:16	236.57	27.47	7.71	13.59	162.84	1153.97	1522.72
	3/6/20 14:17	236.67	27.33	7.71	13.55	164.47	1153.63	1564.93
	3/6/20 14:18	236.46	27.35	7.71	13.59	163.09	1153.25	1585.72
	3/6/20 14:19	236.77	27.32	7.71	13.72	165.14	1154.13	1531.74
	3/6/20 14:20	236.29	27.41	7.71	13.73	160.83	1152.93	1564.06
	3/6/20 14:21	236.75	27.28	7.71	13.95	163.97	1153.23	1554.78
	3/6/20 14:22	236.57	27.42	7.71	13.72	163.88	1152.58	1557.39
	3/6/20 14:23	236.52	27.38	7.71	13.60	163.06	1152.64	1545.52
	3/6/20 14:24	236.24	27.49	7.70	13.73	162.02	1153.51	1558.09
	3/6/20 14:25	236.44	27.58	7.70	13.43	163.94	1151.88	1576.93
	3/6/20 14:26	236.50	27.29	7.70	13.17	165.03	1152.84	1528.05
	3/6/20 14:27	231.82	26.95	7.70	13.61	161.76	1153.41	1551.65
	3/6/20 14:28	229.75	26.56	7.70	13.13	144.15	1144.10	1560.85
	3/6/20 14:29	231.08	26.92	7.70	14.05	147.81	1153.31	1532.29
	3/6/20 14:30	231.86	26.91	7.70	13.65	143.47	1155.52	1537.03
	3/6/20 14:31	233.20	27.01	7.70	13.88	140.04	1160.74	1574.25
	3/6/20 14:32	233.81	27.10	7.70	14.09	138.82	1160.48	1545.90
	3/6/20 14:33	233.59	27.16	7.70	13.81	131.34	1159.66	1551.29
	3/6/20 14:34	233.92	27.16	7.70	13.85	124.02	1159.80	1567.05
	3/6/20 14:35	233.47	27.13	7.70	13.82	119.46	1160.11	1526.58
	3/6/20 14:36	236.69	27.46	7.70	13.50	114.66	1157.24	1547.96
	3/6/20 14:37	236.32	27.31	7.70	13.36	128.96	1152.84	1560.77
	3/6/20 14:38	236.31	27.14	7.70	13.97	155.70	1152.99	1551.48
	3/6/20 14:39	236.41	27.49	7.70	13.43	169.36	1153.44	1570.94
	3/6/20 14:40	236.64	27.41	7.70	13.62	171.05	1153.97	1560.03
	3/6/20 14:41	236.55	27.45	7.70	13.65	171.11	1152.88	1530.95
	3/6/20 14:42	237.05	27.44	7.70	13.61	174.78	1153.48	1569.82
	3/6/20 14:43	236.41	27.51	7.69	13.66	174.40	1153.14	1542.69
	3/6/20 14:44	236.60	27.65	7.69	13.65	178.04	1153.45	1548.10
	3/6/20 14:45	236.45	27.27	7.69	13.54	175.11	1152.92	1562.57
	3/6/20 14:46	236.61	27.51	7.69	13.80	176.99	1153.10	1536.38
	3/6/20 14:47	236.27	27.42	7.69	13.42	171.17	1152.95	1555.83
	3/6/20 14:48	236.64	27.53	7.69	13.55	167.87	1152.73	1572.11
	3/6/20 14:49	236.52	27.66	7.69	13.53	165.69	1152.80	1527.46
	3/6/20 14:50	236.38	27.56	7.69	13.57	166.92	1153.69	1549.50

Description		CTG1 Gross output	CT1 gas flow	U1 duct burner gas flow	HRSG1 duct inlet pressure	SCR NH3 flow rate	CT1 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/6 14:50 - 3/6 15:50)		236.24	27.41	7.67	13.60	163.97	1152.59	1408.50
COUNT = 61								
Signal Tagname		G1.DWATT	G1.FQG	H1.SF_DctBrnrGas FuelMassFlw	H1.01BAPT001	H1.01BSFIT500	G1.WEXH	BOPC2.00SBFY061
	3/6/20 14:50	236.38	27.56	7.69	13.57	166.92	1153.69	1549.50
	3/6/20 14:51	236.46	27.42	7.69	13.63	162.27	1152.89	1556.75
	3/6/20 14:52	236.77	27.32	7.69	13.54	160.00	1153.65	1563.14
	3/6/20 14:53	236.66	27.51	7.69	13.91	158.33	1153.23	1556.22
	3/6/20 14:54	236.59	27.43	7.69	13.47	160.33	1153.13	1559.53
	3/6/20 14:55	236.98	27.40	7.69	13.57	164.29	1154.13	1559.07
	3/6/20 14:56	236.41	27.53	7.69	13.54	165.24	1152.88	1567.61
	3/6/20 14:57	236.49	27.43	7.69	13.69	162.70	1152.37	1537.82
	3/6/20 14:58	233.64	27.05	7.69	13.46	168.14	1154.35	1551.96
	3/6/20 14:59	229.26	26.50	7.69	13.45	146.73	1145.34	1566.19
	3/6/20 15:00	236.41	27.68	7.69	13.41	149.94	1152.67	1507.21
	3/6/20 15:01	236.42	27.30	7.68	13.55	152.18	1152.85	1410.43
	3/6/20 15:02	236.41	27.55	7.68	13.64	153.48	1152.95	1406.53
	3/6/20 15:03	236.58	27.39	7.68	13.55	155.23	1152.99	1388.63
	3/6/20 15:04	236.48	27.33	7.68	13.70	161.02	1153.03	1419.91
	3/6/20 15:05	235.86	27.31	7.68	13.29	164.95	1152.24	1390.96
	3/6/20 15:06	236.06	27.45	7.68	13.57	165.79	1152.13	1410.70
	3/6/20 15:07	236.68	27.36	7.68	13.79	170.06	1153.50	1409.81
	3/6/20 15:08	236.25	27.43	7.68	13.70	169.11	1153.15	1386.11
	3/6/20 15:09	236.71	27.51	7.68	13.61	171.59	1153.04	1396.65
	3/6/20 15:10	236.29	27.56	7.68	13.50	171.60	1152.03	1404.69
	3/6/20 15:11	236.48	27.42	7.68	13.46	171.09	1151.93	1380.56
	3/6/20 15:12	236.55	27.49	7.68	13.75	169.62	1152.90	1387.88
	3/6/20 15:13	236.36	27.57	7.68	13.82	165.53	1152.72	1386.00
	3/6/20 15:14	236.77	27.27	7.68	13.77	164.85	1153.78	1409.50
	3/6/20 15:15	236.40	27.49	7.68	13.53	165.47	1153.02	1384.22
	3/6/20 15:16	236.42	27.43	7.68	13.54	164.65	1153.05	1368.51
	3/6/20 15:17	236.81	27.32	7.68	13.75	165.35	1153.86	1395.39
	3/6/20 15:18	236.67	27.38	7.68	13.95	166.17	1153.07	1362.97
	3/6/20 15:19	236.55	27.48	7.68	13.50	165.77	1153.04	1357.44
	3/6/20 15:20	236.34	27.53	7.67	13.75	165.25	1153.02	1358.24
	3/6/20 15:21	236.57	27.36	7.67	13.62	165.96	1152.73	1386.07
	3/6/20 15:22	236.37	27.45	7.67	13.52	166.69	1153.05	1370.07
	3/6/20 15:23	236.36	27.53	7.67	13.61	162.74	1152.39	1376.30
	3/6/20 15:24	236.33	27.39	7.67	13.81	165.40	1153.05	1360.54
	3/6/20 15:25	236.71	27.42	7.67	13.43	165.03	1152.61	1383.58
	3/6/20 15:26	236.20	27.51	7.67	13.30	165.63	1152.03	1382.34
	3/6/20 15:27	236.62	27.44	7.67	13.66	165.25	1152.79	1364.12
	3/6/20 15:28	236.49	27.23	7.67	13.54	164.52	1153.05	1347.60
	3/6/20 15:29	236.44	27.43	7.67	13.97	166.18	1153.20	1357.78
	3/6/20 15:30	236.18	27.54	7.67	13.95	165.78	1152.16	1375.46
	3/6/20 15:31	236.28	27.41	7.67	13.42	165.67	1151.61	1379.78
	3/6/20 15:32	236.07	27.59	7.67	13.51	164.82	1152.86	1370.03
	3/6/20 15:33	236.16	27.23	7.67	13.75	165.08	1152.68	1358.66
	3/6/20 15:34	236.56	27.16	7.67	13.74	159.96	1152.36	1388.18
	3/6/20 15:35	236.27	27.52	7.67	13.42	160.21	1152.32	1366.79
	3/6/20 15:36	236.09	27.44	7.67	13.35	164.64	1152.08	1356.59
	3/6/20 15:37	236.23	27.35	7.67	13.83	165.19	1152.74	1363.95
	3/6/20 15:38	236.51	27.41	7.67	13.31	163.91	1152.97	1368.01
	3/6/20 15:39	236.28	27.50	7.66	13.78	164.30	1152.07	1382.92
	3/6/20 15:40	235.93	27.46	7.66	13.47	164.62	1151.72	1370.12
	3/6/20 15:41	236.53	27.42	7.66	13.85	162.20	1152.34	1368.38
	3/6/20 15:42	236.23	27.39	7.66	13.51	164.18	1152.00	1351.73
	3/6/20 15:43	236.29	27.40	7.66	13.91	165.47	1152.33	1353.79
	3/6/20 15:44	236.12	27.39	7.66	13.37	165.07	1152.80	1366.01
	3/6/20 15:45	236.47	27.49	7.66	13.55	165.40	1152.39	1362.67
	3/6/20 15:46	236.11	27.64	7.66	13.52	165.78	1151.94	1376.52
	3/6/20 15:47	236.33	27.37	7.66	13.50	162.57	1151.55	1370.18
	3/6/20 15:48	236.62	27.49	7.66	13.61	165.72	1153.06	1378.59
	3/6/20 15:49	236.25	27.36	7.66	13.54	164.80	1151.44	1341.75
	3/6/20 15:50	236.02	27.22	7.66	13.47	165.75	1150.98	1349.74

EMISSION DATA RECORDS

Reference Method Data
Base Load
NOx, CO, VOC, and NH_3

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,644	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,019	Btu/SCF fuel
Turbine Fuel Flow	1,673	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,260,589	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	41	%
Ambient Temperature	43	° F
Specific Humidity	0.002353	lb H_2O / lb air

Unit Data

Unit Load	240.4	megawatts
Heat Input	2,303	MMBtu/hr
NH_3 Flow Rate	170	lb/hr
Meas. Stack Moisture	5.8	%
Stack Exhaust Flow (M19)	51,893,455	SCFH

Data from: From PM Run PM U-00001 Base-1

Base Load, Run - 1-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/17/20 13:35:04	3500	12.90	2.59	0.04	0.59	4.84	1.52
02/17/20 13:35:34	3530	12.91	2.61	0.07	0.82	4.83	1.32
02/17/20 13:36:04	3560	12.92	2.62	0.06	0.77	4.83	1.25
02/17/20 13:36:34	3590	12.90	2.50	0.09	0.46	4.83	1.41
02/17/20 13:37:04	3620	12.92	2.50	0.00	0.04	4.83	1.41
02/17/20 13:37:34	3650	12.91	2.57	0.07	0.40	4.82	1.45
02/17/20 13:38:04	3680	12.91	2.49	0.02	0.69	4.83	1.51
02/17/20 13:38:34	3710	12.89	2.41	0.04	0.41	4.83	1.56
02/17/20 13:39:04	3740	12.91	2.36	0.03	0.87	4.82	1.68
02/17/20 13:39:34	3770	12.92	2.53	0.09	1.09	4.82	1.58
02/17/20 13:40:04	3800	12.93	2.41	0.09	1.20	4.83	1.49
02/17/20 13:40:34	3830	12.92	2.28	0.09	1.27	4.82	1.55
02/17/20 13:41:04	3860	12.93	2.33	0.09	0.60	4.83	1.63
02/17/20 13:41:34	3890	12.93	2.37	0.06	0.56	4.82	1.89
02/17/20 13:42:04	3920	12.91	2.41	0.15	0.64	4.82	1.81
02/17/20 13:42:34	3950	12.92	2.53	0.07	0.65	4.82	1.81
02/17/20 13:43:04	3980	12.93	2.64	0.09	0.71	4.82	1.75
02/17/20 13:43:34	4010	12.92	2.58	0.06	0.77	4.82	1.69
02/17/20 13:44:04	4040	12.92	2.58	0.13	0.66	4.82	1.70
02/17/20 13:44:34	4070	12.92	2.67	0.17	0.62	4.82	1.69
02/17/20 13:45:04	4100	12.90	2.60	0.06	0.71	4.82	1.61
02/17/20 13:45:34	4130	12.88	2.53	0.14	0.12	4.83	1.69
02/17/20 13:46:04	4160	12.90	2.60	0.21	0.00	4.81	1.66
02/17/20 13:46:34	4190	12.91	2.70	0.17	0.21	4.81	1.64
02/17/20 13:47:04	4220	12.92	2.52	0.16	0.34	4.82	1.63
02/17/20 13:47:34	4250	12.92	2.40	0.25	0.40	4.81	1.62
02/17/20 13:48:04	4280	12.92	2.38	0.15	0.88	4.81	1.51
02/17/20 13:48:34	4310	12.92	2.44	0.12	0.87	4.81	1.51
02/17/20 13:49:04	4340	12.90	2.46	0.15	0.59	4.81	1.20
02/17/20 13:49:34	4370	12.91	2.56	0.06	0.22	4.81	1.45
02/17/20 13:50:04	4400	12.90	2.58	0.09	0.67	4.81	1.60
02/17/20 13:50:34	4430	12.91	2.54	0.09	0.44	4.82	1.57
02/17/20 13:51:04	4460	12.86	2.68	0.26	0.49	4.81	1.39
02/17/20 13:51:34	4490	12.90	2.72	0.36	0.44	4.82	1.29
02/17/20 13:52:04	4520	12.88	2.70	0.36	0.71	4.82	1.40
02/17/20 13:52:34	4550	12.88	2.55	0.41	0.91	4.82	1.45
02/17/20 13:53:04	4580	12.90	2.62	0.40	0.98	4.82	1.27
02/17/20 13:53:34	4610	12.91	2.66	0.47	0.88	4.82	1.39
02/17/20 13:54:04	4640	12.92	2.49	0.37	0.56	4.82	1.41
02/17/20 13:54:34	4670	12.93	2.50	0.25	0.71	4.82	1.38
02/17/20 13:55:04	4700	12.90	2.48	0.28	0.18	4.82	1.41
02/17/20 13:55:34	4730	12.92	2.53	0.22	0.46	4.81	1.34
02/17/20 13:56:04	4760	12.92	2.52	0.38	0.91	4.82	1.47
02/17/20 13:56:34	4790	12.92	2.39	0.33	0.10	4.82	1.62
02/17/20 13:57:04	4820	12.93	2.31	0.30	0.18	4.81	1.83
02/17/20 13:57:34	4850	12.92	2.33	0.33	0.60	4.82	1.55
02/17/20 13:58:04	4880	12.92	2.32	0.38	0.69	4.81	1.55
02/17/20 13:58:34	4910	12.92	2.32	0.25	0.87	4.81	1.80
02/17/20 13:59:04	4940	12.93	2.39	0.29	0.63	4.81	1.87
02/17/20 13:59:34	4970	12.85	2.49	0.36	0.70	4.81	2.03
02/17/20 14:00:04	5000	12.88	2.72	0.33	0.70	4.82	2.00
02/17/20 14:00:34	5030	12.89	2.95	0.32	0.55	4.81	2.05
02/17/20 14:01:04	5060	12.90	2.95	0.51	0.64	4.81	2.23
02/17/20 14:01:34	5090	12.89	2.89	0.59	0.70	4.81	2.40
02/17/20 14:02:04	5120	12.91	2.72	0.62	0.78	4.81	2.10
02/17/20 14:02:34	5150	12.90	2.48	0.50	0.73	4.81	2.15
02/17/20 14:03:04	5180	12.90	2.27	0.51	0.64	4.81	2.29
02/17/20 14:03:34	5210	12.88	2.34	0.45	0.18	4.81	2.08
02/17/20 14:04:04	5240	12.89	2.44	0.32	0.48	4.80	1.87
02/17/20 14:04:34	5270	12.89	2.50	0.35	0.74	4.81	1.56
02/17/20 14:05:04	5300	12.89	2.52	0.39	0.75	4.81	1.64
02/17/20 14:05:34	5330	12.89	2.61	0.42	0.55	4.81	1.62
02/17/20 14:06:04	5360	12.90	2.71	0.32	0.50	4.81	1.63
02/17/20 14:06:34	5390	12.91	2.65	0.29	0.42	4.81	1.62
02/17/20 14:07:04	5420	12.92	2.50	0.28	0.04	4.81	1.48
02/17/20 14:07:34	5450	12.92	2.43	0.25	0.28	4.80	1.45
02/17/20 14:08:04	5480	12.91	2.36	0.30	0.73	4.81	1.41
02/17/20 14:08:34	5510	12.93	2.33	0.38	0.57	4.81	1.38
02/17/20 14:09:04	5540	12.88	2.32	0.36	0.57	4.81	1.31
02/17/20 14:09:34	5570	12.90	2.40	0.39	0.63	4.81	1.36
02/17/20 14:10:04	5600	12.92	2.44	0.41	0.98	4.81	1.45
02/17/20 14:10:34	5630	12.88	2.36	0.42	0.82	4.81	1.45
02/17/20 14:11:04	5660	12.89	2.37	0.37	0.56	4.81	1.44
02/17/20 14:11:34	5690	12.90	2.47	0.32	0.44	4.81	1.42

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,644	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,019	Btu/SCF fuel
Turbine Fuel Flow	1,673	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,260,589	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	41	%
Ambient Temperature	43	° F
Specific Humidity	0.002353	lb H_2O / lb air

Unit Data

Unit Load	240.4	megawatts
Heat Input	2,303	MMBtu/hr
NH_3 Flow Rate	170	lb/hr
Meas. Stack Moisture	5.8	%
Stack Exhaust Flow (M19)	51,893,455	SCFH

Data from: From PM Run PM U-00001 Base-1

Base Load, Run - 1-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/17/20 14:12:04	5720	12.90	2.47	0.29	0.62	4.81	1.49
02/17/20 14:12:34	5750	12.91	2.52	0.29	0.79	4.81	1.50
02/17/20 14:13:04	5780	12.91	2.53	0.24	0.82	4.81	1.48
02/17/20 14:13:34	5810	12.92	2.58	0.39	0.42	4.82	1.89
02/17/20 14:14:04	5840	12.92	2.59	0.37	0.55	4.81	1.64
02/17/20 14:14:34	5870	12.91	2.56	0.33	0.62	4.82	1.57
02/17/20 14:15:04	5900	12.93	2.53	0.45	0.72	4.81	1.67
02/17/20 14:15:34	5930	12.93	2.46	0.37	0.76	4.82	1.77
02/17/20 14:16:04	5960	12.94	2.37	0.42	0.53	4.81	1.87
02/17/20 14:16:34	5990	12.93	2.31	0.43	0.60	4.81	1.82
02/17/20 14:17:04	6020	12.92	2.30	0.48	0.74	4.81	1.86
02/17/20 14:17:34	6050	12.92	2.26	0.50	0.85	4.82	1.85
02/17/20 14:18:04	6080	12.92	2.31	0.41	0.13	4.82	1.87
02/17/20 14:18:34	6110	12.93	2.29	0.41	0.39	4.81	1.88
02/17/20 14:19:04	6140	12.93	2.27	0.38	0.50	4.81	1.80
02/17/20 14:19:34	6170	12.94	2.33	0.44	0.58	4.81	1.68
02/17/20 14:20:04	6200	12.94	2.39	0.48	0.18	4.82	1.65
02/17/20 14:20:34	6230	12.92	2.47	0.48	0.34	4.81	1.64
02/17/20 14:21:04	6260	12.90	2.54	0.49	0.56	4.81	1.70
02/17/20 14:21:34	6290	12.92	2.61	0.44	0.70	4.82	1.56
02/17/20 14:22:04	6320	12.93	2.69	0.42	0.35	4.82	1.59
02/17/20 14:22:34	6350	12.90	2.67	0.38	0.49	4.81	1.17
02/17/20 14:23:04	6380	12.93	2.65	0.44	0.52	4.81	1.34
02/17/20 14:23:34	6410	12.92	2.60	0.49	0.73	4.82	1.44
02/17/20 14:24:04	6440	12.93	2.52	0.40	0.63	4.82	1.43
02/17/20 14:24:34	6470	12.93	2.43	0.38	0.45	4.82	1.42
02/17/20 14:25:04	6500	12.92	2.36	0.34	0.27	4.82	1.20
02/17/20 14:25:34	6530	12.92	2.34	0.35	0.29	4.81	1.22
02/17/20 14:26:04	6560	12.94	2.29	0.42	0.00	4.82	1.29
02/17/20 14:26:34	6590	12.94	2.27	0.45	0.27	4.81	1.37
02/17/20 14:27:04	6620	12.93	2.23	0.55	0.57	4.82	1.36
02/17/20 14:27:34	6650	12.93	2.21	0.46	0.23	4.82	1.40
02/17/20 14:28:04	6680	12.92	2.28	0.41	0.47	4.81	1.30
02/17/20 14:28:34	6710	12.93	2.35	0.36	0.69	4.82	1.45
02/17/20 14:29:04	6740	12.94	2.41	0.27	0.01	4.82	1.35
02/17/20 14:29:34	6770	12.94	2.45	0.41	0.08	4.81	1.57
02/17/20 14:30:04	6800	12.94	2.54	0.47	0.31	4.81	1.54
02/17/20 14:30:34	6830	12.95	2.54	0.49	0.45	4.81	1.51
02/17/20 14:31:04	6860	12.95	2.48	0.56	0.31	4.81	1.56
02/17/20 14:31:34	6890	12.95	2.48	0.44	0.23	4.81	1.74
02/17/20 14:32:04	6920	12.92	2.47	0.48	0.02	4.82	1.45
02/17/20 14:32:34	6950	12.94	2.45	0.55	0.05	4.81	1.40
02/17/20 14:33:04	6980	12.93	2.47	0.49	0.12	4.81	1.72
02/17/20 14:33:34	7010	12.95	2.40	0.48	0.31	4.81	1.78
02/17/20 14:34:04	7040	12.91	2.36	0.45	0.44	4.81	1.89
02/17/20 14:34:34	7070	12.94	2.32	0.50	0.62	4.81	1.55
RAW AVERAGE		**12.91**	**2.48**	**0.32**	**0.54**	**4.82**	**1.60**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0014	inst-nx-0020	inst-co-0045	inst-th-0010	inst-c2-0023	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.03	0.01	0.00	0.01	0.00	
Bias	**Final Zero**	0.10	0.02	0.01	0.01	0.03	
Bias	**Avg. Zero**	0.07	0.02	0.01	0.01	0.02	
Bias	**Initial UpScale**	11.99	8.91	9.08	3.29	8.94	
Bias	**Final UpScale**	12.10	9.06	9.15	3.30	8.91	
Bias	**Avg. UpScale**	12.05	8.99	9.12	3.30	8.93	
Upscale Cal Gas		12.01	8.90	9.10	3.37	8.95	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	12.88	2.45	0.31	0.57	4.82	1.69
Concentration (ppm@ 15%O_2)	N/A	1.80	0.23	0.42	N/A	1.25

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,644	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,019	Btu/SCF fuel
Turbine Fuel Flow	1,673	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,261,296	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	40	%
Ambient Temperature	43	° F
Specific Humidity	0.002295	lb H_2O / lb air

Unit Data

Unit Load	240.4	megawatts
Heat Input	2,304	MMBtu/hr
NH_3 Flow Rate	165	lb/hr
Meas. Stack Moisture	5.8	%
Stack Exhaust Flow (M19)	51,868,559	SCFH

Data from: From PM Run PM U-00001 Base-1

Base Load, Run - 1-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/17/20 14:50:04	800	12.96	2.40	0.48	0.79	4.81	0.90
02/17/20 14:50:34	830	12.96	2.38	0.47	0.77	4.82	1.21
02/17/20 14:51:04	860	12.96	2.34	0.46	0.71	4.82	1.37
02/17/20 14:51:34	890	12.96	2.36	0.36	0.72	4.82	1.36
02/17/20 14:52:04	920	12.92	2.39	0.23	0.26	4.82	1.58
02/17/20 14:52:34	950	12.96	2.44	0.26	0.24	4.81	1.28
02/17/20 14:53:04	980	12.91	2.46	0.25	0.05	4.82	1.60
02/17/20 14:53:34	1010	12.94	2.49	0.25	0.18	4.81	1.09
02/17/20 14:54:04	1040	12.95	2.48	0.41	0.62	4.82	1.59
02/17/20 14:54:34	1070	12.92	2.47	0.44	0.36	4.82	1.42
02/17/20 14:55:04	1100	12.94	2.47	0.41	0.17	4.81	1.16
02/17/20 14:55:34	1130	12.95	2.48	0.41	0.46	4.82	1.03
02/17/20 14:56:04	1160	12.95	2.44	0.50	0.79	4.82	0.91
02/17/20 14:56:34	1190	12.96	2.45	0.40	0.79	4.81	0.82
02/17/20 14:57:04	1220	12.96	2.45	0.52	0.66	4.81	0.77
02/17/20 14:57:34	1250	12.96	2.45	0.54	0.66	4.81	0.86
02/17/20 14:58:04	1280	12.96	2.40	0.54	0.51	4.81	0.83
02/17/20 14:58:34	1310	12.96	2.37	0.52	0.57	4.81	0.84
02/17/20 14:59:04	1340	12.95	2.34	0.56	0.23	4.82	0.82
02/17/20 14:59:34	1370	12.94	2.30	0.60	0.09	4.81	0.68
02/17/20 15:00:04	1400	12.95	2.27	0.51	0.24	4.81	0.74
02/17/20 15:00:34	1430	12.95	2.25	0.48	0.52	4.81	0.87
02/17/20 15:01:04	1460	12.93	2.30	0.53	0.20	4.82	0.71
02/17/20 15:01:34	1490	12.95	2.35	0.41	0.18	4.81	0.66
02/17/20 15:02:04	1520	12.94	2.45	0.48	0.31	4.81	0.66
02/17/20 15:02:34	1550	12.95	2.52	0.40	0.50	4.82	0.72
02/17/20 15:03:04	1580	12.95	2.56	0.35	0.59	4.82	0.70
02/17/20 15:03:34	1610	12.96	2.53	0.37	0.60	4.82	0.73
02/17/20 15:04:04	1640	12.96	2.50	0.33	0.47	4.82	0.65
02/17/20 15:04:34	1670	12.96	2.55	0.20	0.53	4.82	0.70
02/17/20 15:05:04	1700	12.93	2.53	0.33	0.07	4.82	0.73
02/17/20 15:05:34	1730	12.95	2.48	0.34	0.26	4.81	0.70
02/17/20 15:06:04	1760	12.95	2.46	0.37	0.46	4.82	0.68
02/17/20 15:06:34	1790	12.94	2.46	0.46	0.36	4.81	0.66
02/17/20 15:07:04	1820	12.95	2.44	0.44	0.41	4.82	0.67
02/17/20 15:07:34	1850	12.96	2.39	0.47	0.61	4.82	0.60
02/17/20 15:08:04	1880	12.93	2.31	0.51	0.29	4.81	0.63
02/17/20 15:08:34	1910	12.95	2.26	0.56	0.45	4.81	0.59
02/17/20 15:09:04	1940	12.95	2.22	0.39	0.52	4.81	0.61
02/17/20 15:09:34	1970	12.94	2.18	0.37	0.49	4.81	0.57
02/17/20 15:10:04	2000	12.95	2.21	0.37	0.28	4.81	0.58
02/17/20 15:10:34	2030	12.95	2.30	0.42	0.33	4.82	0.58
02/17/20 15:11:04	2060	12.96	2.35	0.37	0.55	4.82	0.71
02/17/20 15:11:34	2090	12.91	2.41	0.43	0.15	4.82	0.96
02/17/20 15:12:04	2120	12.93	2.51	0.40	0.06	4.82	1.05
02/17/20 15:12:34	2150	12.94	2.61	0.49	0.46	4.81	0.95
02/17/20 15:13:04	2180	12.94	2.63	0.38	0.62	4.81	0.97
02/17/20 15:13:34	2210	12.95	2.64	0.40	0.56	4.81	1.20
02/17/20 15:14:04	2240	12.95	2.61	0.34	0.57	4.81	1.07
02/17/20 15:14:34	2270	12.96	2.59	0.40	0.70	4.81	0.81
02/17/20 15:15:04	2300	12.93	2.60	0.44	0.20	4.81	1.37
02/17/20 15:15:34	2330	12.96	2.49	0.40	0.42	4.81	1.49
02/17/20 15:16:04	2360	12.91	2.35	0.47	0.04	4.81	1.69
02/17/20 15:16:34	2390	12.92	2.27	0.37	0.16	4.81	1.64
02/17/20 15:17:04	2420	12.94	2.22	0.38	0.29	4.81	1.58
02/17/20 15:17:34	2450	12.95	2.16	0.42	0.48	4.81	1.43
02/17/20 15:18:04	2480	12.95	2.20	0.27	0.51	4.82	1.66
02/17/20 15:18:34	2510	12.94	2.24	0.32	0.28	4.81	1.04
02/17/20 15:19:04	2540	12.95	2.28	0.31	0.28	4.81	1.49
02/17/20 15:19:34	2570	12.94	2.36	0.34	0.21	4.81	1.58
02/17/20 15:20:04	2600	12.95	2.50	0.35	0.10	4.81	1.24
02/17/20 15:20:34	2630	12.95	2.61	0.38	0.08	4.81	1.03
02/17/20 15:21:04	2660	12.95	2.70	0.42	0.21	4.82	2.28
02/17/20 15:21:34	2690	12.94	2.77	0.39	0.08	4.81	1.83
02/17/20 15:22:04	2720	12.95	2.81	0.41	0.13	4.81	1.84
02/17/20 15:22:34	2750	12.96	2.73	0.42	0.29	4.81	1.83
02/17/20 15:23:04	2780	12.93	2.62	0.46	0.00	4.81	1.73
02/17/20 15:23:34	2810	12.95	2.54	0.49	0.06	4.81	1.86
02/17/20 15:24:04	2840	12.91	2.45	0.53	0.00	4.81	1.36
02/17/20 15:24:34	2870	12.94	2.34	0.61	0.06	4.82	1.95
02/17/20 15:25:04	2900	12.95	2.24	0.47	0.30	4.81	1.42
02/17/20 15:25:34	2930	12.95	2.17	0.40	0.39	4.81	1.16
02/17/20 15:26:04	2960	12.96	2.14	0.39	0.34	4.82	1.26
02/17/20 15:26:34	2990	12.93	2.14	0.39	0.10	4.82	1.25

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,644	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,019	Btu/SCF fuel
Turbine Fuel Flow	1,673	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,261,296	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	40	%
Ambient Temperature	43	° F
Specific Humidity	0.002295	lb H_2O / lb air

Unit Data

Unit Load	240.4	megawatts
Heat Input	2,304	MMBtu/hr
NH_3 Flow Rate	165	lb/hr
Meas. Stack Moisture	5.8	%
Stack Exhaust Flow (M19)	51,868,559	SCFH

Data from: From PM Run PM U-00001 Base-1

Base Load, Run - 1-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/17/20 15:27:04	3020	12.95	2.22	0.34	0.00	4.82	1.66
02/17/20 15:27:34	3050	12.95	2.35	0.42	0.16	4.82	1.63
02/17/20 15:28:04	3080	12.95	2.48	0.41	0.21	4.82	1.42
02/17/20 15:28:34	3110	12.91	2.62	0.38	0.01	4.81	1.72
02/17/20 15:29:04	3140	12.93	2.74	0.35	0.01	4.82	1.39
02/17/20 15:29:34	3170	12.93	2.84	0.41	0.13	4.81	1.54
02/17/20 15:30:04	3200	12.94	2.76	0.43	0.36	4.82	1.78
02/17/20 15:30:34	3230	12.95	2.65	0.41	0.46	4.82	1.75
02/17/20 15:31:04	3260	12.94	2.55	0.50	0.39	4.82	1.56
02/17/20 15:31:34	3290	12.94	2.47	0.42	0.19	4.82	1.19
02/17/20 15:32:04	3320	12.95	2.37	0.47	0.22	4.82	1.42
02/17/20 15:32:34	3350	12.93	2.27	0.45	0.09	4.82	1.28
02/17/20 15:33:04	3380	12.95	2.23	0.42	0.21	4.82	1.77
02/17/20 15:33:34	3410	12.96	2.17	0.37	0.28	4.82	1.44
02/17/20 15:34:04	3440	12.97	2.12	0.20	0.30	4.82	1.15
02/17/20 15:34:34	3470	12.95	2.13	0.40	0.04	4.83	1.02
02/17/20 15:35:04	3500	12.97	2.19	0.34	0.06	4.82	0.99
02/17/20 15:35:34	3530	12.97	2.23	0.40	0.12	4.82	1.14
02/17/20 15:36:04	3560	12.98	2.20	0.44	0.13	4.83	1.32
02/17/20 15:36:34	3590	12.96	2.22	0.40	0.13	4.82	1.27
02/17/20 15:37:04	3620	12.91	2.33	0.47	0.00	4.83	1.38
02/17/20 15:37:34	3650	12.93	2.09	0.37	0.00	4.81	1.09
02/17/20 15:38:04	3680	12.94	2.33	0.38	0.00	4.82	0.99
02/17/20 15:38:34	3710	12.94	2.37	0.42	0.00	4.83	1.48
02/17/20 15:39:04	3740	12.95	2.35	0.27	0.00	4.83	1.26
02/17/20 15:39:34	3770	12.95	2.39	0.32	0.00	4.83	1.02
02/17/20 15:40:04	3800	12.96	2.34	0.31	0.00	4.82	1.43
02/17/20 15:40:34	3830	12.93	2.25	0.34	0.00	4.82	1.28
02/17/20 15:41:04	3860	12.96	2.19	0.35	0.00	4.83	1.33
02/17/20 15:41:34	3890	12.91	2.14	0.38	0.00	4.83	1.11
02/17/20 15:42:04	3920	12.92	2.14	0.42	0.00	4.82	1.14
02/17/20 15:42:34	3950	12.94	2.13	0.39	0.00	4.82	1.35
02/17/20 15:43:04	3980	12.95	2.12	0.41	0.00	4.83	2.75
02/17/20 15:43:34	4010	12.95	2.14	0.42	0.00	4.83	1.93
02/17/20 15:44:04	4040	12.94	2.17	0.46	0.00	4.83	1.73
02/17/20 15:44:34	4070	12.95	2.23	0.49	0.00	4.83	1.81
02/17/20 15:45:04	4100	12.94	2.28	0.53	0.00	4.83	1.54
02/17/20 15:45:34	4130	12.95	2.29	0.61	0.00	4.83	1.22
02/17/20 15:46:04	4160	12.95	2.30	0.32	0.00	4.82	1.38
02/17/20 15:46:34	4190	12.95	2.32	0.37	0.00	4.83	1.42
02/17/20 15:47:04	4220	12.94	2.32	0.20	0.00	4.82	1.50
02/17/20 15:47:34	4250	12.95	2.31	0.40	0.00	4.83	1.36
02/17/20 15:48:04	4280	12.96	2.31	0.34	0.00	4.82	1.42
02/17/20 15:48:34	4310	12.93	2.27	0.40	0.00	4.82	1.16
02/17/20 15:49:04	4340	12.97	2.26	0.44	0.00	4.82	1.27
02/17/20 15:49:34	4370	12.97	2.25	0.40	0.00	4.82	1.08
RAW AVERAGE		**12.95**	**2.38**	**0.41**	**0.25**	**4.82**	**1.22**

		O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3
	Serial Number:	inst-02-0014	inst-nx-0020	inst-co-0045	inst-th-0010	inst-c2-0023	inst-ir-0004
Bias	**Initial Zero**	0.10	0.02	0.01	0.01	0.03	
	Final Zero	0.03	0.02	0.00	0.00	0.02	
	Avg. Zero	0.07	0.02	0.01	0.01	0.03	
	Initial UpScale	12.10	9.06	9.15	3.30	8.91	
	Final UpScale	12.06	8.94	9.07	3.28	8.99	
	Avg. UpScale	12.08	9.00	9.11	3.29	8.95	
Upscale Cal Gas		12.01	8.90	9.10	3.37	8.95	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	12.88	2.34	0.40	0.27	4.81	1.30
Concentration (ppm@ 15%O_2)	N/A	1.72	0.30	0.20	N/A	0.95

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,644	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,019	Btu/SCF fuel
Turbine Fuel Flow	1,678	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,267,876	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.30	in. Hg
Relative Humidity	39	%
Ambient Temperature	45	° F
Specific Humidity	0.002414	lb H_2O / lb air

Unit Data

Unit Load	241.3	megawatts
Heat Input	2,311	MMBtu/hr
NH_3 Flow Rate	172	lb/hr
Meas. Stack Moisture	5.8	%
Stack Exhaust Flow (M19)	52,178,300	SCFH

Data from: From PM Run PM U-00001 Base-1

Base Load, Run - 1-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/17/20 16:00:04	1400	12.96	2.42	0.00	0.00	4.81	1.23
02/17/20 16:00:34	1430	12.96	2.38	0.00	0.00	4.81	1.30
02/17/20 16:01:04	1460	12.96	2.39	0.00	0.00	4.82	1.10
02/17/20 16:01:34	1490	12.96	2.47	0.01	0.00	4.82	0.94
02/17/20 16:02:04	1520	12.96	2.44	0.01	0.00	4.82	1.08
02/17/20 16:02:34	1550	12.96	2.45	0.00	0.00	4.82	1.24
02/17/20 16:03:04	1580	12.96	2.48	0.00	0.00	4.82	1.12
02/17/20 16:03:34	1610	12.96	2.45	0.00	0.00	4.82	1.42
02/17/20 16:04:04	1640	12.96	2.45	0.00	0.00	4.82	1.41
02/17/20 16:04:34	1670	12.96	2.43	0.00	0.00	4.82	1.16
02/17/20 16:05:04	1700	12.96	2.43	0.00	0.00	4.82	1.51
02/17/20 16:05:34	1730	12.96	2.46	0.00	0.00	4.82	1.21
02/17/20 16:06:04	1760	12.96	2.48	0.00	0.00	4.82	1.06
02/17/20 16:06:34	1790	12.96	2.50	0.02	0.00	4.82	1.47
02/17/20 16:07:04	1820	12.96	2.50	0.01	0.00	4.82	1.35
02/17/20 16:07:34	1850	12.96	2.45	0.01	0.00	4.82	1.11
02/17/20 16:08:04	1880	12.96	2.39	0.00	0.00	4.82	1.37
02/17/20 16:08:34	1910	12.96	2.39	0.01	0.00	4.82	1.40
02/17/20 16:09:04	1940	12.96	2.37	0.00	0.00	4.82	1.32
02/17/20 16:09:34	1970	12.96	2.37	0.01	0.00	4.82	1.07
02/17/20 16:10:04	2000	12.96	2.40	0.00	0.00	4.82	0.95
02/17/20 16:10:34	2030	12.93	2.44	0.00	0.00	4.82	0.84
02/17/20 16:11:04	2060	12.95	2.53	0.02	0.00	4.81	0.83
02/17/20 16:11:34	2090	12.95	2.60	0.00	0.00	4.82	0.74
02/17/20 16:12:04	2120	12.96	2.64	0.03	0.00	4.82	0.68
02/17/20 16:12:34	2150	12.93	2.71	0.02	0.02	4.82	0.88
02/17/20 16:13:04	2180	12.96	2.71	0.04	0.00	4.82	1.02
02/17/20 16:13:34	2210	12.96	2.65	0.10	0.00	4.82	1.28
02/17/20 16:14:04	2240	12.93	2.58	0.01	0.05	4.82	1.13
02/17/20 16:14:34	2270	12.95	2.51	0.05	0.00	4.82	0.85
02/17/20 16:15:04	2300	12.95	2.41	0.04	0.02	4.82	0.69
02/17/20 16:15:34	2330	12.94	2.38	0.02	0.12	4.82	0.70
02/17/20 16:16:04	2360	12.95	2.27	0.08	0.00	4.82	0.71
02/17/20 16:16:34	2390	12.94	2.23	0.03	0.10	4.82	0.71
02/17/20 16:17:04	2420	12.93	2.25	0.08	0.00	4.82	0.73
02/17/20 16:17:34	2450	12.94	2.34	0.05	0.00	4.81	1.13
02/17/20 16:18:04	2480	12.95	2.41	0.02	0.10	4.82	0.85
02/17/20 16:18:34	2510	12.96	2.40	0.06	0.12	4.82	1.24
02/17/20 16:19:04	2540	12.96	2.44	0.02	0.24	4.82	0.98
02/17/20 16:19:34	2570	12.91	2.44	0.01	0.14	4.82	0.77
02/17/20 16:20:04	2600	12.93	2.48	0.10	0.00	4.82	1.41
02/17/20 16:20:34	2630	12.94	2.52	0.03	0.00	4.82	0.91
02/17/20 16:21:04	2660	12.95	2.57	0.03	0.19	4.82	1.06
02/17/20 16:21:34	2690	12.94	2.62	0.07	0.18	4.82	0.96
02/17/20 16:22:04	2720	12.94	2.56	0.02	0.15	4.82	1.38
02/17/20 16:22:34	2750	12.95	2.55	0.03	0.00	4.82	1.17
02/17/20 16:23:04	2780	12.95	2.57	0.03	0.14	4.82	0.84
02/17/20 16:23:34	2810	12.96	2.53	0.06	0.26	4.82	0.71
02/17/20 16:24:04	2840	12.96	2.52	0.04	0.27	4.82	0.73
02/17/20 16:24:34	2870	12.97	2.49	0.05	0.27	4.82	1.02
02/17/20 16:25:04	2900	12.95	2.43	0.01	0.05	4.82	1.02
02/17/20 16:25:34	2930	12.95	2.40	0.01	0.03	4.82	2.06
02/17/20 16:26:04	2960	12.95	2.36	0.00	0.05	4.82	1.58
02/17/20 16:26:34	2990	12.96	2.30	0.03	0.10	4.82	1.72
02/17/20 16:27:04	3020	12.93	2.33	0.03	0.12	4.82	2.25
02/17/20 16:27:34	3050	12.94	2.35	0.00	0.00	4.82	2.36
02/17/20 16:28:04	3080	12.94	2.43	0.01	0.00	4.82	2.21
02/17/20 16:28:34	3110	12.95	2.49	0.01	0.00	4.82	1.88
02/17/20 16:29:04	3140	12.94	2.48	0.04	0.00	4.82	2.01
02/17/20 16:29:34	3170	12.96	2.57	0.03	0.01	4.82	1.70
02/17/20 16:30:04	3200	12.93	2.62	0.03	0.02	4.83	1.87
02/17/20 16:30:34	3230	12.95	2.69	0.00	0.00	4.82	1.85
02/17/20 16:31:04	3260	12.94	2.77	0.04	0.00	4.82	1.65
02/17/20 16:31:34	3290	12.95	2.78	0.03	0.00	4.82	1.36
02/17/20 16:32:04	3320	12.95	2.77	0.00	0.00	4.82	1.27
02/17/20 16:32:34	3350	12.96	2.62	0.03	0.00	4.82	1.60
02/17/20 16:33:04	3380	12.96	2.49	0.00	0.00	4.82	1.40
02/17/20 16:33:34	3410	12.96	2.37	0.02	0.00	4.82	1.41
02/17/20 16:34:04	3440	12.94	2.27	0.03	0.00	4.82	1.75
02/17/20 16:34:34	3470	12.95	2.25	0.00	0.00	4.82	1.60
02/17/20 16:35:04	3500	12.95	2.24	0.01	0.00	4.82	1.92
02/17/20 16:35:34	3530	12.95	2.19	0.03	0.01	4.82	1.71
02/17/20 16:36:04	3560	12.94	2.20	0.01	0.00	4.82	1.37
02/17/20 16:36:34	3590	12.95	2.25	0.00	0.00	4.82	1.93

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,644	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,019	Btu/SCF fuel
Turbine Fuel Flow	1,678	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,267,876	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.30	in. Hg
Relative Humidity	39	%
Ambient Temperature	45	° F
Specific Humidity	0.002414	lb H_2O / lb air

Unit Data

Unit Load	241.3	megawatts
Heat Input	2,311	MMBtu/hr
NH_3 Flow Rate	172	lb/hr
Meas. Stack Moisture	5.8	%
Stack Exhaust Flow (M19)	52,178,300	SCFH

Data from: From PM Run PM U-00001 Base-1

Base Load, Run - 1-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/17/20 16:37:04	3620	12.95	2.37	0.00	0.00	4.82	1.79
02/17/20 16:37:34	3650	12.93	2.39	0.00	0.00	4.82	2.13
02/17/20 16:38:04	3680	12.95	2.55	0.01	0.00	4.82	1.54
02/17/20 16:38:34	3710	12.95	2.75	0.00	0.00	4.82	1.55
02/17/20 16:39:04	3740	12.95	2.91	0.00	0.00	4.82	1.33
02/17/20 16:39:34	3770	12.94	2.95	0.04	0.00	4.82	1.57
02/17/20 16:40:04	3800	12.94	2.94	0.00	0.00	4.82	1.36
02/17/20 16:40:34	3830	12.93	2.94	0.01	0.00	4.82	1.70
02/17/20 16:41:04	3860	12.94	2.82	0.03	0.00	4.82	1.34
02/17/20 16:41:34	3890	12.91	2.64	0.00	0.00	4.83	1.53
02/17/20 16:42:04	3920	12.92	2.41	0.00	0.00	4.82	2.09
02/17/20 16:42:34	3950	12.93	2.32	0.02	0.00	4.82	1.79
02/17/20 16:43:04	3980	12.94	2.20	0.01	0.00	4.82	1.86
02/17/20 16:43:34	4010	12.93	2.12	0.00	0.00	4.82	2.17
02/17/20 16:44:04	4040	12.94	2.10	0.00	0.00	4.82	1.09
02/17/20 16:44:34	4070	12.93	2.14	0.00	0.00	4.83	0.96
02/17/20 16:45:04	4100	12.94	2.21	0.00	0.00	4.83	0.98
02/17/20 16:45:34	4130	12.95	2.33	0.00	0.00	4.82	0.90
02/17/20 16:46:04	4160	12.94	2.38	0.00	0.00	4.83	1.61
02/17/20 16:46:34	4190	12.94	2.41	0.00	0.00	4.83	1.26
02/17/20 16:47:04	4220	12.95	2.51	0.00	0.00	4.83	1.61
02/17/20 16:47:34	4250	12.95	2.57	0.00	0.00	4.83	1.48
02/17/20 16:48:04	4280	12.94	2.49	0.00	0.00	4.83	1.70
02/17/20 16:48:34	4310	12.93	2.44	0.00	0.00	4.83	1.19
02/17/20 16:49:04	4340	12.94	2.38	0.00	0.00	4.83	1.33
02/17/20 16:49:34	4370	12.95	2.39	0.00	0.00	4.83	1.22
02/17/20 16:50:04	4400	12.94	2.38	0.01	0.00	4.83	1.18
02/17/20 16:50:34	4430	12.94	2.38	0.00	0.00	4.83	0.86
02/17/20 16:51:04	4460	12.95	2.37	0.01	0.00	4.83	0.72
02/17/20 16:51:34	4490	12.94	2.20	0.01	0.00	4.82	0.67
02/17/20 16:52:04	4520	12.93	2.12	0.00	0.00	4.82	1.21
02/17/20 16:52:34	4550	12.94	2.10	0.00	0.00	4.82	1.21
02/17/20 16:53:04	4580	12.93	2.14	0.00	0.00	4.83	1.35
02/17/20 16:53:34	4610	12.94	2.21	0.00	0.00	4.83	1.30
02/17/20 16:54:04	4640	12.95	2.33	0.00	0.00	4.82	1.32
02/17/20 16:54:34	4670	12.94	2.38	0.00	0.00	4.83	1.39
02/17/20 16:55:04	4700	12.94	2.41	0.00	0.00	4.83	1.61
02/17/20 16:55:34	4730	12.95	2.51	0.00	0.00	4.83	1.16
02/17/20 16:56:04	4760	12.95	2.57	0.00	0.00	4.83	1.34
02/17/20 16:56:34	4790	12.94	2.49	0.00	0.00	4.83	0.91
02/17/20 16:57:04	4820	12.93	2.44	0.00	0.00	4.83	0.78
02/17/20 16:57:34	4850	12.94	2.38	0.00	0.00	4.83	1.25
02/17/20 16:58:04	4880	12.95	2.39	0.00	0.00	4.83	1.28
02/17/20 16:58:34	4910	12.94	2.38	0.01	0.00	4.83	1.15
02/17/20 16:59:04	4940	12.94	2.38	0.00	0.00	4.83	0.76
02/17/20 16:59:34	4970	12.95	2.37	0.01	0.00	4.83	1.17
RAW AVERAGE		**12.95**	**2.45**	**0.02**	**0.02**	**4.82**	**1.30**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0014	inst-nx-0020	inst-co-0045	inst-th-0010	inst-c2-0023	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.03	0.02	0.00	0.00	0.02	
Bias	**Final Zero**	0.01	0.00	0.00	0.00	0.02	
Bias	**Avg. Zero**	0.02	0.01	0.00	0.00	0.02	
Bias	**Initial UpScale**	12.06	8.94	9.07	3.28	8.99	
Bias	**Final UpScale**	12.05	8.96	9.11	3.33	9.01	
Bias	**Avg. UpScale**	12.06	8.95	9.09	3.31	9.00	
Upscale Cal Gas		12.01	8.90	9.10	3.37	8.95	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	12.90	2.43	0.02	0.02	4.79	1.38
Concentration (ppm@ 15%O_2)	N/A	1.79	0.01	0.02	N/A	1.02

Non-Bias Adjusted Averages Include: *

EMISSION DATA RECORDS

Reference Method Data
Base Load
PM_{10}

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#1	
Operator		Aaron Blum	
Date for Preliminary Run	(mm/dd/yy)	02/16/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		U-00001	
Base Run Number		PM U-00001 Base	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	02/17/20	02/17/20	02/19/20	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8643.54	8643.54	8642.95	dscf/MMBtu
Meter Box Number	from ACS	Samp-cp-0030	Samp-cp-0030	Samp-cp-0030	
Meter Calibration Factor	(Y)	0.974	0.974	0.974	
Orifice Meter Coefficient	($\Delta H_@$)	1.878	1.878	1.878	in H_2O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	4187/10	4187/10	4187/10	
Pitot Tube Coefficient	(C_p)	0.7240	0.7240	0.7240	
Nozzle Number	from ACS	4b	4b	4b	must match cyc nozz tab (e.g. 3a, 4b, etc.)
Nozzle Diameter	(D_n)	0.156	0.156	0.156	in
Probe Number	from ACS	SAMP-PR-0133	SAMP-PR-0133	SAMP-PR-0133	
Probe Length		120.0	120.0	120.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039	
Impinger Case Number	from ACS	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	02/16/20
Sampling Location	U-00001 Base	**Stack Type**	Circular
Operator	Aaron Blum	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	4
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

○ Method 1 Trav

◉ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
4	**Ports by**	3	**Across**
12	**Pts Used**	12	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.044	10	18
2	0.146	33 2/8	41 2/8
3	0.296	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Cricket Valley Energy Center			
Sampling Location	U-00001 Base			
Operator	Aaron Blum			
Project #	bec-19-cricketvalley.ny-start#1			
Pitot Leak Check	x	**PreTest**	x	**PostTest**

Preliminary Run Date	02/16/20		
Stack Type	Circular		
Ports Available	4		
Thermocouple ID	SAMP-PR-0133		
Pitot Coefficient	0.8198	**Pitot Identification**	A4187

RM 201A or OTM 27 Blckag.	**RM 201A or OTM 27 Pitot Coeff.**
5.39E-04	0.7240

Stack Dimensions			
Area of Stack	(A_s)	283.53	ft²
Diameter of Stack	(D)	228.00	in

Pressures			
Barometric Pressure	(P_b)	29.73	in Hg
Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	29.80	in Hg

Stack Gas Composition			
Composition Data:	**Estimated Composition**		
Carbon Dioxide Concentration	(%CO_2)	4.90	%vd
Oxygen Concentration	(%O_2)	13.00	%vd
Carbon Monoxide Concentration	(ppmCO)	0.00	ppmvd
Nitrogen Concentration	(%N_2)	82.10	%vd
Stack Moisture Content	(B_{ws})	8.00	%
Stack Dry Molecular Weight	(M_d)	29.30	lb/lb-mole
Stack Wet Molecular Weight	(M_w)	28.40	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v_s)	55.95	ft/sec
Avg Stack Dry Std Flow Rate	(Q_{sd})	42,826,096	dscf/hr
Avg Stack Dry Std Flow Rate	(Q_{sd})	713,768	dscf/min
Avg Stack Wet Flow Rate	(Q_{aw})	951,820	acf/min
Avg Stack Wet Std Flow Rate	(Q_{sw})	46,550,104	ascf/hr

40 CFR 60, Method 2G, Section 8.11.1 (but applies to all Method 2 type static pressure measurements):
If a Type S probe is used for this measurement, position the probe at or between any traverse point(s) and rotate the probe until a null differential pressure reading is obtained. Disconnect the tubing from one of the pressure ports; read and record the ΔP. For pressure devices with one-directional scales, if a deflection in the positive direction is noted with the negative side disconnected, then the static pressure is positive. Likewise, if a deflection in the positive direction is noted with the positive side disconnected, then the static pressure is negative.

Stack Cross Section Schematic

Velocity Traverse Data

Run Number	PM U-00001 Base-V1				
Run Time	08:00	**Start**	08:41	**End**	

Traverse Point	**Velocity Head** (Δp)	**Null Angle** (N_a)	**Zero Deg Pressure** ($0°_a$)	**Stack Temp** (t_s)	**Local Velocity** ($v_{s(l)}$)	**Adjusted Velocity Pressure**	**Adjusted Velocity Pressure w/BF, if app**
	in H_2O	deg	in H_2O	°F	ft/sec	in H_2O	in H_2O
A-1	1.50	5	0.04	186	74.99	1.17	1.17
A-2	1.40	5	0.10	184	72.34	1.09	1.09
A-3	1.40	10	0.07	185	72.39	1.09	1.09
B-1	1.30	5	0.11	186	69.81	1.01	1.01
B-2	1.40	5	0.02	184	72.34	1.09	1.09
B-3	1.30	-5	-0.02	187	69.87	1.01	1.01
C-1	1.40	0	0.00	186	72.45	1.09	1.09
C-2	1.40	-5	0.10	183	72.28	1.09	1.09
C-3	1.30	5	0.11	185	69.76	1.01	1.01
D-1	1.40	0	0.00	187	72.51	1.09	1.09
D-2	1.40	-5	0.06	185	72.39	1.09	1.09
D-3	1.30	-5	0.10	184	69.71	1.01	1.01
Average	1.38	5		185		1.07	1.07
	1.17	**= Square roots of Δp**					1.04
Standard deviation of null angles =				2.6			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	PM U-00001 Base-4	PM U-00001 Base-5	PM U-00001 Base-6	
Carbon Dioxide Content	4.9	4.9	4.8	4.8				%
Oxygen Content	13.0	12.7	12.8	12.8				%
Stack Moisture Content	8.0	5.8	6.7	6.6				%
Nitrogen plus CO Content	82.1	82.4	82.4	82.4				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H_2O)	Min.	1.01	Max.	1.17

Stack and Equipment Information	Prelim	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	PM U-00001 Base-4	PM U-00001 Base-5	PM U-00001 Base-6	
Barometric Pressure	29.73	29.98	29.88	30.12				in Hg
Stack Static Pressure	0.95	0.95	0.95	0.95				in H_2O
Absolute Stack Pressure	29.80	30.05	29.95	30.19				in Hg
Average Stack Temp	185	190	190	184				0.00
Average Stack Temp	645	650	650	644				°R
Average Meter Temp	85	67	65	75				0.00
Orifice Meter Coefficient	1.878	1.878	1.878	1.878				in H_2O
Pitot Coefficient	0.724	0.724	0.724	0.724				
Stack Dry Molecular Weight	29.30	29.29	29.28	29.28				lb/lb mole
Stack Wet Molecular Weight	28.40	28.64	28.53	28.54				lb/lb mole
Stack Viscosity	201.12	204.09	203.35	202.01				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.08							
Cunningham Correction Factor, for a 2.5 µm particle		1.07	1.07	1.07				
Prelim Cut Dia., Cyclone I, D_{50LL}, N_{re}<3162	10.28	2.32	2.33	2.35				µm
Middle Zone Dia., Cyclone I, D_{50T}, N_{re}<3162	10.64							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.), N_{re}<3162	0.48							dscfm
Reynolds Number, Cyc I & IV, N_{re}<3162	2720.44	2795.22	2776.75	2786.81				
Dia. of 50% Prob. (D_{50}) Cyc IV (N_{re}<3162)	2.38	2.33	2.34	2.35				µm
Sampling Rate, Cyc IV, N_{re}<3,162	0.48							dscfm
Reynolds Number, Cyc IV, N_{re}<3162	2720.40	2795.22	2776.75	2786.81				
Prelim Cut Dia., Cyclone I, $D_{50LL\geq3162}$	10.62							µm
Middle Zone Dia., Cyclone I, $D_{50T\geq3162}$	10.81							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.)≥3162	0.47							dscfm
Reynolds Number, Cyc I & IV, N_{re}≥3162	2659.02							
Dia. of 50% Prob. (D_{50}) CIV (N_{re}≥3162)	2.30							µm
Sampling Rate, Cyc IV, N_{re}≥3,162	4.72							dscfm
Reynolds Number ≥ 3162	26590.32							
Cyclone Flow Rate	0.48	0.50	0.50	0.49				ft³/min
Recalculated D_{50-1} for C_{IV}		2.32	2.33	2.35				
Recalculated Cunninham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		100.69	99.60	100.81				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.156	0.156	0.156				in

Orifice Head and Nozzle Selection Calculation											
Nozzle No.	2a	2b	3a	3b	4a	4b	5a	5b	6a	6b	7a
Nozzle diameter, D_n, in.	0.119	0.130	0.130	0.143	0.155	0.156	0.175	0.172	0.197	0.192	0.212
Nozzle velocity, v_n, ft/sec	104.17	87.29	87.29	72.14	61.67	60.62	48.17	49.86	38.01	40.02	32.82
R_{min}	0.77	0.76	0.76	0.74	0.73	0.73	0.69	0.70	0.64	0.65	0.58
v_{min}, ft/sec	80.02	66.18	66.18	53.64	44.86	43.97	33.29	34.77	24.16	26.01	19.14
R_{max}	1.22	1.23	1.23	1.24	1.25	1.25	1.27	1.27	1.30	1.29	1.32
v_{max}, ft/sec	127.34	107.28	107.28	89.34	76.98	75.74	61.13	63.11	49.29	51.62	43.29
Δp_{min}, in. H_2O @ $t_{s-50}{}^oF$	2.38	1.63	1.63	1.07	0.75	0.72	0.41	0.45	0.22	0.25	0.14
Δp_{min}, in. H_2O @ t_s	2.19	1.50	1.50	0.99	0.69	0.66	0.38	0.41	0.20	0.23	0.13
Δp_{max}, in. H_2O @ t_s	5.55	3.94	3.94	2.73	2.03	1.96	1.28	1.36	0.83	0.91	0.64
Δp_{min}, in. H_2O @ $t_{s+50}{}^oF$	5.15	3.66	3.66	2.54	1.88	1.82	1.19	1.27	0.77	0.85	0.60
ΔH, in. H_2O @ t_s+50°F	0.396										
ΔH, in. H_2O @ t_s	**0.460**										
ΔH, in. H_2O @ t_s-50°F	0.540										

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/16/20		
Sampling Location	U-00001 Base	**Operator**	Aaron Blum		
Project #	bec-19-cricketvalley.ny-start#1	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	PM U-00001 Base-1		**Date**	02/17/20	**Run Start Time**	17:02	**Run Stop Time**	22:11
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
05:09	4.9	12.7	0.0	82.4	29.29	1.673	140.3	YES

Gas Analysis Data

Run Number	PM U-00001 Base-2		**Date**	02/17/20	**Run Start Time**	23:05	**Run Stop Time**	04:05
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
05:00	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

Gas Analysis Data

Run Number	PM U-00001 Base-3		**Date**	02/19/20	**Run Start Time**	14:25	**Run Stop Time**	18:27
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:02	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/16/20
Sampling Location	U-00001 Base	**Operator**	Aaron Blum
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	02/16/20	500	499.7	-0.3	Pass
Test Day 1	02/17/20	500	499.7	-0.3	Pass
Test Day 2	02/19/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		PM U-00001 Base-1		**Date**	02/17/20	**Start Time**	17:02	**Stop Time**	22:11
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume	(V_m)	104.890	dcf			**Barometric Pressure**	(P_b)	29.98	in Hg
Average Stack Temp	$(t_s)_{avg}$	190	°F			**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp	$(t_m)_{avg}$	67	°F			**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	471.90	555.10	716.00	859.00				
Initial Value	(V_i),(W_i)	357.70	552.90	715.80	842.40				
Net Value	(V_n),(W_n)	114.2	2.2	0.2	16.6				
Results									
Total Weight	(W_t)	133.20	g			**Water Vol Weighed**	($V_{wsg(std)}$)	6.280	scf
Std Meter Volume	($V_{m(std)}$)	102.645	dscf			**Sat. Moisture Content**	($B_{ws(svp)}$)	62.60	%
Calc Moisture Content	($B_{ws(calc)}$)	5.77	%			**Final Moisture Content**	(B_{ws})	5.77	%

Moisture Content Data									
Run Number		PM U-00001 Base-2		**Date**	02/17/20	**Start Time**	23:05	**Stop Time**	04:05
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume	(V_m)	103.580	dcf			**Barometric Pressure**	(P_b)	29.88	in Hg
Average Stack Temp	$(t_s)_{avg}$	190	°F			**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp	$(t_m)_{avg}$	65	°F			**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	509.50	583.10	728.80	901.30				
Initial Value	(V_i),(W_i)	374.00	581.70	724.60	889.00				
Net Value	(V_n),(W_n)	135.5	1.4	4.2	12.3				
Results									
Total Weight	(W_t)	153.40	g			**Water Vol Weighed**	($V_{wsg(std)}$)	7.233	scf
Std Meter Volume	($V_{m(std)}$)	101.410	dscf			**Sat. Moisture Content**	($B_{ws(svp)}$)	63.04	%
Calc Moisture Content	($B_{ws(calc)}$)	6.66	%			**Final Moisture Content**	(B_{ws})	6.66	%

Moisture Content Data									
Run Number		PM U-00001 Base-3		**Date**	02/19/20	**Start Time**	14:25	**Stop Time**	18:27
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume	(V_m)	102.290	dcf			**Barometric Pressure**	(P_b)	30.12	in Hg
Average Stack Temp	$(t_s)_{avg}$	184	°F			**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp	$(t_m)_{avg}$	75	°F			**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	507.70	584.10	733.70	930.10				
Initial Value	(V_i),(W_i)	374.80	584.00	729.90	918.60				
Net Value	(V_n),(W_n)	132.9	0.1	3.8	11.5				
Results									
Total Weight	(W_t)	148.30	g			**Water Vol Weighed**	($V_{wsg(std)}$)	6.992	scf
Std Meter Volume	($V_{m(std)}$)	99.080	dscf			**Sat. Moisture Content**	($B_{ws(svp)}$)	55.00	%
Calc Moisture Content	($B_{ws(calc)}$)	6.59	%			**Final Moisture Content**	(B_{ws})	6.59	%

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Date	02/17/20
Operator	Aaron Blum
Run Number	PM U-00001 Base-1

Filter #
18082942
PM U-00001 Base-1-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	189.6	°F
Average Meter Temp	(t_m)	67.2	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.16	in H_2O
Stack Moisture Content	(B_{ws})	5.77	%
Stack Dry Molecular Weight	(M_d)	29.29	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.36	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.00	in H_2O	3.6	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.00	in H_2O	3.9	in H_2O for	15.0	sec [≥15]
	Post (+)	0.00	in H_2O	3.8	in H_2O for	15.0	sec [≥15]
	Post (-)	0.00	in H_2O	4.1	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{na})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.2212	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	29.98	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.05	in Hg
Absolute Meter Pressure	(P_m)	30.12	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	17:02	**End**	22:11

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	357.7	552.9	715.8	842.4				
Post	471.9	555.1	716.0	859.0				

Wash Volumes					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	328.160	1.30	0.460	0.46	189	255	254	48	66	74	64	64	2.5	1.14	61.28	8.319	100.7	101.248
A-2	22.0	00:22:00	336.610	1.40	0.460	0.46	190	250	262	45	66	75	64	64	2.5	1.18	63.64	16.727	97.8	100.081
A-3	44.8	00:44:45	345.150	1.30	0.460	0.46	189	251	250	45	67	76	66	66	2.5	1.14	61.28	24.965	98.4	100.142
B-1	66.8	01:06:45	353.550	1.30	0.460	0.46	190	252	251	46	68	77	65	65	2.5	1.14	61.33	33.190	98.7	100.131
B-2	88.8	01:28:45	361.920	1.40	0.460	0.46	188	251	252	49	70	78	66	66	2.5	1.18	63.55	42.066	99.0	101.015
B-3	111.5	01:51:30	370.970	1.30	0.460	0.46	190	250	252	46	71	76	68	68	2.5	1.14	61.33	50.859	100.3	102.005
C-1	133.5	02:13:30	379.970	1.40	0.460	0.46	188	251	254	43	67	77	69	69	2.5	1.18	63.55	60.319	101.3	103.363
C-2	156.3	02:36:15	389.670	1.40	0.460	0.46	189	250	256	43	68	77	69	69	2.5	1.18	63.60	68.755	100.5	102.844
C-3	179.0	02:59:00	398.320	1.30	0.460	0.46	191	249	246	44	67	77	68	68	2.5	1.14	61.38	77.255	100.8	102.910
D-1	201.0	03:21:00	407.020	1.30	0.460	0.46	192	250	247	45	66	78	68	68	2.5	1.14	61.42	85.912	101.2	103.152
D-2	223.0	03:43:00	415.880	1.40	0.460	0.46	190	250	252	44	63	76	69	69	2.5	1.18	63.64	94.152	100.5	102.581
D-3	245.8	04:05:45	424.330	1.30	0.460	0.46	189	252	254	45	64	77	70	70	2.5	1.14	61.28	102.640	100.7	102.640
Last Pt	267.8	04:27:45	433.050																	
Final Val	267.8	04:27:45	433.050											**Max Vac**	2.5	**Final Values**		102.640	100.7	
Average Values					1.34		0.46	190	251	253	45	67	77	67	67		1.16	62.27			
													67							

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.36	8.319	100.7	837.6
0.156	0.36	8.408	94.9	797.9
0.156	0.36	8.238	99.7	821.5
0.156	0.36	8.225	99.6	819.3
0.156	0.36	8.876	100.0	887.8
0.156	0.36	8.793	106.5	936.6
0.156	0.36	9.460	106.6	1008.4
0.156	0.36	8.436	95.1	802.5
0.156	0.36	8.500	103.0	875.9
0.156	0.36	8.657	105.0	909.1
0.156	0.36	8.241	93.0	766.4
0.156	0.36	8.488	102.7	871.9
0.156	0.36	102.640		

RM 201A Calculations

Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**	
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Prelim. Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.75	22.86	1.40		1.40	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	204.09	μP
	Cyclone Flow Rate (Q_a)	0.50	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.49	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{re}<3162)	10.29	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.64	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.32	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}<3162)	0.50	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2795.22	
	Actual Particle Cut Diameter for CI	10.49	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.33	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.32	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	100.69	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.662	in H_2O
	Δp_{max}	1.965	in H_2O

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Date	02/17/20
Operator	Aaron Blum
Run Number	PM U-00001 Base-2

Filter #
18092937
PM U-00001 Base-2-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	189.8	°F
Average Meter Temp	(t_m)	65.2	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.16	in H_2O
Stack Moisture Content	(B_{ws})	6.66	%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.38	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.36	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
Pitot	**Pre (+)**	0.000	in H_2O	3.7	in H_2O for	15.0	sec (≥15)
PASS	**Pre (-)**	0.000	in H_2O	4.0	in H_2O for	15.0	sec (≥15)
	Post (+)	0.000	in H_2O	3.7	in H_2O for	15.0	sec (≥15)
	Post (-)	0.000	in H_2O	4.3	in H_2O for	15.0	sec (≥15)

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1580	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	29.88	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	29.95	in Hg
Absolute Meter Pressure	(P_m)	30.02	in Hg

Nozzle Measurements				**ID: 4b**
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	23:05	**End**	04:05

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	374.0	581.7	724.6	889.0				
Post	509.5	583.1	728.8	901.3				

Wash Volumes					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1026	8082	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	469.310	1.30	0.460	0.46	193	250	255	42	67	77	62	62	2.5	1.14	61.69	8.116	99.4	99.148
A-2	22.0	00:22:00	477.550	1.40	0.460	0.46	190	254	255	45	66	74	64	64	2.5	1.18	63.88	16.849	99.5	101.190
A-3	44.8	00:44:45	486.450	1.50	0.460	0.46	191	249	252	46	66	75	63	63	2.5	1.22	66.17	26.120	98.9	102.478
B-1	68.5	01:08:30	495.880	1.40	0.460	0.46	190	251	253	44	65	75	66	66	2.5	1.18	63.88	34.585	98.3	101.860
B-2	91.3	01:31:15	504.540	1.30	0.460	0.46	189	255	248	43	63	77	60	60	2.5	1.14	61.50	42.713	98.5	101.361
B-3	113.3	01:53:15	512.760	1.40	0.460	0.46	190	254	249	44	65	78	63	63	2.5	1.18	63.88	51.256	98.3	101.287
C-1	136.0	02:16:00	521.450	1.30	0.460	0.46	188	252	251	45	64	78	65	65	2.5	1.14	61.46	59.737	99.0	101.610
C-2	158.0	02:38:00	530.110	1.40	0.460	0.46	189	254	247	45	65	78	66	66	2.5	1.18	63.83	68.427	99.0	101.742
C-3	180.8	03:00:45	539.000	1.40	0.460	0.46	190	251	250	44	66	77	67	67	2.5	1.18	63.88	77.228	99.1	101.990
D-1	203.5	03:23:30	548.020	1.20	0.460	0.46	188	250	253	45	67	78	68	68	2.5	1.10	59.05	85.223	99.7	101.907
D-2	224.8	03:44:45	556.230	1.30	0.460	0.46	189	250	250	46	66	78	69	69	2.5	1.14	61.50	93.533	99.9	101.872
D-3	246.8	04:06:45	564.780	1.30	0.460	0.46	190	250	249	47	67	78	69	69	2.5	1.14	61.55	101.415	99.6	101.415
Last Pt	268.8	04:28:45	572.890																	
Final Val	268.8	04:28:45	572.890											**Max Vac**	2.5	**Final Values**		101.415	99.6	
Average Values				1.35		0.46	190	252	251	45	66	77	65	65		1.16	62.69			
													65							

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.36	8.116	99.4	807.1
0.156	0.36	8.733	99.5	868.8
0.156	0.36	9.271	97.8	906.7
0.156	0.36	8.465	96.4	816.3
0.156	0.36	8.128	99.3	806.9
0.156	0.36	8.543	97.3	831.4
0.156	0.36	8.481	103.5	878.0
0.156	0.36	8.690	98.9	859.6
0.156	0.36	8.800	100.2	882.2
0.156	0.36	7.995	105.2	840.7
0.156	0.36	8.310	101.5	843.6
0.156	0.36	7.883	96.4	759.6
0.156	0.36	101.415		

RM 201A Calculations

Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**	
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
23.75	23.66	1.50	23.66	1.50	0
22.75	22.86	1.40		1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.75	22.86	1.40	22.86	1.40	0
21.25	21.16	1.20		1.20	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30	22.03	1.30	0

Notes:

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	203.35	μP
	Cyclone Flow Rate (Q_a)	0.50	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.50	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{re}<3162)	10.27	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.64	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.33	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}<3162)	0.50	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2776.75	
	Actual Particle Cut Diameter for CI	10.50	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.34	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.33	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	99.60	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.662	in H_2O
	Δp_{max}	1.965	in H_2O

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Date	02/19/20
Operator	Aaron Blum
Run Number	PM U-00001 Base-3

Filter #
18082945
PM U-00001 Base-3-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	183.8	°F
Average Meter Temp	(t_m)	75.1	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.14	in H_2O
Stack Moisture Content	(B_{ws})	6.59	%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.38	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.37	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
Pitot	**Pre (+)**	0.00	in H_2O	3.7	in H_2O for	15.0	sec ≥15]
PASS	**Pre (-)**	0.00	in H_2O	4.0	in H_2O for	15.0	sec ≥15]
	Post (+)	0.00	in H_2O	3.6	in H_2O for	15.0	sec ≥15]
	Post (-)	0.00	in H_2O	4.2	in H_2O for	15.0	sec ≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1562	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.12	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.19	in Hg
Absolute Meter Pressure	(P_m)	30.26	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	14:25	**End**	18:27

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	374.8	584.0	729.9	918.6				
Post	507.7	584.1	733.7	930.1				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	283.800	1.30	0.460	0.46	185	250	257	55	51	73	70	70	2.5	1.14	61.06	8.459	102.5	101.218
A-2	22.0	00:22:00	292.450	1.30	0.460	0.46	184	251	258	53	49	74	72	72	2.5	1.14	61.02	16.896	102.4	101.086
A-3	44.0	00:44:00	301.110	1.40	0.460	0.46	183	254	255	54	51	75	72	72	2.5	1.18	63.27	25.235	99.6	99.523
B-1	66.8	01:06:45	309.670	1.20	0.460	0.46	183	255	252	55	55	74	74	74	2.5	1.10	58.58	33.301	101.0	99.618
B-2	88.0	01:28:00	317.980	1.30	0.460	0.46	184	249	249	55	57	76	77	77	2.5	1.14	61.02	41.254	100.1	98.727
B-3	110.0	01:50:00	326.220	1.20	0.460	0.46	183	248	251	51	59	77	78	78	2.5	1.10	58.58	49.490	101.3	99.264
C-1	131.3	02:11:15	334.770	1.30	0.460	0.46	184	250	252	52	60	76	78	78	2.5	1.14	61.02	57.737	101.1	99.179
C-2	153.3	02:33:15	343.330	1.40	0.460	0.46	185	254	251	53	61	77	75	75	2.5	1.18	63.37	66.359	100.6	99.256
C-3	176.0	02:56:00	352.230	1.30	0.460	0.46	183	250	248	54	64	77	76	76	2.5	1.14	60.97	74.307	100.1	98.795
D-1	198.0	03:18:00	360.450	1.20	0.460	0.46	184	255	253	56	66	76	76	76	2.5	1.10	58.62	82.343	100.6	98.868
D-2	219.3	03:39:15	368.760	1.30	0.460	0.46	183	256	254	57	67	76	76	76	2.5	1.14	60.97	90.185	100.1	98.409
D-3	241.3	04:01:15	376.870	1.30	0.460	0.46	185	257	255	58	68	77	77	77	2.5	1.14	61.06	99.084	100.8	99.084
Last Pt	263.3	04:23:15	386.090																	
Final Val	263.3	04:23:15	386.090											**Max Vac**	2.5	**Final Values**		99.084	100.8	
Average Values				1.29		0.46	184	252	253	54	59	76	75	75		1.14	60.79			
													75							

Actual Nozzle Diameter (D_{na})	**DP to Actual DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.37	8.459	102.5	867.4
0.156	0.37	8.437	102.2	862.2
0.156	0.37	8.339	94.1	784.4
0.156	0.37	8.066	105.2	848.4
0.156	0.37	7.953	96.3	766.1
0.156	0.37	8.237	107.4	884.8
0.156	0.37	8.246	99.9	823.7
0.156	0.37	8.622	97.4	839.7
0.156	0.37	7.948	96.2	764.6
0.156	0.37	8.035	104.9	842.8
0.156	0.37	7.842	94.9	744.3
0.156	0.37	8.899	107.9	959.9
0.156	0.37	99.084		

RM 201A Calculations						
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times Prelim. Trav. (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
22.00	22.03	1.30		1.30	0
22.00	22.03	1.30	22.03	1.30	0
22.75	22.86	1.40	22.86	1.40	0
21.25	21.16	1.20		1.20	0
22.00	22.03	1.30	22.03	1.30	0
21.25	21.16	1.20	21.16	1.20	0
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0
21.25	21.16	1.20		1.20	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30	22.03	1.30	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	202.01	μP
	Cyclone Flow Rate (Q_s)	0.49	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.56	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.30	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.65	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.35	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2786.81	
	Actual Particle Cut Diameter for CI	10.56	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.35	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.35	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	100.81	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.662	in H_2O
	Δp_{max}	1.965	in H_2O

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base Load
SAM

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#1	
Operator		Atlas Melchert	
Date for Preliminary Run	(mm/dd/yy)	02/17/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	10 L/min	10.6	scf
Run Duration	8a, 2.4.1.3	120	minutes
Unit Number		U-00001	
Base Run Number		SAM U-00001 Base	
Number of Ports Available		4	
Number of Ports Used		1	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	02/18/20	02/18/20	02/19/20	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8643.54	8643.54	8642.95	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0007	samp-cp-0007	samp-cp-0007	
Meter Calibration Factor	(Y)	0.985	0.985	0.985	
Orifice Meter Coefficient	($\Delta H_@$)	1.731	1.731	1.731	in H_2O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-SAM-01	SAMP-SAM-01	SAMP-SAM-01	
Probe Length		72.0	72.0	72.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-ha-0005	samp-ha-0005	samp-ha-0005	
Impinger Case Number	from ACS	samp-bc-0032	samp-bc-0032	samp-bc-0032	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	02/17/20
Sampling Location	U-00001 Base	**Stack Type**	Circular
Operator	Atlas Melchert	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	1
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

◉ Method 1 Trav

○ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
1	**Ports by**	1	**Across**
1	**Pts Used**	1	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
Number	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.275	62 6/8	70 6/8
2			
3			
4			
5			
6			
7			
8			
9			

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/17/20		
Sampling Location	U-00001 Base	**Operator**	Atlas Melchert		
Project #	bec-19-cricketvalley.ny-start#1	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	SAM U-00001 Base-1		**Date**	02/18/20	**Run Start Time**	02:03	**Run Stop Time**	04:03
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.8	12.7	0.0	82.5	29.28	1.708	139.9	YES

Gas Analysis Data

Run Number	SAM U-00001 Base-2		**Date**	02/18/20	**Run Start Time**	04:57	**Run Stop Time**	06:57
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.8	12.7	0.0	82.5	29.28	1.708	139.9	YES

Gas Analysis Data

Run Number	SAM U-00001 Base-3		**Date**	02/19/20	**Run Start Time**	14:32	**Run Stop Time**	16:32
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.8	12.7	0.0	82.5	29.28	1.708	139.9	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/17/20
Sampling Location	U-00001 Base	**Operator**	Atlas Melchert
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	1

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	02/17/20	500	499.7	-0.3	Pass
Test Day 2	02/18/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		SAM U-00001 Base-1		**Date**	02/18/20	**Start Time**	02:03	**Stop Time**	04:03
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	42.320	dcf		**Barometric Pressure**	(P_b)	29.98	in Hg
Average Stack Temp		$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	89	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	784.40	711.30	616.50	932.20				
Initial Value	(V_i),(W_i)	716.30	708.00	616.20	926.30				
Net Value	(V_n),(W_n)	68.1	3.3	0.3	5.9				
Results									
Total Weight		(W_t)	77.60	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.659	scf
Std Meter Volume		($V_{m(std)}$)	40.232	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	8.34	%		**Final Moisture Content**	(B_{ws})		%

Moisture Content Data									
Run Number		SAM U-00001 Base-2		**Date**	02/18/20	**Start Time**	04:57	**Stop Time**	06:57
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	42.320	dcf		**Barometric Pressure**	(P_b)	29.88	in Hg
Average Stack Temp		$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	90	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	856.70	712.70	616.60	937.50				
Initial Value	(V_i),(W_i)	784.40	711.30	616.50	932.20				
Net Value	(V_n),(W_n)	72.3	1.4	0.1	5.3				
Results									
Total Weight		(W_t)	79.10	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.730	scf
Std Meter Volume		($V_{m(std)}$)	39.975	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	8.53	%		**Final Moisture Content**	(B_{ws})		%

Moisture Content Data									
Run Number		SAM U-00001 Base-3		**Date**	02/19/20	**Start Time**	14:32	**Stop Time**	16:32
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	42.320	dcf		**Barometric Pressure**	(P_b)	30.12	in Hg
Average Stack Temp		$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	101	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	788.70	734.50	614.50	963.50				
Initial Value	(V_i),(W_i)	732.80	731.30	614.40	957.40				
Net Value	(V_n),(W_n)	55.9	3.2	0.1	6.1				
Results									
Total Weight		(W_t)	65.30	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.079	scf
Std Meter Volume		($V_{m(std)}$)	39.506	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	7.23	%		**Final Moisture Content**	(B_{ws})		%

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Date	02/18/20
Operator	Atlas Melchert
Run Number	SAM U-00001 Base-1

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	88.6	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	29.98	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.05	in Hg
Absolute Meter Pressure	(P_m)	30.11	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	02:03	**End**	04:03

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	716.3	708.0	616.2	926.3				
Post	784.4	711.3	616.5	932.2				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	564.120	--	0.342	0.34	--	350	500	44	62	--	80	80	1.5			1.781		42.751
A-2	5.0	00:05:00	565.964	--	0.342	0.34	--	350	511	43	77	--	83	79	1.3			3.533		42.401
A-3	10.0	00:10:00	567.782	--	0.342	0.34	--	350	522	42	92	--	86	78	1.1			5.351		42.810
A-4	15.0	00:15:00	569.671	--	0.342	0.34	--	350	533	42	107	--	91	79	1.0			7.030		42.183
A-5	20.0	00:20:00	571.426	--	0.342	0.34	--	350	531	42	109	--	92	79	1.0			8.700		41.758
A-6	25.0	00:25:00	573.171	--	0.342	0.34	--	350	529	42	111	--	93	79	1.0			10.393		41.572
A-7	30.0	00:30:00	574.944	--	0.342	0.34	--	350	527	42	114	--	94	81	1.0			12.048		41.306
A-8	35.0	00:35:00	576.681	--	0.342	0.34	--	350	526	41	111	--	94	81	1.0			13.702		41.106
A-9	40.0	00:40:00	578.418	--	0.342	0.34	--	350	525	40	108	--	94	81	1.0			15.374		40.996
A-10	45.0	00:45:00	580.172	--	0.342	0.34	--	350	526	39	106	--	96	82	1.0			17.015		40.836
A-11	50.0	00:50:00	581.900	--	0.342	0.34	--	350	524	39	106	--	96	82	1.0			18.665		40.724
A-12	55.0	00:55:00	583.637	--	0.342	0.34	--	350	522	39	106	--	96	82	1.0			20.298		40.596
A-13	60.0	01:00:00	585.356	--	0.342	0.34	--	350	522	40	108	--	97	84	1.0			21.961		40.543
A-14	65.0	01:05:00	587.111	--	0.342	0.34	--	350	526	40	107	--	97	84	1.0			23.623		40.497
A-15	70.0	01:10:00	588.866	--	0.342	0.34	--	350	530	40	106	--	97	84	1.0			25.303		40.484
A-16	75.0	01:15:00	590.638	--	0.342	0.34	--	350	536	40	107	--	99	85	1.0			26.961		40.441
A-17	80.0	01:20:00	592.393	--	0.342	0.34	--	350	535	40	106	--	98	85	1.0			28.620		40.405
A-18	85.0	01:25:00	594.148	--	0.342	0.34	--	350	534	40	105	--	97	85	1.0			30.298		40.397
A-19	90.0	01:30:00	595.920	--	0.342	0.34	--	350	533	40	106	--	98	86	1.0			31.948		40.355
A-20	95.0	01:35:00	597.666	--	0.342	0.34	--	350	528	40	106	--	98	86	1.0			33.597		40.317
A-21	100.0	01:40:00	599.412	--	0.342	0.34	--	350	523	40	106	--	98	86	1.0			35.255		40.292
A-22	105.0	01:45:00	601.167	--	0.342	0.34	--	350	520	40	107	--	98	86	1.0			36.913		40.269
A-23	110.0	01:50:00	602.922	--	0.342	0.34	--	350	520	40	107	--	98	86	1.0			38.571		40.248
A-24	115.0	01:55:00	604.676	--	0.342	0.34	--	350	520	40	107	--	98	86	1.0			40.238		40.238
Last Pt	120.0	02:00:00	606.440																	
Final Val	120.0	02:00:00	606.440											**Max Vac**	1.5	**Final Values**		40.238		
Average Values						0.34		350	525	41	104		95	83						
													89							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Date	02/18/20
Operator	Atlas Melchert
Run Number	SAM U-00001 Base-2

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	90.3	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.34	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	29.88	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	29.95	in Hg
Absolute Meter Pressure	(P_m)	30.01	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	04:57	**End**	06:57

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	784.4	711.3	616.5	932.2				
Post	856.7	712.7	616.6	937.5				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	617.900	--	0.342	0.34	--	350	511	38	62	--	84	83	1.5			1.681		40.338
A-2	5.0	00:05:00	619.657	--	0.342	0.34	--	350	510	37	70	--	87	83	1.3			3.357		40.283
A-3	10.0	00:10:00	621.415	--	0.342	0.34	--	350	509	36	78	--	90	83	1.1			5.046		40.365
A-4	15.0	00:15:00	623.190	--	0.342	0.34	--	350	509	36	88	--	94	83	1.0			6.702		40.215
A-5	20.0	00:20:00	624.938	--	0.342	0.34	--	350	506	36	89	--	94	83	1.0			8.368		40.166
A-6	25.0	00:25:00	626.696	--	0.342	0.34	--	350	503	36	90	--	94	83	1.0			10.033		40.133
A-7	30.0	00:30:00	628.453	--	0.342	0.34	--	350	502	36	92	--	96	84	1.0			11.694		40.094
A-8	35.0	00:35:00	630.210	--	0.342	0.34	--	350	504	36	91	--	96	84	1.0			13.355		40.065
A-9	40.0	00:40:00	631.968	--	0.342	0.34	--	350	506	36	90	--	96	84	1.0			15.025		40.065
A-10	45.0	00:45:00	633.734	--	0.342	0.34	--	350	508	36	89	--	97	84	1.0			16.684		40.041
A-11	50.0	00:50:00	635.491	--	0.342	0.34	--	350	510	36	90	--	97	84	1.0			18.343		40.022
A-12	55.0	00:55:00	637.249	--	0.342	0.34	--	350	512	36	91	--	97	84	1.0			20.011		40.022
A-13	60.0	01:00:00	639.015	--	0.342	0.34	--	350	514	36	92	--	98	85	1.0			21.668		40.002
A-14	65.0	01:05:00	640.772	--	0.342	0.34	--	350	509	36	92	--	98	85	1.0			23.332		39.998
A-15	70.0	01:10:00	642.539	--	0.342	0.34	--	350	504	36	92	--	98	85	1.0			24.980		39.969
A-16	75.0	01:15:00	644.287	--	0.342	0.34	--	350	501	36	93	--	98	86	1.0			26.661		39.991
A-17	80.0	01:20:00	646.071	--	0.342	0.34	--	350	509	36	92	--	98	86	1.0			28.333		39.999
A-18	85.0	01:25:00	647.847	--	0.342	0.34	--	350	517	36	91	--	98	86	1.0			30.021		40.028
A-19	90.0	01:30:00	649.640	--	0.342	0.34	--	350	527	36	90	--	99	86	1.0			31.675		40.010
A-20	95.0	01:35:00	651.397	--	0.342	0.34	--	350	524	36	91	--	99	86	1.0			33.328		39.994
A-21	100.0	01:40:00	653.155	--	0.342	0.34	--	350	521	36	92	--	99	86	1.0			34.981		39.979
A-22	105.0	01:45:00	654.912	--	0.342	0.34	--	350	520	36	93	--	99	86	1.0			36.643		39.975
A-23	110.0	01:50:00	656.678	--	0.342	0.34	--	350	520	36	93	--	99	86	1.0			38.305		39.971
A-24	115.0	01:55:00	658.445	--	0.342	0.34	--	350	520	36	93	--	99	86	1.0			39.976		39.976
Last Pt	120.0	02:00:00	660.220																	
Final Val	120.0	02:00:00	660.220											**Max Vac**	1.5	**Final Values**		39.976		
Average Values						0.34		350	512	36	89		96	85						
													90							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Date	02/19/20
Operator	Atlas Melchert
Run Number	SAM U-00001 Base-3

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	101.3	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.33	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.12	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.19	in Hg
Absolute Meter Pressure	(P_m)	30.25	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	14:32	**End**	16:32

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	732.8	731.3	614.4	957.4				
Post	788.7	734.5	614.5	963.5				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	837.110	--	0.342	0.34	--	350	500	46	71	--	93	92	1.5			1.675		40.203
A-2	5.0	00:05:00	838.876	--	0.342	0.34	--	350	515	48	80	--	95	92	1.5			3.339		40.067
A-3	10.0	00:10:00	840.634	--	0.342	0.34	--	350	530	50	89	--	97	92	1.5			5.025		40.197
A-4	15.0	00:15:00	842.418	--	0.342	0.34	--	350	547	54	100	--	101	92	1.5			6.663		39.977
A-5	20.0	00:20:00	844.157	--	0.342	0.34	--	350	544	54	102	--	102	92	1.5			8.308		39.877
A-6	25.0	00:25:00	845.906	--	0.342	0.34	--	350	541	54	104	--	103	92	1.5			9.951		39.805
A-7	30.0	00:30:00	847.655	--	0.342	0.34	--	350	538	56	108	--	106	94	1.5			11.604		39.785
A-8	35.0	00:35:00	849.421	--	0.342	0.34	--	350	538	55	107	--	106	94	1.5			13.248		39.745
A-9	40.0	00:40:00	851.178	--	0.342	0.34	--	350	538	54	106	--	106	94	1.5			14.909		39.758
A-10	45.0	00:45:00	852.954	--	0.342	0.34	--	350	540	55	105	--	108	96	1.5			16.548		39.715
A-11	50.0	00:50:00	854.711	--	0.342	0.34	--	350	538	56	108	--	108	96	1.5			18.187		39.680
A-12	55.0	00:55:00	856.468	--	0.342	0.34	--	350	536	57	111	--	108	96	1.5			19.833		39.667
A-13	60.0	01:00:00	858.235	--	0.342	0.34	--	350	534	60	115	--	110	97	1.5			21.476		39.648
A-14	65.0	01:05:00	860.001	--	0.342	0.34	--	350	534	59	115	--	110	97	1.5			23.110		39.617
A-15	70.0	01:10:00	861.758	--	0.342	0.34	--	350	534	58	115	--	110	97	1.5			24.761		39.617
A-16	75.0	01:15:00	863.534	--	0.342	0.34	--	350	536	59	115	--	111	98	1.5			26.392		39.588
A-17	80.0	01:20:00	865.291	--	0.342	0.34	--	350	535	59	116	--	111	98	1.5			28.032		39.574
A-18	85.0	01:25:00	867.057	--	0.342	0.34	--	350	534	59	117	--	111	98	1.5			29.671		39.561
A-19	90.0	01:30:00	868.824	--	0.342	0.34	--	350	535	60	120	--	111	99	1.5			31.309		39.548
A-20	95.0	01:35:00	870.590	--	0.342	0.34	--	350	535	60	119	--	111	99	1.5			32.947		39.537
A-21	100.0	01:40:00	872.356	--	0.342	0.34	--	350	535	60	118	--	111	99	1.5			34.594		39.535
A-22	105.0	01:45:00	874.131	--	0.342	0.34	--	350	535	61	119	--	111	99	1.5			36.232		39.525
A-23	110.0	01:50:00	875.897	--	0.342	0.34	--	350	535	61	119	--	111	99	1.5			37.870		39.516
A-24	115.0	01:55:00	877.664	--	0.342	0.34	--	350	535	61	119	--	111	99	1.5			39.508		39.508
Last Pt	120.0	02:00:00	879.430																	
Final Val	120.0	02:00:00	879.430											**Max Vac**	1.5	**Final Values**		39.508		
Average Values						0.34		350	534	57	108		107	96						
													101							

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base Load
Opacity

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

Duct Burners

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): bcc-19-cricketvalley.ny Start #1 | Page 1 of 2

Continued on Form Number (AHI Project Code): bcc-19-cricketvalley.ny-Start #1

Company Name	Bechtel corporation
Facility Name	Cricket valley Energy center
Street Address	2241 NY-22
City	Wingdale
State	NY
Zip	12594

Process	Combined Cycle
Unit #	1
Operating Mode	
Control Equipment	
Operating Mode	


Describe Emissions Point: top of unit one

Height of Emiss. Pt. Start	300 ft	End 300 ft	Height of Emiss. Pt. Rel. to Observer Start 300 ft End 300 ft
Distance to Emiss. Pt. Start	900 ft	End 900 ft	Direction to Emiss. Pt. (Degrees) Start 7° N End 7° N
Vetical Angle to Obs. Pt. Start	30°	End 30°	Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start	900 ft 189°S	End	900 ft 189°S

Describe Emissions Start	N/A	End N/A	
Emission Color Start	N/A	End N/A	Water Droplet Plume Start N/A End N/A

Describe Plume Background Start	blue	End blue	
Background Color Start	blue	End blue	Sky Conditions Start clear End clear
Wind Speed Start	1-4 mph	End 1-5mph	Wind Direction Start SSE End SSE
Ambient Temp. Start	49.6	End 49.8	Wet Bulb Temp. 40.5 RH Percent 39.3

Source Layout Sketch



Latitude	Longitude	Declination
41.6711	-73.5790	

Additional Information:

Min \ Sec	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print)	Matt Jones
Observer's Signature	Matt Jones — Date 2/17/20
Organization	Air Hygiene
Certified By	CAA — Date 1/3/20

3

Duct Burners

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 2241 NY-22
City: Wingdale | State: NY | Zip: 12594

Process: combined cycle | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:


Describe Emissions Point: top of unit one
Height of Emiss. Pt. Start: 300 ft End: 300 ft | Height of Emiss. Pt. Rel. to Observer Start: 300 ft End: 300 ft
Distance to Emiss. Pt. Start: 900 ft End: 900 ft | Direction to Emiss. Pt. (Degrees) Start: 70° N End: 70° N

Vertical Angle to Obs. Pt. Start: 30° End: 30° | Direction to Obs. Pt. (Degrees) Start: 189°S End: 189°S
Distance and Direction to Observation Point from Emission Point Start: 900 ft 189°S End: 900 ft 189°S

Describe Emissions Start: N/A End: N/A
Emission Color Start: N/A End: N/A | Water Droplet Plume Start: N/A End: N/A

Describe Plume Background Start: blue End: blue
Background Color Start: blue End: blue | Sky Conditions Start: clear End: clear
Wind Speed Start: 1.5 mph End: 2 mph | Wind Direction Start: SSE End: SSE
Ambient Temp. Start: 49.6 End: 48.2 | Wet Bulb Temp.: 40.6 | RH Percent: 41.9

Source Layout Sketch



Latitude: 41.6711 | Longitude: -73.5790 | Declination:

Additional Information:

Form Number (AHI Project Code): bec-19-cricketvalley,NY-start#1 | Page 2 of 2
Continued on Form Number (AHI Project Code): bec-19-cricketvalley,NY-start#1
Observation Date: 02/17/2020 | Time Zone: EST | Start Time: 1300 | End Time: 1330

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24		0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): matt Jones
Observer's Signature: [signature] | Date: 2/17/20
Organization: Air Hygiene
Certified By: CAA | Date: 1/3/20

Duct Burners

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 2241 NY-22
City: Wingdale State: NY Zip: 12594

Process: Combined Cycle Unit #: 1 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Point: Top of unit one
Height of Emiss. Pt. Start: 300 ft End: 300 ft
Height of Emiss. Pt. Rel. to Observer Start: 300 ft End: 300 ft
Distance to Emiss. Pt. Start: 900 ft End: 900 ft
Direction to Emiss. Pt. (Degrees) Start: 70W End: 70W

Vertical Angle to Obs. Pt. Start: 30° End: 30°
Direction to Obs. Pt. (Degrees) Start: 189°S End: 189°S
Distance and Direction to Observation Point from Emission Point Start: 900 ft 189°S End: 900 ft 189°S

Describe Emissions Start: N/A End: N/A
Emission Color Start: N/A End: N/A
Water Droplet Plume Start: N/A End: N/A

Describe Plume Background Start: blue End: blue
Background Color Start: blue End: blue
Sky Conditions Start: clear End: clear
Wind Speed Start: 3mph End: 3mph
Wind Direction Start: SSE End: SSE
Ambient Temp. Start: 44.9 End: 45.2
Wet Bulb Temp.: 40.3
RH Percent: 32.0

Source Layout Sketch



Latitude: 41.6711 Longitude: -73.5790 Declination:

Additional Information:

Form Number (AHI Project Code): bec-19 cricketValley, NY-Start #1 Page 1 of 2
Continued on Form Number (AHI Project Code): bec-19-cricket valley, NY-Start #1
Observation Date: 07/17/2020 Time Zone: EST Start Time: 1332 End Time: 1402

Sec / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Matt Jones
Observer's Signature: Date: 7/17/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/20

Duct Burners

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 2241 NY-22
City: Wingdale | State: NY | Zip: 12594

Process: Combined Cycle | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:


Describe Emissions Point: Top of unit 1
Height of Emiss. Pt. Start: 300 Ft End: 300 ft
Height of Emiss. Pt. Rel. to Observer Start: 300 ft End: 300 ft
Distance to Emiss. Pt. Start: 900 ft End: 900 ft
Direction to Emiss. Pt. (Degrees) Start: 70°N End: 70°N

Vertical Angle to Obs. Pt. Start: 30° End: 30°
Direction to Obs. Pt. (Degrees) Start: 189°S End: 189°S
Distance and Direction to Observation Point from Emission Point Start: 900 ft 189°S End: 900 ft 189°S

Describe Emissions Start: N/A End: N/A
Emission Color Start: N/A End: N/A
Water Droplet Plume Start: N/A End: N/A

Describe Plume Background Start: blue End: blue
Background Color Start: blue End: blue
Sky Conditions Start: clear End: clear
Wind Speed Start: 3.5 mph End: 4 mph
Wind Direction Start: SSE End: SSE
Ambient Temp. Start: 47.2 End: 45.6
Wet Bulb Temp.: 41.5
RH Percent: 29.2

Source Layout Sketch



Latitude: 41.671 | Longitude: -73.579 | Declination:

Additional Information:

Form Number (AHI Project Code): bec-19-cricketValley, NY-Stack #1 | Page 2 of 2
Continued on Form Number (AHI Project Code): bec-19-cricketValley, NY-Stack #1
Observation Date: 08/17/2020 | Time Zone: EST | Start Time: 1402 | End Time: 1432

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Matt Jones
Observer's Signature: [signature] | Date: 2/17/20
Organization: Air Hygiene
Certified By: CAA | Date: 1/3/20

Duct Burners

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 7741 NY-22
City: Wingdale State: NY Zip: 12594

Process: Combined Cycle Unit #: 1 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Point: Top of unit one
Height of Emiss. Pt. Start: 300 ft End: 300 ft
Height of Emiss. Pt. Rel. to Observer Start: 300 ft End: 300 ft
Distance to Emiss. Pt. Start: 900 ft End: 900 ft
Direction to Emiss. Pt. (Degrees) Start: 70°N End: 70°N

Vertical Angle to Obs. Pt. Start: 30° End: 30°
Direction to Obs. Pt. (Degrees) Start: 189°S End: 189°S
Distance and Direction to Observation Point from Emission Point Start: 900 ft 189°S End: 900 ft 189°S

Describe Emissions Start: N/A End: N/A
Emission Color Start: N/A End: N/A
Water Droplet Plume Start: N/A End: N/A

Describe Plume Background Start: blue End: blue
Background Color Start: blue End: blue
Sky Conditions Start: clear End: clear
Wind Speed Start: 4.1 mph End: 3.8 mph
Wind Direction Start: SSE End: SSE
Ambient Temp. Start: 58.5 End: 51.1
Wet Bulb Temp.: 37.9
RH Percent: 38.4

Source Layout Sketch



Latitude: 41.6711 Longitude: -73.5740 Declination: N/A

Additional Information:

Form Number (AHI Project Code): bec-19-CricketValley,NY-Start #1 Page 1 of 2
Continued on Form Number (AHI Project Code): bec-19-CricketValley,NY-Start #1
Observation Date: 02/17/2020 Time Zone: EST Start Time: 1435 End Time: 1505

Min \ Sec	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Matt Jones
Observer's Signature: [signature] Date: 2/17/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/20

Duct Burners

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 2241 NY-22
City: Wingdale | State: NY | Zip: 12594

Process: Combined Cycle | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:

Describe Emissions Point: Top of unit ore


Height of Emiss. Pt. Start 300 Ft End 300 Ft
Height of Emiss. Pt. Rel. to Observer Start 300 Ft End 300 Ft
Distance to Emiss. Pt. Start 900 Ft End 900 Ft
Direction to Emiss. Pt. (Degrees) Start 7° W End 7° W

Vertical Angle to Obs. Pt. Start 30° End 30°
Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 Ft 189°S End 900 Ft 189°S

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A
Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue
Sky Conditions Start clear End clear
Wind Speed Start 4 mph End 4.4 mph
Wind Direction Start SSE End SSE
Ambient Temp. Start 51.1 End 51.4
Wet Bulb Temp. 37.9
RH Percent 36.5

Source Layout Sketch



Latitude 41.6711 | Longitude -73.5790 | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): Dec-19-CricketValley.NY-Stack #1 | Page 2 of 2
Continued on Form Number (AHI Project Code): Dec-19-CricketValley.NY-Stack #1
Observation Date: 01/17/2020 | Time Zone: EST | Start Time: 1505 | End Time: 1535

Min \ Sec	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Matt Jones
Observer's Signature: [signature] | Date: 1/17/20
Organization: Air Hygiene
Certified By: CAA | Date: 1/3/20

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
NOx, CO, VOC, and NH_3

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,643	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,016	Btu/SCF fuel
Turbine Fuel Flow	1,668	lb/min
Duct Burner Fuel Flow	158	lb/min
Total Fuel Flow	2,468,984	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.07	in. Hg
Relative Humidity	81	%
Ambient Temperature	37	° F
Specific Humidity	0.003714	lb H_2O / lb air

Unit Data

Unit Load	240.9	megawatts
Heat Input	2,508	MMBtu/hr
NH_3 Flow Rate	200	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,278,069	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/19/20 4:25:06	1640	11.72	2.69	0.00	0.00	5.11	0.88
02/19/20 4:25:36	1670	11.72	2.70	0.00	0.00	5.11	0.88
02/19/20 4:26:06	1700	11.72	2.69	0.00	0.00	5.11	0.87
02/19/20 4:26:36	1730	11.72	2.69	0.00	0.00	5.11	0.74
02/19/20 4:27:06	1760	11.72	2.69	0.00	0.00	5.11	0.81
02/19/20 4:27:36	1790	11.72	2.69	0.00	0.00	5.12	0.80
02/19/20 4:28:06	1820	11.71	2.67	0.00	0.00	5.12	0.83
02/19/20 4:28:36	1850	11.71	2.65	0.00	0.00	5.12	0.87
02/19/20 4:29:06	1880	11.71	2.61	0.00	0.00	5.12	0.81
02/19/20 4:29:36	1910	11.71	2.58	0.00	0.00	5.12	0.84
02/19/20 4:30:06	1940	11.71	2.58	0.00	0.00	5.12	0.79
02/19/20 4:30:36	1970	11.71	2.59	0.00	0.00	5.12	0.78
02/19/20 4:31:06	2000	11.71	2.60	0.00	0.00	5.12	0.78
02/19/20 4:31:36	2030	11.71	2.59	0.00	0.00	5.12	0.82
02/19/20 4:32:06	2060	11.71	2.56	0.00	0.00	5.12	0.80
02/19/20 4:32:36	2090	11.71	2.52	0.00	0.00	5.12	0.82
02/19/20 4:33:06	2120	11.70	2.51	0.00	0.00	5.12	0.77
02/19/20 4:33:36	2150	11.70	2.50	0.00	0.00	5.12	0.74
02/19/20 4:34:06	2180	11.70	2.47	0.00	0.00	5.12	0.69
02/19/20 4:34:36	2210	11.70	2.45	0.00	0.00	5.12	0.76
02/19/20 4:35:06	2240	11.71	2.47	0.00	0.00	5.12	0.79
02/19/20 4:35:36	2270	11.70	2.47	0.00	0.00	5.12	0.74
02/19/20 4:36:06	2300	11.70	2.46	0.00	0.00	5.12	0.72
02/19/20 4:36:36	2330	11.70	2.45	0.00	0.00	5.12	0.72
02/19/20 4:37:06	2360	11.69	2.47	0.00	0.00	5.12	0.67
02/19/20 4:37:36	2390	11.70	2.48	0.00	0.00	5.13	0.67
02/19/20 4:38:06	2420	11.69	2.48	0.00	0.00	5.13	0.61
02/19/20 4:38:36	2450	11.70	2.49	0.00	0.00	5.13	0.68
02/19/20 4:39:06	2480	11.70	2.49	0.00	0.00	5.13	0.68
02/19/20 4:39:36	2510	11.69	2.50	0.00	0.00	5.12	0.65
02/19/20 4:40:06	2540	11.69	2.51	0.00	0.00	5.13	0.67
02/19/20 4:40:36	2570	11.69	2.51	0.00	0.00	5.13	0.70
02/19/20 4:41:06	2600	11.69	2.51	0.00	0.00	5.13	0.66
02/19/20 4:41:36	2630	11.69	2.53	0.00	0.00	5.13	0.65
02/19/20 4:42:06	2660	11.69	2.56	0.00	0.00	5.13	0.70
02/19/20 4:42:36	2690	11.70	2.59	0.00	0.00	5.13	0.68
02/19/20 4:43:06	2720	11.69	2.60	0.00	0.00	5.13	0.66
02/19/20 4:43:36	2750	11.69	2.62	0.00	0.00	5.13	0.70
02/19/20 4:44:06	2780	11.69	2.63	0.00	0.00	5.13	0.68
02/19/20 4:44:36	2810	11.69	2.64	0.00	0.00	5.13	0.69
02/19/20 4:45:06	2840	11.69	2.64	0.00	0.00	5.13	0.67
02/19/20 4:45:36	2870	11.69	2.63	0.00	0.00	5.13	1.26
02/19/20 4:46:06	2900	11.69	2.65	0.00	0.00	5.13	0.88
02/19/20 4:46:36	2930	11.69	2.67	0.00	0.00	5.13	1.07
02/19/20 4:47:06	2960	11.69	2.66	0.00	0.00	5.13	1.15
02/19/20 4:47:36	2990	11.69	2.66	0.00	0.00	5.13	1.43
02/19/20 4:48:06	3020	11.69	2.66	0.00	0.00	5.13	1.24
02/19/20 4:48:36	3050	11.69	2.66	0.00	0.00	5.14	1.52
02/19/20 4:49:06	3080	11.69	2.68	0.00	0.00	5.13	1.92
02/19/20 4:49:36	3110	11.69	2.68	0.00	0.00	5.13	1.82
02/19/20 4:50:06	3140	11.69	2.66	0.00	0.00	5.13	2.12
02/19/20 4:50:36	3170	11.69	2.64	0.00	0.00	5.13	1.61
02/19/20 4:51:06	3200	11.70	2.63	0.00	0.00	5.13	1.41
02/19/20 4:51:36	3230	11.69	2.61	0.00	0.00	5.13	1.38
02/19/20 4:52:06	3260	11.69	2.61	0.00	0.00	5.13	1.72
02/19/20 4:52:36	3290	11.69	2.61	0.00	0.00	5.13	1.11
02/19/20 4:53:06	3320	11.69	2.61	0.00	0.00	5.13	1.05
02/19/20 4:53:36	3350	11.69	2.61	0.00	0.00	5.13	2.33
02/19/20 4:54:06	3380	11.70	2.61	0.00	0.00	5.14	1.92
02/19/20 4:54:36	3410	11.69	2.61	0.00	0.00	5.13	1.99
02/19/20 4:55:06	3440	11.69	2.60	0.00	0.00	5.14	2.42
02/19/20 4:55:36	3470	11.69	2.60	0.00	0.00	5.14	1.95
02/19/20 4:56:06	3500	11.70	2.58	0.00	0.00	5.14	2.32
02/19/20 4:56:36	3530	11.69	2.57	0.00	0.00	5.14	1.59
02/19/20 4:57:06	3560	11.69	2.58	0.00	0.00	5.14	2.26
02/19/20 4:57:36	3590	11.69	2.58	0.00	0.00	5.13	2.30
02/19/20 4:58:06	3620	11.69	2.58	0.00	0.00	5.14	1.50
02/19/20 4:58:36	3650	11.69	2.57	0.00	0.00	5.13	2.15
02/19/20 4:59:06	3680	11.69	2.57	0.00	0.00	5.13	2.19
02/19/20 4:59:36	3710	11.69	2.56	0.00	0.00	5.14	2.30
02/19/20 5:00:06	3740	11.69	2.53	0.00	0.00	5.14	1.76
02/19/20 5:00:36	3770	11.69	2.51	0.00	0.00	5.13	1.90
02/19/20 5:01:06	3800	11.69	2.53	0.00	0.00	5.14	2.52
02/19/20 5:01:36	3830	11.69	2.54	0.00	0.00	5.14	2.20

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,643	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,016	Btu/SCF fuel
Turbine Fuel Flow	1,668	lb/min
Duct Burner Fuel Flow	158	lb/min
Total Fuel Flow	2,468,984	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.07	in. Hg
Relative Humidity	81	%
Ambient Temperature	37	° F
Specific Humidity	0.003714	lb H_2O / lb air

Unit Data

Unit Load	240.9	megawatts
Heat Input	2,508	MMBtu/hr
NH_3 Flow Rate	200	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,278,069	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/19/20 5:02:06	3860	11.69	2.54	0.00	0.00	5.14	1.38
02/19/20 5:02:36	3890	11.69	2.54	0.00	0.00	5.13	1.92
02/19/20 5:03:06	3920	11.69	2.50	0.00	0.00	5.13	1.85
02/19/20 5:03:36	3950	11.69	2.47	0.00	0.00	5.14	1.25
02/19/20 5:04:06	3980	11.69	2.46	0.00	0.00	5.14	2.74
02/19/20 5:04:36	4010	11.69	2.43	0.00	0.00	5.14	2.22
02/19/20 5:05:06	4040	11.68	2.43	0.00	0.00	5.14	1.80
02/19/20 5:05:36	4070	11.69	2.44	0.00	0.00	5.14	1.26
02/19/20 5:06:06	4100	11.69	2.45	0.00	0.00	5.14	1.13
02/19/20 5:06:36	4130	11.69	2.46	0.00	0.00	5.14	0.94
02/19/20 5:07:06	4160	11.69	2.46	0.00	0.00	5.14	1.97
02/19/20 5:07:36	4190	11.69	2.47	0.00	0.00	5.14	2.39
02/19/20 5:08:06	4220	11.69	2.50	0.00	0.00	5.14	1.96
02/19/20 5:08:36	4250	11.69	2.52	0.00	0.00	5.14	1.69
02/19/20 5:09:06	4280	11.69	2.52	0.00	0.00	5.14	1.31
02/19/20 5:09:36	4310	11.69	2.53	0.00	0.00	5.14	1.69
02/19/20 5:10:06	4340	11.68	2.56	0.00	0.00	5.14	1.80
02/19/20 5:10:36	4370	11.69	2.58	0.00	0.00	5.14	2.13
02/19/20 5:11:06	4400	11.69	2.58	0.00	0.00	5.14	2.37
02/19/20 5:11:36	4430	11.69	2.58	0.00	0.00	5.14	2.26
02/19/20 5:12:06	4460	11.69	2.58	0.00	0.00	5.14	2.14
02/19/20 5:12:36	4490	11.69	2.58	0.00	0.00	5.14	2.08
02/19/20 5:13:06	4520	11.69	2.59	0.00	0.00	5.14	1.64
02/19/20 5:13:36	4550	11.69	2.59	0.00	0.00	5.14	1.27
02/19/20 5:14:06	4580	11.69	2.58	0.00	0.00	5.14	1.52
02/19/20 5:14:36	4610	11.69	2.55	0.00	0.00	5.14	1.48
02/19/20 5:15:06	4640	11.69	2.55	0.00	0.00	5.14	1.91
02/19/20 5:15:36	4670	11.68	2.53	0.00	0.00	5.14	1.24
02/19/20 5:16:06	4700	11.69	2.52	0.00	0.00	5.14	0.98
02/19/20 5:16:36	4730	11.69	2.51	0.00	0.00	5.14	0.94
02/19/20 5:17:06	4760	11.69	2.53	0.00	0.00	5.14	0.92
02/19/20 5:17:36	4790	11.69	2.54	0.00	0.00	5.14	2.48
02/19/20 5:18:06	4820	11.69	2.54	0.00	0.00	5.14	3.92
02/19/20 5:18:36	4850	11.69	2.54	0.00	0.00	5.14	2.75
02/19/20 5:19:06	4880	11.69	2.53	0.00	0.00	5.14	1.63
02/19/20 5:19:36	4910	11.69	2.52	0.00	0.00	5.14	1.88
02/19/20 5:20:06	4940	11.69	2.50	0.00	0.00	5.14	1.89
02/19/20 5:20:36	4970	11.69	2.48	0.00	0.00	5.14	3.25
02/19/20 5:21:06	5000	11.68	2.48	0.00	0.00	5.14	2.62
02/19/20 5:21:36	5030	11.68	2.48	0.00	0.00	5.14	2.19
02/19/20 5:22:06	5060	11.69	2.49	0.00	0.00	5.14	1.60
02/19/20 5:22:36	5090	11.69	2.49	0.00	0.00	5.14	1.89
02/19/20 5:23:06	5120	11.68	2.46	0.00	0.00	5.14	2.03
02/19/20 5:23:36	5150	11.69	2.45	0.00	0.00	5.14	1.40
02/19/20 5:24:06	5180	11.69	2.47	0.00	0.00	5.14	1.30
02/19/20 5:24:36	5210	11.69	2.48	0.00	0.00	5.13	2.00
RAW AVERAGE		**11.69**	**2.56**	**0.00**	**0.00**	**5.13**	**1.45**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0014	inst-nx-0020	inst-co-0045	inst-th-0010	inst-c2-0023	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.03	0.01	0.00	0.00	0.00	
Bias	**Final Zero**	0.01	0.00	0.00	0.00	0.00	
Bias	**Avg. Zero**	0.02	0.01	0.00	0.00	0.00	
Bias	**Initial UpScale**	11.99	8.87	9.08	3.39	9.01	
Bias	**Final UpScale**	12.00	8.99	9.13	3.32	9.03	
Bias	**Avg. UpScale**	12.00	8.93	9.11	3.36	9.02	
Upscale Cal Gas		12.01	8.90	9.10	3.37	8.95	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.71	2.54	0.00	0.00	5.09	1.55
Concentration (ppm@ 15%O_2)	N/A	1.63	0.00	0.00	N/A	1.00

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,643	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,016	Btu/SCF fuel
Turbine Fuel Flow	1,669	lb/min
Duct Burner Fuel Flow	158	lb/min
Total Fuel Flow	2,469,676	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.11	in. Hg
Relative Humidity	72	%
Ambient Temperature	36	° F
Specific Humidity	0.003166	lb H_2O / lb air

Unit Data

Unit Load	241.2	megawatts
Heat Input	2,508	MMBtu/hr
NH_3 Flow Rate	205	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,219,375	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/19/20 5:33:06	440	11.67	2.49	0.00	0.00	5.14	1.41
02/19/20 5:33:36	470	11.67	2.47	0.00	0.00	5.14	1.76
02/19/20 5:34:06	500	11.67	2.45	0.00	0.00	5.14	1.89
02/19/20 5:34:36	530	11.67	2.43	0.00	0.00	5.14	2.64
02/19/20 5:35:06	560	11.68	2.41	0.00	0.00	5.14	2.05
02/19/20 5:35:36	590	11.67	2.42	0.00	0.00	5.14	1.79
02/19/20 5:36:06	620	11.67	2.42	0.00	0.00	5.14	3.38
02/19/20 5:36:36	650	11.67	2.44	0.00	0.00	5.14	3.56
02/19/20 5:37:06	680	11.68	2.44	0.00	0.00	5.14	2.10
02/19/20 5:37:36	710	11.67	2.43	0.00	0.00	5.14	2.19
02/19/20 5:38:06	740	11.68	2.44	0.00	0.00	5.14	2.08
02/19/20 5:38:36	770	11.68	2.45	0.00	0.00	5.14	1.48
02/19/20 5:39:06	800	11.68	2.47	0.00	0.00	5.14	1.65
02/19/20 5:39:36	830	11.68	2.48	0.00	0.00	5.13	1.30
02/19/20 5:40:06	860	11.67	2.49	0.00	0.00	5.13	2.13
02/19/20 5:40:36	890	11.67	2.49	0.00	0.00	5.13	2.41
02/19/20 5:41:06	920	11.67	2.48	0.00	0.00	5.14	2.07
02/19/20 5:41:36	950	11.67	2.50	0.00	0.00	5.14	1.48
02/19/20 5:42:06	980	11.68	2.51	0.00	0.00	5.14	1.18
02/19/20 5:42:36	1010	11.68	2.55	0.00	0.00	5.13	1.60
02/19/20 5:43:06	1040	11.68	2.59	0.00	0.00	5.13	1.67
02/19/20 5:43:36	1070	11.68	2.60	0.00	0.00	5.13	1.31
02/19/20 5:44:06	1100	11.67	2.63	0.00	0.00	5.13	1.18
02/19/20 5:44:36	1130	11.67	2.63	0.00	0.00	5.14	1.28
02/19/20 5:45:06	1160	11.68	2.62	0.00	0.00	5.14	1.84
02/19/20 5:45:36	1190	11.68	2.63	0.00	0.00	5.13	1.64
02/19/20 5:46:06	1220	11.67	2.64	0.00	0.00	5.13	1.18
02/19/20 5:46:36	1250	11.67	2.63	0.00	0.00	5.13	1.10
02/19/20 5:47:06	1280	11.67	2.62	0.00	0.00	5.14	0.97
02/19/20 5:47:36	1310	11.67	2.58	0.00	0.00	5.13	1.42
02/19/20 5:48:06	1340	11.67	2.55	0.00	0.00	5.13	1.34
02/19/20 5:48:36	1370	11.67	2.55	0.00	0.00	5.13	1.75
02/19/20 5:49:06	1400	11.67	2.55	0.00	0.00	5.13	1.13
02/19/20 5:49:36	1430	11.68	2.55	0.00	0.00	5.14	1.43
02/19/20 5:50:06	1460	11.68	2.55	0.00	0.00	5.14	1.61
02/19/20 5:50:36	1490	11.68	2.53	0.00	0.00	5.13	1.67
02/19/20 5:51:06	1520	11.68	2.52	0.00	0.00	5.13	2.15
02/19/20 5:51:36	1550	11.67	2.50	0.00	0.00	5.13	1.33
02/19/20 5:52:06	1580	11.68	2.48	0.00	0.00	5.13	1.04
02/19/20 5:52:36	1610	11.68	2.50	0.00	0.00	5.13	0.90
02/19/20 5:53:06	1640	11.68	2.51	0.00	0.00	5.13	0.93
02/19/20 5:53:36	1670	11.68	2.54	0.00	0.00	5.13	0.90
02/19/20 5:54:06	1700	11.68	2.56	0.00	0.00	5.13	0.85
02/19/20 5:54:36	1730	11.68	2.59	0.00	0.00	5.13	0.85
02/19/20 5:55:06	1760	11.67	2.62	0.00	0.00	5.13	1.25
02/19/20 5:55:36	1790	11.67	2.57	0.00	0.00	5.13	1.20
02/19/20 5:56:06	1820	11.68	2.52	0.00	0.00	5.13	1.70
02/19/20 5:56:36	1850	11.68	2.52	0.00	0.00	5.13	1.33
02/19/20 5:57:06	1880	11.67	2.52	0.00	0.00	5.13	0.99
02/19/20 5:57:36	1910	11.67	2.51	0.00	0.00	5.13	1.00
02/19/20 5:58:06	1940	11.67	2.50	0.00	0.00	5.13	1.31
02/19/20 5:58:36	1970	11.68	2.47	0.00	0.00	5.13	1.84
02/19/20 5:59:06	2000	11.68	2.45	0.00	0.00	5.13	1.69
02/19/20 5:59:36	2030	11.67	2.46	0.00	0.00	5.13	1.50
02/19/20 6:00:06	2060	11.67	2.48	0.00	0.00	5.13	1.66
02/19/20 6:00:36	2090	11.67	2.50	0.00	0.00	5.13	4.33
02/19/20 6:01:06	2120	11.68	2.51	0.00	0.00	5.13	3.14
02/19/20 6:01:36	2150	11.66	2.55	0.00	0.00	5.13	3.10
02/19/20 6:02:06	2180	11.65	2.57	0.00	0.00	5.13	3.07
02/19/20 6:02:36	2210	11.67	2.53	0.00	0.00	5.13	3.02
02/19/20 6:03:06	2240	11.67	2.50	0.00	0.00	5.13	2.70
02/19/20 6:03:36	2270	11.67	2.54	0.00	0.00	5.13	2.20
02/19/20 6:04:06	2300	11.68	2.56	0.00	0.00	5.13	1.36
02/19/20 6:04:36	2330	11.68	2.57	0.00	0.00	5.13	1.27
02/19/20 6:05:06	2360	11.63	2.58	0.00	0.00	5.13	1.51
02/19/20 6:05:36	2390	11.66	2.55	0.00	0.00	5.14	1.52
02/19/20 6:06:06	2420	11.65	2.54	0.00	0.00	5.14	1.27
02/19/20 6:06:36	2450	11.66	2.55	0.00	0.00	5.13	2.08
02/19/20 6:07:06	2480	11.67	2.56	0.00	0.00	5.13	2.56
02/19/20 6:07:36	2510	11.67	2.59	0.00	0.00	5.12	3.35
02/19/20 6:08:06	2540	11.66	2.62	0.00	0.00	5.13	2.55
02/19/20 6:08:36	2570	11.64	2.59	0.00	0.00	5.13	2.20
02/19/20 6:09:06	2600	11.66	2.56	0.00	0.00	5.13	1.59
02/19/20 6:09:36	2630	11.65	2.55	0.00	0.00	5.13	1.19

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,643	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,016	Btu/SCF fuel
Turbine Fuel Flow	1,669	lb/min
Duct Burner Fuel Flow	158	lb/min
Total Fuel Flow	2,469,676	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.11	in. Hg
Relative Humidity	72	%
Ambient Temperature	36	° F
Specific Humidity	0.003166	lb H_2O / lb air

Unit Data

Unit Load	241.2	megawatts
Heat Input	2,508	MMBtu/hr
NH_3 Flow Rate	205	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,219,375	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/19/20 6:10:06	2660	11.65	2.56	0.00	0.00	5.13	1.23
02/19/20 6:10:36	2690	11.66	2.61	0.00	0.00	5.13	1.15
02/19/20 6:11:06	2720	11.66	2.65	0.00	0.00	5.13	1.71
02/19/20 6:11:36	2750	11.67	2.62	0.00	0.00	5.12	1.41
02/19/20 6:12:06	2780	11.68	2.59	0.00	0.00	5.13	2.43
02/19/20 6:12:36	2810	11.63	2.54	0.00	0.00	5.13	2.40
02/19/20 6:13:06	2840	11.65	2.51	0.00	0.00	5.13	2.41
02/19/20 6:13:36	2870	11.67	2.52	0.00	0.00	5.13	2.24
02/19/20 6:14:06	2900	11.67	2.53	0.00	0.00	5.12	2.07
02/19/20 6:14:36	2930	11.67	2.56	0.00	0.00	5.12	1.88
02/19/20 6:15:06	2960	11.67	2.61	0.00	0.00	5.13	1.80
02/19/20 6:15:36	2990	11.67	2.59	0.00	0.00	5.13	2.11
02/19/20 6:16:06	3020	11.68	2.58	0.00	0.00	5.13	2.19
02/19/20 6:16:36	3050	11.67	2.58	0.00	0.00	5.13	4.69
02/19/20 6:17:06	3080	11.68	2.58	0.00	0.00	5.13	2.68
02/19/20 6:17:36	3110	11.67	2.57	0.00	0.00	5.13	2.67
02/19/20 6:18:06	3140	11.68	2.56	0.00	0.00	5.13	2.16
02/19/20 6:18:36	3170	11.68	2.53	0.00	0.00	5.13	2.16
02/19/20 6:19:06	3200	11.68	2.51	0.00	0.00	5.13	2.40
02/19/20 6:19:36	3230	11.68	2.51	0.00	0.00	5.13	2.12
02/19/20 6:20:06	3260	11.65	2.53	0.00	0.00	5.13	2.21
02/19/20 6:20:36	3290	11.67	2.54	0.00	0.00	5.13	2.01
02/19/20 6:21:06	3320	11.68	2.56	0.00	0.00	5.13	2.20
02/19/20 6:21:36	3350	11.68	2.59	0.00	0.00	5.12	3.26
02/19/20 6:22:06	3380	11.68	2.61	0.00	0.00	5.12	2.47
02/19/20 6:22:36	3410	11.68	2.60	0.00	0.00	5.13	2.33
02/19/20 6:23:06	3440	11.68	2.60	0.00	0.00	5.13	1.98
02/19/20 6:23:36	3470	11.69	2.60	0.00	0.00	5.13	2.02
02/19/20 6:24:06	3500	11.69	2.59	0.00	0.00	5.13	3.56
02/19/20 6:24:36	3530	11.69	2.58	0.00	0.00	5.13	2.29
02/19/20 6:25:06	3560	11.70	2.58	0.00	0.00	5.13	2.45
02/19/20 6:25:36	3590	11.63	2.57	0.00	0.00	5.13	2.39
02/19/20 6:26:06	3620	11.63	2.56	0.00	0.00	5.13	1.98
02/19/20 6:26:36	3650	11.66	2.60	0.00	0.00	5.14	2.17
02/19/20 6:27:06	3680	11.66	2.62	0.00	0.00	5.13	2.15
02/19/20 6:27:36	3710	11.67	2.63	0.00	0.00	5.12	3.42
02/19/20 6:28:06	3740	11.66	2.66	0.00	0.00	5.12	2.32
02/19/20 6:28:36	3770	11.67	2.70	0.00	0.00	5.12	2.37
02/19/20 6:29:06	3800	11.67	2.73	0.00	0.00	5.12	2.01
02/19/20 6:29:36	3830	11.68	2.66	0.00	0.00	5.12	3.07
02/19/20 6:30:06	3860	11.67	2.60	0.00	0.00	5.13	2.89
02/19/20 6:30:36	3890	11.62	2.60	0.00	0.00	5.12	2.48
02/19/20 6:31:06	3920	11.64	2.60	0.00	0.00	5.13	2.66
02/19/20 6:31:36	3950	11.67	2.60	0.00	0.00	5.14	2.41
02/19/20 6:32:06	3980	11.66	2.61	0.00	0.00	5.12	2.47
02/19/20 6:32:36	4010	11.68	2.65	0.00	0.00	5.12	1.84
RAW AVERAGE		**11.67**	**2.55**	**0.00**	**0.00**	**5.13**	**1.99**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0014	inst-nx-0020	inst-co-0045	inst-th-0010	inst-c2-0023	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.01	0.00	0.00	0.00	0.00	
Bias	**Final Zero**	0.02	0.00	0.00	0.00	0.00	
Bias	**Avg. Zero**	0.02	0.00	0.00	0.00	0.00	
Bias	**Initial UpScale**	12.00	8.99	9.13	3.32	9.03	
Bias	**Final UpScale**	11.97	8.86	9.08	3.40	8.98	
Bias	**Avg. UpScale**	11.99	8.93	9.11	3.36	9.01	
Upscale Cal Gas		12.01	8.90	9.10	3.37	8.95	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.69	2.54	0.00	0.00	5.10	2.13
Concentration (ppm@ 15%O_2)	N/A	1.63	0.00	0.00	N/A	1.36

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,643	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,016	Btu/SCF fuel
Turbine Fuel Flow	1,673	lb/min
Duct Burner Fuel Flow	158	lb/min
Total Fuel Flow	2,474,805	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.15	in. Hg
Relative Humidity	70	%
Ambient Temperature	34	° F
Specific Humidity	0.002837	lb H_2O / lb air

Unit Data

Unit Load	241.5	megawatts
Heat Input	2,514	MMBtu/hr
NH_3 Flow Rate	207	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	48,739,716	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/19/20 6:41:06	320	11.57	2.49	0.21	0.00	5.02	2.44
02/19/20 6:41:36	350	11.56	2.47	0.21	0.00	5.02	2.04
02/19/20 6:42:06	380	11.57	2.45	0.15	0.00	5.02	2.29
02/19/20 6:42:36	410	11.57	2.40	0.17	0.00	5.02	3.62
02/19/20 6:43:06	440	11.54	2.37	0.25	0.00	5.02	3.26
02/19/20 6:43:36	470	11.56	2.38	0.22	0.00	5.02	2.83
02/19/20 6:44:06	500	11.57	2.42	0.21	0.00	5.02	2.64
02/19/20 6:44:36	530	11.57	2.33	0.22	0.00	5.02	2.33
02/19/20 6:45:06	560	11.55	2.28	0.26	0.00	5.02	2.62
02/19/20 6:45:36	590	11.56	2.33	0.14	0.00	5.02	2.52
02/19/20 6:46:06	620	11.56	2.44	0.16	0.00	5.01	2.23
02/19/20 6:46:36	650	11.57	2.47	0.23	0.00	5.02	2.63
02/19/20 6:47:06	680	11.57	2.57	0.26	0.00	5.02	1.87
02/19/20 6:47:36	710	11.58	2.57	0.23	0.00	5.02	2.42
02/19/20 6:48:06	740	11.57	2.51	0.22	0.00	5.02	3.60
02/19/20 6:48:36	770	11.58	2.43	0.19	0.00	5.02	2.70
02/19/20 6:49:06	800	11.58	2.42	0.23	0.00	5.02	2.53
02/19/20 6:49:36	830	11.58	2.34	0.19	0.00	5.02	2.92
02/19/20 6:50:06	860	11.58	2.33	0.25	0.00	5.02	3.57
02/19/20 6:50:36	890	11.55	2.32	0.21	0.00	5.02	3.09
02/19/20 6:51:06	920	11.57	2.37	0.26	0.00	5.02	2.81
02/19/20 6:51:36	950	11.57	2.51	0.23	0.00	5.02	3.43
02/19/20 6:52:06	980	11.58	2.24	0.23	0.00	5.02	4.65
02/19/20 6:52:36	1010	11.58	2.17	0.26	0.00	5.02	2.78
02/19/20 6:53:06	1040	11.58	2.26	0.18	0.00	5.02	2.66
02/19/20 6:53:36	1070	11.55	2.39	0.21	0.00	5.02	2.58
02/19/20 6:54:06	1100	11.55	2.53	0.24	0.00	5.02	2.51
02/19/20 6:54:36	1130	11.57	2.71	0.26	0.00	5.01	2.37
02/19/20 6:55:06	1160	11.57	2.75	0.19	0.00	5.02	2.44
02/19/20 6:55:36	1190	11.54	2.65	0.25	0.00	5.02	2.60
02/19/20 6:56:06	1220	11.51	2.63	0.27	0.00	5.02	2.26
02/19/20 6:56:36	1250	11.55	2.75	0.28	0.00	5.00	1.72
02/19/20 6:57:06	1280	11.54	2.70	0.22	0.00	5.01	2.88
02/19/20 6:57:36	1310	11.53	2.54	0.27	0.00	5.01	2.88
02/19/20 6:58:06	1340	11.55	2.53	0.17	0.00	5.01	2.63
02/19/20 6:58:36	1370	11.55	2.46	0.19	0.00	5.02	2.20
02/19/20 6:59:06	1400	11.57	2.46	0.17	0.00	5.02	2.41
02/19/20 6:59:36	1430	11.57	2.44	0.32	0.00	5.02	2.03
02/19/20 7:00:06	1460	11.57	2.31	0.24	0.00	5.02	2.14
02/19/20 7:00:36	1490	11.57	2.31	0.24	0.00	5.02	2.05
02/19/20 7:01:06	1520	11.57	2.33	0.29	0.00	5.02	1.96
02/19/20 7:01:36	1550	11.55	2.43	0.24	0.00	5.02	2.28
02/19/20 7:02:06	1580	11.54	2.53	0.23	0.00	5.02	1.96
02/19/20 7:02:36	1610	11.56	2.60	0.31	0.00	5.01	2.16
02/19/20 7:03:06	1640	11.53	2.59	0.34	0.00	5.01	1.91
02/19/20 7:03:36	1670	11.56	2.54	0.28	0.00	5.01	2.36
02/19/20 7:04:06	1700	11.56	2.54	0.29	0.00	5.02	1.68
02/19/20 7:04:36	1730	11.57	2.41	0.32	0.00	5.02	2.41
02/19/20 7:05:06	1760	11.57	2.37	0.22	0.00	5.02	1.88
02/19/20 7:05:36	1790	11.57	2.30	0.33	0.00	5.02	2.00
02/19/20 7:06:06	1820	11.58	2.27	0.28	0.00	5.02	2.05
02/19/20 7:06:36	1850	11.57	2.27	0.29	0.00	5.02	1.67
02/19/20 7:07:06	1880	11.57	2.28	0.31	0.00	5.02	2.09
02/19/20 7:07:36	1910	11.52	2.32	0.29	0.00	5.03	1.64
02/19/20 7:08:06	1940	11.54	2.47	0.28	0.00	5.01	2.26
02/19/20 7:08:36	1970	11.55	2.62	0.33	0.00	5.02	1.94
02/19/20 7:09:06	2000	11.56	2.64	0.24	0.00	5.02	1.93
02/19/20 7:09:36	2030	11.55	2.71	0.31	0.00	5.02	2.07
02/19/20 7:10:06	2060	11.54	2.85	0.31	0.00	5.02	1.64
02/19/20 7:10:36	2090	11.55	2.92	0.34	0.00	5.02	1.67
02/19/20 7:11:06	2120	11.56	2.82	0.25	0.00	5.02	1.34
02/19/20 7:11:36	2150	11.53	2.63	0.39	0.00	5.02	1.17
02/19/20 7:12:06	2180	11.53	2.45	0.29	0.00	5.02	1.95
02/19/20 7:12:36	2210	11.54	2.52	0.26	0.00	5.01	1.59
02/19/20 7:13:06	2240	11.53	2.46	0.33	0.00	5.02	1.95
02/19/20 7:13:36	2270	11.56	2.36	0.31	0.00	5.01	1.47
02/19/20 7:14:06	2300	11.56	2.38	0.33	0.00	5.02	1.49
02/19/20 7:14:36	2330	11.55	2.34	0.36	0.00	5.02	1.79
02/19/20 7:15:06	2360	11.55	2.36	0.32	0.00	5.02	1.95
02/19/20 7:15:36	2390	11.56	2.48	0.29	0.00	5.02	2.11
02/19/20 7:16:06	2420	11.56	2.57	0.35	0.00	5.03	2.12
02/19/20 7:16:36	2450	11.54	2.69	0.24	0.00	5.03	2.66
02/19/20 7:17:06	2480	11.53	2.82	0.37	0.00	5.02	2.07
02/19/20 7:17:36	2510	11.55	2.83	0.34	0.00	5.02	2.54

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,643	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,016	Btu/SCF fuel
Turbine Fuel Flow	1,673	lb/min
Duct Burner Fuel Flow	158	lb/min
Total Fuel Flow	2,474,805	SCFH

Note: Turbine fuel flow reduced by 1.5%, no change to duct burner fuel flow

Weather Data

Barometric Pressure	30.15	in. Hg
Relative Humidity	70	%
Ambient Temperature	34	° F
Specific Humidity	0.002837	lb H_2O / lb air

Unit Data

Unit Load	241.5	megawatts
Heat Input	2,514	MMBtu/hr
NH_3 Flow Rate	207	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	48,739,716	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
02/19/20 7:18:06	2540	11.57	2.85	0.26	0.00	5.02	2.24
02/19/20 7:18:36	2570	11.57	2.70	0.27	0.00	5.03	1.96
02/19/20 7:19:06	2600	11.53	2.57	0.29	0.00	5.03	1.68
02/19/20 7:19:36	2630	11.56	2.43	0.22	0.00	5.03	2.01
02/19/20 7:20:06	2660	11.57	2.56	0.23	0.00	5.02	1.54
02/19/20 7:20:36	2690	11.55	2.46	0.23	0.00	5.03	1.29
02/19/20 7:21:06	2720	11.56	2.50	0.30	0.00	5.03	2.01
02/19/20 7:21:36	2750	11.57	2.47	0.18	0.00	5.03	2.04
02/19/20 7:22:06	2780	11.54	2.29	0.22	0.00	5.03	1.86
02/19/20 7:22:36	2810	11.56	2.34	0.28	0.00	5.03	1.74
02/19/20 7:23:06	2840	11.53	2.36	0.21	0.00	5.03	1.47
02/19/20 7:23:36	2870	11.56	2.44	0.26	0.00	5.02	2.46
02/19/20 7:24:06	2900	11.54	2.58	0.23	0.00	5.03	2.10
02/19/20 7:24:36	2930	11.55	2.57	0.25	0.00	5.03	2.28
02/19/20 7:25:06	2960	11.53	2.70	0.22	0.00	5.03	2.00
02/19/20 7:25:36	2990	11.55	2.79	0.23	0.00	5.02	1.91
02/19/20 7:26:06	3020	11.56	2.71	0.30	0.00	5.03	2.27
02/19/20 7:26:36	3050	11.55	2.61	0.27	0.00	5.03	2.15
02/19/20 7:27:06	3080	11.55	2.60	0.27	0.00	5.03	1.97
02/19/20 7:27:36	3110	11.56	2.48	0.16	0.00	5.03	3.03
02/19/20 7:28:06	3140	11.57	2.41	0.20	0.00	5.03	2.46
02/19/20 7:28:36	3170	11.56	2.33	0.29	0.00	5.03	2.18
02/19/20 7:29:06	3200	11.55	2.27	0.24	0.00	5.03	2.05
02/19/20 7:29:36	3230	11.56	2.22	0.25	0.00	5.03	2.19
02/19/20 7:30:06	3260	11.53	2.27	0.25	0.00	5.03	1.94
02/19/20 7:30:36	3290	11.56	2.28	0.24	0.00	5.02	2.15
02/19/20 7:31:06	3320	11.56	2.30	0.26	0.00	5.03	3.20
02/19/20 7:31:36	3350	11.57	2.35	0.21	0.00	5.03	2.49
02/19/20 7:32:06	3380	11.57	2.46	0.21	0.00	5.03	1.86
02/19/20 7:32:36	3410	11.54	2.57	0.21	0.00	5.03	1.84
02/19/20 7:33:06	3440	11.56	2.70	0.25	0.00	5.03	4.00
02/19/20 7:33:36	3470	11.52	2.78	0.28	0.00	5.03	3.11
02/19/20 7:34:06	3500	11.55	2.73	0.32	0.00	5.02	2.80
02/19/20 7:34:36	3530	11.56	2.72	0.28	0.00	5.03	2.63
02/19/20 7:35:06	3560	11.54	2.57	0.23	0.00	5.03	3.82
02/19/20 7:35:36	3590	11.56	2.44	0.20	0.00	5.03	3.62
02/19/20 7:36:06	3620	11.56	2.39	0.22	0.00	5.03	3.17
02/19/20 7:36:36	3650	11.56	2.32	0.23	0.00	5.03	2.68
02/19/20 7:37:06	3680	11.55	2.30	0.22	0.00	5.03	3.49
02/19/20 7:37:36	3710	11.53	2.35	0.23	0.00	5.03	4.68
02/19/20 7:38:06	3740	11.54	2.36	0.29	0.00	5.03	3.36
02/19/20 7:38:36	3770	11.55	2.44	0.25	0.00	5.03	3.03
02/19/20 7:39:06	3800	11.55	2.45	0.27	0.00	5.03	2.86
02/19/20 7:39:36	3830	11.55	2.44	0.29	0.00	5.03	2.14
02/19/20 7:40:06	3860	11.55	2.53	0.23	0.00	5.03	1.67
02/19/20 7:40:36	3890	11.53	2.46	0.35	0.00	5.03	2.75
RAW AVERAGE		**11.56**	**2.48**	**0.25**	**0.00**	**5.02**	**2.37**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0014	inst-nx-0020	inst-co-0045	inst-th-0010	inst-c2-0023	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.02	0.00	0.00	0.00	0.00	
Bias	**Final Zero**	0.00	0.00	0.00	0.00	0.00	
Bias	**Avg. Zero**	0.01	0.00	0.00	0.00	0.00	
Bias	**Initial UpScale**	11.97	8.86	9.08	3.40	8.98	
Bias	**Final UpScale**	11.99	8.96	9.24	3.35	8.96	
Bias	**Avg. UpScale**	11.98	8.91	9.16	3.38	8.97	
Upscale Cal Gas		12.01	8.90	9.10	3.37	8.95	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.58	2.48	0.25	0.00	5.01	2.54
Concentration (ppm@ 15%O_2)	N/A	1.57	0.16	0.00	N/A	1.61

Non-Bias Adjusted Averages Include: *

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
PM_{10}

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#1	
Operator		Aaron Blum	
Date for Preliminary Run	(mm/dd/yy)	02/18/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		U-00001	
Base Run Number		PM U-00001 Base+DB	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	02/18/20	02/19/20	02/19/20	
Load		Base+DB	Base+DB	Base+DB	% or w/DB
Fuel F-Factor		8643.54	8642.95	8642.95	dscf/MMBtu
Meter Box Number	from ACS	Samp-cp-0030	Samp-cp-0030	Samp-cp-0030	
Meter Calibration Factor	(Y)	0.974	0.974	0.974	
Orifice Meter Coefficient	($\Delta H_@$)	1.878	1.878	1.878	in H_2O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	4187/10	4187/10	4187/10	
Pitot Tube Coefficient	(C_p)	0.7240	0.7240	0.7240	
Nozzle Number	from ACS	4b	4b	4b	must match cyc nozz tab (e.g. 3a, 4b, etc.)
Nozzle Diameter	(D_n)	0.156	0.156	0.156	in
Probe Number	from ACS	SAMP-PR-0133	SAMP-PR-0133	SAMP-PR-0133	
Probe Length		120.0	120.0	120.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039	
Impinger Case Number	from ACS	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	02/18/20
Sampling Location	U-00001 Base+DB	**Stack Type**	Circular
Operator	Aaron Blum	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	4
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

○ Method 1 Trav

◉ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
4	**Ports by**	3	**Across**
12	**Pts Used**	12	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.044	10	18
2	0.146	33 2/8	41 2/8
3	0.296	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Cricket Valley Energy Center			
Sampling Location	U-00001 Base+DB			
Operator	Aaron Blum			
Project #	bec-19-cricketvalley.ny-start#1			
Pitot Leak Check	x	**PreTest**	x	**PostTest**

Preliminary Run Date	02/18/20		
Stack Type	Circular		
Ports Available	4		
Thermocouple ID	SAMP-PR-0133		
Pitot Coefficient	0.8198	**Pitot Identification**	A4187

RM 201A or OTM 27 Blckag.	**RM 201A or OTM 27 Pitot Coeff.**
5.39E-04	0.7240

Stack Dimensions			
Area of Stack	(A_s)	283.53	ft²
Diameter of Stack	(D)	228.00	in

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.21	in Hg

Stack Gas Composition			
Composition Data:	**Estimated Composition**		
Carbon Dioxide Concentration	(%CO_2)	5.10	%vd
Oxygen Concentration	(%O_2)	12.30	%vd
Carbon Monoxide Concentration	(ppmCO)	0.00	ppmvd
Nitrogen Concentration	(%N_2)	82.60	%vd
Stack Moisture Content	(B_{ws})	8.00	%
Stack Dry Molecular Weight	(M_d)	29.31	lb/lb-mole
Stack Wet Molecular Weight	(M_w)	28.40	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v_s)	55.57	ft/sec
Avg Stack Dry Std Flow Rate	(Q_{sd})	43,116,906	dscf/hr
Avg Stack Dry Std Flow Rate	(Q_{sd})	718,615	dscf/min
Avg Stack Wet Flow Rate	(Q_{aw})	945,278	acf/min
Avg Stack Wet Std Flow Rate	(Q_{sw})	46,866,202	ascf/hr

40 CFR 60, Method 2G, Section 8.11.1 (but applies to all Method 2 type static pressure measurements):
If a Type S probe is used for this measurement, position the probe at or between any traverse point(s) and rotate the probe until a null differential pressure reading is obtained. Disconnect the tubing from one of the pressure ports; read and record the ΔP. For pressure devices with one-directional scales, if a deflection in the positive direction is noted with the negative side disconnected, then the static pressure is positive. Likewise, if a deflection in the positive direction is noted with the positive side disconnected, then the static pressure is negative.

Stack Cross Section Schematic

Velocity Traverse Data

Run Number	PM U-00001 Base+DB-V1				
Run Time	13:50	**Start**	14:12	**End**	

Traverse Point	**Velocity Head** (Δp)	**Null Angle** (N_a)	**Zero Deg Pressure** ($0°_a$)	**Stack Temp** (t_s)	**Local Velocity** ($v_{s(l)}$)	**Adjusted Velocity Pressure**	**Adjusted Velocity Pressure w/BF, if app**
	in H_2O	deg	in H_2O	°F	ft/sec	in H_2O	in H_2O
A-1	1.50	5	0.04	186	74.48	1.17	1.17
A-2	1.40	5	0.10	184	71.84	1.09	1.09
A-3	1.40	10	0.07	185	71.90	1.09	1.09
B-1	1.30	5	0.11	186	69.33	1.01	1.01
B-2	1.40	5	0.02	184	71.84	1.09	1.09
B-3	1.30	-5	-0.02	187	69.39	1.01	1.01
C-1	1.40	0	0.00	186	71.95	1.09	1.09
C-2	1.40	-5	0.10	183	71.78	1.09	1.09
C-3	1.30	5	0.11	185	69.28	1.01	1.01
D-1	1.40	0	0.00	187	72.01	1.09	1.09
D-2	1.40	-5	0.06	185	71.90	1.09	1.09
D-3	1.30	-5	0.10	184	69.23	1.01	1.01
Average	1.38	5		185		1.07	1.07
	1.17	**= Square roots of Δp**					1.04
Standard deviation of null angles =				2.6			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	PM U-00001 Base+DB-4	PM U-00001 Base+DB-5	PM U-00001 Base+DB-6	
Carbon Dioxide Content	5.1	5.3	5.3	5.3				%
Oxygen Content	12.3	11.7	11.7	11.7				%
Stack Moisture Content	8.0	6.9	6.7	6.9				%
Nitrogen plus CO Content	82.6	83.0	83.0	83.0				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H_2O)	Min.	1.01	Max.	1.17

Stack and Equipment Information	Prelim	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	PM U-00001 Base+DB-4	PM U-00001 Base+DB-5	PM U-00001 Base+DB-6	
Barometric Pressure	30.14	30.14	30.02	30.14				in Hg
Stack Static Pressure	0.95	0.95	0.95	0.95				in H_2O
Absolute Stack Pressure	30.21	30.21	30.09	30.21				in Hg
Average Stack Temp	185	177	174	172				0.00
Average Stack Temp	645	637	634	632				°R
Average Meter Temp	85	70	68	74				0.00
Orifice Meter Coefficient	1.878	1.878	1.878	1.878				in H_2O
Pitot Coefficient	0.724	0.724	0.724	0.724				
Stack Dry Molecular Weight	29.31	29.32	29.31	29.31				lb/lb mole
Stack Wet Molecular Weight	28.40	28.53	28.56	28.53				lb/lb mole
Stack Viscosity	200.74	199.46	198.89	198.19				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.08							
Cunningham Correction Factor, for a 2.5 µm particle		1.07	1.07	1.07				
Prelim Cut Dia., Cyclone I, D_{50LL}, N_{re}<3162	10.30	2.36	2.33	2.32				µm
Middle Zone Dia., Cyclone I, D_{50T}, N_{re}<3162	10.65							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.), N_{re}<3162	0.48							dscfm
Reynolds Number, Cyc I & IV, N_{re}<3162	2742.55	2792.15	2818.10	2843.00				
Dia. of 50% Prob. (D_{50}) Cyc IV (N_{re}<3162)	2.38	2.36	2.34	2.32				µm
Sampling Rate, Cyc IV, N_{re}<3,162	0.48							dscfm
Reynolds Number, Cyc IV, N_{re}<3162	2742.50	2792.15	2818.10	2843.00				
Prelim Cut Dia., Cyclone I, $D_{50LL\geq3162}$	10.63							µm
Middle Zone Dia., Cyclone I, $D_{50T\geq3162}$	10.81							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.)≥3162	0.47							dscfm
Reynolds Number, Cyc I & IV, N_{re}≥3162	2684.42							
Dia. of 50% Prob. (D_{50}) CIV (N_{re}≥3162)	2.29							µm
Sampling Rate, Cyc IV, N_{re}≥3,162	4.69							dscfm
Reynolds Number ≥ 3162	26844.41							
Cyclone Flow Rate	0.48	0.48	0.48	0.48				ft³/min
Recalculated D_{50-1} for C_{IV}		2.36	2.33	2.32				
Recalculated Cunninham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		98.08	98.64	98.22				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.156	0.156	0.156				in

Orifice Head and Nozzle Selection Calculation											
Nozzle No.	2a	2b	3a	3b	4a	4b	5a	5b	6a	6b	7a
Nozzle diameter, D_n, in.	0.119	0.130	0.130	0.143	0.155	0.156	0.175	0.172	0.197	0.192	0.212
Nozzle velocity, v_n, ft/sec	103.38	86.63	86.63	71.59	61.20	60.16	47.80	49.49	37.72	39.71	32.57
R_{min}	0.77	0.76	0.76	0.74	0.73	0.72	0.69	0.70	0.63	0.65	0.58
v_{min}, ft/sec	79.40	65.66	65.66	53.21	44.49	43.61	33.01	34.47	23.93	25.78	18.94
R_{max}	1.22	1.23	1.23	1.24	1.25	1.25	1.27	1.27	1.30	1.29	1.32
v_{max}, ft/sec	126.39	106.48	106.48	88.68	76.41	75.18	60.68	62.65	48.94	51.25	42.98
Δp_{min}, in. H_2O @ $t_{s-50}{}^oF$	2.37	1.62	1.62	1.07	0.75	0.72	0.41	0.45	0.22	0.25	0.13
Δp_{min}, in. H_2O @ t_s	2.19	1.50	1.50	0.98	0.69	0.66	0.38	0.41	0.20	0.23	0.12
Δp_{max}, in. H_2O @ t_s	5.55	3.94	3.94	2.73	2.03	1.96	1.28	1.36	0.83	0.91	0.64
Δp_{min}, in. H_2O @ $t_{s+50}{}^oF$	5.15	3.65	3.65	2.53	1.88	1.82	1.19	1.26	0.77	0.85	0.60
ΔH, in. H_2O @ t_s+50°F	0.395										
ΔH, in. H_2O @ t_s	**0.459**										
ΔH, in. H_2O @ t_s-50°F	0.540										

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/18/20		
Sampling Location	U-00001 Base+DB	**Operator**	Aaron Blum		
Project #	bec-19-cricketvalley.ny-start#1	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	PM U-00001 Base+DB-1		**Date**	02/18/20	**Run Start Time**	14:55	**Run Stop Time**	19:04
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:09	5.3	11.7	0.0	83.0	29.32	1.740	114.1	YES

Gas Analysis Data

Run Number	PM U-00001 Base+DB-2		**Date**	02/19/20	**Run Start Time**	04:24	**Run Stop Time**	08:15
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
03:51	5.3	11.7	0.0	83.0	29.31	1.742	113.9	YES

Gas Analysis Data

Run Number	PM U-00001 Base+DB-3		**Date**	02/19/20	**Run Start Time**	09:14	**Run Stop Time**	13:51
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:37	5.3	11.7	0.0	83.0	29.31	1.746	114.0	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/18/20
Sampling Location	U-00001 Base+DB	**Operator**	Aaron Blum
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	02/18/20	500	499.7	-0.3	Pass
Test Day 1	02/19/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		PM U-00001 Base+DB-1		**Date**	02/18/20	**Start Time**	14:55	**Stop Time**	19:04
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	100.690	dcf		**Barometric Pressure**	(P_b)	30.14	in Hg
Average Stack Temp		$(t_s)_{avg}$	177	°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	70	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.44	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	499.00	557.80	718.20	875.20				
Initial Value	(V_i),(W_i)	360.60	558.20	716.00	859.60				
Net Value	(V_n),(W_n)	138.4	-0.4	2.2	15.6				
Results									
Total Weight		(W_t)	155.80	g		**Water Vol Weighed**	$(V_{wsg(std)})$	7.346	scf
Std Meter Volume		$(V_{m(std)})$	98.511	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	47.32	%
Calc Moisture Content		$(B_{ws(calc)})$	6.94	%		**Final Moisture Content**	(B_{ws})	6.94	%

Moisture Content Data									
Run Number		PM U-00001 Base+DB-2		**Date**	02/19/20	**Start Time**	04:24	**Stop Time**	08:15
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	101.550	dcf		**Barometric Pressure**	(P_b)	30.02	in Hg
Average Stack Temp		$(t_s)_{avg}$	174	°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	68	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.44	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	506.90	582.10	729.90	918.60				
Initial Value	(V_i),(W_i)	374.50	582.70	728.80	901.30				
Net Value	(V_n),(W_n)	132.4	-0.6	1.1	17.3				
Results									
Total Weight		(W_t)	150.20	g		**Water Vol Weighed**	$(V_{wsg(std)})$	7.082	scf
Std Meter Volume		$(V_{m(std)})$	99.332	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	43.90	%
Calc Moisture Content		$(B_{ws(calc)})$	6.66	%		**Final Moisture Content**	(B_{ws})	6.66	%

Moisture Content Data									
Run Number		PM U-00001 Base+DB-3		**Date**	02/19/20	**Start Time**	09:14	**Stop Time**	13:51
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	103.130	dcf		**Barometric Pressure**	(P_b)	30.14	in Hg
Average Stack Temp		$(t_s)_{avg}$	172	°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	74	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.44	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	500.00	556.00	718.70	893.20				
Initial Value	(V_i),(W_i)	359.10	556.80	718.20	875.20				
Net Value	(V_n),(W_n)	140.9	-0.8	0.5	18.0				
Results									
Total Weight		(W_t)	158.60	g		**Water Vol Weighed**	$(V_{wsg(std)})$	7.478	scf
Std Meter Volume		$(V_{m(std)})$	100.236	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	41.94	%
Calc Moisture Content		$(B_{ws(calc)})$	6.94	%		**Final Moisture Content**	(B_{ws})	6.94	%

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Date	02/18/20
Operator	Aaron Blum
Run Number	PM U-00001 Base+DB-1

Filter #
18042521
PM U-00001 Base+DB-1-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	177.1	°F
Average Meter Temp	(t_m)	70.1	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.15	in H_2O
Stack Moisture Content	(B_{ws})	6.94	%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.37	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.00	in H_2O	3.3	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.00	in H_2O	3.6	in H_2O for	15.0	sec [≥15]
	Post (+)	0.00	in H_2O	3.6	in H_2O for	15.0	sec [≥15]
	Post (-)	0.00	in H_2O	4.0	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.2201	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.21	in Hg
Absolute Meter Pressure	(P_m)	30.28	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	14:55	**End**	19:04

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	360.6	558.2	716.0	859.6				
Post	499.0	557.8	718.2	875.2				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	49.090	1.30	0.459	0.44	175	250	251	45	67	76	64	64	2.5	1.14	60.57	8.383	101.2	101.166
A-2	22.0	00:22:00	57.560	1.40	0.459	0.44	175	249	245	49	64	77	67	67	3.0	1.18	62.86	17.013	99.1	100.939
A-3	44.8	00:44:45	66.330	1.40	0.459	0.44	177	249	246	50	65	78	68	68	3.0	1.18	62.96	25.647	98.5	100.878
B-1	67.5	01:07:30	75.120	1.20	0.459	0.44	176	250	256	50	66	78	72	72	3.0	1.10	58.24	33.553	99.5	100.375
B-2	88.8	01:28:45	83.230	1.30	0.459	0.44	178	251	255	47	67	77	73	73	3.0	1.14	60.72	41.765	99.5	100.123
B-3	110.8	01:50:45	91.670	1.40	0.459	0.44	177	252	256	48	68	76	73	73	3.0	1.18	62.96	50.609	99.5	100.650
C-1	133.5	02:13:30	100.760	1.30	0.459	0.44	178	250	252	46	68	77	73	73	3.0	1.14	60.72	58.510	99.0	99.900
C-2	155.5	02:35:30	108.880	1.20	0.459	0.44	177	250	251	51	69	78	70	70	3.0	1.10	58.29	66.055	98.9	99.222
C-3	176.8	02:56:45	116.590	1.30	0.459	0.44	178	250	253	50	68	77	70	70	3.0	1.14	60.72	74.313	99.0	99.271
D-1	198.8	03:18:45	125.030	1.40	0.459	0.44	177	250	249	50	67	78	70	70	3.0	1.18	62.96	82.689	98.5	99.115
D-2	221.5	03:41:30	133.590	1.30	0.459	0.44	179	250	250	53	68	78	70	70	3.0	1.14	60.76	90.693	98.4	98.887
D-3	243.5	04:03:30	141.770	1.30	0.459	0.44	178	251	253	54	68	78	71	71	3.0	1.14	60.72	98.516	98.1	98.516
Last Pt	265.5	04:25:30	149.780																	
Final Val	265.5	04:25:30	149.780											**Max Vac**	3.0	**Final Values**		98.516	98.1	
Average Values				1.32		0.44	177	250	251	49	67	77	70	70		1.15	61.04			
													70							

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.37	8.383	101.2	848.0
0.156	0.37	8.630	97.0	837.6
0.156	0.37	8.634	97.2	839.5
0.156	0.37	7.906	102.9	813.4
0.156	0.37	8.212	99.3	815.7
0.156	0.37	8.845	99.6	881.0
0.156	0.37	7.901	95.6	755.0
0.156	0.37	7.544	98.3	741.3
0.156	0.37	8.259	99.9	825.0
0.156	0.37	8.376	94.3	790.2
0.156	0.37	8.004	96.9	775.5
0.156	0.37	7.823	94.6	740.3
0.156	0.37	98.516		

RM 201A Calculations						
Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**		
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**	
min	min	in H_2O	min	in H_2O		
22.00	22.03	1.30		1.30	0	
22.75	22.86	1.40	22.86	1.40	0	
22.75	22.86	1.40	22.86	1.40	0	
21.25	21.16	1.20		1.20	0	
22.00	22.03	1.30	22.03	1.30	0	
22.75	22.86	1.40	22.86	1.40	0	
22.00	22.03	1.30		1.30	0	
21.25	21.16	1.20	21.16	1.20	0	
22.00	22.03	1.30	22.03	1.30	0	
22.75	22.86	1.40		1.40	0	
22.00	22.03	1.30	22.03	1.30	0	
22.00	22.03	1.30	22.03	1.30	0	

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	199.46	μP
	Cyclone Flow Rate (Q_a)	0.48	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.61	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{re}<3162)	10.32	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.66	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.47	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.36	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}<3162)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2792.15	
	Actual Particle Cut Diameter for CI	10.61	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.36	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.36	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	98.08	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.660	in H_2O
	Δp_{max}	1.963	in H_2O

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Date	02/19/20
Operator	Aaron Blum
Run Number	PM U-00001 Base+DB-2

Filter #
18082944
PM U-00001 Base+DB-2-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	173.6	°F
Average Meter Temp	(t_m)	68.1	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.15	in H_2O
Stack Moisture Content	(B_{ws})	6.66	%
Stack Dry Molecular Weight	(M_d)	29.31	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.37	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.37	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
Pitot	**Pre (+)**	0.000	in H_2O	3.3	in H_2O for	15.0	sec (≥15)
PASS	**Pre (-)**	0.000	in H_2O	3.8	in H_2O for	15.0	sec (≥15)
	Post (+)	0.000	in H_2O	3.7	in H_2O for	15.0	sec (≥15)
	Post (-)	0.000	in H_2O	3.8	in H_2O for	15.0	sec (≥15)

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1548	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.02	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.09	in Hg
Absolute Meter Pressure	(P_m)	30.16	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	04:24	**End**	08:15

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	374.5	582.7	728.8	901.3				
Post	506.9	582.1	729.9	918.6				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1026	8082	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	126.000	1.40	0.459	0.44	172	248	256	57	60	75	60	60	2.5	1.18	62.80	8.722	97.8	101.785
A-2	22.8	00:22:45	134.780	1.30	0.459	0.44	173	250	251	57	69	77	70	70	2.5	1.14	60.57	16.704	97.0	99.103
A-3	44.8	00:44:45	142.970	1.40	0.459	0.44	171	252	249	55	70	77	71	71	2.5	1.18	62.75	25.264	96.6	99.373
B-1	67.5	01:07:30	151.770	1.20	0.459	0.44	173	251	251	59	71	78	64	64	2.5	1.10	58.19	32.835	97.0	98.228
B-2	88.8	01:28:45	159.450	1.30	0.459	0.44	170	250	254	60	71	77	66	66	2.5	1.14	60.42	41.261	97.9	98.914
B-3	110.8	01:50:45	168.030	1.30	0.459	0.44	175	250	250	62	74	78	68	68	2.5	1.14	60.66	49.801	98.7	99.603
C-1	132.8	02:12:45	176.760	1.40	0.459	0.44	176	250	253	63	76	77	68	68	2.5	1.18	63.00	58.303	98.3	99.546
C-2	155.5	02:35:30	185.450	1.20	0.459	0.44	175	250	247	64	77	78	69	69	2.5	1.10	58.28	66.544	99.4	99.958
C-3	176.8	02:56:45	193.890	1.30	0.459	0.44	176	251	245	65	77	78	69	69	2.5	1.14	60.71	74.893	99.5	100.046
D-1	198.8	03:18:45	202.440	1.40	0.459	0.44	175	251	253	61	70	77	70	70	2.5	1.18	62.95	83.255	99.0	99.794
D-2	221.5	03:41:30	211.020	1.30	0.459	0.44	174	250	253	61	71	78	71	71	2.5	1.14	60.61	91.378	98.9	99.634
D-3	243.5	04:03:30	219.370	1.30	0.459	0.44	173	251	252	62	71	77	71	71	2.5	1.14	60.57	99.335	98.6	99.335
Last Pt	265.5	04:25:30	227.550																	
Final Val	265.5	04:25:30	227.550											**Max Vac**	2.5	**Final Values**		99.335	98.6	
Average Values					1.32		0.44	174	250	251	61	71	77	68	68		1.15	60.96		
														68						

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.37	8.722	97.8	852.9
0.156	0.37	7.982	96.1	767.2
0.156	0.37	8.560	95.9	821.0
0.156	0.37	7.571	98.2	743.7
0.156	0.37	8.426	101.2	852.9
0.156	0.37	8.541	103.0	879.8
0.156	0.37	8.502	95.6	813.0
0.156	0.37	8.241	107.1	882.7
0.156	0.37	8.349	100.8	841.3
0.156	0.37	8.362	94.0	785.9
0.156	0.37	8.123	97.9	795.1
0.156	0.37	7.957	95.8	762.5
0.156	0.37	99.335		

RM 201A Calculations					
Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**	
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Prelim. Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
22.75	22.86	1.40		1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.75	22.86	1.40	22.86	1.40	0
21.25	21.16	1.20		1.20	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30	22.03	1.30	0
22.75	22.86	1.40		1.40	0
21.25	21.16	1.20	21.16	1.20	0
22.00	22.03	1.30	22.03	1.30	0
22.75	22.86	1.40		1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30	22.03	1.30	0

Notes:

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	198.89	μP
	Cyclone Flow Rate (Q_s)	0.48	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.55	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.33	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.66	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.47	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.33	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2818.10	
	Actual Particle Cut Diameter for CI	10.55	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.34	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.33	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	98.64	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.660	in H_2O
	Δp_{max}	1.963	in H_2O

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Date	02/19/20
Operator	Aaron Blum
Run Number	PM U-00001 Base+DB-3

Filter #
18082938
PM U-00001 Base+DB-3-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	171.8	°F
Average Meter Temp	(t_m)	73.6	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.15	in H_2O
Stack Moisture Content	(B_{ws})	6.94	%
Stack Dry Molecular Weight	(M_d)	29.31	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.37	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.37	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
Pitot	**Pre (+)**	0.00	in H_2O	3.2	in H_2O for	15.0	sec (≥15)
	Pre (-)	0.00	in H_2O	3.5	in H_2O for	15.0	sec (≥15)
PASS	**Post (+)**	0.00	in H_2O	3.4	in H_2O for	15.0	sec (≥15)
	Post (-)	0.00	in H_2O	3.6	in H_2O for	15.0	sec (≥15)

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1544	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.21	in Hg
Absolute Meter Pressure	(P_m)	30.28	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	09:14	**End**	13:51

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	359.1	556.8	718.2	875.2				
Post	500.0	556.0	718.7	893.2				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	204.310	1.30	0.459	0.44	170	250	250	44	68	73	66	66	2.5	1.14	60.34	7.947	95.5	96.445
A-2	22.0	00:22:00	212.370	1.40	0.459	0.44	171	253	264	45	70	77	70	70	2.5	1.18	62.67	16.616	96.4	99.141
A-3	44.8	00:44:45	221.230	1.30	0.459	0.44	170	254	261	46	71	76	70	70	2.5	1.14	60.34	25.080	98.2	100.322
B-1	66.8	01:06:45	229.880	1.30	0.459	0.44	173	255	273	48	74	77	72	72	2.5	1.14	60.48	33.220	98.2	99.942
B-2	88.8	01:28:45	238.230	1.40	0.459	0.44	172	256	273	48	74	77	72	72	2.5	1.18	62.72	41.662	97.5	99.765
B-3	111.5	01:51:30	246.890	1.30	0.459	0.44	170	255	270	49	73	77	73	73	2.5	1.14	60.34	49.874	97.7	99.749
C-1	133.5	02:13:30	255.330	1.30	0.459	0.44	171	254	254	51	74	78	75	75	2.5	1.14	60.39	58.385	98.4	100.250
C-2	155.5	02:35:30	264.110	1.40	0.459	0.44	172	252	253	52	74	77	75	75	2.5	1.18	62.72	67.556	99.0	101.191
C-3	178.3	02:58:15	273.570	1.30	0.459	0.44	173	253	251	54	75	77	77	77	2.5	1.14	60.48	75.571	98.7	100.762
D-1	200.3	03:20:15	281.870	1.40	0.459	0.44	174	255	252	50	60	75	77	77	2.5	1.18	62.81	84.070	98.4	100.658
D-2	223.0	03:43:00	290.670	1.30	0.459	0.44	173	251	252	52	62	77	78	78	2.5	1.14	60.48	92.100	98.2	100.370
D-3	245.0	04:05:00	299.000	1.30	0.459	0.44	172	252	255	53	63	77	78	78	2.5	1.14	60.43	100.236	98.2	100.236
Last Pt	267.0	04:27:00	307.440																	
Final Val	267.0	04:27:00	307.440											**Max Vac**	2.5	**Final Values**		100.236	98.2	
Average Values				1.33		0.44	172	253	259	49	70	77	74	74		1.15	61.18			
													74							

Actual Actual Nozzle Diameter (D_{na})	**DP to DP to DH Iso Factor (K)**	**Point-by-point Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.37	7.947	95.5	759.0
0.156	0.37	8.670	97.2	842.5
0.156	0.37	8.464	101.7	861.1
0.156	0.37	8.140	98.1	798.3
0.156	0.37	8.442	94.7	799.5
0.156	0.37	8.212	98.7	810.6
0.156	0.37	8.511	102.4	871.3
0.156	0.37	9.170	102.9	943.3
0.156	0.37	8.016	96.6	774.1
0.156	0.37	8.499	95.5	811.5
0.156	0.37	8.030	96.7	776.8
0.156	0.37	8.136	97.9	796.8
0.156	0.37	100.236		

RM 201A Calculations						
Trav. Point Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point First Point Dwell Times Prelim. Trav. (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30		1.30	0
22.75	22.86	1.40	22.86	1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.75	22.86	1.40		1.40	0
22.00	22.03	1.30	22.03	1.30	0
22.00	22.03	1.30	22.03	1.30	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	198.19	μP
	Cyclone Flow Rate (Q_s)	0.48	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.51	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.34	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.67	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.47	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.32	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2843.00	
	Actual Particle Cut Diameter for CI	10.51	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.32	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.32	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	98.22	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.660	in H_2O
	Δp_{max}	1.963	in H_2O

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
SAM

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#1	
Operator		Atlas Melchert	
Date for Preliminary Run	(mm/dd/yy)	02/17/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	10 L/min	10.6	scf
Run Duration	8a, 2.4.1.3	120	minutes
Unit Number		U-00001	
Base Run Number		SAM U-00001 Base+DB	
Number of Ports Available		4	
Number of Ports Used		1	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	02/18/20	02/19/20	02/19/20	
Load		Base+DB	Base+DB	Base+DB	% or w/DB
Fuel F-Factor		8643.54	8642.95	8642.95	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0007	samp-cp-0007	samp-cp-0007	
Meter Calibration Factor	(Y)	0.985	0.985	0.985	
Orifice Meter Coefficient	($\Delta H_@$)	1.731	1.731	1.731	in H_2O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-SAM-01	SAMP-SAM-01	SAMP-SAM-01	
Probe Length		72.0	72.0	72.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-ha-0005	samp-ha-0005	samp-ha-0005	
Impinger Case Number	from ACS	samp-bc-0032	samp-bc-0032	samp-bc-0032	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	02/17/20
Sampling Location	U-00001 Base+DB	**Stack Type**	Circular
Operator	Atlas Melchert	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	1
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

- (•) Method 1 Trav
- ( ) 12 Point PM Trav (M201a ONLY)
- ( ) Velocity

Number of Traverse Points Used			
1	**Ports by**	1	**Across**
1	**Pts Used**	1	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.275	62 6/8	70 6/8
2			
3			
4			
5			
6			
7			
8			
9			

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/17/20		
Sampling Location	U-00001 Base+DB	**Operator**	Atlas Melchert		
Project #	bec-19-cricketvalley.ny-start#1	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	SAM U-00001 Base+DB-1		**Date**	02/18/20	**Run Start Time**	14:40	**Run Stop Time**	16:40
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	5.3	11.7	0.0	83.0	29.32	1.736	114.6	YES

Gas Analysis Data

Run Number	SAM U-00001 Base+DB-2		**Date**	02/19/20	**Run Start Time**	04:09	**Run Stop Time**	06:09
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	5.3	11.7	0.0	83.0	29.32	1.736	114.6	YES

Gas Analysis Data

Run Number	SAM U-00001 Base+DB-3		**Date**	02/19/20	**Run Start Time**	07:26	**Run Stop Time**	09:26
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	5.3	11.7	0.0	83.0	29.32	1.736	114.6	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	02/17/20
Sampling Location	U-00001 Base+DB	**Operator**	Atlas Melchert
Project #	bec-19-cricketvalley.ny-start#1	**Ports Used**	1

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	02/18/20	500	499.7	-0.3	Pass
Test Day 2	02/19/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number	SAM U-00001 Base+DB-1		**Date**	02/18/20	**Start Time**	14:40	**Stop Time**	16:40	
Meter Box Number	samp-cp-0007				**Meter Cal Factor**	(Y)	0.985		
Total Meter Volume	(V_m)	42.320	dcf		**Barometric Pressure**	(P_b)	30.14	in Hg	
Average Stack Temp	$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O	
Average Meter Temp	$(t_m)_{avg}$	96	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O	
	Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**	
	(g)	(g)	(g)	(g)					
Contents	H_2O_2	H_2O_2	DI Water	Sil Gel					
Final Value (V_f),(W_f)	771.20	715.30	616.50	944.60					
Initial Value (V_i),(W_i)	693.10	712.70	615.40	937.50					
Net Value (V_n),(W_n)	78.1	2.6	1.1	7.1					
Results									
Total Weight	(W_t)	88.90	g		**Water Vol Weighed**	($V_{wsg(std)}$)	4.192	scf	
Std Meter Volume	($V_{m(std)}$)	39.933	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%	
Calc Moisture Content	($B_{ws(calc)}$)	9.50	%		**Final Moisture Content**	(B_{ws})		%	

Moisture Content Data									
Run Number	SAM U-00001 Base+DB-2		**Date**	02/19/20	**Start Time**	04:09	**Stop Time**	06:09	
Meter Box Number	samp-cp-0007				**Meter Cal Factor**	(Y)	0.985		
Total Meter Volume	(V_m)	42.320	dcf		**Barometric Pressure**	(P_b)	30.02	in Hg	
Average Stack Temp	$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O	
Average Meter Temp	$(t_m)_{avg}$	101	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O	
	Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**	
	(g)	(g)	(g)	(g)					
Contents	H_2O_2	H_2O_2	DI Water	Sil Gel					
Final Value (V_f),(W_f)	780.10	722.00	618.70	951.90					
Initial Value (V_i),(W_i)	716.00	715.30	616.50	944.60					
Net Value (V_n),(W_n)	64.1	6.7	2.2	7.3					
Results									
Total Weight	(W_t)	80.30	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.786	scf	
Std Meter Volume	($V_{m(std)}$)	39.432	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%	
Calc Moisture Content	($B_{ws(calc)}$)	8.76	%		**Final Moisture Content**	(B_{ws})		%	

Moisture Content Data									
Run Number	SAM U-00001 Base+DB-3		**Date**	02/19/20	**Start Time**	07:26	**Stop Time**	09:26	
Meter Box Number	samp-cp-0007				**Meter Cal Factor**	(Y)	0.985		
Total Meter Volume	(V_m)	42.320	dcf		**Barometric Pressure**	(P_b)	30.14	in Hg	
Average Stack Temp	$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O	
Average Meter Temp	$(t_m)_{avg}$	101	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O	
	Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**	
	(g)	(g)	(g)	(g)					
Contents	H_2O_2	H_2O_2	DI Water	Sil Gel					
Final Value (V_f),(W_f)	787.50	731.30	620.30	957.40					
Initial Value (V_i),(W_i)	722.40	722.00	618.70	951.90					
Net Value (V_n),(W_n)	65.1	9.3	1.6	5.5					
Results									
Total Weight	(W_t)	81.50	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.843	scf	
Std Meter Volume	($V_{m(std)}$)	39.528	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%	
Calc Moisture Content	($B_{ws(calc)}$)	8.86	%		**Final Moisture Content**	(B_{ws})		%	

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Date	02/18/20
Operator	Atlas Melchert
Run Number	SAM U-00001 Base+DB-1

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	95.7	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.21	in Hg
Absolute Meter Pressure	(P_m)	30.27	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	14:40	**End**	16:40

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	693.1	712.7	615.4	937.5				
Post	771.2	715.3	616.5	944.6				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	671.410	--	0.342	0.34	--	350	513	41	69	--	87	86	1.5			1.681		40.347
A-2	5.0	00:05:00	673.162	--	0.342	0.34	--	350	510	41	78	--	89	86	1.5			3.359		40.310
A-3	10.0	00:10:00	674.914	--	0.342	0.34	--	350	507	41	87	--	91	86	1.5			5.051		40.410
A-4	15.0	00:15:00	676.684	--	0.342	0.34	--	350	504	42	96	--	95	87	1.5			6.719		40.312
A-5	20.0	00:20:00	678.437	--	0.342	0.34	--	350	504	42	98	--	97	87	1.5			8.383		40.238
A-6	25.0	00:25:00	680.189	--	0.342	0.34	--	350	504	42	100	--	99	87	1.5			10.061		40.245
A-7	30.0	00:30:00	681.959	--	0.342	0.34	--	350	505	43	102	--	101	88	1.5			11.718		40.176
A-8	35.0	00:35:00	683.711	--	0.342	0.34	--	350	509	43	101	--	101	88	1.5			13.392		40.176
A-9	40.0	00:40:00	685.481	--	0.342	0.34	--	350	513	43	100	--	101	88	1.5			15.040		40.107
A-10	45.0	00:45:00	687.224	--	0.342	0.34	--	350	518	43	100	--	102	90	1.5			16.735		40.163
A-11	50.0	00:50:00	689.021	--	0.342	0.34	--	350	515	42	100	--	102	90	1.5			18.404		40.154
A-12	55.0	00:55:00	690.791	--	0.342	0.34	--	350	512	41	100	--	102	90	1.5			20.141		40.281
A-13	60.0	01:00:00	692.633	--	0.342	0.34	--	350	509	42	100	--	104	91	1.5			21.747		40.148
A-14	65.0	01:05:00	694.340	--	0.342	0.34	--	350	507	42	99	--	104	91	1.5			23.369		40.062
A-15	70.0	01:10:00	696.065	--	0.342	0.34	--	350	505	42	98	--	104	91	1.5			24.967		39.947
A-16	75.0	01:15:00	697.764	--	0.342	0.34	--	350	503	43	99	--	105	92	1.5			26.620		39.930
A-17	80.0	01:20:00	699.525	--	0.342	0.34	--	350	502	43	98	--	105	92	1.5			28.282		39.927
A-18	85.0	01:25:00	701.295	--	0.342	0.34	--	350	501	43	97	--	105	92	1.5			29.944		39.925
A-19	90.0	01:30:00	703.065	--	0.342	0.34	--	350	500	43	98	--	106	93	1.5			31.611		39.930
A-20	95.0	01:35:00	704.844	--	0.342	0.34	--	350	500	42	98	--	106	93	1.5			33.270		39.924
A-21	100.0	01:40:00	706.614	--	0.342	0.34	--	350	500	41	98	--	106	93	1.5			34.945		39.937
A-22	105.0	01:45:00	708.402	--	0.342	0.34	--	350	500	42	99	--	106	94	1.5			36.603		39.930
A-23	110.0	01:50:00	710.172	--	0.342	0.34	--	350	500	42	99	--	106	94	1.5			38.260		39.923
A-24	115.0	01:55:00	711.942	--	0.342	0.34	--	350	500	42	99	--	106	94	1.5			39.934		39.934
Last Pt	120.0	02:00:00	713.730																	
Final Val	120.0	02:00:00	713.730											**Max Vac**	1.5	**Final Values**		39.934		
Average Values						0.34		350	506	42	96		101	90						
													96							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Date	02/19/20
Operator	Atlas Melchert
Run Number	SAM U-00001 Base+DB-2

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	100.5	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.33	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.02	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.09	in Hg
Absolute Meter Pressure	(P_m)	30.15	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	04:09	**End**	06:09

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	716.0	715.3	616.5	944.6				
Post	780.1	722.0	618.7	951.9				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	726.910	--	0.342	0.34	--	350	513	47	59	--	93	92	1.5			1.702		40.859
A-2	5.0	00:05:00	728.711	--	0.342	0.34	--	350	516	50	75	--	95	92	1.5			3.377		40.523
A-3	10.0	00:10:00	730.486	--	0.342	0.34	--	350	519	53	91	--	97	92	1.5			5.098		40.784
A-4	15.0	00:15:00	732.313	--	0.342	0.34	--	350	524	57	108	--	101	92	1.5			6.731		40.383
A-5	20.0	00:20:00	734.053	--	0.342	0.34	--	350	522	58	112	--	102	92	1.5			8.362		40.136
A-6	25.0	00:25:00	735.792	--	0.342	0.34	--	350	520	59	116	--	103	92	1.5			9.991		39.964
A-7	30.0	00:30:00	737.532	--	0.342	0.34	--	350	519	61	120	--	106	94	1.5			11.613		39.817
A-8	35.0	00:35:00	739.271	--	0.342	0.34	--	350	515	62	121	--	106	94	1.5			13.244		39.732
A-9	40.0	00:40:00	741.020	--	0.342	0.34	--	350	511	63	122	--	106	94	1.5			14.866		39.643
A-10	45.0	00:45:00	742.759	--	0.342	0.34	--	350	509	64	123	--	108	95	1.5			16.500		39.601
A-11	50.0	00:50:00	744.516	--	0.342	0.34	--	350	516	64	123	--	108	95	1.5			18.135		39.567
A-12	55.0	00:55:00	746.273	--	0.342	0.34	--	350	523	64	123	--	108	95	1.5			19.769		39.538
A-13	60.0	01:00:00	748.030	--	0.342	0.34	--	350	530	65	125	--	109	96	1.5			21.400		39.508
A-14	65.0	01:05:00	749.788	--	0.342	0.34	--	350	529	63	124	--	109	96	1.5			23.032		39.483
A-15	70.0	01:10:00	751.545	--	0.342	0.34	--	350	528	61	123	--	109	96	1.5			24.680		39.487
A-16	75.0	01:15:00	753.319	--	0.342	0.34	--	350	527	60	124	--	109	98	1.5			26.308		39.462
A-17	80.0	01:20:00	755.076	--	0.342	0.34	--	350	525	59	124	--	109	97	1.5			27.946		39.453
A-18	85.0	01:25:00	756.842	--	0.342	0.34	--	350	523	58	124	--	109	96	1.5			29.586		39.448
A-19	90.0	01:30:00	758.608	--	0.342	0.34	--	350	521	58	125	--	109	97	1.5			31.240		39.461
A-20	95.0	01:35:00	760.392	--	0.342	0.34	--	350	516	57	124	--	109	97	1.5			32.886		39.464
A-21	100.0	01:40:00	762.166	--	0.342	0.34	--	350	511	56	123	--	109	97	1.5			34.565		39.503
A-22	105.0	01:45:00	763.976	--	0.342	0.34	--	350	508	57	124	--	109	98	1.5			36.185		39.475
A-23	110.0	01:50:00	765.725	--	0.342	0.34	--	350	508	57	124	--	109	98	1.5			37.806		39.450
A-24	115.0	01:55:00	767.473	--	0.342	0.34	--	350	508	57	124	--	109	98	1.5			39.434		39.434
Last Pt	120.0	02:00:00	769.230																	
Final Val	120.0	02:00:00	769.230											**Max Vac**	1.5	**Final Values**		39.434		
Average Values						0.34		350	518	59	116		106	95						
													101							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Date	02/19/20
Operator	Atlas Melchert
Run Number	SAM U-00001 Base+DB-3

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	101.4	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.33	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.21	in Hg
Absolute Meter Pressure	(P_m)	30.27	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	07:26	**End**	09:26

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	722.4	722.0	618.7	951.9				
Post	787.5	731.3	620.3	957.4				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	782.510	--	0.342	0.34	--	350	524	53	69	--	94	94	1.5			1.658		39.786
A-2	5.0	00:05:00	784.262	--	0.342	0.34	--	350	520	54	82	--	97	94	1.5			3.311		39.733
A-3	10.0	00:10:00	786.013	--	0.342	0.34	--	350	516	55	95	--	100	94	1.5			4.960		39.679
A-4	15.0	00:15:00	787.765	--	0.342	0.34	--	350	513	56	108	--	103	95	1.5			6.611		39.667
A-5	20.0	00:20:00	789.525	--	0.342	0.34	--	350	513	56	111	--	104	95	1.5			8.261		39.652
A-6	25.0	00:25:00	791.285	--	0.342	0.34	--	350	513	56	114	--	105	95	1.5			9.917		39.670
A-7	30.0	00:30:00	793.055	--	0.342	0.34	--	350	515	56	118	--	107	95	1.5			11.563		39.644
A-8	35.0	00:35:00	794.815	--	0.342	0.34	--	350	515	56	119	--	107	95	1.5			13.216		39.649
A-9	40.0	00:40:00	796.584	--	0.342	0.34	--	350	515	56	120	--	107	95	1.5			14.870		39.653
A-10	45.0	00:45:00	798.353	--	0.342	0.34	--	350	516	58	121	--	108	96	1.5			16.521		39.650
A-11	50.0	00:50:00	800.123	--	0.342	0.34	--	350	521	59	122	--	108	96	1.5			18.171		39.647
A-12	55.0	00:55:00	801.892	--	0.342	0.34	--	350	526	60	123	--	108	96	1.5			19.830		39.661
A-13	60.0	01:00:00	803.670	--	0.342	0.34	--	350	533	61	124	--	109	97	1.5			21.470		39.636
A-14	65.0	01:05:00	805.430	--	0.342	0.34	--	350	535	60	123	--	109	97	1.5			23.109		39.616
A-15	70.0	01:10:00	807.191	--	0.342	0.34	--	350	537	59	122	--	109	97	1.5			24.757		39.611
A-16	75.0	01:15:00	808.960	--	0.342	0.34	--	350	539	60	123	--	109	97	1.5			26.388		39.582
A-17	80.0	01:20:00	810.712	--	0.342	0.34	--	350	536	58	121	--	109	97	1.5			28.020		39.557
A-18	85.0	01:25:00	812.463	--	0.342	0.34	--	350	533	56	119	--	109	97	1.5			29.667		39.556
A-19	90.0	01:30:00	814.232	--	0.342	0.34	--	350	532	55	117	--	109	98	1.5			31.297		39.533
A-20	95.0	01:35:00	815.984	--	0.342	0.34	--	350	531	55	116	--	109	98	1.5			32.935		39.522
A-21	100.0	01:40:00	817.744	--	0.342	0.34	--	350	530	55	115	--	109	98	1.5			34.557		39.493
A-22	105.0	01:45:00	819.487	--	0.342	0.34	--	350	529	55	116	--	109	98	1.5			36.211		39.503
A-23	110.0	01:50:00	821.265	--	0.342	0.34	--	350	529	55	116	--	109	98	1.5			37.866		39.512
A-24	115.0	01:55:00	823.043	--	0.342	0.34	--	350	529	55	116	--	109	98	1.5			39.528		39.528
Last Pt	120.0	02:00:00	824.830																	
Final Val	120.0	02:00:00	824.830											**Max Vac**	1.5	**Final Values**		39.528		
Average Values						0.34		350	525	57	114		107	96						
													101							

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
Opacity

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel corporation
Facility Name: Cricket Valley Energy center
Street Address: 3241 NY-22
City: Wingdale | State: NY | Zip: 12594

Process: Combined cycle | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:


Describe Emissions Pont: Top of unit one
Height of Emiss. Pt. Start 300ft End 300 ft | Height of Emiss. Pt. Rel. to Observer Start 300 ft End 300 ft
Distance to Emiss. Pt. Start 900 ft End 900 ft | Direction to Emiss. Pt. (Degrees) Start 7°N End 7°N

Vetical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 ft 189°S End 900 ft 189°S

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue | Sky Conditions Start Scattered End Scattered
Wind Speed Start 10mph End 10mph | Wind Direction Start NW End NW
Ambient Temp. Start 45°F End 45°F | Wet Bulb Temp. 37.3 | RH Percent 41.7

Source Layout Sketch



Latitude 41.6711 | Longitude -73.5790 | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 1 of 2
Continued on Form Number (AHI Project Code): Bechtel Cricket Valley, NY - Stack #1
Observation Date 08/19/2020 | Time Zone EST -1hr | Start Time 1200 | End Time 1230

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Matt Jones
Observer's Signature | Date 2/19/20
Organization: AH Hydro
Certified By | Date

CAA 1/3/20

Method Used (Circle One): ~~Method 9~~ 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 2

Continued on Form Number (AHI Project Code) bcl-ly-cricketvalley,ny-stack #1

Company Name Bechtel Corporation

Facility Name Cricket Valley Energy Center

Street Address 22 41 NY-22

City Wingdale State NY Zip 12594

Observation Date 01/19/2020 Time Zone EST -1hr Start Time 1230 End Time 1300

Process Combined Cycle Unit # 1 Operating Mode

Control Equipment Operating Mode

Describe Emissions Point Tip of vit ave

Height of Emiss. Pt. Start 300 ft End 300 ft Height of Emiss. Pt. Rel. to Observer Start 300 ft End 300 ft

Distance to Emiss. Pt. Start 900 ft End 900 ft Direction to Emiss. Pt. (Degrees) Start 70 W End 70 W

Vetical Angle to Obs. Pt. Start 30° End 30° Direction to Obs. Pt. (Degrees) Start 189°S End 189°S

Distance and Direction to Observation Point from Emission Point Start 900 ft 189°S End 900 ft 189°S

Describe Emissions Start N/A End N/A

Emission Color Start N/A End N/A Water Droplet Plume Start N/A End N/A


Describe Plume Background Start blue End blue

Background Color Start blue End blue Sky Conditions Start Scattered End Scattered

Wind Speed Start 11mph End 11mph Wind Direction Start NW End NW

Ambient Temp. Start 44.3 End 44.0 Wet Bulb Temp. 33.4 RH Percent 41.7

Source Layout Sketch



Latitude 41.6711 Longitude -73.5790 Declination

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Additional Information

Observer's Name (Print) Matt Jones

Observer's Signature Date 2/14/20

Organization AH Hygiene

Certified By CAA Date 1/3/20

Method Used (Circle One)
Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy center
Street Address: 3441 NY-22
City: Dingdale | State: NY | Zip: 12594

Process: Combined CYCR | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:


Describe Emissions Point: Top of unit 1
Height of Emiss. Pt. Start 380 ft End 380 ft | Height of Emiss. Pt. Rel. to Observer Start 340 ft End 340 ft
Distance to Emiss. Pt. Start 900 ft End 900 ft | Direction to Emiss. Pt. (Degrees) Start ~~189S~~ 70W End 70W

Vertical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 ft 189°S End 900 ft 189°S

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue | Sky Conditions Start Scattered End Scattered
Wind Speed Start 11 mph End 13 mph | Wind Direction Start NW End NW
Ambient Temp. Start 44.0 End 43.6 | Wet Bulb Temp. 33.6 | RH Percent 41.9

Source Layout Sketch



Latitude 41.6711 | Longitude -73.5790 | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 1 of 2
Continued on Form Number (AHI Project Code): ba-ny-cricketvalley.ny-5-form #1
Observation Date 08/19/2020 | Time Zone EST -1hr | Start Time 1302 | End Time 1332

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Matt Jones
Observer's Signature | Date 8/19/20
Organization: Air Rigor
Certified By: CAA | Date 1/3/20

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 2 of 2

Continued on Form Number (AHI Project Code): bc-19-cricketvalley.ing stack #1

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 2241 NY-22
City: Wingdale | State: NY | Zip: 12594

Process: Combined Cycle | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:


Describe Emissions Point: Top of unit one
Height of Emiss. Pt. Start 300 ft End 300 ft | Height of Emiss. Pt. Rel. to Observer Start 300 ft End 300 ft
Distance to Emiss. Pt. Start 900 ft End 900 ft | Direction to Emiss. Pt. (Degrees) Start 7°N End 7°N

Vertical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 ft 189°S End 900 ft 189°S

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue | Sky Conditions Start Scattered End Scattered
Wind Speed Start 13 mph End 13 mph | Wind Direction Start NW End NW
Ambient Temp. Start 43.5 End 43.1 | Wet Bulb Temp. 33.9 | RH Percent 46.1

Source Layout Sketch



Latitude 41.6711 | Longitude -73.5790 | Declination

Additional Information

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observation Date: 07/19/2020 | Time Zone: EST -1hr | Start Time: 1330 | End Time: 1402

Observer's Name (Print): Matt Jones
Observer's Signature: [signature] | Date: 7/14/20
Organization: Air Physics
Certified By: CAA | Date: 1/3/20

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 1 of 2

Continued on Form Number (AHI Project Code): 5a-19-cricketvalley.ny-start#1

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 3241 NY-22
City: Wingdale | State: NY | Zip: 12594

Observation Date: 08/14/2020 | Time Zone: EST -1hr | Start Time: 1404 | End Time: 1434

Process: Combined Cycle | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:

Describe Emissions Pont: Top of unit one

Height of Emiss. Pt. Start 300 Ft End 300 Ft | Height of Emiss. Pt. Rel. to Observer Start 300 Ft End 300 Ft
Distance to Emiss. Pt. Start 900 Ft End 900 Ft | Direction to Emiss. Pt. (Degrees) Start 7W End 7W


Vetical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 Ft 189°S End 900 Ft 189°S

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue | Sky Conditions Start Scattered End Scattered
Wind Speed Start 13 kmph End 13.9 kmph | Wind Direction Start NW End NW
Ambient Temp. Start 43.1 End 42.7 | Wet Bulb Temp. 33.9 | RH Percent 42.1

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Source Layout Sketch



Latitude: 41.6711 | Longitude: -73.5790 | Declination:

Additional Information:

Observer's Name (Print): Matt Jurs
Observer's Signature: [signature] | Date: 8/14/20
Organization: AY Hygiene
Certified By: CAA | Date: 1/3/20

Method Used (Circle One)
Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 22 41 NY-22
City: Wingdale | State: NY | Zip: 12594

Process: Combined Cycle | Unit #: 1 | Operating Mode:
Control Equipment: | Operating Mode:


Describe Emissions Point: Top of unit exhaust
Height of Emiss. Pt. Start 300 ft End 300 ft | Height of Emiss. Pt. Rel. to Observer Start 300 ft End 300 ft
Distance to Emiss. Pt. Start 900 ft End 900 ft | Direction to Emiss. Pt. (Degrees) Start 70° N End 70° N

Vertical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 ft 189°S End 900 ft 189°S

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue | Sky Conditions Start scattered End scattered
Wind Speed Start 14 mph End 17.4 mph | Wind Direction Start NW End NW
Ambient Temp. Start 48.7 End 47.3 | Wet Bulb Temp. 34 | RH Percent 48.3

Source Layout Sketch



Latitude: 41.6711 | Longitude: -73.5790 | Declination:

Additional Information:

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code): | Page 2 of 2
Continued on Form Number (AHI Project Code): bc-19-cricket wkly .my -Stack #1
Observation Date: 02/19/2020 | Time Zone: EST -1hr | Start Time: 1134 | End Time: 1504

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Matt Jones
Observer's Signature: | Date: 2/19/20
Organization: Air Hygiene International, Inc.
Certified By: CAA | Date: 1/3/20

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load and Auxiliary Boiler
Opacity

Following completion of the stack emission test program for Unit #U-00001, it was discovered that the U-00001 fuel gas flow meter operation was tied to a “test mode” (Mode 0) setting, and not the expected “natural gas mode” setting (Mode 1). Further investigations of the impact of this setting, indicate that the initial Mode 0 fuel gas flow results have a positive bias of 1.5%. Consequently, the original fuel gas flow results (see U-00001-supplied operational fuel gas data) have been reduced by 1.5%. The operating mode of the Unit 1 gas flowmeter has been reset to the correct Mode 1 (natural gas).

Method Used (Circle One)
Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel Corporation
Facility Name: Cricket Valley Energy Center
Street Address: 2241 NY-22
City: Wingdale | State: NY | Zip: 12594

Process: combined cycle | Unit #: 1 | Operating Mode: AUX BOP w DB
Control Equipment | Operating Mode


Describe Emissions Point: Top of unit 1

	Start	End
Height of Emiss. Pt.	300 Ft	300 Ft
Height of Emiss. Pt. Rel. to Observer	300 Ft	300 Ft
Distance to Emiss. Pt.	900 Ft	900 Ft
Direction to Emiss. Pt. (Degrees)	70 N	70 N
Vetical Angle to Obs. Pt.	30°	30°
Direction to Obs. Pt. (Degrees)	189°S	189°S
Distance and Direction to Observation Point from Emission Point	900 Ft 189°S	900 Ft 189°S

Describe Emissions: Start None | End None
Emission Color: Start N/A | End N/A
Water Droplet Plume: Start N/A | End N/A

Describe Plume Background: Start blue | End blue
Background Color: Start blue | End blue
Sky Conditions: Start Scattered | End Scattered
Wind Speed: Start 10 mph | End 9 mph
Wind Direction: Start NW | End NW
Ambient Temp.: Start 40.1 | End 39.9
Wet Bulb Temp.: 65
RH Percent: 24

Source Layout Sketch



Latitude: 41.6708 | Longitude: -73.5789 | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 1 of 2
Continued on Form Number (AHI Project Code): Loc-19 - Cricket Valley Energy Start #1
Observation Date: 03/[illegible]/20 | Time Zone: EST | Start Time: 1250 | End Time: 1320

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): [illegible]
Observer's Signature: [illegible] | Date: 3/6/20
Organization: AHT
Certified By: CAA | Date: 1/3/2020

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Company Name: Bechtel corporation
Facility Name: cricket valley Energy center
Street Address: 22-41 NY-22
City: wingdale | State: NY | Zip: 12594

Process: combine cycle | Unit #: 1 | Operating Mode: Aux base w DB
Control Equipment | Operating Mode


Describe Emissions Point: Top of unit 1
Height of Emiss. Pt. Start 300 ft End 300 ft | Height of Emiss. Pt. Rel. to Observer Start 300 ft End 300 ft
Distance to Emiss. Pt. Start 900 ft End 900 ft | Direction to Emiss. Pt. (Degrees) Start 7° N End 7° N

Vertical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 ft 189°S End 900 ft 189°S

Describe Emissions Start None End None
Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue | Sky Conditions Start Scattered End Scattered
Wind Speed Start 10 mph End 10 mph | Wind Direction Start NW End NW
Ambient Temp. Start 39.9 End 39.7 | Wet Bulb Temp. 65 | RH Percent 29

Source Layout Sketch



Latitude 41.6708 | Longitude -73.5789 | Declination

Additional Information

Form Number (AHI Project Code) | Page 2 of 2
Continued on Form Number (AHI Project Code): bec-19-cricket valley energy ctr #1
Observation Date 03/06/2020 | Time Zone EST | Start Time 1220 | End Time 1350

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print)
Observer's Signature | Date 3/6/20
Organization AHI
Certified By CAA | Date 1/3/2020

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 1 of 2

Continued on Form Number (AHI Project Code): Loc-19-Cricket Valley Energy-Stack #1

Company Name: Bechtel corporation

Facility Name: Cricket Valley Energy Center

Street Address: 2241 NY-22

City: Wingdale | State: NY | Zip: 12594

Observation Date: 03/06/2020 | Time Zone: EST | Start Time: 1350 | End Time: 1420

Process: combined cycle | Unit #: 1 | Operating Mode: base AUX w DB

Control Equipment | Operating Mode

Describe Emissions Point: Top of unit 1

Height of Emiss. Pt. Start 300 Ft End 300 Ft | Height of Emiss. Pt. Rel. to Observer Start 300 Ft End 300 Ft

Distance to Emiss. Pt. Start 900 Ft End 900 Ft | Direction to Emiss. Pt. (Degrees) Start 7°N End 7°N

Vertical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S

Distance and Direction to Observation Point from Emission Point Start 900 Ft 189°S End 900 Ft 189°S

Describe Emissions Start None End None

Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start blue End blue


Background Color Start blue End blue | Sky Conditions Start Scattered End Scattered

Wind Speed Start 10.3mph End 10.6mph | Wind Direction Start NW End NW

Ambient Temp. Start 39.7 End 39.6 | Wet Bulb Temp. 65 | RH Percent 74

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	●	0	0	
30	0	0	0	0	

Source Layout Sketch



Latitude: 41.6708 | Longitude: -73.5789 | Declination

Additional Information

Observer's Name (Print): Rob White

Observer's Signature | Date: 03/06/20

Organization: AHT

Certified By: CAA | Date: 1/3/2020

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Bechtel corporation
Facility Name: cricket valley Energy center
Street Address: 2241 NY-22
City: Wingdale | State: NY | Zip: 12522

Process: combined cycle | Unit #: 1 | Operating Mode: Base MAX W DB
Control Equipment | Operating Mode


Describe Emissions Point: Top of unit 1

	Start	End
Height of Emiss. Pt.	300 ft	300 ft
Height of Emiss. Pt. Rel. to Observer	300 ft	300 ft
Distance to Emiss. Pt.	900 ft	900 ft
Direction to Emiss. Pt. (Degrees)	7° W	7° W
Vertical Angle to Obs. Pt.	30°	30°
Direction to Obs. Pt. (Degrees)	189°S	189°S
Distance and Direction to Observation Point from Emission Point	900 ft 189°S	900 ft 189°S

Describe Emissions: Start none | End none
Emission Color: Start N/A | End N/A
Water Droplet Plume: Start N/A | End N/A

Describe Plume Background: Start blue | End blue
Background Color: Start blue | End blue
Sky Conditions: Start Scattered | End Scattered
Wind Speed: Start 10.6 mph | End 11 mph
Wind Direction: Start NW | End NW
Ambient Temp.: Start 39.6 | End 39.6
Wet Bulb Temp.: 65
RH Percent: 74

Source Layout Sketch



Latitude: 41.6708 | Longitude: -73.5789 | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 2 of 2
Continued on Form Number (AHI Project Code): bec-19-cricket valley-ny-stat #1
Observation Date: 03/06/2020 | Time Zone: EST | Start Time: 1420 | End Time: 1450

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print)
Observer's Signature | Date 3/6/2020
Organization AHI
Certified By CAA | Date 1/3/2020

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 1 of 2

Continued on Form Number (AHI Project Code): lec-ny-cricket valley.ny-Start #1

Company Name: Bechtel Collaboration
Facility Name: Cricket Valley Energy Center
Street Address: 2241 NY-22
City: Wingdale | State: NY | Zip: 12594

Observation Date: 03/06/2020 | Time Zone: EST | Start Time: 1450 | End Time: 1520

Process: combined cycle | Unit #: 1 | Operating Mode: Base Aux w DB
Control Equipment | Operating Mode

Min \ Sec	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Point: Top of unit 1


Height of Emiss. Pt.: Start 300 ft End 300 ft | Height of Emiss. Pt. Rel. to Observer: Start 300 ft End 300 ft
Distance to Emiss. Pt.: Start 900 ft End 900 ft | Direction to Emiss. Pt. (Degrees): Start 70° End 70°

Vertical Angle to Obs. Pt.: Start 30° End 30° | Direction to Obs. Pt. (Degrees): Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point: Start 900 ft 189°S End 900 ft 189°S

Describe Emissions: Start Plume End Plume
Emission Color: Start N/A End N/A | Water Droplet Plume: Start N/A End N/A

Describe Plume Background: Start blue End blue
Background Color: Start blue End blue | Sky Conditions: Start Overcast End Scattered
Wind Speed: Start 11 mph End 11.2 mph | Wind Direction: Start NW End NW
Ambient Temp.: Start 39.5 End 39.5 | Wet Bulb Temp.: 65 | RH Percent: 24

Source Layout Sketch | Draw North Arrow



Latitude: 41.6708 | Longitude: -73.5789 | Declination

Additional Information

Observer's Name (Print): Kal White
Observer's Signature: [signature] | Date: 03/06/20
Organization: AHI
Certified By: CAA | Date: 1/3/2020

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Company Name: Becker corporation
Facility Name: cricket valley Energy center
Street Address: 2241 WY-22
City: Wingdale State: NY Zip: 12594

Process: crushed rock Unit #: 1 Operating Mode: base AUX w DP
Control Equipment: Operating Mode:

Describe Emissions Point: Top of unit 1


Height of Emiss. Pt. Start 30ft End 30ft | Height of Emiss. Pt. Rel. to Observer Start 30ft End 300ft
Distance to Emiss. Pt. Start 900ft End 900ft | Direction to Emiss. Pt. (Degrees) Start 7°N End 7°N

Vetical Angle to Obs. Pt. Start 30° End 30° | Direction to Obs. Pt. (Degrees) Start 189°S End 189°S
Distance and Direction to Observation Point from Emission Point Start 900 ft 189°S End 900 ft 189°S

Describe Emissions Start None End none
Emission Color Start N/A End N/A | Water Droplet Plume Start NA End N/A

Describe Plume Background Start blue End blue
Background Color Start blue End blue | Sky Conditions Start Scattered End Scattered
Wind Speed Start 11.5 mph End 11.5 mph | Wind Direction Start NW End NW
Ambient Temp. Start 39.5 End 39.1 | Wet Bulb Temp. | RH Percent

Source Layout Sketch



Latitude 41.6708 | Longitude -73.5789 | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) | Page 2 of 2
Continued on Form Number (AHI Project Code): bec-19 - Cricket Valley .ny Stack #1
Observation Date: 03/06/2020 | Time Zone: EST | Start Time: 1520 | End Time: 1550

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Rob White
Observer's Signature: | Date 3/6/20
Organization: AHL
Certified By: CAA | Date 1/3/2020

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

CERTIFICATE OF ANALYSIS
(Zero Ambient Nitrogen)

Cylinder Number:	CC731563	**Certification Date:**	12/12/2019
Product ID Number:	121026	**Expiration Date:**	12/10/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	CC731563.20191212-0	**Lot Number:**	CC731563.20191212
Customer PO. NO.:		**Tracking Number:**	098934324
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
PGVP Vendor ID # G12019
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

Anthony Cyr
Assistant Operations Manager

Version 02-B, Revised on 2015-05-27

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0096307	**Certification Date:**	09/13/2018
Product ID Number:	124605	**Expiration Date:**	09/11/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0096307.20180830-0	**Lot Number:**	EB0096307.20180830
Customer PO. NO.:		**Tracking Number:**	095690632
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**18.7 %**	±0.14 %	NDIR	09/13/2018
Oxygen	**21.1 %**	±0.11 %	MPA	09/04/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004987	EB0004987.20180323	07/15/2026	GMIS	N2	CO2	19.5 %	0.767	101001
EB0032246	EB0032246.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0097755	EB0097755.20171018-0	12/26/2025	GMIS	N2	CO2	24.86 %	0.212	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	09/04/2018
CO2	NDIR	Thermo	410i	1162980025	08/14/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0069916	**Certification Date:**	07/02/2019
Product ID Number:	124606	**Expiration Date:**	06/30/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0069916.20190618-0	**Lot Number:**	EB0069916.20190618
Customer PO. NO.:		**Tracking Number:**	084212429
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.95 %**	±0.05 %	NDIR	07/02/2019
Oxygen	**12.01 %**	±0.07 %	MPA	06/26/2019
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004987	EB0004987.20190327	06/18/2027	GMIS	N2	CO2	9.52 %	0.191	C1579010.02
EB0005592	EB0005592.20180118	07/21/2026	GMIS	N2	O2	11.98 %	0.507	071001
EB0049614	EB0049614.20180504	07/21/2026	GMIS	N2	O2	24 %	0.497	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	05/31/2019
CO2	NDIR	Thermo	410i	1162980025	07/01/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0018282	**Certification Date:**	02/27/2018
Product ID Number:	124606	**Expiration Date:**	02/25/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0018282.20180219-0	**Lot Number:**	EB0018282.20180219
Customer PO. NO.:		**Tracking Number:**	040342887
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.94 %**	±0.06 %	NDIR	02/27/2018
Oxygen	**11.96 %**	±0.06 %	MPA	02/23/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0019964	EB0019964.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0097755	EB0097755.20171018-0	12/26/2025	GMIS	N2	CO2	24.86 %	0.212	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	02/23/2018
CO2	NDIR	Thermo	410i	1162980025	02/26/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0019999	**Certification Date:**	09/14/2018
Product ID Number:	125780	**Expiration Date:**	09/13/2021
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0019999.20180724-0	**Lot Number:**	EB0019999.20180724
Customer PO. NO.:		**Tracking Number:**	040266073
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G2.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**18.3 PPM**	±0.2 PPM	FTIR	08/21/2018
Nitric Oxide	**17.5 PPM**	±0.2 PPM	Chemiluminescence	08/31/2018, 09/14/2018
Total Oxides of Nitrogen	17.8 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0001972	EB0001972.20180209	07/18/2021	GMIS	N2	NO	32.5 PPM	1.064	12100115
EB0005969	EB0005969.20171228	07/17/2026	GMIS	N2	NO	62.3 PPM	1.065	12100115
EB0010962	EB0010962.20171116	05/31/2021	GMIS	N2	NO	15.1 PPM	1.085	12100115
EB0024184	EB0024184.20171228	05/22/2026	GMIS	N2	NO	91 PPM	1.061	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	08/20/2018
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	08/20/2018
NO	Chemiluminescence	Thermo	42i-HL	1152610017	09/14/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0040961	**Certification Date:**	10/31/2019
Product ID Number:	124737	**Expiration Date:**	10/30/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0040961.20191017-0	**Lot Number:**	EB0040961.20191017
Customer PO. NO.:		**Tracking Number:**	065159907
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**9.1 PPM**	±0.12 PPM	FTIR	10/30/2019
Nitric Oxide	**8.8 PPM**	±0.10 PPM	Chemiluminescence	10/23/2019, 10/31/2019
Total Oxides of Nitrogen	8.9 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM005307	ALM0053007.20181025	10/09/2022	GMIS	N2	NO	34.2 PPM	1.062	1684B
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002
EB0089797	EB0089797.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.085	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	10/18/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/30/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0101718	**Certification Date:**	07/26/2019
Product ID Number:	125564	**Expiration Date:**	07/25/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0101718.20190710-0	**Lot Number:**	EB0101718.20190710
Customer PO. NO.:		**Tracking Number:**	095705907
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**5.09 PPM**	±0.07 PPM	FTIR	07/25/2019
Nitric Oxide	**4.98 PPM**	±0.06 PPM	Chemiluminescence	07/16/2019, 07/26/2019
Total Oxides of Nitrogen	4.99 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0032297	EB0032297.20160725	09/06/2025	GMIS	N2	CO	6.15 PPM	1.067	091002
EB0060662	EB0060662.20151012	01/02/2022	GMIS	N2	NO	2.97 PPM	1.062	12100115
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002
EB0078555	EB0078555.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.113	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	07/08/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0038438	**Certification Date:**	11/27/2018
Product ID Number:	126123	**Expiration Date:**	11/25/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0038438.20181121-0	**Lot Number:**	EB0038438.20181121
Customer PO. NO.:		**Tracking Number:**	056853515
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**8.77 PPM**	±0.05 PPM	FTIR	11/27/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0042063	EB0042063.20171231	03/17/2023	GMIS	N2	CH4	30.37 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/27/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0060640	**Certification Date:**	06/08/2018
Product ID Number:	124609	**Expiration Date:**	06/06/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0060640.20180604-0	**Lot Number:**	EB0060640.20180604
Customer PO. NO.:		**Tracking Number:**	082997030
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**4.90 PPM**	±0.03 PPM	FTIR	06/08/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/08/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0057200	**Certification Date:**	09/18/2018
Product ID Number:	125892	**Expiration Date:**	09/16/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0057200.20180913-0	**Lot Number:**	EB0057200.20180913
Customer PO. NO.:		**Tracking Number:**	074329951
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**3.37 PPM**	±0.03 PPM	FTIR	09/18/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/18/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

CERTIFIED GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0100161	**Certification Date:**	12/30/2019
Product ID Number:	125123	**Expiration Date:**	12/29/2020
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0100161.20191230-0	**Lot Number:**	EB0100161.20191230
Customer PO. NO.:		**Tracking Number:**	095703088
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Ammonia	**50.4 PPM**	± 2% NIST	FTIR
Sulfur Hexafluoride	**9.02 PPM**	± 2% NIST	FTIR
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
SA18481	70086910005	04/12/2020	PS	N2	NH3	21.1 PPM	1.2	73248226
EB0079029	EB0079029	06/27/2020	PS	N2	SF6	10.1 PPM	5	191064

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NH3	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	
SF6	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-G, Revised on 2017-07-02

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0026149	**Certification Date:**	01/19/2018
Product ID Number:	124731	**Expiration Date:**	01/18/2021
Cylinder Pressure:	1800 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0026149.20171219-0	**Lot Number:**	EB0026149.20171219
Customer PO. NO.:		**Tracking Number:**	048443465
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	**49.1 PPM**	±0.5 PPM	FTIR	01/12/2018, 01/19/2018

Air Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0084166	EB0084166.20161201	12/06/2020	GMIS	AIR	NO2	62.5 PPM	1.049	5605008

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	12/14/2017
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	01/12/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Nate Fielder
Anaylst
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the “hands of the test” on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the “hands of the test” on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene’s review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer’s instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody
Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training
Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3 A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods
With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy
Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

Data Provided by Client
Data provided by the Client is clearly identified in the report. Air Hygiene accepts data provided by the Client as accurate.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO_2 to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO_2 in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS
QUALITY ASSURANCE DATA

Date: February 17-19 and March __, 2020
Company: Cricket Valley Energy Center LLC
Location: Dover Plains, New York
Techs: RW / SB / AM / MW / AB / MJ / JJ

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
February 17-19 and March __, 2020	1	0

Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This laboratory also meets the A2LA *R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (*refer to joint ISO-ILAC-IAF Communiqué dated April 2017*).

Presented this 18th day of December 2019

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2021

For the tests to which this accreditation applies, please refer to the laboratory's Envrionmental Scope of Accreditation.

STACK TESTING ACCREDITATION COUNCIL

American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 18th day of December 2019.

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2021

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY

Qualified Source Testing Individual

LET IT BE KNOWN THAT

ROBERT C. WHITE, Jr.

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 25TH DAY OF OCTOBER 2019 AND EFFECTIVE UNTIL OCTOBER 24TH, 2024

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Tina Sanderson, QSTI/QSTO Review Board

J. Wade Bice, QSTI/QSTO Review Board

Karen D. Kajiya-Mills , QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board

CERTIFICATE NO. 2015-898

Compliance Assurance Associates Inc.

Helping Industry Comply with Environmental Regulations

This is to acknowledge that

Matt Jones

BRO200103-15622

Certificate verification is available at www.Compliance.Assurance.com/certs.php using the last name and 15622

successfully participated in Visible Emissions Evaluation field training and certification and pursuant to US EPA 40 CFR 60 Appendix A, Reference Method 9, as amended, is certified to evaluate Visible Emissions for a period of six (6) months from the date of this certification.



Anthony Ferro - Field Manager	Broken Arrow, OK	01/03/2020
	Location	Date

Compliance Assurance Associates, Inc. 682 Orvil Smith Rd, Harvest, AL, 35749. 901-381-9960. compliance-assurance.com

Compliance Assurance Associates Inc.

Helping Industry Comply with Environmental Regulations

This is to acknowledge that

Rob White

BRO200103-14351

Certificate verification is available at www.Compliance.Assurance.com/certs.php using the last name and 14351

successfully participated in Visible Emissions Evaluation field training and certification and pursuant to US EPA 40 CFR 60 Appendix A, Reference Method 9, as amended, is certified to evaluate Visible Emissions for a period of six (6) months from the date of this certification.



Anthony Ferro - Field Manager	Broken Arrow, OK	01/03/2020
	Location	Date

Compliance Assurance Associates, Inc. 682 Orvil Smith Rd, Harvest, AL, 35749. 901-381-9960. compliance-assurance.com

QUALITY ASSURANCE AND QUALITY CONTROL DATA


Daily Reference Method Analyzer Calibration Data

Calibration Date: February 17, 2020 **Location: Cricket Valley Energy Center - Unit U-00001**

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 17.80

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.06	0.34	0.06	YES (%)
8.90	8.73	-0.96	0.17	YES (%)
17.80	17.68	-0.67	0.12	YES (%)
Linearity = 1.010				




CO Span (ppm) = 18.30

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.00	0.00	0.00	YES (%)
9.10	9.10	0.00	0.00	YES (%)
18.30	18.37	0.38	0.07	YES (%)
Linearity = 0.996				



O_2 Span (%) = 21.10


SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.06	0.28	0.06	YES (%)
12.01	12.03	0.09	0.02	YES (%)
21.10	21.09	-0.05	0.01	YES (%)
Linearity = 1.003				



VOC (as C1) Range (ppm) = 10


VIG 210 (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass (±2,5%)[1]
0.00	0.00	0.00	N/A	YES
3.37	3.29	-3.74	3.42	YES
4.90	5.12	3.12	4.97	YES
8.77	8.89	1.20	N/A	YES
Linearity = 0.974				

[1]-zero/high based on 2% of span, low/mid based on 5% of concentration



CO_2 Span (%) = 18.70

SERVOMEX 1440 (CO_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.03	0.16	0.03	YES (%)
8.95	9.13	0.96	0.18	YES (%)
18.70	18.69	-0.05	0.01	YES (%)
Linearity = 1.002				




Calibration Date: February 19, 2020 **Location: Cricket Valley Energy Center - Unit U-00001**

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 17.80

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.02	0.11	0.02	YES (%)
8.90	8.81	-0.51	0.09	YES (%)
17.80	17.78	-0.11	0.02	YES (%)
Linearity = 1.002				




CO Span (ppm) = 18.30

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.00	0.00	0.00	YES (%)
9.10	9.12	0.11	0.02	YES (%)
18.30	18.38	0.44	0.08	YES (%)
Linearity = 0.996				



O_2 Span (%) = 21.10


SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.05	0.24	0.05	YES (%)
12.01	12.01	0.00	0.00	YES (%)
21.10	21.02	-0.38	0.08	YES (%)
Linearity = 1.006				



VOC (as C1) Range (ppm) = 10


VIG 210 (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass (±2,5%)[1]
0.00	0.00	0.00	N/A	YES
3.37	3.35	-0.37	3.36	YES
4.90	4.90	0.23	4.89	YES
8.77	8.75	-0.20	N/A	YES
Linearity = 1.001				

[1]-zero/high based on 2% of span,low/mid based on 5% of concentration



CO_2 Span (%) = 18.70

SERVOMEX 1440 (CO_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.00	0.00	0.00	YES (%)
8.95	9.03	0.43	0.08	YES (%)
18.70	18.71	0.05	0.01	YES (%)
Linearity = 1.000				



NOx Converter Efficiency

Date: February 17, 2020

Analyzer: inst-nx-0020

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**49.10**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**2.30**
	Analyzer Reading, NOx Channel, ppmvd	**48.37**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**46.07**
	Converter Efficiency, %	**93.83**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{46.07 \text{ ppmvd}}{49.10 \text{ ppmvd}}$ x 100 = 93.83%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
02/17/20 12:37:04	20	47.01	3.06
02/17/20 12:37:34	50	47.26	3.04
02/17/20 12:38:04	80	47.48	3.01
02/17/20 12:38:34	110	47.68	2.98
02/17/20 12:39:04	140	47.82	2.95
02/17/20 12:39:34	170	48.01	2.94
02/17/20 12:40:04	***200***	***48.37***	***2.30***

NOx Converter Efficiency

Date: February 19, 2020

Analyzer: inst-nx-0020

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**49.10**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**2.40**
	Analyzer Reading, NOx Channel, ppmvd	**47.72**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**45.32**
	Converter Efficiency, %	**92.30**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{45.32 \text{ ppmvd}}{49.10 \text{ ppmvd}}$ x 100 = 92.3%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
02/19/20 07:45:06	4160	47.57	2.56
02/19/20 07:45:36	4190	47.65	2.53
02/19/20 07:46:06	***4220***	***47.72***	***2.40***
02/19/20 07:46:36	4250	47.81	2.40
02/19/20 07:47:06	4280	47.87	2.49
02/19/20 07:47:36	4310	47.80	2.47
02/19/20 07:48:06	4340	47.65	2.44

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/17/20	7:42:04	UNIT 1 MKS_0014.LAB	9.2406
02/17/20	7:42:34	UNIT 1 MKS_0015.LAB	9.1524
02/17/20	7:43:04	UNIT 1 MKS_0016.LAB	9.1499
02/17/20	7:43:35	UNIT 1 MKS_0017.LAB	9.1572
02/17/20	7:44:05	UNIT 1 MKS_0018.LAB	9.1676

PRE TEST AVERAGE **9.17**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/17/20	19:00:10	UNIT 1 RUN 1_1362.LAB	9.0354
02/17/20	19:00:40	UNIT 1 RUN 1_1363.LAB	9.1390
02/17/20	19:01:10	UNIT 1 RUN 1_1364.LAB	8.8000
02/17/20	19:01:40	UNIT 1 RUN 1_1365.LAB	9.0642
02/17/20	19:02:10	UNIT 1 RUN 1_1366.LAB	9.1347

POST TEST AVERAGE **9.03**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.95

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.17	2.50	PASS
Post Test	9.03	0.95	PASS

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/17/20	7:52:09	UNIT 1 MKS_0034.LAB	47.8070
02/17/20	7:52:39	UNIT 1 MKS_0035.LAB	48.4938
02/17/20	7:53:09	UNIT 1 MKS_0036.LAB	55.8076
02/17/20	7:53:40	UNIT 1 MKS_0037.LAB	51.3194
02/17/20	7:54:10	UNIT 1 MKS_0038.LAB	47.7508

PRE TEST AVERAGE **50.24**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/17/20	19:21:43	UNIT 1 RUN 1_1405.LAB	50.5981
02/17/20	19:22:13	UNIT 1 RUN 1_1406.LAB	50.1445
02/17/20	19:22:43	UNIT 1 RUN 1_1407.LAB	50.4284
02/17/20	19:23:13	UNIT 1 RUN 1_1408.LAB	50.6571
02/17/20	19:23:43	UNIT 1 RUN 1_1409.LAB	50.6678

POST TEST AVERAGE **50.50**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 50.40

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	50.24	-0.33	PASS
Post Test	50.50	0.20	PASS

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd
02/17/20	8:16:16	UNIT 1 MKS_0082.LAB	50.1646
02/17/20	8:16:46	UNIT 1 MKS_0083.LAB	50.5970
02/17/20	8:17:16	UNIT 1 MKS_0084.LAB	50.7342
02/17/20	8:17:46	UNIT 1 MKS_0085.LAB	50.3635
02/17/20	8:18:17	UNIT 1 MKS_0086.LAB	50.8787
02/17/20	8:18:47	UNIT 1 MKS_0087.LAB	50.0742
02/17/20	8:19:17	UNIT 1 MKS_0088.LAB	50.3992
02/17/20	8:19:47	UNIT 1 MKS_0089.LAB	50.8070
RAW AVERAGE			**50.502**

Calibration Gas #2

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	SF_6 ppmvd
02/17/20	8:16:16	UNIT 1 MKS_0082.LAB	9.7448
02/17/20	8:16:46	UNIT 1 MKS_0083.LAB	9.7298
02/17/20	8:17:16	UNIT 1 MKS_0084.LAB	9.7354
02/17/20	8:17:46	UNIT 1 MKS_0085.LAB	9.7474
02/17/20	8:18:17	UNIT 1 MKS_0086.LAB	9.7394
02/17/20	8:18:47	UNIT 1 MKS_0087.LAB	9.7168
02/17/20	8:19:17	UNIT 1 MKS_0088.LAB	9.7326
02/17/20	8:19:47	UNIT 1 MKS_0089.LAB	9.7355
RAW AVERAGE			**9.735**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/17/20	8:27:18	UNIT 1 MKS_0104.LAB	4.8114	8.1644	1.6119	0.0013
02/17/20	8:27:48	UNIT 1 MKS_0105.LAB	4.8114	7.9960	1.7031	0.0012
02/17/20	8:28:18	UNIT 1 MKS_0106.LAB	4.8128	7.9803	1.7059	-0.0005
02/17/20	8:28:48	UNIT 1 MKS_0107.LAB	4.8128	7.8806	1.6900	-0.0038
02/17/20	8:29:18	UNIT 1 MKS_0108.LAB	4.8128	7.9795	1.7702	-0.0014
02/17/20	8:29:48	UNIT 1 MKS_0109.LAB	4.8134	7.9191	1.7365	-0.0053
02/17/20	8:30:18	UNIT 1 MKS_0110.LAB	4.8127	7.9927	1.8926	0.0000
02/17/20	8:30:48	UNIT 1 MKS_0111.LAB	4.8145	8.0350	1.8940	0.0032
RAW AVERAGE			**4.813**	**7.993**	**1.751**	**-0.001**

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/17/20	8:38:20	UNIT 1 MKS_0126.LAB	3.5403	8.5237	0.4365	3.9694
02/17/20	8:38:50	UNIT 1 MKS_0127.LAB	3.3992	8.4282	0.4354	3.9142
02/17/20	8:39:19	UNIT 1 MKS_0128.LAB	3.3643	8.4018	0.4263	3.6743
02/17/20	8:39:50	UNIT 1 MKS_0129.LAB	3.3928	8.4541	0.4353	3.7970
02/17/20	8:40:20	UNIT 1 MKS_0130.LAB	3.4090	8.4787	0.4284	3.8287
02/17/20	8:40:50	UNIT 1 MKS_0131.LAB	3.4332	8.2948	0.4389	3.9521
02/17/20	8:41:19	UNIT 1 MKS_0132.LAB	3.4566	8.6075	0.4380	3.8248
02/17/20	8:41:49	UNIT 1 MKS_0133.LAB	3.4204	8.5443	0.4294	4.3658
RAW AVERAGE			**3.427**	**8.467**	**0.434**	**3.916**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/17/20	8:49:20	UNIT 1 MKS_0148.LAB	4.8156	7.1468	1.7334	-0.0003
02/17/20	8:49:51	UNIT 1 MKS_0149.LAB	4.8153	6.9111	1.6884	0.0031
02/17/20	8:50:21	UNIT 1 MKS_0150.LAB	4.8166	7.1915	1.6402	0.0013
02/17/20	8:50:51	UNIT 1 MKS_0151.LAB	4.8184	6.8733	1.5827	-0.0008
02/17/20	8:51:21	UNIT 1 MKS_0152.LAB	4.8166	7.1891	1.5101	0.0003
02/17/20	8:51:51	UNIT 1 MKS_0153.LAB	4.8156	7.1163	1.4398	-0.0021
02/17/20	8:52:21	UNIT 1 MKS_0154.LAB	4.8160	8.0617	1.6926	-0.0024
02/17/20	8:52:51	UNIT 1 MKS_0155.LAB	4.8151	9.1029	1.5972	0.0000
RAW AVERAGE			**4.816**	**7.449**	**1.611**	**0.000**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/17/20	9:00:22	UNIT 1 MKS_0170.LAB	3.4330	8.6802	0.3922	3.8887
02/17/20	9:00:52	UNIT 1 MKS_0171.LAB	3.4392	9.5001	0.3922	3.7278
02/17/20	9:01:22	UNIT 1 MKS_0172.LAB	3.5215	9.2708	0.3916	3.8999
02/17/20	9:01:52	UNIT 1 MKS_0173.LAB	3.3741	8.6999	0.3918	3.8767
02/17/20	9:02:23	UNIT 1 MKS_0174.LAB	3.4539	8.5292	0.3922	3.5894
02/17/20	9:02:53	UNIT 1 MKS_0175.LAB	3.4656	8.4816	0.3916	3.5462
02/17/20	9:03:22	UNIT 1 MKS_0176.LAB	3.3611	8.4769	0.3912	3.4599
02/17/20	9:03:52	UNIT 1 MKS_0177.LAB	3.3528	8.6448	0.3909	3.4735
RAW AVERAGE			**3.425**	**8.785**	**0.392**	**3.683**

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/17/20	9:12:24	UNIT 1 MKS_0194.LAB	4.8199	8.8567	1.4464	0.0022
02/17/20	9:12:54	UNIT 1 MKS_0195.LAB	4.8202	9.3786	1.3426	-0.0028
02/17/20	9:13:24	UNIT 1 MKS_0196.LAB	4.8199	9.0872	1.3336	-0.0073
02/17/20	9:13:54	UNIT 1 MKS_0197.LAB	4.8196	9.1273	1.5250	0.0016
02/17/20	9:14:23	UNIT 1 MKS_0198.LAB	4.8200	8.7111	1.5254	-0.0026
02/17/20	9:14:54	UNIT 1 MKS_0199.LAB	4.8201	8.2667	1.4940	0.0007
02/17/20	9:15:24	UNIT 1 MKS_0200.LAB	4.8201	7.9235	1.4653	0.0021
02/17/20	9:15:54	UNIT 1 MKS_0201.LAB	4.8193	7.6802	1.4550	-0.0041
RAW AVERAGE			**4.820**	**8.629**	**1.448**	**-0.001**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/17/20	9:24:25	UNIT 1 MKS_0218.LAB	4.2543	8.4276	0.4913	3.9361
02/17/20	9:24:55	UNIT 1 MKS_0219.LAB	4.2414	8.4806	0.4906	4.0366
02/17/20	9:25:25	UNIT 1 MKS_0220.LAB	4.2871	8.1807	0.4907	3.9837
02/17/20	9:25:55	UNIT 1 MKS_0221.LAB	4.3099	8.5743	0.4906	3.7499
02/17/20	9:26:25	UNIT 1 MKS_0222.LAB	4.2646	8.5066	0.4904	3.9702
02/17/20	9:26:55	UNIT 1 MKS_0223.LAB	4.2633	8.3920	0.4904	3.8667
02/17/20	9:27:26	UNIT 1 MKS_0224.LAB	4.2941	8.7570	0.4901	4.0832
02/17/20	9:27:56	UNIT 1 MKS_0225.LAB	4.2737	8.7671	0.4888	3.9214
RAW AVERAGE			**4.274**	**8.511**	**0.490**	**3.943**

Cricket Valley Energy Center LLC
February 17, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	50.50	50.50	50.50
Concentration of SF_6 Cylinder	ppmvd	9.74	9.74	9.74

Spike A

Stack CO_2 Concentration	%vd	4.813	4.816	4.820
Stack H_2O Concentration	%	7.993	7.449	8.629
Stack NH_3 Concentration	ppmvd	1.751	1.611	1.448
Stack SF_6 Concentration	ppmvd	-0.001	0.000	-0.001
Stack + Spike CO_2 Concentration	%vd	3.427	3.425	4.274
Stack + Spike H_2O Concentration	%	8.467	8.785	8.511
Stack + Spike NH_3 Concentration	ppmvd	3.916	3.683	3.943
Stack + Spike SF_6 Concentration	ppmvd	0.434	0.392	0.490
Dilution Ratio		0.045	0.040	0.050
Ideal NH_3 Spike Yield	ppmvd	3.922	3.578	3.919
Percent Recovery NH_3	%	99.74%	105.17%	100.95%

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/19/20	3:18:07	UNIT 1 BKG_1507.LAB	9.1128
02/19/20	3:18:37	UNIT 1 BKG_1508.LAB	9.0001
02/19/20	3:19:07	UNIT 1 BKG_1509.LAB	8.9262
02/19/20	3:19:37	UNIT 1 BKG_1510.LAB	8.9381
02/19/20	3:20:07	UNIT 1 BKG_1511.LAB	8.9567

PRE TEST AVERAGE **8.99**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/19/20	7:44:39	UNIT 1 RUN 1_2029.LAB	8.9430
02/19/20	7:45:09	UNIT 1 RUN 1_2030.LAB	8.6493
02/19/20	7:45:39	UNIT 1 RUN 1_2031.LAB	8.8445
02/19/20	7:46:09	UNIT 1 RUN 1_2032.LAB	8.6241
02/19/20	7:46:39	UNIT 1 RUN 1_2033.LAB	8.7849

POST TEST AVERAGE **8.77**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.95

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	8.99	0.41	PASS
Post Test	8.77	-2.02	PASS

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/19/20	3:22:07	UNIT 1 BKG_1515.LAB	49.0988
02/19/20	3:22:37	UNIT 1 BKG_1516.LAB	49.2503
02/19/20	3:23:07	UNIT 1 BKG_1517.LAB	49.4185
02/19/20	3:23:37	UNIT 1 BKG_1518.LAB	49.5153
02/19/20	3:24:07	UNIT 1 BKG_1519.LAB	49.6730

PRE TEST AVERAGE **49.39**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/19/20	7:54:40	UNIT 1 RUN 1_2049.LAB	49.0707
02/19/20	7:55:11	UNIT 1 RUN 1_2050.LAB	49.7940
02/19/20	7:55:40	UNIT 1 RUN 1_2051.LAB	49.9085
02/19/20	7:56:11	UNIT 1 RUN 1_2052.LAB	50.2710
02/19/20	7:56:41	UNIT 1 RUN 1_2053.LAB	49.8649

POST TEST AVERAGE **49.78**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 50.40

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	49.39	-2.00	PASS
Post Test	49.78	-1.23	PASS

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd
02/19/20	3:27:08	UNIT 1 BKG_1525.LAB	47.9995
02/19/20	3:27:38	UNIT 1 BKG_1526.LAB	48.5635
02/19/20	3:28:08	UNIT 1 BKG_1527.LAB	49.0942
02/19/20	3:28:38	UNIT 1 BKG_1528.LAB	49.5615
02/19/20	3:29:08	UNIT 1 BKG_1529.LAB	49.8815
02/19/20	3:29:38	UNIT 1 BKG_1530.LAB	50.3110
02/19/20	3:30:08	UNIT 1 BKG_1531.LAB	50.5988
02/19/20	3:30:38	UNIT 1 BKG_1532.LAB	50.9278
RAW AVERAGE			**49.617**

Calibration Gas #2

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	SF_6 ppmvd
02/19/20	3:33:09	UNIT 1 BKG_1537.LAB	8.9793
02/19/20	3:33:39	UNIT 1 BKG_1538.LAB	8.9528
02/19/20	3:34:09	UNIT 1 BKG_1539.LAB	8.9671
02/19/20	3:34:39	UNIT 1 BKG_1540.LAB	8.9693
02/19/20	3:35:09	UNIT 1 BKG_1541.LAB	8.9746
02/19/20	3:35:39	UNIT 1 BKG_1542.LAB	8.9738
02/19/20	3:38:12	UNIT 1 BKG_1543BKG.LAB	8.8611
02/19/20	3:38:49	UNIT 1 BKG_1544.LAB	8.7872
RAW AVERAGE			**8.933**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/19/20	3:42:49	UNIT 1 BKG_1552.LAB	5.1699	8.7056	1.9962	-0.0115
02/19/20	3:43:20	UNIT 1 BKG_1553.LAB	5.1572	8.9031	1.8991	-0.0076
02/19/20	3:43:50	UNIT 1 BKG_1554.LAB	5.1530	8.6815	1.8251	-0.0061
02/19/20	3:44:19	UNIT 1 BKG_1555.LAB	5.1433	8.6307	1.7437	-0.0053
02/19/20	3:44:49	UNIT 1 BKG_1556.LAB	5.1531	8.8853	1.6789	-0.0061
02/19/20	3:45:19	UNIT 1 BKG_1557.LAB	5.1372	8.3918	1.6025	-0.0067
02/19/20	3:45:49	UNIT 1 BKG_1558.LAB	5.1407	8.9943	1.5784	-0.0072
02/19/20	3:46:20	UNIT 1 BKG_1559.LAB	5.1473	8.9234	1.6357	-0.0060
RAW AVERAGE			**5.150**	**8.764**	**1.745**	**-0.007**

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/19/20	3:50:20	UNIT 1 BKG_1567.LAB	3.3034	8.8276	0.3825	3.8811
02/19/20	3:50:50	UNIT 1 BKG_1568.LAB	3.1623	8.8262	0.3814	3.7114
02/19/20	3:51:20	UNIT 1 BKG_1569.LAB	3.1274	8.8262	0.3723	3.7006
02/19/20	3:51:51	UNIT 1 BKG_1570.LAB	3.1559	8.8266	0.3813	3.8002
02/19/20	3:52:20	UNIT 1 BKG_1571.LAB	3.1721	8.8261	0.3744	3.8436
02/19/20	3:52:51	UNIT 1 BKG_1572.LAB	3.1963	8.8259	0.3849	3.6096
02/19/20	3:53:21	UNIT 1 BKG_1573.LAB	3.2197	8.8253	0.3840	3.6948
02/19/20	3:53:51	UNIT 1 BKG_1574.LAB	3.1835	8.8263	0.3754	3.8130
RAW AVERAGE			**3.190**	**8.826**	**0.380**	**3.757**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/19/20	3:56:21	UNIT 1 BKG_1579.LAB	5.1554	8.7733	1.8008	-0.0084
02/19/20	3:56:51	UNIT 1 BKG_1580.LAB	5.1550	8.4849	1.7586	-0.0092
02/19/20	3:57:21	UNIT 1 BKG_1581.LAB	5.1553	8.7704	1.7133	-0.0107
02/19/20	3:57:51	UNIT 1 BKG_1582.LAB	5.1509	8.6380	1.7795	-0.0082
02/19/20	3:58:21	UNIT 1 BKG_1583.LAB	5.1647	8.5952	1.6892	-0.0089
02/19/20	3:58:51	UNIT 1 BKG_1584.LAB	5.1579	8.5910	1.6654	-0.0115
02/19/20	3:59:21	UNIT 1 BKG_1585.LAB	5.1568	8.6678	1.6233	-0.0083
02/19/20	3:59:52	UNIT 1 BKG_1586.LAB	5.1669	8.9784	1.6544	-0.0100
RAW AVERAGE			**5.158**	**8.687**	**1.711**	**-0.009**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/19/20	4:04:41	UNIT 1 RUN 1_1590.LAB	3.1108	8.8975	0.4382	3.8840
02/19/20	4:05:11	UNIT 1 RUN 1_1591.LAB	3.2701	8.6032	0.3743	3.8593
02/19/20	4:05:41	UNIT 1 RUN 1_1592.LAB	3.3577	8.6274	0.3558	3.8760
02/19/20	4:06:11	UNIT 1 RUN 1_1593.LAB	3.2087	8.6517	0.3699	3.8245
02/19/20	4:06:41	UNIT 1 RUN 1_1594.LAB	2.9525	9.0394	0.3618	3.7961
02/19/20	4:07:11	UNIT 1 RUN 1_1595.LAB	3.2355	9.0810	0.4004	3.7499
02/19/20	4:07:41	UNIT 1 RUN 1_1596.LAB	3.2865	8.9148	0.3767	3.8185
02/19/20	4:08:11	UNIT 1 RUN 1_1597.LAB	3.2150	8.7624	0.3964	3.8547
RAW AVERAGE			**3.205**	**8.822**	**0.384**	**3.833**

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/19/20	4:12:12	UNIT 1 RUN 1_1605.LAB	5.2003	8.5559	1.4172	-0.0679
02/19/20	4:12:42	UNIT 1 RUN 1_1606.LAB	5.2150	8.3897	1.5632	-0.0416
02/19/20	4:13:12	UNIT 1 RUN 1_1607.LAB	5.2155	8.3482	1.6687	-0.0720
02/19/20	4:13:42	UNIT 1 RUN 1_1608.LAB	5.2183	8.7567	1.2404	-0.1229
02/19/20	4:14:12	UNIT 1 RUN 1_1609.LAB	5.2118	8.7671	1.6588	-0.0461
02/19/20	4:14:42	UNIT 1 RUN 1_1610.LAB	5.2413	8.7810	1.9392	-0.1001
02/19/20	4:15:12	UNIT 1 RUN 1_1611.LAB	5.2240	8.6494	1.6206	-0.0819
02/19/20	4:15:42	UNIT 1 RUN 1_1612.LAB	5.2109	8.5975	1.7034	-0.0851
RAW AVERAGE			**5.217**	**8.606**	**1.601**	**-0.077**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/19/20	4:17:42	UNIT 1 RUN 1_1616.LAB	3.3300	8.9661	0.4167	3.9361
02/19/20	4:18:12	UNIT 1 RUN 1_1617.LAB	3.3489	8.8797	0.4376	4.0366
02/19/20	4:18:42	UNIT 1 RUN 1_1618.LAB	3.2875	8.9260	0.4357	3.9837
02/19/20	4:19:13	UNIT 1 RUN 1_1619.LAB	3.0759	8.7065	0.4305	3.7499
02/19/20	4:19:43	UNIT 1 RUN 1_1620.LAB	3.1805	8.8473	0.4297	3.9702
02/19/20	4:20:13	UNIT 1 RUN 1_1621.LAB	3.2341	8.7714	0.4478	3.8667
02/19/20	4:20:43	UNIT 1 RUN 1_1622.LAB	3.1729	8.8713	0.4861	4.0832
02/19/20	4:21:13	UNIT 1 RUN 1_1623.LAB	3.0820	8.8454	0.4287	3.9214
RAW AVERAGE			**3.214**	**8.852**	**0.439**	**3.943**

Cricket Valley Energy Center LLC
February 19, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	49.62	49.62	49.62
Concentration of SF_6 Cylinder	ppmvd	8.93	8.93	8.93

Spike A

Stack CO_2 Concentration	%vd	5.150	5.158	5.217
Stack H_2O Concentration	%	8.764	8.687	8.606
Stack NH_3 Concentration	ppmvd	1.745	1.711	1.601
Stack SF_6 Concentration	ppmvd	-0.007	-0.009	-0.077
Stack + Spike CO_2 Concentration	%vd	3.190	3.205	3.214
Stack + Spike H_2O Concentration	%	8.826	8.822	8.852
Stack + Spike NH_3 Concentration	ppmvd	3.757	3.833	3.943
Stack + Spike SF_6 Concentration	ppmvd	0.380	0.384	0.439
Dilution Ratio		0.042	0.043	0.049
Ideal NH_3 Spike Yield	ppmvd	3.779	3.771	3.962
Percent Recovery NH_3	%	98.96%	102.90%	99.26%

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	0.07	0.13
Final Zero	0.07	0.35
Avg. Zero	0.07	0.24
Initial UpScale	11.99	4.87
Final UpScale	11.86	4.71
Avg. UpScale	11.93	4.79
Sys Resp (Zero)	0.04	0.00
Sys Resp (Upscale)	11.99	4.98
Upscale Cal Gas	11.96	4.99
Initial Zero Bias	0.14%	1.46%
Final Zero Bias	0.14%	3.93%
Zero Drift	0.00%	2.47%
Initial Upscale Bias	0.00%	-1.24%
Final Upscale Bias	-0.62%	-3.03%
Upscale Drift	0.62%	1.80%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.13
Alternative Specification Abs Diff **Final Zero**	0.03	0.35
Alternative Specification Abs Diff **Initial Upscale**	0.00	0.11
Alternative Specification Abs Diff **Final Upscale**	0.13	0.27
Calibration Span	21.10	8.90
3% of Cal. Span (drift)	0.63	0.27
5% of Cal. Span (bias)	1.06	0.45

Response Time (min)	1.7	4.0
Sys. Response (min)	4.0	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
02/05/20 14:15:10		**12.14**			3.02		x
02/05/20 14:15:20		**11.60**			3.02		
02/05/20 14:15:30		11.06			3.02		
02/05/20 14:15:40		10.52			3.02		
02/05/20 14:15:50		11.03			2.55		
02/05/20 14:16:00		**11.55**	x		2.08		
02/05/20 14:16:10		**12.07**			1.60		
02/05/20 14:16:20		**12.07**			1.27		
02/05/20 14:16:30		**12.07**			0.93		
02/05/20 14:16:40		**12.08**			0.60		
02/05/20 14:16:50		**12.08**			0.59		
02/05/20 14:17:00		**12.08**			0.58		
02/05/20 14:17:10		**12.08**			0.57		
02/05/20 14:17:20		**12.08**		x	**0.39**		
02/05/20 14:17:30		**12.08**			**0.21**		
02/05/20 14:17:40		**12.08**			**0.03**		
02/05/20 14:17:50		**12.08**			**-0.02**		
02/05/20 14:18:00		**12.08**			**-0.07**		
02/05/20 14:18:10		**12.08**			**-0.12**		
02/05/20 14:18:20		**12.08**			**-0.11**		
02/05/20 14:18:30		**12.09**			**-0.09**		x
02/05/20 14:18:40		**12.09**			**-0.07**		
02/05/20 14:18:50		**12.09**			**-0.07**		
02/05/20 14:19:00		**12.09**			**-0.07**		
02/05/20 14:19:10		**12.10**			**-0.07**		
02/05/20 14:19:20		9.77			**-0.05**		
02/05/20 14:19:30		7.44			**-0.03**		
02/05/20 14:19:40		5.11			**0.00**		
02/05/20 14:19:50		3.59			0.79		
02/05/20 14:20:00		2.08			1.58		
02/05/20 14:20:10	x	**0.56**			2.38		
02/05/20 14:20:20		**0.43**			3.11		
02/05/20 14:20:30		**0.30**			3.84		
02/05/20 14:20:40		**0.16**			4.57		
02/05/20 14:20:50		**0.14**			4.57		
02/05/20 14:21:00		**0.11**			4.58		
02/05/20 14:21:10		**0.09**			4.58		
02/05/20 14:21:20		**0.08**			4.57		
02/05/20 14:21:30		**0.08**			4.55		
02/05/20 14:21:40		**0.07**			4.54		
02/05/20 14:21:50		**0.07**			4.54		
02/05/20 14:22:00		**0.06**			4.55		
02/05/20 14:22:10		**0.06**			4.55		
02/05/20 14:22:20		**0.05**			4.62		
02/05/20 14:22:30		**0.05**			**4.68**		x
02/05/20 14:22:40		**0.05**			**4.75**		
02/05/20 14:22:50		**0.05**			**4.77**		
02/05/20 14:23:00		**0.05**			**4.78**		
02/05/20 14:23:10		**0.04**			**4.80**		

DRIFT AND BIAS CHECK					
Base Load, Run - 1-1	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.91	2.48	0.32	0.54	4.82
Corrected Average	12.88	2.45	0.31	0.57	4.82
Initial Zero	0.03	0.01	0.00	0.01	0.00
Final Zero	0.10	0.02	0.01	0.01	0.03
Avg. Zero	0.07	0.02	0.01	0.01	0.02
Initial UpScale	11.99	8.91	9.08	3.29	8.94
Final UpScale	12.10	9.06	9.15	3.30	8.91
Avg. UpScale	12.05	8.99	9.12	3.30	8.93
Sys Resp (Zero)	0.06	0.06	0.00	0.00	0.03
Sys Resp (Upscale)	12.03	8.73	9.10	3.29	9.13
Upscale Cal Gas	12.01	8.90	9.10	3.37	8.95
Initial Zero Bias	-0.14%	-0.28%	0.00%	0.10%	-0.16%
Final Zero Bias	0.19%	-0.22%	0.05%	0.10%	0.00%
Zero Drift	0.33%	0.06%	0.05%	0.00%	0.16%
Initial Upscale Bias	-0.19%	1.01%	-0.11%	0.00%	-1.02%
Final Upscale Bias	0.33%	1.85%	0.27%	0.10%	-1.18%
Upscale Drift	0.52%	0.84%	0.38%	0.10%	0.16%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.05	0.00	--	0.03
Alternative Specification Abs Diff **Final Zero**	0.04	0.04	0.01	--	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.04	0.18	0.02	--	0.19
Alternative Specification Abs Diff **Final Upscale**	0.07	0.33	0.05	--	0.22
Calibration Span	21.10	17.80	18.30	10.00	18.70
3% of Cal. Span (drift)	0.63	0.53	0.55	0.30	0.56
5% of Cal. Span (bias)	1.06	0.89	0.92	0.50	0.94

DRIFT AND BIAS CHECK					
Base Load, Run - 1-2	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.95	2.38	0.41	0.25	4.82
Corrected Average	12.88	2.34	0.40	0.27	4.81
Initial Zero	0.10	0.02	0.01	0.01	0.03
Final Zero	0.03	0.02	0.00	0.00	0.02
Avg. Zero	0.07	0.02	0.01	0.01	0.03
Initial UpScale	12.10	9.06	9.15	3.30	8.91
Final UpScale	12.06	8.94	9.07	3.28	8.99
Avg. UpScale	12.08	9.00	9.11	3.29	8.95
Sys Resp (Zero)	0.06	0.06	0.00	0.00	0.03
Sys Resp (Upscale)	12.03	8.73	9.10	3.29	9.13
Upscale Cal Gas	12.01	8.90	9.10	3.37	8.95
Initial Zero Bias	0.19%	-0.22%	0.05%	0.10%	0.00%
Final Zero Bias	-0.14%	-0.22%	0.00%	0.00%	-0.05%
Zero Drift	0.33%	0.00%	0.05%	0.10%	0.05%
Initial Upscale Bias	0.33%	1.85%	0.27%	0.10%	-1.18%
Final Upscale Bias	0.14%	1.18%	-0.16%	-0.10%	-0.75%
Upscale Drift	0.19%	0.67%	0.44%	0.20%	0.43%
Alternative Specification Abs Diff **Initial Zero**	0.04	0.04	0.01	--	0.00
Alternative Specification Abs Diff **Final Zero**	0.03	0.04	0.00	--	0.01
Alternative Specification Abs Diff **Initial Upscale**	0.07	0.33	0.05	--	0.22
Alternative Specification Abs Diff **Final Upscale**	0.03	0.21	0.03	--	0.14
Calibration Span	21.10	17.80	18.30	10.00	18.70
3% of Cal. Span (drift)	0.63	0.53	0.55	0.30	0.56
5% of Cal. Span (bias)	1.06	0.89	0.92	0.50	0.94

DRIFT AND BIAS CHECK					
Base Load, Run - 1-3	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.95	2.45	0.02	0.02	4.82
Corrected Average	12.90	2.43	0.02	0.02	4.79
Initial Zero	0.03	0.02	0.00	0.00	0.02
Final Zero	0.01	0.00	0.00	0.00	0.02
Avg. Zero	0.02	0.01	0.00	0.00	0.02
Initial UpScale	12.06	8.94	9.07	3.28	8.99
Final UpScale	12.05	8.96	9.11	3.33	9.01
Avg. UpScale	12.06	8.95	9.09	3.31	9.00
Sys Resp (Zero)	0.06	0.06	0.00	0.00	0.03
Sys Resp (Upscale)	12.03	8.73	9.10	3.29	9.13
Upscale Cal Gas	12.01	8.90	9.10	3.37	8.95
Initial Zero Bias	-0.14%	-0.22%	0.00%	0.00%	-0.05%
Final Zero Bias	-0.24%	-0.34%	0.00%	0.00%	-0.05%
Zero Drift	0.09%	0.11%	0.00%	0.00%	0.00%
Initial Upscale Bias	0.14%	1.18%	-0.16%	-0.10%	-0.75%
Final Upscale Bias	0.09%	1.29%	0.05%	0.40%	-0.64%
Upscale Drift	0.05%	0.11%	0.22%	0.50%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.04	0.00	--	0.01
Alternative Specification Abs Diff **Final Zero**	0.05	0.06	0.00	--	0.01
Alternative Specification Abs Diff **Initial Upscale**	0.03	0.21	0.03	--	0.14
Alternative Specification Abs Diff **Final Upscale**	0.02	0.23	0.01	--	0.12
Calibration Span	21.10	17.80	18.30	10.00	18.70
3% of Cal. Span (drift)	0.63	0.53	0.55	0.30	0.56
5% of Cal. Span (bias)	1.06	0.89	0.92	0.50	0.94

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-1	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	11.69	2.56	0.00	0.00	5.13
Corrected Average	11.71	2.54	0.00	0.00	5.09
Initial Zero	0.03	0.01	0.00	0.00	0.00
Final Zero	0.01	0.00	0.00	0.00	0.00
Avg. Zero	0.02	0.01	0.00	0.00	0.00
Initial UpScale	11.99	8.87	9.08	3.39	9.01
Final UpScale	12.00	8.99	9.13	3.32	9.03
Avg. UpScale	12.00	8.93	9.11	3.36	9.02
Sys Resp (Zero)	0.05	0.02	0.00	0.00	0.00
Sys Resp (Upscale)	12.01	8.81	9.12	3.35	9.03
Upscale Cal Gas	12.01	8.90	9.10	3.37	8.95
Initial Zero Bias	-0.09%	-0.06%	0.00%	0.00%	0.00%
Final Zero Bias	-0.19%	-0.11%	0.00%	0.00%	0.00%
Zero Drift	0.09%	0.06%	0.00%	0.00%	0.00%
Initial Upscale Bias	-0.09%	0.34%	-0.22%	0.40%	-0.11%
Final Upscale Bias	-0.05%	1.01%	0.05%	-0.30%	0.00%
Upscale Drift	0.05%	0.67%	0.27%	0.70%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.02	0.01	0.00	--	0.00
Alternative Specification Abs Diff **Final Zero**	0.04	0.02	0.00	--	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.02	0.06	0.04	--	0.02
Alternative Specification Abs Diff **Final Upscale**	0.01	0.18	0.01	--	0.00
Calibration Span	21.10	17.80	18.30	10.00	18.70
3% of Cal. Span (drift)	0.63	0.53	0.55	0.30	0.56
5% of Cal. Span (bias)	1.06	0.89	0.92	0.50	0.94

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-2	O_2	NOx	CO	VOC (as C1)	CO_2
Raw Average	11.67	2.55	0.00	0.00	5.13
Corrected Average	11.69	2.54	0.00	0.00	5.10
Initial Zero	0.01	0.00	0.00	0.00	0.00
Final Zero	0.02	0.00	0.00	0.00	0.00
Avg. Zero	0.02	0.00	0.00	0.00	0.00
Initial UpScale	12.00	8.99	9.13	3.32	9.03
Final UpScale	11.97	8.86	9.08	3.40	8.98
Avg. UpScale	11.99	8.93	9.11	3.36	9.01
Sys Resp (Zero)	0.05	0.02	0.00	0.00	0.00
Sys Resp (Upscale)	12.01	8.81	9.12	3.35	9.03
Upscale Cal Gas	12.01	8.90	9.10	3.37	8.95
Initial Zero Bias	-0.19%	-0.11%	0.00%	0.00%	0.00%
Final Zero Bias	-0.14%	-0.11%	0.00%	0.00%	0.00%
Zero Drift	0.05%	0.00%	0.00%	0.00%	0.00%
Initial Upscale Bias	-0.05%	1.01%	0.05%	-0.30%	0.00%
Final Upscale Bias	-0.19%	0.28%	-0.22%	0.50%	-0.27%
Upscale Drift	0.14%	0.73%	0.27%	0.80%	0.27%
Alternative Specification Abs Diff: Initial Zero	0.04	0.02	0.00	--	0.00
Alternative Specification Abs Diff: Final Zero	0.03	0.02	0.00	--	0.00
Alternative Specification Abs Diff: Initial Upscale	0.01	0.18	0.01	--	0.00
Alternative Specification Abs Diff: Final Upscale	0.04	0.05	0.04	--	0.05
Calibration Span	21.10	17.80	18.30	10.00	18.70
3% of Cal. Span (drift)	0.63	0.53	0.55	0.30	0.56
5% of Cal. Span (bias)	1.06	0.89	0.92	0.50	0.94

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-3	O_2	NOx	CO	VOC (as C1)	CO_2
Raw Average	11.56	2.48	0.25	0.00	5.02
Corrected Average	11.58	2.48	0.25	0.00	5.01
Initial Zero	0.02	0.00	0.00	0.00	0.00
Final Zero	0.00	0.00	0.00	0.00	0.00
Avg. Zero	0.01	0.00	0.00	0.00	0.00
Initial UpScale	11.97	8.86	9.08	3.40	8.98
Final UpScale	11.99	8.96	9.24	3.35	8.96
Avg. UpScale	11.98	8.91	9.16	3.38	8.97
Sys Resp (Zero)	0.05	0.02	0.00	0.00	0.00
Sys Resp (Upscale)	12.01	8.81	9.12	3.35	9.03
Upscale Cal Gas	12.01	8.90	9.10	3.37	8.95
Initial Zero Bias	-0.14%	-0.11%	0.00%	0.00%	0.00%
Final Zero Bias	-0.24%	-0.11%	0.00%	0.00%	0.00%
Zero Drift	0.09%	0.00%	0.00%	0.00%	0.00%
Initial Upscale Bias	-0.19%	0.28%	-0.22%	0.50%	-0.27%
Final Upscale Bias	-0.09%	0.84%	0.66%	0.00%	-0.37%
Upscale Drift	0.09%	0.56%	0.87%	0.50%	0.11%
Alternative Specification Abs Diff: Initial Zero	0.03	0.02	0.00	--	0.00
Alternative Specification Abs Diff: Final Zero	0.05	0.02	0.00	--	0.00
Alternative Specification Abs Diff: Initial Upscale	0.04	0.05	0.04	--	0.05
Alternative Specification Abs Diff: Final Upscale	0.02	0.15	0.12	--	0.07
Calibration Span	21.10	17.80	18.30	10.00	18.70
3% of Cal. Span (drift)	0.63	0.53	0.55	0.30	0.56
5% of Cal. Span (bias)	1.06	0.89	0.92	0.50	0.94

AIR HYGIENE

SINGLE LOAD TEST - FIELD DATA SHEET

Company:	Cricket Valley Energy LLC
Location:	Cricket Valley Energy Center
Date:	3-17-26 Project Code: bec-19-cricketvalley.ny-Start#1
Unit Make and Model:	General Electric 7F.05
Unit Number:	GT-00001
Serial Number:	
Data Recorded By:	AB
Tested With AHI Unit(s):	Truck(s): Trailer(s):
LDEQ Warmup/Cal Req:	On (Day/Time): Cal (Day/Time):

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low			
	Mid	EB0069916	EB0040967	EB0040967
	High	EB0096307	EB0019999	EB0019999

CYLINDER SERIAL NUMBERS		THC	CO_2	NH3
	Low	EB0003761		
	Mid	EB0057200	EB0069916	
	High	EB0038438	EB0096307	EB0100161

Stack Dia. = _____
Measured By: _____
Measured With: _____

RUN INFORMATION	Load		
	____% #1	____% #2	____% #3
Time Start (hh:mm:ss)	13:35:04	14:50:04	16:00:01
Time Stop (hh:mm:ss)	14:34:34	15:49:34	16:59:31
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)	30.28	3028	30.3
Ambient Temperature (°F)	43	43	45
Relative Humidity (%)	41	40	39
Turbine Fuel Flow (SCFH)			
Duct Burner Fuel Flow (SCFH)			
Power Output			

NO_2 CONVERSION	
NO_2 Gas (ppm)	49.1
NO Reading (ppm)	2.3
NOx Reading (ppm)	48.37
Cylinder Num	EB0026149

REPORT INFORMATION		
	INSTRUMENT	SERIAL #
O_2	servomax 1440	inst-02-0014
NOx	Thermo 42I-HL	inst-nx-00020
CO	Thermo 48I	inst-co-0045

RESPONSE TIME		
	TIME (hh:mm)	RESP (min)
1st Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
2nd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
3rd Gas Inject		

CALIBRATION	O_2		NOx		CO		THC		CO_2		SO_2	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0	.06	0	.06	0	0	0	0	0	.03		
Low Gas				0			3.37	3.24				
Mid Gas	11.96	12.03	8.9	8.73	9.1	9.1	4.84	5.12	8.99	9.13		
High Gas	21	21.09	17.8	17.68	18.3	18.37	8.77	8.89	18.7	18.69		

BIAS	O_2		NOx		CO		THC		CO_2		SO_2	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Run #1	.03	11.99	.01	8.91	0	9.08	.01	3.29	0	8.94		
Run #1 / Run #2	.01	12.1	.02	9.06	.01	9.15	.01	3.36	.03	8.91		
Run #2 / Run #3	.03	12.06	.02	8.94	0	9.07	0	3.28	.02	8.94		
Run #3 / Final	.01	12.05	0	8.96	0	9.11	0	3.33	.02	9.01		
Bias Gas Actual Conc.												

Signature _____

SINGLE LOAD TEST - FIELD DATA SHEET

AIR HYGIENE

Company:	Cricket Valley Energy LLC
Location:	Cricket Valley Energy Center
Date:	2-19-20 Project Code: bec-19-cricketvalley.ny-Start#1
Unit Make and Model:	General Electric 7F.05
Unit Number:	GT-00001
Serial Number:	
Data Recorded By:	AB
Tested With AHI Unit(s):	Truck(s): Trailer(s):
LDEQ Warmup/Cal Req:	On (Day/Time): Cal (Day/Time):

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low			
	Mid	EB0069916	EB0040967	EB0040967
	High	EB0096307	EB0019999	EB0019999

Stack Dia. = _____
Measured By: _____
Measured With: _____

CYLINDER SERIAL NUMBERS		THC	CO_2	NH3
	Low	EB0003761		
	Mid	EB0057200	EB0069916	
	High	EB0038438	EB0096307	EB0100161

RUN INFORMATION	Load		
	_____% #1	_____% #2	_____% #3
Time Start (hh:mm:ss)	4:25:06	5:33:06	6:41:06
Time Stop (hh:mm:ss)	5:24:36	6:32:36	7:40:36
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)	30.07	30.11	30.15
Ambient Temperature (°F)	37	36	34
Relative Humidity (%)	81	72	76
Turbine Fuel Flow (SCFH)			
Duct Burner Fuel Flow (SCFH)			
Power Output			

NO_2 CONVERSION	
NO_2 Gas (ppm)	49.1
NO Reading (ppm)	2.4
NOx Reading (ppm)	47.72
Cylinder Num	EB0026149

REPORT INFORMATION		
	INSTRUMENT	SERIAL #
O_2	servomax 1440	inst-02-0014
NOx	Thermo 42I-HL	inst-nx-00020
CO	Thermo 48I	inst-co-0045

RESPONSE TIME		
	TIME (hh:mm)	RESP (min)
1st Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
2nd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
3rd Gas Inject		

CALIBRATION	O_2		NOx		CO		THC		CO_2		SO_2	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0	.05	0	.02	0	Ø	0	Ø	0	Ø		
Low Gas							3.37	3.35				
Mid Gas	11.96	12.01	8.9	8.81	9.1	9.12	4.84	4.9	8.99	9.03		
High Gas	21	21.02	17.8	17.78	18.3	18.38	8.77	8.75	18.7	18.71		

BIAS	O_2		NOx		CO		THC		CO_2		SO_2	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Run #1	.03	11.99	.01	8.87	Ø	9.08	Ø	3.39	Ø	9.01		
Run #1 / Run #2	.01	12.0	Ø	8.94	Ø	9.13	Ø	3.32	Ø	9.03		
Run #2 / Run #3	.02	11.97	Ø	8.86	Ø	9.08	Ø	3.40	Ø	8.98		
Run #3 / Final	Ø	11.99	Ø	8.96	Ø	9.24	Ø	3.35	Ø	8.96		
Bias Gas Actual Conc.												

Signature _____

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data Summary Base Load PM_{10}

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	02/16/20
Sampling Location	U-00001 Base	**Operator**	Aaron Blum
Project #	bec-19-cricketvalley.ny-start#1		

Run History Data				
Run Number	PM U-00001 Base-1	PM U-00001 Base-2	PM U-00001 Base-3	
Run Start Time	17:02	23:05	14:25	(hh:mm)
Run Stop Time	22:11	04:05	18:27	(hh:mm)
Train Prepared By	RW	RW	RW	
Train Recovered By	RW	RW	RW	
Recovery Date	02/17/20	02/18/20	02/19/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	02/20/20	02/20/20	02/20/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039
Sample Box	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099
PM Filter	18082942	18092937	18082945
CPM Filter	PM U-00001 Base-1-CPM	PM U-00001 Base-2-CPM	PM U-00001 Base-3-CPM

Sample Blank Taken	☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	1743.0	1821.4	1825.5	g
Initial Weight	(W_i)	1626.4	1680.3	1688.7	g
Net Weight	(W_n)	116.6	141.1	136.8	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	859.0	901.3	930.1	g
Initial Weight	(W_i)	842.4	889.0	918.6	g
Net Weight	(W_n)	16.6	12.3	11.5	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	133.2	153.4	148.3	g
Total Volume	(V_{lc})	133.4	153.7	148.6	ml

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base-1		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

(3) Negative weight observed WET, Filter received wet, * Reported at RDL

Gravimetric Concentrations			**Run**		1	**Start Time**	17:02
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	(3) --	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			16.2	100	0.0000	16.2000	
Cyclone Wash 2.5<PM<10			1.3	130	0.0000	1.3000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.7	130	0.0000	1.7000	
Inorganic Impinger Contents			4.6	502	1.4762	3.1238	
Organic Impinger Contents			1.6	228	0.5238	1.0762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base-2		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

(2) Negative weight observed, * Reported at RDL

Gravimetric Concentrations			**Run**		2	**Start Time**	23:05
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	(2) --	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			14.5	110	0.0000	14.5000	
Cyclone Wash 2.5<PM<10			1.7	130	0.0000	1.7000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			2.7	130	0.0000	2.7000	
Inorganic Impinger Contents			4.2	441	1.4762	2.7238	
Organic Impinger Contents			2.4	349	0.5238	1.8762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base-3		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations

Blank Type	Weight	Volume	Concentration	Mass	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

(4) Negtive results observed WET, Filter received wet LFT, Loose filter material in the petri dish DE, Edges of the filter are frayed, * Reported at RDL

Gravimetric Concentrations			**Run**		3	**Start Time**	14:25
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	(4) --	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			14.0	97	0.0000	14.0000	
Cyclone Wash 2.5<PM<10			1.5	85	0.0000	1.5000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.7	63	0.0000	1.7000	
Inorganic Impinger Contents			3.6	441	1.4762	2.1238	
Organic Impinger Contents		*	1.0	349	0.5238	0.4762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base-FB		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Gravimetric Concentrations					
Sample Portion	**Final**	**Tare**	**Gain**		**Actual Gain**
	(g)	(g)	(mg)		(mg)
Inorganic Impinger Contents	0.0031	0.0000	1.4762	max 2 mg total blank adjustment, proportioned	3.1000
Organic Impinger Contents	0.0011	0.0000	0.5238		1.1000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data Summary Base+DB Load PM_{10}

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	02/18/20
Sampling Location	U-00001 Base+DB	**Operator**	Aaron Blum
Project #	bec-19-cricketvalley.ny-start#1		

Run History Data				
Run Number	PM U-00001 Base+DB-1	PM U-00001 Base+DB-2	PM U-00001 Base+DB-3	
Run Start Time	14:55	04:24	09:14	(hh:mm)
Run Stop Time	19:04	08:15	13:51	(hh:mm)
Train Prepared By	RW	RW	RW	
Train Recovered By	RW	RW	RW	
Recovery Date	02/18/20	08/19/20	08/19/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	02/20/20	02/20/20	02/20/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039
Sample Box	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099
PM Filter	18042521	18082944	18082938
CPM Filter	PM U-00001 Base+DB-1-CPM	PM U-00001 Base+DB-2-CPM	PM U-00001 Base+DB-3-CPM

Sample Blank Taken	☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	1775.0	1818.9	1774.7	g
Initial Weight	(W_i)	1634.8	1686.0	1634.1	g
Net Weight	(W_n)	140.2	132.9	140.6	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	875.2	918.6	893.2	g
Initial Weight	(W_i)	859.6	901.3	875.2	g
Net Weight	(W_n)	15.6	17.3	18.0	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	155.8	150.2	158.6	g
Total Volume	(V_{lc})	156.1	150.5	158.9	ml

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base+DB-1		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations

Blank Type	Weight	Volume	Concentration	Mass	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

(1) Negative weight observed LFT, Loose filter material in the petri dish DE, Edges of the filter are frayed, * Reported at RDL

Gravimetric Concentrations			**Run**		1	**Start Time**	14:55
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	(1) --	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.1	140	0.0000	1.1000	
Cyclone Wash 2.5<PM<10			0.9	120	0.0000	0.9000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.7	120	0.0000	1.7000	
Inorganic Impinger Contents			4.6	371	1.4762	3.1238	
Organic Impinger Contents			1.3	334	0.5238	0.7762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base+DB-2		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL

Gravimetric Concentrations			**Run**		2	**Start Time**	04:24
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			13.9	110	0.0000	13.9000	
Cyclone Wash 2.5<PM<10			1.4	99	0.0000	1.4000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.7	120	0.0000	1.7000	
Inorganic Impinger Contents			3.7	471	1.4762	2.2238	
Organic Impinger Contents			1.2	425	0.5238	0.6762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base+DB-3		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

(2) Negative weight observed, * Reported at RDL

Gravimetric Concentrations			**Run**		3	**Start Time**	09:14
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	(2) --	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.2	120	0.0000	1.2000	
Cyclone Wash 2.5<PM<10			1.8	130	0.0000	1.8000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.4	130	0.0000	1.4000	
Inorganic Impinger Contents			3.8	391	1.4762	2.3238	
Organic Impinger Contents		*	1.0	319	0.5238	0.4762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00001 Base+DB
Project #	bec-19-cricketvalley.ny-start#1

Analytical Data		**Run**	PM U-00001 Base+DB-FB		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Gravimetric Concentrations					
Sample Portion	**Final**	**Tare**	**Gain**		**Actual Gain**
	(g)	(g)	(mg)		(mg)
Inorganic Impinger Contents	0.0031	0.0000	1.4762	max 2 mg total blank adjustment, proportioned	3.1000
Organic Impinger Contents	0.0011	0.0000	0.5238		1.1000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Field Collection Data QA SAM

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	02/17/20
Sampling Location	U-00001 Base	**Operator**	Atlas Melchert
Project #	bec-19-cricketvalley.ny-start#1		

Run History Data				
Run Number	SAM U-00001 Base-1	SAM U-00001 Base-2	SAM U-00001 Base-3	
Run Start Time	02:03	04:57	14:32	(hh:mm)
Run Stop Time	04:03	06:57	16:32	(hh:mm)
Train Prepared By	AM	AM	AM	
Train Recovered By	AM	AM	AM	
Recovery Date	02/18/20	02/18/20	02/19/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	02/20/20	02/20/20	02/20/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	samp-ha-0005	samp-ha-0005	samp-ha-0005
Sample Box	samp-bc-0032	samp-bc-0032	samp-bc-0032
Filter	R0001	R0001	R0001

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	2112.2	2186.0	2137.7	g
Initial Weight	(W_i)	2040.5	2112.2	2078.5	g
Net Weight	(W_n)	71.7	73.8	59.2	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	932.2	937.5	963.5	g
Initial Weight	(W_i)	926.3	932.2	957.4	g
Net Weight	(W_n)	5.9	5.3	6.1	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	77.6	79.1	65.3	g
Total Volume	(V_{lc})	77.7	79.2	65.4	ml

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	02/17/20
Sampling Location	U-00001 Base+DB	**Operator**	Atlas Melchert
Project #	bec-19-cricketvalley.ny-start#1		

Run History Data				
Run Number	SAM U-00001 Base+DB-1	SAM U-00001 Base+DB-2	SAM U-00001 Base+DB-3	
Run Start Time	14:40	04:09	07:26	(hh:mm)
Run Stop Time	16:40	06:09	09:26	(hh:mm)
Train Prepared By	AM	AM	AM	
Train Recovered By	AM	AM	AM	
Recovery Date	02/18/20	02/18/20	02/19/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	02/20/20	02/20/20	02/20/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	samp-ha-0005	samp-ha-0005	samp-ha-0005
Sample Box	samp-bc-0032	samp-bc-0032	samp-bc-0032
Filter	R0001	R0001	R0001

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	2103.0	2120.8	2139.1	g
Initial Weight	(W_i)	2021.2	2047.8	2063.1	g
Net Weight	(W_n)	81.8	73.0	76.0	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	944.6	951.9	957.4	g
Initial Weight	(W_i)	937.5	944.6	951.9	g
Net Weight	(W_n)	7.1	7.3	5.5	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	88.9	80.3	81.5	g
Total Volume	(V_{lc})	89.1	80.4	81.6	ml

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data PM_{10} and SAM
BV Labs

Your Project #: BEC-19-CRICKETVALLEY.NY-START1

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/03
Report #: R6096087
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C048069
Received: 2020/02/21, 17:15

Sample Matrix: Stack Sampling Train
Samples Received: 23

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Extractable Condensables (M202)	9	2020/02/27	2020/02/26	BRL SOP-00118	EPA 202 m
Non Extractable Condensibles (M202)	8	2020/02/27	2020/02/27	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
>10um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	7	N/A	2020/02/26	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
Sulphuric Acid Mist by Titration (M8A)	7	2020/03/02	2020/03/02	BRL SOP-00116	EPA CFR PTM 8 m
Final Volume of Acetone Probe Rinse	7	N/A	2020/02/26	BRL SOP-00109	
Final Volume of Impinger	7	N/A	2020/03/02		
Weight of Solvent from Impingers	9	N/A	2020/02/26		
Weight of Water from Impingers	8	N/A	2020/02/26		

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.
Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.
This Certificate shall not be reproduced except in full, without the written approval of the laboratory.
Reference Method suffix “m” indicates test methods incorporate validated modifications from specific reference methods to improve performance.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

Your Project #: BEC-19-CRICKETVALLEY.NY-START1

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/03
Report #: R6096087
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C048069
Received: 2020/02/21, 17:15

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key



Bureau Veritas Laboratories
03 Mar 2020 16:17:38

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: Clayton.Johnson@bvlabs.com
Phone# (905)817-5769

==========

This report has been generated and distributed using a secure automated process.
BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

BV Labs ID		MBP551	MBP552	MBP553	MBP554		
Sampling Date			2020/02/18	2020/02/18	2020/02/18		
	UNITS	M201A- BLANK	M201A- W/DB-R1	M201A- W/DB-R2	M201A- W/DB-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	1.2	1.1	13.9	1.2	0.5	6608986
< 2.5 Particulate Weight in Acetone Rinse	mg	1.9	1.7	1.7	1.4	0.5	6608981
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.7	0.9	1.4	1.8	0.5	6608984
< 2.5 Particulate Weight on Filter	mg	<0.30	<0.30 (1)	<0.30	<0.30 (2)	0.30	6607770
Acetone Rinse Volume (10)	ml	110	140	110	120	1	6608983
Acetone Rinse Volume (2.5 - 10)	ml	91	120	99	130	1	6608983
Acetone Rinse Volume (2.5)	ml	100	120	120	130	1	6608983

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative weight observed

LFT Loose filter material in the petri dish
DE Edges of the filter are frayed
(2) Negative weight observed

BV Labs ID		MBP556	MBP557	MBP558		
Sampling Date		2020/02/17	2020/02/17	2020/02/17		
	UNITS	M201A- W/ODB-R1	M201A- W/ODB-R2	M201A- W/ODB-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	16.2	14.5	14.0	0.5	6608986
< 2.5 Particulate Weight in Acetone Rinse	mg	1.7	2.7	1.7	0.5	6608981
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.3	1.7	1.5	0.5	6608984
< 2.5 Particulate Weight on Filter	mg	<0.30 (1)	<0.30 (2)	<0.30 (3)	0.30	6607770
Acetone Rinse Volume (10)	ml	100	110	97	1	6608983
Acetone Rinse Volume (2.5 - 10)	ml	130	130	85	1	6608983
Acetone Rinse Volume (2.5)	ml	130	130	63	1	6608983

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative weight observed

WET Filters was received wet
(2) Negative weight observed
(3) Negtive results observed

WET Filters were received wet
LFT Loose filter material in the petri dish
DE Edges of the filter are frayed

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

BV Labs ID		MBP535	MBP536	MBP537	MBP538		
Sampling Date							
	UNITS	M8A/M202- DI WATER BLANK	M202- HEXANE BLANK	M202- ACETONE BLANK	M202- FB	RDL	QC Batch
Weight	g	200	N/A	N/A	440	0.1	6608740
Weight of Solvent	g	N/A	130	150	320	0.1	6608738
Miscellaneous Parameters							
Inorganic Condensibles	mg	<0.5	N/A	N/A	3.1	0.5	6608739
Organic Condensibles	mg	N/A	<1.0	<1.0	1.1	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
N/A = Not Applicable

BV Labs ID		MBP539	MBP540	MBP541	MBP543	MBP544		
Sampling Date		2020/02/18	2020/02/18	2020/02/18	2020/02/17	2020/02/17		
	UNITS	M202- W/DB-R1	M202- W/DB-R2	M202- W/DB-R3	M202- W/ODB-R1	M202- W/ODB-R2	RDL	QC Batch
Weight	g	370	470	390	500	440	0.1	6608740
Weight of Solvent	g	220	280	210	150	230	0.1	6608738
Miscellaneous Parameters								
Inorganic Condensibles	mg	4.6	3.7	3.8	4.6	4.2	0.5	6608739
Organic Condensibles	mg	1.3	1.2	<1.0	1.6	2.4	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MBP545		
Sampling Date		2020/02/17		
	UNITS	M202- W/ODB-R3	RDL	QC Batch
Weight	g	440	0.1	6608740
Weight of Solvent	g	230	0.1	6608738
Miscellaneous Parameters				
Inorganic Condensibles	mg	3.6	0.5	6608739
Organic Condensibles	mg	<1.0	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

BV Labs ID		MBP535		MBP785	MBP785		
Sampling Date				2020/02/17	2020/02/17		
	UNITS	M8A/M202- DI WATER BLANK	RDL	M8A- W/DB- R1-CW	M8A- W/DB- R1-CW Lab-Dup	RDL	QC Batch
Impinger Volume	ml	196	1	232	N/A	1	6613884
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.78	0.78	<0.93	<0.93	0.93	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

BV Labs ID		MBP801		MBP802		MBP805		
Sampling Date		2020/02/17		2020/02/17		2020/02/18		
	UNITS	M8A- W/DB- R2-CW	RDL	M8A- W/DB- R3-CW	RDL	M8A- W/ODB- R1-CW	RDL	QC Batch
Impinger Volume	ml	194	1	254	1	191	1	6613884
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	<0.78	0.78	<1	1	<0.76	0.76	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MBP806		MBP807		
Sampling Date		2020/02/18		2020/02/18		
	UNITS	M8A- W/ODB- R2-CW	RDL	M8A- W/ODB- R3-CW	RDL	QC Batch
Impinger Volume	ml	197	1	232	1	6613884
Miscellaneous Parameters						
Sulphuric Acid Mist	mg	<0.79	0.79	<0.93	0.93	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP535 **Collected:**
Sample ID: M8A/M202- DI WATER BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP536 **Collected:**
Sample ID: M202- HEXANE BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP537 **Collected:**
Sample ID: M202- ACETONE BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP538 **Collected:**
Sample ID: M202- FB **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP539 **Collected:** 2020/02/18
Sample ID: M202- W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP540 **Collected:** 2020/02/18
Sample ID: M202- W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP540
Sample ID: M202- W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP541
Sample ID: M202- W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP543
Sample ID: M202- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP544
Sample ID: M202- W/ODB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP545
Sample ID: M202- W/ODB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP551
Sample ID: M201A- BLANK
Matrix: Stack Sampling Train

Collected:
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP552
Sample ID: M201A- W/DB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP553
Sample ID: M201A- W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP554
Sample ID: M201A- W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP556
Sample ID: M201A- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP556
Sample ID: M201A- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP557
Sample ID: M201A- W/ODB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP558
Sample ID: M201A- W/ODB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP785
Sample ID: M8A- W/DB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP785 Dup
Sample ID: M8A- W/DB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP801
Sample ID: M8A- W/DB- R2- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP802
Sample ID: M8A- W/DB- R3- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP805
Sample ID: M8A- W/ODB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP806
Sample ID: M8A- W/ODB- R2- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP807
Sample ID: M8A- W/ODB- R3- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

GENERAL COMMENTS

Sample MBP535 [M8A/M202- DI WATER BLANK] : INORGANIC EXTRACTION: No residue noted in Teflon dish.

Sample MBP536 [M202- HEXANE BLANK] : ORGANIC EXTRACTION: No residue noted in vial.

Sample MBP537 [M202- ACETONE BLANK] : ORGANIC EXTRACTION: No residue noted in vial.

Sample MBP538 [M202- FB] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP539 [M202- W/DB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP540 [M202- W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP541 [M202- W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP543 [M202- W/ODB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP544 [M202- W/ODB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP545 [M202- W/ODB- R3] : ORGANIC EXTRACTION : Light oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Results relate only to the items tested.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
6608735	MOR	Spiked Blank	Organic Condensibles	2020/02/28		98	%	70 - 130
6608735	MOR	Method Blank	Organic Condensibles	2020/02/26	<1.0		mg	
6608739	MOR	Method Blank	Inorganic Condensibles	2020/03/02	<0.5		mg	
6608981	MOR	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6608984	MOR	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6608986	MOR	Method Blank	> 10 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6613883	RSU	Matrix Spike(MBP785)	Sulphuric Acid Mist	2020/03/02		97	%	80 - 120
6613883	RSU	Spiked Blank	Sulphuric Acid Mist	2020/03/02		99	%	90 - 110
6613883	RSU	Method Blank	Sulphuric Acid Mist	2020/03/02	<0.2		mg	
6613883	RSU	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/02	NC		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Brenda Moore, Team Lead, Inorganic

Frank Mo, B.Sc., Inorganic Lab. Manager

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports.
For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

5048089

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:
Person Taking Samples:	Aaron Blum	Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	–	–
CTG-0001_W/DB-1-F	Unit CTG-0001_W/DB - Run 1 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-1-C2	Unit CTG-0001_W/DB - Run 1 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-1-C3	Unit CTG-0001_W/DB - Run 1 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-1-C4	Unit CTG-0001_W/DB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-1-C5	Unit CTG-0001_W/DB - Run 1 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-1-C6	Unit CTG-0001_W/DB - Run 1 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-1-CPM	Unit CTG-0001_W/DB - Run 1 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-2-F	Unit CTG-0001_W/DB - Run 2 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-2-C2	Unit CTG-0001_W/DB - Run 2 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-2-C3	Unit CTG-0001_W/DB - Run 2 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-2-C4	Unit CTG-0001_W/DB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-2-C5	Unit CTG-0001_W/DB - Run 2 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-2-C6	Unit CTG-0001_W/DB - Run 2 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-2-CPM	Unit CTG-0001_W/DB - Run 2 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-3-F	Unit CTG-0001_W/DB - Run 3 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-3-C2	Unit CTG-0001_W/DB - Run 3 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-3-C3	Unit CTG-0001_W/DB - Run 3 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-3-C4	Unit CTG-0001_W/DB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-3-C5	Unit CTG-0001_W/DB - Run 3 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-3-C6	Unit CTG-0001_W/DB - Run 3 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-3-CPM	Unit CTG-0001_W/DB - Run 3 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-FB-C3	Unit CTG-0001_W/DB - Run FB - Cyclone Wash 2.5<PM<10	FB		X			
CTG-0001_W/DB-FB-C4	Unit CTG-0001_W/DB - Run FB - Cyclone Exit to Front Half of Filter Wash (<2.5)	FB	N/A	X			
CTG-0001_W/DB-FB-C5	Unit CTG-0001_W/DB - Run FB - Inorganic Impinger Contents	FB			X		
CTG-0001_W/DB-B1-Acetone	Unit CTG-0001_W/DB - Blank - Acetone		200		X		
CTG-0001_W/DB-B2-DI Water	Unit CTG-0001_W/DB - Blank - DI Water		200	X			
CTG-0001_W/DB-B3-Hexane	Unit CTG-0001_W/DB - Blank - Hexane		200		X		

Signature	Date	Time	Signature	Date	Time
			ODBIÓR WYŁĄCZNIE	2020/02/21	17:15
			ODBIÓR WYŁĄCZNIE	2020/02/25	13:40

C048-069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:
Person Taking Samples:	Aaron Blum	Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	–	–
CTG-0001_W/ODB-1-F	Unit CTG-0001_W/ODB - Run 1 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-1-C2	Unit CTG-0001_W/ODB - Run 1 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-1-C3	Unit CTG-0001_W/ODB - Run 1 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-1-C4	Unit CTG-0001_W/ODB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-1-C5	Unit CTG-0001_W/ODB - Run 1 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-1-C6	Unit CTG-0001_W/ODB - Run 1 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-1-CPM	Unit CTG-0001_W/ODB - Run 1 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-2-F	Unit CTG-0001_W/ODB - Run 2 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-2-C2	Unit CTG-0001_W/ODB - Run 2 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-2-C3	Unit CTG-0001_W/ODB - Run 2 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-2-C4	Unit CTG-0001_W/ODB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-2-C5	Unit CTG-0001_W/ODB - Run 2 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-2-C6	Unit CTG-0001_W/ODB - Run 2 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-2-CPM	Unit CTG-0001_W/ODB - Run 2 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-3-F	Unit CTG-0001_W/ODB - Run 3 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-3-C2	Unit CTG-0001_W/ODB - Run 3 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-3-C3	Unit CTG-0001_W/ODB - Run 3 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-3-C4	Unit CTG-0001_W/ODB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-3-C5	Unit CTG-0001_W/ODB - Run 3 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-3-C6	Unit CTG-0001_W/ODB - Run 3 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-3-CPM	Unit CTG-0001_W/ODB - Run 3 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-FB-C3	Unit CTG-0001_W/ODB - Run FB - Cyclone Wash 2.5<PM<10	FB		X			
CTG-0001_W/ODB-FB-C4	Unit CTG-0001_W/ODB - Run FB - Cyclone Exit to Front Half of Filter Wash (<2.5)	FB	N/A	X			
CTG-0001_W/ODB-FB-C5	Unit CTG-0001_W/ODB - Run FB - Inorganic Impinger Contents	FB			X		
CTG-0001_W/ODB-B1-Acetone	Unit CTG-0001_W/ODB - Blank - Acetone		200		X		
CTG-0001_W/ODB-B2-DI Water	Unit CTG-0001_W/ODB - Blank - DI Water		200	X			
CTG-0001_W/ODB-B3-Hexane	Unit CTG-0001_W/ODB - Blank - Hexane		200		X		

Signature	Date	Time	Signature	Date	Time
[signature]	2/20/20	1400	FIDELE NTAMWEMEZI [signature]	2020/02/21	17 15
			FIDELE NTAMWEMEZI [signature]	2020/02/25	13 40

C048069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:
Person Taking Samples:	Atlas Melchert	Titration

Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
CT-0001W/DB-1-CW	Unit CT-0001W/DB - Run 1 - Condenser Wash	02/17/20					
CT-0001W/DB-2-CW	Unit CT-0001W/DB - Run 2 - Condenser Wash	02/17/20					
CT-0001W/DB-3-CW	Unit CT-0001W/DB - Run 3 - Condenser Wash	02/17/20					
CT-0001W/DB-B2-DI Water	Unit CT-0001W/DB - Blank - DI Water		100				
CT-0001W/DB-B3-H_2O_2	Unit CT-0001W/DB - Blank - H_2O_2		100				

Signature	Date	Time	Signature	Date	Time
[signature]	2/20/20	1420	FIDELE NTAMWEMEZI [signature]	2020/02/21	17:15
			FIDELE NTAMWEMEZI [signature]	2020/02/25	13:40

bec-19-cricketvally.ny-start#1-M8a-wDB

SD&L

C048069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number: bec-19-cricketvalley.ny-start#1

Person Taking Samples:

Laboratory Analysis Requested: Titration

Sample Number	Location	Date	Volume	Analysis Method: Cont Cond	--	--	--
CT-0001w/oDB-1-CW	Unit CT-0001w/oDB - Run 1 - Condenser Wash	02/18/20					
CT-0001w/oDB-2-CW	Unit CT-0001w/oDB - Run 2 - Condenser Wash	02/18/20					
CT-0001w/oDB-3-CW	Unit CT-0001w/oDB - Run 3 - Condenser Wash	02/18/20					
CT-0001w/oDB-B2-DI Water	Unit CT-0001w/oDB - Blank - DI Water		100				
CT-0001w/oDB-B3-H_2O_2	Unit CT-0001w/oDB - Blank - H_2O_2		100				

Signature	Date	Time	Signature	Date	Time
[signature]	2/18/20	1900	FIDELE NTAMWEMEZI	2020/02/21	17:15
			FIDELE NTAMWEMEZI	2020/02/25	13:40

bec-19-cricketvalley.ny-start#1-woDB-M8A

SD&L

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Supplemental Laboratory Data PM_{10} Filters
BV Labs

Inorganic Analysis Action / Comment Form

Client ID	Air Hygiene
Maxxam Job #	C048069
Maxxam Sample ID's	start MBP551-01R

Analytical Worksheet(s)			
	Filters	6607770	
	Solvent Rinse	6608981	
	Solvent Volumes	6608983	

Analysis	Particulates
Analyst ID	

Actions:	*Impacted Sample ID's
Bottle discrepancies	
Filters damaged	
Solvent rinse anomalies	
Water impinger anomalies	
Filter blank submitted	Yes
Solvent blank submitted	Yes
Water blank submitted	
Other	

Comments

See data sheets for any anomalies of samples

Filter
Particulate Weight Log

Job #	C048069		Metals	No	supplier	Pall	N/A	
Client	Air Hygiene		Filter Blank Submitted	Yes	p/n	61631	N/A	
Analysis	Particulate Weight on Filter		Date of Dessication	2020/02/25	lot #	T83173	N/A	Type
Balance ID	220-BALANAL4		Time of Dessication	3:25 PM				M5
Condition	Dickson THDX S/N 6003123							

DE Edges of filter frayed
LPC Loose particulate material in filter containe
FT Filter torn
FCL Filter contains liquid after dessication
LFT Loose filter material

Increment 1

Analyst	B Moore	B Moore	B Moore						
Weighing Date		2020/02/26	2020/02/27						
Weighing Time		3:53 PM	10:18 AM						
Temperature (ºC)		23	23						
Humidity (%)	40	40	39						

Worksheet #	#	Maxxam #	Filter Condition	Filter ID #	Pre Weight gm	Weight #1 gm	Weight #2 gm	Weight #3 gm	Weight #4 gm	Weight #5 gm	Weight #6 gm	Weight #7 gm	Final Weight gm	Particulate mg	RDL mg
6607770	1	MBP551-01R	NORMAL	18042522	0.11325	0.1132	0.1131						0.1131	-0.1	0.3
6607770	2	MBP552-01R	*DE**LFT*	18082938	0.11415	0.1097	0.1095						0.1095	-4.7	0.3
6607770	3	MBP553-01R	NORMAL	18082944	0.11435	0.1145	0.1144						0.1144	0.1	0.3
6607770	4	MBP554-01R	NORMAL	18042521	0.11180	0.1093	0.1093						0.1093	-2.5	0.3
6607770	5	MBP556-01R	WET	18082942	0.11415	0.1117	0.1117						0.1117	-2.5	0.3
6607770	6	MBP557-01R	NORMAL	18082937	0.11400	0.1118	0.1117						0.1117	-2.3	0.3
6607770	7	MBP558-01R	WET*DE*LFT	18082945	0.11190	0.1069	0.1068						0.1068	-5.1	0.3
	8														
	9														
	10														
				zero	0.0000	0.0000	-0.0001								
				0.3000 gm	0.3000	0.3000	0.2999								
	11														
	12														
	13														
	14														
	15														
	16														
	17														
	18														
	19														
	20														
				zero											
				0.3000 gm											
	21														
	22														
	23														
	24														
	25														
	26														
	27														
	28														
	29														
	30														
				zero											
				0.3000 gm											
	31														
	32														
	33														
	34														
	35														
	36														
	37														
	38														
	39														
	40														
				zero											
				0.3000 gm											

Filters are placed in a dessicator for 24 hours minimum prior to beginning weighing cycle.
Filters are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity of≥50 %.
Verification Weight 5mg S/N 1000144533
Verification Weight 100mg S/N 29785
Verification Weight 300mg S/N 1000112492

Specific data from the lab regarding the filter weights reported at the RDL and noted as “negative weight observed”.

Comparison of actual Lab Reported Filter Loss to the gains in the sample train sections just prior to and just after the filter. The total gains in each of these sections always accounts for the filter loss. Air Hygiene concluded that the frayed filter edges either ended up in the section prior to the filter and/or the section just downstream of the filter.

Data Summary

Run	Filter	Gain in Cyclone End to Front Half of Filter Wash (<2.5) (mg)	Gain in Inorganic Impinger Content (mg)	Sum of Gains (mg)	Lab Reported Filter Loss (mg)
Base – Run 1	18082942	1.7	4.6	6.3	-2.5
Base – Run 2	18082937	2.7	4.2	6.9	-2.3
Base – Run 3	18082945	1.7	3.6	5.3	-5.1
Base+DB – Run 1	18042521	1.7	4.6	6.3	-2.5
Base+DB – Run 2	18082944	1.7	3.7	5.4	0.1
Base+DB – Run 3	18082938	1.4	3.8	5.2	-4.7

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Supplemental Laboratory Data SAM by IC
BV Labs

Your Project #: BEC-19-CRICKETVALLEY.NY-START1

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/13
Report #: R6108718
Version: 3 - Revision

CERTIFICATE OF ANALYSIS – REVISED REPORT

BV LABS JOB #: C048069
Received: 2020/02/21, 17:15

Sample Matrix: Stack Sampling Train
Samples Received: 7

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
H2SO4 Acid Mist in IPA Impinger (M8mod)	7	2020/03/10	2020/03/10	BRL SOP-00105	EPA 8 m
Sulphuric Acid Mist by Titration (M8A)	7	2020/03/02	2020/03/02	BRL SOP-00116	EPA CFR PTM 8 m

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.
Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.
This Certificate shall not be reproduced except in full, without the written approval of the laboratory.
Reference Method suffix “m” indicates test methods incorporate validated modifications from specific reference methods to improve performance.
* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: Clayton.Johnson@bvlabs.com
Phone# (905)817-5769

==========

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

55555 North Service Road, Burlington, Ontario, Canada L7L 5H7 Tel: (905) 332-8788 Toll Free: (800) 668-0639 Fax: (905) 332-9169

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

BV Labs ID		MBP535		MBP785	MBP785		
Sampling Date				2020/02/17	2020/02/17		
	UNITS	M8A/M202- DI WATER BLANK	RDL	M8A- W/DB- R1-CW	M8A- W/DB- R1-CW Lab-Dup	RDL	QC Batch
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.02	0.02	<0.024	<0.024	0.024	6627946

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate

BV Labs ID		MBP801		MBP802		MBP805		
Sampling Date		2020/02/17		2020/02/17		2020/02/18		
	UNITS	M8A- W/DB- R2-CW	RDL	M8A- W/DB- R3-CW	RDL	M8A- W/ODB- R1-CW	RDL	QC Batch
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	0.04	0.02	0.056	0.026	0.02	0.02	6627946

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MBP806		MBP807		
Sampling Date		2020/02/18		2020/02/18		
	UNITS	M8A- W/ODB- R2-CW	RDL	M8A- W/ODB- R3-CW	RDL	QC Batch
Miscellaneous Parameters						
Sulphuric Acid Mist	mg	0.03	0.02	0.028	0.024	6627946

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

55555 North Service Road, Burlington, Ontario, Canada L7L 5H7 Tel: (905) 332-8788 Toll Free: (800) 668-0639 Fax: (905) 332-9169

TEST SUMMARY

BV Labs ID: MBP535 **Collected:**
Sample ID: M8A/M202- DI WATER BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP785 **Collected:** 2020/02/17
Sample ID: M8A- W/DB- R1- CW **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP785 Dup **Collected:** 2020/02/17
Sample ID: M8A- W/DB- R1- CW **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP801 **Collected:** 2020/02/17
Sample ID: M8A- W/DB- R2- CW **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP802 **Collected:** 2020/02/17
Sample ID: M8A- W/DB- R3- CW **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP805 **Collected:** 2020/02/18
Sample ID: M8A- W/ODB- R1- CW **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

55555 North Service Road, Burlington, Ontario, Canada L7L 5H7 Tel: (905) 332-8788 Toll Free: (800) 668-0639 Fax: (905) 332-9169

TEST SUMMARY

BV Labs ID: MBP806
Sample ID: M8A- W/ODB- R2- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP807
Sample ID: M8A- W/ODB- R3- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6627946	2020/03/10	2020/03/10	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

55555 North Service Road, Burlington, Ontario, Canada L7L 5H7 Tel: (905) 332-8788 Toll Free: (800) 668-0639 Fax: (905) 332-9169

GENERAL COMMENTS

Sample MBP535 [M8A/M202- DI WATER BLANK] : INORGANIC EXTRACTION: No residue noted in Teflon dish.

Results relate only to the items tested.

55555 North Service Road, Burlington, Ontario, Canada L7L 5H7 Tel: (905) 332-8788 Toll Free: (800) 668-0639 Fax: (905) 332-9169

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
6613883	RSU	Matrix Spike(MBP785)	Sulphuric Acid Mist	2020/03/02		97	%	80 - 120
6613883	RSU	Spiked Blank	Sulphuric Acid Mist	2020/03/02		99	%	90 - 110
6613883	RSU	Method Blank	Sulphuric Acid Mist	2020/03/02	<0.2		mg	
6613883	RSU	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/02	NC		%	20
6627946	LLE	Matrix Spike(MBP785)	Sulphuric Acid Mist	2020/03/10		97	%	80 - 120
6627946	LLE	Spiked Blank	Sulphuric Acid Mist	2020/03/10		102	%	90 - 110
6627946	LLE	Method Blank	Sulphuric Acid Mist	2020/03/10	<0.02		mg	
6627946	LLE	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/10	NC		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.


Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

55555 North Service Road, Burlington, Ontario, Canada L7L 5H7 Tel: (905) 332-8788 Toll Free: (800) 668-0639 Fax: (905) 332-9169

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Ann-Marie Stern, Team Lead, Inorganic



Frank Mo, B.Sc., Inorganic Lab. Manager

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports.
For Service Group specific validation please refer to the Validation Signature Page.

55555 North Service Road, Burlington, Ontario, Canada L7L 5H7 Tel: (905) 332-8788 Toll Free: (800) 668-0639 Fax: (905) 332-9169

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Audit Sample Data
(not required for this scope of work)

APPENDIX E

FUEL ANALYSIS RECORDS

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: February 17, 2020
Project #: bec-19-cricketvalley.ny-start#1

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	93.1168	16.0430	14.94	87.36	994.85	926.37	895.75	834.10
Ethane	C_2H_6	4.9202	30.0700	1.48	8.65	1,743.15	85.77	1,594.41	78.45
Propane	C_3H_8	0.2063	44.0970	0.09	0.53	2,478.35	5.11	2,280.17	4.70
iso-Butane	iC_4H_{10}	0.0167	58.1230	0.01	0.06	3,203.11	0.53	2,955.38	0.49
n-Butane	nC_4H_{10}	0.0174	58.1230	0.01	0.06	3,213.35	0.56	2,965.62	0.52
Iso-Pentane	iC_5H_{12}	0.0047	72.1500	0.00	0.02	3,940.87	0.19	3,643.50	0.17
n-Pentane	nC_5H_{12}	0.0027	72.1500	0.00	0.01	3,948.75	0.11	3,648.32	0.10
Hexanes	C_6H_{14}	0.0054	86.1770	0.00	0.03	4,684.54	0.25	4,337.82	0.23
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.4658	44.0100	0.20	1.20	0.00	0.00	0.00	0.00
Nitrogen	N_2	1.0304	28.0134	0.29	1.69	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.2136	31.9988	0.07	0.40	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		**100.000**		**17.10**	**100.00**	**dry**	**1,018.89**	**dry**	**918.76**
						wet[2,5]	**995.39**	**wet[2,5]**	**897.58**

Characteristics of Fuel Gas		
Molecular Weight of gas =	17.101	lb/lb-mole
Btu per lb. of gas[4] =	22,952.168	gross (HHV)
Btu per lb. of gas[4] =	20,696.745	net (LHV)
Density of fuel gas[2] =	0.0444	lb/cu. ft
Wt % VOC in fuel gas =	0.71	%
Specific Gravity[1] =	0.5905	

Component	Wt%
carbon	73.22
oxygen	1.27
hydrogen	23.82
nitrogen	1.69
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,643.54
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: February 18, 2020
Project #: bec-19-cricketvalley.ny-start#1

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	93.1168	16.0430	14.94	87.36	994.85	926.37	895.75	834.10
Ethane	C_2H_6	4.9202	30.0700	1.48	8.65	1,743.15	85.77	1,594.41	78.45
Propane	C_3H_8	0.2063	44.0970	0.09	0.53	2,478.35	5.11	2,280.17	4.70
iso-Butane	iC_4H_{10}	0.0167	58.1230	0.01	0.06	3,203.11	0.53	2,955.38	0.49
n-Butane	nC_4H_{10}	0.0174	58.1230	0.01	0.06	3,213.35	0.56	2,965.62	0.52
Iso-Pentane	iC_5H_{12}	0.0047	72.1500	0.00	0.02	3,940.87	0.19	3,643.50	0.17
n-Pentane	nC_5H_{12}	0.0027	72.1500	0.00	0.01	3,948.75	0.11	3,648.32	0.10
Hexanes	C_6H_{14}	0.0054	86.1770	0.00	0.03	4,684.54	0.25	4,337.82	0.23
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.4658	44.0100	0.20	1.20	0.00	0.00	0.00	0.00
Nitrogen	N_2	1.0304	28.0134	0.29	1.69	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.2136	31.9988	0.07	0.40	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		**100.000**		**17.10**	**100.00**	**dry**	**1,018.89**	**dry**	**918.76**
						wet[2,5]	**995.39**	**wet[2,5]**	**897.58**

Characteristics of Fuel Gas		
Molecular Weight of gas =	17.101	lb/lb-mole
Btu per lb. of gas[4] =	22,952.168	gross (HHV)
Btu per lb. of gas[4] =	20,696.745	net (LHV)
Density of fuel gas[2] =	0.0444	lb/cu. ft
Wt % VOC in fuel gas =	0.71	%
Specific Gravity[1] =	0.5905	

Component	Wt%
carbon	73.22
oxygen	1.27
hydrogen	23.82
nitrogen	1.69
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,643.54
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: February 19, 2020
Project #: bec-19-cricketvalley.ny-start#1

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	93.1346	16.0430	14.94	87.39	994.85	926.54	895.75	834.26
Ethane	C_2H_6	4.7455	30.0700	1.43	8.35	1,743.15	82.72	1,594.41	75.66
Propane	C_3H_8	0.2007	44.0970	0.09	0.52	2,478.35	4.97	2,280.17	4.58
iso-Butane	iC_4H_{10}	0.0147	58.1230	0.01	0.05	3,203.11	0.47	2,955.38	0.43
n-Butane	nC_4H_{10}	0.0158	58.1230	0.01	0.05	3,213.35	0.51	2,965.62	0.47
Iso-Pentane	iC_5H_{12}	0.0039	72.1500	0.00	0.02	3,940.87	0.15	3,643.50	0.14
n-Pentane	nC_5H_{12}	0.0022	72.1500	0.00	0.01	3,948.75	0.09	3,648.32	0.08
Hexanes	C_6H_{14}	0.0040	86.1770	0.00	0.02	4,684.54	0.19	4,337.82	0.17
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.4917	44.0100	0.22	1.27	0.00	0.00	0.00	0.00
Nitrogen	N_2	1.1346	28.0134	0.32	1.86	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.2523	31.9988	0.08	0.47	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		**100.000**		**17.10**	**100.00**	**dry**	**1,015.65**	**dry**	**915.80**
						wet[2,5]	**992.23**	**wet[2,5]**	**894.68**

Characteristics of Fuel Gas		
Molecular Weight of gas =	17.098	lb/lb-mole
Btu per lb. of gas[4] =	22,883.761	gross (HHV)
Btu per lb. of gas[4] =	20,633.993	net (LHV)
Density of fuel gas[2] =	0.0444	lb/cu. ft
Wt % VOC in fuel gas =	0.67	%
Specific Gravity[1] =	0.5903	

Component	Wt%
carbon	72.99
oxygen	1.39
hydrogen	23.76
nitrogen	1.86
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,642.95
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-003 Page 1 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R2&3-NoDuct R3 Natural Gas Sample 2020-02-17		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography, ASTM D 1945.a

	Results, Mol %
Hydrogen	0.0000
Oxygen	0.3437
Nitrogen	1.3731
Carbon Dioxide	0.4530
Methane	93.1300
Ethane	4.4506
Propane	0.2115
iso-Butane	0.0142
n-Butane	0.0146
iso-Pentane	0.0035
n-Pentane	0.0020
Hexanes Plus	0.0038
TOTAL	**100.0000**

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 60°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	930.2
Gross (Dry basis), BTU/scf	1,032
NET (Dry basis), BTU/lb	20,308
Gross (Dry basis), BTU/lb	22,519

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 68°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	916.1
Gross (Dry basis), BTU/scf	1,016
NET (Dry basis), BTU/lb	20,308
Gross (Dry basis), BTU/lb	22,519

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-003 Page 2 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R2&3-NoDuct R3 Natural Gas Sample 2020-02-17		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	0.9
Carbonyl Sulfide	0.1
2-Methyl Thiophene	0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	<0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.2
Methyl Mercaptan	0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.1
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	0.8
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-003 Page 3 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R2&3-NoDuct R3 Natural Gas Sample 2020-02-17		

TEST	**RESULT**

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	3.9×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	3.8×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	3.9
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	3.8
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.12
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.11

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-001 Page 1 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R1-NoDuct Natural Gas Sample 2020-02-18		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography. ASTM D 1945.a

	Results, Mol %
Hydrogen	0.0000
Oxygen	0.2136
Nitrogen	1.0304
Carbon Dioxide	0.4658
Methane	93.1168
Ethane	4.9202
Propane	0.2063
iso-Butane	0.0167
n-Butane	0.0174
iso-Pentane	0.0047
n-Pentane	0.0027
Hexanes Plus	0.0054
TOTAL	**100.0000**

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 60°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	937.0
Gross (Dry basis), BTU/scf	1,039
NET (Dry basis), BTU/lb	20,501
Gross (Dry basis), BTU/lb	22,731

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 68°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	922.8
Gross (Dry basis), BTU/scf	1,023
NET (Dry basis), BTU/lb	20,501
Gross (Dry basis), BTU/lb	22,731

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-001 Page 2 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R1-NoDuct Natural Gas Sample 2020-02-18		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	0.7
Carbonyl Sulfide	0.1
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	<0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.2
Methyl Mercaptan	<0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.1
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	0.8
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-001 Page 3 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R1-NoDuct Natural Gas Sample 2020-02-18		

TEST	**RESULT**

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	3.5×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	3.4×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	3.5
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	3.4
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.10
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.10

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-002 Page 1 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R1-Duct Natural Gas Sample 2020-02-19		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography. ASTM D 1945.a

	Results, Mol %
Hydrogen	0.0000
Oxygen	0.2523
Nitrogen	1.1346
Carbon Dioxide	0.4917
Methane	93.1346
Ethane	4.7455
Propane	0.2007
iso-Butane	0.0147
n-Butane	0.0158
iso-Pentane	0.0039
n-Pentane	0.0022
Hexanes Plus	0.0040
TOTAL	**100.0000**

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 60°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	934.5
Gross (Dry basis), BTU/scf	1,036
NET (Dry basis), BTU/lb	20,415
Gross (Dry basis), BTU/lb	22,636

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 68°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	920.3
Gross (Dry basis), BTU/scf	1,020
NET (Dry basis), BTU/lb	20,415
Gross (Dry basis), BTU/lb	22,636

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-002 Page 2 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R1-Duct Natural Gas Sample 2020-02-19		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	0.8
Carbonyl Sulfide	0.1
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	<0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.2
Methyl Mercaptan	0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.1
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	0.8
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:		**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92010-002 Page 3 of 3	**REPORT DATE:**	March 03, 2020
SAMPLE:	Cricket Valley-R1-Duct Natural Gas Sample 2020-02-19		

TEST	**RESULT**

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	3.9×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	3.8×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	3.9
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	3.8
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.12
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.11

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

SINCE 1985
Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

Conversion Factors (Gas Analysis) to adjust BTU/ft^3 and Sulfur content @60ºF and 68ºF

NET (Dry Basis) BTU/scf @60ºF, factor= 1

NET (Dry Basis) BTU/scf @68ºF, factor= 0.984839

Gross (Dry Basis) BTU/scf @60ºF, factor = 1

Gross (Dry Basis) BTU/scf @68ºF, factor = 0.984839

NET (Dry Basis) BTU/lb @60ºF, factor = 1

NET (Dry Basis) BTU/lb @68ºF, factor = 1

GROSS (Dry Basis) BTU/lb @60ºF, factor= 1

GROSS (Dry Basis) BTU/lb @68ºF, factor= 1

Sulfur Total Volatile, ASTM D 6667 @60ºF, wt% or ppmwt, factor= 1

Sulfur Total Volatile, ASTM D 6667 @68ºF, wt% or ppmwt, factor= 0.984839

Sulfur Total Volatile, ASTM D 6667 @60ºF, grains/100scf = ppmwt @60ºF x 0.0300

Sulfur Total Volatile, ASTM D 6667 @68ºF, grains/100scf = ppmwt @60ºF x 0.0295

Conversion Factors (Liquid Fuel Analysis)

Liquid Fuel BTU/lb @60ºF= Liquid fuel BTU/lb @68ºF

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:	
Person Taking Samples:	Swanson B., Aaron Blum	Fuel Component and Sulfur Analysis	

Sample Number	Location	Date	Volume	Analysis Method(s) [and target(s)]						
				GPA2261/ASTM 1945 [component analysis]	GPA 2172 Calculation @ 60 F & 68 F [HHV]	ASTM 5504 [speciated sulfur content]				
021720-Run1 with Out-1A	Cricket Valley-R1-NoDuct Natural Gas Sample [primary]	02/17/20	10L	X	X	X				
021720-Run1 with DB-1B	Cricket Valley-R1-NoDuct Natural Gas Sample [backup]	02/17/20	10L	as necessary	as necessary	as necessary				
021820-Run 1 with Duct-1A	Cricket Valley-R1-Duct Natural Gas Sample [primary]	02/18/20	10L	X	X	X				
021820-Run 1 with Duct-1B	Cricket Valley-R1-Duct Natural Gas Sample [backup]	02/18/20	10L	as necessary	as necessary	as necessary				
021920-R2&3 Duct-1A	Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample [primary]	02/19/20	10L	X	X	X				
021920-R2&3 Duct-1B	Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample [backup]	02/19/20	10L	as necessary	as necessary	as necessary				

Relin Sean Hawes — 02/20/20 (Date:) — 14:00 (Time:)

Relinquished by: (Signature) — Date: — Time:

Received by: (Signature) — 2/24/20 (Date:) — 09:30am (Time:)

Received by: (Signature) — Date: — Time:

APPENDIX F

STRATIFICATION TEST DATA

STRATIFICATION TEST DATA

Stratification Test Data Base Load

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric 7F.05
Location	Dover Plains, New York

Test Information	
Date	02/05/20
Project #	bec-19-cricketvalley.ny-start#1
Unit Number	U-00001
Load	Base
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)** ☐ Part 60	☑ Part 75	

Created with Traverse-AHI v20200108

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	02/05/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2


Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters


Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
				12 points	

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.


[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	





Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	02/05/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	14:35:09	**Run End**	16:38:09

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	8.00	14:35:09	14:43:09	12.15	0.50%	2.57	7.47%
D-2	8.00	14:43:09	14:51:09	12.24	0.24%	2.62	5.67%
D-1	8.00	14:51:09	14:59:09	12.24	0.24%	2.56	**7.83%**
C-3	8.00	14:59:09	15:07:09	12.18	0.25%	2.70	2.79%
C-2	8.00	15:07:09	15:15:09	12.16	0.42%	2.77	0.27%
C-1	8.00	15:15:09	15:23:09	12.15	0.50%	2.87	3.33%
B-3	31.00	15:23:09	15:54:09	12.30	0.73%	2.90	4.41%
B-2	8.00	15:54:09	16:02:09	12.30	0.73%	2.76	0.63%
B-1	8.00	16:02:09	16:10:09	12.32	**0.89%**	2.93	5.49%
A-3	9.00	16:10:09	16:19:09	12.12	0.74%	2.97	6.93%
A-2	8.00	16:19:09	16:27:09	12.16	0.42%	2.88	3.69%
A-1	11.00	16:27:09	16:38:09	12.21	0.01%	2.80	0.81%
Average				12.21		2.78	

			O_2		NOx		
			Criteria	**Results**	**Criteria**	**Results**	**AND criteria**
RATA Part 75	Non-Stratified %	≤	5%	Non (%)	5%	Non (Δ)	Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.
	Non-Stratified Δ	≤	0.3		3		
	Minimally-Stratified %	≤	10%		10%		
	Minimally-Stratified Δ	≤	0.5		5		
	Stratified	>	10%		10%		
	Outcome		1 point		1 point		
	Location		any point		any point		
	Maximum Concentration		12.32		2.97		
	Upscale Δ = Max Concentration - Average		0.11	Non	0.19	Non	
	Upscale % Difference		0.89%	Non	6.93%	Mini	
	Minimum Concentration		12.12		2.56		
	Downscale Δ = Average - Min Concentration		0.09	Non	0.22	Non	
	Downscale % Difference		0.74%	Non	7.83%	Mini	
	First Point on List Closest to Average				C-1		
Port Averages with Maximum Concentration Indicator	**Port A Average**		12.16		2.88	<max	
	Port B Average		12.31	<max	2.86		
	Port C Average		12.16		2.78		
	Port D Average		12.21		2.58		
	Port E Average						
	Port F Average						
	Port G Average						

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	02/05/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	14:35:09	**Run End**	16:38:09

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	7.83 % for NOx
Maximum Pollutant Conc. Diff.	0.22 ppm for NOx
Maximum Diluent Conc. Diff.	0.11 % for O_2
Stratification Conclusions	
Comparison	all diluents/pollutants
Stack Diameter	D > 93.6 in.


Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type
- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

☐ Use 6.5.6.3(a) points?

☐ 6.5.6(b)(2) alt. points could apply



STRATIFICATION TEST DATA

Stratification Test Data Base+DB Load

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric 7F.05
Location	Dover Plains, New York

Test Information	
Date	02/17/20
Project #	bec-19-cricketvalley.ny-start#1
Unit Number	U-00001
Load	Base+DB
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)** ☐ Part 60	☑ Part 75	

Created with Traverse-AHI v20200108

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	02/17/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4


Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2

Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
				12 points	


[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	02/17/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	10:19:14	**Run End**	12:01:14

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	8.00	10:19:14	10:27:14	12.45	0.09%	2.40	7.99%
D-2	8.00	10:27:14	10:35:14	12.43	0.25%	2.36	6.19%
D-1	8.00	10:35:14	10:43:14	12.42	**0.33%**	2.47	11.14%
C-3	10.00	10:43:14	10:53:14	12.47	0.07%	2.11	5.06%
C-2	8.00	10:53:14	11:01:14	12.46	0.01%	2.12	4.61%
C-1	8.00	11:01:14	11:09:14	12.46	0.01%	2.16	2.81%
B-3	10.00	11:09:14	11:19:14	12.49	0.23%	2.09	5.96%
B-2	8.00	11:19:14	11:27:14	12.48	0.15%	2.07	6.86%
B-1	8.00	11:27:14	11:35:14	12.44	0.17%	2.49	**12.04%**
A-3	10.00	11:35:14	11:45:14	12.48	0.15%	2.18	1.91%
A-2	8.00	11:45:14	11:53:14	12.48	0.15%	2.12	4.61%
A-1	8.00	11:53:14	12:01:14	12.47	0.07%	2.10	5.51%
Average				12.46		2.22	

			O_2		NOx		
			Criteria	**Results**	**Criteria**	**Results**	**AND criteria**
RATA Part 75	Non-Stratified %	≤	5%	Non (%)	5%	Non (Δ)	Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.
	Non-Stratified Δ	≤	0.3		3		
	Minimally-Stratified %	≤	10%		10%		
	Minimally-Stratified Δ	≤	0.5		5		
	Stratified	>	10%		10%		
	Outcome		1 point		1 point		
	Location		any point		any point		
	Maximum Concentration		12.49		2.49		
	Upscale Δ = Max Concentration - Average		0.03	Non	0.27	Non	
	Upscale % Difference		0.23%	Non	12.04%	Strat	
	Minimum Concentration		12.42		2.07		
	Downscale Δ = Average - Min Concentration		0.04	Non	0.15	Non	
	Downscale % Difference		0.33%	Non	6.86%	Mini	
	First Point on List Closest to Average		C-1		A-2		
Port Averages with Maximum Concentration Indicator	**Port A Average**		12.48	<max	2.13		
	Port B Average		12.47		2.22		
	Port C Average		12.46		2.13		
	Port D Average		12.43		2.41	<max	
	Port E Average						
	Port F Average						
	Port G Average						

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	02/17/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	10:19:14	**Run End**	12:01:14

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	12.04 % for NOx
Maximum Pollutant Conc. Diff.	0.27 ppm for NOx
Maximum Diluent Conc. Diff.	0.04 % for O_2
Stratification Conclusions	
Comparison	all diluents/pollutants
Stack Diameter	D > 93.6 in.


Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type
- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

☐ Use 6.5.6.3(a) points?

☐ 6.5.6(b)(2) alt. points could apply



APPENDIX G

EQUIPMENT CALIBRATION RECORDS

APEX SOURCE TESTING EQUIPMENT INSTRUMENTS

Apex Instruments, Inc.
204 Technology Park Lane
Fuquay-Varina, NC 27526

S-TYPE PITOT TUBE CALIBRATION SHEET

Reference USEPA Reference Method 2 (40CFR60, App. A, Meth. 2)

PITOT SERIAL#	4187	CALIBRATION DATE:	10-Jan-13
PITOT TYPE:	S-Type	BAROMETRIC PRESSURE:	29.74 in Hg
STD. PITOT TYPE:	Ellipsoidal	STATIC PRESSURE	1.4 in H_20
Cp(std):	0.990	BLOCKAGE %:	N/A
PROBE SERIAL#	NICK	CORRECTION FACTOR:	1.00

	SIDE "A" CALIBRATION			
RUN NO.	Δ Pstd in H_2O	Δ Ps in H_2O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.560	0.820	0.818	-0.001
2	0.560	0.815	0.821	0.002
3	0.560	0.820	0.818	-0.001
		"A" AVERAGE	0.819	0.0014 (must be ≤ 0.01)

	SIDE "B" CALIBRATION			
RUN NO.	Δ Pstd in H_2O	Δ Ps in H_2O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.560	0.815	0.821	0.000
2	0.560	0.815	0.821	0.000
3	0.560	0.815	0.821	0.000
		"B" AVERAGE	0.821	0.0000 (must be ≤ 0.01)

ACCEPTANCE CRITERIA

AVERAGE -0.0017 AVG. Cp (A) - AVG. Cp (B) must be ≤ 0.01

If the Average and both Deviation Averages "A" & "B" are ≤ 0.01, then the OVERALL AVERAGE below may be used.
*** If NOT, use the "A" Average OR "B" Average.**

OVERALL AVERAGE 0.8198



I certify that the above pitot tube was tested in accordance with the US EPA Method 2 standards.
See the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 2, Item 4.

Print Name: Nick Allen

Signature:

Date 1.11.13

Wind Tunnel Pitot Calibration

S-type Pitot ID:	**A4187**	Date:	**2-Mar-15**
Standard Pitot ID:	**001**	Personnel:	**KMR MF**
Cp(std):	**0.99**	Cp(actual):	**0.724**
Part Number:		P_{bar}(in Hg):	**29.71**
Test Velocity (fps):	**50**	T(°F):	**55**
Wind Tunnel Location:	**Calera, AL**	Tunnel Size:	**20" x 40"**
Customer:	**Air Hygiene**		

A-SIDE

ΔP_{std} (in. H_2O)	ΔP_s (in. H_2O)	Cp(s)	Deviation*
0.563	**1.053**	**0.723**	0.002
0.561	**1.048**	**0.724**	-0.001
0.561	**1.050**	**0.724**	0.000
	AVERAGE	**0.724**	0.001
		Std deviation	0.002

NOTES:

1. **Pitot calibrated with an Environmental Supply Co. PM10 cyclone.**
2. **C_p is only valid when used with PM10 cyclone.**
3. **C_p is only valid with 1" spacing from PM10 cyclone.**

$$Cp(s) = Cp(std)\sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

*Deviation = {Cp(s) - *AVG* Cp(s)} {must be <0.010}

Standard deviation of the deviations must be less than 0.02 for both sides.

Pitot tube S/N A4187 was calibrated in accordance with the CFR 40, Part 60 Appendix A, Method 2, Section 10.

Signature

3/2/15
Date

METERING SYSTEM DRY GAS METER CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1706009

Date: 07/03/19
Barometric Pressure: 29.10 (in. Hg)
Theoretical Critical Vacuum: 13.73 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume Initial (ft³)	Volume Final (ft³)	Volume Total (ft³)	Initial Temperature Inlet (°F)	Initial Temperature Outlet (°F)
0.32	17.00	443.350	448.680	5.330	71.0	71.0
0.63	12.00	448.680	454.070	5.390	73.0	73.0
1.10	10.00	454.070	460.140	6.070	74.0	74.0
1.90	10.00	460.140	468.070	7.930	76.0	76.0
3.50	10.00	468.070	479.010	10.940	77.0	77.0

Final Temperature Inlet (°F)	Final Temperature Outlet (°F)	Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature Initial (°F)	Ambient Temperature Final (°F)	Ambient Temperature Average (°F)
73.0	73.0	40	0.2341	16.0	71.3	72.0	71.7
74.0	74.0	48	0.3350	16.0	72.0	72.5	72.3
76.0	76.0	55	0.4531	16.0	72.5	72.7	72.6
77.0	77.0	63	0.5888	16.0	72.7	72.8	72.8
80.0	80.0	73	0.8077	16.0	72.8	73.0	72.9

RESULTS

DRY GAS METER VOLUME CORRECTED Vm(std) (ft³)	DRY GAS METER VOLUME CORRECTED Vm(std) (liters)	ORIFICE VOLUME CORRECTED Vcr(std) (ft³)	ORIFICE VOLUME CORRECTED Vcr(std) (liters)	ORIFICE VOLUME NOMINAL Vcr (ft³)
5.147	145.76	5.023	142.2	5.202
5.194	147.11	5.071	143.6	5.258
5.840	165.40	5.713	161.8	5.928
7.624	215.91	7.423	210.2	7.704
10.521	297.95	10.182	288.3	10.570

DRY GAS METER CALIBRATION FACTOR Y Variation (number)	DRY GAS METER CALIBRATION FACTOR Y Value (number)	ORIFICE CALIBRATION FACTOR ΔH@ Value (in. H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Value (mm H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Variation (in. H2O)
0.001	0.976	1.990	50.56	0.113
0.002	0.976	1.910	48.52	0.033
0.004	0.978	1.819	46.21	-0.058
-0.001	0.974	1.856	47.15	-0.021
-0.007	0.968	1.811	46.00	-0.067
AVERAGE:	**0.974**	**1.878**	47.69	**PASSED**

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter,acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H_20 that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)^3*(deg R)^0.5/((in.Hg)*(min)).

SIGNATURE: Craig McCarty DATE: 07/03/19 07/03/19

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1706009

Date: 07/03/19
Barometric Pressure: 29.28 (in. Hg)
Temperature (ASTM cal): 75.40 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	603.00	0.50	1206.00	0.50
Probe	101.00	0.50	603.00	0.50	1206.00	0.50
Filter	101.00	0.50	603.00	0.50	1206.00	0.50
Dryer	101.00	0.50	603.00	0.50	1206.00	0.50
Aux.	101.00	0.50	603.00	0.50	1206.00	0.50

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	75.40 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	74.0	1.40	yes
DGM Out	74.0	1.40	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 07/03/19 07/03/19

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
Appendix A, Method 5
10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration

Air Hygiene Assett ID(s): **Probe:** samp-hp-0086 **Hotbox:** samp-bh-0012 **Gooseneck:** samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Barometric Pressure: 29.10

Thermo-couples		Temps (°F)	Signature		Date	
Stack	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Probe	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Filter	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Cond.	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
CPM	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Exit	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319 T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	267.75	268.75	263.25	minutes
Actual Meter Volume	V_m	104.89	103.58	102.29	dcf
Meter Temperature	T_m	527.17	525.17	535.08	°R
Meter Pressure at 0.75 cfm	ΔH@	1.878	1.878	1.878	in. H_2O
Barometric Pressure	P_{bar}	29.98	29.88	30.12	in. Hg
Average Meter Pressure	ΔH_{avg}	0.46	0.46	0.46	in. H_2O
Dry Molecular Weight	M_d	29.29	29.28	29.28	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.68	0.68	0.68	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9409	0.9564	0.9537	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9503
Y_i	0.9740
%Diff	2.43%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{267.75}{104.89} \times \sqrt{\frac{0.0319 \times 527.17}{1.878 \times \left(29.98 + \frac{0.46}{13.6}\right)}} \times \frac{29}{29.29} \times 0.6782 = 0.9409$$

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	265.50	265.50	267.00	minutes
Actual Meter Volume	V_m	100.69	101.55	103.13	dcf
Meter Temperature	T_m	530.08	528.08	533.58	°R
Meter Pressure at 0.75 cfm	ΔH@	1.878	1.878	1.878	in. H_2O
Barometric Pressure	P_{bar}	30.14	30.02	30.14	in. Hg
Average Meter Pressure	ΔH_{avg}	0.44	0.44	0.44	in. H_2O
Dry Molecular Weight	M_d	29.32	29.31	29.31	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.66	0.66	0.66	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9503	0.9424	0.9362	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9430
Y_i	0.9740
%Diff	3.19%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{265.50}{100.69} \times \sqrt{\frac{0.0319 \times 530.08}{1.878 \times \left(30.14 + \frac{0.44}{13.6}\right)} \times \frac{29}{29.32}} \times 0.6633 = 0.9503$$

METERING SYSTEM DRY GAS METER CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0007

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0007 Calibration 2-20-19.xls]Original (5 point)

Make: Thermo Environmental
Model #: MST-C1
Serial #: 90704

Date: 02/20/19
Barometric Pressure: 29.03 (in. Hg)
Theoretical Critical Vacuum: 13.69 (in. Hg)

DRY GAS METER READINGS

ΔH	Time	Volume			Initial Temperature	
		Initial	Final	Total	Inlet	Outlet
(in. H2O)	(min)	(ft³)	(ft³)	(ft³)	(°F)	(°F)
0.26	17.00	280.930	286.280	5.350	80.0	71.0
0.55	12.00	286.280	291.690	5.410	80.0	73.0
1.10	10.00	291.690	297.800	6.110	86.0	74.0
1.80	10.00	297.800	305.720	7.920	89.0	75.0
3.50	10.00	305.720	316.650	10.930	94.0	76.0

Final Temperature		Orifice	K' Orifice	Actual	Ambient Temperature		
Inlet	Outlet	Serial#	Coefficient	Vacuum	Initial	Final	Average
(°F)	(°F)	(number)	(see above)	(in. Hg)	(°F)	(°F)	(°F)
81.0	73.0	40	0.2341	16.0	68.7	69.4	69.1
86.0	74.0	48	0.3350	16.0	69.4	69.5	69.5
89.0	75.0	55	0.4531	16.0	69.5	69.5	69.5
94.0	76.0	63	0.5888	16.0	69.6	69.5	69.6
93.0	77.0	73	0.8077	16.0	69.5	69.5	69.5

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
5.112	144.78	5.023	142.2	5.189
5.154	145.97	5.072	143.6	5.244
5.800	164.24	5.716	161.9	5.911
7.496	212.30	7.428	210.4	7.681
10.361	293.42	10.190	288.6	10.536

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
-0.003	0.982	1.613	40.98	-0.118
-0.001	0.984	1.663	42.24	-0.068
0.000	0.986	1.815	46.10	0.083
0.006	0.991	1.756	44.59	0.024
-0.002	0.983	1.811	45.99	0.079
AVERAGE:	**0.985**	**1.731**	43.98	**PASSED**

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter,acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H_20 that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)^3*(deg R)^0.5/((in.Hg)*(min)).

SIGNATURE: Craig McCarty _____ DATE: 02/20/19 02/20/19

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0007

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0007 Calibration 2-20-19.xls]Original (5 point)

Make: Thermo Environmental
Model #: MST-C1
Serial #: 90704

Date: 02/20/19
Barometric Pressure: 29.03 (in. Hg)
Temperature (ASTM cal): 68.70 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	602.00	0.33	1205.00	0.42
Probe	101.00	0.50	602.00	0.33	1205.00	0.42
Filter	101.00	0.50	602.00	0.33	1205.00	0.42
Dryer	101.00	0.50	602.00	0.33	1205.00	0.42
Aux.	101.00	0.50	602.00	0.33	1205.00	0.42

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	68.70 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	68.0	0.70	yes
DGM Out	67.0	1.70	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 02/20/19 02/20/19

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
Appendix A, Method 5
10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration

Air Hygiene Assett ID(s): **Probe:** samp-hp-0086 **Hotbox:** samp-bh-0012 **Gooseneck:** samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0007 Calibration 2-20-19.xls]Original (5 point)

Barometric Pressure: 29.03

Thermo-couples		Temps (°F)	Signature		Date	
Stack	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	70.00				
	±°F	1.10				
Probe	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	70.00				
	±°F	1.10				
Filter	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	69.00				
	±°F	0.10				
Cond.	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	69.00				
	±°F	0.10				
CPM	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	69.00				
	±°F	0.10				
Exit	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	70.00				
	±°F	1.10				

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319 T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	120.00	120.00	120.00	minutes
Actual Meter Volume	V_m	42.32	42.32	42.32	dcf
Meter Temperature	T_m	548.63	550.31	561.31	°R
Meter Pressure at 0.75 cfm	ΔH@	1.731	1.731	1.731	in. H_2O
Barometric Pressure	P_{bar}	29.98	29.88	30.12	in. Hg
Average Meter Pressure	ΔH_{avg}	0.34	0.34	0.34	in. H_2O
Dry Molecular Weight	M_d	29.28	29.28	29.28	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.58	0.58	0.58	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9552	0.9583	0.9640	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9592
Y_i	0.9850
%Diff	2.62%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{120.00}{42.32} \times \sqrt{\frac{0.0319 \times 548.63}{1.731 \times \left(29.98 + \frac{0.34}{13.6}\right)}} \times \frac{29}{29.28} \times 0.5831 = 0.9552$$

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	120.00	120.00	120.00	minutes
Actual Meter Volume	V_m	42.32	42.32	42.32	dcf
Meter Temperature	T_m	555.69	560.50	561.38	°R
Meter Pressure at 0.75 cfm	ΔH@	1.731	1.731	1.731	in. H_2O
Barometric Pressure	P_{bar}	30.14	30.02	30.14	in. Hg
Average Meter Pressure	ΔH_{avg}	0.34	0.34	0.34	in. H_2O
Dry Molecular Weight	M_d	29.32	29.32	29.32	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.58	0.58	0.58	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9581	0.9642	0.9630	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9618
Y_i	0.9850
%Diff	2.36%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{120.00}{42.32} \times \sqrt{\frac{0.0319 \times 555.69}{1.731 \times \left(30.14 + \frac{0.34}{13.6}\right)}} \times \frac{29}{29.32} \times 0.5831 = 0.9581$$

Field Balance Weight Verfication
Annual 500g Field Balance Stock Weight vs. 500g ISO 17025 Traceable Weight
Air Hygiene Asset ID: samp-sc-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\Field Balance Weights\2020\[samp-sc-0028-Extra.xlsm]Balance
Make: Ohaus
Model #: Scout Pro SP2001-US
Serial #: B228113219
Field Weight #: sc-0028
Trailer #: Extra

ISO 17025 Weight ID LABS-WT-0005
ISO S/N 1000128090
ISO Cal Due 7/29/2020

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.90	0.10

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.50	0.50

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.80	0.20

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

Note: Calibrated against ISO 17025 Certified weight LABS-WT-0005

EPA Method 4 - Section 10.3, EPA Method 5 - Section 10.7, EPA Method 202 - Section 10.3: Field Balance Calibration Check. Check the calibration of the balance used to weigh impingers with a weight that is at least 500g or within 50g of a loaded impinger. The weight must be ASTM E617-13 "Standard Specification for Laboratory Weights and Precision Mass Standards" Class 6 (or better). Daily before used, the field balance must meausure within ±0.5g of the certified mass. If the daily balance calibration check fails, perform corrective measures and repeat the check before using balance.

ISO 17025 Certified 500g Weight is certified annually. Certified weight is used to verify Class 6 or better weight that accompanies each field balance on the balance it will be used. Acceptance critieria is certified weight must be within ±0.5g of Class 6 or better weight.

WEATHER STATION CALIBRATION SHEET
Temperature, Barometric Pressure, and Relative Humidity Periodic Calibration
Air Hygiene Asset ID: samp-we-0014

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\Weather Stations\2020\[SAMP-WE-0014_224.xlsm]112013
Make: Kestrel — ISO 17025 Weather Station ID: SAMP-WE-0033
Model #: 4000 — ISO 17025 S/N: A026334
Serial #: 671144 — ISO 17025 Cal Due: 7/23/2020

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.10	69.70	0.40	29.11	29.13	0.02	15:08

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.50	70.40	0.10	29.11	29.12	0.01	15:26

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.80	70.40	0.40	29.11	29.12	0.01	15:41

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.60	69.00	1.60	29.10	29.12	0.02	16:00

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

Note: Verified against ISO 17025 Traceable Barometer and Thermometer (SAMP-WE-0033).

this page intentionally left blank
end of report

EMISSION COMPLIANCE TEST
FOR THE
GENERAL ELECTRIC, 7F.05, UNIT #U-00002
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
MARCH 9-11, 2020

Permit No: 3-1326-00275/00009
Facility DEC ID: 3132600275
Report Date: April 8, 2020



Corporate Headquarters
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012

AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices
Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

EMISSION COMPLIANCE TEST
FOR THE
GENERAL ELECTRIC, 7F.05, UNIT #U-00002
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
MARCH 9-11, 2020

Prepared and Reviewed by:

Logan K. Tsotsoros

Logan Tsotsoros
AHU Support Staff

Thomas K Graham

Thomas K. Graham, PE, QSTI
Director of AHU


I, Rob C. White

Rob White, QSTI
Test Manager
certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

CERTIFICATION OF INFORMATION

I certify under penalty of law that I believe the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.



Rob White, QSTI
Test Manager
Air Hygiene International, Inc.

March 11, 2020
Date

FACILITY CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attached documents and, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.

I am the responsible official with direct knowledge and overall responsibility for the information contained in this report.

Name

Title

Signature

Date

(this page intentionally left blank)

Table of Contents

1.0 INTRODUCTION 1

1.1 TEST PURPOSE AND OBJECTIVES 1

1.2 SUMMARY OF TEST PROGRAM 1

1.2.1 Participating Organizations 1
1.2.2 Industry 1
1.2.3 Air Permit Requirements 1
1.2.4 Plant Location 1
1.2.5 Equipment Tested 1
1.2.6 Emission Points 2
1.2.7 Emission Parameters Measured 2
1.2.8 Dates of Emission Test 2
1.2.9 Federal Certifications 2

1.3 KEY PERSONNEL 2

2.0 SUMMARY OF TEST RESULTS 2

3.0 SOURCE OPERATION 4

3.1 PROCESS DESCRIPTION 4

3.2 SAMPLING LOCATION 4

4.0 SAMPLING AND ANALYTICAL PROCEDURES 4

4.1 TEST METHODS 4

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS 5

APPENDICES

Appendix A Test Results and Calculations
Table A.1: Emissions Testing Schedule (Sampling Log)
Emissions Results Base Load NOx, CO, VOC, and NH_3
Emissions Results Base Load PM_{10}
Emissions Results Base Load SAM
Emissions Results Base+DB Load NOx, CO, VOC, and NH_3
Emissions Results Base+DB Load PM_{10}
Emissions Results Base+DB Load SAM

Appendix B Emission Data Records
Operating Data Base Load NOx, CO, VOC, and NH_3
Operating Data Base Load PM_{10}
Operating Data Base Load SAM
Operating Data Base Load Opacity
Operating Data Base+DB Load NOx, CO, VOC, and NH_3
Operating Data Base+DB Load PM_{10}
Operating Data Base+DB Load SAM
Operating Data Base+DB Load Opacity

Table of Contents
(continued)

APPENDICES

Appendix B Emission Data Records
- Reference Method Data Base Load NOx, CO, VOC, and NH_3
- Reference Method Data Base Load PM_{10}
- Reference Method Data Base Load SAM
- Reference Method Data Base Load Opacity
- Reference Method Data Base+DB Load NOx, CO, VOC, and NH_3
- Reference Method Data Base+DB Load PM_{10}
- Reference Method Data Base+DB Load SAM
- Reference Method Data Base+DB Load Opacity

Appendix C Calibration Gas Certifications

Appendix D Quality Assurance and Quality Control Data
- Daily Reference Method Analyzer Calibration Data
- Laboratory Data Summary Base Load PM_{10}
- Laboratory Data Summary Base+DB Load PM_{10}
- Field Collection Data QA SAM
- Laboratory Data PM_{10} and SAM, BV Labs
- Laboratory Data PM_{10} and SAM Blanks, BV Labs [U-00001 Report]
- Supplemental Laboratory Data PM_{10} Filters, BV Labs
- Audit Sample Data

Appendix E Fuel Analysis Records

Appendix F Stratification Test Data
- Stratification Test Data Base Load
- Stratification Test Data Base+DB Load

Appendix G Equipment Calibration Records

Emissions Compliance Test
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center LLC
Cricket Valley Energy Center
Dover Plains, New York
March 9-11, 2020

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Emissions Compliance Test for nitrogen oxides (NOx), carbon monoxide (CO), total hydrocarbons/volatile organic compounds (THC/VOC), sulfur dioxide (SO_2) [by fuel analysis], ammonia (NH_3), particulate matter (PM_{10}), sulfuric acid mist (SAM), opacity / visual emissions (VE), flow, moisture (H_2O), carbon dioxide (CO_2), and oxygen (O_2) from the exhaust of the General Electric, 7F.05, Unit #U-00002 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on March 9-11, 2020.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to conduct an initial compliance emission test to document levels of selected pollutants at two test loads, base loaded with duct burners on and base loaded with duct burners off (Base+DB and Base). The information will be used to confirm compliance with the operating permit issued by the New York State Department of Environmental Conservation (NYSDEC). The specific objective was to determine the emission concentrations and rates of NOx, CO, THC/VOC, SO_2 [fuel analysis], NH_3, PM_{10}, SAM, VE, flow, H_2O, CO_2, and O_2 from the exhaust of Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00002 at Base+DB and Base.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations
- New York State Department of Environmental Conservation (NYSDEC)
- Cricket Valley Energy Center LLC
- Bechtel Corporation
- Air Hygiene

1.2.2 Industry
- Electric Utility / Electric Services

1.2.3 Air Permit Requirements
- Permit Number: 3-1326-00275/00009

1.2.4 Plant Location
- Cricket Valley Energy Center in Dover Plains, New York
  - GPS Coordinates [Latitude 41.67721, Longitude -73.57992]
  - Physical Address: 2241 ST RTE 22, Dover Plains, New York 12522
  - Federal Registry System / Facility Registry Service (FRS) No. – 110043340364
  - Source Classification Code (SCC) – 10200602

1.2.5 Equipment Tested
- General Electric, 7F.05, Unit #U-00002

1.2.6 Emission Points

- Exhaust from the General Electric, 7F.05, Unit #U-00002
- For all gases, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00002, determined after conducting a 12-point stratification test
- For all PM_{10} testing, 12 sampling points in the exhaust duct from the General Electric, 7F.05, Unit #U-00002
- For all SAM testing, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00002
- For opacity, one sample visual observation point from the exit of the exhaust duct to the atmosphere from the General Electric, 7F.05, Unit #U-00002

1.2.7 Emission Parameters Measured

- NOx
- CO
- THC/VOC
- SO_2 [fuel analysis]
- NH_3
- PM_{10}
- SAM
- Opacity
- Flow
- H_2O
- CO_2
- O_2

1.2.8 Dates of Emission Test

- March 9-11, 2020

1.2.9 Federal Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Cricket Valley Energy Center LLC:	Marc Duquette (mduquette@cricketvalley.com)	617-320-5219
Bechtel Corporation:	John Curran	772-678-1878
Bechtel Corporation:	Peter Carr (pcarr@bechtel.com)	571-392-6737
NYSDEC:	Alyssa Carbone	845-256-3051
Air Hygiene:	Rob White (rwhite@airhygiene.com)	918-307-8865
Air Hygiene:	Swanson Bierman (swanson@airhygiene.com)	918-307-8865
Air Hygiene:	Andrew McMahan	918-307-8865
Air Hygiene:	Taylor Williams	918-307-8865
Air Hygiene:	Sean Fields	918-307-8865
Air Hygiene:	Matt Jones	918-307-8865
Air Hygiene:	Adrian Lopez	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00002 located at the Cricket Valley Energy Center on March 9-11, 2020 are summarized in the following table and relate only to the items tested.

TABLE 2.1
SUMMARY OF GENERAL ELECTRIC, 7F.05, UNIT #U-00002 RESULTS

Parameter	Base Load	Base+DB Load	Permit Limits Base	Permit Limits Base+DB
Heat Input (MMBtu/hr)	2,218.4	2,465.5	--	--
CT Power Output (megawatts)	230.7	232.1	--	--
Load Condition	Nominal base load, w/o DB[1]	Nominal base load, w/ DB[2]	--	--
NOx (ppmvd)	2.08	2.51	--	--
NOx (ppm@15%O_2)	1.57	1.66	2.0	2.0
CO (ppmvd)	0.19	0.21	--	--
CO (ppm@15%O_2)	0.15	0.14	2.0	2.0
VOC (as C1) (ppmvd)	0.00	0.00	--	--
VOC (as C1) (ppm@15%O_2)	0.00	0.00	0.7	1.8
Total PM_{10} (mg)	8.83	7.10	--	--
Total PM_{10} (lb/MMBtu)	0.0044	0.0031	0.005	0.006
Fuel Sulfur (grains / 100 scf)	0.13	0.12	0.4	0.4
SAM (as H_2SO_4) (mg)	0.02	0.02	--	--
SAM (as H_2SO_4) (lb/MMBtu)	0.00003	0.00003	0.00065	0.00065
NH_3 (ppmvd)	1.30	1.74	--	--
NH_3 (ppm@15%O_2)	0.98	1.15	5.0	5.0
Opacity (%)	0	0	20	20

Notes: [1]Air permit specifically indicates design capacity heat input of 2395.7 MMBtu/hr [ISO Conditions, 1 atm (29.923 in Hg), temperature 15 C or 59 F, and RH 60%] for the gas turbine. [2]Air permit specifically indicates design capacity heat input of 247 mmBtu/hr [ISO Conditions, 1 atm (29.923 in Hg), temperature 15 C or 59 F, and RH 60%] for the duct burner.

The results of all measured pollutant emissions were below the required limits. All testing was conducted according to the approved testing protocol. All testing was performed without any real or apparent errors with the following exceptions:

The PM_{10} filter weights were reported by the laboratory at the reportable detection limit (RDL). Supplemental laboratory data was provided and additional data analysis indicated minor filter losses, which were accounted for in either the sample train section cleanup just prior to the filter or the sample train cleanup in the section just after the filter. As a result, the PM results are considered valid with accounting for all minor filter weight losses in other fractions of the sample train results.

The SAM analysis was conducted by titration, per the requirements of CTM-013 with all results reported below the reportable detection limits (RDLs). However, when reporting emission rates using the titration based RDL values, the SAM results exceeded permitted limits. To remedy, the SAM analysis was also conducted by ion chromatography (IC). The supplemental IC analysis (Appendix D) yielded lower RDLs and also all results that were below the permitted limits. Emission rates were calculated based on the supplemental IC data.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

Cricket Valley Energy Center LLC owns and operates the Cricket Valley Energy Center located at 2241 ST RTE 22 in Dover Plains, New York. Located on the Cricket Valley Energy Center are three General Electric 7F.05 Combustion Turbine Generators (CTGs), designated as Emission Units U-00001, U-00002, and U-00003. The CTGs and associated heat recovery steam generators (HRSGs) which are equipped with dry low NOx burners in combination with selective catalytic reduction systems (SCRs). The CTG-HRSGs are also equipped with oxidation catalysts which reduce CO and VOC emissions.

3.2 SAMPLING LOCATION

The sample ports were located approximately vertical, circular and measures 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 265.8 ft above grade level with an exit elevation of approximately 282.5 ft above grade level. The test ports are located approximately 70.8 ft (850 inches) downstream and approximately 16.7 ft (200.4 inches) upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by Cricket Valley Energy Center LLC. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test. During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time. For PM_{10} testing, an initial velocity traverse was performed across the stack from 12 total points at each test load. All PM_{10} sampling occurred from the same 12 points. All SAM testing occurred from a simple sample point. All opacity observations were made by viewing the point where the exhaust system exited to the atmosphere at the top of the exhaust stack.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the General Electric, 7F.05, Unit #U-00002 at the Cricket Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on March 9-11, 2020.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	S-Type Pitot Tube
Oxygen	EPA Method 3A	Paramagnetic Cell
Carbon Dioxide	EPA Method 3A	Nondispersive Infrared Analyzer
Stack Moisture Content	EPA Method 4	Gravimetric Analysis

Pollutant or Parameter	Sampling Method	Analysis Method
Sulfur Dioxide	GPA 2261	Fuel Sulfur Content
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Sulfuric Acid Mist	CTM-013 (EPA Method 8A)	Wet Chemistry Solubility
Opacity	EPA Method 9	Visual Observation
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Volatile Organic Compounds	EPA Method 18/25A	Gas Chromatograph and Flame Ionization Detector
Stack Flow Rate	EPA Method 19	ASTM 5504 and Dry Oxygen F Factor
Particulate Matter	EPA Method 201A	Front Half Filterables
Particulate Matter	EPA Method 202	Back Half Condensables
Ammonia Slip	EPA Method 320	Fourier Transform Infrared

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3A, 4, 7E, 9, 10, 18, 19, 25A; 40 CFR 51, Appendix M, Methods 201A and 202; 40 CFR 63, Appendix A, Method 320; Conditional Test Method (CTM)-013 [Method 8A]; ASTM 5504; and GPA 2261.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless-steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample. Exhaust samples were routed to the wet based analyzer prior to gas conditioning.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer,

interferograms consisting of 27 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations. Spectral data was analyzed by the MKS MG2000 software.

Figure 4.2 represents the sample system used for the PM_{10} tests. A heated stainless-steel probe with a glass liner and stainless-steel nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter. Glassware that is used to collect and analyze Method 202 condensable particulate samples is cleaned prior to the test with soap and water, and rinsed using tap water, deionized water, acetone, and finally, hexane. After cleaning, Air Hygiene incorporates a glassware bake at 300ºC for six hours rather than the alternative of collecting a field train proof blank.

Figure 4.3 represents the sample system used for the SAM tests. A heated stainless-steel probe with a glass liner was inserted into a sample port of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter.

The stack gas analysis for O_2 and CO_2 concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O_2 analyzer uses a paramagnetic cell detector and the CO_2 analyzer uses a continuous nondispersive infrared analyzer.

EPA Method 7E was used to determine concentrations of NOx. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO_2 in nitrogen certified gas cylinder was used to verify at least a 90 percent NO_2 conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.


THC emission concentrations were quantified in accordance with procedures set forth in EPA Method 25A. A continuous flame ionization (FID) analyzer was used for this purpose. THC emissions concentrations were below VOC limits and all assumed as VOCs. EPA Method 18 for Tedlar bag sampling and analysis of methane and ethane content was not analyzed or subtracted from the THC concentrations to determine VOC concentrations.

An MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer, or equivalent, was used for NH_3 analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm^{-1}. The system employed a silicon carbide infrared source at 1200ºC, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191ºC. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 10.0 liters per minute, the sample gas in the cell is refreshed at least times each minute. Interferograms consisting of 27 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations.


TABLE 4.2
ANALYTICAL INSTRUMENTATION

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NOx	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO_2 to NO. Chemiluminescence of reaction of NO with O_3. Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor-based linearization.
CO_2	SERVOMEX 1440	0-20%	0.1%	Nondispersive infrared
NH_3	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
VOC	THERMO 51 series	User may select up to 10,000 ppm	0.1 ppm	Flame Ionization Detector
O_2	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

COPYRIGHT © 2011 AIR HYGIENE INTERNATIONAL, INC.



LEGEND
- Heated Teflon Tubing (pre-conditioned sample)
- Unheated Teflon Tubing (conditioned sample)
- Diluted Calibration Gas
- Calibration Gas
- Electronic Input/Output



PROCESS INLET OR 2ND STACK

dual line heated sample umbilical

STACK EXHAUST

TEST TRAILER EXTERIOR

TEST TRAILER INTERIOR


DATA RECORDER



COMPUTER




GAS CONDITIONER



dual line heated sample umbilical

MOBILE SECONDARY ANALYZERS

MANIFOLD





GAS DILUTER

THC, VOC



O_2, CO_2, NOx, CO, SO_2



HOT/WET ANALYZERS
COLD/DRY ANALYZERS




COLD/DRY ANALYZERS HOT/WET



O_2, CO_2, NOx, CO, SO_2

FLOW CONTROL MANIFOLD





FTIR


THC, VOC



CONDITIONER

VENT

CALIBRATION/ BIAS GAS BOTTLES



VENT

FIXED PRIMARY ANALYZERS


Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.

AIR HYGIENE

Figure 4.1
EMISSIONS TESTING LAB

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

COPYRIGHT © 2009 AIR HYGIENE INTERNATIONAL, INC.




Wet Chemistry Assembly
(photo)





Figure 4.2
RM201A / 202 ASSEMBLY

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

COPYRIGHT © 2013 AIR HYGIENE INTERNATIONAL, INC.



TEST NOTES:
10 LPM SAMPLE FLOW
Delta H @ 0.35 IS ABOUT 10 LPM ON STANDARD CONSOLE
15 MIN AMBIENT AIR PURGE

Figure 4.3
METHOD 8A ASSEMBLY

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1: EMISSIONS TESTING SCHEDULE

Unit	Load	Component	Run	Date	Start	Stop	Time Sync	Duration
U-00002	Base	Stratification Test	Base-1	02/25/20	06:14	07:12	DAHS	00:58
U-00002	Base	Cyclonic Flow Check	PM U-00002 Base-V1	03/09/20	06:44	07:11	DAHS	00:27
U-00002	Base	NOx, CO, VOC, NH_3	1-1	03/09/20	14:44	15:43	DAHS	01:00
U-00002	Base	NOx, CO, VOC, NH_3	1-2	03/09/20	16:05	17:04	DAHS	01:00
U-00002	Base	NOx, CO, VOC, NH_3	1-3	03/09/20	17:18	18:17	DAHS	01:00
U-00002	Base	Opacity	Op-1-1	03/09/20	10:52	11:52	DAHS	01:00
U-00002	Base	Opacity	Op-1-2	03/09/20	11:52	12:52	DAHS	01:00
U-00002	Base	Opacity	Op-1-3	03/09/20	12:52	13:52	DAHS	01:00
U-00002	Base	PM_{10}	PM U-00002 Base-1	03/09/20	08:15	13:16	DAHS	05:01
U-00002	Base	PM_{10}	PM U-00002 Base-2	03/09/20	13:30	19:48	DAHS	06:18
U-00002	Base	PM_{10}	PM U-00002 Base-3	03/10/20	07:23	12:15	DAHS	04:52
U-00002	Base	SAM	SAM U-00002 Base-1	03/09/20	08:06	10:06	DAHS	02:00
U-00002	Base	SAM	SAM U-00002 Base-2	03/09/20	11:49	13:49	DAHS	02:00
U-00002	Base	SAM	SAM U-00002 Base-3	03/09/20	15:17	17:17	DAHS	02:00
U-00002	Base+DB	Stratification Test	BaseDB-1	03/10/20	12:32	14:11	DAHS	01:39
U-00002	Base+DB	Cyclonic Flow Check	PM U-00002 Base+DB-V1	03/10/20	13:08	13:24	DAHS	00:16
U-00002	Base+DB	NOx, CO, VOC, NH_3	2-1	03/10/20	15:27	16:26	DAHS	01:00
U-00002	Base+DB	NOx, CO, VOC, NH_3	2-2	03/10/20	17:35	18:34	DAHS	01:00
U-00002	Base+DB	NOx, CO, VOC, NH_3	2-3	03/10/20	18:35	19:34	DAHS	01:00
U-00002	Base+DB	Opacity	Op-2-1	03/10/20	14:30	15:30	DAHS	01:00
U-00002	Base+DB	Opacity	Op-2-2	03/10/20	15:30	16:30	DAHS	01:00
U-00002	Base+DB	Opacity	Op-2-3	03/10/20	16:30	17:30	DAHS	01:00
U-00002	Base+DB	PM_{10}	PM U-00002 Base+DB-1	03/10/20	14:12	18:40	DAHS	04:28
U-00002	Base+DB	PM_{10}	PM U-00002 Base+DB-2	03/11/20	06:23	11:17	DAHS	04:54
U-00002	Base+DB	PM_{10}	PM U-00002 Base+DB-3	03/11/20	12:30	17:15	DAHS	04:45
U-00002	Base+DB	SAM	SAM U-00002 Base+DB-1	03/11/20	05:46	07:46	DAHS	02:00
U-00002	Base+DB	SAM	SAM U-00002 Base+DB-2	03/11/20	08:40	10:40	DAHS	02:00
U-00002	Base+DB	SAM	SAM U-00002 Base+DB-3	03/11/20	11:33	13:33	DAHS	02:00

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
NOx, CO, VOC, and NH_3

GENERAL ELECTRIC, 7F.05, UNIT #U-00002 BASE LOAD DATA SUMMARY

Parameter	Base Load, Run - 1-1	Base Load, Run - 1-2	Base Load, Run - 1-3	Average
Date (mm/dd/yy)	03/09/20	03/09/20	03/09/20	03/09/20
Start Time (hh:mm:ss)	14:44:11	16:05:11	17:18:11	14:44:11
End Time (hh:mm:ss)	15:43:41	17:04:41	18:17:41	18:17:41
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	30.28	30.28	30.30	30.29
Amb. Temp. (°F)	66	67	65	66
Rel. Humidity (%)	22	25	28	25
Spec. Humidity (lb water / lb air)	0.002926	0.003445	0.003599	0.003323
NH_3 Flow Rate (lb/hr)	126.8	123.3	124.2	124.7
Turbine Fuel Flow (lb/min)	1,617	1,624	1,622	1,621
Duct Burner Fuel Flow (lb/min)	0	0	0	0
Total Fuel Flow (SCFH)	2,195,187	2,205,298	2,202,317	2,200,934
Stack Flow (RM19) (SCFH)	51,014,767	51,447,204	50,992,328	51,151,433
Stack Moisture (% Method 4)	7.6	7.6	7.6	7.6
Heat Input (MMBtu/hr)	2,212.6	2,222.8	2,219.8	2,218.4
CT Power Output (megawatts)	230.8	230.6	230.5	230.7
NOx (ppmvd)	2.14	2.15	1.95	2.08
NOx (ppm@15%O_2)	1.61	1.63	1.46	1.57
CO (ppmvd)	0.21	0.22	0.15	0.19
CO (ppm@15%O_2)	0.16	0.16	0.11	0.15
VOC (as C1) (ppmvd)	0.00	0.01	0.00	0.00
VOC (as C1) (ppm@15%O_2)	0.00	0.01	0.00	0.00
Fuel Sulfur (grains / 100 scf)	0.13	0.13	0.13	0.13
CO_2 (%)	4.22	4.75	4.42	4.46
O_2 (%)	13.07	13.10	13.04	13.07

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO_2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH_3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO_2 (lb/lb-mole) =	44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO_2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH_3 =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO_2 =	0.0000001142434

NOTE: units are lb/ppm*ft^3

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$

2. Correction to % O_2, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$

3. Correction to % O_2 and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_O - 0.00633))} \times \left(\frac{288}{T_a}\right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000}\right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}}\right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O_2 based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp \cdot hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \; or \; \frac{E_{lb/hr} \times 453.6}{hp}$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO_2 to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H_2O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
$\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
$\%_{CO2d}$,$\%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g.,24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO_2 rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O_2.
E_{jo},E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft^3 = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
$\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
$\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = $2x10^4$ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p,L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
$\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
$M_{\%}$ = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)[1]
NCM = net Btu per SCF (constant based on compound)
$\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
$\%_{O2d}$, $\%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO2 emissions, percent.
$\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
$\%_{Sf}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
$\%S_p$, $\%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
$t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, ^oF
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2}=CO_2 Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

EXAMPLE CALCULATIONS (FFACTOR)

RM 19, (02-27-14),
2.0 Summary of Method,
2.1 Emission Rates. Oxygen (O_2) or carbon dioxide (CO_2) concentrations and appropriate F factors (ratios of combustion gas volumes to heat inputs) are used to calculate pollutant emission rates from pollutant concentrations.

RM 19, (02-27-14),
12.2 Emission Rates of PM, SO_2, and NOx. Select from the following sections the applicable procedure to compute the PM, SO_2, or NOx emission rate (E) in lb/MMBtu. The pollutant concentration must be in lb/scf and the F factor must be in scf/MMBtu. If the pollutant concentration (C) is not in the appropriate units, use Table 19–1 in Section 17.0 to make the proper conversion. An F factor is the ratio of the gas volume of the products of combustion to the heat content of the fuel. The dry F factor (F_d) includes all components of combustion less water, the wet F factor (F_w) includes all components of combustion, and the carbon F factor (F_c) includes only carbon dioxide.

Mark's Std Hdbk, 10th ed.,pg 4-26
High Heat Value Dry (HHV_{dry}), calc for Methane (single component for the fuel gas)

$$HHV_{dry}\left(Btu / SCF\right) = \left[\left(\frac{M_{\%}}{100}\right) \times GCM\right]$$

HHV_{dry} = 93.50 % / 100.00 x 994.85 Btu / SCF = 930.20 Btu / SCF

Mark's Std Hdbk, 10th ed., pg 4-26
Low Heat Value Dry (LHV_{dry}), calc for Methane (single component for the fuel gas)

$$LHV_{dry}\left(Btu / SCF\right) = \left[\left(\frac{M_{\%}}{100}\right) \times NCM\right]$$

LHV_{dry} = 93.50 % / 100.00 x 895.75 Btu / SCF = 837.55 Btu / SCF

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
High Heat Value Wet (HHV_{wet}), calc for entire sample (all components of the fuel gas)

$$HHV_{wet}\left(Btu / SCF\right) = \frac{HHV_{dry}}{W / D.factor}$$

HHV_{wet} = 1,007.94 Btu/SCF / 1.0236 = 984.70 Btu/SCF

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
Low Heat Value Wet (LHV_{wet}), calc for entire sample (all components of the fuel gas)

$$LHV_{wet}\left(Btu / SCF\right) = \frac{LHV_{dry}}{W / D.factor}$$

LHV_{wet} = 908.68 Btu/SCF / 1.0236 = 887.73 Btu/SCF

Lbs Component per Lb-Mol of Gas (CM), calc for Methane (single component for the fuel gas)

$$CM\left(lb / lb-mol\right) = \left[\left(\frac{M_{\%}}{100}\right) \times MW\right]$$

CM = 93.50 % / 100.00 x 16.04 lb / lb-mol = 15.00 lb/lb-mol

ASTM D 3588
Fuel Molecular Weight (MW_{Fuel})

$$MW_{Fuel}\left(lb / lb \cdot mol\right) = \left[\sum \left(CM\right)\right]$$

MW_{Fuel} = 15.00 lb/lb-mol
\+ 1.26 lb/lb-mol
\+ etc. = 17.023 lb/lb-mol

Btu per Lb of Gas Gross (**GCV**)

$$GCV\left(Btu / lb\right) = \left[\frac{HHV_{dry} \times G}{MW_{Fuel}}\right]$$

GCV = 1,007.94 Btu/SCF x 385.23 ft^3/lbmol / 17.023 lb/lb-mol = 22,809.48 Btu/lb

ASTM D 3588 (SG)
Specific Gravity

$$SG = \left[\frac{MW_{Fuel}}{MW_{AIR}}\right]$$

SG = 17.02 lb/lb-mol / 28.96 lb/lb-mol = 0.5878

Btu per Lb of Gas Net (**NCV**)

$$NCV\left(Btu / lb\right) = \left[\frac{LHV_{dry} \times G}{MW_{Fuel}}\right]$$

NCV = 908.68 Btu/SCF x 385.23 ft^3/lbmol / 17.023 lb/lb-mol = 20,563.29 Btu/lb

Weight Percent of Component ($C_{\%}$), methane

$$C_{\%}\left(\%\right) = \left[\left(\frac{CM}{MW_{Fuel}}\right) \times 100\right]$$

$C_{\%}$ = 15.00 lb/lb-mol / 17.02 lb/lb-mol x 100 = 88.12 %

Weight Percent of Volatile Organic Compounds ($VOC_{\%}$)

$$VOC_{\%}(\%) = \left[\sum_{C_3H_8}^{C_8H_{18}} Wt_{\%}\right]$$

$VOC_{\%}$ = 0.38 % + 0.03 % + 0.03 % + etc. = 0.47 %

RM 19, (02-27-14), 12.3.2 Determined **F Factors**. If the fuel burned is not listed in Table 19–2 or if the owner or operator chooses to determine an F factor rather than use the values in Table 19–2, use the procedure below: 12.3.2.1 Equations. Use the eq

RM 19, (02-27-14),
12.1 Nomenclature

K (scf/lb)/%	
H	3.64
C	1.53
S	0.57
N_2	0.14
O_2	0.46

$$F_d = \frac{K\left(K_{hd}\%H + K_c\%C + K_s\%S + K_n\%N - K_o\%O\right)}{GCV} \qquad \text{Eq. 19-13}$$

F_d = 10^6Btu / MMBtu x [3.64 SCF / lb · % x 23.72 % + 1.53 SCF / lb · % x 72.59 % + 0.57 SCF / lb · % x 0.00 % + 0.14 SCF / lb · % x 2.17 % - 0.46 SCF / lb · % x 1.51 %] x lb / 22,809.48 Btu = 8,638.42 SCF / MMBtu

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RHsp (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp}(lb/lb) = \left[\left(\frac{gr}{lb}\right) \times \frac{lb}{7000\,gr}\right]$$

RH_{sp}= $\frac{20.48\ gr}{lb}$ x $\frac{1\ lb}{7000\ gr}$ = 0.002926 $\frac{lb\ H_2O}{lb\ Air}$

Fuel Flow Conversion (Q_f)

Note: Qf(lb/min) is a value obtained from the source operator.

$$Q_f = \left[Q_f \times G \times \left(\frac{1}{MW_{Fuel}}\right)\right]$$

Q_f = $\frac{1{,}616.74\ lb}{min}$ x $\frac{60\ min}{hr}$ x $\frac{385.23\ ft^3}{lb\text{-}mol}$ x $\frac{lb\text{-}mol}{17.02\ lb}$ = 2,195,187 SCFH

Heat Rate (MMBtu/hr)

$$HR = \frac{HHV_{DRY} \times Q_f}{1{,}000{,}000}$$

Heat Rate = $\frac{1{,}007.94\ Btu}{SCF}$ x $\frac{2{,}195{,}186.52\ SCF}{hr}$ x $\frac{MMBtu}{10^6\ Btu}$ = $\frac{2{,}212.62\ \ MMBtu}{hr}$

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

ACE = $\frac{5.05\ ppm - \ 4.91\ ppm}{8.90\ ppm}$ x 100 = 1.57 %

Calibration Error and Estimated Point, RM 25A, THC/VOC Analyzer

RM 25A, (02-27-14), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC/VOC analyzer mid gas, if applicable)

$$E_P = \frac{C_{Dir(H)} - C_{Dir(Z)}}{C_{V(H)} - C_{V(Z)}} \times C_{Dir(M)} + C_{Dir(Z)}$$

Eq. of a line
y=mx+b

E_p = $\frac{8.82\ ppm - \ 0.00\ ppm}{8.77\ ppm - \ 0.00\ ppm}$ x 4.90 ppm + 0.00 = 4.93 ppm

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

$ACE_{VOC(}$ = $\frac{4.73\ ppm - \ 4.93\ ppm}{4.90\ ppm}$ x 100 = -4.05 %

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS}\right) \times 100$$ Eq. 7E-2

SB = $\frac{4.84 \text{ ppm} - 5.05 \text{ ppm}}{8.90 \text{ ppm}}$ x 100 = -2.36 %

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = \left|SB_{final} - SB_i\right|$$ Eq. 7E-4

D = | -1.35 % - -2.36 % | = 1.01 %

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs – Cdir| is ≤ 0.5 ppmv or if |Cs – Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = \left|C_S - C_{Dir}\right|$$ Eq. Section 13.2 and 13.3

SB / D_{Alt} = | 4.84 ppm - 5.05 ppm | = 0.21 ppm

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$ Eq. 7E-5b

C_{Gas} = $\left(2.08 \text{ ppm} - -0.08 \text{ ppm}\right)$ $\left(\frac{4.91 \text{ ppm}}{4.89 \text{ ppm} - -0.08 \text{ ppm}}\right)$ = 2.14 ppm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_W}{1 - B_{WS}}$$ Eq. 7E-10

C_D = $\frac{1.97 \text{ ppmvw}}{1 - 0.08}$ = 2.14 ppmvd or inversely, $C_W = C_D \times \left(1 - B_{WS}\right)$

C_W = 2.14 ppmvd x $\left(1 - 0.08\right)$ = 1.97 ppmvw

Diluent-Corrected Pollutant Concentration, O_2 Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O_2 Concentration. Calculate the O_2 corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$ Eq. 20-4

C_{adj} = 2.14 ppm x $\left(\frac{20.9\% - 15.00\ \%}{20.9\% - 13.07\ \%}\right)$ = 1.61 ppm@15%O_2

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Historical Data	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
Run Start Time	08:15	13:30	07:23		hh:mm	
Run Stop Time	13:16	19:48	12:15		hh:mm	
Test Date	03/09/20	03/09/20	03/10/20		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.974	0.974	0.974			
Pitot Tube Coefficient	0.7240	0.7240	0.7240			
Average Nozzle Diameter	0.156	0.156	0.156		in	
Stack Test Data	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
Initial Meter Volume	364.330	468.560	572.380		ft^3	
Final Meter Volume	468.230	570.440	675.200		ft^3	
Total Meter Volume	103.900	101.880	102.820	102.867	ft^3	
Total Sampling Time	270.25	262.25	266.75	266.42	min	
Average Meter Temperature	77.33	87.58	78.50	81.14	°F	
Average Stack Temperature	189.67	191.83	190.25	190.58	°F	
Barometric Pressure	30.30	30.25	30.14	30.23	in Hg	
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89	in H_2O	
Absolute Stack Pressure	30.23	30.18	30.07	30.16	in Hg	
Average Orifice Pressure Drop	0.46	0.46	0.46	0.46	in H_2O	
Absolute Meter Pressure	30.44	30.39	30.28	30.37	in Hg	
Avg Square Root Pitot Pressure	1.19	1.15	1.17	1.17	$\sqrt{(in\ H_2O)}$	
Moisture Content Data	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	164.00	145.20	140.60	149.93	g	
Silica Gel Weight Gain	31.70	24.00	23.30	26.33	g	
Total Water Volume Collected	196.05	169.51	164.20	176.58	ml	
Standard Water Vapor Volume	9.23	7.98	7.73	8.31	scf	
Standard Meter Volume	100.8	96.8	99.0	98.9	dscf	
Standard Metric Meter Volume	2.9	2.7	2.8	2.8	dscm	
Calculated Stack Moisture	8.39	7.61	7.24	7.74	%	
Saturated Stack Moisture	62.33	65.40	63.45	63.73	%	
Reported Stack Moisture Content	8.39	7.61	7.24	7.74	%	
Gas Analysis Data	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	4.9	4.8	4.8	4.8	%	
Oxygen Content	12.7	12.8	12.8	12.8	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.4	82.4	82.4	82.4	%	
Stack Dry Molecular Weight	29.29	29.28	29.28	29.28	lb/lb-mole	
Stack Wet Molecular Weight	28.35	28.42	28.46	28.41	lb/lb-mole	
Calculated Fuel Factor	1.673	1.688	1.688	1.683		
Fuel F-Factor	8638.42	8638.42	8638.67	8638.50	dscf/MMBtu	
Percent Excess Air	140.3	143.0	143.0	142.1	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Volumetric Flow Rate Data	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
Average Stack Gas Velocity	63.94	62.27	63.24	63.15	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft²	
Actual Stack Flow Rate	1,087,671	1,059,255	1,075,842	1,074,256	acfm	
Wet Standard Stack Flow Rate	53,596	51,936	52,685	52,739	wkscfh	
Dry Standard Stack Flow Rate	49,102,141	47,983,757	48,871,628	48,652,509	dscfh	
Percent of Isokinetic Rate	97.5	98.8	97.5	97.9	%	
Gravimetric Analysis	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	ml	
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	mg	
Emission Rate Data	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
Total PM_{10} Mass	9.10	9.80	7.60	8.83	mg	--
Total PM_{10} Concentration	9.03E-05	1.01E-04	7.67E-05	8.94E-05	g/dscf	--
	1.39E-03	1.56E-03	1.18E-03	1.38E-03	gr/dscf	--
Total PM_{10} Emission Rate	4.43	4.86	3.75	4.35	kg/hr	--
	9.77	10.70	8.27	9.58	lb/hr	--
	42.80	46.89	36.22	41.97	tpy	--
	0.0044	0.0050	0.0038	0.0044	lb/MMBtu	0.005
Filterable PM_{10} Mass	2.70	3.10	1.70	2.50	mg	--
Filterable PM_{10} Concentration	2.68E-05	3.20E-05	1.72E-05	2.53E-05	g/dscf	--
	4.13E-04	4.94E-04	2.65E-04	3.91E-04	gr/dscf	--
Filterable PM_{10} Emission Rate	1.32	1.54	0.84	1.23	kg/hr	--
	2.90	3.39	1.85	2.71	lb/hr	--
	12.70	14.83	8.10	11.88	tpy	--
	0.0013	0.0016	0.0008	0.0012	lb/MMBtu	--
Condensable PM_{10} Mass	6.40	6.70	5.90	6.33	mg	--
Condensable PM_{10} Concentration	6.35E-05	6.92E-05	5.96E-05	6.41E-05	g/dscf	--
	9.80E-04	1.07E-03	9.19E-04	9.89E-04	gr/dscf	--
Condensable PM_{10} Emission Rate	3.12	3.32	2.91	3.12	kg/hr	--
	6.87	7.32	6.42	6.87	lb/hr	--
	30.10	32.06	28.12	30.09	tpy	--
	0.0031	0.0034	0.0029	0.0031	lb/MMBtu	--
RM 201A Quality Control	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	**Average**	**Units**	**Limits**
Stack Viscosity	201.67	202.96	202.93	202.52	µP	
Cyclone Flow Rate	0.496	0.489	0.490	0.492	ft³/min	
Dry Gas Sampling Rate	0.373	0.369	0.371	0.371	dscfm	
Reynolds Number	2802.09	2740.48	2748.34	2,763.64		
Recalculated Cunninham	1.079	1.077	1.078	1.078		
Dia. of 50% Prob. (D50) CI	10.45	10.60	10.58	10.54		
Recalculated D50-1 for CIV	2.31	2.37	2.36	2.35		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Δp	0	0	0	0	points	

Nomenclature

- %CO = carbon monoxide concentration (%)
- $\%CO_2$ = carbon dioxide concentration (%)
- $\%N_2$ = nitrogen concentration (%)
- $\%O_2$ = oxygen concentration (%)
- $\%O_{2,wet}$ = Oxygen content of gas stream, % by volume of wet gas. (Note: The oxygen percentage used in Method 201A, Equation 3 is on a wet gas basis. That means that since oxygen is typically measured on a dry gas basis, the measured percent O2 must be multiplied by the quantity $(1 - B_{ws})$ to convert to the actual volume fraction. Therefore, $\%O_{2,wet} = (1 - B_{ws}) * \%O_{2, dry}$)
- $(\%EA)_{avg}$ = average excess air (%)
- $(F_o)_{avg}$ = average calculated fuel factor
- $[(\Delta p)^{0.5}]_{avg}$ = Average of square roots of the velocity pressures measured during the preliminary traverse, inches W.C.
- μ = Gas viscosity, micropoise
- 12.0 = Constant calculated as 60 percent of 20.5 square inch cross-sectional area of combined cyclone head, square inches
- 17.03 = mg/milliequivalents for ammonium ion
- 22.4 = liters of ideal gas per lb-mol of substance at 0^oC and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 24.04 = liters of ideal gas per lb-mol of substance at 20^oC and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 5.02×10^4 = constant derived from the molecular weight and correcting standard temperature and pressure (ref. Bay Area Air Quality Management District, Source Test Procedure ST-1B, Ammonia Integrated Sampling, Adopted January 20, 1982, Regulation 7-303)
- A = distance upstream (in.)
- A_D = stack diameters upstream (dia.)
- An = Area of nozzle, square feet
- A_s = area of stack (ft^2)
- B = distance downstream (in.)
- B_D = stack diameters downstream (dia.)
- b_f = Average blockage factor calculated in Equation 26, dimensionless
- B_{wm} = meter moisture content (%)
- B_{ws} = stack moisture content (%)
- C = Cunningham correction factor for particle diameter, Dp, and calculated using the actual stack gas temperature, dimensionless
- C_1 = -150.3162 (micropoise)
- C_2 = 18.0614 (micropoise/$K^{0.5}$) = 13.4622 (micropoise/$R^{0.5}$)
- C_3 = 1.19183×10^6 (micropoise/K^2) = 3.86153×10^6 (micropoise/R^2)
- C_4 = 0.591123 (micropoise)
- C_5 = 91.9723 (micropoise)
- C_6 = 4.91705×10^{-5} (micropoise/K^2) = 1.51761×10^{-5} (micropoise/R^2)
- C_a = Acetone blank concentration, mg/mg
- C_b = Concentration of NH3 ion in the back half of train (breakthrough)
- C_f = Concentration of NH3 ion in the front half of train (main catch)
- C_{fPM10} = Conc. of filterable PM_{10}, gr/dscf
- $C_{fPM2.5}$ = Conc. of filterable $PM_{2.5}$, gr/dscf
- C_k = K Factor Constant, 849.8

Nomenclature

- C_n = nozzle diameter constant, 0.03575
- C_p' = Coefficient for the pitot used in the preliminary traverse, dimensionless
- C_p = Pitot coefficient for the combined cyclone pitot, dimensionless
- C_{cpm} = Concentration of the condensable PM in the stack gas, dry basis, corrected to standard conditions, milligrams/dry standard cubic foot.
- C_r = Re-estimated Cunningham correction factor for particle diameter equivalent to the actual cut size diameter and calculated using the actual stack gas temperature, dimensionless
- D_{50} = Particle cut diameter, micrometers
- $D_{50(N+1)}$ = D_{50} value for cyclone IV calculated during the N+1 iterative step, micrometers
- D_{50-1} = Re-calculated particle cut diameters based on re-estimated C_r, micrometers
- D_{50LL} = Cut diameter for cyclone I corresponding to the 2.25 micrometer cut diameter for cyclone IV, micrometer
- D_{50N} = D_{50} value for cyclone IV calculated during the Nth iterative step, micrometers
- D_{50T} = Cyclone I cut diameter corresponding to the middle of the overlap zone shown in Method 201A, Figure 10 of Section 17, micrometers
- D_e = equivalent stack diameter (in.)
- ΔH@ = ΔH @ 0.75 scfm (in. H2O)
- ΔH_{avg} = average orifice pressure (in. H_2O)
- D_n = Inner diameter of sampling nozzle mounted on Cyclone I, inches
- D_{na} = actual nozzle diameter (in.)
- D_p = Physical particle size, micrometers
- Δp = velocity head (in. H_2O)
- Δp_1 = velocity head at first current traverse point (in. H_2O)
- $\Delta p'_1$ = velocity head at first preliminary traverse point (in. H_2O)
- Δp_{avg} = average pitot tube differential pressure (in. H_2O)
- Δp_n = velocity head at subsequent current traverse point (in. H_2O)
- Δp_{RM2} = method 2 velocity head (in. H_2O)
- D_s = diameter of stack (in.)
- F_d = fuel f-factor (dscf/MMBtu)
- f_{O2} = stack gas fraction of O_2, by volume, dry basis
- I = Percent isokinetic sampling, dimensionless
- K_1 = standard volume correction, 17.65^{o}R/in. Hg
- K_4 = isokinetic conversion constant, 0.0945min•in.Hg/sec•^{o}R
- K_5 = water mass to std water vapor, 0.04715 ft^3/g
- K_p = 85.49, ((ft/sec)/(pounds/mole -^{o}R))
- L = length of stack (in.)
- L_{fw} = distance to far wall of stack (in.)
- L_{nw} = distance to near wall of stack (in.) [reference]
- $m_{\#x}$ = weight measurements (g)
- M_1 = Milligrams of PM collected on the filter, less than or equal to 2.5 micrometers
- M_2 = Milligrams of PM recovered from Container #2 (acetone blank corrected), greater than 10 micrometers
- M_3 = Milligrams of PM recovered from Container #3 (acetone blank corrected), less than or equal to 10 and greater than 2.5 micrometers
- M_4 = Milligrams of PM recovered from Container #4 (acetone blank corrected), less than or equal to 2.5 micrometers

Nomenclature

- m_a = Mass of residue of acetone after evaporation, mg
- m_c = Mass of the NH4+ added to sample to form ammonium sulfate, mg
- m_{cpm} = Mass of the total condensable PM, mg
- M_d = Molecular weight of dry gas, pounds/pound mole
- m_{fb} = Mass of total CPM in field train recovery blank, mg
- m_{fx} = final weight, avg of last two measurements (g)
- mg = Milligram
- mg/L = Milligram per liter
- m_i = Mass of inorganic CPM, mg
- m_{ib} = Mass of inorganic CPM in field train recovery blank, mg
- M_n = total particulates (mg)
- m_o = Mass of organic CPM, mg
- m_{ob} = Mass of organic CPM in field train blank, mg
- m_r = Mass of dried sample from inorganic fraction, mg
- m_{tx} = tare weight (g)
- MW = molecular weight (lb/lb-mole)
- M_w = Molecular weight of wet gas, pounds/pound mole
- N = Normality of ammonium hydroxide titrant
- N_a = null angle (deg.)
- N_{re} = Reynolds number, dimensionless
- N_{tp} = Number of iterative steps or total traverse points
- P_b = P_{bar} = barometric pressure (in. Hg)
- P_{bar} = barometric pressure (in. Hg)
- ppmCO = carbon monoxide concentration (ppm)
- ppmv = Parts per million by volume
- ppmw = Parts per million by weight
- P_s = absolute stack pressure (in. Hg)
- P_{static} = static pressure (in. H_2O)
- P_{std} = standard pressure, 29.92 in. Hg
- Θ = total sampling time (min)
- Q_{aw} = average stack wet flow rate (ascf/min)
- Q_I = Sampling rate for cyclone I to achieve specified D_{50}
- Q_m = estimated orifice flow rate, 0.750 acfm, else Vm/Q from previous run
- Q_s = Sampling rate for cyclone I to achieve specified D_{50}
- $Q_{s(std)}$ = total cyclone flow rate at standard conditions (dscf/min)
- Q_{sd} = dry standard stack flow rate (dscfm)
- Q_{sST} = Dry gas sampling rate through the sampling assembly, dscfm
- Q_{sw} = wet standard stack flow rate (ascfm)
- R_{max} = Nozzle/stack velocity ratio parameter, dimensionless
- R_{min} = Nozzle/stack velocity ratio parameter, dimensionless
- t_1 = Sampling time at point 1, min
- t_m = average gas meter temperature (^oF)
- t_m = average meter temperature (^oF)
- T_m = Meter box and orifice gas temperature, ^oR
- t_n = Sampling time at point n, min

Nomenclature

- t_r = Total projected run time, min
- T_s = Absolute stack gas temperature, ^oR
- T_{std} = standard temperature, 68^oF, 528^oR
- T_u = absolute temperature offset, 460^oR
- V_a = Volume of acetone blank, ml
- V_{aw} = Volume of acetone used in sample recovery wash, ml
- V_b = Volume of aliquot taken for IC analysis, ml
- V_c = Quantity of water captured in impingers and silica gel, ml
- V_f = final impinger volume (ml)
- V_i = initial impinger volume (ml)
- V_{ic} = Volume of impinger contents sample, ml
- V_m = Dry gas meter volume sampled, acf
- $V_{m(std)}$ = standard meter volume (dscf)
- v_{max} = Maximum gas velocity calculated from Equations 18 or 19, ft/sec
- v_{max} = maximum nozzle velocity (ft/sec)
- V_{mf} = final dry gas meter reading (dcf)
- V_{mi} = initial dry gas meter reading (dcf)
- v_{min} = Minimum gas velocity calculated from Method 201A, Equations 16 or 17, ft/sec
- V_{ms} = Dry gas meter volume sampled, corrected to standard conditions, dscf
- v_n = Sample gas velocity in the nozzle, ft/sec
- v_{org} = organics wash volume (ml)
- V_p = Volume of water added during train purge
- v_s = average stack gas velocity (ft/sec)
- v_{sl} = local velocity (ft/sec)
- V_t = total impinger volume (ml) = ;(V_f-V_i)
- V_t = Volume of NH4OH titrant, ml
- $V_{w(std)}$ = volume of water vapor in gas sample at standard conditions (scf)
- v_x = blank volume (ml)
- W = width of stack (in.)
- $W_{2,3,4}$ = Weight of PM recovered from Containers #2, #3, and #4, mg
- W_a = Weight of blank residue in acetone used to recover samples, mg
- W_f = final impinger weight (g)
- W_i = initial impinger weight (g)
- W_t = total impinger weight (g) = ;(W_f-W_i)
- w_x = blank weight of solids (g)
- Y = meter calibration factor (a.k.a gamma)
- Z = Ratio between estimated cyclone IV D_{50} values, dimensionless
- γ = Dry gas meter gamma value, dimensionless
- ΔH = Meter box orifice pressure drop, inches W.C.
- ΔH@ = Pressure drop across orifice at flow rate of 0.75 scfm at standard conditions, inches W.C. (Note: Specific to each orifice and meter box.)
- Δp_1 = Velocity pressure measured at point 1, inches W.C.
- Δp_{avg} = Average velocity pressure, inches W.C.
- Δp_m = Observed velocity pressure using S-type pitot tube in preliminary traverse, inches W.C.
- Δp_{max} = Maximum velocity pressure, inches W.C.

Nomenclature

- Δp_{min} = Minimum velocity pressure, inches W.C.
- Δp_n = Velocity pressure measured at point n during the test run, inches W.C.
- Δp_s = Velocity pressure calculated in Method 201a, Equation 25, inches W.C.
- Δp_{s1} = Velocity pressure adjusted for combined cyclone pitot tube, inches W.C.
- Δp_{s2} = Velocity pressure corrected for blockage, inches W.C.
- θ = Total run time, min
- ρ_a = Density of acetone, mg/ml (see label on bottle)
- Σ_n = total number of sampling points

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]

Carbon Monoxide Concentration (%)

$$\%CO = \frac{ppmCO}{10{,}000}$$

$$\%CO\ (\%) = \frac{0.00 \quad ppm}{10{,}000\ ppm/\%} = 0.0000\ \%$$

Nitrogen Concentration (%)

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$\%N_2$ (%) = 100 - 4.90 % - 12.70 % - 0.00 / 10,000 % = 82.4 %

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d\,(lb/lb-mol) = \sum\left(\frac{MW_{comp}}{100} \times \%component\right)$$

M_d (lb/lb-mol) = ($\frac{44 \text{ lb/lb-mol}}{100}$ x 4.90 %) +

($\frac{32 \text{ lb/lb-mol}}{100}$ x 12.70 %) + ($\frac{28 \text{ lb/lb-mol}}{100}$ x [$\frac{0.00}{10{,}000}$ + 82.40]) = $\frac{29.29 \text{ lb}}{\text{lb-mol}}$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_S\,(lb/lb-mol) = \left[M_d \times \left(1 - \frac{B_{WS}}{100}\right)\right] + \left[MW_{H_2O} \times \frac{B_{WS}}{100}\right]$$

M_S (lb/lb-mol) = { $\frac{29.29 \text{ lb}}{\text{lb-mol}}$ x (1 - $\frac{8.39 \%}{100}$) } + { $\frac{18 \text{ lb}}{\text{lb-mol}}$ x $\frac{8.39 \%}{100}$ } = $\frac{28.35 \text{ lb}}{\text{lb-mol}}$

Average Calculated Fuel Factor (F_o)

$$F_{o(avg)} = \frac{\left[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$F_{o(avg)}$ = $\frac{20.9\% - 12.70\ \% - (0.5 \text{ x } 0.000\ \%)}{4.90\ \% + 0.000\ \%}$ = 1.673

Average Excess Air (%)

$$\%EA_{avg}\,(\%) = \frac{100 \times \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(0.264 \times (N_2)_{avg}) - \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}$$

$(\%EA)_{AVG}$ = $\frac{100 \text{ x } \{ \ 12.70\ \% - (0.5 \text{ x } 0.000\ \%) \}}{(\ 0.264 \text{ x } 82.40\ \%) - \{\ 12.70\ \% - (0.5 \text{ x } 0.000\ \%)\}}$ = 140.28 %

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]

Absolute Stack Pressure (in. Hg)

$$P_S\,(in.Hg) = P_b + \frac{P_{static}}{13.6}$$

P_s (in. Hg) = 30.30 in. Hg + $\frac{\text{-0.89 in. } H_2O}{\text{13.6 in. } H_2O/\text{in. Hg}}$ = 30.23 in. Hg

Average Stack Gas Velocity (ft/sec)

$$v_s\,(ft/\sec) = K_p \times C_p \times \left(\sqrt{\Delta p}\right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

v_{sl} (ft/sec) =

$\left(\frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\text{sec } (^oR)(\text{in. } H_2O)}\right)^{1/2}$ x 0.72 x 1.19 in.$H_2O^{1/2}$ x $\sqrt{\frac{189.67 + 460\ ^oR}{30.23 \text{ in. Hg x } 28.35 \text{ lb/lb-mol}}}$ = $\frac{63.9 \text{ ft}}{\text{sec}}$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd}\,(dscfh) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sd} (dscf/hr) = $\frac{3600 \text{ sec}}{\text{hr}}$ x (1 - $\frac{8.39\ \%}{100}$) x $\frac{63.94 \text{ ft}}{\text{sec}}$ x 283.53 ft^2 x $\frac{68.00 + 460\ ^oR}{189.67 + 460\ ^oR}$ x $\frac{30.23 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{49{,}102{,}141.46 \text{ dscf}}{\text{hr}}$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw}\,(acfm) = 60 \times v_s \times A_s$$

Q_{aw} (acf/min) = $\frac{60 \text{ sec}}{\text{min}}$ x $\frac{63.94 \text{ ft}}{\text{sec}}$ x 283.53 ft^2 = $\frac{1{,}087{,}671.38 \text{ acf}}{\text{min}}$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw}\,(ascfh) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sw} (ascf/hr) = $\frac{60 \text{ min}}{\text{hr}}$ x $\frac{1{,}087{,}671.38 \text{ acf}}{\text{min}}$ x $\frac{68.00 + 460\ ^oR}{189.67 + 460\ ^oR}$ x $\frac{30.23 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{53{,}596{,}241.59 \text{ ascf}}{\text{hr}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 195.70 g x 0.04715 ft^3/g = 9.227 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65\ ^\circ R}{\text{in. Hg}} \times 0.97 \times 103.90\ \text{dcf} \times \frac{(30.30\ \text{in. Hg} + \frac{0.46\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}})}{77.33\ ^\circ F + 460\ ^\circ R} = 100.82\ \text{dscf}$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{9.23\ \text{dscf}}{9.23\ \text{dscf} + 100.82\ \text{dscf}} = 8.39\ \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)}(\%) = 100 \times \frac{10^{\left(6.691 - \frac{3144}{t_{s(avg)} + 390.86}\right)}}{P_b + \frac{P_{static}}{13.6}} \leq 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left(6.691 - \frac{3144}{189.67\ ^\circ F + 390.86}\right)}}{30.30\ \text{in. Hg} + \frac{-0.89\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}}} \leq 100 = 62.33\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Desired Orifice (in. H_2O) (first point)

$$\Delta H_d\,(in.H_2O) = K \times \Delta p$$

ΔH_d (in. H_2O) = x

in. H_2O = in. H_2O

Absolute Meter Pressure (in. Hg)

$$P_m\,(in.Hg) = P_b + \frac{\Delta H @}{13.6}$$

P_m (in. Hg) = 30.30 in. Hg + $\frac{1.88 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.44 in. Hg

Recommended Nozzle Diameter (in.)

$$D_{ni}\,(in.) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}}\right)} \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}{P_s \times \Delta p_{avg}}\right]}$$

D_{ni} (in.) = $\sqrt{\frac{0.03575 \text{ (lb-mole•°R•in. } H_2O)^{1/2}\text{•min•in.}^2}{\text{acf•in. Hg}^{3/4}\text{•lb}^{1/2}} \text{ x } 0.75 \text{ acf x } 30.44 \text{ in. Hg } \left(1 - \frac{0.00\ \%}{100}\right) \text{ x } \left(\frac{1 - \frac{0.00\ \%}{100}}{1 - \frac{8.39\ \%}{100}}\right) \text{ x } \left(\frac{77.33 \text{ °F} + 460\text{°R}}{0.72}\right) \text{ x } \left(189.67 \text{ °F} + 460\text{°R}\right) \text{ x } \frac{\frac{29.29 \text{ lb}}{\text{lb-mole}} \text{ x } \left(1 - \frac{8.39\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{8.39\ \%}{100}\right)}{30.23 \text{ in. Hg x } 1.19 \text{ in. } H_2O}}$ = 0.218 in.

ΔP to ΔH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H @ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100}\right) + \left(18 \times \frac{B_{wm}}{100}\right)}{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}\right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}}\right)^2 \times \left(\frac{t_m + T_u}{ts + T_u}\right) \times \frac{P_s}{P_m}$$

K = $\frac{849.8}{\text{in. } H_2O\text{•in.}^4}$ x 0.72 ^{2} x 1.88 in. H_2O x 0.16 ^{4} x $\left(\frac{1 - \frac{8.39\ \%}{100}}{1 - \frac{0.00\ \%}{100}}\right)^2$ x $\frac{77.33 \text{ °F} + 460\text{°R}}{189.67 \text{ °F} + 460\text{°R}}$) x ($\frac{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{0.00\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{0.00\ \%}{100}\right)}{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{8.39\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{8.39\ \%}{100}\right)}$ x $\frac{30.23 \text{ in. Hg}}{30.44 \text{ in. Hg}}$ = 0.35

Percent Isokinetic (%) (first point)

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

I (%) = $\frac{0.0945 \text{ min•in. Hg}}{\text{sec•°R}}$ x (191.00 °F + 460 °R) x 8.41 dscf

$\frac{}{22.50 \text{ min x } \frac{63.83 \text{ ft}}{\text{sec}} \text{ x } 30.23 \text{ in. Hg x } 3.14 \text{ x } \left(\frac{0.16 \text{ in.}}{2} \text{ x } \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \text{ x } \left(1 - \frac{8.39\ \%}{100}\right)}$ = 97.99 %

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Cumulative Percent Isokinetic (%) (weighted average of all points)

$$I(\%) = \sum_{1-n} \frac{\left[I(\%) \times V_{m(std)}\right]_{1-n}}{V_{m(std)_{1-n}}}$$

Using Method 5, Eq 5-8 to determine intermediate isokinetics at each point, weighted averaging of the cumulative isokinetics is necessary since all points are not equal, and determined by using the dry standard meter volume collected at each point to weight the cumulative average. Intermediate isokinetics and dry standard meter volumes are found at each point. At each point the cumulative sum is found of each value and the quotient of the two used to determine the cumulative isokinetics for each residual point (n).

Pt	In (%)	x	Vm(std)n	=	I (%)n	∑(I (%)n)	/	∑(Vm(std)n)	=	I (%)
A-1	97.99	x	8.410	=	824.08	824.08	/	8.41	=	98.0
A-2	96.71	x	8.306	=	803.28	1627.35	/	16.72	=	97.3
A-3	94.83	x	7.506	=	711.79	2339.14	/	24.22	=	96.6
B-1	102.98	x	9.461	=	974.30	3313.44	/	33.68	=	98.4
B-2	94.42	x	8.122	=	766.87	4080.31	/	41.81	=	97.6
B-3	95.04	x	8.170	=	776.44	4856.75	/	49.98	=	97.2
C-1	101.69	x	8.043	=	817.88	5674.63	/	58.02	=	97.8
C-2	96.79	x	8.886	=	860.06	6534.69	/	66.90	=	97.7
C-3	96.92	x	8.325	=	806.84	7341.53	/	75.23	=	97.6
D-1	91.52	x	8.415	=	770.17	8111.70	/	83.64	=	97.0
D-2	98.83	x	8.489	=	839.01	8950.71	/	92.13	=	97.1
D-3	100.83	x	8.668	=	873.96	9824.67	/	100.80	=>	97.5

Last Pt

Percent Isokinetic (%) (intermediate equation, all points)
[equivalent to taking an average of point-by-point isokinetics without weighting the average (e.g. all points equal)]

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I(\%) = \frac{\frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^{\circ}\text{R}} \times (189.67\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times 100.82 \text{ dscf}}{270.25 \text{ min} \times \frac{63.94 \text{ ft}}{\text{sec}} \times 30.23 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \times \left(1 - \frac{8.39\ \%}{100}\right)} = 97.43\ \%$$

Raw Data Percent Isokinetic (%)
[utilizes the raw data equation for isokinetics from Method 5]

$$I(\%) = \frac{100\left((t_s)_{avg} + T_u\right)\left[K_4 V_{1c} + \frac{V_m Y}{(t_m)_{avg} + T_u}\left(P_{bar} + \frac{\Delta H}{13.6}\right)\right]}{60\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right)}$$

$$I(\%) = \frac{100 \times (189.67\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times \left[\frac{0.002669 \text{ ft}^3\text{•in. Hg}}{\text{ml•}^{\circ}\text{R}} \times 196.1 \text{ ml} + \frac{103.90 \text{ dcf} \times 0.974}{77.33\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}} \left(30.30 \text{ in Hg} + \frac{1.186}{13.6}\right)\right]}{60 \times 270.25 \text{ min} \times \frac{63.94 \text{ ft}}{\text{sec}} \times 30.23 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2} = 97.54\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Gravimetric Analysis) [Values from Run 1 test]

Blank Concentration [Acetone Blank Weight of Solids] (mg/ml)

$$C_x(mg/ml) = \frac{1000 \times w_x}{v_x}$$

C_x (mg/ml) = $\frac{1000\ mg}{g}$ x $\frac{0.0000\ g}{200.60\ ml}$ = $\frac{0.0000\ mg}{ml}$ = $\frac{\quad mg}{ml}$

Blank Adjustment [Acetone Blank Weight of Solids and Nozzle Wash PM>10] (mg)

$$W_x(mg) = v_x \times C_x$$

W_x (mg) = 61 ml x 0.0000 mg/ml = 0.00 mg < Sample Gain

Sample Gain [Nozzle Wash PM>10] (mg)

$$m_x(mg) = \left(m_{fx} - m_{tx}\right) \times 1000$$

m_x (mg) = $\frac{1000\ mg}{g}$ x (0.0091 g - 0.00 g) = 9.10 mg

Adjusted Sample Gain [Nozzle Wash PM>10] (mg)

$$m_{xadj}(mg) = m_x - W_x$$

m_{xadj} (mg) = 9.1 mg - 0.00 mg = 9.10 mg

0.1N NH_4OH Correction (mg)

$$m_c(mg) = 17.03 \times V_t \times N$$

m_c (mg) = 17.03 x 0.00 ml x 0.1 N = 0.00 mg

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - Total PM_{10} Mass]

Stack Total Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s \text{ (g/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{9.10 mg}}{\text{100.82 dscf}} = \frac{\text{9.03E-05 g}}{\text{dscf}}$$

Stack Total Concentration (gr/dscf)

$$c_s'(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s \text{ (gr/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{9.10 mg}}{\text{100.82 dscf}} \times \frac{\text{7000 gr}}{\text{lb}} \times \frac{\text{lb}}{\text{453.592 g}} = \frac{\text{1.39E-03 gr}}{\text{dscf}}$$

Total Emissions Rate (kg/hr)

$$E(kg/hr) = c_s \times Q_{sd} \times \frac{kg}{1000\ g}$$

$$E \text{ (kg/hr)} = \frac{\text{kg}}{\text{1000 g}} \times \frac{\text{9.03E-05 g}}{\text{dscf}} \times \frac{\text{49,102,141 dscf}}{\text{hr}} = \frac{\text{4.43 kg}}{\text{hr}}$$

Total Emissions Rate (lb/hr)

$$E'(lb/hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{lb \times g}{453.592g \times 1000mg}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{9.10 mg}}{\text{100.82 dscf}} \times \frac{\text{49,102,141 dscf}}{\text{hr}} = \frac{\text{9.77 lb}}{\text{hr}}$$

Total Emissions Rate (tpy)

$$E''(ton/yr) = E' \times \frac{8760}{2000}$$

$$E'' \text{ (tpy)} = \frac{\text{ton}}{\text{2000 lb}} \times \frac{\text{8,760 hr}}{\text{yr}} \times \frac{\text{9.77 lb}}{\text{hr}} = \frac{\text{42.80 ton}}{\text{yr}}$$

Total Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{9.10 mg}}{\text{100.82 dscf}} \times \frac{\text{8,638.42 dscf}}{\text{MMBtu}} \times \left(\frac{\text{20.9}}{\text{20.9 - 12.7 \%}}\right) = \frac{\text{0.0044 lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Stack Gas Viscosity (μP) [based on preliminary data] [RM 201A, Eq. 3]

$$\mu(\mu P) = C_1 + C_2\sqrt{T_s} + C_3 T_s^{-2} + C4(\%O_{2,wet}) - C_5 B_{ws} + C_6 B_{ws} T_s^2$$

μ (μP) = -150.3162 μP + 13.4622 $\sqrt{\quad 187 \quad + 460}$ + 3.86153x10^{6} (187 + 460)$^{-2}$ + 0.591123 (13.0 x (1 - 8.00 /100) - 91.9723 (8.00 /100) + 1.51761x10^{-5} (8.00 /100)(187 + 460)^2 = 201.52 μP

Cunningham Correction Factor [RM 201A, Eq. 4]
[based on preliminary data for a 2.25 micrometer diameter particle]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{201.52\ \mu P}{30.24\ \text{in Hg} \times 2.25\ \mu m}\right)\left(\frac{187 + 460\ ^{o}R}{28.40\ \text{lb / lb-mole}}\right)^{0.5} = 1.08$$

First calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}<3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 5]
[assumes N_{re}<3,162]

$$D_{50LL}(\mu m) = 9.507 C^{0.3007}\left[\frac{M_w P_s}{T_s}\right]^{0.1993}$$

$$D_{50LL}\ (\mu m) = 9.507 \times 1.08^{\ 0.3007} \times \left(\frac{30.24\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{187 + 460\ ^{o}R}\right)^{0.1993} = 10.30\ \mu m$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}<3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

$$D_{50T}\ (\mu m) = \frac{11 + 10.30\ \mu m}{2} = 10.65\ \mu m$$

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}<3,162]

Qs (acfm) =

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu)\left[\frac{T_s}{M_w P_s}\right]^{0.2949}\left[\frac{1}{D_{50T}}\right]^{1.4102}$$

$$0.07296 \times 201.52\ \mu P \times \left(\frac{187 + 460\ ^{o}R}{30.24\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}\right)^{0.2949} \times \left(\frac{1}{10.65\ \mu m}\right)^{1.4102} = 0.48\ \text{acfm}$$

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5\left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

$$N_{re} = 8.64 \times 10^5 \times \frac{30.24\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{187 + 460\ ^{o}R} \times \frac{0.48\ \text{acfm}}{201.52\ \mu P} = 2739.94 < 3{,}162$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Second calculation set using Cyclone IV, assuming N_{re}<3,162

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (μm) [RM 201A, Eq. 34]
[assumes N_{re}<3,162]

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (μm) =

0.0024302 x (201.52 μP / 0.48 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (187 + 460 °R / 30.24 in Hg x 28.40 lb / lb-mole)$^{0.6790}$ = 2.38 μm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Less than 3,162 (acfm) [RM 201A, Eq. 8]

$$Q_{IV}(acfm) = 0.0060639 \left(\frac{\mu}{C^{0.4242}}\right) \left[\frac{P_s M_w}{T_s}\right]^{-.05759} \left[\frac{1}{D_{50}}\right]^{0.8481}$$

Q_{IV} (acfm) =

0.0060639 x (201.52 μP / 1.08 $^{0.4242}$) x (30.24 in Hg x 28.40 lb / lb-mole / 187 + 460 °R)$^{-0.5759}$ x (1 / 2.38 μm)$^{0.8481}$ = 0.48 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

N_{re} = 8.64 x 10^5 x 30.24 in Hg x 28.40 lb / lb-mole / 187 + 460 °R x 0.48 acfm / 201.52 μP = 2739.90 < 3,162

Third calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}≥3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 12]
[assumes N_{re}≥3,162]

$$D_{50LL}(\mu m) = 10.0959 C^{0.4400} \left[\frac{M_w P_s}{T_s}\right]^{0.0600}$$

D_{50LL} (μm) = 10.0959 x 1.08 $^{0.4400}$ x (30.24 in Hg x 28.40 lb / lb-mole / 187 + 460 °R)$^{0.0600}$ = 10.63 μm

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}≥3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

D_{50T} (μm) = (11 + 10.63 μm) / 2 = 10.81 μm

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}≥3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu) \left[\frac{T_s}{M_w P_s}\right]^{0.2949} \left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

0.07296 x 201.52 μP x (187 + 460 °R / 30.24 in Hg x 28.40 lb / lb-mole)$^{0.2949}$ x (1 / 10.81 μm)$^{1.4102}$ = 0.47 acfm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (30.24 in Hg x 28.40 lb / lb-mole) / (187 + 460 °R) x (0.47 acfm) / (201.52 µP) = 2681.40 < 3,162

Fourth calculation set using Cyclone IV, assuming N_{re}≥3,162

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]
[assumes N_{re}≥3,162]

D_{50} (µm) =

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

0.019723 x (201.52 µP / 0.47 acfm)$^{0.8058}$ x (1 / 1.08)$^{0.5}$
x (187 + 460 °R / 30.24 in Hg x 28.40 lb / lb-mole)$^{0.3058}$ = 2.29 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Greater than or Equal to 3,162 (acfm) [RM 201A, Eq. 9]

Q_{IV} (acfm) =

$$Q_{IV}(acfm) = 0.007657 \left(\frac{\mu}{C^{0.6205}}\right)\left[\frac{P_s M_w}{T_s}\right]^{-0.3795} \left[\frac{1}{D_{50}}\right]^{1.241}$$

0.007657 x (201.52 µP / 1.08 $^{0.6205}$) x (30.24 in Hg x 28.40 lb / lb-mole / 187 + 460 °R)$^{-0.3795}$
x (1 / 2.29 µm)$^{1.241}$ = 0.47 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (30.24 in Hg x 28.40 lb / lb-mole) / (187 + 460 °R) x (0.48 acfm) / (201.52 µP) = 2739.94 < 3,162

Meter Box Orifice Pressure Drop (in H_2O) [RM 201A, Eq. 11]
As calculated using applicable calculation set 1, 2, 3, or 4

$$\Delta H(inH_2O) = \left[\frac{Q_s(1 - B_{ws})P_s}{T_s}\right]^2 \left[\frac{1.083 T_m M_d \Delta H_@}{P_{bar}}\right]$$

ΔH (in H_2O) = (0.48 acfm x (1 - 8.00 /100) x 30.24 in Hg / 187 + 460 °R)^2
x (1.083 x (85.00 + 460 °R) x 29.30 lb / lb-mole x 1.878 in H_2O / 30.31 in Hg) = 0.459 in H_2O

50 °F above stack temperature	T_{s+50} =	237	ΔH_{+50} =	0.396 in H_2O
50 °F below stack temperature	T_{s+50} =	137	ΔH_{+50} =	0.539 in H_2O

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Adjusted Velocity Pressure (in H_2O) [point A-1] [RM201A, Eq. 25]

$$\Delta p_s(inH_2O) = \Delta p_m\left[\frac{C_p}{C'_p}\right]^2$$

Δp_s (in H_2O) = 1.50 in H_2O x (0.7240 / 0.8198)^2 = 1.17 in H_2O

Average Probe Blockage Factor [RM201A, Eq. 26]

$$b_f = \frac{22.0}{A}$$

b_f = 22.0 / 40828.14 in^2 = 5.39E-04

Velocity Pressure Adjusted for Blockage Factor (in H_2O) [point A-1] [RM201A, Eq. 27]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$\Delta p_{s2}(inH_2O) = \Delta p_{s1}\left[\frac{1}{(1-b_f)}\right]^2$$

Δp_s (in H_2O) = 1.17 in H_2O x (1 / (1 - 0.00E+00))^2 = 1.17 in H_2O

Velocity of Stack Gas Adjusted for Blockage Factor and/or C_p / C'_p (ft/sec) [RM201A, Eq. 13]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$v_s = K_p C_p \left(\sqrt{(\Delta p)}\right)_{avg}\left[\sqrt{\frac{T_s}{P_s M_w}}\right]$$

v_s (ft/sec) =

85.49 ft/sec / lb/mole - °R x 0.7240 x 1.06 x (187 + 460 °R / 30.24 in Hg x 28.40 lb / lb-mole)$^{0.5}$ = 56.77 ft/sec

Calculated Nozzle Diameter for Acceptable Sampling Rate (in) [RM201A, Eq. 14]

$$D(in) = \left[\frac{3.056 Q_s}{v_s}\right]^{0.5}$$

D (in) = (3.056 x 0.48 acfm / 56.77 ft/sec)$^{0.5}$ = 0.161 in

Represents ideal diameter, which we then compare to capabilities of all nozzles from multiple sets

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Velocity of Gas in Nozzle 4b (diam. = 0.156 in), (ft/sec) [RM201A, Eq. 15]

v_n (ft/sec) = $\frac{0.48 \text{ acfm}}{60 \text{ min / sec}} \div 1.33\text{E-}04 \text{ ft}^2$ = 60.43 $\frac{\text{ft}}{\text{sec}}$

Example set of calculations for nozzle used with run 1

$$v_n = \frac{\left(\frac{Q_s}{60 \frac{\text{min}}{\text{sec}}}\right)}{A_n}$$

Minimum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 16]

Nozzle 4b (diam. = 0.156 in)

$$R_{min} = \left[0.2457 + \left(0.3072 - \frac{0.2603(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{min} =

$0.2457 + (0.3072 - \frac{0.2603 \text{ x } 201.52 \text{ µP x } (0.48 \text{ acfm})^{0.5}}{60.43 \text{ in}^{1.5}})^{0.5}$ = 0.73

Maximum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 17]

Nozzle 4b (diam. = 0.156 in)

$$R_{max} = \left[0.4457 + \left(0.5690 + \frac{0.2603(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{max} =

$0.4457 + (0.5690 + \frac{0.2603 \text{ x } 201.52 \text{ µP x } (0.48 \text{ acfm})^{0.5}}{60.43 \text{ in}^{1.5}})^{0.5}$ = 1.25

Minimum Gas Velocity for R_{min} Less than 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{min}\ (ft/sec) = v_n(0.5)$ **[RM201A, Eq. 18]**

v_{min} (ft/sec) = 0.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ Not Applicable

Minimum Gas Velocity for R_{min} Greater than or Equal to 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{min}\ (ft/sec) = v_n R_{min}$ **[RM201A, Eq. 19]**

v_{min} (ft/sec) = 60.43 $\frac{\text{ft}}{\text{sec}}$ x 0.73 = 43.81 $\frac{\text{ft}}{\text{sec}}$

Maximum Gas Velocity for R_{max} Less than 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{max}\ (ft/sec) = v_n R_{max}$ **[RM201A, Eq. 20]**

v_{max} (ft/sec) = 60.43 $\frac{\text{ft}}{\text{sec}}$ x 1.25 = 75.52 $\frac{\text{ft}}{\text{sec}}$

Maximum Gas Velocity for R_{max} Greater than or Equal to 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{max}\ (ft/sec) = v_n(1.5)$ **[RM201A, Eq. 21]**

v_{max} (ft/sec) = 1.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ Not Applicable

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Minimum Velocity Pressure (in H_2O) [RM201A, Eq. 22] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{min} below preliminary data minimum

$$\Delta p_{min}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{min}}{C_p}\right]^2$$

Δp_{min} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{30.24 \text{ in Hg} \times 28.40 \text{ lb / lb-mole}}{187 + 460\ ^{o}R}\right) \times \left(\frac{43.81 \text{ ft/sec}}{0.7240}\right)^2 =$ 0.67 in H_2O vs. 1.01

Maximum Velocity Pressure (in H_2O) [RM201A, Eq. 23] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{max} above preliminary data maximum

$$\Delta p_{max}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{max}}{C_p}\right]^2$$

Δp_{max} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{30.24 \text{ in Hg} \times 28.40 \text{ lb / lb-mole}}{187 + 460\ ^{o}R}\right) \times \left(\frac{75.52 \text{ ft/sec}}{0.7240}\right)^2 =$ 1.98 in H_2O vs. 1.25

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sampling Dwell Time at Each Point (minutes) [point A-1] [RM201A, Eq. 24]

$$t_n(\text{min}) = \left[\frac{C_p\sqrt{\Delta p_n}}{C_p'\left(\sqrt{\Delta p_n}\right)_{avg}}\right]\left[\frac{t_r}{N_{tp}}\right]$$

t_n (min) = $\left(\frac{0.7240 \times (1.40)^{0.5}}{0.7240 \times 1.06}\right) \times \left(\frac{240.00 \text{ min}}{12.00}\right) =$ 22.39 minutes

Dry Gas Volume Sampled at Standard Conditions (dscf) [point A-1] [RM201A, Eq. 28]

$$v_{ms}(dscf) = \left[\frac{528}{29.92}\right]\left[\gamma \cdot v_m\right]\left[\frac{\left(P_{bar} + \frac{\Delta H}{13.6}\right)}{T_m}\right]$$

v_{ms} (dscf) = $\left(\frac{528}{29.92}\right)$ (0.974 x 8.42 dcf) x

$\left(\frac{30.30 \text{ in Hg} + 0.46 \text{ in } H_2O / 13.6}{62.00 + 460\ ^{o}R}\right) =$ 8.41 dscf

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sample Flow Rate at Standard Conditions (dscfm) [RM201A, Eq. 29]

$Q_{sST}\ (dscfm) = \frac{v_{ms}}{\Theta}$

Q_{sST} (dscfm) = $\frac{100.82\ \text{dscf}}{270.25\ \text{min}} = \frac{0.37\ \text{dscf}}{\text{min}}$

Sampling Rate (acfm) [e.g. cyclone flow rate] [RM201A, Eq. 32]

$Q_s(acfm) = \frac{29.92}{528} Q_{sST} \left[\frac{1}{(1-B_{ws})}\right]\left[\frac{T_s}{P_s}\right]$

Q_s (acfm) = $\frac{29.92\ \text{in Hg}}{528\ ^{o}\text{R}} \times \frac{0.37\ \text{dscf}}{\text{min}} \times \frac{1}{(1-\ 8.39\ /100)} \times \frac{190\ + 460\ ^{o}\text{R}}{30.23\ \text{in Hg}} =$ 0.50 acfm

Actual Conditions Reynolds Number (dimensionless) [RM 201A, Eq. 10]

$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$

$N_{re} = 8.64 \times 10^5 \times \frac{30.23\ \text{in Hg} \times 28.35\ \text{lb / lb-mole}}{190\ + 460\ ^{o}\text{R}} \times \frac{0.50\ \text{acfm}}{201.67\ \mu\text{P}} =$ 2802.09

Actual Conditions Particle Cut Diameter for Cyclone I (µm) [RM201A, Eq. 33]

$D_{50}\ (\mu m) = 0.15625 \left[\frac{T_s}{M_w P_s}\right]^{0.2091} \left[\frac{\mu}{Q_s}\right]^{0.7091}$

D_{50} (µm) = 0.15625 x $\left(\frac{190\ + 460\ ^{o}\text{R}}{30.23\ \text{in Hg} \times 28.35\ \text{lb / lb-mole}}\right)^{0.2091}$ x $\left(\frac{201.67\ \mu\text{P}}{0.50\ \text{acfm}}\right)^{0.7091} =$ 10.45 µm

Actual Particle Cut Diameter for Cyclone IV is determined by:

Actual Conditions Cunningham Correction Factor [RM 201A, Eq. 4]
[for a 2.5 micrometer diameter particle (estimated size)]

$C = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$

C = 1 + 0.0057193 x $\left(\frac{201.67\ \mu\text{P}}{30.23\ \text{in Hg x 2.5 µm}}\right)\left(\frac{190\ + 460\ ^{o}\text{R}}{28.35\ \text{lb / lb-mole}}\right)^{0.5} =$ 1.07

Actual Conditions Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]

$D_{50}\ (\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$

D_{50} (µm) =

0.0024302 x $\left(\frac{201.67\ \mu\text{P}}{0.50\ \text{acfm}}\right)^{1.1791}$ x $\left(\frac{1}{1.07}\right)^{0.5}$

x $\left(\frac{190\ + 460\ ^{o}\text{R}}{30.23\ \text{in Hg} \times 28.35\ \text{lb / lb-mole}}\right)^{0.6790} =$ 2.32 µm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Actual Conditions Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Re-calculated Cunningham Correction Factor (dimensionless) [RM 201A, Eq. 36]

$$C_r = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x (201.67 µP / 30.23 in Hg x 2.32 µm)(190 + 460 °R / 28.35 lb / lb-mole)$^{0.5}$ = 1.08

Re-calculated Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 37]

$$D_{50-1}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50-1} (µm) =

0.0024302 x (201.67 µP / 0.50 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (190 + 460 °R / 30.23 in Hg x 28.35 lb / lb-mole)$^{0.6790}$ = 2.31 µm

Re-Calculated Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 38]

$$D_{50-1}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50-1} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Ratio (Z) Between D_{50} and D_{50-1} Values (dimensionless) [RM 201A, Eq. 39]

$$Z = \frac{D_{50-1}}{D_{50}} \qquad 0.99 \le \left[Z = \left(\frac{D_{50}}{D_{50-1}}\right)\right] \le 1.01$$

Z = 2.31 µm / 2.31 µm = 1.00

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Historical Data	SAM U-00002 Base-1	SAM U-00002 Base-2	SAM U-00002 Base-3	**Average**	**Units**	**Limits**
Run Start Time	08:06	11:49	15:17		hh:mm	
Run Stop Time	10:06	13:49	17:17		hh:mm	
Test Date	03/09/20	03/09/20	03/09/20		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.985	0.985	0.985			
Stack Test Data	SAM U-00002 Base-1	SAM U-00002 Base-2	SAM U-00002 Base-3	**Average**	**Units**	**Limits**
Initial Meter Volume	892.500	942.200	995.600		ft^3	
Final Meter Volume	935.060	984.610	1038.180		ft^3	
Total Meter Volume	42.560	42.410	42.580	42.517	ft^3	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	87.13	87.92	90.71	88.58	°F	
Barometric Pressure	30.30	29.88	30.12	30.10	in Hg	
Stack Static Pressure	0.95	0.95	0.95	0.95	in H_2O	
Absolute Stack Pressure	30.37	29.95	30.19	30.17	in Hg	
Average Orifice Pressure Drop	0.34	0.34	0.34	0.34	in H_2O	
Absolute Meter Pressure	30.43	30.01	30.25	30.23	in Hg	
Moisture Content Data	SAM U-00002 Base-1	SAM U-00002 Base-2	SAM U-00002 Base-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	63.10	69.90	57.50	63.50	g	
Silica Gel Weight Gain	8.30	12.20	7.30	9.27	g	
Total Water Volume Collected	71.53	82.25	64.92	72.90	ml	
Standard Water Vapor Volume	3.37	3.87	3.06	3.43	scf	
Standard Meter Volume	41.0	40.2	40.5	40.6	dscf	
Standard Metric Meter Volume	1.2	1.1	1.1	1.1	dscm	
Calculated Stack Moisture	7.59	8.78	7.01	7.79	%	
Gas Analysis Data	SAM U-00002 Base-1	SAM U-00002 Base-2	SAM U-00002 Base-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	4.8	4.8	4.8	4.8	%	
Oxygen Content	12.7	12.8	12.8	12.8	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.5	82.4	82.4	82.4	%	
Stack Dry Molecular Weight	29.28	29.28	29.28	29.28	lb/lb-mole	
Calculated Fuel Factor	1.708	1.688	1.688	1.694		
Fuel F-Factor	8638.42	8638.42	8638.42	8638.42	dscf/MMBtu	
Sulfuric Acid Mist IC Analysis	SAM U-00002 Base-1	SAM U-00002 Base-2	SAM U-00002 Base-3	**Average**	**Units**	**Limits**
H_2SO_4 (IC) Sample Volume - Front Half Rinse	201.0	138.0	138.0	159.00	ml	--
H_2SO_4 (IC) Sample - Mass Per Volume	0.1	0.2	0.1	0.14	mg/L	--
H_2SO_4 (IC) Mass	0.02	0.03	0.02	0.02	mg	--
H_2SO_4 (IC) Concentration	5.12E-07	6.96E-07	4.20E-07	5.43E-07	g/dscf	--
	7.90E-06	1.07E-05	6.48E-06	8.37E-06	gr/dscf	--
	1.81E-08	2.46E-08	1.48E-08	1.92E-08	g/L	--
	0.00	0.01	0.00	0.00	ppmvd	--
H_2SO_4 (IC) Emission Rate	0.00002	0.00003	0.00002	0.00003	lb/MMBtu	0.00065

Note: Run 1 reported at the RDL (0.021 mg)

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 71.40 g x 0.04715 ft^3/g = 3.367 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{\frac{17.65\ ^\circ R}{in.\ Hg} \times 0.99 \times 42.56\ dcf \times \left(30.30\ in.\ Hg + \frac{0.34\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{87.13\ ^\circ F + 460\ ^\circ R} = 41.00\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{3.37\ dscf}{3.37\ dscf + 41.00\ dscf} = 7.59\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - H_2SO_4 (IC)]

Stack H_2SO_4 Mass (mg)

$$M_n(mg) = \frac{M_{n(lab)}}{V_{s(lab)}} \times V_{sample} \times \frac{L}{1000ml}$$

M_n (mg) = $\frac{\text{L}}{\text{1000 ml}}$ x 0.10 $\frac{\text{mg}}{\text{L}}$ x 201.00 ml = 0.02 mg

Stack H_2SO_4 Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

c_s (g/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{41.00 dscf}}$ = $\frac{\text{5.10E-07 g}}{\text{dscf}}$

Stack H_2SO_4 Concentration (gr/dscf)

$$c'_s(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

c'$_s$ (gr/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{41.00 dscf}}$ x $\frac{\text{7000 gr}}{\text{lb}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ = $\frac{\text{7.90E-06 gr}}{\text{dscf}}$

Stack H_2SO_4 Concentration (g/L)

$$c''_s(g/L) = c'_s \times \frac{dscf}{28.31685 dsL}$$

c'$_s$ (gr/dscf) = 5.12E-07 $\frac{\text{g}}{\text{dscf}}$ x $\frac{\text{dscf}}{\text{28.31685 dsL}}$ = $\frac{\text{2.00E-08 g}}{\text{L}}$

Stack H_2SO_4 Concentration (ppmvd)

$$c'''_s(ppmvd) = \frac{M_n}{V_{m(std)}} \times Ideal\ Gas\ Constant \times \frac{10^6 parts}{million\ parts} \times \frac{1}{Mol\ Wt}$$

c'''$_s$ (ppmvd) = 1.81E-08 $\frac{\text{g}}{\text{L}}$ x $\frac{\text{24.04 L gas}}{\text{lb-mol}}$ x $\frac{10^6 \text{ parts}}{\text{MM parts}}$ x $\frac{\text{lb-mol}}{\text{98.0790 lb}}$ = 0.004 ppmvd

H_2SO_4 Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

E''' (lb/MMBtu) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ x $\frac{\text{0.02 mg}}{\text{41.00 dscf}}$ x $\frac{\text{8,638.42 dscf}}{\text{MMBtu}}$ x ($\frac{\text{20.9}}{\text{20.9 - 12.7 \%}}$) = $\frac{\text{0.00002 lb}}{\text{MMBtu}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
NOx, CO, VOC, and NH_3

GENERAL ELECTRIC, 7F.05, UNIT #U-00002 BASE+DB LOAD DATA SUMMARY

Parameter	Base+DB Load, Run - 2-1	Base+DB Load, Run - 2-2	Base+DB Load, Run - 2-3	Average
Date (mm/dd/yy)	03/10/20	03/10/20	03/10/20	03/10/20
Start Time (hh:mm:ss)	15:27:20	17:35:20	18:35:20	15:27:20
End Time (hh:mm:ss)	16:26:50	18:34:50	19:34:50	19:34:50
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	30.17	30.15	30.12	30.15
Amb. Temp. (°F)	52	49	46	49
Rel. Humidity (%)	53	70	73	65
Spec. Humidity (lb water / lb air)	0.004296	0.005086	0.004740	0.004707
NH_3 Flow Rate (lb/hr)	151.7	149.8	149.2	150.2
Turbine Fuel Flow (lb/min)	1,625	1,625	1,627	1,626
Duct Burner Fuel Flow (lb/min)	166	171	174	170
Total Fuel Flow (SCFH)	2,431,495	2,438,066	2,444,977	2,438,179
Stack Flow (RM19) (SCFH)	50,273,314	49,918,813	49,882,005	50,024,711
Stack Moisture (% Method 4)	6.7	6.7	6.7	6.7
Heat Input (MMBtu/hr)	2,458.8	2,465.4	2,472.4	2,465.5
CT Power Output (megawatts)	231.8	232.1	232.6	232.1
NOx (ppmvd)	2.44	2.53	2.55	2.51
NOx (ppm@15%O_2)	1.63	1.68	1.68	1.66
CO (ppmvd)	0.21	0.21	0.21	0.21
CO (ppm@15%O_2)	0.14	0.14	0.14	0.14
VOC (as C1) (ppmvd)	0.00	0.00	0.00	0.00
VOC (as C1) (ppm@15%O_2)	0.00	0.00	0.00	0.00
Fuel Sulfur (grains / 100 scf)	0.12	0.12	0.12	0.12
CO_2 (%)	5.07	5.06	5.08	5.07
O_2 (%)	12.07	11.98	11.95	12.00

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Historical Data	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Run Start Time	14:12	06:23	12:30		hh:mm	
Run Stop Time	18:40	11:17	17:15		hh:mm	
Test Date	03/10/20	03/11/20	03/11/20		mm/dd/yy	
Load	Base+DB	Base+DB	Base+DB		% or w/DB	--
Meter Calibration Factor	0.974	0.974	0.974			
Pitot Tube Coefficient	0.7240	0.7240	0.7240			
Average Nozzle Diameter	0.156	0.156	0.156		in	
Stack Test Data	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Initial Meter Volume	675.750	778.770	884.600		ft^3	
Final Meter Volume	777.340	884.310	987.200		ft^3	
Total Meter Volume	101.590	105.540	102.600	103.243	ft^3	
Total Sampling Time	272.25	277.75	275.00	275.00	min	
Average Meter Temperature	87.17	80.67	83.29	83.71	°F	
Average Stack Temperature	189.00	181.50	181.33	183.94	°F	
Barometric Pressure	30.14	30.12	30.11	30.12	in Hg	
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89	in H_2O	
Absolute Stack Pressure	30.07	30.05	30.04	30.06	in Hg	
Average Orifice Pressure Drop	0.44	0.44	0.44	0.44	in H_2O	
Absolute Meter Pressure	30.28	30.26	30.25	30.26	in Hg	
Avg Square Root Pitot Pressure	1.12	1.14	1.13	1.13	$\sqrt{(in\ H_2O)}$	
Moisture Content Data	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	186.30	225.50	210.00	207.27	g	
Silica Gel Weight Gain	19.80	20.50	20.50	20.27	g	
Total Water Volume Collected	206.47	246.44	230.92	227.94	ml	
Standard Water Vapor Volume	9.72	11.60	10.87	10.73	scf	
Standard Meter Volume	96.3	101.2	97.8	98.4	dscf	
Standard Metric Meter Volume	2.7	2.9	2.8	2.8	dscm	
Calculated Stack Moisture	9.17	10.29	10.00	9.82	%	
Saturated Stack Moisture	61.77	52.49	52.31	55.52	%	
Reported Stack Moisture Content	9.17	10.29	10.00	9.82	%	
Gas Analysis Data	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	5.3	5.3	5.3	5.3	%	
Oxygen Content	11.7	11.7	11.7	11.7	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	83.0	83.0	83.0	83.0	%	
Stack Dry Molecular Weight	29.32	29.31	29.31	29.31	lb/lb-mole	
Stack Wet Molecular Weight	28.28	28.15	28.18	28.20	lb/lb-mole	
Calculated Fuel Factor	1.740	1.742	1.746	1.742		
Fuel F-Factor	8638.67	8636.30	8636.30	8637.09	dscf/MMBtu	
Percent Excess Air	114.1	113.9	114.0	114.0	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Volumetric Flow Rate Data	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Average Stack Gas Velocity	60.63	61.62	60.99	61.08	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft²	
Actual Stack Flow Rate	1,031,351	1,048,278	1,037,485	1,039,038	acfm	
Wet Standard Stack Flow Rate	50,604	52,001	51,462	51,356	wkscfh	
Dry Standard Stack Flow Rate	45,965,064	46,652,496	46,317,226	46,311,595	dscfh	
Percent of Isokinetic Rate	98.8	100.2	98.6	99.2	%	
Gravimetric Analysis	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	ml	
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	mg	
Emission Rate Data	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Total PM_{10} Mass	7.80	5.20	8.30	7.10	mg	--
Total PM_{10} Concentration	8.10E-05	5.14E-05	8.48E-05	7.24E-05	g/dscf	--
	1.25E-03	7.93E-04	1.31E-03	1.12E-03	gr/dscf	--
Total PM_{10} Emission Rate	3.72	2.40	3.93	3.35	kg/hr	--
	8.21	5.29	8.66	7.39	lb/hr	--
	35.96	23.16	37.94	32.35	tpy	--
	0.0035	0.0022	0.0037	0.0031	lb/MMBtu	0.006
Filterable PM_{10} Mass	2.90	1.90	1.90	2.23	mg	--
Filterable PM_{10} Concentration	3.01E-05	1.88E-05	1.94E-05	2.28E-05	g/dscf	--
	4.65E-04	2.90E-04	3.00E-04	3.51E-04	gr/dscf	--
Filterable PM_{10} Emission Rate	1.38	0.88	0.90	1.05	kg/hr	--
	3.05	1.93	1.98	2.32	lb/hr	--
	13.37	8.46	8.69	10.17	tpy	--
	0.0013	0.0008	0.0008	0.0010	lb/MMBtu	--
Condensable PM_{10} Mass	4.90	3.30	6.40	4.87	mg	--
Condensable PM_{10} Concentration	5.09E-05	3.26E-05	6.54E-05	4.96E-05	g/dscf	--
	7.85E-04	5.03E-04	1.01E-03	7.66E-04	gr/dscf	--
Condensable PM_{10} Emission Rate	2.34	1.52	3.03	2.30	kg/hr	--
	5.16	3.35	6.68	5.06	lb/hr	--
	22.59	14.69	29.26	22.18	tpy	--
	0.0022	0.0014	0.0028	0.0021	lb/MMBtu	--
RM 201A Quality Control	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Stack Viscosity	200.23	197.41	197.64	198.43	µP	
Cyclone Flow Rate	0.476	0.491	0.478	0.482	ft³/min	
Dry Gas Sampling Rate	0.354	0.364	0.356	0.358	dscfm	
Reynolds Number	2692.23	2834.63	2759.69	2,762.18		
Recalculated Cunninham	1.075	1.078	1.076	1.077		
Dia. of 50% Prob. (D50) CI	10.71	10.36	10.56	10.54		
Recalculated D50-1 for CIV	2.42	2.28	2.36	2.35		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Δp	0	0	0	0	points	

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]

Carbon Monoxide Concentration (%)

$$\%CO = \frac{ppmCO}{10{,}000}$$

$$\%CO\ (\%) = \frac{0.00 \quad ppm}{10{,}000\ ppm/\%} = 0.0000\ \%$$

Nitrogen Concentration (%)

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$\%N_2$ (%) = 100 - 5.30 % - 11.68 % - 0.00 / 10,000 % = 83.02 %

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d\,(lb/lb-mol) = \sum\left(\frac{MW_{comp}}{100} \times \%component\right)$$

$$M_d\ (lb/lb\text{-}mol) = \left(\frac{44\ lb/lb\text{-}mol}{100} \times 5.30\ \%\right) +$$

$$\left(\frac{32\ lb/lb\text{-}mol}{100} \times 11.68\ \%\right) + \left(\frac{28\ lb/lb\text{-}mol}{100} \times \left[\frac{0.00}{10{,}000} + 83.02\ \right]\right) = \frac{29.32\ lb}{lb\text{-}mol}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_S\,(lb/lb-mol) = \left[M_d \times \left(1 - \frac{B_{WS}}{100}\right)\right] + \left[MW_{H_2O} \times \frac{B_{WS}}{100}\right]$$

$$M_S\ (lb/lb\text{-}mol) = \left\{\frac{29.32\ lb}{lb\text{-}mol} \times \left(1 - \frac{9.17\ \%}{100}\right)\right\} + \left\{\frac{18\ lb}{lb\text{-}mol} \times \frac{9.17\ \%}{100}\right\} = \frac{28.28\ lb}{lb\text{-}mol}$$

Average Calculated Fuel Factor (F_o)

$$F_{o(avg)} = \frac{\left[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - 11.68\ \% - (0.5 \times 0.000\ \%)}{5.30\ \% + 0.000\ \%} = 1.740$$

Average Excess Air (%)

$$\%EA_{avg}\,(\%) = \frac{100 \times \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(0.264 \times (N_2)_{avg}) - \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{\ 11.68\ \% - (0.5 \times 0.000\ \%)\ \}}{(\ 0.264 \times 83.02\ \%) - \{\ 11.68\ \% - (0.5 \times 0.000\ \%)\}} = 114.09\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]

Absolute Stack Pressure (in. Hg)

$$P_S\,(in.Hg) = P_b + \frac{P_{static}}{13.6}$$

P_s (in. Hg) = 30.14 in. Hg + $\frac{\text{-0.89 in. } H_2O}{\text{13.6 in. } H_2O/\text{in. Hg}}$ = 30.07 in. Hg

Average Stack Gas Velocity (ft/sec)

$$v_s\,(ft/\sec) = K_p \times C_p \times \left(\sqrt{\Delta p}\right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

v_{sl} (ft/sec) =

$$\left(\frac{85.49\ \text{ft}\ \ (\text{lb/lb-mol})(\text{in. Hg})}{\text{sec}\qquad (^{o}\text{R})(\text{in. } H_2O)}\right)^{1/2} \times\ 0.72\ \times\ 1.12\ \text{in.}H_2O^{1/2}\ \times \sqrt{\frac{189.00\ +\ 460\ ^{o}\text{R}}{30.07\ \text{in. Hg} \times\ 28.28\ \text{lb/lb-mol}}} = \frac{60.6\ \text{ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd}\,(dscfh) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sd} (dscf/hr) = $\frac{3600\ \text{sec}}{\text{hr}}$ x (1 - $\frac{9.17\ \%}{100}$) x $\frac{60.63\ \text{ft}}{\text{sec}}$ x 283.53 ft^2 x $\frac{68.00\ +\ 460\ ^{o}\text{R}}{189.00\ +\ 460\ ^{o}\text{R}}$ x $\frac{30.07\ \text{in. Hg}}{29.92\ \text{in. Hg}}$ = $\frac{45{,}965{,}063.97\ \text{dscf}}{\text{hr}}$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw}\,(acfm) = 60 \times v_s \times A_s$$

Q_{aw} (acf/min) = $\frac{60\ \text{sec}}{\text{min}}$ x $\frac{60.63\ \text{ft}}{\text{sec}}$ x 283.53 ft^2 = $\frac{1{,}031{,}350.91\ \text{acf}}{\text{min}}$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw}\,(ascfh) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sw} (ascf/hr) = $\frac{60\ \text{min}}{\text{hr}}$ x $\frac{1{,}031{,}350.91\ \text{acf}}{\text{min}}$ x $\frac{68.00\ +\ 460\ ^{o}\text{R}}{189.00\ +\ 460\ ^{o}\text{R}}$ x $\frac{30.07\ \text{in. Hg}}{29.92\ \text{in. Hg}}$ = $\frac{50{,}603{,}971.98\ \text{ascf}}{\text{hr}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 206.10 g x 0.04715 ft^3/g = 9.718 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65\ ^\circ R}{\text{in. Hg}} \times 0.97 \times 101.59\ \text{dcf} \times \frac{30.14\ \text{in. Hg} + \frac{0.44\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}}}{87.17\ ^\circ F + 460\ ^\circ R} = 96.29\ \text{dscf}$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{9.72\ \text{dscf}}{9.72\ \text{dscf} + 96.29\ \text{dscf}} = 9.17\ \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)}(\%) = 100 \times \frac{10^{\left(6.691 - \frac{3144}{t_{s(avg)} + 390.86}\right)}}{P_b + \frac{P_{static}}{13.6}} \le 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left(6.691 - \frac{3144}{189.00\ ^\circ F + 390.86}\right)}}{30.14\ \text{in. Hg} + \frac{-0.89\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}}} \le 100 = 61.77\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Desired Orifice (in. H_2O) (first point)

$$\Delta H_d\,(in.H_2O) = K \times \Delta p$$

ΔH_d (in. H_2O) = x

in. H_2O = in. H_2O

Absolute Meter Pressure (in. Hg)

$$P_m\,(in.Hg) = P_b + \frac{\Delta H\,@}{13.6}$$

P_m (in. Hg) = 30.14 in. Hg + $\frac{1.88 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.28 in. Hg

Recommended Nozzle Diameter (in.)

$$D_{ni}\,(in.) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}}\right)} \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}{P_s \times \Delta p_{avg}}\right]}$$

D_{ni} (in.) = $\sqrt{\frac{0.03575 \text{ (lb-mole•°R•in. } H_2O)^{1/2}\text{•min•in.}^2}{\text{acf•in. Hg}^{3/4}\text{•lb}^{1/2}} \text{ x } 0.75 \text{ acf x } 30.28 \text{ in. Hg } \left(1 - \frac{0.00\ \%}{100}\right) \text{ x } \left(\frac{1 - \frac{0.00\ \%}{100}}{1 - \frac{9.17\ \%}{100}}\right) \text{ x } \left[\frac{(87.17\ ^\circ\text{F} + 460^\circ\text{R}) \text{ x } 0.72}{(189.00\ ^\circ\text{F} + 460^\circ\text{R}) \text{ x } \frac{\frac{29.32 \text{ lb}}{\text{lb-mole}} \text{ x } \left(1 - \frac{9.17\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{9.17\ \%}{100}\right)}{30.07 \text{ in. Hg x } 1.12 \text{ in. } H_2O}}\right]}$ = 0.219 in.

ΔP to ΔH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H\,@ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100}\right) + \left(18 \times \frac{B_{wm}}{100}\right)}{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}\right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}}\right)^2 \times \left(\frac{t_m + T_u}{ts + T_u}\right) \times \frac{P_s}{P_m}$$

K = $\frac{849.8}{\text{in. } H_2O\text{•in.}^4}$ x 0.72 ^{2} x 1.88 in. H_2O x 0.16 ^{4} x $\left(\frac{1 - \frac{9.17\ \%}{100}}{1 - \frac{0.00\ \%}{100}}\right)^2$ x $\frac{87.17\ ^\circ\text{F} + 460^\circ\text{R}}{189.00\ ^\circ\text{F} + 460^\circ\text{R}}$) x

$\left(\frac{\frac{29.32 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{0.00\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{0.00\ \%}{100}\right)}{\frac{29.32 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{9.17\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{9.17\ \%}{100}\right)}\right)$ x $\frac{30.07 \text{ in. Hg}}{30.28 \text{ in. Hg}}$ = 0.35

Percent Isokinetic (%) (first point)

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

I (%) = $\frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^\circ\text{R}}$ x (187.00 °F + 460 °R) x 8.48 dscf

23.00 min x $\frac{61.55 \text{ ft}}{\text{sec}}$ x 30.07 in. Hg x 3.14 x $\left(\frac{0.16 \text{ in.}}{2} \text{ x } \frac{\text{ft.}}{12 \text{ in.}}\right)^2$ x $\left(1 - \frac{9.17\ \%}{100}\right)$ = 101.04 %

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Cumulative Percent Isokinetic (%) (weighted average of all points)

$$I(\%) = \sum_{1-n} \frac{\lfloor I(\%) \times V_{m(std)} \rfloor_{1-n}}{V_{m(std)_{1-n}}}$$

Using Method 5, Eq 5-8 to determine intermediate isokinetics at each point, weighted averaging of the cumulative isokinetics is necessary since all points are not equal, and determined by using the dry standard meter volume collected at each point to weight the cumulative average. Intermediate isokinetics and dry standard meter volumes are found at each point. At each point the cumulative sum is found of each value and the quotient of the two used to determine the cumulative isokinetics for each residual point (n).

Pt	In (%)	x	Vm(std)n	=	I (%)n	∑(I (%)n)	/	∑(Vm(std)n)	=	I (%)
A-1	101.04	x	8.483	=	857.07	857.07	/	8.48	=	101.0
A-2	94.05	x	7.333	=	689.70	1546.77	/	15.82	=	97.8
A-3	103.53	x	8.085	=	837.09	2383.86	/	23.90	=	99.7
B-1	91.93	x	7.713	=	709.05	3092.91	/	31.61	=	97.8
B-2	96.55	x	6.890	=	665.21	3758.13	/	38.50	=	97.6
B-3	94.48	x	7.921	=	748.37	4506.50	/	46.42	=	97.1
C-1	97.66	x	8.181	=	798.93	5305.44	/	54.60	=	97.2
C-2	106.55	x	9.657	=	1028.89	6334.33	/	64.26	=	98.6
C-3	98.43	x	8.245	=	811.57	7145.90	/	72.51	=	98.6
D-1	103.51	x	8.053	=	833.53	7979.43	/	80.56	=	99.1
D-2	95.32	x	7.421	=	707.33	8686.76	/	87.98	=	98.7
D-3	99.14	x	8.298	=	822.61	9509.37	/	96.28	=>	98.8

Last Pt

Percent Isokinetic (%) (intermediate equation, all points)
[equivalent to taking an average of point-by-point isokinetics without weighting the average (e.g. all points equal)]

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I(\%) = \frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^{\circ}\text{R}} \times (189.00\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times 96.29 \text{ dscf}$$

$$\frac{}{272.25 \text{ min} \times \frac{60.63 \text{ ft}}{\text{sec}} \times 30.07 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \times \left(1 - \frac{9.17\ \%}{100}\right)} = 98.67\ \%$$

Raw Data Percent Isokinetic (%)
[utilizes the raw data equation for isokinetics from Method 5]

$$I(\%) = \frac{100\left((t_s)_{avg} + T_u\right)\left[K_4 V_{1c} + \frac{V_m Y}{(t_m)_{avg} + T_u}\left(P_{bar} + \frac{\Delta H}{13.6}\right)\right]}{60\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right)}$$

$$I(\%) = \frac{100 \times (189.00\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times \left[\frac{0.002669 \text{ ft}^3\text{•in. Hg}}{\text{ml•}^{\circ}\text{R}} \times 206.5 \text{ ml} + \frac{101.59 \text{ dcf} \times 0.974}{87.17\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}} \left(30.14 \text{ in Hg} + \frac{1.121}{13.6}\right)\right]}{}$$

$$\frac{}{60 \times 272.25 \text{ min} \times \frac{60.63 \text{ ft}}{\text{sec}} \times 30.07 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2} = 98.77\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Gravimetric Analysis) [Values from Run 1 test]

Blank Concentration [Acetone Blank Weight of Solids] (mg/ml)

$$C_x(mg/ml) = \frac{1000 \times w_x}{v_x}$$

C_x (mg/ml) = $\frac{1000\ mg}{g}$ x $\frac{0.0000\ g}{200.60\ ml}$ = $\frac{0.0000\ mg}{ml}$ = $\frac{\quad mg}{ml}$

Blank Adjustment [Acetone Blank Weight of Solids and Nozzle Wash PM>10] (mg)

$$W_x(mg) = v_x \times C_x$$

W_x (mg) = 96 ml x 0.0000 mg/ml = 0.00 mg < Sample Gain

Sample Gain [Nozzle Wash PM>10] (mg)

$$m_x(mg) = \left(m_{fx} - m_{tx}\right) \times 1000$$

m_x (mg) = $\frac{1000\ mg}{g}$ x (0.0108 g - 0.00 g) = 10.80 mg

Adjusted Sample Gain [Nozzle Wash PM>10] (mg)

$$m_{xadj}(mg) = m_x - W_x$$

m_{xadj} (mg) = 10.8 mg - 0.00 mg = 10.80 mg

0.1N NH_4OH Correction (mg)

$$m_c(mg) = 17.03 \times V_t \times N$$

m_c (mg) = 17.03 x 0.00 ml x 0.1 N = 0.00 mg

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - Total PM_{10} Mass]

Stack Total Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s \text{ (g/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{7.80 mg}}{\text{96.29 dscf}} = \frac{\text{8.10E-05 g}}{\text{dscf}}$$

Stack Total Concentration (gr/dscf)

$$c_s'(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s \text{ (gr/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{7.80 mg}}{\text{96.29 dscf}} \times \frac{\text{7000 gr}}{\text{lb}} \times \frac{\text{lb}}{\text{453.592 g}} = \frac{\text{1.25E-03 gr}}{\text{dscf}}$$

Total Emissions Rate (kg/hr)

$$E(kg/hr) = c_s \times Q_{sd} \times \frac{kg}{1000\ g}$$

$$E \text{ (kg/hr)} = \frac{\text{kg}}{\text{1000 g}} \times \frac{\text{8.10E-05 g}}{\text{dscf}} \times \frac{\text{45,965,064 dscf}}{\text{hr}} = \frac{\text{3.72 kg}}{\text{hr}}$$

Total Emissions Rate (lb/hr)

$$E'(lb/hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{lb \times g}{453.592g \times 1000mg}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{7.80 mg}}{\text{96.29 dscf}} \times \frac{\text{45,965,064 dscf}}{\text{hr}} = \frac{\text{8.21 lb}}{\text{hr}}$$

Total Emissions Rate (tpy)

$$E''(ton/yr) = E' \times \frac{8760}{2000}$$

$$E'' \text{ (tpy)} = \frac{\text{ton}}{\text{2000 lb}} \times \frac{\text{8,760 hr}}{\text{yr}} \times \frac{\text{8.21 lb}}{\text{hr}} = \frac{\text{35.96 ton}}{\text{yr}}$$

Total Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{7.80 mg}}{\text{96.29 dscf}} \times \frac{\text{8,638.67 dscf}}{\text{MMBtu}} \times \left(\frac{\text{20.9}}{\text{20.9 - 11.7 \%}}\right) = \frac{\text{0.0035 lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Stack Gas Viscosity (μP) [based on preliminary data] [RM 201A, Eq. 3]

$$\mu(\mu P) = C_1 + C_2\sqrt{T_s} + C_3 T_s^{-2} + C4(\%O_{2,wet}) - C_5 B_{ws} + C_6 B_{ws} T_s^2$$

μ (μP) = -150.3162 μP + 13.4622 $\sqrt{\quad 181 \quad + 460}$ + 3.86153x10^{6} (181 + 460)$^{-2}$ + 0.591123 (5.2 x (1 - 8.00 /100)
- 91.9723 (8.00 /100) + 1.51761x10^{-5} (8.00 /100)(181 + 460)^2 = 195.85 μP

Cunningham Correction Factor [RM 201A, Eq. 4]
[based on preliminary data for a 2.25 micrometer diameter particle]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{195.85\ \mu P}{30.07\ \text{in Hg} \times 2.25\ \mu m}\right)\left(\frac{181 + 460\ ^{o}R}{29.14\ \text{lb / lb-mole}}\right)^{0.5} = 1.08$$

First calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}<3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 5]
[assumes N_{re}<3,162]

$$D_{50LL}(\mu m) = 9.507 C^{0.3007}\left[\frac{M_w P_s}{T_s}\right]^{0.1993}$$

$$D_{50LL}\ (\mu m) = 9.507 \times 1.08^{\ 0.3007} \times \left(\frac{30.07\ \text{in Hg} \times 29.14\ \text{lb / lb-mole}}{181 + 460\ ^{o}R}\right)^{0.1993} = 10.35\ \mu m$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}<3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

$$D_{50T}\ (\mu m) = \frac{11 + 10.35\ \mu m}{2} = 10.67\ \mu m$$

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}<3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu)\left[\frac{T_s}{M_w P_s}\right]^{0.2949}\left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

$$0.07296 \times 195.85\ \mu P \times \left(\frac{181 + 460\ ^{o}R}{30.07\ \text{in Hg} \times 29.14\ \text{lb / lb-mole}}\right)^{0.2949} \times \left(\frac{1}{10.67\ \mu m}\right)^{1.4102} = 0.46\ \text{acfm}$$

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5\left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

$$N_{re} = 8.64 \times 10^5 \times \frac{30.07\ \text{in Hg} \times 29.14\ \text{lb / lb-mole}}{181 + 460\ ^{o}R} \times \frac{0.46\ \text{acfm}}{195.85\ \mu P} = 2788.06 < 3{,}162$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Second calculation set using Cyclone IV, assuming N_{re}<3,162

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]
[assumes N_{re}<3,162]

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) = 0.0024302 x (195.85 µP / 0.46 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (181 + 460 °R / 30.07 in Hg x 29.14 lb / lb-mole)$^{0.6790}$ = 2.37 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Less than 3,162 (acfm) [RM 201A, Eq. 8]

$$Q_{IV}(acfm) = 0.0060639 \left(\frac{\mu}{C^{0.4242}}\right) \left[\frac{P_s M_w}{T_s}\right]^{-.05759} \left[\frac{1}{D_{50}}\right]^{0.8481}$$

Q_{IV} (acfm) = 0.0060639 x (195.85 µP / 1.08 $^{0.4242}$) x (30.07 in Hg x 29.14 lb / lb-mole / 181 + 460 °R)$^{-0.5759}$ x (1 / 2.37 µm)$^{0.8481}$ = 0.46 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

N_{re} = 8.64 x 10^5 x 30.07 in Hg x 29.14 lb / lb-mole / 181 + 460 °R x 0.46 acfm / 195.85 µP = 2788.01 < 3,162

Third calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}≥3,162

Lower Limit Cut Diameter for Cyclone I (µm) [RM 201A, Eq. 12]
[assumes N_{re}≥3,162]

$$D_{50LL}(\mu m) = 10.0959 C^{0.4400} \left[\frac{M_w P_s}{T_s}\right]^{0.0600}$$

D_{50LL} (µm) = 10.0959 x 1.08 $^{0.4400}$ x (30.07 in Hg x 29.14 lb / lb-mole / 181 + 460 °R)$^{0.0600}$ = 10.63 µm

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (µm) [RM 201A, Eq. 6]
[assumes N_{re}≥3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

D_{50T} (µm) = (11 + 10.63 µm) / 2 = 10.82 µm

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}≥3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu) \left[\frac{T_s}{M_w P_s}\right]^{0.2949} \left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) = 0.07296 x 195.85 µP x (181 + 460 °R / 30.07 in Hg x 29.14 lb / lb-mole)$^{0.2949}$ x (1 / 10.82 µm)$^{1.4102}$ = 0.45 acfm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (30.07 in Hg x 29.14 lb / lb-mole) / (181 + 460 °R) x (0.45 acfm) / (195.85 µP) = 2736.91 < 3,162

Fourth calculation set using Cyclone IV, assuming N_{re}≥3,162

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]
[assumes N_{re}≥3,162]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x ((195.85 µP) / (0.45 acfm))$^{0.8058}$ x ((1) / (1.08))$^{0.5}$
x ((181 + 460 °R) / (30.07 in Hg x 29.14 lb / lb-mole))$^{0.3058}$ = 2.29 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Greater than or Equal to 3,162 (acfm) [RM 201A, Eq. 9]

$$Q_{IV}(acfm) = 0.007657 \left(\frac{\mu}{C^{0.6205}}\right)\left[\frac{P_s M_w}{T_s}\right]^{-0.3795}\left[\frac{1}{D_{50}}\right]^{1.241}$$

Q_{IV} (acfm) =

0.007657 x ((195.85 µP) / (1.08 $^{0.6205}$)) x ((30.07 in Hg x 29.14 lb / lb-mole) / (181 + 460 °R))$^{-0.3795}$
x ((1) / (2.29 µm))$^{1.241}$ = 0.45 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (30.07 in Hg x 29.14 lb / lb-mole) / (181 + 460 °R) x (0.46 acfm) / (195.85 µP) = 2788.06 < 3,162

Meter Box Orifice Pressure Drop (in H_2O) [RM 201A, Eq. 11]
As calculated using applicable calculation set 1, 2, 3, or 4

$$\Delta H(inH_2O) = \left[\frac{Q_s(1 - B_{ws})P_s}{T_s}\right]^2 \left[\frac{1.083 T_m M_d \Delta H_@}{P_{bar}}\right]$$

ΔH (in H_2O) = (0.46 acfm x (1 - 8.00 /100) x 30.07 in Hg) / (181 + 460 °R))^2
x (1.083 x (85.00 + 460 °R) x 30.11 lb / lb-mole x 1.878 in H_2O) / (30.14 in Hg)) = 0.441 in H_2O

50 °F above stack temperature	T_{s+50} =	231	ΔH_{+50} =	0.379 in H_2O
50 °F below stack temperature	T_{s+50} =	131	ΔH_{+50} =	0.519 in H_2O

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Adjusted Velocity Pressure (in H_2O) [point A-1] [RM201A, Eq. 25]

$$\Delta p_s(inH_2O) = \Delta p_m\left[\frac{C_p}{C'_p}\right]^2$$

Δp_s (in H_2O) = 1.30 in H_2O x (0.7240 / 0.8198)^2 = 1.01 in H_2O

Average Probe Blockage Factor [RM201A, Eq. 26]

$$b_f = \frac{22.0}{A}$$

b_f = 22.0 / 40828.14 in^2 = 5.39E-04

Velocity Pressure Adjusted for Blockage Factor (in H_2O) [point A-1] [RM201A, Eq. 27]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$\Delta p_{s2}(inH_2O) = \Delta p_{s1}\left[\frac{1}{(1-b_f)}\right]^2$$

Δp_s (in H_2O) = 1.01 in H_2O x (1 / (1 - 0.00E+00))^2 = 1.01 in H_2O

Velocity of Stack Gas Adjusted for Blockage Factor and/or C_p / C'_p (ft/sec) [RM201A, Eq. 13]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$v_s = K_p C_p \left(\sqrt{(\Delta p)}\right)_{avg}\left[\sqrt{\frac{T_s}{P_s M_w}}\right]$$

v_s (ft/sec) =

85.49 ft/sec / lb/mole - °R x 0.7240 x 0.99 x (181 + 460 °R / 30.07 in Hg x 29.14 lb / lb-mole)$^{0.5}$ = 52.41 ft/sec

Calculated Nozzle Diameter for Acceptable Sampling Rate (in) [RM201A, Eq. 14]

$$D(in) = \left[\frac{3.056 Q_s}{v_s}\right]^{0.5}$$

D (in) = (3.056 x 0.46 acfm / 52.41 ft/sec)$^{0.5}$ = 0.164 in

Represents ideal diameter, which we then compare to capabilities of all nozzles from multiple sets

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Velocity of Gas in Nozzle 4b (diam. = 0.156 in), (ft/sec) [RM201A, Eq. 15]

v_n (ft/sec) = $\frac{0.46 \text{ acfm}}{60 \text{ min/sec} \times 1.33\text{E-}04 \text{ ft}^2}$ = 58.02 $\frac{\text{ft}}{\text{sec}}$

Example set of calculations for nozzle used with run 1

$$v_n = \frac{\left(\frac{Q_s}{60 \frac{\text{min}}{\text{sec}}}\right)}{A_n}$$

Minimum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 16]

Nozzle 4b (diam. = 0.156 in)

$$R_{min} = \left[0.2457 + \left(0.3072 - \frac{0.2603(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{min} =

$0.2457 + (0.3072 - \frac{0.2603 \times 195.85 \text{ µP} \times (0.46 \text{ acfm})^{0.5}}{58.02 \text{ in}^{1.5}})^{0.5}$ = 0.72

Maximum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 17]

Nozzle 4b (diam. = 0.156 in)

$$R_{max} = \left[0.4457 + \left(0.5690 + \frac{0.2603(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{max} =

$0.4457 + (0.5690 + \frac{0.2603 \times 195.85 \text{ µP} \times (0.46 \text{ acfm})^{0.5}}{58.02 \text{ in}^{1.5}})^{0.5}$ = 1.25

Minimum Gas Velocity for R_{min} Less than 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{min}(ft/sec) = v_n(0.5)$ v_{min} (ft/sec) = 0.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 18]**

Not Applicable

Minimum Gas Velocity for R_{min} Greater than or Equal to 0.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{min}(ft/sec) = v_n R_{min}$ v_{min} (ft/sec) = 58.02 $\frac{\text{ft}}{\text{sec}}$ x 0.72 = 42.01 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 19]**

Maximum Gas Velocity for R_{max} Less than 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{max}(ft/sec) = v_n R_{max}$ v_{max} (ft/sec) = 58.02 $\frac{\text{ft}}{\text{sec}}$ x 1.25 = 72.55 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 20]**

Maximum Gas Velocity for R_{max} Greater than or Equal to 1.5 (ft/sec) **Nozzle 4b (diam. = 0.156 in)**

$v_{max}(ft/sec) = v_n(1.5)$ v_{max} (ft/sec) = 1.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 21]**

Not Applicable

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Minimum Velocity Pressure (in H_2O) [RM201A, Eq. 22] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{min} below preliminary data minimum

$$\Delta p_{min}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{min}}{C_p}\right]^2$$

Δp_{min} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{30.07 \text{ in Hg} \times 29.14 \text{ lb / lb-mole}}{181 + 460\ ^{o}R}\right) \times \left(\frac{42.01 \text{ ft/sec}}{0.7240}\right)^2 =$ 0.63 in H_2O vs. 0.86

Maximum Velocity Pressure (in H_2O) [RM201A, Eq. 23] **Nozzle 4b (diam. = 0.156 in)**

Run 1 nozzle is able to achieve Δp_{max} above preliminary data maximum

$$\Delta p_{max}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{max}}{C_p}\right]^2$$

Δp_{max} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{30.07 \text{ in Hg} \times 29.14 \text{ lb / lb-mole}}{181 + 460\ ^{o}R}\right) \times \left(\frac{72.55 \text{ ft/sec}}{0.7240}\right)^2 =$ 1.88 in H_2O vs. 1.09

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sampling Dwell Time at Each Point (minutes) [point A-1] [RM201A, Eq. 24]

$$t_n(\text{min}) = \left[\frac{C_p\sqrt{\Delta p_n}}{C_p'\left(\sqrt{\Delta p_n}\right)_{avg}}\right]\left[\frac{t_r}{N_{tp}}\right]$$

t_n (min) = $\left(\frac{0.7240 \times \left(1.30\right)^{0.5}}{0.7240 \times 0.99}\right) \times \left(\frac{240.00 \text{ min}}{12.00}\right) =$ 23.03 minutes

Dry Gas Volume Sampled at Standard Conditions (dscf) [point A-1] [RM201A, Eq. 28]

$$v_{ms}(dscf) = \left[\frac{528}{29.92}\right]\left[\gamma \cdot v_m\right]\left[\frac{\left(P_{bar} + \frac{\Delta H}{13.6}\right)}{T_m}\right]$$

v_{ms} (dscf) = $\left(\frac{528}{29.92}\right)$ (0.974 x 8.80 dcf) x

$\left(\frac{30.14 \text{ in Hg} + 0.44 \text{ in } H_2O / 13.6}{78.00 + 460\ ^{o}R}\right) =$ 8.48 dscf

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sample Flow Rate at Standard Conditions (dscfm) [RM201A, Eq. 29]

$$Q_{sST}\,(dscfm) = \frac{v_{ms}}{\Theta}$$

Q_{sST} (dscfm) = $\frac{96.29 \text{ dscf}}{272.25 \text{ min}}$ = $\frac{0.35 \text{ dscf}}{\text{min}}$

Sampling Rate (acfm) [e.g. cyclone flow rate] [RM201A, Eq. 32]

$$Q_s(acfm) = \frac{29.92}{528} Q_{sST} \left[\frac{1}{(1 - B_{ws})}\right]\left[\frac{T_s}{P_s}\right]$$

Q_s (acfm) = $\frac{29.92 \text{ in Hg}}{528\ ^{o}\text{R}}$ x $\frac{0.35 \text{ dscf}}{\text{min}}$ x $\frac{1}{(1 - 9.17 /100)}$ x $\frac{189 + 460\ ^{o}\text{R}}{30.07 \text{ in Hg}}$ = 0.48 acfm

Actual Conditions Reynolds Number (dimensionless) [RM 201A, Eq. 10]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

N_{re} = 8.64 x 10^5 x $\frac{30.07 \text{ in Hg x } 28.28 \text{ lb / lb-mole}}{189 + 460\ ^{o}\text{R}}$ x $\frac{0.48 \text{ acfm}}{200.23 \text{ µP}}$ = 2692.23

Actual Conditions Particle Cut Diameter for Cyclone I (µm) [RM201A, Eq. 33]

$$D_{50}\,(\mu m) = 0.15625 \left[\frac{T_s}{M_w P_s}\right]^{0.2091} \left[\frac{\mu}{Q_s}\right]^{0.7091}$$

D_{50} (µm) = 0.15625 x ($\frac{189 + 460\ ^{o}\text{R}}{30.07 \text{ in Hg x } 28.28 \text{ lb / lb-mole}}$)$^{0.2091}$ x ($\frac{200.23 \text{ µP}}{0.48 \text{ acfm}}$)$^{0.7091}$ = 10.71 µm

Actual Particle Cut Diameter for Cyclone IV is determined by:

Actual Conditions Cunningham Correction Factor [RM 201A, Eq. 4]
[for a 2.5 micrometer diameter particle (estimated size)]

$$C = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x ($\frac{200.23 \text{ µP}}{30.07 \text{ in Hg x } 2.5 \text{ µm}}$)($\frac{189 + 460\ ^{o}\text{R}}{28.28 \text{ lb / lb-mole}}$)$^{0.5}$ = 1.07

Actual Conditions Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]

$$D_{50}\,(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) =

0.0024302 x ($\frac{200.23 \text{ µP}}{0.48 \text{ acfm}}$)$^{1.1791}$ x ($\frac{1}{1.07}$)$^{0.5}$

x ($\frac{189 + 460\ ^{o}\text{R}}{30.07 \text{ in Hg x } 28.28 \text{ lb / lb-mole}}$)$^{0.6790}$ = 2.42 µm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Actual Conditions Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Re-calculated Cunningham Correction Factor (dimensionless) [RM 201A, Eq. 36]

$$C_r = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x (200.23 µP / 30.07 in Hg x 2.42 µm)(189 + 460 °R / 28.28 lb / lb-mole)$^{0.5}$ = 1.08

Re-calculated Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 37]

$$D_{50-1}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50-1} (µm) =

0.0024302 x (200.23 µP / 0.48 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (189 + 460 °R / 30.07 in Hg x 28.28 lb / lb-mole)$^{0.6790}$ = 2.42 µm

Re-Calculated Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 38]

$$D_{50-1}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50-1} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Ratio (Z) Between D_{50} and D_{50-1} Values (dimensionless) [RM 201A, Eq. 39]

$$Z = \frac{D_{50-1}}{D_{50}} \qquad 0.99 \le \left[Z = \left(\frac{D_{50}}{D_{50-1}}\right)\right] \le 1.01$$

Z = 2.42 µm / 2.42 µm = 1.00

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	U-00001 Base+DB

Historical Data	SAM U-00002 Base+DB-1	SAM U-00002 Base+DB-2	SAM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Run Start Time	05:46	08:40	11:33		hh:mm	
Run Stop Time	07:46	10:40	13:33		hh:mm	
Test Date	03/11/20	03/11/20	03/11/20		mm/dd/yy	
Load	Base+DB	Base+DB	Base+DB		% or w/DB	--
Meter Calibration Factor	0.985	0.985	0.985			
Stack Test Data	SAM U-00002 Base+DB-1	SAM U-00002 Base+DB-2	SAM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Initial Meter Volume	46.270	SAM U-0001 Base+DB	142.600		ft^3	
Final Meter Volume	87.230	136.210	183.900		ft^3	
Total Meter Volume	40.960	41.810	41.300	41.357	ft^3	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	83.10	86.21	88.71	86.01	°F	
Barometric Pressure	30.09	30.15	30.14	30.13	in Hg	
Stack Static Pressure	0.95	0.95	0.95	0.95	in H_2O	
Absolute Stack Pressure	30.16	43878.00	30.21	14646.12	in Hg	
Average Orifice Pressure Drop	0.34	0.34	0.34	0.34	in H_2O	
Absolute Meter Pressure	30.22	30.28	30.27	30.25	in Hg	
Moisture Content Data	SAM U-00002 Base+DB-1	SAM U-00002 Base+DB-2	SAM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	56.80	66.10	61.60	61.50	g	
Silica Gel Weight Gain	8.40	8.30	6.80	7.83	g	
Total Water Volume Collected	65.32	74.53	68.52	69.46	ml	
Standard Water Vapor Volume	3.07	3.51	3.23	3.27	scf	
Standard Meter Volume	39.5	40.1	39.5	39.7	dscf	
Standard Metric Meter Volume	1.1	1.1	1.1	1.1	dscm	
Calculated Stack Moisture	7.22	8.04	7.55	7.60	%	
Gas Analysis Data	SAM U-00002 Base+DB-1	SAM U-00002 Base+DB-2	SAM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	5.3	5.3	5.3	5.3	%	
Oxygen Content	11.7	11.7	11.7	11.7	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	83.0	83.0	83.0	83.0	%	
Stack Dry Molecular Weight	29.32	29.32	29.32	29.32	lb/lb-mole	
Calculated Fuel Factor	1.736	1.736	1.736	1.736		
Fuel F-Factor	8636.30	8636.30	8636.30	8636.30	dscf/MMBtu	
Sulfuric Acid Mist IC Analysis	SAM U-00002 Base+DB-1	SAM U-00002 Base+DB-2	SAM U-00002 Base+DB-3	**Average**	**Units**	**Limits**
H_2SO_4 (IC) Sample Volume - Front Half Rinse	154.0	160.0	144.0	152.67	ml	--
H_2SO_4 (IC) Sample - Mass Per Volume	0.2	0.1	0.2	0.15	mg/L	--
H_2SO_4 (IC) Mass	0.03	0.02	0.03	0.02	mg	--
H_2SO_4 (IC) Concentration	6.84E-07	3.99E-07	6.59E-07	5.80E-07	g/dscf	--
	1.06E-05	6.15E-06	1.02E-05	8.96E-06	gr/dscf	--
	2.42E-08	1.41E-08	2.33E-08	2.05E-08	g/L	--
	0.01	0.00	0.01	0.01	ppmvd	--
H_2SO_4 (IC) Emission Rate	0.00003	0.00002	0.00003	0.00003	lb/MMBtu	0.00065

Note: Run 2 reported at the RDL (0.016 mg)

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 65.20 g x 0.04715 ft^3/g = 3.074 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{\frac{17.65\ ^\circ R}{in.\ Hg} \times 0.99 \times 40.96\ dcf \times \left(30.09\ in.\ Hg + \frac{0.34\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{83.10\ ^\circ F + 460\ ^\circ R} = 39.48\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{3.07\ dscf}{3.07\ dscf + 39.48\ dscf} = 7.22\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - H_2SO_4 (IC)]

Stack H_2SO_4 Mass (mg)

$$M_n(mg) = \frac{M_{n(lab)}}{V_{s(lab)}} \times V_{sample} \times \frac{L}{1000ml}$$

M_n (mg) = $\frac{\text{L}}{\text{1000 ml}}$ x 0.18 $\frac{\text{mg}}{\text{L}}$ x 154.00 ml = 0.03 mg

Stack H_2SO_4 Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

c_s (g/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.03 mg}}{\text{39.48 dscf}}$ = $\frac{\text{6.80E-07 g}}{\text{dscf}}$

Stack H_2SO_4 Concentration (gr/dscf)

$$c'_s(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

c'$_s$ (gr/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.03 mg}}{\text{39.48 dscf}}$ x $\frac{\text{7000 gr}}{\text{lb}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ = $\frac{\text{1.06E-05 gr}}{\text{dscf}}$

Stack H_2SO_4 Concentration (g/L)

$$c''_s(g/L) = c'_s \times \frac{dscf}{28.31685 dsL}$$

c'$_s$ (gr/dscf) = 6.84E-07 $\frac{\text{g}}{\text{dscf}}$ x $\frac{\text{dscf}}{\text{28.31685 dsL}}$ = $\frac{\text{2.00E-08 g}}{\text{L}}$

Stack H_2SO_4 Concentration (ppmvd)

$$c'''_s(ppmvd) = \frac{M_n}{V_{m(std)}} \times Ideal\ Gas\ Constant \times \frac{10^6 parts}{million\ parts} \times \frac{1}{Mol\ Wt}$$

c'''$_s$ (ppmvd) = 2.42E-08 $\frac{\text{g}}{\text{L}}$ x $\frac{\text{24.04 L gas}}{\text{lb-mol}}$ x $\frac{10^6 \text{ parts}}{\text{MM parts}}$ x $\frac{\text{lb-mol}}{\text{98.0790 lb}}$ = 0.006 ppmvd

H_2SO_4 Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

E''' (lb/MMBtu) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ x $\frac{\text{0.03 mg}}{\text{39.48 dscf}}$ x $\frac{\text{8,636.30 dscf}}{\text{MMBtu}}$ x ($\frac{\text{20.9}}{\text{20.9 - 11.7 \%}}$) = $\frac{\text{0.00003 lb}}{\text{MMBtu}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B

EMISSION DATA RECORDS

Cricket Valley Energy Center LLC

Air Permit Number:	3-1326-00275/00009
Plant Name or Location:	Cricket Valley Energy Center
Date:	March 9, 2020
Project Number:	bec-19-cricketvalley.ny-start#2
Manufacturer & Equipment:	General Electric
Model:	7F.05
Unit Number:	U-00002
Test Load:	Multiiple
Tester(s) / Test Unit(s):	RW/AM/220/213

		RUN					
	UNITS	**1-1**	**1-2**	**1-3**	**2-1**	**2-2**	**2-3**
Start Time	hh:mm:ss	14:44:11	16:05:11	17:18:11	15:27:20	17:35:20	18:35:20
End Time	hh:mm:ss	15:43:41	17:04:41	18:17:41	16:26:50	18:34:50	19:34:50
Bar. Pressure	in. Hg	30.28	30.28	30.30	30.17	30.15	30.12
Amb. Temp.	°F	66	67	65	52	49	46
Rel. Humidity	%	22	25	28	53	70	73
Spec. Humidity	lb water / lb air	0.002926	0.003445	0.003599	0.004296	0.005086	0.004740
Date	mm/dd/yy	03/09/20	03/09/20	03/09/20	03/10/20	03/10/20	03/10/20
Load Designator		Base	Base	Base	Base+DB	Base+DB	Base+DB
NH_3 Flow Rate	lb/hr	126.8	123.3	124.2	151.7	149.8	149.2
Turbine Fuel Flow	lb/min	1,617	1,624	1,622	1,625	1,625	1,627
Duct Burner Fuel Flow	lb/min	0	0	0	166	171	174
Total Fuel Flow	SCFH	2,195,187	2,205,298	2,202,317	2,431,495	2,438,066	2,444,977
Stack Moisture	% Method 4	7.61	7.61	7.61	6.66	6.66	6.66
Heat Input	MMBtu/hr	2212.6	2222.8	2219.8	2458.8	2465.4	2472.4
CT Power Output	megawatts	230.8	230.6	230.5	231.8	232.1	232.6

Created with Comp&RATA&Eng-AHI v20190529

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
NOx, CO, VOC, and NH_3

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 14:44 - 3/9 15:43)		230.78	26.95	0.00	12.41	126.77	1167.92	6.35
COUNT = 60								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 14:44	231.22	26.97	0.00	12.49	127.92	1167.93	6.56
	3/9/20 14:45	230.88	27.00	0.00	12.49	127.95	1167.84	6.56
	3/9/20 14:46	230.82	26.97	0.00	12.49	127.60	1168.17	6.55
	3/9/20 14:47	231.22	27.02	0.00	12.50	127.17	1167.74	6.54
	3/9/20 14:48	231.07	27.01	0.00	12.50	126.84	1168.31	6.54
	3/9/20 14:49	230.81	26.97	0.00	12.50	126.57	1167.98	6.53
	3/9/20 14:50	230.96	26.93	0.00	12.50	126.84	1168.00	6.52
	3/9/20 14:51	230.96	26.98	0.00	12.51	127.14	1168.17	6.52
	3/9/20 14:52	231.00	26.96	0.00	12.51	127.66	1168.28	6.51
	3/9/20 14:53	230.96	26.99	0.00	12.51	127.45	1168.23	6.50
	3/9/20 14:54	230.97	26.91	0.00	12.51	127.44	1168.29	6.49
	3/9/20 14:55	230.99	26.92	0.00	12.51	127.15	1168.10	6.49
	3/9/20 14:56	230.80	26.97	0.00	12.52	126.48	1167.86	6.48
	3/9/20 14:57	230.98	26.88	0.00	12.52	126.35	1167.94	6.47
	3/9/20 14:58	231.17	27.02	0.00	12.52	125.90	1168.20	6.47
	3/9/20 14:59	230.92	26.87	0.00	12.52	126.08	1167.89	6.46
	3/9/20 15:00	230.91	26.98	0.00	12.53	126.65	1167.56	6.45
	3/9/20 15:01	230.66	26.90	0.00	12.53	127.09	1167.80	6.44
	3/9/20 15:02	230.70	26.94	0.00	12.52	126.99	1167.68	6.44
	3/9/20 15:03	230.70	26.91	0.00	12.49	127.29	1168.41	6.43
	3/9/20 15:04	230.74	26.93	0.00	12.46	126.73	1168.46	6.42
	3/9/20 15:05	230.89	26.98	0.00	12.44	126.77	1168.13	6.42
	3/9/20 15:06	230.98	26.99	0.00	12.41	126.68	1168.47	6.41
	3/9/20 15:07	230.95	26.93	0.00	12.38	126.65	1168.10	6.40
	3/9/20 15:08	230.75	26.92	0.00	12.37	126.34	1168.18	6.39
	3/9/20 15:09	230.74	26.87	0.00	12.36	126.34	1167.46	6.39
	3/9/20 15:10	231.01	26.97	0.00	12.35	126.66	1168.07	6.38
	3/9/20 15:11	230.64	26.90	0.00	12.35	126.85	1167.66	6.37
	3/9/20 15:12	230.38	26.90	0.00	12.34	127.62	1167.64	6.37
	3/9/20 15:13	230.52	26.90	0.00	12.33	127.26	1168.10	6.36
	3/9/20 15:14	230.63	26.92	0.00	12.32	126.80	1168.10	6.35
	3/9/20 15:15	231.06	26.87	0.00	12.31	126.09	1167.82	6.34
	3/9/20 15:16	231.19	27.01	0.00	12.30	126.42	1167.75	6.34
	3/9/20 15:17	230.97	26.93	0.00	12.30	126.86	1167.74	6.33
	3/9/20 15:18	230.72	26.96	0.00	12.29	128.31	1168.45	6.32
	3/9/20 15:19	230.89	26.88	0.00	12.28	128.35	1168.18	6.32
	3/9/20 15:20	230.60	26.96	0.00	12.27	127.18	1167.65	6.31
	3/9/20 15:21	230.56	26.99	0.00	12.26	126.67	1168.15	6.30
	3/9/20 15:22	230.62	26.87	0.00	12.25	126.53	1167.45	6.29
	3/9/20 15:23	230.82	26.92	0.00	12.24	126.42	1168.26	6.29
	3/9/20 15:24	230.67	26.96	0.00	12.24	126.08	1167.88	6.28
	3/9/20 15:25	230.63	26.92	0.00	12.25	126.79	1167.53	6.27
	3/9/20 15:26	230.46	27.00	0.00	12.28	126.78	1167.78	6.27
	3/9/20 15:27	230.22	26.91	0.00	12.30	126.72	1167.24	6.26
	3/9/20 15:28	230.33	26.89	0.00	12.33	126.66	1167.17	6.25
	3/9/20 15:29	230.78	26.98	0.00	12.35	127.09	1168.06	6.24
	3/9/20 15:30	230.59	26.91	0.00	12.38	126.53	1168.19	6.24
	3/9/20 15:31	230.60	26.90	0.00	12.40	127.18	1168.18	6.23
	3/9/20 15:32	230.87	26.95	0.00	12.43	127.38	1168.39	6.22
	3/9/20 15:33	230.79	26.98	0.00	12.45	126.33	1167.80	6.22
	3/9/20 15:34	230.60	26.93	0.00	12.48	125.84	1167.46	6.21
	3/9/20 15:35	230.69	27.02	0.00	12.50	125.96	1167.68	6.20
	3/9/20 15:36	230.53	26.93	0.00	12.53	126.59	1167.93	6.19
	3/9/20 15:37	230.58	26.90	0.00	12.56	126.63	1168.15	6.19
	3/9/20 15:38	230.64	27.01	0.00	12.36	126.52	1167.44	6.18
	3/9/20 15:39	230.35	26.94	0.00	12.37	126.87	1167.83	6.17
	3/9/20 15:40	230.59	26.95	0.00	12.38	126.63	1167.89	6.17
	3/9/20 15:41	230.92	26.98	0.00	12.39	125.63	1167.47	6.16
	3/9/20 15:42	230.76	26.98	0.00	12.40	125.34	1167.64	6.15
	3/9/20 15:43	230.52	26.98	0.00	12.40	124.58	1167.55	6.15

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 16:5 - 3/9 17:4)		230.63	27.07	0.00	12.43	123.26	1174.41	5.78
COUNT = 60								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 16:05	231.11	27.09	0.00	12.41	125.02	1174.88	5.99
	3/9/20 16:06	231.26	27.09	0.00	12.39	125.10	1174.92	5.98
	3/9/20 16:07	231.20	27.16	0.00	12.36	125.07	1174.73	5.97
	3/9/20 16:08	231.21	27.17	0.00	12.43	124.74	1175.15	5.97
	3/9/20 16:09	231.26	27.07	0.00	12.47	124.40	1174.28	5.96
	3/9/20 16:10	231.38	27.10	0.00	12.48	123.80	1174.58	5.95
	3/9/20 16:11	230.96	27.08	0.00	12.49	123.69	1174.58	5.95
	3/9/20 16:12	230.84	27.04	0.00	12.50	123.37	1174.61	5.94
	3/9/20 16:13	230.40	27.07	0.00	12.50	122.92	1174.46	5.93
	3/9/20 16:14	230.54	27.09	0.00	12.51	122.48	1174.43	5.92
	3/9/20 16:15	230.75	27.14	0.00	12.51	122.61	1174.45	5.92
	3/9/20 16:16	231.05	27.08	0.00	12.50	122.84	1174.51	5.91
	3/9/20 16:17	230.75	27.04	0.00	12.49	122.55	1174.16	5.90
	3/9/20 16:18	230.72	27.03	0.00	12.48	122.99	1174.71	5.90
	3/9/20 16:19	230.54	27.02	0.00	12.48	122.62	1173.96	5.89
	3/9/20 16:20	230.66	27.05	0.00	12.47	122.61	1174.19	5.88
	3/9/20 16:21	230.79	27.12	0.00	12.46	123.18	1174.64	5.87
	3/9/20 16:22	231.16	27.13	0.00	12.45	122.87	1175.04	5.87
	3/9/20 16:23	230.83	27.11	0.00	12.44	123.33	1174.50	5.86
	3/9/20 16:24	230.94	27.13	0.00	12.43	123.18	1174.71	5.85
	3/9/20 16:25	230.98	27.12	0.00	12.42	123.42	1174.40	5.85
	3/9/20 16:26	230.75	27.13	0.00	12.41	124.40	1174.75	5.84
	3/9/20 16:27	231.02	27.08	0.00	12.42	123.86	1174.29	5.83
	3/9/20 16:28	231.19	27.11	0.00	12.44	123.56	1174.23	5.82
	3/9/20 16:29	230.81	27.06	0.00	12.45	123.54	1173.95	5.82
	3/9/20 16:30	230.38	27.10	0.00	12.47	123.45	1174.24	5.81
	3/9/20 16:31	230.46	27.03	0.00	12.49	123.75	1174.45	5.80
	3/9/20 16:32	230.64	27.05	0.00	12.51	123.01	1174.60	5.80
	3/9/20 16:33	230.74	27.08	0.00	12.49	122.52	1174.00	5.79
	3/9/20 16:34	230.92	27.03	0.00	12.46	122.63	1174.61	5.78
	3/9/20 16:35	231.14	27.21	0.00	12.44	123.50	1174.39	5.77
	3/9/20 16:36	230.93	27.10	0.00	12.42	123.90	1174.62	5.77
	3/9/20 16:37	230.60	27.11	0.00	12.39	123.12	1174.43	5.76
	3/9/20 16:38	230.51	27.14	0.00	12.37	123.44	1174.95	5.75
	3/9/20 16:39	230.62	27.06	0.00	12.34	123.72	1174.32	5.75
	3/9/20 16:40	230.69	27.15	0.00	12.32	123.34	1174.84	5.74
	3/9/20 16:41	230.81	27.01	0.00	12.29	123.35	1174.57	5.73
	3/9/20 16:42	230.35	27.00	0.00	12.39	123.65	1174.18	5.73
	3/9/20 16:43	230.14	27.01	0.00	12.45	123.58	1174.65	5.72
	3/9/20 16:44	229.95	27.07	0.00	12.45	123.01	1174.22	5.71
	3/9/20 16:45	229.94	27.04	0.00	12.44	121.50	1174.13	5.70
	3/9/20 16:46	230.06	26.99	0.00	12.44	121.07	1174.91	5.70
	3/9/20 16:47	230.17	27.00	0.00	12.43	121.37	1173.54	5.69
	3/9/20 16:48	230.40	27.04	0.00	12.43	121.40	1174.14	5.68
	3/9/20 16:49	230.01	27.07	0.00	12.43	122.46	1174.81	5.68
	3/9/20 16:50	230.01	27.04	0.00	12.42	122.57	1174.18	5.67
	3/9/20 16:51	229.89	26.94	0.00	12.42	122.98	1173.74	5.66
	3/9/20 16:52	230.02	27.03	0.00	12.41	123.54	1173.94	5.65
	3/9/20 16:53	230.07	27.00	0.00	12.41	122.84	1174.12	5.65
	3/9/20 16:54	230.20	27.00	0.00	12.41	122.17	1174.28	5.64
	3/9/20 16:55	230.58	27.09	0.00	12.40	122.66	1174.37	5.63
	3/9/20 16:56	230.57	27.10	0.00	12.40	123.58	1174.09	5.63
	3/9/20 16:57	230.80	27.10	0.00	12.40	124.30	1174.41	5.62
	3/9/20 16:58	230.32	27.00	0.00	12.39	124.83	1174.05	5.61
	3/9/20 16:59	230.46	27.03	0.00	12.39	125.13	1174.49	5.60
	3/9/20 17:00	230.33	27.00	0.00	12.38	124.47	1174.49	5.60
	3/9/20 17:01	230.31	27.02	0.00	12.38	123.10	1174.33	5.59
	3/9/20 17:02	230.79	27.08	0.00	12.38	122.63	1174.35	5.58
	3/9/20 17:03	230.41	27.08	0.00	12.37	122.41	1174.19	5.58
	3/9/20 17:04	230.48	27.08	0.00	12.37	122.74	1173.75	5.57

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 17:18 - 3/9 18:17)		230.55	27.03	0.00	12.49	124.21	1174.02	5.26
COUNT = 60								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 17:18	230.29	27.01	0.00	12.52	123.39	1174.04	5.47
	3/9/20 17:19	230.07	26.99	0.00	12.52	123.36	1173.27	5.46
	3/9/20 17:20	230.10	27.01	0.00	12.52	123.49	1173.25	5.45
	3/9/20 17:21	230.19	27.05	0.00	12.52	123.85	1173.66	5.45
	3/9/20 17:22	230.26	27.04	0.00	12.52	124.22	1173.85	5.44
	3/9/20 17:23	230.44	27.02	0.00	12.52	124.29	1174.40	5.43
	3/9/20 17:24	230.34	27.00	0.00	12.52	124.59	1174.29	5.43
	3/9/20 17:25	229.93	27.01	0.00	12.52	124.20	1173.98	5.42
	3/9/20 17:26	230.27	27.05	0.00	12.52	123.99	1173.33	5.41
	3/9/20 17:27	230.19	26.89	0.00	12.52	123.89	1174.12	5.40
	3/9/20 17:28	230.20	27.03	0.00	12.52	124.62	1174.21	5.40
	3/9/20 17:29	230.07	26.98	0.00	12.52	123.78	1173.74	5.39
	3/9/20 17:30	230.04	27.00	0.00	12.52	123.44	1173.51	5.38
	3/9/20 17:31	229.80	26.93	0.00	12.52	123.48	1174.17	5.38
	3/9/20 17:32	230.47	27.07	0.00	12.52	123.43	1174.00	5.37
	3/9/20 17:33	230.03	27.04	0.00	12.52	123.31	1174.38	5.36
	3/9/20 17:34	230.27	27.05	0.00	12.52	123.55	1173.79	5.36
	3/9/20 17:35	230.28	26.97	0.00	12.52	123.86	1173.47	5.35
	3/9/20 17:36	230.19	27.02	0.00	12.52	124.09	1173.89	5.34
	3/9/20 17:37	230.33	27.01	0.00	12.51	124.53	1174.09	5.33
	3/9/20 17:38	230.62	27.09	0.00	12.50	124.37	1174.37	5.33
	3/9/20 17:39	230.28	26.96	0.00	12.49	124.65	1174.03	5.32
	3/9/20 17:40	230.45	26.99	0.00	12.48	125.14	1174.05	5.31
	3/9/20 17:41	230.47	27.01	0.00	12.47	124.80	1173.47	5.31
	3/9/20 17:42	230.48	27.02	0.00	12.46	124.15	1173.92	5.30
	3/9/20 17:43	230.52	26.98	0.00	12.45	123.53	1173.74	5.29
	3/9/20 17:44	230.88	27.06	0.00	12.43	123.57	1174.07	5.28
	3/9/20 17:45	230.73	27.08	0.00	12.42	124.11	1174.43	5.28
	3/9/20 17:46	230.89	27.01	0.00	12.41	124.66	1173.95	5.27
	3/9/20 17:47	230.64	26.98	0.00	12.40	125.10	1173.82	5.26
	3/9/20 17:48	230.58	27.01	0.00	12.39	125.18	1174.61	5.26
	3/9/20 17:49	230.50	27.03	0.00	12.38	124.81	1173.78	5.25
	3/9/20 17:50	230.44	27.02	0.00	12.37	123.96	1174.31	5.24
	3/9/20 17:51	230.57	27.07	0.00	12.36	123.93	1173.39	5.23
	3/9/20 17:52	230.40	27.01	0.00	12.35	123.93	1173.88	5.23
	3/9/20 17:53	230.73	27.06	0.00	12.36	123.98	1173.99	5.22
	3/9/20 17:54	230.76	27.11	0.00	12.38	123.82	1173.54	5.21
	3/9/20 17:55	231.05	27.10	0.00	12.39	124.22	1173.98	5.21
	3/9/20 17:56	230.91	27.06	0.00	12.41	124.18	1173.72	5.20
	3/9/20 17:57	230.86	27.10	0.00	12.42	124.02	1174.03	5.19
	3/9/20 17:58	231.05	27.07	0.00	12.44	124.38	1174.51	5.18
	3/9/20 17:59	230.91	27.10	0.00	12.45	124.49	1174.27	5.18
	3/9/20 18:00	231.06	27.05	0.00	12.47	124.44	1173.80	5.17
	3/9/20 18:01	230.36	27.08	0.00	12.48	124.94	1174.47	5.16
	3/9/20 18:02	230.54	26.99	0.00	12.50	124.85	1174.08	5.16
	3/9/20 18:03	230.84	27.08	0.00	12.51	124.56	1174.34	5.15
	3/9/20 18:04	230.62	27.06	0.00	12.53	123.91	1174.30	5.14
	3/9/20 18:05	231.07	27.08	0.00	12.54	124.04	1174.29	5.13
	3/9/20 18:06	231.12	27.02	0.00	12.56	124.44	1174.14	5.13
	3/9/20 18:07	231.02	27.01	0.00	12.56	124.38	1173.84	5.12
	3/9/20 18:08	230.71	27.07	0.00	12.56	124.72	1174.23	5.11
	3/9/20 18:09	230.82	27.09	0.00	12.56	124.87	1174.15	5.11
	3/9/20 18:10	230.88	27.08	0.00	12.56	124.37	1173.83	5.10
	3/9/20 18:11	230.82	27.05	0.00	12.56	124.32	1173.83	5.09
	3/9/20 18:12	230.68	27.05	0.00	12.56	124.93	1174.14	5.08
	3/9/20 18:13	230.62	27.06	0.00	12.56	124.34	1174.32	5.08
	3/9/20 18:14	230.74	26.97	0.00	12.56	124.48	1174.54	5.07
	3/9/20 18:15	230.65	27.06	0.00	12.56	124.57	1174.03	5.06
	3/9/20 18:16	230.58	27.04	0.00	12.56	124.06	1174.59	5.06
	3/9/20 18:17	231.30	27.05	0.00	12.56	123.84	1174.79	5.05

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
PM_{10}

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 8:15 - 3/9 13:16)		236.44	27.39	0.00	12.32	144.05	1172.02	247.08
COUNT = 302								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 8:15	241.72	27.82	0.00	12.17	181.22	1173.32	476.96
	3/9/20 8:16	242.02	27.78	0.00	12.16	180.99	1173.82	476.48
	3/9/20 8:17	241.70	27.77	0.00	12.14	180.55	1173.21	476.13
	3/9/20 8:18	241.62	27.78	0.00	12.13	179.42	1173.07	476.94
	3/9/20 8:19	241.33	27.88	0.00	12.12	178.34	1173.26	477.75
	3/9/20 8:20	241.58	27.73	0.00	12.11	177.73	1173.80	478.44
	3/9/20 8:21	241.59	27.75	0.00	12.10	178.03	1173.38	478.80
	3/9/20 8:22	241.52	27.79	0.00	12.09	177.67	1173.52	479.16
	3/9/20 8:23	241.32	27.72	0.00	12.09	176.76	1173.07	479.52
	3/9/20 8:24	241.31	27.77	0.00	12.10	175.34	1173.09	479.88
	3/9/20 8:25	241.32	27.78	0.00	12.10	174.79	1173.46	479.57
	3/9/20 8:26	241.44	27.73	0.00	12.11	174.49	1173.15	478.83
	3/9/20 8:27	241.54	27.74	0.00	12.11	175.11	1173.44	478.09
	3/9/20 8:28	241.67	27.77	0.00	12.11	175.90	1173.24	477.35
	3/9/20 8:29	241.61	27.70	0.00	12.12	176.73	1172.99	476.63
	3/9/20 8:30	241.35	27.82	0.00	12.12	177.28	1172.89	475.90
	3/9/20 8:31	241.47	27.84	0.00	12.12	177.39	1172.78	475.18
	3/9/20 8:32	241.68	27.83	0.00	12.12	176.53	1173.60	474.92
	3/9/20 8:33	241.43	27.74	0.00	12.12	176.25	1173.76	475.07
	3/9/20 8:34	241.64	27.90	0.00	12.12	176.95	1173.04	475.23
	3/9/20 8:35	241.38	27.78	0.00	12.13	178.82	1172.89	475.38
	3/9/20 8:36	241.40	27.74	0.00	12.13	177.88	1173.51	475.53
	3/9/20 8:37	241.56	27.70	0.00	12.13	177.36	1173.56	475.68
	3/9/20 8:38	240.97	27.63	0.00	12.13	176.88	1172.47	475.84
	3/9/20 8:39	241.51	27.81	0.00	12.13	176.03	1173.02	475.99
	3/9/20 8:40	241.07	27.76	0.00	12.13	173.93	1173.26	476.14
	3/9/20 8:41	241.27	27.74	0.00	12.13	173.35	1172.82	475.88
	3/9/20 8:42	241.25	27.68	0.00	12.13	173.07	1172.93	475.60
	3/9/20 8:43	241.36	27.74	0.00	12.13	173.98	1173.07	475.33
	3/9/20 8:44	241.12	27.66	0.00	12.13	175.08	1172.73	475.05
	3/9/20 8:45	241.07	27.65	0.00	12.13	175.75	1173.23	474.77
	3/9/20 8:46	240.91	27.71	0.00	12.14	175.37	1172.88	474.53
	3/9/20 8:47	240.92	27.78	0.00	12.14	174.47	1173.05	474.43
	3/9/20 8:48	240.93	27.68	0.00	12.14	173.12	1172.78	474.33
	3/9/20 8:49	240.92	27.64	0.00	12.15	171.80	1173.07	474.24
	3/9/20 8:50	241.12	27.72	0.00	12.15	171.90	1172.46	474.14
	3/9/20 8:51	240.85	27.74	0.00	12.15	171.23	1172.61	474.04
	3/9/20 8:52	240.96	27.72	0.00	12.16	171.80	1172.72	473.95
	3/9/20 8:53	240.82	27.72	0.00	12.16	171.97	1172.91	473.85
	3/9/20 8:54	240.82	27.76	0.00	12.17	171.51	1172.99	473.76
	3/9/20 8:55	240.81	27.73	0.00	12.17	170.89	1173.07	473.66
	3/9/20 8:56	240.54	27.66	0.00	12.18	170.17	1172.42	473.62
	3/9/20 8:57	240.45	27.66	0.00	12.18	170.53	1173.05	473.63
	3/9/20 8:58	240.55	27.67	0.00	12.18	169.33	1172.54	474.58
	3/9/20 8:59	240.55	27.65	0.00	12.19	168.17	1173.41	478.01
	3/9/20 9:00	240.55	27.70	0.00	12.19	168.00	1173.16	477.43
	3/9/20 9:01	240.50	27.67	0.00	12.20	168.41	1172.66	476.85
	3/9/20 9:02	240.57	27.66	0.00	12.21	168.36	1172.23	476.27
	3/9/20 9:03	240.39	27.63	0.00	12.23	169.10	1173.43	475.69
	3/9/20 9:04	240.06	27.68	0.00	12.24	170.07	1172.73	475.11
	3/9/20 9:05	240.20	27.61	0.00	12.26	168.39	1173.74	474.53
	3/9/20 9:06	240.04	27.68	0.00	12.27	165.17	1173.02	473.94
	3/9/20 9:07	239.72	27.62	0.00	12.29	163.71	1172.98	473.36
	3/9/20 9:08	240.03	27.61	0.00	12.30	161.82	1173.00	473.01
	3/9/20 9:09	239.88	27.66	0.00	12.32	161.64	1172.95	474.29
	3/9/20 9:10	240.19	27.68	0.00	12.33	161.89	1172.77	474.92
	3/9/20 9:11	239.84	27.61	0.00	12.35	161.60	1172.41	474.60
	3/9/20 9:12	239.80	27.66	0.00	12.36	161.96	1172.60	474.28
	3/9/20 9:13	239.66	27.61	0.00	12.37	161.61	1172.72	473.96
	3/9/20 9:14	239.75	27.70	0.00	12.39	161.24	1173.24	473.63
	3/9/20 9:15	239.58	27.64	0.00	12.40	160.51	1172.29	473.31
	3/9/20 9:16	239.49	27.65	0.00	12.42	160.27	1172.54	472.99
	3/9/20 9:17	239.66	27.62	0.00	12.43	160.44	1172.62	472.74
	3/9/20 9:18	239.59	27.65	0.00	12.44	159.58	1172.81	474.10
	3/9/20 9:19	239.32	27.59	0.00	12.46	159.00	1172.81	475.46
	3/9/20 9:20	239.44	27.54	0.00	12.47	157.69	1172.98	476.55
	3/9/20 9:21	239.50	27.62	0.00	12.48	157.35	1172.69	476.54

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 8:15 - 3/9 13:16)	236.44	27.39	0.00	12.32	144.05	1172.02	247.08
COUNT = 302							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 9:22	239.59	27.62	0.00	12.50	156.44	1172.67	476.52
3/9/20 9:23	239.37	27.62	0.00	12.51	156.31	1172.95	476.51
3/9/20 9:24	239.26	27.59	0.00	12.51	155.47	1173.26	476.49
3/9/20 9:25	239.41	27.63	0.00	12.51	153.49	1173.50	475.55
3/9/20 9:26	238.78	27.64	0.00	12.51	153.31	1172.69	474.36
3/9/20 9:27	239.00	27.60	0.00	12.52	153.41	1173.06	473.17
3/9/20 9:28	239.22	27.55	0.00	12.52	153.47	1173.04	473.49
3/9/20 9:29	239.28	27.53	0.00	12.52	153.92	1172.76	474.00
3/9/20 9:30	238.72	27.54	0.00	12.52	153.88	1172.97	474.51
3/9/20 9:31	238.76	27.49	0.00	12.52	152.76	1172.44	475.53
3/9/20 9:32	239.04	27.57	0.00	12.53	150.91	1173.10	474.81
3/9/20 9:33	239.13	27.55	0.00	12.53	150.60	1173.44	471.72
3/9/20 9:34	239.21	27.55	0.00	12.53	152.52	1173.37	472.53
3/9/20 9:35	239.05	27.54	0.00	12.53	152.71	1172.97	476.08
3/9/20 9:36	238.86	27.52	0.00	12.54	153.49	1172.56	475.03
3/9/20 9:37	239.06	27.48	0.00	12.54	153.04	1173.55	473.88
3/9/20 9:38	238.79	27.53	0.00	12.54	152.49	1172.49	473.91
3/9/20 9:39	238.52	27.51	0.00	12.54	152.82	1173.03	475.77
3/9/20 9:40	238.62	27.59	0.00	12.52	152.38	1173.33	475.03
3/9/20 9:41	238.49	27.58	0.00	12.50	151.07	1173.01	474.28
3/9/20 9:42	238.72	27.55	0.00	12.47	149.18	1173.16	473.54
3/9/20 9:43	238.58	27.57	0.00	12.45	148.38	1173.45	472.61
3/9/20 9:44	238.64	27.56	0.00	12.42	148.44	1172.55	471.18
3/9/20 9:45	238.69	27.49	0.00	12.40	149.13	1173.38	470.88
3/9/20 9:46	238.43	27.59	0.00	12.37	149.50	1172.32	471.14
3/9/20 9:47	238.43	27.57	0.00	12.34	150.53	1172.80	470.86
3/9/20 9:48	238.63	27.56	0.00	12.32	150.37	1172.79	470.36
3/9/20 9:49	238.69	27.55	0.00	12.29	150.48	1172.34	470.36
3/9/20 9:50	238.59	27.50	0.00	12.27	149.23	1172.90	471.14
3/9/20 9:51	238.63	27.55	0.00	12.24	149.42	1173.14	471.88
3/9/20 9:52	238.41	27.59	0.00	12.22	149.87	1173.20	472.51
3/9/20 9:53	238.61	27.54	0.00	12.20	150.20	1173.21	473.13
3/9/20 9:54	238.33	27.50	0.00	12.21	150.70	1173.05	474.58
3/9/20 9:55	238.28	27.53	0.00	12.22	148.69	1173.04	473.60
3/9/20 9:56	238.28	27.45	0.00	12.24	146.53	1173.01	472.10
3/9/20 9:57	238.14	27.54	0.00	12.25	146.03	1173.00	472.36
3/9/20 9:58	238.18	27.53	0.00	12.26	146.48	1173.04	472.90
3/9/20 9:59	238.10	27.60	0.00	12.27	146.85	1173.38	473.33
3/9/20 10:00	238.14	27.40	0.00	12.28	147.29	1173.15	473.75
3/9/20 10:01	238.15	27.46	0.00	12.29	146.88	1172.88	474.17
3/9/20 10:02	237.81	27.51	0.00	12.30	147.08	1172.86	474.59
3/9/20 10:03	238.16	27.51	0.00	12.31	147.47	1172.86	475.01
3/9/20 10:04	237.98	27.45	0.00	12.32	147.05	1172.88	475.07
3/9/20 10:05	237.52	27.49	0.00	12.33	146.91	1172.64	473.33
3/9/20 10:06	237.80	27.47	0.00	12.34	146.30	1173.08	471.75
3/9/20 10:07	237.52	27.55	0.00	12.35	145.02	1172.88	473.59
3/9/20 10:08	237.75	27.50	0.00	12.35	144.81	1173.07	473.95
3/9/20 10:09	237.81	27.46	0.00	12.33	144.81	1173.03	473.67
3/9/20 10:10	237.61	27.46	0.00	12.32	145.01	1172.29	473.39
3/9/20 10:11	237.73	27.46	0.00	12.31	145.33	1172.85	473.11
3/9/20 10:12	237.66	27.51	0.00	12.30	145.55	1172.49	472.83
3/9/20 10:13	237.80	27.50	0.00	12.28	145.83	1172.61	472.55
3/9/20 10:14	237.42	27.44	0.00	12.27	145.49	1172.17	472.27
3/9/20 10:15	237.57	27.40	0.00	12.26	144.66	1172.26	474.63
3/9/20 10:16	237.10	27.46	0.00	12.25	143.15	1172.11	475.01
3/9/20 10:17	237.45	27.52	0.00	12.24	141.27	1172.12	474.37
3/9/20 10:18	237.35	27.50	0.00	12.24	140.63	1172.41	473.73
3/9/20 10:19	237.35	27.47	0.00	12.25	140.45	1172.52	473.09
3/9/20 10:20	237.24	27.45	0.00	12.25	141.70	1172.07	472.80
3/9/20 10:21	237.39	27.49	0.00	12.26	142.86	1172.58	472.56
3/9/20 10:22	237.31	27.45	0.00	12.26	143.63	1171.86	472.32
3/9/20 10:23	237.04	27.51	0.00	12.27	144.51	1171.90	472.07
3/9/20 10:24	237.24	27.38	0.00	12.27	143.81	1172.25	471.83
3/9/20 10:25	236.98	27.41	0.00	12.28	142.03	1173.21	471.59
3/9/20 10:26	237.09	27.35	0.00	12.28	141.32	1172.33	471.35
3/9/20 10:27	236.89	27.50	0.00	12.28	140.68	1172.48	471.10
3/9/20 10:28	237.02	27.32	0.00	12.29	140.56	1172.96	473.41

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 8:15 - 3/9 13:16)	236.44	27.39	0.00	12.32	144.05	1172.02	247.08
COUNT = 302							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 10:29	236.72	27.51	0.00	12.29	140.07	1172.42	473.76
3/9/20 10:30	236.73	27.41	0.00	12.30	139.08	1172.29	473.38
3/9/20 10:31	236.86	27.43	0.00	12.30	138.55	1172.08	472.99
3/9/20 10:32	236.75	27.44	0.00	12.31	138.08	1173.07	472.60
3/9/20 10:33	237.03	27.49	0.00	12.31	139.20	1172.44	472.22
3/9/20 10:34	236.98	27.45	0.00	12.32	140.46	1173.04	471.90
3/9/20 10:35	236.73	27.42	0.00	12.32	140.57	1172.45	471.90
3/9/20 10:36	236.64	27.42	0.00	12.33	140.73	1173.27	471.89
3/9/20 10:37	237.00	27.43	0.00	12.33	139.82	1172.48	471.88
3/9/20 10:38	236.51	27.46	0.00	12.34	139.44	1172.18	471.87
3/9/20 10:39	236.72	27.43	0.00	12.34	139.02	1172.79	471.87
3/9/20 10:40	236.57	27.43	0.00	12.35	138.35	1172.34	471.86
3/9/20 10:41	236.54	27.44	0.00	12.35	137.98	1172.23	471.85
3/9/20 10:42	236.22	27.33	0.00	12.36	138.47	1172.54	471.84
3/9/20 10:43	236.04	27.33	0.00	12.36	138.70	1172.34	471.84
3/9/20 10:44	236.41	27.40	0.00	12.37	137.78	1172.75	468.46
3/9/20 10:45	236.27	27.45	0.00	12.37	135.48	1172.29	471.19
3/9/20 10:46	236.12	27.38	0.00	12.38	135.52	1171.81	470.58
3/9/20 10:47	235.90	27.32	0.00	12.38	135.14	1172.09	470.69
3/9/20 10:48	235.92	27.32	0.00	12.38	135.04	1172.45	470.96
3/9/20 10:49	235.98	27.39	0.00	12.39	134.84	1173.18	471.22
3/9/20 10:50	235.89	27.47	0.00	12.39	134.57	1172.58	8.23
3/9/20 10:51	236.28	27.40	0.00	12.37	134.74	1172.94	8.22
3/9/20 10:52	236.27	27.38	0.00	12.36	135.12	1173.00	8.22
3/9/20 10:53	236.29	27.33	0.00	12.34	136.03	1173.24	8.21
3/9/20 10:54	236.16	27.33	0.00	12.33	136.19	1172.72	8.20
3/9/20 10:55	236.22	27.40	0.00	12.32	135.96	1172.62	8.19
3/9/20 10:56	235.92	27.43	0.00	12.30	136.11	1172.58	8.19
3/9/20 10:57	235.94	27.35	0.00	12.29	135.99	1172.56	8.18
3/9/20 10:58	235.79	27.39	0.00	12.29	135.42	1172.31	8.17
3/9/20 10:59	235.93	27.36	0.00	12.31	134.54	1172.91	8.17
3/9/20 11:00	236.08	27.32	0.00	12.34	134.78	1172.46	8.16
3/9/20 11:01	235.98	27.33	0.00	12.36	134.21	1172.56	8.15
3/9/20 11:02	235.65	27.29	0.00	12.38	134.65	1172.93	8.14
3/9/20 11:03	235.77	27.34	0.00	12.41	134.68	1172.33	8.14
3/9/20 11:04	235.85	27.35	0.00	12.43	134.35	1172.39	8.13
3/9/20 11:05	235.61	27.31	0.00	12.45	134.34	1172.28	8.12
3/9/20 11:06	235.93	27.36	0.00	12.48	134.84	1172.78	8.12
3/9/20 11:07	235.81	27.32	0.00	12.50	134.87	1172.09	8.11
3/9/20 11:08	235.73	27.39	0.00	12.51	134.75	1172.56	8.10
3/9/20 11:09	235.77	27.35	0.00	12.51	134.76	1172.41	8.10
3/9/20 11:10	235.69	27.33	0.00	12.50	134.77	1172.99	8.09
3/9/20 11:11	235.87	27.36	0.00	12.50	135.39	1172.83	8.08
3/9/20 11:12	235.92	27.37	0.00	12.50	135.33	1172.63	8.07
3/9/20 11:13	235.81	27.34	0.00	12.50	136.23	1172.97	8.07
3/9/20 11:14	236.24	27.37	0.00	12.50	135.98	1173.45	8.06
3/9/20 11:15	235.69	27.34	0.00	12.50	135.39	1171.82	8.05
3/9/20 11:16	235.68	27.35	0.00	12.50	134.75	1172.08	8.05
3/9/20 11:17	235.55	27.37	0.00	12.50	133.79	1171.94	8.04
3/9/20 11:18	235.25	27.30	0.00	12.50	133.36	1171.57	8.03
3/9/20 11:19	235.50	27.28	0.00	12.49	132.99	1172.51	8.02
3/9/20 11:20	235.26	27.30	0.00	12.49	131.90	1172.24	8.02
3/9/20 11:21	235.23	27.30	0.00	12.49	131.83	1171.42	8.01
3/9/20 11:22	235.06	27.28	0.00	12.49	132.31	1171.85	8.00
3/9/20 11:23	235.17	27.35	0.00	12.49	132.81	1172.44	8.00
3/9/20 11:24	234.48	27.36	0.00	12.49	132.73	1171.58	7.99
3/9/20 11:25	234.73	27.20	0.00	12.49	132.73	1172.31	7.98
3/9/20 11:26	234.43	27.30	0.00	12.49	132.19	1172.06	7.97
3/9/20 11:27	234.95	27.27	0.00	12.49	131.29	1172.38	7.97
3/9/20 11:28	235.05	27.25	0.00	12.48	130.83	1172.10	7.96
3/9/20 11:29	234.99	27.30	0.00	12.48	130.67	1171.92	7.95
3/9/20 11:30	234.61	27.25	0.00	12.48	130.60	1171.07	7.95
3/9/20 11:31	234.44	27.22	0.00	12.48	130.95	1171.57	7.94
3/9/20 11:32	234.45	27.22	0.00	12.48	131.17	1171.66	7.93
3/9/20 11:33	234.35	27.23	0.00	12.48	131.41	1171.58	7.92
3/9/20 11:34	234.11	27.24	0.00	12.47	131.12	1171.49	7.92
3/9/20 11:35	233.91	27.23	0.00	12.44	131.02	1170.73	7.91

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 8:15 - 3/9 13:16)		236.44	27.39	0.00	12.32	144.05	1172.02	247.08
COUNT = 302								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 11:36	233.99	27.22	0.00	12.40	129.96	1171.71	7.90
	3/9/20 11:37	233.80	27.25	0.00	12.37	127.87	1171.92	7.90
	3/9/20 11:38	234.12	27.25	0.00	12.34	127.89	1172.41	7.89
	3/9/20 11:39	233.66	27.24	0.00	12.33	127.26	1171.25	7.88
	3/9/20 11:40	233.79	27.21	0.00	12.33	128.34	1171.61	7.87
	3/9/20 11:41	234.11	27.20	0.00	12.34	128.91	1171.70	7.87
	3/9/20 11:42	233.63	27.19	0.00	12.34	129.82	1171.37	7.86
	3/9/20 11:43	233.66	27.23	0.00	12.35	129.78	1171.47	7.85
	3/9/20 11:44	233.79	27.14	0.00	12.35	128.43	1171.51	7.85
	3/9/20 11:45	233.32	27.16	0.00	12.35	128.15	1171.48	7.84
	3/9/20 11:46	233.28	27.19	0.00	12.36	128.60	1171.42	7.83
	3/9/20 11:47	233.19	27.17	0.00	12.36	128.32	1171.22	7.82
	3/9/20 11:48	233.46	27.15	0.00	12.37	128.21	1171.30	7.82
	3/9/20 11:49	233.72	27.23	0.00	12.37	127.91	1170.77	7.81
	3/9/20 11:50	234.10	27.29	0.00	12.37	128.76	1171.27	7.80
	3/9/20 11:51	233.79	27.28	0.00	12.38	129.43	1171.70	7.80
	3/9/20 11:52	233.95	27.26	0.00	12.38	129.99	1171.58	7.79
	3/9/20 11:53	234.06	27.21	0.00	12.38	130.02	1171.05	7.78
	3/9/20 11:54	233.95	27.26	0.00	12.39	130.48	1170.99	7.77
	3/9/20 11:55	234.10	27.24	0.00	12.39	131.05	1171.30	7.77
	3/9/20 11:56	233.96	27.19	0.00	12.39	131.04	1171.21	7.76
	3/9/20 11:57	233.73	27.16	0.00	12.40	130.92	1171.74	7.75
	3/9/20 11:58	233.93	27.18	0.00	12.40	131.31	1171.88	7.75
	3/9/20 11:59	233.59	27.23	0.00	12.40	130.46	1171.39	7.74
	3/9/20 12:00	233.56	27.21	0.00	12.41	129.79	1171.78	7.73
	3/9/20 12:01	233.43	27.22	0.00	12.41	129.46	1171.39	7.72
	3/9/20 12:02	233.38	27.14	0.00	12.41	128.16	1171.22	7.72
	3/9/20 12:03	233.80	27.17	0.00	12.42	127.85	1171.22	7.71
	3/9/20 12:04	233.46	27.18	0.00	12.42	128.59	1171.04	7.70
	3/9/20 12:05	233.52	27.19	0.00	12.42	129.18	1170.82	7.70
	3/9/20 12:06	233.59	27.07	0.00	12.43	130.60	1171.28	7.69
	3/9/20 12:07	233.23	27.21	0.00	12.43	130.39	1170.90	7.68
	3/9/20 12:08	233.13	27.16	0.00	12.43	130.80	1170.82	7.68
	3/9/20 12:09	232.98	27.23	0.00	12.41	130.38	1170.44	7.67
	3/9/20 12:10	233.22	27.07	0.00	12.39	129.12	1171.15	7.66
	3/9/20 12:11	233.21	27.15	0.00	12.37	129.11	1170.58	7.65
	3/9/20 12:12	233.12	27.22	0.00	12.35	128.73	1170.89	7.65
	3/9/20 12:13	233.50	27.24	0.00	12.34	129.36	1171.45	7.64
	3/9/20 12:14	233.36	27.13	0.00	12.32	129.41	1170.64	7.63
	3/9/20 12:15	233.31	27.20	0.00	12.30	129.86	1170.39	7.63
	3/9/20 12:16	233.42	27.18	0.00	12.28	130.17	1171.26	7.62
	3/9/20 12:17	233.04	27.05	0.00	12.26	130.83	1170.54	7.61
	3/9/20 12:18	233.58	27.17	0.00	12.25	131.37	1171.74	7.60
	3/9/20 12:19	233.26	27.13	0.00	12.23	131.52	1171.15	7.60
	3/9/20 12:20	233.12	27.23	0.00	12.21	132.00	1171.09	7.59
	3/9/20 12:21	233.05	27.11	0.00	12.19	131.64	1170.95	7.58
	3/9/20 12:22	232.54	27.16	0.00	12.17	130.82	1170.22	7.58
	3/9/20 12:23	233.10	27.17	0.00	12.18	131.21	1170.56	7.57
	3/9/20 12:24	232.97	27.11	0.00	12.18	131.00	1170.51	7.56
	3/9/20 12:25	232.69	27.11	0.00	12.18	131.58	1170.61	7.55
	3/9/20 12:26	232.59	27.09	0.00	12.18	132.27	1170.24	7.55
	3/9/20 12:27	232.42	27.17	0.00	12.18	132.75	1170.44	7.54
	3/9/20 12:28	232.76	27.09	0.00	12.18	132.84	1170.46	7.53
	3/9/20 12:29	232.51	27.08	0.00	12.18	132.85	1170.09	7.53
	3/9/20 12:30	231.90	27.04	0.00	12.19	131.65	1170.58	7.52
	3/9/20 12:31	232.05	27.04	0.00	12.19	131.28	1169.96	7.51
	3/9/20 12:32	232.04	27.09	0.00	12.19	131.20	1170.33	7.50
	3/9/20 12:33	232.40	27.10	0.00	12.19	130.22	1169.75	7.50
	3/9/20 12:34	232.63	27.12	0.00	12.19	130.01	1169.97	7.49
	3/9/20 12:35	232.92	27.12	0.00	12.20	129.54	1170.83	7.48
	3/9/20 12:36	232.71	27.14	0.00	12.22	131.02	1170.60	7.48
	3/9/20 12:37	232.80	27.15	0.00	12.24	131.06	1169.84	7.47
	3/9/20 12:38	232.23	27.11	0.00	12.26	131.55	1170.25	7.46
	3/9/20 12:39	232.23	27.05	0.00	12.26	131.12	1170.13	7.45
	3/9/20 12:40	231.87	27.03	0.00	12.26	131.15	1169.65	7.45
	3/9/20 12:41	232.07	27.13	0.00	12.26	131.12	1170.34	7.44
	3/9/20 12:42	231.84	27.01	0.00	12.27	130.62	1170.31	7.43

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 8:15 - 3/9 13:16)		236.44	27.39	0.00	12.32	144.05	1172.02	247.08
COUNT = 302								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 12:43	232.09	27.05	0.00	12.27	129.55	1170.77	7.43
	3/9/20 12:44	232.03	27.05	0.00	12.27	129.03	1170.33	7.42
	3/9/20 12:45	231.91	27.08	0.00	12.28	128.36	1169.60	7.41
	3/9/20 12:46	231.79	27.12	0.00	12.28	128.20	1169.36	7.40
	3/9/20 12:47	231.87	27.08	0.00	12.28	128.11	1170.09	7.40
	3/9/20 12:48	232.28	27.06	0.00	12.28	127.90	1170.60	7.39
	3/9/20 12:49	232.53	27.05	0.00	12.29	128.73	1169.90	7.38
	3/9/20 12:50	232.68	27.08	0.00	12.29	128.56	1170.65	7.38
	3/9/20 12:51	232.01	27.05	0.00	12.29	129.56	1170.17	7.37
	3/9/20 12:52	231.92	27.06	0.00	12.30	129.54	1169.51	7.36
	3/9/20 12:53	232.22	27.07	0.00	12.30	129.47	1169.83	7.35
	3/9/20 12:54	232.19	27.10	0.00	12.30	128.58	1169.70	7.35
	3/9/20 12:55	232.22	27.15	0.00	12.31	127.46	1169.93	7.34
	3/9/20 12:56	232.12	27.05	0.00	12.31	127.90	1170.58	7.33
	3/9/20 12:57	232.27	27.18	0.00	12.31	126.80	1170.47	7.33
	3/9/20 12:58	231.95	27.08	0.00	12.32	126.97	1170.49	7.32
	3/9/20 12:59	231.97	27.15	0.00	12.34	127.03	1170.08	7.31
	3/9/20 13:00	232.07	27.10	0.00	12.36	126.65	1169.50	7.31
	3/9/20 13:01	231.64	27.04	0.00	12.38	126.57	1169.76	7.30
	3/9/20 13:02	231.78	26.97	0.00	12.40	125.90	1170.48	7.29
	3/9/20 13:03	232.04	27.13	0.00	12.40	125.72	1170.39	7.28
	3/9/20 13:04	231.84	27.03	0.00	12.37	125.13	1170.03	7.28
	3/9/20 13:05	232.04	27.03	0.00	12.35	125.32	1170.06	7.27
	3/9/20 13:06	231.90	27.09	0.00	12.32	125.90	1169.78	7.26
	3/9/20 13:07	231.84	27.03	0.00	12.29	126.92	1169.67	7.26
	3/9/20 13:08	231.57	26.98	0.00	12.26	127.06	1169.52	7.25
	3/9/20 13:09	231.71	27.07	0.00	12.25	127.11	1169.73	7.24
	3/9/20 13:10	231.51	26.97	0.00	12.24	127.29	1169.53	7.23
	3/9/20 13:11	231.97	27.07	0.00	12.24	126.83	1170.34	7.23
	3/9/20 13:12	232.05	26.97	0.00	12.24	126.77	1169.62	7.22
	3/9/20 13:13	231.75	27.10	0.00	12.24	126.19	1169.45	7.21
	3/9/20 13:14	231.85	27.01	0.00	12.24	126.55	1170.20	7.21
	3/9/20 13:15	231.44	27.08	0.00	12.24	126.67	1169.14	7.20
	3/9/20 13:16	231.55	27.04	0.00	12.24	127.21	1169.79	7.19

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 13:30 - 3/9 19:48)		231.19	27.05	0.00	12.45	125.57	1172.24	5.79
COUNT = 379								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 13:30	231.63	27.06	0.00	12.24	125.53	1169.21	7.09
	3/9/20 13:31	231.84	27.03	0.00	12.24	125.78	1168.91	7.08
	3/9/20 13:32	231.85	27.04	0.00	12.24	126.82	1168.95	7.08
	3/9/20 13:33	231.51	27.03	0.00	12.24	127.42	1168.99	7.07
	3/9/20 13:34	231.60	26.99	0.00	12.24	127.18	1169.24	7.06
	3/9/20 13:35	231.34	26.98	0.00	12.23	126.79	1168.44	7.06
	3/9/20 13:36	230.91	27.02	0.00	12.23	127.22	1169.08	7.05
	3/9/20 13:37	231.23	26.94	0.00	12.23	126.86	1169.17	7.04
	3/9/20 13:38	231.18	27.04	0.00	12.23	125.46	1169.40	7.03
	3/9/20 13:39	231.15	26.99	0.00	12.23	125.48	1169.46	7.03
	3/9/20 13:40	231.07	27.03	0.00	12.23	125.46	1168.59	7.02
	3/9/20 13:41	231.42	26.99	0.00	12.23	125.09	1169.03	7.01
	3/9/20 13:42	231.38	27.01	0.00	12.23	125.85	1168.89	7.01
	3/9/20 13:43	231.12	26.85	0.00	12.23	126.87	1168.64	7.00
	3/9/20 13:44	231.12	26.95	0.00	12.23	126.32	1169.24	6.99
	3/9/20 13:45	231.35	26.93	0.00	12.23	125.94	1168.86	6.98
	3/9/20 13:46	231.20	26.97	0.00	12.23	125.77	1168.30	6.98
	3/9/20 13:47	231.31	26.91	0.00	12.23	125.61	1168.79	6.97
	3/9/20 13:48	230.76	27.06	0.00	12.23	125.95	1168.89	6.96
	3/9/20 13:49	231.30	26.92	0.00	12.23	125.54	1168.82	6.96
	3/9/20 13:50	231.48	26.99	0.00	12.23	125.81	1168.48	6.95
	3/9/20 13:51	231.38	26.98	0.00	12.26	126.49	1168.62	6.94
	3/9/20 13:52	231.38	26.97	0.00	12.30	127.06	1167.95	6.93
	3/9/20 13:53	231.42	26.97	0.00	12.34	127.04	1168.65	6.93
	3/9/20 13:54	231.35	27.05	0.00	12.32	126.95	1168.99	6.92
	3/9/20 13:55	231.48	26.99	0.00	12.31	126.76	1169.18	6.91
	3/9/20 13:56	231.48	26.98	0.00	12.30	127.01	1168.92	6.91
	3/9/20 13:57	231.67	26.96	0.00	12.28	127.05	1169.10	6.90
	3/9/20 13:58	231.72	27.03	0.00	12.27	126.97	1168.88	6.89
	3/9/20 13:59	231.63	26.96	0.00	12.26	126.80	1169.17	6.89
	3/9/20 14:00	231.60	27.00	0.00	12.24	126.90	1169.28	6.88
	3/9/20 14:01	231.89	27.00	0.00	12.23	126.71	1169.76	6.87
	3/9/20 14:02	231.92	27.01	0.00	12.22	126.63	1168.69	6.86
	3/9/20 14:03	231.77	27.02	0.00	12.21	126.64	1168.72	6.86
	3/9/20 14:04	231.37	27.04	0.00	12.19	127.40	1168.20	6.85
	3/9/20 14:05	231.46	26.96	0.00	12.20	128.69	1168.56	6.84
	3/9/20 14:06	231.13	26.99	0.00	12.22	128.03	1168.66	6.84
	3/9/20 14:07	230.78	26.96	0.00	12.24	126.55	1168.50	6.83
	3/9/20 14:08	230.98	26.96	0.00	12.26	126.34	1168.51	6.82
	3/9/20 14:09	231.23	26.98	0.00	12.29	125.09	1168.71	6.81
	3/9/20 14:10	231.52	26.95	0.00	12.31	125.78	1168.92	6.81
	3/9/20 14:11	231.34	27.01	0.00	12.33	125.69	1168.28	6.80
	3/9/20 14:12	231.41	26.96	0.00	12.34	125.98	1168.77	6.79
	3/9/20 14:13	231.64	26.98	0.00	12.35	126.40	1168.70	6.79
	3/9/20 14:14	231.88	27.03	0.00	12.36	126.72	1168.67	6.78
	3/9/20 14:15	231.94	27.01	0.00	12.37	127.00	1168.96	6.77
	3/9/20 14:16	231.63	26.97	0.00	12.37	128.12	1168.51	6.76
	3/9/20 14:17	231.65	26.95	0.00	12.38	128.27	1168.99	6.76
	3/9/20 14:18	231.44	27.09	0.00	12.39	127.05	1168.54	6.75
	3/9/20 14:19	231.55	26.98	0.00	12.40	126.75	1168.49	6.74
	3/9/20 14:20	231.78	27.00	0.00	12.41	126.30	1168.40	6.74
	3/9/20 14:21	231.35	27.02	0.00	12.42	127.06	1168.32	6.73
	3/9/20 14:22	231.25	26.96	0.00	12.43	127.77	1168.98	6.72
	3/9/20 14:23	231.38	27.01	0.00	12.44	126.25	1167.89	6.71
	3/9/20 14:24	231.36	27.02	0.00	12.45	126.37	1168.82	6.71
	3/9/20 14:25	231.40	26.97	0.00	12.46	126.16	1168.50	6.70
	3/9/20 14:26	231.37	27.05	0.00	12.47	126.60	1168.66	6.69
	3/9/20 14:27	231.29	27.00	0.00	12.48	127.19	1168.45	6.69
	3/9/20 14:28	231.34	27.01	0.00	12.49	127.46	1168.92	6.68
	3/9/20 14:29	231.51	27.02	0.00	12.50	127.36	1168.36	6.67
	3/9/20 14:30	231.31	27.06	0.00	12.51	127.69	1168.53	6.66
	3/9/20 14:31	231.06	27.05	0.00	12.52	127.54	1168.07	6.66
	3/9/20 14:32	230.98	27.04	0.00	12.51	126.85	1168.29	6.65
	3/9/20 14:33	231.03	27.04	0.00	12.49	126.74	1168.36	6.64
	3/9/20 14:34	231.41	27.13	0.00	12.47	126.70	1168.31	6.64
	3/9/20 14:35	230.99	26.98	0.00	12.46	127.45	1167.91	6.63
	3/9/20 14:36	231.22	27.04	0.00	12.45	127.10	1168.57	6.62

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 13:30 - 3/9 19:48)	231.19	27.05	0.00	12.45	125.57	1172.24	5.79
COUNT = 379							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 14:37	231.39	27.00	0.00	12.44	127.33	1168.27	6.61
3/9/20 14:38	231.70	27.01	0.00	12.43	127.41	1168.60	6.61
3/9/20 14:39	231.38	27.03	0.00	12.43	127.85	1168.14	6.60
3/9/20 14:40	231.33	27.04	0.00	12.42	128.15	1168.31	6.59
3/9/20 14:41	231.30	27.05	0.00	12.46	127.88	1167.94	6.59
3/9/20 14:42	231.44	26.99	0.00	12.48	128.19	1168.41	6.58
3/9/20 14:43	231.25	27.08	0.00	12.49	127.53	1168.07	6.57
3/9/20 14:44	231.22	26.97	0.00	12.49	127.92	1167.93	6.56
3/9/20 14:45	230.88	27.00	0.00	12.49	127.95	1167.84	6.56
3/9/20 14:46	230.82	26.97	0.00	12.49	127.60	1168.17	6.55
3/9/20 14:47	231.22	27.02	0.00	12.50	127.17	1167.74	6.54
3/9/20 14:48	231.07	27.01	0.00	12.50	126.84	1168.31	6.54
3/9/20 14:49	230.81	26.97	0.00	12.50	126.57	1167.98	6.53
3/9/20 14:50	230.96	26.93	0.00	12.50	126.84	1168.00	6.52
3/9/20 14:51	230.96	26.98	0.00	12.51	127.14	1168.17	6.52
3/9/20 14:52	231.00	26.96	0.00	12.51	127.66	1168.28	6.51
3/9/20 14:53	230.96	26.99	0.00	12.51	127.45	1168.23	6.50
3/9/20 14:54	230.97	26.91	0.00	12.51	127.44	1168.29	6.49
3/9/20 14:55	230.99	26.92	0.00	12.51	127.15	1168.10	6.49
3/9/20 14:56	230.80	26.97	0.00	12.52	126.48	1167.86	6.48
3/9/20 14:57	230.98	26.88	0.00	12.52	126.35	1167.94	6.47
3/9/20 14:58	231.17	27.02	0.00	12.52	125.90	1168.20	6.47
3/9/20 14:59	230.92	26.87	0.00	12.52	126.08	1167.89	6.46
3/9/20 15:00	230.91	26.98	0.00	12.53	126.65	1167.56	6.45
3/9/20 15:01	230.66	26.90	0.00	12.53	127.09	1167.80	6.44
3/9/20 15:02	230.70	26.94	0.00	12.52	126.99	1167.68	6.44
3/9/20 15:03	230.70	26.91	0.00	12.49	127.29	1168.41	6.43
3/9/20 15:04	230.74	26.93	0.00	12.46	126.73	1168.46	6.42
3/9/20 15:05	230.89	26.98	0.00	12.44	126.77	1168.13	6.42
3/9/20 15:06	230.98	26.99	0.00	12.41	126.68	1168.47	6.41
3/9/20 15:07	230.95	26.93	0.00	12.38	126.65	1168.10	6.40
3/9/20 15:08	230.75	26.92	0.00	12.37	126.34	1168.18	6.39
3/9/20 15:09	230.74	26.87	0.00	12.36	126.34	1167.46	6.39
3/9/20 15:10	231.01	26.97	0.00	12.35	126.66	1168.07	6.38
3/9/20 15:11	230.64	26.90	0.00	12.35	126.85	1167.66	6.37
3/9/20 15:12	230.38	26.90	0.00	12.34	127.62	1167.64	6.37
3/9/20 15:13	230.52	26.90	0.00	12.33	127.26	1168.10	6.36
3/9/20 15:14	230.63	26.92	0.00	12.32	126.80	1168.10	6.35
3/9/20 15:15	231.06	26.87	0.00	12.31	126.09	1167.82	6.34
3/9/20 15:16	231.19	27.01	0.00	12.30	126.42	1167.75	6.34
3/9/20 15:17	230.97	26.93	0.00	12.30	126.86	1167.74	6.33
3/9/20 15:18	230.72	26.96	0.00	12.29	128.31	1168.45	6.32
3/9/20 15:19	230.89	26.88	0.00	12.28	128.35	1168.18	6.32
3/9/20 15:20	230.60	26.96	0.00	12.27	127.18	1167.65	6.31
3/9/20 15:21	230.56	26.99	0.00	12.26	126.67	1168.15	6.30
3/9/20 15:22	230.62	26.87	0.00	12.25	126.53	1167.45	6.29
3/9/20 15:23	230.82	26.92	0.00	12.24	126.42	1168.26	6.29
3/9/20 15:24	230.67	26.96	0.00	12.24	126.08	1167.88	6.28
3/9/20 15:25	230.63	26.92	0.00	12.25	126.79	1167.53	6.27
3/9/20 15:26	230.46	27.00	0.00	12.28	126.78	1167.78	6.27
3/9/20 15:27	230.22	26.91	0.00	12.30	126.72	1167.24	6.26
3/9/20 15:28	230.33	26.89	0.00	12.33	126.66	1167.17	6.25
3/9/20 15:29	230.78	26.98	0.00	12.35	127.09	1168.06	6.24
3/9/20 15:30	230.59	26.91	0.00	12.38	126.53	1168.19	6.24
3/9/20 15:31	230.60	26.90	0.00	12.40	127.18	1168.18	6.23
3/9/20 15:32	230.87	26.95	0.00	12.43	127.38	1168.39	6.22
3/9/20 15:33	230.79	26.98	0.00	12.45	126.33	1167.80	6.22
3/9/20 15:34	230.60	26.93	0.00	12.48	125.84	1167.46	6.21
3/9/20 15:35	230.69	27.02	0.00	12.50	125.96	1167.68	6.20
3/9/20 15:36	230.53	26.93	0.00	12.53	126.59	1167.93	6.19
3/9/20 15:37	230.58	26.90	0.00	12.56	126.63	1168.15	6.19
3/9/20 15:38	230.64	27.01	0.00	12.36	126.52	1167.44	6.18
3/9/20 15:39	230.35	26.94	0.00	12.37	126.87	1167.83	6.17
3/9/20 15:40	230.59	26.95	0.00	12.38	126.63	1167.89	6.17
3/9/20 15:41	230.92	26.98	0.00	12.39	125.63	1167.47	6.16
3/9/20 15:42	230.76	26.98	0.00	12.40	125.34	1167.64	6.15
3/9/20 15:43	230.52	26.98	0.00	12.40	124.58	1167.55	6.15

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 13:30 - 3/9 19:48)		231.19	27.05	0.00	12.45	125.57	1172.24	5.79
COUNT = 379								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 15:44	230.51	26.96	0.00	12.41	125.50	1166.82	6.14
	3/9/20 15:45	230.49	26.94	0.00	12.42	124.62	1167.02	6.13
	3/9/20 15:46	230.54	26.93	0.00	12.43	124.69	1166.88	6.12
	3/9/20 15:47	230.35	26.90	0.00	12.44	124.60	1167.57	6.12
	3/9/20 15:48	230.36	26.96	0.00	12.45	124.46	1167.13	6.11
	3/9/20 15:49	231.25	27.07	0.00	12.45	125.55	1174.35	6.10
	3/9/20 15:50	230.85	27.10	0.00	12.46	126.11	1175.13	6.10
	3/9/20 15:51	230.86	27.14	0.00	12.44	126.54	1174.67	6.09
	3/9/20 15:52	230.58	27.10	0.00	12.43	126.01	1174.62	6.08
	3/9/20 15:53	230.81	27.11	0.00	12.41	124.92	1175.08	6.07
	3/9/20 15:54	230.98	27.08	0.00	12.39	123.25	1174.33	6.07
	3/9/20 15:55	230.89	27.09	0.00	12.38	123.20	1174.30	6.06
	3/9/20 15:56	230.78	27.13	0.00	12.37	124.14	1174.82	6.05
	3/9/20 15:57	230.24	27.09	0.00	12.41	124.92	1174.58	6.05
	3/9/20 15:58	230.54	27.05	0.00	12.45	124.22	1174.66	6.04
	3/9/20 15:59	231.10	27.16	0.00	12.49	122.75	1174.74	6.03
	3/9/20 16:00	230.85	27.06	0.00	12.53	122.54	1174.32	6.02
	3/9/20 16:01	230.84	27.03	0.00	12.52	123.03	1174.65	6.02
	3/9/20 16:02	230.96	27.12	0.00	12.50	123.85	1174.41	6.01
	3/9/20 16:03	230.93	27.07	0.00	12.47	123.62	1174.42	6.00
	3/9/20 16:04	231.08	27.10	0.00	12.44	124.70	1174.79	6.00
	3/9/20 16:05	231.11	27.09	0.00	12.41	125.02	1174.88	5.99
	3/9/20 16:06	231.26	27.09	0.00	12.39	125.10	1174.92	5.98
	3/9/20 16:07	231.20	27.16	0.00	12.36	125.07	1174.73	5.97
	3/9/20 16:08	231.21	27.17	0.00	12.43	124.74	1175.15	5.97
	3/9/20 16:09	231.26	27.07	0.00	12.47	124.40	1174.28	5.96
	3/9/20 16:10	231.38	27.10	0.00	12.48	123.80	1174.58	5.95
	3/9/20 16:11	230.96	27.08	0.00	12.49	123.69	1174.58	5.95
	3/9/20 16:12	230.84	27.04	0.00	12.50	123.37	1174.61	5.94
	3/9/20 16:13	230.40	27.07	0.00	12.50	122.92	1174.46	5.93
	3/9/20 16:14	230.54	27.09	0.00	12.51	122.48	1174.43	5.92
	3/9/20 16:15	230.75	27.14	0.00	12.51	122.61	1174.45	5.92
	3/9/20 16:16	231.05	27.08	0.00	12.50	122.84	1174.51	5.91
	3/9/20 16:17	230.75	27.04	0.00	12.49	122.55	1174.16	5.90
	3/9/20 16:18	230.72	27.03	0.00	12.48	122.99	1174.71	5.90
	3/9/20 16:19	230.54	27.02	0.00	12.48	122.62	1173.96	5.89
	3/9/20 16:20	230.66	27.05	0.00	12.47	122.61	1174.19	5.88
	3/9/20 16:21	230.79	27.12	0.00	12.46	123.18	1174.64	5.87
	3/9/20 16:22	231.16	27.13	0.00	12.45	122.87	1175.04	5.87
	3/9/20 16:23	230.83	27.11	0.00	12.44	123.33	1174.50	5.86
	3/9/20 16:24	230.94	27.13	0.00	12.43	123.18	1174.71	5.85
	3/9/20 16:25	230.98	27.12	0.00	12.42	123.42	1174.40	5.85
	3/9/20 16:26	230.75	27.13	0.00	12.41	124.40	1174.75	5.84
	3/9/20 16:27	231.02	27.08	0.00	12.42	123.86	1174.29	5.83
	3/9/20 16:28	231.19	27.11	0.00	12.44	123.56	1174.23	5.82
	3/9/20 16:29	230.81	27.06	0.00	12.45	123.54	1173.95	5.82
	3/9/20 16:30	230.38	27.10	0.00	12.47	123.45	1174.24	5.81
	3/9/20 16:31	230.46	27.03	0.00	12.49	123.75	1174.45	5.80
	3/9/20 16:32	230.64	27.05	0.00	12.51	123.01	1174.60	5.80
	3/9/20 16:33	230.74	27.08	0.00	12.49	122.52	1174.00	5.79
	3/9/20 16:34	230.92	27.03	0.00	12.46	122.63	1174.61	5.78
	3/9/20 16:35	231.14	27.21	0.00	12.44	123.50	1174.39	5.77
	3/9/20 16:36	230.93	27.10	0.00	12.42	123.90	1174.62	5.77
	3/9/20 16:37	230.60	27.11	0.00	12.39	123.12	1174.43	5.76
	3/9/20 16:38	230.51	27.14	0.00	12.37	123.44	1174.95	5.75
	3/9/20 16:39	230.62	27.06	0.00	12.34	123.72	1174.32	5.75
	3/9/20 16:40	230.69	27.15	0.00	12.32	123.34	1174.84	5.74
	3/9/20 16:41	230.81	27.01	0.00	12.29	123.35	1174.57	5.73
	3/9/20 16:42	230.35	27.00	0.00	12.39	123.65	1174.18	5.73
	3/9/20 16:43	230.14	27.01	0.00	12.45	123.58	1174.65	5.72
	3/9/20 16:44	229.95	27.07	0.00	12.45	123.01	1174.22	5.71
	3/9/20 16:45	229.94	27.04	0.00	12.44	121.50	1174.13	5.70
	3/9/20 16:46	230.06	26.99	0.00	12.44	121.07	1174.91	5.70
	3/9/20 16:47	230.17	27.00	0.00	12.43	121.37	1173.54	5.69
	3/9/20 16:48	230.40	27.04	0.00	12.43	121.40	1174.14	5.68
	3/9/20 16:49	230.01	27.07	0.00	12.43	122.46	1174.81	5.68
	3/9/20 16:50	230.01	27.04	0.00	12.42	122.57	1174.18	5.67

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 13:30 - 3/9 19:48) COUNT = 379	231.19	27.05	0.00	12.45	125.57	1172.24	5.79

Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 16:51	229.89	26.94	0.00	12.42	122.98	1173.74	5.66
3/9/20 16:52	230.02	27.03	0.00	12.41	123.54	1173.94	5.65
3/9/20 16:53	230.07	27.00	0.00	12.41	122.84	1174.12	5.65
3/9/20 16:54	230.20	27.00	0.00	12.41	122.17	1174.28	5.64
3/9/20 16:55	230.58	27.09	0.00	12.40	122.66	1174.37	5.63
3/9/20 16:56	230.57	27.10	0.00	12.40	123.58	1174.09	5.63
3/9/20 16:57	230.80	27.10	0.00	12.40	124.30	1174.41	5.62
3/9/20 16:58	230.32	27.00	0.00	12.39	124.83	1174.05	5.61
3/9/20 16:59	230.46	27.03	0.00	12.39	125.13	1174.49	5.60
3/9/20 17:00	230.33	27.00	0.00	12.38	124.47	1174.49	5.60
3/9/20 17:01	230.31	27.02	0.00	12.38	123.10	1174.33	5.59
3/9/20 17:02	230.79	27.08	0.00	12.38	122.63	1174.35	5.58
3/9/20 17:03	230.41	27.08	0.00	12.37	122.41	1174.19	5.58
3/9/20 17:04	230.48	27.08	0.00	12.37	122.74	1173.75	5.57
3/9/20 17:05	230.48	27.05	0.00	12.37	123.38	1173.90	5.56
3/9/20 17:06	230.38	27.10	0.00	12.36	123.53	1174.00	5.55
3/9/20 17:07	230.35	27.03	0.00	12.37	124.13	1173.28	5.55
3/9/20 17:08	230.09	27.12	0.00	12.39	124.09	1174.07	5.54
3/9/20 17:09	230.40	27.09	0.00	12.41	124.53	1173.69	5.53
3/9/20 17:10	230.14	27.01	0.00	12.43	123.96	1173.53	5.53
3/9/20 17:11	230.13	27.01	0.00	12.45	123.59	1174.15	5.52
3/9/20 17:12	229.85	27.01	0.00	12.47	122.91	1173.75	5.51
3/9/20 17:13	229.50	26.98	0.00	12.49	122.63	1174.08	5.50
3/9/20 17:14	230.06	27.02	0.00	12.51	122.54	1173.61	5.50
3/9/20 17:15	229.97	26.98	0.00	12.52	122.96	1173.66	5.49
3/9/20 17:16	229.83	26.96	0.00	12.52	123.71	1173.75	5.48
3/9/20 17:17	230.26	27.01	0.00	12.52	123.53	1173.67	5.48
3/9/20 17:18	230.29	27.01	0.00	12.52	123.39	1174.04	5.47
3/9/20 17:19	230.07	26.99	0.00	12.52	123.36	1173.27	5.46
3/9/20 17:20	230.10	27.01	0.00	12.52	123.49	1173.25	5.45
3/9/20 17:21	230.19	27.05	0.00	12.52	123.85	1173.66	5.45
3/9/20 17:22	230.26	27.04	0.00	12.52	124.22	1173.85	5.44
3/9/20 17:23	230.44	27.02	0.00	12.52	124.29	1174.40	5.43
3/9/20 17:24	230.34	27.00	0.00	12.52	124.59	1174.29	5.43
3/9/20 17:25	229.93	27.01	0.00	12.52	124.20	1173.98	5.42
3/9/20 17:26	230.27	27.05	0.00	12.52	123.99	1173.33	5.41
3/9/20 17:27	230.19	26.89	0.00	12.52	123.89	1174.12	5.40
3/9/20 17:28	230.20	27.03	0.00	12.52	124.62	1174.21	5.40
3/9/20 17:29	230.07	26.98	0.00	12.52	123.78	1173.74	5.39
3/9/20 17:30	230.04	27.00	0.00	12.52	123.44	1173.51	5.38
3/9/20 17:31	229.80	26.93	0.00	12.52	123.48	1174.17	5.38
3/9/20 17:32	230.47	27.07	0.00	12.52	123.43	1174.00	5.37
3/9/20 17:33	230.03	27.04	0.00	12.52	123.31	1174.38	5.36
3/9/20 17:34	230.27	27.05	0.00	12.52	123.55	1173.79	5.36
3/9/20 17:35	230.28	26.97	0.00	12.52	123.86	1173.47	5.35
3/9/20 17:36	230.19	27.02	0.00	12.52	124.09	1173.89	5.34
3/9/20 17:37	230.33	27.01	0.00	12.51	124.53	1174.09	5.33
3/9/20 17:38	230.62	27.09	0.00	12.50	124.37	1174.37	5.33
3/9/20 17:39	230.28	26.96	0.00	12.49	124.65	1174.03	5.32
3/9/20 17:40	230.45	26.99	0.00	12.48	125.14	1174.05	5.31
3/9/20 17:41	230.47	27.01	0.00	12.47	124.80	1173.47	5.31
3/9/20 17:42	230.48	27.02	0.00	12.46	124.15	1173.92	5.30
3/9/20 17:43	230.52	26.98	0.00	12.45	123.53	1173.74	5.29
3/9/20 17:44	230.88	27.06	0.00	12.43	123.57	1174.07	5.28
3/9/20 17:45	230.73	27.08	0.00	12.42	124.11	1174.43	5.28
3/9/20 17:46	230.89	27.01	0.00	12.41	124.66	1173.95	5.27
3/9/20 17:47	230.64	26.98	0.00	12.40	125.10	1173.82	5.26
3/9/20 17:48	230.58	27.01	0.00	12.39	125.18	1174.61	5.26
3/9/20 17:49	230.50	27.03	0.00	12.38	124.81	1173.78	5.25
3/9/20 17:50	230.44	27.02	0.00	12.37	123.96	1174.31	5.24
3/9/20 17:51	230.57	27.07	0.00	12.36	123.93	1173.39	5.23
3/9/20 17:52	230.40	27.01	0.00	12.35	123.93	1173.88	5.23
3/9/20 17:53	230.73	27.06	0.00	12.36	123.98	1173.99	5.22
3/9/20 17:54	230.76	27.11	0.00	12.38	123.82	1173.54	5.21
3/9/20 17:55	231.05	27.10	0.00	12.39	124.22	1173.98	5.21
3/9/20 17:56	230.91	27.06	0.00	12.41	124.18	1173.72	5.20
3/9/20 17:57	230.86	27.10	0.00	12.42	124.02	1174.03	5.19

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 13:30 - 3/9 19:48)	231.19	27.05	0.00	12.45	125.57	1172.24	5.79
COUNT = 379							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 17:58	231.05	27.07	0.00	12.44	124.38	1174.51	5.18
3/9/20 17:59	230.91	27.10	0.00	12.45	124.49	1174.27	5.18
3/9/20 18:00	231.06	27.05	0.00	12.47	124.44	1173.80	5.17
3/9/20 18:01	230.36	27.08	0.00	12.48	124.94	1174.47	5.16
3/9/20 18:02	230.54	26.99	0.00	12.50	124.85	1174.08	5.16
3/9/20 18:03	230.84	27.08	0.00	12.51	124.56	1174.34	5.15
3/9/20 18:04	230.62	27.06	0.00	12.53	123.91	1174.30	5.14
3/9/20 18:05	231.07	27.08	0.00	12.54	124.04	1174.29	5.13
3/9/20 18:06	231.12	27.02	0.00	12.56	124.44	1174.14	5.13
3/9/20 18:07	231.02	27.01	0.00	12.56	124.38	1173.84	5.12
3/9/20 18:08	230.71	27.07	0.00	12.56	124.72	1174.23	5.11
3/9/20 18:09	230.82	27.09	0.00	12.56	124.87	1174.15	5.11
3/9/20 18:10	230.88	27.08	0.00	12.56	124.37	1173.83	5.10
3/9/20 18:11	230.82	27.05	0.00	12.56	124.32	1173.83	5.09
3/9/20 18:12	230.68	27.05	0.00	12.56	124.93	1174.14	5.08
3/9/20 18:13	230.62	27.06	0.00	12.56	124.34	1174.32	5.08
3/9/20 18:14	230.74	26.97	0.00	12.56	124.48	1174.54	5.07
3/9/20 18:15	230.65	27.06	0.00	12.56	124.57	1174.03	5.06
3/9/20 18:16	230.58	27.04	0.00	12.56	124.06	1174.59	5.06
3/9/20 18:17	231.30	27.05	0.00	12.56	123.84	1174.79	5.05
3/9/20 18:18	231.05	27.03	0.00	12.56	123.93	1174.14	5.04
3/9/20 18:19	230.65	27.01	0.00	12.56	125.18	1173.94	5.03
3/9/20 18:20	230.49	27.07	0.00	12.56	125.26	1174.09	5.03
3/9/20 18:21	230.70	27.01	0.00	12.55	125.63	1174.24	5.02
3/9/20 18:22	230.72	27.03	0.00	12.55	124.51	1173.86	5.01
3/9/20 18:23	230.76	27.05	0.00	12.55	124.01	1174.50	5.01
3/9/20 18:24	230.56	27.03	0.00	12.55	123.42	1174.72	5.00
3/9/20 18:25	231.05	27.01	0.00	12.54	123.58	1175.02	4.99
3/9/20 18:26	230.94	27.07	0.00	12.54	123.69	1174.17	4.98
3/9/20 18:27	230.83	27.06	0.00	12.54	124.18	1174.27	4.98
3/9/20 18:28	230.92	27.00	0.00	12.54	124.09	1174.29	4.97
3/9/20 18:29	231.28	27.07	0.00	12.53	124.80	1174.51	4.96
3/9/20 18:30	231.09	26.98	0.00	12.53	125.20	1174.32	4.96
3/9/20 18:31	231.20	27.04	0.00	12.53	124.70	1174.64	4.95
3/9/20 18:32	230.96	27.08	0.00	12.53	124.39	1174.08	4.94
3/9/20 18:33	230.84	27.08	0.00	12.52	124.57	1174.33	4.94
3/9/20 18:34	231.21	27.03	0.00	12.52	124.97	1174.44	4.93
3/9/20 18:35	231.14	27.04	0.00	12.52	125.30	1174.71	4.92
3/9/20 18:36	231.51	27.05	0.00	12.52	124.89	1174.82	4.91
3/9/20 18:37	231.27	27.00	0.00	12.51	124.63	1173.90	4.91
3/9/20 18:38	231.48	27.10	0.00	12.51	125.21	1174.16	4.90
3/9/20 18:39	231.49	27.05	0.00	12.51	124.66	1174.46	4.89
3/9/20 18:40	231.07	27.05	0.00	12.51	124.68	1174.19	4.89
3/9/20 18:41	231.64	27.08	0.00	12.51	124.98	1174.36	4.89
3/9/20 18:42	231.67	27.05	0.00	12.51	125.02	1174.14	4.89
3/9/20 18:43	231.59	27.05	0.00	12.52	125.13	1174.46	4.89
3/9/20 18:44	231.65	27.08	0.00	12.53	125.74	1174.72	4.89
3/9/20 18:45	231.64	27.10	0.00	12.53	126.03	1174.35	4.88
3/9/20 18:46	231.91	27.12	0.00	12.54	125.44	1175.10	4.88
3/9/20 18:47	231.79	27.12	0.00	12.55	125.30	1174.62	4.88
3/9/20 18:48	231.44	27.10	0.00	12.55	125.31	1174.98	4.88
3/9/20 18:49	231.86	27.14	0.00	12.56	124.95	1174.66	4.88
3/9/20 18:50	231.93	27.03	0.00	12.57	125.09	1174.61	4.88
3/9/20 18:51	231.46	27.09	0.00	12.57	125.55	1174.61	4.88
3/9/20 18:52	231.71	27.10	0.00	12.58	125.24	1174.24	4.88
3/9/20 18:53	232.07	27.14	0.00	12.59	125.01	1175.11	4.88
3/9/20 18:54	231.76	27.15	0.00	12.59	124.44	1174.88	4.88
3/9/20 18:55	231.85	27.14	0.00	12.60	124.90	1175.06	4.88
3/9/20 18:56	232.28	27.12	0.00	12.61	125.28	1175.44	4.88
3/9/20 18:57	232.39	27.14	0.00	12.61	125.62	1174.73	4.88
3/9/20 18:58	232.43	27.10	0.00	12.62	126.54	1175.01	4.88
3/9/20 18:59	232.34	27.17	0.00	12.63	126.18	1174.75	4.88
3/9/20 19:00	232.44	27.16	0.00	12.63	126.86	1174.73	4.87
3/9/20 19:01	232.53	27.18	0.00	12.64	126.79	1174.81	4.87
3/9/20 19:02	232.49	27.22	0.00	12.65	126.77	1174.95	4.87
3/9/20 19:03	232.64	27.13	0.00	12.65	126.89	1175.82	4.87
3/9/20 19:04	232.37	27.16	0.00	12.66	127.06	1175.06	4.87

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 13:30 - 3/9 19:48)		231.19	27.05	0.00	12.45	125.57	1172.24	5.79
COUNT = 379								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 19:05	232.56	27.19	0.00	12.67	129.57	1175.44	4.87
	3/9/20 19:06	232.65	27.16	0.00	12.67	128.19	1175.28	4.87
	3/9/20 19:07	232.90	27.22	0.00	12.67	127.12	1175.09	4.87
	3/9/20 19:08	232.85	27.26	0.00	12.66	127.02	1175.18	4.87
	3/9/20 19:09	232.68	27.12	0.00	12.66	127.42	1175.61	4.87
	3/9/20 19:10	232.75	27.21	0.00	12.65	127.98	1175.07	4.87
	3/9/20 19:11	232.94	27.18	0.00	12.65	127.63	1175.33	4.87
	3/9/20 19:12	232.38	27.14	0.00	12.65	127.64	1174.87	4.87
	3/9/20 19:13	232.83	27.22	0.00	12.64	127.08	1175.76	4.87
	3/9/20 19:14	232.77	27.26	0.00	12.64	126.81	1175.61	4.87
	3/9/20 19:15	232.84	27.16	0.00	12.63	126.74	1175.05	4.86
	3/9/20 19:16	232.62	27.21	0.00	12.63	127.40	1175.95	4.86
	3/9/20 19:17	232.88	27.19	0.00	12.62	127.33	1175.80	4.86
	3/9/20 19:18	232.87	27.22	0.00	12.62	127.99	1174.79	4.86
	3/9/20 19:19	232.85	27.17	0.00	12.62	127.59	1175.40	4.86
	3/9/20 19:20	232.67	27.22	0.00	12.61	129.04	1175.63	4.86
	3/9/20 19:21	232.91	27.19	0.00	12.61	127.81	1175.12	4.86
	3/9/20 19:22	233.12	27.22	0.00	12.60	127.24	1175.52	4.86
	3/9/20 19:23	233.31	27.25	0.00	12.60	127.29	1174.98	4.86
	3/9/20 19:24	233.22	27.21	0.00	12.59	127.69	1175.27	4.86
	3/9/20 19:25	233.40	27.23	0.00	12.59	128.14	1175.14	4.86
	3/9/20 19:26	233.44	27.20	0.00	12.59	128.65	1175.56	4.86
	3/9/20 19:27	233.72	27.24	0.00	12.58	128.97	1175.68	4.86
	3/9/20 19:28	233.48	27.28	0.00	12.58	129.57	1175.25	4.86
	3/9/20 19:29	233.24	27.17	0.00	12.57	130.07	1175.57	4.86
	3/9/20 19:30	232.77	27.23	0.00	12.57	129.77	1175.64	4.85
	3/9/20 19:31	233.14	27.17	0.00	12.56	128.55	1175.89	4.85
	3/9/20 19:32	233.37	27.24	0.00	12.57	127.52	1175.09	4.85
	3/9/20 19:33	233.29	27.19	0.00	12.57	127.30	1175.81	4.85
	3/9/20 19:34	233.66	27.26	0.00	12.57	128.00	1175.32	4.85
	3/9/20 19:35	233.21	27.19	0.00	12.57	128.49	1174.62	4.85
	3/9/20 19:36	233.65	27.22	0.00	12.57	129.04	1175.29	4.85
	3/9/20 19:37	233.71	27.27	0.00	12.57	129.38	1175.39	4.85
	3/9/20 19:38	233.58	27.19	0.00	12.57	129.77	1175.68	4.85
	3/9/20 19:39	233.59	27.26	0.00	12.57	129.23	1175.81	4.85
	3/9/20 19:40	233.94	27.26	0.00	12.57	128.38	1175.96	4.85
	3/9/20 19:41	233.61	27.29	0.00	12.57	128.04	1175.60	4.85
	3/9/20 19:42	233.82	27.27	0.00	12.57	128.49	1176.09	4.85
	3/9/20 19:43	233.70	27.27	0.00	12.57	129.43	1175.40	4.85
	3/9/20 19:44	233.90	27.30	0.00	12.57	129.54	1175.84	4.85
	3/9/20 19:45	234.23	27.29	0.00	12.57	130.60	1176.11	4.85
	3/9/20 19:46	234.07	27.29	0.00	12.57	131.01	1175.76	4.84
	3/9/20 19:47	234.57	27.33	0.00	12.57	131.85	1175.78	4.84
	3/9/20 19:48	234.43	27.33	0.00	12.57	131.66	1175.73	4.84

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 7:23 - 3/10 12:15)	237.11	27.49	0.94	12.31	144.47	1170.02	4.46
COUNT = 293							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 7:23	240.29	27.78	1.54	12.36	168.57	1171.79	4.49
3/10/20 7:24	240.52	27.76	1.53	12.35	168.58	1172.20	4.49
3/10/20 7:25	240.50	27.77	1.52	12.34	168.54	1171.77	4.49
3/10/20 7:26	240.24	27.72	1.52	12.33	168.40	1171.44	4.49
3/10/20 7:27	240.15	27.72	1.51	12.32	168.55	1172.17	4.49
3/10/20 7:28	240.28	27.75	1.50	12.31	168.70	1171.16	4.49
3/10/20 7:29	240.29	27.72	1.50	12.31	168.74	1171.65	4.49
3/10/20 7:30	240.07	27.76	1.49	12.30	168.70	1171.54	4.49
3/10/20 7:31	239.88	27.75	1.48	12.29	168.93	1171.46	4.49
3/10/20 7:32	240.36	27.72	1.48	12.28	168.73	1172.08	4.49
3/10/20 7:33	240.32	27.71	1.47	12.27	169.91	1171.58	4.49
3/10/20 7:34	239.87	27.66	1.47	12.26	169.56	1171.46	4.49
3/10/20 7:35	240.14	27.74	1.46	12.25	168.79	1171.34	4.49
3/10/20 7:36	240.30	27.80	1.45	12.23	168.42	1171.61	4.49
3/10/20 7:37	239.96	27.75	1.45	12.22	168.59	1171.39	4.49
3/10/20 7:38	240.16	27.72	1.44	12.20	169.01	1171.11	4.49
3/10/20 7:39	240.00	27.81	1.43	12.20	168.74	1171.43	4.48
3/10/20 7:40	239.94	27.71	1.43	12.20	168.76	1171.30	4.48
3/10/20 7:41	240.01	27.78	1.42	12.20	168.52	1171.32	4.48
3/10/20 7:42	239.85	27.72	1.41	12.20	168.17	1171.08	4.48
3/10/20 7:43	239.75	27.68	1.41	12.21	166.67	1171.61	4.48
3/10/20 7:44	239.89	27.78	1.40	12.21	165.67	1171.45	4.48
3/10/20 7:45	239.64	27.71	1.39	12.21	166.43	1171.38	4.48
3/10/20 7:46	239.64	27.69	1.39	12.22	165.12	1171.88	4.48
3/10/20 7:47	239.68	27.65	1.38	12.22	164.20	1171.73	4.48
3/10/20 7:48	239.99	27.61	1.37	12.22	162.97	1171.44	4.48
3/10/20 7:49	239.59	27.69	1.37	12.23	162.66	1171.70	4.48
3/10/20 7:50	239.63	27.66	1.36	12.23	161.87	1171.71	4.48
3/10/20 7:51	239.53	27.74	1.36	12.23	162.41	1171.23	4.48
3/10/20 7:52	239.56	27.65	1.35	12.23	161.56	1170.66	4.48
3/10/20 7:53	239.59	27.69	1.34	12.24	161.37	1171.93	4.48
3/10/20 7:54	239.73	27.62	1.34	12.24	161.94	1170.72	4.48
3/10/20 7:55	239.54	27.78	1.33	12.24	162.51	1171.13	4.48
3/10/20 7:56	239.43	27.65	1.32	12.25	162.67	1171.16	4.48
3/10/20 7:57	239.43	27.63	1.32	12.25	163.49	1171.23	4.48
3/10/20 7:58	239.40	27.68	1.31	12.25	163.28	1170.50	4.48
3/10/20 7:59	239.29	27.69	1.30	12.25	162.70	1171.16	4.48
3/10/20 8:00	239.30	27.61	1.30	12.25	161.29	1171.08	4.48
3/10/20 8:01	239.15	27.64	1.29	12.25	160.97	1170.62	4.48
3/10/20 8:02	239.20	27.62	1.28	12.25	159.83	1170.64	4.48
3/10/20 8:03	239.20	27.66	1.28	12.25	160.32	1170.82	4.48
3/10/20 8:04	239.26	27.69	1.27	12.25	159.72	1170.86	4.48
3/10/20 8:05	239.32	27.67	1.27	12.25	158.36	1170.97	4.48
3/10/20 8:06	239.05	27.63	1.26	12.25	158.26	1170.38	4.48
3/10/20 8:07	239.06	27.65	1.25	12.25	157.70	1170.85	4.48
3/10/20 8:08	239.04	27.60	1.25	12.25	158.25	1170.86	4.48
3/10/20 8:09	238.73	27.51	1.24	12.26	157.82	1170.07	4.48
3/10/20 8:10	238.80	27.58	1.23	12.26	157.74	1170.48	4.48
3/10/20 8:11	239.00	27.67	1.23	12.26	156.82	1171.13	4.48
3/10/20 8:12	238.97	27.62	1.22	12.26	157.13	1170.93	4.48
3/10/20 8:13	239.13	27.67	1.21	12.26	155.91	1171.12	4.47
3/10/20 8:14	239.04	27.61	1.21	12.26	156.62	1171.44	4.47
3/10/20 8:15	239.28	27.68	1.20	12.26	156.77	1171.04	4.47
3/10/20 8:16	239.08	27.71	1.19	12.26	158.40	1171.18	4.47
3/10/20 8:17	239.21	27.59	1.19	12.26	157.77	1171.67	4.47
3/10/20 8:18	239.07	27.65	1.18	12.26	157.38	1171.09	4.47
3/10/20 8:19	238.97	27.67	1.17	12.26	157.01	1171.43	4.47
3/10/20 8:20	239.41	27.62	1.17	12.26	157.11	1171.47	4.47
3/10/20 8:21	239.17	27.69	1.16	12.26	156.85	1172.18	4.47
3/10/20 8:22	238.92	27.62	1.16	12.26	156.91	1170.84	4.47
3/10/20 8:23	239.09	27.64	1.15	12.26	156.45	1171.24	4.47
3/10/20 8:24	238.81	27.63	1.14	12.26	156.88	1171.29	4.47
3/10/20 8:25	238.98	27.54	1.14	12.26	155.64	1171.22	4.47
3/10/20 8:26	238.96	27.58	1.13	12.26	155.26	1170.61	4.47
3/10/20 8:27	238.64	27.66	1.12	12.26	154.51	1171.01	4.47
3/10/20 8:28	238.73	27.62	1.12	12.26	154.16	1170.60	4.47
3/10/20 8:29	238.85	27.64	1.11	12.26	153.67	1171.01	4.47

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 7:23 - 3/10 12:15)		237.11	27.49	0.94	12.31	144.47	1170.02	4.46
COUNT = 293								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/10/20 8:30	238.69	27.62	1.10	12.26	154.42	1170.41	4.47
	3/10/20 8:31	238.78	27.58	1.10	12.26	154.36	1171.48	4.47
	3/10/20 8:32	238.77	27.61	1.09	12.26	155.02	1170.83	4.47
	3/10/20 8:33	238.92	27.70	1.08	12.26	154.75	1171.05	4.47
	3/10/20 8:34	238.99	27.55	1.08	12.27	154.22	1171.52	4.47
	3/10/20 8:35	238.84	27.57	1.07	12.27	153.58	1171.17	4.47
	3/10/20 8:36	239.08	27.62	1.06	12.27	153.66	1171.64	4.47
	3/10/20 8:37	238.95	27.63	1.06	12.27	153.83	1171.34	4.47
	3/10/20 8:38	238.93	27.68	1.05	12.27	154.29	1170.91	4.47
	3/10/20 8:39	239.25	27.60	1.05	12.28	155.24	1171.30	4.47
	3/10/20 8:40	238.99	27.68	1.04	12.28	154.87	1170.59	4.47
	3/10/20 8:41	238.91	27.75	1.03	12.28	155.20	1171.27	4.47
	3/10/20 8:42	238.96	27.59	1.03	12.28	156.20	1171.06	4.47
	3/10/20 8:43	238.90	27.60	1.02	12.28	156.77	1171.09	4.47
	3/10/20 8:44	238.79	27.65	1.01	12.28	156.81	1170.92	4.47
	3/10/20 8:45	238.63	27.57	1.01	12.27	156.75	1171.17	4.47
	3/10/20 8:46	238.86	27.67	1.00	12.27	157.03	1170.81	4.46
	3/10/20 8:47	238.80	27.61	0.99	12.27	156.16	1170.91	4.46
	3/10/20 8:48	238.57	27.67	0.99	12.26	155.02	1170.95	4.46
	3/10/20 8:49	238.55	27.66	0.98	12.26	153.00	1170.84	4.46
	3/10/20 8:50	238.56	27.54	0.97	12.25	152.02	1170.54	4.46
	3/10/20 8:51	238.55	27.59	0.97	12.24	151.78	1170.38	4.46
	3/10/20 8:52	238.53	27.59	0.96	12.23	151.14	1170.66	4.46
	3/10/20 8:53	238.53	27.62	0.95	12.21	151.44	1170.38	4.46
	3/10/20 8:54	238.20	27.50	0.95	12.20	152.58	1171.29	4.46
	3/10/20 8:55	238.34	27.56	0.94	12.20	152.35	1170.90	4.46
	3/10/20 8:56	238.39	27.54	0.94	12.22	151.26	1170.41	4.46
	3/10/20 8:57	238.08	27.55	0.93	12.24	149.96	1170.77	4.46
	3/10/20 8:58	238.22	27.57	0.92	12.26	149.31	1170.42	4.46
	3/10/20 8:59	238.00	27.55	0.92	12.28	148.65	1170.44	4.46
	3/10/20 9:00	238.22	27.51	0.91	12.30	149.12	1170.67	4.46
	3/10/20 9:01	237.96	27.56	0.90	12.32	148.79	1170.42	4.46
	3/10/20 9:02	238.20	27.60	0.90	12.34	148.19	1170.52	4.46
	3/10/20 9:03	238.11	27.56	0.89	12.36	147.86	1170.52	4.46
	3/10/20 9:04	238.07	27.64	0.88	12.36	147.72	1170.00	4.46
	3/10/20 9:05	238.05	27.58	0.88	12.35	147.88	1170.64	4.46
	3/10/20 9:06	238.16	27.57	0.87	12.35	148.66	1170.64	4.46
	3/10/20 9:07	238.18	27.53	0.86	12.34	149.17	1171.00	4.46
	3/10/20 9:08	238.18	27.50	0.86	12.34	149.33	1170.84	4.46
	3/10/20 9:09	237.86	27.56	0.85	12.33	149.44	1170.56	4.46
	3/10/20 9:10	237.97	27.57	0.84	12.33	149.08	1170.77	4.46
	3/10/20 9:11	237.74	27.60	0.84	12.32	148.97	1170.29	4.46
	3/10/20 9:12	237.97	27.48	0.83	12.32	147.99	1170.58	4.46
	3/10/20 9:13	237.90	27.61	0.83	12.31	148.04	1170.22	4.46
	3/10/20 9:14	237.98	27.61	0.82	12.31	148.34	1170.17	4.46
	3/10/20 9:15	238.04	27.54	0.81	12.30	147.95	1170.79	4.46
	3/10/20 9:16	237.88	27.55	0.81	12.30	147.80	1170.66	4.46
	3/10/20 9:17	237.85	27.45	0.80	12.29	147.04	1170.83	4.46
	3/10/20 9:18	237.76	27.51	0.79	12.29	145.25	1170.59	4.46
	3/10/20 9:19	237.60	27.53	0.79	12.28	145.61	1170.45	4.46
	3/10/20 9:20	237.66	27.48	0.78	12.28	144.41	1170.69	4.45
	3/10/20 9:21	237.61	27.54	0.77	12.27	143.91	1170.89	4.45
	3/10/20 9:22	237.55	27.51	0.77	12.27	143.51	1170.30	4.45
	3/10/20 9:23	237.66	27.57	0.76	12.26	143.51	1170.58	4.45
	3/10/20 9:24	237.46	27.57	0.75	12.26	143.63	1169.80	4.45
	3/10/20 9:25	237.82	27.53	0.75	12.25	142.85	1170.76	4.45
	3/10/20 9:26	237.49	27.56	0.74	12.25	141.60	1170.63	4.45
	3/10/20 9:27	237.61	27.45	0.74	12.25	143.40	1171.22	4.45
	3/10/20 9:28	237.52	27.48	0.73	12.26	143.33	1170.17	4.45
	3/10/20 9:29	237.44	27.53	0.72	12.26	143.56	1170.90	4.45
	3/10/20 9:30	237.52	27.45	0.72	12.27	143.03	1170.88	4.45
	3/10/20 9:31	237.33	27.58	0.71	12.28	141.74	1170.58	4.45
	3/10/20 9:32	237.47	27.49	0.70	12.28	142.19	1170.99	4.45
	3/10/20 9:33	237.46	27.50	0.70	12.29	143.34	1171.09	4.45
	3/10/20 9:34	237.43	27.58	0.69	12.30	143.85	1170.82	4.45
	3/10/20 9:35	237.55	27.41	0.68	12.31	144.16	1170.71	4.45
	3/10/20 9:36	237.31	27.53	0.68	12.31	144.75	1170.38	4.45

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 7:23 - 3/10 12:15)	237.11	27.49	0.94	12.31	144.47	1170.02	4.46
COUNT = 293							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 9:37	237.55	27.51	0.67	12.32	145.49	1170.11	4.45
3/10/20 9:38	237.59	27.46	0.66	12.33	145.63	1171.07	4.45
3/10/20 9:39	237.22	27.54	0.66	12.33	144.21	1170.26	4.45
3/10/20 9:40	237.45	27.50	0.65	12.34	142.36	1170.45	4.45
3/10/20 9:41	237.47	27.51	0.64	12.35	141.16	1170.66	4.45
3/10/20 9:42	237.14	27.40	0.64	12.36	141.26	1170.57	4.45
3/10/20 9:43	237.28	27.42	0.63	12.36	142.54	1170.75	4.45
3/10/20 9:44	237.37	27.49	0.63	12.37	142.28	1170.90	4.45
3/10/20 9:45	237.04	27.53	0.62	12.38	142.40	1170.32	4.45
3/10/20 9:46	237.17	27.53	0.61	12.38	141.88	1170.96	4.45
3/10/20 9:47	237.34	27.58	0.61	12.39	141.23	1171.14	4.45
3/10/20 9:48	237.23	27.44	0.60	12.40	141.35	1170.44	4.45
3/10/20 9:49	237.24	27.45	0.59	12.40	140.41	1170.69	4.45
3/10/20 9:50	237.37	27.50	0.59	12.41	141.18	1171.24	4.45
3/10/20 9:51	237.03	27.49	0.58	12.42	140.56	1169.71	4.45
3/10/20 9:52	237.10	27.51	0.57	12.42	141.25	1170.66	4.45
3/10/20 9:53	237.29	27.49	0.57	12.43	142.07	1170.82	4.45
3/10/20 9:54	237.44	27.50	0.56	12.44	141.61	1170.29	4.44
3/10/20 9:55	237.28	27.46	0.55	12.45	141.00	1170.69	4.44
3/10/20 9:56	237.33	27.52	0.55	12.45	141.38	1170.30	4.44
3/10/20 9:57	237.24	27.42	0.54	12.46	140.60	1170.70	4.44
3/10/20 9:58	237.13	27.49	0.53	12.47	140.15	1170.67	4.44
3/10/20 9:59	237.08	27.44	0.53	12.47	140.04	1171.49	4.44
3/10/20 10:00	237.15	27.48	0.52	12.48	138.65	1170.59	4.44
3/10/20 10:01	236.98	27.48	0.52	12.49	139.22	1170.53	4.44
3/10/20 10:02	236.77	27.51	0.51	12.49	139.30	1170.18	4.44
3/10/20 10:03	236.87	27.50	0.50	12.49	138.76	1171.01	4.44
3/10/20 10:04	236.97	27.47	0.50	12.49	138.55	1170.59	4.44
3/10/20 10:05	237.09	27.47	0.49	12.49	139.06	1170.58	4.44
3/10/20 10:06	236.91	27.47	0.48	12.49	139.10	1170.13	4.44
3/10/20 10:07	237.07	27.43	0.48	12.49	139.19	1170.45	4.44
3/10/20 10:08	236.79	27.47	0.47	12.49	139.63	1170.19	4.44
3/10/20 10:09	236.79	27.51	0.46	12.49	140.44	1169.50	4.44
3/10/20 10:10	237.09	27.50	0.46	12.49	139.92	1170.50	4.44
3/10/20 10:11	236.66	27.48	0.45	12.49	139.97	1169.95	4.44
3/10/20 10:12	237.00	27.44	0.44	12.49	140.00	1170.15	4.44
3/10/20 10:13	236.92	27.49	0.44	12.48	139.99	1169.62	4.44
3/10/20 10:14	236.86	27.43	0.43	12.48	139.84	1169.58	4.44
3/10/20 10:15	236.53	27.46	0.42	12.48	139.69	1169.62	4.44
3/10/20 10:16	236.87	27.42	0.42	12.48	140.01	1169.00	4.44
3/10/20 10:17	236.77	27.45	0.41	12.48	140.07	1169.97	4.44
3/10/20 10:18	236.77	27.51	0.41	12.48	139.39	1169.87	4.44
3/10/20 10:19	236.73	27.51	0.40	12.48	139.21	1169.44	4.44
3/10/20 10:20	236.63	27.47	0.39	12.47	139.38	1170.04	4.44
3/10/20 10:21	236.79	27.41	0.39	12.46	139.02	1169.59	4.44
3/10/20 10:22	236.77	27.46	0.38	12.44	139.13	1169.55	4.44
3/10/20 10:23	236.73	27.44	0.37	12.42	139.31	1169.71	4.44
3/10/20 10:24	236.58	27.46	0.37	12.40	139.78	1169.71	4.44
3/10/20 10:25	236.72	27.46	0.36	12.39	139.13	1170.62	4.44
3/10/20 10:26	236.98	27.43	0.35	12.37	138.37	1170.33	4.44
3/10/20 10:27	236.65	27.46	0.35	12.35	138.24	1170.02	4.44
3/10/20 10:28	236.69	27.43	0.34	12.33	138.50	1170.37	4.43
3/10/20 10:29	236.68	27.43	0.33	12.32	138.02	1169.79	4.43
3/10/20 10:30	236.67	27.47	0.33	12.30	138.64	1169.90	4.43
3/10/20 10:31	236.89	27.46	0.32	12.28	138.73	1170.04	4.43
3/10/20 10:32	236.25	27.44	0.31	12.28	138.89	1168.70	4.44
3/10/20 10:33	236.67	27.47	0.31	12.28	138.71	1169.59	4.44
3/10/20 10:34	236.66	27.36	0.30	12.28	138.32	1170.04	4.44
3/10/20 10:35	236.60	27.46	0.30	12.28	137.72	1169.60	4.44
3/10/20 10:36	236.44	27.46	0.29	12.27	137.50	1169.96	4.44
3/10/20 10:37	236.30	27.47	0.28	12.27	137.66	1169.38	4.44
3/10/20 10:38	236.15	27.40	0.28	12.27	137.11	1169.73	4.44
3/10/20 10:39	236.30	27.44	0.27	12.27	136.86	1169.94	4.44
3/10/20 10:40	236.22	27.39	0.26	12.27	135.73	1169.09	4.44
3/10/20 10:41	236.24	27.40	0.26	12.27	135.77	1169.34	4.44
3/10/20 10:42	236.19	27.49	0.25	12.26	137.07	1169.71	4.44
3/10/20 10:43	235.97	27.42	0.24	12.26	136.69	1169.57	4.44

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 7:23 - 3/10 12:15)	237.11	27.49	0.94	12.31	144.47	1170.02	4.46
COUNT = 293							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 10:44	235.89	27.44	0.24	12.26	136.93	1169.63	4.44
3/10/20 10:45	235.60	27.36	0.23	12.26	136.15	1169.35	4.44
3/10/20 10:46	235.85	27.40	0.22	12.26	135.98	1169.20	4.44
3/10/20 10:47	235.76	27.38	0.22	12.26	135.35	1169.24	4.44
3/10/20 10:48	236.02	27.38	0.21	12.25	135.64	1169.27	4.44
3/10/20 10:49	235.99	27.40	0.21	12.25	135.33	1169.14	4.44
3/10/20 10:50	235.85	27.41	0.20	12.25	135.52	1169.43	4.44
3/10/20 10:51	235.72	27.34	0.19	12.25	135.57	1169.18	4.44
3/10/20 10:52	235.60	27.36	0.19	12.25	135.08	1169.26	4.44
3/10/20 10:53	235.78	27.31	0.18	12.25	134.26	1169.10	4.44
3/10/20 10:54	235.55	27.32	0.17	12.24	134.41	1169.31	4.44
3/10/20 10:55	235.70	27.33	0.17	12.24	134.14	1168.97	4.44
3/10/20 10:56	235.31	27.36	0.16	12.24	133.99	1168.80	4.44
3/10/20 10:57	235.49	27.39	0.15	12.24	133.88	1169.35	4.44
3/10/20 10:58	235.46	27.34	0.15	12.24	134.16	1169.01	4.45
3/10/20 10:59	235.27	27.35	0.14	12.24	133.76	1168.84	4.45
3/10/20 11:00	235.42	27.38	0.13	12.23	133.99	1168.59	4.45
3/10/20 11:01	235.50	27.39	0.13	12.23	134.29	1168.82	4.45
3/10/20 11:02	235.26	27.33	0.12	12.23	134.86	1168.90	4.45
3/10/20 11:03	234.95	27.25	0.11	12.23	134.94	1168.78	4.45
3/10/20 11:04	234.91	27.37	0.11	12.23	134.66	1168.81	4.45
3/10/20 11:05	234.59	27.25	0.10	12.23	134.18	1169.33	4.45
3/10/20 11:06	234.72	27.28	0.10	12.22	133.48	1169.17	4.45
3/10/20 11:07	234.57	27.24	0.09	12.22	133.24	1169.54	4.45
3/10/20 11:08	234.72	27.34	0.08	12.22	132.44	1169.53	4.45
3/10/20 11:09	234.62	27.26	0.08	12.22	131.58	1169.51	4.45
3/10/20 11:10	234.68	27.30	0.07	12.22	131.25	1168.73	4.45
3/10/20 11:11	234.22	27.24	0.06	12.22	131.36	1168.41	4.45
3/10/20 11:12	234.44	27.36	0.06	12.21	131.42	1169.46	4.45
3/10/20 11:13	234.56	27.25	0.05	12.21	131.45	1169.20	4.45
3/10/20 11:14	234.32	27.30	0.04	12.22	131.29	1169.00	4.45
3/10/20 11:15	234.65	27.23	0.04	12.24	130.83	1169.43	4.45
3/10/20 11:16	234.56	27.29	0.03	12.25	130.80	1169.22	4.45
3/10/20 11:17	234.57	27.25	0.02	12.27	131.38	1169.23	4.45
3/10/20 11:18	234.60	27.24	0.02	12.28	131.56	1169.03	4.45
3/10/20 11:19	234.89	27.27	0.01	12.30	132.35	1169.64	4.45
3/10/20 11:20	234.65	27.26	0.00	12.32	132.31	1169.38	4.45
3/10/20 11:21	234.77	27.29	0.02	12.35	131.78	1170.17	4.45
3/10/20 11:22	234.60	27.28	0.08	12.38	131.64	1169.14	4.45
3/10/20 11:23	234.60	27.33	0.14	12.40	131.46	1169.25	4.45
3/10/20 11:24	234.87	27.37	0.20	12.43	131.66	1169.37	4.46
3/10/20 11:25	234.76	27.29	0.26	12.46	131.41	1169.33	4.46
3/10/20 11:26	234.57	27.32	0.32	12.47	131.93	1169.17	4.46
3/10/20 11:27	234.42	27.29	0.38	12.48	132.11	1168.94	4.46
3/10/20 11:28	234.52	27.36	0.45	12.44	131.98	1168.96	4.46
3/10/20 11:29	234.53	27.22	0.51	12.40	131.64	1168.97	4.46
3/10/20 11:30	234.37	27.25	0.57	12.37	131.16	1168.82	4.46
3/10/20 11:31	234.58	27.30	0.63	12.36	130.96	1168.36	4.46
3/10/20 11:32	234.64	27.35	0.69	12.35	130.63	1169.23	4.46
3/10/20 11:33	234.48	27.24	0.75	12.34	130.74	1168.42	4.46
3/10/20 11:34	234.64	27.36	0.81	12.33	130.81	1168.81	4.46
3/10/20 11:35	234.40	27.21	0.87	12.32	131.20	1168.91	4.46
3/10/20 11:36	234.13	27.24	0.94	12.31	130.38	1167.82	4.46
3/10/20 11:37	234.36	27.23	1.00	12.30	130.25	1168.54	4.46
3/10/20 11:38	234.25	27.31	1.06	12.29	129.52	1168.42	4.46
3/10/20 11:39	234.35	27.32	1.12	12.28	129.69	1168.18	4.46
3/10/20 11:40	234.56	27.19	1.18	12.27	129.74	1168.44	4.46
3/10/20 11:41	234.48	27.30	1.24	12.27	130.44	1167.95	4.46
3/10/20 11:42	234.78	27.25	1.30	12.27	130.58	1167.97	4.46
3/10/20 11:43	234.74	27.25	1.36	12.26	129.94	1168.14	4.46
3/10/20 11:44	234.66	27.38	1.43	12.26	130.23	1168.11	4.46
3/10/20 11:45	234.70	27.33	1.49	12.25	129.38	1169.08	4.46
3/10/20 11:46	234.79	27.36	1.55	12.25	129.21	1168.00	4.46
3/10/20 11:47	234.68	27.27	1.61	12.25	128.69	1168.34	4.46
3/10/20 11:48	234.66	27.29	1.67	12.24	130.71	1168.32	4.46
3/10/20 11:49	234.45	27.25	1.73	12.24	131.12	1168.30	4.46
3/10/20 11:50	234.34	27.27	1.79	12.23	130.56	1168.39	4.47

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 7:23 - 3/10 12:15)	237.11	27.49	0.94	12.31	144.47	1170.02	4.46
COUNT = 293							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 11:51	234.43	27.30	1.85	12.23	129.48	1167.79	4.47
3/10/20 11:52	234.37	27.35	1.92	12.23	128.75	1167.93	4.47
3/10/20 11:53	234.47	27.33	1.98	12.26	128.74	1168.30	4.47
3/10/20 11:54	234.45	27.31	2.04	12.33	128.70	1168.28	4.47
3/10/20 11:55	234.41	27.29	2.10	12.40	129.04	1168.00	4.47
3/10/20 11:56	234.59	27.35	2.16	12.47	129.06	1167.86	4.47
3/10/20 11:57	234.48	27.30	2.22	12.54	129.36	1167.78	4.47
3/10/20 11:58	234.81	27.33	2.28	12.55	128.65	1167.67	4.47
3/10/20 11:59	234.42	27.33	2.34	12.53	128.54	1166.71	4.47
3/10/20 12:00	234.52	27.31	2.40	12.50	128.19	1167.24	4.47
3/10/20 12:01	234.37	27.31	2.47	12.48	128.31	1167.41	4.47
3/10/20 12:02	233.97	27.26	2.53	12.46	128.31	1168.03	4.47
3/10/20 12:03	234.27	27.28	2.59	12.44	128.22	1167.30	4.47
3/10/20 12:04	233.94	27.22	2.65	12.42	128.39	1166.87	4.47
3/10/20 12:05	234.46	27.21	2.71	12.39	127.16	1167.09	4.47
3/10/20 12:06	234.16	27.27	2.77	12.39	126.88	1166.89	4.47
3/10/20 12:07	234.42	27.29	2.83	12.40	127.45	1167.01	4.47
3/10/20 12:08	234.13	27.26	2.89	12.40	128.42	1166.84	4.47
3/10/20 12:09	234.49	27.27	2.96	12.41	129.02	1167.23	4.47
3/10/20 12:10	234.21	27.25	3.02	12.41	129.60	1166.85	4.47
3/10/20 12:11	234.15	27.29	3.08	12.41	129.52	1166.69	4.47
3/10/20 12:12	234.11	27.22	3.14	12.41	129.08	1167.29	4.47
3/10/20 12:13	234.02	27.24	3.20	12.41	128.69	1166.77	4.47
3/10/20 12:14	234.04	27.26	3.26	12.41	128.54	1166.88	4.47
3/10/20 12:15	234.02	27.18	3.32	12.42	128.62	1166.39	4.47

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
SAM

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 8:6 - 3/9 10:6)		240.08	27.65	0.00	12.28	164.25	1173.06	475.06
COUNT = 121								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 8:06	242.01	27.76	0.00	12.26	178.67	1173.73	480.58
	3/9/20 8:07	241.75	27.83	0.00	12.25	178.75	1173.40	480.28
	3/9/20 8:08	241.95	27.80	0.00	12.24	179.32	1173.62	480.13
	3/9/20 8:09	242.16	27.79	0.00	12.23	180.96	1174.13	479.82
	3/9/20 8:10	242.19	27.80	0.00	12.22	181.97	1174.17	479.04
	3/9/20 8:11	242.03	27.78	0.00	12.21	183.08	1174.00	478.25
	3/9/20 8:12	242.03	27.77	0.00	12.20	182.77	1173.67	477.47
	3/9/20 8:13	242.02	27.76	0.00	12.19	182.94	1173.43	477.33
	3/9/20 8:14	241.79	27.76	0.00	12.18	182.68	1173.53	477.22
	3/9/20 8:15	241.72	27.82	0.00	12.17	181.22	1173.32	476.96
	3/9/20 8:16	242.02	27.78	0.00	12.16	180.99	1173.82	476.48
	3/9/20 8:17	241.70	27.77	0.00	12.14	180.55	1173.21	476.13
	3/9/20 8:18	241.62	27.78	0.00	12.13	179.42	1173.07	476.94
	3/9/20 8:19	241.33	27.88	0.00	12.12	178.34	1173.26	477.75
	3/9/20 8:20	241.58	27.73	0.00	12.11	177.73	1173.80	478.44
	3/9/20 8:21	241.59	27.75	0.00	12.10	178.03	1173.38	478.80
	3/9/20 8:22	241.52	27.79	0.00	12.09	177.67	1173.52	479.16
	3/9/20 8:23	241.32	27.72	0.00	12.09	176.76	1173.07	479.52
	3/9/20 8:24	241.31	27.77	0.00	12.10	175.34	1173.09	479.88
	3/9/20 8:25	241.32	27.78	0.00	12.10	174.79	1173.46	479.57
	3/9/20 8:26	241.44	27.73	0.00	12.11	174.49	1173.15	478.83
	3/9/20 8:27	241.54	27.74	0.00	12.11	175.11	1173.44	478.09
	3/9/20 8:28	241.67	27.77	0.00	12.11	175.90	1173.24	477.35
	3/9/20 8:29	241.61	27.70	0.00	12.12	176.73	1172.99	476.63
	3/9/20 8:30	241.35	27.82	0.00	12.12	177.28	1172.89	475.90
	3/9/20 8:31	241.47	27.84	0.00	12.12	177.39	1172.78	475.18
	3/9/20 8:32	241.68	27.83	0.00	12.12	176.53	1173.60	474.92
	3/9/20 8:33	241.43	27.74	0.00	12.12	176.25	1173.76	475.07
	3/9/20 8:34	241.64	27.90	0.00	12.12	176.95	1173.04	475.23
	3/9/20 8:35	241.38	27.78	0.00	12.13	178.82	1172.89	475.38
	3/9/20 8:36	241.40	27.74	0.00	12.13	177.88	1173.51	475.53
	3/9/20 8:37	241.56	27.70	0.00	12.13	177.36	1173.56	475.68
	3/9/20 8:38	240.97	27.63	0.00	12.13	176.88	1172.47	475.84
	3/9/20 8:39	241.51	27.81	0.00	12.13	176.03	1173.02	475.99
	3/9/20 8:40	241.07	27.76	0.00	12.13	173.93	1173.26	476.14
	3/9/20 8:41	241.27	27.74	0.00	12.13	173.35	1172.82	475.88
	3/9/20 8:42	241.25	27.68	0.00	12.13	173.07	1172.93	475.60
	3/9/20 8:43	241.36	27.74	0.00	12.13	173.98	1173.07	475.33
	3/9/20 8:44	241.12	27.66	0.00	12.13	175.08	1172.73	475.05
	3/9/20 8:45	241.07	27.65	0.00	12.13	175.75	1173.23	474.77
	3/9/20 8:46	240.91	27.71	0.00	12.14	175.37	1172.88	474.53
	3/9/20 8:47	240.92	27.78	0.00	12.14	174.47	1173.05	474.43
	3/9/20 8:48	240.93	27.68	0.00	12.14	173.12	1172.78	474.33
	3/9/20 8:49	240.92	27.64	0.00	12.15	171.80	1173.07	474.24
	3/9/20 8:50	241.12	27.72	0.00	12.15	171.90	1172.46	474.14
	3/9/20 8:51	240.85	27.74	0.00	12.15	171.23	1172.61	474.04
	3/9/20 8:52	240.96	27.72	0.00	12.16	171.80	1172.72	473.95
	3/9/20 8:53	240.82	27.72	0.00	12.16	171.97	1172.91	473.85
	3/9/20 8:54	240.82	27.76	0.00	12.17	171.51	1172.99	473.76
	3/9/20 8:55	240.81	27.73	0.00	12.17	170.89	1173.07	473.66
	3/9/20 8:56	240.54	27.66	0.00	12.18	170.17	1172.42	473.62
	3/9/20 8:57	240.45	27.66	0.00	12.18	170.53	1173.05	473.63
	3/9/20 8:58	240.55	27.67	0.00	12.18	169.33	1172.54	474.58
	3/9/20 8:59	240.55	27.65	0.00	12.19	168.17	1173.41	478.01
	3/9/20 9:00	240.55	27.70	0.00	12.19	168.00	1173.16	477.43
	3/9/20 9:01	240.50	27.67	0.00	12.20	168.41	1172.66	476.85
	3/9/20 9:02	240.57	27.66	0.00	12.21	168.36	1172.23	476.27
	3/9/20 9:03	240.39	27.63	0.00	12.23	169.10	1173.43	475.69
	3/9/20 9:04	240.06	27.68	0.00	12.24	170.07	1172.73	475.11
	3/9/20 9:05	240.20	27.61	0.00	12.26	168.39	1173.74	474.53
	3/9/20 9:06	240.04	27.68	0.00	12.27	165.17	1173.02	473.94
	3/9/20 9:07	239.72	27.62	0.00	12.29	163.71	1172.98	473.36
	3/9/20 9:08	240.03	27.61	0.00	12.30	161.82	1173.00	473.01
	3/9/20 9:09	239.88	27.66	0.00	12.32	161.64	1172.95	474.29
	3/9/20 9:10	240.19	27.68	0.00	12.33	161.89	1172.77	474.92
	3/9/20 9:11	239.84	27.61	0.00	12.35	161.60	1172.41	474.60
	3/9/20 9:12	239.80	27.66	0.00	12.36	161.96	1172.60	474.28

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 8:6 - 3/9 10:6)	240.08	27.65	0.00	12.28	164.25	1173.06	475.06
COUNT = 121							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 9:13	239.66	27.61	0.00	12.37	161.61	1172.72	473.96
3/9/20 9:14	239.75	27.70	0.00	12.39	161.24	1173.24	473.63
3/9/20 9:15	239.58	27.64	0.00	12.40	160.51	1172.29	473.31
3/9/20 9:16	239.49	27.65	0.00	12.42	160.27	1172.54	472.99
3/9/20 9:17	239.66	27.62	0.00	12.43	160.44	1172.62	472.74
3/9/20 9:18	239.59	27.65	0.00	12.44	159.58	1172.81	474.10
3/9/20 9:19	239.32	27.59	0.00	12.46	159.00	1172.81	475.46
3/9/20 9:20	239.44	27.54	0.00	12.47	157.69	1172.98	476.55
3/9/20 9:21	239.50	27.62	0.00	12.48	157.35	1172.69	476.54
3/9/20 9:22	239.59	27.62	0.00	12.50	156.44	1172.67	476.52
3/9/20 9:23	239.37	27.62	0.00	12.51	156.31	1172.95	476.51
3/9/20 9:24	239.26	27.59	0.00	12.51	155.47	1173.26	476.49
3/9/20 9:25	239.41	27.63	0.00	12.51	153.49	1173.50	475.55
3/9/20 9:26	238.78	27.64	0.00	12.51	153.31	1172.69	474.36
3/9/20 9:27	239.00	27.60	0.00	12.52	153.41	1173.06	473.17
3/9/20 9:28	239.22	27.55	0.00	12.52	153.47	1173.04	473.49
3/9/20 9:29	239.28	27.53	0.00	12.52	153.92	1172.76	474.00
3/9/20 9:30	238.72	27.54	0.00	12.52	153.88	1172.97	474.51
3/9/20 9:31	238.76	27.49	0.00	12.52	152.76	1172.44	475.53
3/9/20 9:32	239.04	27.57	0.00	12.53	150.91	1173.10	474.81
3/9/20 9:33	239.13	27.55	0.00	12.53	150.60	1173.44	471.72
3/9/20 9:34	239.21	27.55	0.00	12.53	152.52	1173.37	472.53
3/9/20 9:35	239.05	27.54	0.00	12.53	152.71	1172.97	476.08
3/9/20 9:36	238.86	27.52	0.00	12.54	153.49	1172.56	475.03
3/9/20 9:37	239.06	27.48	0.00	12.54	153.04	1173.55	473.88
3/9/20 9:38	238.79	27.53	0.00	12.54	152.49	1172.49	473.91
3/9/20 9:39	238.52	27.51	0.00	12.54	152.82	1173.03	475.77
3/9/20 9:40	238.62	27.59	0.00	12.52	152.38	1173.33	475.03
3/9/20 9:41	238.49	27.58	0.00	12.50	151.07	1173.01	474.28
3/9/20 9:42	238.72	27.55	0.00	12.47	149.18	1173.16	473.54
3/9/20 9:43	238.58	27.57	0.00	12.45	148.38	1173.45	472.61
3/9/20 9:44	238.64	27.56	0.00	12.42	148.44	1172.55	471.18
3/9/20 9:45	238.69	27.49	0.00	12.40	149.13	1173.38	470.88
3/9/20 9:46	238.43	27.59	0.00	12.37	149.50	1172.32	471.14
3/9/20 9:47	238.43	27.57	0.00	12.34	150.53	1172.80	470.86
3/9/20 9:48	238.63	27.56	0.00	12.32	150.37	1172.79	470.36
3/9/20 9:49	238.69	27.55	0.00	12.29	150.48	1172.34	470.36
3/9/20 9:50	238.59	27.50	0.00	12.27	149.23	1172.90	471.14
3/9/20 9:51	238.63	27.55	0.00	12.24	149.42	1173.14	471.88
3/9/20 9:52	238.41	27.59	0.00	12.22	149.87	1173.20	472.51
3/9/20 9:53	238.61	27.54	0.00	12.20	150.20	1173.21	473.13
3/9/20 9:54	238.33	27.50	0.00	12.21	150.70	1173.05	474.58
3/9/20 9:55	238.28	27.53	0.00	12.22	148.69	1173.04	473.60
3/9/20 9:56	238.28	27.45	0.00	12.24	146.53	1173.01	472.10
3/9/20 9:57	238.14	27.54	0.00	12.25	146.03	1173.00	472.36
3/9/20 9:58	238.18	27.53	0.00	12.26	146.48	1173.04	472.90
3/9/20 9:59	238.10	27.60	0.00	12.27	146.85	1173.38	473.33
3/9/20 10:00	238.14	27.40	0.00	12.28	147.29	1173.15	473.75
3/9/20 10:01	238.15	27.46	0.00	12.29	146.88	1172.88	474.17
3/9/20 10:02	237.81	27.51	0.00	12.30	147.08	1172.86	474.59
3/9/20 10:03	238.16	27.51	0.00	12.31	147.47	1172.86	475.01
3/9/20 10:04	237.98	27.45	0.00	12.32	147.05	1172.88	475.07
3/9/20 10:05	237.52	27.49	0.00	12.33	146.91	1172.64	473.33
3/9/20 10:06	237.80	27.47	0.00	12.34	146.30	1173.08	471.75

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 11:49 - 3/9 13:49)	232.32	27.09	0.00	12.28	128.41	1170.10	7.38
COUNT = 121							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 11:49	233.72	27.23	0.00	12.37	127.91	1170.77	7.81
3/9/20 11:50	234.10	27.29	0.00	12.37	128.76	1171.27	7.80
3/9/20 11:51	233.79	27.28	0.00	12.38	129.43	1171.70	7.80
3/9/20 11:52	233.95	27.26	0.00	12.38	129.99	1171.58	7.79
3/9/20 11:53	234.06	27.21	0.00	12.38	130.02	1171.05	7.78
3/9/20 11:54	233.95	27.26	0.00	12.39	130.48	1170.99	7.77
3/9/20 11:55	234.10	27.24	0.00	12.39	131.05	1171.30	7.77
3/9/20 11:56	233.96	27.19	0.00	12.39	131.04	1171.21	7.76
3/9/20 11:57	233.73	27.16	0.00	12.40	130.92	1171.74	7.75
3/9/20 11:58	233.93	27.18	0.00	12.40	131.31	1171.88	7.75
3/9/20 11:59	233.59	27.23	0.00	12.40	130.46	1171.39	7.74
3/9/20 12:00	233.56	27.21	0.00	12.41	129.79	1171.78	7.73
3/9/20 12:01	233.43	27.22	0.00	12.41	129.46	1171.39	7.72
3/9/20 12:02	233.38	27.14	0.00	12.41	128.16	1171.22	7.72
3/9/20 12:03	233.80	27.17	0.00	12.42	127.85	1171.22	7.71
3/9/20 12:04	233.46	27.18	0.00	12.42	128.59	1171.04	7.70
3/9/20 12:05	233.52	27.19	0.00	12.42	129.18	1170.82	7.70
3/9/20 12:06	233.59	27.07	0.00	12.43	130.60	1171.28	7.69
3/9/20 12:07	233.23	27.21	0.00	12.43	130.39	1170.90	7.68
3/9/20 12:08	233.13	27.16	0.00	12.43	130.80	1170.82	7.68
3/9/20 12:09	232.98	27.23	0.00	12.41	130.38	1170.44	7.67
3/9/20 12:10	233.22	27.07	0.00	12.39	129.12	1171.15	7.66
3/9/20 12:11	233.21	27.15	0.00	12.37	129.11	1170.58	7.65
3/9/20 12:12	233.12	27.22	0.00	12.35	128.73	1170.89	7.65
3/9/20 12:13	233.50	27.24	0.00	12.34	129.36	1171.45	7.64
3/9/20 12:14	233.36	27.13	0.00	12.32	129.41	1170.64	7.63
3/9/20 12:15	233.31	27.20	0.00	12.30	129.86	1170.39	7.63
3/9/20 12:16	233.42	27.18	0.00	12.28	130.17	1171.26	7.62
3/9/20 12:17	233.04	27.05	0.00	12.26	130.83	1170.54	7.61
3/9/20 12:18	233.58	27.17	0.00	12.25	131.37	1171.74	7.60
3/9/20 12:19	233.26	27.13	0.00	12.23	131.52	1171.15	7.60
3/9/20 12:20	233.12	27.23	0.00	12.21	132.00	1171.09	7.59
3/9/20 12:21	233.05	27.11	0.00	12.19	131.64	1170.95	7.58
3/9/20 12:22	232.54	27.16	0.00	12.17	130.82	1170.22	7.58
3/9/20 12:23	233.10	27.17	0.00	12.18	131.21	1170.56	7.57
3/9/20 12:24	232.97	27.11	0.00	12.18	131.00	1170.51	7.56
3/9/20 12:25	232.69	27.11	0.00	12.18	131.58	1170.61	7.55
3/9/20 12:26	232.59	27.09	0.00	12.18	132.27	1170.24	7.55
3/9/20 12:27	232.42	27.17	0.00	12.18	132.75	1170.44	7.54
3/9/20 12:28	232.76	27.09	0.00	12.18	132.84	1170.46	7.53
3/9/20 12:29	232.51	27.08	0.00	12.18	132.85	1170.09	7.53
3/9/20 12:30	231.90	27.04	0.00	12.19	131.65	1170.58	7.52
3/9/20 12:31	232.05	27.04	0.00	12.19	131.28	1169.96	7.51
3/9/20 12:32	232.04	27.09	0.00	12.19	131.20	1170.33	7.50
3/9/20 12:33	232.40	27.10	0.00	12.19	130.22	1169.75	7.50
3/9/20 12:34	232.63	27.12	0.00	12.19	130.01	1169.97	7.49
3/9/20 12:35	232.92	27.12	0.00	12.20	129.54	1170.83	7.48
3/9/20 12:36	232.71	27.14	0.00	12.22	131.02	1170.60	7.48
3/9/20 12:37	232.80	27.15	0.00	12.24	131.06	1169.84	7.47
3/9/20 12:38	232.23	27.11	0.00	12.26	131.55	1170.25	7.46
3/9/20 12:39	232.23	27.05	0.00	12.26	131.12	1170.13	7.45
3/9/20 12:40	231.87	27.03	0.00	12.26	131.15	1169.65	7.45
3/9/20 12:41	232.07	27.13	0.00	12.26	131.12	1170.34	7.44
3/9/20 12:42	231.84	27.01	0.00	12.27	130.62	1170.31	7.43
3/9/20 12:43	232.09	27.05	0.00	12.27	129.55	1170.77	7.43
3/9/20 12:44	232.03	27.05	0.00	12.27	129.03	1170.33	7.42
3/9/20 12:45	231.91	27.08	0.00	12.28	128.36	1169.60	7.41
3/9/20 12:46	231.79	27.12	0.00	12.28	128.20	1169.36	7.40
3/9/20 12:47	231.87	27.08	0.00	12.28	128.11	1170.09	7.40
3/9/20 12:48	232.28	27.06	0.00	12.28	127.90	1170.60	7.39
3/9/20 12:49	232.53	27.05	0.00	12.29	128.73	1169.90	7.38
3/9/20 12:50	232.68	27.08	0.00	12.29	128.56	1170.65	7.38
3/9/20 12:51	232.01	27.05	0.00	12.29	129.56	1170.17	7.37
3/9/20 12:52	231.92	27.06	0.00	12.30	129.54	1169.51	7.36
3/9/20 12:53	232.22	27.07	0.00	12.30	129.47	1169.83	7.35
3/9/20 12:54	232.19	27.10	0.00	12.30	128.58	1169.70	7.35
3/9/20 12:55	232.22	27.15	0.00	12.31	127.46	1169.93	7.34

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 11:49 - 3/9 13:49)	232.32	27.09	0.00	12.28	128.41	1170.10	7.38
COUNT = 121							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 12:56	232.12	27.05	0.00	12.31	127.90	1170.58	7.33
3/9/20 12:57	232.27	27.18	0.00	12.31	126.80	1170.47	7.33
3/9/20 12:58	231.95	27.08	0.00	12.32	126.97	1170.49	7.32
3/9/20 12:59	231.97	27.15	0.00	12.34	127.03	1170.08	7.31
3/9/20 13:00	232.07	27.10	0.00	12.36	126.65	1169.50	7.31
3/9/20 13:01	231.64	27.04	0.00	12.38	126.57	1169.76	7.30
3/9/20 13:02	231.78	26.97	0.00	12.40	125.90	1170.48	7.29
3/9/20 13:03	232.04	27.13	0.00	12.40	125.72	1170.39	7.28
3/9/20 13:04	231.84	27.03	0.00	12.37	125.13	1170.03	7.28
3/9/20 13:05	232.04	27.03	0.00	12.35	125.32	1170.06	7.27
3/9/20 13:06	231.90	27.09	0.00	12.32	125.90	1169.78	7.26
3/9/20 13:07	231.84	27.03	0.00	12.29	126.92	1169.67	7.26
3/9/20 13:08	231.57	26.98	0.00	12.26	127.06	1169.52	7.25
3/9/20 13:09	231.71	27.07	0.00	12.25	127.11	1169.73	7.24
3/9/20 13:10	231.51	26.97	0.00	12.24	127.29	1169.53	7.23
3/9/20 13:11	231.97	27.07	0.00	12.24	126.83	1170.34	7.23
3/9/20 13:12	232.05	26.97	0.00	12.24	126.77	1169.62	7.22
3/9/20 13:13	231.75	27.10	0.00	12.24	126.19	1169.45	7.21
3/9/20 13:14	231.85	27.01	0.00	12.24	126.55	1170.20	7.21
3/9/20 13:15	231.44	27.08	0.00	12.24	126.67	1169.14	7.20
3/9/20 13:16	231.55	27.04	0.00	12.24	127.21	1169.79	7.19
3/9/20 13:17	231.25	27.07	0.00	12.24	126.98	1169.32	7.18
3/9/20 13:18	231.81	27.06	0.00	12.24	126.61	1169.52	7.18
3/9/20 13:19	231.17	27.02	0.00	12.24	124.57	1169.78	7.17
3/9/20 13:20	231.34	27.03	0.00	12.24	124.21	1168.72	7.16
3/9/20 13:21	231.82	26.98	0.00	12.24	124.71	1169.39	7.16
3/9/20 13:22	231.70	27.04	0.00	12.24	124.30	1169.65	7.15
3/9/20 13:23	231.71	27.06	0.00	12.24	124.98	1169.55	7.14
3/9/20 13:24	231.63	26.97	0.00	12.24	125.85	1168.99	7.13
3/9/20 13:25	231.52	27.07	0.00	12.24	126.57	1169.59	7.13
3/9/20 13:26	231.84	27.08	0.00	12.24	127.27	1169.49	7.12
3/9/20 13:27	231.74	27.06	0.00	12.24	127.29	1169.14	7.11
3/9/20 13:28	231.74	27.04	0.00	12.24	127.33	1168.74	7.11
3/9/20 13:29	231.47	26.96	0.00	12.24	125.47	1169.00	7.10
3/9/20 13:30	231.63	27.06	0.00	12.24	125.53	1169.21	7.09
3/9/20 13:31	231.84	27.03	0.00	12.24	125.78	1168.91	7.08
3/9/20 13:32	231.85	27.04	0.00	12.24	126.82	1168.95	7.08
3/9/20 13:33	231.51	27.03	0.00	12.24	127.42	1168.99	7.07
3/9/20 13:34	231.60	26.99	0.00	12.24	127.18	1169.24	7.06
3/9/20 13:35	231.34	26.98	0.00	12.23	126.79	1168.44	7.06
3/9/20 13:36	230.91	27.02	0.00	12.23	127.22	1169.08	7.05
3/9/20 13:37	231.23	26.94	0.00	12.23	126.86	1169.17	7.04
3/9/20 13:38	231.18	27.04	0.00	12.23	125.46	1169.40	7.03
3/9/20 13:39	231.15	26.99	0.00	12.23	125.48	1169.46	7.03
3/9/20 13:40	231.07	27.03	0.00	12.23	125.46	1168.59	7.02
3/9/20 13:41	231.42	26.99	0.00	12.23	125.09	1169.03	7.01
3/9/20 13:42	231.38	27.01	0.00	12.23	125.85	1168.89	7.01
3/9/20 13:43	231.12	26.85	0.00	12.23	126.87	1168.64	7.00
3/9/20 13:44	231.12	26.95	0.00	12.23	126.32	1169.24	6.99
3/9/20 13:45	231.35	26.93	0.00	12.23	125.94	1168.86	6.98
3/9/20 13:46	231.20	26.97	0.00	12.23	125.77	1168.30	6.98
3/9/20 13:47	231.31	26.91	0.00	12.23	125.61	1168.79	6.97
3/9/20 13:48	230.76	27.06	0.00	12.23	125.95	1168.89	6.96
3/9/20 13:49	231.30	26.92	0.00	12.23	125.54	1168.82	6.96

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 15:17 - 3/9 17:17)	230.60	27.04	0.00	12.42	124.24	1172.60	5.90
COUNT = 121							

Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 15:17	230.97	26.93	0.00	12.30	126.86	1167.74	6.33
3/9/20 15:18	230.72	26.96	0.00	12.29	128.31	1168.45	6.32
3/9/20 15:19	230.89	26.88	0.00	12.28	128.35	1168.18	6.32
3/9/20 15:20	230.60	26.96	0.00	12.27	127.18	1167.65	6.31
3/9/20 15:21	230.56	26.99	0.00	12.26	126.67	1168.15	6.30
3/9/20 15:22	230.62	26.87	0.00	12.25	126.53	1167.45	6.29
3/9/20 15:23	230.82	26.92	0.00	12.24	126.42	1168.26	6.29
3/9/20 15:24	230.67	26.96	0.00	12.24	126.08	1167.88	6.28
3/9/20 15:25	230.63	26.92	0.00	12.25	126.79	1167.53	6.27
3/9/20 15:26	230.46	27.00	0.00	12.28	126.78	1167.78	6.27
3/9/20 15:27	230.22	26.91	0.00	12.30	126.72	1167.24	6.26
3/9/20 15:28	230.33	26.89	0.00	12.33	126.66	1167.17	6.25
3/9/20 15:29	230.78	26.98	0.00	12.35	127.09	1168.06	6.24
3/9/20 15:30	230.59	26.91	0.00	12.38	126.53	1168.19	6.24
3/9/20 15:31	230.60	26.90	0.00	12.40	127.18	1168.18	6.23
3/9/20 15:32	230.87	26.95	0.00	12.43	127.38	1168.39	6.22
3/9/20 15:33	230.79	26.98	0.00	12.45	126.33	1167.80	6.22
3/9/20 15:34	230.60	26.93	0.00	12.48	125.84	1167.46	6.21
3/9/20 15:35	230.69	27.02	0.00	12.50	125.96	1167.68	6.20
3/9/20 15:36	230.53	26.93	0.00	12.53	126.59	1167.93	6.19
3/9/20 15:37	230.58	26.90	0.00	12.56	126.63	1168.15	6.19
3/9/20 15:38	230.64	27.01	0.00	12.36	126.52	1167.44	6.18
3/9/20 15:39	230.35	26.94	0.00	12.37	126.87	1167.83	6.17
3/9/20 15:40	230.59	26.95	0.00	12.38	126.63	1167.89	6.17
3/9/20 15:41	230.92	26.98	0.00	12.39	125.63	1167.47	6.16
3/9/20 15:42	230.76	26.98	0.00	12.40	125.34	1167.64	6.15
3/9/20 15:43	230.52	26.98	0.00	12.40	124.58	1167.55	6.15
3/9/20 15:44	230.51	26.96	0.00	12.41	125.50	1166.82	6.14
3/9/20 15:45	230.49	26.94	0.00	12.42	124.62	1167.02	6.13
3/9/20 15:46	230.54	26.93	0.00	12.43	124.69	1166.88	6.12
3/9/20 15:47	230.35	26.90	0.00	12.44	124.60	1167.57	6.12
3/9/20 15:48	230.36	26.96	0.00	12.45	124.46	1167.13	6.11
3/9/20 15:49	231.25	27.07	0.00	12.45	125.55	1174.35	6.10
3/9/20 15:50	230.85	27.10	0.00	12.46	126.11	1175.13	6.10
3/9/20 15:51	230.86	27.14	0.00	12.44	126.54	1174.67	6.09
3/9/20 15:52	230.58	27.10	0.00	12.43	126.01	1174.62	6.08
3/9/20 15:53	230.81	27.11	0.00	12.41	124.92	1175.08	6.07
3/9/20 15:54	230.98	27.08	0.00	12.39	123.25	1174.33	6.07
3/9/20 15:55	230.89	27.09	0.00	12.38	123.20	1174.30	6.06
3/9/20 15:56	230.78	27.13	0.00	12.37	124.14	1174.82	6.05
3/9/20 15:57	230.24	27.09	0.00	12.41	124.92	1174.58	6.05
3/9/20 15:58	230.54	27.05	0.00	12.45	124.22	1174.66	6.04
3/9/20 15:59	231.10	27.16	0.00	12.49	122.75	1174.74	6.03
3/9/20 16:00	230.85	27.06	0.00	12.53	122.54	1174.32	6.02
3/9/20 16:01	230.84	27.03	0.00	12.52	123.03	1174.65	6.02
3/9/20 16:02	230.96	27.12	0.00	12.50	123.85	1174.41	6.01
3/9/20 16:03	230.93	27.07	0.00	12.47	123.62	1174.42	6.00
3/9/20 16:04	231.08	27.10	0.00	12.44	124.70	1174.79	6.00
3/9/20 16:05	231.11	27.09	0.00	12.41	125.02	1174.88	5.99
3/9/20 16:06	231.26	27.09	0.00	12.39	125.10	1174.92	5.98
3/9/20 16:07	231.20	27.16	0.00	12.36	125.07	1174.73	5.97
3/9/20 16:08	231.21	27.17	0.00	12.43	124.74	1175.15	5.97
3/9/20 16:09	231.26	27.07	0.00	12.47	124.40	1174.28	5.96
3/9/20 16:10	231.38	27.10	0.00	12.48	123.80	1174.58	5.95
3/9/20 16:11	230.96	27.08	0.00	12.49	123.69	1174.58	5.95
3/9/20 16:12	230.84	27.04	0.00	12.50	123.37	1174.61	5.94
3/9/20 16:13	230.40	27.07	0.00	12.50	122.92	1174.46	5.93
3/9/20 16:14	230.54	27.09	0.00	12.51	122.48	1174.43	5.92
3/9/20 16:15	230.75	27.14	0.00	12.51	122.61	1174.45	5.92
3/9/20 16:16	231.05	27.08	0.00	12.50	122.84	1174.51	5.91
3/9/20 16:17	230.75	27.04	0.00	12.49	122.55	1174.16	5.90
3/9/20 16:18	230.72	27.03	0.00	12.48	122.99	1174.71	5.90
3/9/20 16:19	230.54	27.02	0.00	12.48	122.62	1173.96	5.89
3/9/20 16:20	230.66	27.05	0.00	12.47	122.61	1174.19	5.88
3/9/20 16:21	230.79	27.12	0.00	12.46	123.18	1174.64	5.87
3/9/20 16:22	231.16	27.13	0.00	12.45	122.87	1175.04	5.87
3/9/20 16:23	230.83	27.11	0.00	12.44	123.33	1174.50	5.86

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 15:17 - 3/9 17:17)		230.60	27.04	0.00	12.42	124.24	1172.60	5.90
COUNT = 121								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 16:24	230.94	27.13	0.00	12.43	123.18	1174.71	5.85
	3/9/20 16:25	230.98	27.12	0.00	12.42	123.42	1174.40	5.85
	3/9/20 16:26	230.75	27.13	0.00	12.41	124.40	1174.75	5.84
	3/9/20 16:27	231.02	27.08	0.00	12.42	123.86	1174.29	5.83
	3/9/20 16:28	231.19	27.11	0.00	12.44	123.56	1174.23	5.82
	3/9/20 16:29	230.81	27.06	0.00	12.45	123.54	1173.95	5.82
	3/9/20 16:30	230.38	27.10	0.00	12.47	123.45	1174.24	5.81
	3/9/20 16:31	230.46	27.03	0.00	12.49	123.75	1174.45	5.80
	3/9/20 16:32	230.64	27.05	0.00	12.51	123.01	1174.60	5.80
	3/9/20 16:33	230.74	27.08	0.00	12.49	122.52	1174.00	5.79
	3/9/20 16:34	230.92	27.03	0.00	12.46	122.63	1174.61	5.78
	3/9/20 16:35	231.14	27.21	0.00	12.44	123.50	1174.39	5.77
	3/9/20 16:36	230.93	27.10	0.00	12.42	123.90	1174.62	5.77
	3/9/20 16:37	230.60	27.11	0.00	12.39	123.12	1174.43	5.76
	3/9/20 16:38	230.51	27.14	0.00	12.37	123.44	1174.95	5.75
	3/9/20 16:39	230.62	27.06	0.00	12.34	123.72	1174.32	5.75
	3/9/20 16:40	230.69	27.15	0.00	12.32	123.34	1174.84	5.74
	3/9/20 16:41	230.81	27.01	0.00	12.29	123.35	1174.57	5.73
	3/9/20 16:42	230.35	27.00	0.00	12.39	123.65	1174.18	5.73
	3/9/20 16:43	230.14	27.01	0.00	12.45	123.58	1174.65	5.72
	3/9/20 16:44	229.95	27.07	0.00	12.45	123.01	1174.22	5.71
	3/9/20 16:45	229.94	27.04	0.00	12.44	121.50	1174.13	5.70
	3/9/20 16:46	230.06	26.99	0.00	12.44	121.07	1174.91	5.70
	3/9/20 16:47	230.17	27.00	0.00	12.43	121.37	1173.54	5.69
	3/9/20 16:48	230.40	27.04	0.00	12.43	121.40	1174.14	5.68
	3/9/20 16:49	230.01	27.07	0.00	12.43	122.46	1174.81	5.68
	3/9/20 16:50	230.01	27.04	0.00	12.42	122.57	1174.18	5.67
	3/9/20 16:51	229.89	26.94	0.00	12.42	122.98	1173.74	5.66
	3/9/20 16:52	230.02	27.03	0.00	12.41	123.54	1173.94	5.65
	3/9/20 16:53	230.07	27.00	0.00	12.41	122.84	1174.12	5.65
	3/9/20 16:54	230.20	27.00	0.00	12.41	122.17	1174.28	5.64
	3/9/20 16:55	230.58	27.09	0.00	12.40	122.66	1174.37	5.63
	3/9/20 16:56	230.57	27.10	0.00	12.40	123.58	1174.09	5.63
	3/9/20 16:57	230.80	27.10	0.00	12.40	124.30	1174.41	5.62
	3/9/20 16:58	230.32	27.00	0.00	12.39	124.83	1174.05	5.61
	3/9/20 16:59	230.46	27.03	0.00	12.39	125.13	1174.49	5.60
	3/9/20 17:00	230.33	27.00	0.00	12.38	124.47	1174.49	5.60
	3/9/20 17:01	230.31	27.02	0.00	12.38	123.10	1174.33	5.59
	3/9/20 17:02	230.79	27.08	0.00	12.38	122.63	1174.35	5.58
	3/9/20 17:03	230.41	27.08	0.00	12.37	122.41	1174.19	5.58
	3/9/20 17:04	230.48	27.08	0.00	12.37	122.74	1173.75	5.57
	3/9/20 17:05	230.48	27.05	0.00	12.37	123.38	1173.90	5.56
	3/9/20 17:06	230.38	27.10	0.00	12.36	123.53	1174.00	5.55
	3/9/20 17:07	230.35	27.03	0.00	12.37	124.13	1173.28	5.55
	3/9/20 17:08	230.09	27.12	0.00	12.39	124.09	1174.07	5.54
	3/9/20 17:09	230.40	27.09	0.00	12.41	124.53	1173.69	5.53
	3/9/20 17:10	230.14	27.01	0.00	12.43	123.96	1173.53	5.53
	3/9/20 17:11	230.13	27.01	0.00	12.45	123.59	1174.15	5.52
	3/9/20 17:12	229.85	27.01	0.00	12.47	122.91	1173.75	5.51
	3/9/20 17:13	229.50	26.98	0.00	12.49	122.63	1174.08	5.50
	3/9/20 17:14	230.06	27.02	0.00	12.51	122.54	1173.61	5.50
	3/9/20 17:15	229.97	26.98	0.00	12.52	122.96	1173.66	5.49
	3/9/20 17:16	229.83	26.96	0.00	12.52	123.71	1173.75	5.48
	3/9/20 17:17	230.26	27.01	0.00	12.52	123.53	1173.67	5.48

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
Opacity

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 10:52 - 3/9 11:52)		234.96	27.29	0.00	12.42	132.34	1172.06	8.00
COUNT = 61								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/9/20 10:52	236.27	27.38	0.00	12.36	135.12	1173.00	8.22
	3/9/20 10:53	236.29	27.33	0.00	12.34	136.03	1173.24	8.21
	3/9/20 10:54	236.16	27.33	0.00	12.33	136.19	1172.72	8.20
	3/9/20 10:55	236.22	27.40	0.00	12.32	135.96	1172.62	8.19
	3/9/20 10:56	235.92	27.43	0.00	12.30	136.11	1172.58	8.19
	3/9/20 10:57	235.94	27.35	0.00	12.29	135.99	1172.56	8.18
	3/9/20 10:58	235.79	27.39	0.00	12.29	135.42	1172.31	8.17
	3/9/20 10:59	235.93	27.36	0.00	12.31	134.54	1172.91	8.17
	3/9/20 11:00	236.08	27.32	0.00	12.34	134.78	1172.46	8.16
	3/9/20 11:01	235.98	27.33	0.00	12.36	134.21	1172.56	8.15
	3/9/20 11:02	235.65	27.29	0.00	12.38	134.65	1172.93	8.14
	3/9/20 11:03	235.77	27.34	0.00	12.41	134.68	1172.33	8.14
	3/9/20 11:04	235.85	27.35	0.00	12.43	134.35	1172.39	8.13
	3/9/20 11:05	235.61	27.31	0.00	12.45	134.34	1172.28	8.12
	3/9/20 11:06	235.93	27.36	0.00	12.48	134.84	1172.78	8.12
	3/9/20 11:07	235.81	27.32	0.00	12.50	134.87	1172.09	8.11
	3/9/20 11:08	235.73	27.39	0.00	12.51	134.75	1172.56	8.10
	3/9/20 11:09	235.77	27.35	0.00	12.51	134.76	1172.41	8.10
	3/9/20 11:10	235.69	27.33	0.00	12.50	134.77	1172.99	8.09
	3/9/20 11:11	235.87	27.36	0.00	12.50	135.39	1172.83	8.08
	3/9/20 11:12	235.92	27.37	0.00	12.50	135.33	1172.63	8.07
	3/9/20 11:13	235.81	27.34	0.00	12.50	136.23	1172.97	8.07
	3/9/20 11:14	236.24	27.37	0.00	12.50	135.98	1173.45	8.06
	3/9/20 11:15	235.69	27.34	0.00	12.50	135.39	1171.82	8.05
	3/9/20 11:16	235.68	27.35	0.00	12.50	134.75	1172.08	8.05
	3/9/20 11:17	235.55	27.37	0.00	12.50	133.79	1171.94	8.04
	3/9/20 11:18	235.25	27.30	0.00	12.50	133.36	1171.57	8.03
	3/9/20 11:19	235.50	27.28	0.00	12.49	132.99	1172.51	8.02
	3/9/20 11:20	235.26	27.30	0.00	12.49	131.90	1172.24	8.02
	3/9/20 11:21	235.23	27.30	0.00	12.49	131.83	1171.42	8.01
	3/9/20 11:22	235.06	27.28	0.00	12.49	132.31	1171.85	8.00
	3/9/20 11:23	235.17	27.35	0.00	12.49	132.81	1172.44	8.00
	3/9/20 11:24	234.48	27.36	0.00	12.49	132.73	1171.58	7.99
	3/9/20 11:25	234.73	27.20	0.00	12.49	132.73	1172.31	7.98
	3/9/20 11:26	234.43	27.30	0.00	12.49	132.19	1172.06	7.97
	3/9/20 11:27	234.95	27.27	0.00	12.49	131.29	1172.38	7.97
	3/9/20 11:28	235.05	27.25	0.00	12.48	130.83	1172.10	7.96
	3/9/20 11:29	234.99	27.30	0.00	12.48	130.67	1171.92	7.95
	3/9/20 11:30	234.61	27.25	0.00	12.48	130.60	1171.07	7.95
	3/9/20 11:31	234.44	27.22	0.00	12.48	130.95	1171.57	7.94
	3/9/20 11:32	234.45	27.22	0.00	12.48	131.17	1171.66	7.93
	3/9/20 11:33	234.35	27.23	0.00	12.48	131.41	1171.58	7.92
	3/9/20 11:34	234.11	27.24	0.00	12.47	131.12	1171.49	7.92
	3/9/20 11:35	233.91	27.23	0.00	12.44	131.02	1170.73	7.91
	3/9/20 11:36	233.99	27.22	0.00	12.40	129.96	1171.71	7.90
	3/9/20 11:37	233.80	27.25	0.00	12.37	127.87	1171.92	7.90
	3/9/20 11:38	234.12	27.25	0.00	12.34	127.89	1172.41	7.89
	3/9/20 11:39	233.66	27.24	0.00	12.33	127.26	1171.25	7.88
	3/9/20 11:40	233.79	27.21	0.00	12.33	128.34	1171.61	7.87
	3/9/20 11:41	234.11	27.20	0.00	12.34	128.91	1171.70	7.87
	3/9/20 11:42	233.63	27.19	0.00	12.34	129.82	1171.37	7.86
	3/9/20 11:43	233.66	27.23	0.00	12.35	129.78	1171.47	7.85
	3/9/20 11:44	233.79	27.14	0.00	12.35	128.43	1171.51	7.85
	3/9/20 11:45	233.32	27.16	0.00	12.35	128.15	1171.48	7.84
	3/9/20 11:46	233.28	27.19	0.00	12.36	128.60	1171.42	7.83
	3/9/20 11:47	233.19	27.17	0.00	12.36	128.32	1171.22	7.82
	3/9/20 11:48	233.46	27.15	0.00	12.37	128.21	1171.30	7.82
	3/9/20 11:49	233.72	27.23	0.00	12.37	127.91	1170.77	7.81
	3/9/20 11:50	234.10	27.29	0.00	12.37	128.76	1171.27	7.80
	3/9/20 11:51	233.79	27.28	0.00	12.38	129.43	1171.70	7.80
	3/9/20 11:52	233.95	27.26	0.00	12.38	129.99	1171.58	7.79

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 11:52 - 3/9 12:52)	232.90	27.13	0.00	12.29	130.30	1170.66	7.58
COUNT = 61							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 11:52	233.95	27.26	0.00	12.38	129.99	1171.58	7.79
3/9/20 11:53	234.06	27.21	0.00	12.38	130.02	1171.05	7.78
3/9/20 11:54	233.95	27.26	0.00	12.39	130.48	1170.99	7.77
3/9/20 11:55	234.10	27.24	0.00	12.39	131.05	1171.30	7.77
3/9/20 11:56	233.96	27.19	0.00	12.39	131.04	1171.21	7.76
3/9/20 11:57	233.73	27.16	0.00	12.40	130.92	1171.74	7.75
3/9/20 11:58	233.93	27.18	0.00	12.40	131.31	1171.88	7.75
3/9/20 11:59	233.59	27.23	0.00	12.40	130.46	1171.39	7.74
3/9/20 12:00	233.56	27.21	0.00	12.41	129.79	1171.78	7.73
3/9/20 12:01	233.43	27.22	0.00	12.41	129.46	1171.39	7.72
3/9/20 12:02	233.38	27.14	0.00	12.41	128.16	1171.22	7.72
3/9/20 12:03	233.80	27.17	0.00	12.42	127.85	1171.22	7.71
3/9/20 12:04	233.46	27.18	0.00	12.42	128.59	1171.04	7.70
3/9/20 12:05	233.52	27.19	0.00	12.42	129.18	1170.82	7.70
3/9/20 12:06	233.59	27.07	0.00	12.43	130.60	1171.28	7.69
3/9/20 12:07	233.23	27.21	0.00	12.43	130.39	1170.90	7.68
3/9/20 12:08	233.13	27.16	0.00	12.43	130.80	1170.82	7.68
3/9/20 12:09	232.98	27.23	0.00	12.41	130.38	1170.44	7.67
3/9/20 12:10	233.22	27.07	0.00	12.39	129.12	1171.15	7.66
3/9/20 12:11	233.21	27.15	0.00	12.37	129.11	1170.58	7.65
3/9/20 12:12	233.12	27.22	0.00	12.35	128.73	1170.89	7.65
3/9/20 12:13	233.50	27.24	0.00	12.34	129.36	1171.45	7.64
3/9/20 12:14	233.36	27.13	0.00	12.32	129.41	1170.64	7.63
3/9/20 12:15	233.31	27.20	0.00	12.30	129.86	1170.39	7.63
3/9/20 12:16	233.42	27.18	0.00	12.28	130.17	1171.26	7.62
3/9/20 12:17	233.04	27.05	0.00	12.26	130.83	1170.54	7.61
3/9/20 12:18	233.58	27.17	0.00	12.25	131.37	1171.74	7.60
3/9/20 12:19	233.26	27.13	0.00	12.23	131.52	1171.15	7.60
3/9/20 12:20	233.12	27.23	0.00	12.21	132.00	1171.09	7.59
3/9/20 12:21	233.05	27.11	0.00	12.19	131.64	1170.95	7.58
3/9/20 12:22	232.54	27.16	0.00	12.17	130.82	1170.22	7.58
3/9/20 12:23	233.10	27.17	0.00	12.18	131.21	1170.56	7.57
3/9/20 12:24	232.97	27.11	0.00	12.18	131.00	1170.51	7.56
3/9/20 12:25	232.69	27.11	0.00	12.18	131.58	1170.61	7.55
3/9/20 12:26	232.59	27.09	0.00	12.18	132.27	1170.24	7.55
3/9/20 12:27	232.42	27.17	0.00	12.18	132.75	1170.44	7.54
3/9/20 12:28	232.76	27.09	0.00	12.18	132.84	1170.46	7.53
3/9/20 12:29	232.51	27.08	0.00	12.18	132.85	1170.09	7.53
3/9/20 12:30	231.90	27.04	0.00	12.19	131.65	1170.58	7.52
3/9/20 12:31	232.05	27.04	0.00	12.19	131.28	1169.96	7.51
3/9/20 12:32	232.04	27.09	0.00	12.19	131.20	1170.33	7.50
3/9/20 12:33	232.40	27.10	0.00	12.19	130.22	1169.75	7.50
3/9/20 12:34	232.63	27.12	0.00	12.19	130.01	1169.97	7.49
3/9/20 12:35	232.92	27.12	0.00	12.20	129.54	1170.83	7.48
3/9/20 12:36	232.71	27.14	0.00	12.22	131.02	1170.60	7.48
3/9/20 12:37	232.80	27.15	0.00	12.24	131.06	1169.84	7.47
3/9/20 12:38	232.23	27.11	0.00	12.26	131.55	1170.25	7.46
3/9/20 12:39	232.23	27.05	0.00	12.26	131.12	1170.13	7.45
3/9/20 12:40	231.87	27.03	0.00	12.26	131.15	1169.65	7.45
3/9/20 12:41	232.07	27.13	0.00	12.26	131.12	1170.34	7.44
3/9/20 12:42	231.84	27.01	0.00	12.27	130.62	1170.31	7.43
3/9/20 12:43	232.09	27.05	0.00	12.27	129.55	1170.77	7.43
3/9/20 12:44	232.03	27.05	0.00	12.27	129.03	1170.33	7.42
3/9/20 12:45	231.91	27.08	0.00	12.28	128.36	1169.60	7.41
3/9/20 12:46	231.79	27.12	0.00	12.28	128.20	1169.36	7.40
3/9/20 12:47	231.87	27.08	0.00	12.28	128.11	1170.09	7.40
3/9/20 12:48	232.28	27.06	0.00	12.28	127.90	1170.60	7.39
3/9/20 12:49	232.53	27.05	0.00	12.29	128.73	1169.90	7.38
3/9/20 12:50	232.68	27.08	0.00	12.29	128.56	1170.65	7.38
3/9/20 12:51	232.01	27.05	0.00	12.29	129.56	1170.17	7.37
3/9/20 12:52	231.92	27.06	0.00	12.30	129.54	1169.51	7.36

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/9 12:52 - 3/9 13:52)	231.62	27.03	0.00	12.26	126.43	1169.38	7.15
COUNT = 61							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/9/20 12:52	231.92	27.06	0.00	12.30	129.54	1169.51	7.36
3/9/20 12:53	232.22	27.07	0.00	12.30	129.47	1169.83	7.35
3/9/20 12:54	232.19	27.10	0.00	12.30	128.58	1169.70	7.35
3/9/20 12:55	232.22	27.15	0.00	12.31	127.46	1169.93	7.34
3/9/20 12:56	232.12	27.05	0.00	12.31	127.90	1170.58	7.33
3/9/20 12:57	232.27	27.18	0.00	12.31	126.80	1170.47	7.33
3/9/20 12:58	231.95	27.08	0.00	12.32	126.97	1170.49	7.32
3/9/20 12:59	231.97	27.15	0.00	12.34	127.03	1170.08	7.31
3/9/20 13:00	232.07	27.10	0.00	12.36	126.65	1169.50	7.31
3/9/20 13:01	231.64	27.04	0.00	12.38	126.57	1169.76	7.30
3/9/20 13:02	231.78	26.97	0.00	12.40	125.90	1170.48	7.29
3/9/20 13:03	232.04	27.13	0.00	12.40	125.72	1170.39	7.28
3/9/20 13:04	231.84	27.03	0.00	12.37	125.13	1170.03	7.28
3/9/20 13:05	232.04	27.03	0.00	12.35	125.32	1170.06	7.27
3/9/20 13:06	231.90	27.09	0.00	12.32	125.90	1169.78	7.26
3/9/20 13:07	231.84	27.03	0.00	12.29	126.92	1169.67	7.26
3/9/20 13:08	231.57	26.98	0.00	12.26	127.06	1169.52	7.25
3/9/20 13:09	231.71	27.07	0.00	12.25	127.11	1169.73	7.24
3/9/20 13:10	231.51	26.97	0.00	12.24	127.29	1169.53	7.23
3/9/20 13:11	231.97	27.07	0.00	12.24	126.83	1170.34	7.23
3/9/20 13:12	232.05	26.97	0.00	12.24	126.77	1169.62	7.22
3/9/20 13:13	231.75	27.10	0.00	12.24	126.19	1169.45	7.21
3/9/20 13:14	231.85	27.01	0.00	12.24	126.55	1170.20	7.21
3/9/20 13:15	231.44	27.08	0.00	12.24	126.67	1169.14	7.20
3/9/20 13:16	231.55	27.04	0.00	12.24	127.21	1169.79	7.19
3/9/20 13:17	231.25	27.07	0.00	12.24	126.98	1169.32	7.18
3/9/20 13:18	231.81	27.06	0.00	12.24	126.61	1169.52	7.18
3/9/20 13:19	231.17	27.02	0.00	12.24	124.57	1169.78	7.17
3/9/20 13:20	231.34	27.03	0.00	12.24	124.21	1168.72	7.16
3/9/20 13:21	231.82	26.98	0.00	12.24	124.71	1169.39	7.16
3/9/20 13:22	231.70	27.04	0.00	12.24	124.30	1169.65	7.15
3/9/20 13:23	231.71	27.06	0.00	12.24	124.98	1169.55	7.14
3/9/20 13:24	231.63	26.97	0.00	12.24	125.85	1168.99	7.13
3/9/20 13:25	231.52	27.07	0.00	12.24	126.57	1169.59	7.13
3/9/20 13:26	231.84	27.08	0.00	12.24	127.27	1169.49	7.12
3/9/20 13:27	231.74	27.06	0.00	12.24	127.29	1169.14	7.11
3/9/20 13:28	231.74	27.04	0.00	12.24	127.33	1168.74	7.11
3/9/20 13:29	231.47	26.96	0.00	12.24	125.47	1169.00	7.10
3/9/20 13:30	231.63	27.06	0.00	12.24	125.53	1169.21	7.09
3/9/20 13:31	231.84	27.03	0.00	12.24	125.78	1168.91	7.08
3/9/20 13:32	231.85	27.04	0.00	12.24	126.82	1168.95	7.08
3/9/20 13:33	231.51	27.03	0.00	12.24	127.42	1168.99	7.07
3/9/20 13:34	231.60	26.99	0.00	12.24	127.18	1169.24	7.06
3/9/20 13:35	231.34	26.98	0.00	12.23	126.79	1168.44	7.06
3/9/20 13:36	230.91	27.02	0.00	12.23	127.22	1169.08	7.05
3/9/20 13:37	231.23	26.94	0.00	12.23	126.86	1169.17	7.04
3/9/20 13:38	231.18	27.04	0.00	12.23	125.46	1169.40	7.03
3/9/20 13:39	231.15	26.99	0.00	12.23	125.48	1169.46	7.03
3/9/20 13:40	231.07	27.03	0.00	12.23	125.46	1168.59	7.02
3/9/20 13:41	231.42	26.99	0.00	12.23	125.09	1169.03	7.01
3/9/20 13:42	231.38	27.01	0.00	12.23	125.85	1168.89	7.01
3/9/20 13:43	231.12	26.85	0.00	12.23	126.87	1168.64	7.00
3/9/20 13:44	231.12	26.95	0.00	12.23	126.32	1169.24	6.99
3/9/20 13:45	231.35	26.93	0.00	12.23	125.94	1168.86	6.98
3/9/20 13:46	231.20	26.97	0.00	12.23	125.77	1168.30	6.98
3/9/20 13:47	231.31	26.91	0.00	12.23	125.61	1168.79	6.97
3/9/20 13:48	230.76	27.06	0.00	12.23	125.95	1168.89	6.96
3/9/20 13:49	231.30	26.92	0.00	12.23	125.54	1168.82	6.96
3/9/20 13:50	231.48	26.99	0.00	12.23	125.81	1168.48	6.95
3/9/20 13:51	231.38	26.98	0.00	12.26	126.49	1168.62	6.94
3/9/20 13:52	231.38	26.97	0.00	12.30	127.06	1167.95	6.93

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
NOx, CO, VOC, and NH_3

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 15:27 - 3/10 16:26)	231.82	27.09	9.93	12.64	151.65	1162.48	4.56
COUNT = 60							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 15:27	231.82	27.08	9.86	12.77	153.36	1162.69	4.55
3/10/20 15:28	231.72	27.10	9.86	12.76	153.13	1163.04	4.55
3/10/20 15:29	231.49	27.10	9.86	12.74	151.55	1163.36	4.55
3/10/20 15:30	231.80	27.07	9.86	12.70	150.35	1162.75	4.55
3/10/20 15:31	231.67	27.08	9.87	12.70	149.99	1163.10	4.55
3/10/20 15:32	231.74	27.06	9.87	12.71	152.84	1162.12	4.55
3/10/20 15:33	231.79	27.05	9.87	12.72	152.46	1162.82	4.55
3/10/20 15:34	231.65	27.07	9.88	12.74	153.25	1162.62	4.55
3/10/20 15:35	231.63	27.12	9.88	12.75	153.71	1162.53	4.55
3/10/20 15:36	231.73	27.07	9.88	12.76	152.85	1162.39	4.55
3/10/20 15:37	231.82	27.14	9.88	12.77	154.04	1162.57	4.55
3/10/20 15:38	231.61	27.07	9.89	12.78	152.27	1161.98	4.55
3/10/20 15:39	231.67	27.11	9.89	12.79	152.02	1162.48	4.55
3/10/20 15:40	231.83	27.09	9.89	12.80	151.68	1162.50	4.55
3/10/20 15:41	231.67	27.00	9.89	12.81	151.53	1162.63	4.55
3/10/20 15:42	231.52	27.05	9.90	12.82	151.70	1162.49	4.55
3/10/20 15:43	231.75	27.11	9.90	12.83	151.57	1162.39	4.55
3/10/20 15:44	231.67	27.07	9.90	12.83	151.81	1162.45	4.55
3/10/20 15:45	231.72	27.08	9.90	12.83	151.95	1162.89	4.56
3/10/20 15:46	232.07	27.06	9.91	12.83	152.08	1162.81	4.56
3/10/20 15:47	231.91	27.03	9.91	12.83	151.27	1162.53	4.56
3/10/20 15:48	232.09	27.06	9.91	12.83	151.36	1162.60	4.56
3/10/20 15:49	231.76	27.11	9.91	12.75	150.75	1162.71	4.56
3/10/20 15:50	231.82	27.12	9.92	12.61	152.16	1162.74	4.56
3/10/20 15:51	231.59	27.15	9.92	12.55	151.94	1162.86	4.56
3/10/20 15:52	231.65	27.06	9.92	12.54	151.82	1162.32	4.56
3/10/20 15:53	231.88	27.15	9.92	12.54	151.45	1162.04	4.56
3/10/20 15:54	231.67	27.02	9.93	12.54	151.33	1162.77	4.56
3/10/20 15:55	231.59	27.04	9.93	12.55	151.85	1162.18	4.56
3/10/20 15:56	231.77	27.04	9.93	12.55	151.14	1162.22	4.56
3/10/20 15:57	231.58	27.03	9.93	12.55	151.25	1162.41	4.56
3/10/20 15:58	231.82	27.16	9.94	12.55	151.05	1162.67	4.56
3/10/20 15:59	231.78	27.10	9.94	12.56	151.64	1162.54	4.56
3/10/20 16:00	231.88	27.08	9.94	12.56	152.21	1162.71	4.56
3/10/20 16:01	231.73	27.06	9.94	12.56	152.37	1162.28	4.56
3/10/20 16:02	231.37	27.08	9.95	12.56	152.60	1162.23	4.56
3/10/20 16:03	231.77	27.08	9.95	12.56	152.06	1162.44	4.56
3/10/20 16:04	231.99	27.10	9.95	12.57	151.86	1162.69	4.56
3/10/20 16:05	231.95	27.08	9.95	12.57	149.53	1162.41	4.56
3/10/20 16:06	232.15	27.06	9.96	12.57	150.11	1162.59	4.56
3/10/20 16:07	232.10	27.08	9.96	12.57	150.60	1162.26	4.56
3/10/20 16:08	231.82	27.05	9.96	12.58	151.64	1162.18	4.56
3/10/20 16:09	231.97	27.11	9.96	12.58	151.56	1161.92	4.56
3/10/20 16:10	231.77	27.09	9.97	12.57	152.04	1162.09	4.56
3/10/20 16:11	231.99	27.14	9.97	12.57	151.67	1162.68	4.57
3/10/20 16:12	232.27	27.13	9.97	12.57	152.46	1162.18	4.57
3/10/20 16:13	231.93	27.11	9.97	12.57	151.57	1162.32	4.57
3/10/20 16:14	231.85	27.12	9.98	12.56	151.10	1162.52	4.57
3/10/20 16:15	231.72	27.08	9.98	12.56	151.13	1162.17	4.57
3/10/20 16:16	231.75	27.05	9.98	12.56	150.92	1162.43	4.57
3/10/20 16:17	232.22	27.05	9.98	12.56	151.28	1162.64	4.57
3/10/20 16:18	231.87	27.11	9.99	12.55	151.42	1162.36	4.57
3/10/20 16:19	231.84	27.09	9.99	12.55	151.56	1162.37	4.57
3/10/20 16:20	231.85	27.19	9.99	12.55	151.49	1162.37	4.57
3/10/20 16:21	231.94	27.10	10.00	12.55	150.92	1162.55	4.57
3/10/20 16:22	231.97	27.11	10.00	12.54	151.34	1162.44	4.57
3/10/20 16:23	232.20	27.11	10.00	12.54	151.07	1162.21	4.57
3/10/20 16:24	232.02	27.13	10.00	12.54	150.51	1162.47	4.57
3/10/20 16:25	232.00	27.15	10.01	12.53	151.23	1162.02	4.57
3/10/20 16:26	231.96	27.07	10.01	12.53	149.81	1162.08	4.57

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 17:35 - 3/10 18:34)	232.05	27.08	10.26	12.66	149.83	1161.66	4.61
COUNT = 60							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 17:35	232.26	27.10	10.18	12.76	149.44	1161.86	4.60
3/10/20 17:36	232.22	27.08	10.19	12.77	149.77	1161.62	4.60
3/10/20 17:37	232.10	27.04	10.19	12.77	150.40	1161.69	4.60
3/10/20 17:38	232.07	27.10	10.19	12.78	151.18	1161.61	4.60
3/10/20 17:39	231.96	27.07	10.19	12.78	152.15	1161.45	4.60
3/10/20 17:40	231.76	27.11	10.20	12.79	151.41	1161.93	4.60
3/10/20 17:41	231.97	27.02	10.20	12.79	151.44	1161.62	4.60
3/10/20 17:42	231.74	27.10	10.20	12.79	151.27	1161.57	4.60
3/10/20 17:43	231.95	27.10	10.20	12.80	151.55	1161.33	4.60
3/10/20 17:44	232.00	27.11	10.21	12.80	151.37	1161.69	4.60
3/10/20 17:45	231.89	27.08	10.21	12.81	151.21	1161.72	4.60
3/10/20 17:46	231.91	27.05	10.21	12.81	151.15	1161.75	4.60
3/10/20 17:47	232.17	27.15	10.21	12.81	150.20	1161.84	4.60
3/10/20 17:48	231.93	27.08	10.22	12.79	149.55	1161.83	4.60
3/10/20 17:49	232.16	27.10	10.22	12.76	149.36	1161.69	4.60
3/10/20 17:50	232.15	27.05	10.22	12.74	149.22	1161.75	4.60
3/10/20 17:51	232.17	27.06	10.22	12.71	149.22	1161.97	4.60
3/10/20 17:52	232.10	27.09	10.23	12.69	149.98	1161.20	4.60
3/10/20 17:53	231.90	27.08	10.23	12.66	150.21	1161.73	4.60
3/10/20 17:54	232.06	27.03	10.23	12.64	149.71	1161.99	4.60
3/10/20 17:55	232.21	27.11	10.23	12.61	149.67	1161.74	4.61
3/10/20 17:56	231.91	27.08	10.24	12.59	150.42	1161.53	4.61
3/10/20 17:57	232.12	27.13	10.24	12.56	150.25	1160.95	4.61
3/10/20 17:58	232.01	27.06	10.24	12.54	149.91	1161.33	4.61
3/10/20 17:59	232.03	27.10	10.25	12.52	150.16	1161.62	4.61
3/10/20 18:00	231.89	27.12	10.25	12.50	149.48	1161.78	4.61
3/10/20 18:01	232.24	27.06	10.25	12.49	148.74	1161.80	4.61
3/10/20 18:02	231.94	27.12	10.25	12.47	149.92	1161.57	4.61
3/10/20 18:03	232.35	27.10	10.26	12.46	149.81	1162.18	4.61
3/10/20 18:04	231.94	27.06	10.26	12.45	150.07	1161.54	4.61
3/10/20 18:05	232.04	27.11	10.26	12.44	149.42	1161.80	4.61
3/10/20 18:06	232.03	27.12	10.26	12.43	150.33	1161.55	4.61
3/10/20 18:07	232.11	27.10	10.27	12.44	149.66	1161.44	4.61
3/10/20 18:08	232.49	27.06	10.27	12.47	148.70	1161.50	4.61
3/10/20 18:09	232.01	27.05	10.27	12.50	149.18	1161.90	4.61
3/10/20 18:10	231.91	27.00	10.27	12.53	149.11	1161.25	4.61
3/10/20 18:11	232.05	26.98	10.28	12.53	149.26	1161.51	4.61
3/10/20 18:12	231.89	27.08	10.28	12.53	149.67	1161.30	4.61
3/10/20 18:13	231.84	27.07	10.28	12.53	149.88	1161.37	4.61
3/10/20 18:14	232.06	27.04	10.28	12.52	149.66	1161.78	4.61
3/10/20 18:15	232.03	27.10	10.29	12.52	149.73	1161.91	4.61
3/10/20 18:16	231.97	27.03	10.29	12.52	149.69	1161.49	4.61
3/10/20 18:17	231.74	27.06	10.29	12.58	148.84	1161.92	4.61
3/10/20 18:18	232.07	27.09	10.29	12.67	148.63	1161.71	4.61
3/10/20 18:19	232.07	26.99	10.30	12.72	148.25	1161.77	4.61
3/10/20 18:20	232.03	27.08	10.30	12.69	147.89	1161.59	4.61
3/10/20 18:21	232.08	27.03	10.30	12.67	148.63	1161.52	4.62
3/10/20 18:22	232.06	27.11	10.30	12.64	148.40	1161.28	4.62
3/10/20 18:23	232.09	27.03	10.31	12.65	148.41	1161.86	4.62
3/10/20 18:24	232.05	27.10	10.31	12.67	148.89	1161.73	4.62
3/10/20 18:25	232.08	27.08	10.31	12.70	149.48	1162.01	4.62
3/10/20 18:26	232.28	27.08	10.31	12.72	150.26	1161.71	4.62
3/10/20 18:27	232.10	27.10	10.32	12.74	150.64	1161.61	4.62
3/10/20 18:28	232.31	27.09	10.32	12.76	150.42	1161.50	4.62
3/10/20 18:29	232.18	27.06	10.32	12.79	149.58	1161.96	4.62
3/10/20 18:30	232.22	27.07	10.32	12.81	149.58	1161.73	4.62
3/10/20 18:31	232.13	27.08	10.33	12.83	150.44	1162.04	4.62
3/10/20 18:32	231.94	27.16	10.33	12.86	150.08	1161.55	4.62
3/10/20 18:33	231.95	27.10	10.33	12.87	149.18	1161.66	4.62
3/10/20 18:34	232.19	27.06	10.33	12.87	149.76	1162.03	4.62

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 18:35 - 3/10 19:34)	232.57	27.12	10.41	12.71	149.17	1161.63	4.62
COUNT = 60							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 18:35	232.34	27.07	10.34	12.86	149.00	1161.79	4.62
3/10/20 18:36	232.26	27.15	10.34	12.85	149.92	1162.09	4.62
3/10/20 18:37	232.12	27.09	10.34	12.84	149.15	1161.83	4.62
3/10/20 18:38	232.19	27.06	10.34	12.83	149.35	1161.56	4.62
3/10/20 18:39	232.18	27.07	10.35	12.83	149.05	1161.72	4.62
3/10/20 18:40	232.05	27.08	10.35	12.82	149.58	1161.95	4.62
3/10/20 18:41	232.44	27.11	10.35	12.81	149.62	1161.55	4.62
3/10/20 18:42	232.23	27.12	10.35	12.80	149.47	1161.85	4.62
3/10/20 18:43	232.41	27.08	10.36	12.79	149.66	1161.79	4.62
3/10/20 18:44	232.51	27.08	10.36	12.78	150.09	1161.64	4.62
3/10/20 18:45	232.55	27.00	10.36	12.78	149.95	1162.08	4.62
3/10/20 18:46	232.16	27.11	10.36	12.77	149.92	1161.54	4.62
3/10/20 18:47	232.01	27.14	10.37	12.76	149.70	1161.53	4.62
3/10/20 18:48	232.21	27.09	10.37	12.75	150.51	1161.57	4.62
3/10/20 18:49	232.52	27.03	10.37	12.74	150.57	1161.81	4.62
3/10/20 18:50	232.02	27.13	10.38	12.73	149.66	1161.14	4.62
3/10/20 18:51	232.28	27.14	10.38	12.73	150.17	1161.77	4.62
3/10/20 18:52	232.51	27.11	10.38	12.74	150.15	1161.49	4.62
3/10/20 18:53	232.18	27.17	10.38	12.74	148.71	1161.32	4.62
3/10/20 18:54	232.53	27.13	10.39	12.75	150.09	1161.84	4.62
3/10/20 18:55	232.47	27.13	10.39	12.75	148.29	1161.97	4.62
3/10/20 18:56	232.56	27.17	10.39	12.75	149.19	1161.71	4.62
3/10/20 18:57	232.61	27.09	10.39	12.76	148.98	1162.00	4.62
3/10/20 18:58	232.77	27.11	10.40	12.76	149.46	1161.46	4.62
3/10/20 18:59	232.45	27.15	10.40	12.77	149.48	1161.75	4.62
3/10/20 19:00	232.83	27.14	10.40	12.77	149.84	1161.92	4.62
3/10/20 19:01	232.90	27.16	10.40	12.77	149.45	1161.68	4.62
3/10/20 19:02	232.72	27.14	10.41	12.78	148.53	1161.70	4.62
3/10/20 19:03	232.75	27.17	10.41	12.78	148.47	1161.60	4.62
3/10/20 19:04	232.70	27.09	10.41	12.79	147.61	1162.04	4.62
3/10/20 19:05	232.76	27.13	10.41	12.79	147.86	1161.66	4.62
3/10/20 19:06	232.70	27.13	10.42	12.66	148.50	1161.50	4.62
3/10/20 19:07	232.72	27.21	10.42	12.61	148.44	1161.45	4.62
3/10/20 19:08	232.56	27.14	10.42	12.58	148.96	1161.62	4.62
3/10/20 19:09	232.38	27.14	10.42	12.58	148.81	1161.63	4.62
3/10/20 19:10	232.67	27.13	10.43	12.61	148.95	1161.32	4.62
3/10/20 19:11	232.72	27.12	10.43	12.64	149.81	1161.40	4.62
3/10/20 19:12	232.81	27.14	10.43	12.66	149.79	1161.53	4.62
3/10/20 19:13	232.76	27.13	10.43	12.66	149.05	1161.52	4.62
3/10/20 19:14	232.92	27.13	10.44	12.66	149.29	1160.87	4.62
3/10/20 19:15	232.72	27.09	10.44	12.65	148.98	1162.00	4.62
3/10/20 19:16	232.44	27.17	10.44	12.64	149.37	1161.16	4.62
3/10/20 19:17	232.57	27.04	10.44	12.63	149.67	1161.34	4.62
3/10/20 19:18	232.62	27.14	10.45	12.61	149.08	1161.33	4.62
3/10/20 19:19	232.73	27.13	10.45	12.61	148.59	1161.39	4.62
3/10/20 19:20	232.88	27.10	10.45	12.64	148.23	1161.83	4.62
3/10/20 19:21	232.83	27.18	10.45	12.67	147.87	1161.63	4.62
3/10/20 19:22	232.86	27.13	10.46	12.70	148.60	1162.36	4.62
3/10/20 19:23	232.85	27.12	10.46	12.69	148.21	1161.65	4.62
3/10/20 19:24	232.92	27.15	10.46	12.68	148.43	1161.44	4.62
3/10/20 19:25	233.12	27.12	10.46	12.68	149.10	1161.65	4.62
3/10/20 19:26	232.83	27.14	10.47	12.67	149.33	1161.53	4.62
3/10/20 19:27	232.54	27.09	10.47	12.66	149.41	1161.55	4.62
3/10/20 19:28	232.71	27.12	10.47	12.65	149.22	1161.34	4.62
3/10/20 19:29	232.65	27.16	10.47	12.64	148.31	1161.71	4.62
3/10/20 19:30	232.66	27.09	10.48	12.64	148.51	1161.58	4.62
3/10/20 19:31	232.67	27.11	10.48	12.63	148.14	1161.93	4.62
3/10/20 19:32	232.75	27.19	10.48	12.62	149.45	1161.22	4.62
3/10/20 19:33	232.72	27.03	10.48	12.60	149.43	1161.46	4.62
3/10/20 19:34	232.66	27.13	10.49	12.58	149.49	1161.35	4.62

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
PM_{10}

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 14:12 - 3/10 18:40)	231.92	27.08	10.01	12.64	151.49	1162.44	4.57
COUNT = 269							

Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 14:12	232.52	27.14	9.67	12.55	156.47	1164.01	4.52
3/10/20 14:13	232.29	27.10	9.67	12.55	156.10	1163.92	4.52
3/10/20 14:14	232.50	27.13	9.67	12.55	156.36	1163.76	4.52
3/10/20 14:15	232.45	27.12	9.67	12.55	155.31	1164.40	4.52
3/10/20 14:16	232.57	27.19	9.68	12.56	153.82	1164.16	4.52
3/10/20 14:17	232.06	27.15	9.68	12.57	153.95	1164.04	4.52
3/10/20 14:18	231.93	27.03	9.68	12.59	154.62	1164.14	4.52
3/10/20 14:19	232.05	27.12	9.68	12.61	154.11	1164.03	4.52
3/10/20 14:20	232.08	27.09	9.69	12.63	155.98	1164.00	4.52
3/10/20 14:21	232.12	27.12	9.69	12.62	154.17	1164.23	4.52
3/10/20 14:22	231.76	27.15	9.69	12.61	154.96	1164.03	4.52
3/10/20 14:23	232.10	27.04	9.69	12.60	154.92	1164.42	4.52
3/10/20 14:24	231.78	27.06	9.70	12.59	155.54	1164.38	4.52
3/10/20 14:25	231.84	27.14	9.70	12.59	155.54	1164.03	4.52
3/10/20 14:26	231.74	27.00	9.70	12.58	154.89	1163.69	4.52
3/10/20 14:27	231.92	27.08	9.70	12.57	155.01	1163.77	4.53
3/10/20 14:28	232.22	27.07	9.71	12.57	155.43	1163.85	4.53
3/10/20 14:29	231.90	27.09	9.71	12.56	154.85	1163.59	4.53
3/10/20 14:30	231.81	27.11	9.71	12.56	155.65	1163.65	4.53
3/10/20 14:31	231.91	27.13	9.71	12.56	155.14	1163.28	4.53
3/10/20 14:32	231.97	27.05	9.72	12.55	154.69	1163.82	4.53
3/10/20 14:33	231.88	27.09	9.72	12.55	154.23	1163.76	4.53
3/10/20 14:34	231.85	27.14	9.72	12.55	154.50	1164.07	4.53
3/10/20 14:35	231.91	27.10	9.72	12.54	154.77	1163.52	4.53
3/10/20 14:36	231.97	27.03	9.73	12.54	154.94	1163.09	4.53
3/10/20 14:37	231.69	27.10	9.73	12.54	154.50	1163.58	4.53
3/10/20 14:38	231.98	27.07	9.73	12.53	153.89	1163.34	4.53
3/10/20 14:39	231.83	27.14	9.73	12.53	153.49	1163.66	4.53
3/10/20 14:40	231.50	27.06	9.74	12.53	154.79	1163.33	4.53
3/10/20 14:41	231.71	27.09	9.74	12.52	155.23	1163.16	4.53
3/10/20 14:42	231.95	27.12	9.74	12.52	155.42	1163.52	4.53
3/10/20 14:43	231.65	27.08	9.74	12.52	156.22	1163.78	4.53
3/10/20 14:44	231.77	27.14	9.75	12.51	155.64	1163.62	4.53
3/10/20 14:45	231.90	27.07	9.75	12.51	155.09	1163.72	4.53
3/10/20 14:46	231.84	27.06	9.75	12.51	154.70	1163.64	4.53
3/10/20 14:47	231.92	27.03	9.76	12.52	154.76	1163.77	4.53
3/10/20 14:48	231.97	27.08	9.76	12.53	154.50	1163.45	4.53
3/10/20 14:49	231.83	27.03	9.76	12.54	154.46	1162.65	4.53
3/10/20 14:50	232.00	27.08	9.76	12.55	153.84	1163.73	4.53
3/10/20 14:51	231.60	27.04	9.77	12.56	154.16	1163.47	4.53
3/10/20 14:52	231.66	27.13	9.77	12.56	153.27	1163.39	4.53
3/10/20 14:53	231.91	27.07	9.77	12.57	153.47	1163.42	4.54
3/10/20 14:54	231.74	27.08	9.77	12.58	153.38	1163.10	4.54
3/10/20 14:55	231.64	27.07	9.78	12.58	154.04	1163.32	4.54
3/10/20 14:56	231.52	27.06	9.78	12.58	153.48	1163.32	4.54
3/10/20 14:57	231.77	27.05	9.78	12.57	153.04	1163.56	4.54
3/10/20 14:58	231.66	27.08	9.78	12.56	152.20	1163.48	4.54
3/10/20 14:59	231.59	27.05	9.79	12.55	152.46	1163.35	4.54
3/10/20 15:00	231.73	27.14	9.79	12.54	152.44	1162.98	4.54
3/10/20 15:01	231.58	27.08	9.79	12.54	152.38	1163.98	4.54
3/10/20 15:02	231.61	27.08	9.79	12.53	153.15	1163.00	4.54
3/10/20 15:03	231.43	27.11	9.80	12.54	153.03	1162.82	4.54
3/10/20 15:04	231.68	27.08	9.80	12.55	152.38	1162.70	4.54
3/10/20 15:05	231.36	27.03	9.80	12.55	152.38	1163.02	4.54
3/10/20 15:06	231.66	27.11	9.80	12.56	152.74	1163.04	4.54
3/10/20 15:07	231.68	27.11	9.81	12.57	152.72	1163.13	4.54
3/10/20 15:08	231.81	27.05	9.81	12.58	152.72	1163.29	4.54
3/10/20 15:09	231.78	27.03	9.81	12.59	153.21	1163.46	4.54
3/10/20 15:10	231.70	27.08	9.81	12.60	152.76	1163.18	4.54
3/10/20 15:11	231.84	27.04	9.82	12.60	152.73	1163.03	4.54
3/10/20 15:12	231.48	27.11	9.82	12.61	152.92	1162.51	4.54
3/10/20 15:13	231.65	27.10	9.82	12.62	153.85	1163.12	4.54
3/10/20 15:14	231.85	27.03	9.82	12.63	153.04	1163.27	4.54
3/10/20 15:15	231.69	27.15	9.83	12.64	152.08	1162.51	4.54
3/10/20 15:16	231.68	27.06	9.83	12.65	151.68	1163.07	4.54
3/10/20 15:17	231.76	27.03	9.83	12.65	151.59	1163.44	4.54
3/10/20 15:18	231.80	27.05	9.83	12.66	152.12	1163.21	4.54

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 14:12 - 3/10 18:40)	231.92	27.08	10.01	12.64	151.49	1162.44	4.57
COUNT = 269							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 15:19	231.39	27.14	9.84	12.67	152.37	1162.97	4.55
3/10/20 15:20	231.76	27.04	9.84	12.69	152.52	1163.16	4.55
3/10/20 15:21	231.61	27.08	9.84	12.72	152.68	1162.77	4.55
3/10/20 15:22	231.83	27.02	9.84	12.75	152.73	1162.71	4.55
3/10/20 15:23	231.58	27.05	9.85	12.78	152.84	1162.74	4.55
3/10/20 15:24	231.89	27.05	9.85	12.80	152.76	1162.62	4.55
3/10/20 15:25	231.70	27.05	9.85	12.80	153.18	1162.65	4.55
3/10/20 15:26	232.07	27.10	9.85	12.79	152.54	1163.55	4.55
3/10/20 15:27	231.82	27.08	9.86	12.77	153.36	1162.69	4.55
3/10/20 15:28	231.72	27.10	9.86	12.76	153.13	1163.04	4.55
3/10/20 15:29	231.49	27.10	9.86	12.74	151.55	1163.36	4.55
3/10/20 15:30	231.80	27.07	9.86	12.70	150.35	1162.75	4.55
3/10/20 15:31	231.67	27.08	9.87	12.70	149.99	1163.10	4.55
3/10/20 15:32	231.74	27.06	9.87	12.71	152.84	1162.12	4.55
3/10/20 15:33	231.79	27.05	9.87	12.72	152.46	1162.82	4.55
3/10/20 15:34	231.65	27.07	9.88	12.74	153.25	1162.62	4.55
3/10/20 15:35	231.63	27.12	9.88	12.75	153.71	1162.53	4.55
3/10/20 15:36	231.73	27.07	9.88	12.76	152.85	1162.39	4.55
3/10/20 15:37	231.82	27.14	9.88	12.77	154.04	1162.57	4.55
3/10/20 15:38	231.61	27.07	9.89	12.78	152.27	1161.98	4.55
3/10/20 15:39	231.67	27.11	9.89	12.79	152.02	1162.48	4.55
3/10/20 15:40	231.83	27.09	9.89	12.80	151.68	1162.50	4.55
3/10/20 15:41	231.67	27.00	9.89	12.81	151.53	1162.63	4.55
3/10/20 15:42	231.52	27.05	9.90	12.82	151.70	1162.49	4.55
3/10/20 15:43	231.75	27.11	9.90	12.83	151.57	1162.39	4.55
3/10/20 15:44	231.67	27.07	9.90	12.83	151.81	1162.45	4.55
3/10/20 15:45	231.72	27.08	9.90	12.83	151.95	1162.89	4.56
3/10/20 15:46	232.07	27.06	9.91	12.83	152.08	1162.81	4.56
3/10/20 15:47	231.91	27.03	9.91	12.83	151.27	1162.53	4.56
3/10/20 15:48	232.09	27.06	9.91	12.83	151.36	1162.60	4.56
3/10/20 15:49	231.76	27.11	9.91	12.75	150.75	1162.71	4.56
3/10/20 15:50	231.82	27.12	9.92	12.61	152.16	1162.74	4.56
3/10/20 15:51	231.59	27.15	9.92	12.55	151.94	1162.86	4.56
3/10/20 15:52	231.65	27.06	9.92	12.54	151.82	1162.32	4.56
3/10/20 15:53	231.88	27.15	9.92	12.54	151.45	1162.04	4.56
3/10/20 15:54	231.67	27.02	9.93	12.54	151.33	1162.77	4.56
3/10/20 15:55	231.59	27.04	9.93	12.55	151.85	1162.18	4.56
3/10/20 15:56	231.77	27.04	9.93	12.55	151.14	1162.22	4.56
3/10/20 15:57	231.58	27.03	9.93	12.55	151.25	1162.41	4.56
3/10/20 15:58	231.82	27.16	9.94	12.55	151.05	1162.67	4.56
3/10/20 15:59	231.78	27.10	9.94	12.56	151.64	1162.54	4.56
3/10/20 16:00	231.88	27.08	9.94	12.56	152.21	1162.71	4.56
3/10/20 16:01	231.73	27.06	9.94	12.56	152.37	1162.28	4.56
3/10/20 16:02	231.37	27.08	9.95	12.56	152.60	1162.23	4.56
3/10/20 16:03	231.77	27.08	9.95	12.56	152.06	1162.44	4.56
3/10/20 16:04	231.99	27.10	9.95	12.57	151.86	1162.69	4.56
3/10/20 16:05	231.95	27.08	9.95	12.57	149.53	1162.41	4.56
3/10/20 16:06	232.15	27.06	9.96	12.57	150.11	1162.59	4.56
3/10/20 16:07	232.10	27.08	9.96	12.57	150.60	1162.26	4.56
3/10/20 16:08	231.82	27.05	9.96	12.58	151.64	1162.18	4.56
3/10/20 16:09	231.97	27.11	9.96	12.58	151.56	1161.92	4.56
3/10/20 16:10	231.77	27.09	9.97	12.57	152.04	1162.09	4.56
3/10/20 16:11	231.99	27.14	9.97	12.57	151.67	1162.68	4.57
3/10/20 16:12	232.27	27.13	9.97	12.57	152.46	1162.18	4.57
3/10/20 16:13	231.93	27.11	9.97	12.57	151.57	1162.32	4.57
3/10/20 16:14	231.85	27.12	9.98	12.56	151.10	1162.52	4.57
3/10/20 16:15	231.72	27.08	9.98	12.56	151.13	1162.17	4.57
3/10/20 16:16	231.75	27.05	9.98	12.56	150.92	1162.43	4.57
3/10/20 16:17	232.22	27.05	9.98	12.56	151.28	1162.64	4.57
3/10/20 16:18	231.87	27.11	9.99	12.55	151.42	1162.36	4.57
3/10/20 16:19	231.84	27.09	9.99	12.55	151.56	1162.37	4.57
3/10/20 16:20	231.85	27.19	9.99	12.55	151.49	1162.37	4.57
3/10/20 16:21	231.94	27.10	10.00	12.55	150.92	1162.55	4.57
3/10/20 16:22	231.97	27.11	10.00	12.54	151.34	1162.44	4.57
3/10/20 16:23	232.20	27.11	10.00	12.54	151.07	1162.21	4.57
3/10/20 16:24	232.02	27.13	10.00	12.54	150.51	1162.47	4.57
3/10/20 16:25	232.00	27.15	10.01	12.53	151.23	1162.02	4.57

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 14:12 - 3/10 18:40)	231.92	27.08	10.01	12.64	151.49	1162.44	4.57
COUNT = 269							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 16:26	231.96	27.07	10.01	12.53	149.81	1162.08	4.57
3/10/20 16:27	231.97	27.07	10.01	12.53	151.02	1162.44	4.57
3/10/20 16:28	231.84	27.05	10.01	12.53	150.10	1162.60	4.57
3/10/20 16:29	232.02	27.09	10.02	12.54	149.83	1162.01	4.57
3/10/20 16:30	232.07	27.11	10.02	12.54	149.98	1162.13	4.57
3/10/20 16:31	231.98	27.06	10.02	12.55	150.46	1162.43	4.57
3/10/20 16:32	231.91	27.06	10.02	12.56	150.86	1162.35	4.57
3/10/20 16:33	231.98	27.10	10.03	12.56	151.31	1161.89	4.57
3/10/20 16:34	232.06	27.17	10.03	12.57	151.36	1162.31	4.57
3/10/20 16:35	231.98	27.07	10.03	12.57	151.58	1162.09	4.57
3/10/20 16:36	231.98	27.09	10.03	12.58	151.76	1161.99	4.57
3/10/20 16:37	232.21	27.14	10.04	12.58	151.56	1162.55	4.58
3/10/20 16:38	232.32	27.08	10.04	12.59	151.22	1162.65	4.58
3/10/20 16:39	231.87	27.03	10.04	12.60	152.04	1162.12	4.58
3/10/20 16:40	231.92	27.04	10.04	12.60	152.10	1162.03	4.58
3/10/20 16:41	232.08	27.09	10.05	12.61	150.58	1161.95	4.58
3/10/20 16:42	232.05	27.10	10.05	12.61	150.93	1162.20	4.58
3/10/20 16:43	231.89	27.06	10.05	12.62	150.34	1162.38	4.58
3/10/20 16:44	232.15	27.01	10.05	12.62	150.92	1162.04	4.58
3/10/20 16:45	232.05	27.12	10.06	12.63	150.10	1162.42	4.58
3/10/20 16:46	231.95	27.11	10.06	12.64	150.18	1162.41	4.58
3/10/20 16:47	232.19	27.08	10.06	12.64	149.21	1162.19	4.58
3/10/20 16:48	231.67	27.07	10.06	12.65	150.13	1161.79	4.58
3/10/20 16:49	232.04	27.17	10.07	12.65	150.56	1161.81	4.58
3/10/20 16:50	231.93	27.08	10.07	12.66	151.12	1162.15	4.58
3/10/20 16:51	231.99	27.06	10.07	12.66	150.67	1161.89	4.58
3/10/20 16:52	232.00	27.11	10.07	12.67	150.37	1161.81	4.58
3/10/20 16:53	231.99	27.05	10.08	12.68	150.76	1162.13	4.58
3/10/20 16:54	231.83	27.08	10.08	12.68	150.43	1162.21	4.58
3/10/20 16:55	232.16	27.02	10.08	12.69	150.53	1161.66	4.58
3/10/20 16:56	232.04	27.07	10.08	12.69	150.89	1162.17	4.58
3/10/20 16:57	231.80	27.10	10.09	12.70	150.40	1161.89	4.58
3/10/20 16:58	231.89	27.07	10.09	12.73	150.59	1161.80	4.58
3/10/20 16:59	232.06	27.10	10.09	12.75	150.88	1161.95	4.58
3/10/20 17:00	232.23	27.12	10.09	12.78	150.21	1162.13	4.58
3/10/20 17:01	231.94	27.07	10.10	12.80	149.97	1162.25	4.58
3/10/20 17:02	231.97	26.99	10.10	12.82	149.57	1162.00	4.58
3/10/20 17:03	231.82	27.11	10.10	12.83	149.88	1161.60	4.59
3/10/20 17:04	232.13	27.09	10.10	12.79	150.47	1162.16	4.59
3/10/20 17:05	231.90	27.04	10.11	12.75	150.31	1162.00	4.59
3/10/20 17:06	232.16	27.17	10.11	12.71	150.31	1161.73	4.59
3/10/20 17:07	232.04	27.11	10.11	12.67	150.22	1162.04	4.59
3/10/20 17:08	231.90	27.08	10.11	12.63	150.10	1161.92	4.59
3/10/20 17:09	232.02	27.11	10.12	12.59	150.22	1162.00	4.59
3/10/20 17:10	231.94	27.05	10.12	12.55	150.83	1162.61	4.59
3/10/20 17:11	231.82	27.13	10.12	12.51	149.91	1161.51	4.59
3/10/20 17:12	231.91	27.06	10.13	12.47	150.50	1162.05	4.59
3/10/20 17:13	232.03	27.01	10.13	12.49	150.09	1161.72	4.59
3/10/20 17:14	232.09	27.06	10.13	12.51	150.04	1161.78	4.59
3/10/20 17:15	231.80	27.05	10.13	12.53	150.19	1161.59	4.59
3/10/20 17:16	231.91	27.07	10.14	12.54	150.07	1161.73	4.59
3/10/20 17:17	231.76	27.04	10.14	12.56	150.52	1161.96	4.59
3/10/20 17:18	231.75	27.08	10.14	12.58	150.23	1161.74	4.59
3/10/20 17:19	232.17	27.06	10.14	12.60	149.71	1161.92	4.59
3/10/20 17:20	231.95	27.03	10.15	12.62	149.39	1161.85	4.59
3/10/20 17:21	232.13	27.06	10.15	12.64	149.83	1162.63	4.59
3/10/20 17:22	231.97	27.11	10.15	12.66	149.71	1161.80	4.59
3/10/20 17:23	232.01	27.07	10.15	12.68	149.64	1162.00	4.59
3/10/20 17:24	231.77	27.05	10.16	12.70	150.41	1161.30	4.59
3/10/20 17:25	231.69	27.13	10.16	12.72	151.16	1161.74	4.59
3/10/20 17:26	232.20	27.10	10.16	12.73	150.04	1161.97	4.59
3/10/20 17:27	231.93	27.07	10.16	12.74	149.69	1161.84	4.59
3/10/20 17:28	231.71	27.12	10.17	12.74	150.10	1161.99	4.59
3/10/20 17:29	231.83	27.08	10.17	12.74	148.87	1162.13	4.60
3/10/20 17:30	231.78	27.18	10.17	12.74	149.85	1161.98	4.60
3/10/20 17:31	231.77	27.06	10.17	12.75	149.55	1161.90	4.60
3/10/20 17:32	231.66	27.08	10.18	12.75	148.97	1161.62	4.60

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 14:12 - 3/10 18:40)	231.92	27.08	10.01	12.64	151.49	1162.44	4.57
COUNT = 269							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 17:33	232.00	27.17	10.18	12.75	149.12	1161.46	4.60
3/10/20 17:34	231.91	27.07	10.18	12.76	148.46	1162.01	4.60
3/10/20 17:35	232.26	27.10	10.18	12.76	149.44	1161.86	4.60
3/10/20 17:36	232.22	27.08	10.19	12.77	149.77	1161.62	4.60
3/10/20 17:37	232.10	27.04	10.19	12.77	150.40	1161.69	4.60
3/10/20 17:38	232.07	27.10	10.19	12.78	151.18	1161.61	4.60
3/10/20 17:39	231.96	27.07	10.19	12.78	152.15	1161.45	4.60
3/10/20 17:40	231.76	27.11	10.20	12.79	151.41	1161.93	4.60
3/10/20 17:41	231.97	27.02	10.20	12.79	151.44	1161.62	4.60
3/10/20 17:42	231.74	27.10	10.20	12.79	151.27	1161.57	4.60
3/10/20 17:43	231.95	27.10	10.20	12.80	151.55	1161.33	4.60
3/10/20 17:44	232.00	27.11	10.21	12.80	151.37	1161.69	4.60
3/10/20 17:45	231.89	27.08	10.21	12.81	151.21	1161.72	4.60
3/10/20 17:46	231.91	27.05	10.21	12.81	151.15	1161.75	4.60
3/10/20 17:47	232.17	27.15	10.21	12.81	150.20	1161.84	4.60
3/10/20 17:48	231.93	27.08	10.22	12.79	149.55	1161.83	4.60
3/10/20 17:49	232.16	27.10	10.22	12.76	149.36	1161.69	4.60
3/10/20 17:50	232.15	27.05	10.22	12.74	149.22	1161.75	4.60
3/10/20 17:51	232.17	27.06	10.22	12.71	149.22	1161.97	4.60
3/10/20 17:52	232.10	27.09	10.23	12.69	149.98	1161.20	4.60
3/10/20 17:53	231.90	27.08	10.23	12.66	150.21	1161.73	4.60
3/10/20 17:54	232.06	27.03	10.23	12.64	149.71	1161.99	4.60
3/10/20 17:55	232.21	27.11	10.23	12.61	149.67	1161.74	4.61
3/10/20 17:56	231.91	27.08	10.24	12.59	150.42	1161.53	4.61
3/10/20 17:57	232.12	27.13	10.24	12.56	150.25	1160.95	4.61
3/10/20 17:58	232.01	27.06	10.24	12.54	149.91	1161.33	4.61
3/10/20 17:59	232.03	27.10	10.25	12.52	150.16	1161.62	4.61
3/10/20 18:00	231.89	27.12	10.25	12.50	149.48	1161.78	4.61
3/10/20 18:01	232.24	27.06	10.25	12.49	148.74	1161.80	4.61
3/10/20 18:02	231.94	27.12	10.25	12.47	149.92	1161.57	4.61
3/10/20 18:03	232.35	27.10	10.26	12.46	149.81	1162.18	4.61
3/10/20 18:04	231.94	27.06	10.26	12.45	150.07	1161.54	4.61
3/10/20 18:05	232.04	27.11	10.26	12.44	149.42	1161.80	4.61
3/10/20 18:06	232.03	27.12	10.26	12.43	150.33	1161.55	4.61
3/10/20 18:07	232.11	27.10	10.27	12.44	149.66	1161.44	4.61
3/10/20 18:08	232.49	27.06	10.27	12.47	148.70	1161.50	4.61
3/10/20 18:09	232.01	27.05	10.27	12.50	149.18	1161.90	4.61
3/10/20 18:10	231.91	27.00	10.27	12.53	149.11	1161.25	4.61
3/10/20 18:11	232.05	26.98	10.28	12.53	149.26	1161.51	4.61
3/10/20 18:12	231.89	27.08	10.28	12.53	149.67	1161.30	4.61
3/10/20 18:13	231.84	27.07	10.28	12.53	149.88	1161.37	4.61
3/10/20 18:14	232.06	27.04	10.28	12.52	149.66	1161.78	4.61
3/10/20 18:15	232.03	27.10	10.29	12.52	149.73	1161.91	4.61
3/10/20 18:16	231.97	27.03	10.29	12.52	149.69	1161.49	4.61
3/10/20 18:17	231.74	27.06	10.29	12.58	148.84	1161.92	4.61
3/10/20 18:18	232.07	27.09	10.29	12.67	148.63	1161.71	4.61
3/10/20 18:19	232.07	26.99	10.30	12.72	148.25	1161.77	4.61
3/10/20 18:20	232.03	27.08	10.30	12.69	147.89	1161.59	4.61
3/10/20 18:21	232.08	27.03	10.30	12.67	148.63	1161.52	4.62
3/10/20 18:22	232.06	27.11	10.30	12.64	148.40	1161.28	4.62
3/10/20 18:23	232.09	27.03	10.31	12.65	148.41	1161.86	4.62
3/10/20 18:24	232.05	27.10	10.31	12.67	148.89	1161.73	4.62
3/10/20 18:25	232.08	27.08	10.31	12.70	149.48	1162.01	4.62
3/10/20 18:26	232.28	27.08	10.31	12.72	150.26	1161.71	4.62
3/10/20 18:27	232.10	27.10	10.32	12.74	150.64	1161.61	4.62
3/10/20 18:28	232.31	27.09	10.32	12.76	150.42	1161.50	4.62
3/10/20 18:29	232.18	27.06	10.32	12.79	149.58	1161.96	4.62
3/10/20 18:30	232.22	27.07	10.32	12.81	149.58	1161.73	4.62
3/10/20 18:31	232.13	27.08	10.33	12.83	150.44	1162.04	4.62
3/10/20 18:32	231.94	27.16	10.33	12.86	150.08	1161.55	4.62
3/10/20 18:33	231.95	27.10	10.33	12.87	149.18	1161.66	4.62
3/10/20 18:34	232.19	27.06	10.33	12.87	149.76	1162.03	4.62
3/10/20 18:35	232.34	27.07	10.34	12.86	149.00	1161.79	4.62
3/10/20 18:36	232.26	27.15	10.34	12.85	149.92	1162.09	4.62
3/10/20 18:37	232.12	27.09	10.34	12.84	149.15	1161.83	4.62
3/10/20 18:38	232.19	27.06	10.34	12.83	149.35	1161.56	4.62
3/10/20 18:39	232.18	27.07	10.35	12.83	149.05	1161.72	4.62

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 14:12 - 3/10 18:40) COUNT = 269	231.92	27.08	10.01	12.64	151.49	1162.44	4.57
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 18:40	232.05	27.08	10.35	12.82	149.58	1161.95	4.62

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 6:23 - 3/11 11:17)		240.66	27.71	10.57	12.65	180.46	1176.26	4.37
COUNT = 295								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/11/20 6:23	241.92	27.81	10.57	12.62	215.51	1172.17	4.47
	3/11/20 6:24	242.26	27.83	10.57	12.59	217.02	1172.23	4.47
	3/11/20 6:25	242.11	27.90	10.57	12.56	212.61	1172.22	4.47
	3/11/20 6:26	241.99	27.83	10.57	12.54	208.34	1171.97	4.47
	3/11/20 6:27	242.18	27.83	10.57	12.51	206.86	1172.03	4.47
	3/11/20 6:28	242.33	27.84	10.57	12.49	207.27	1172.77	4.46
	3/11/20 6:29	242.35	27.89	10.57	12.50	209.88	1171.83	4.46
	3/11/20 6:30	242.17	27.86	10.57	12.50	211.73	1172.31	4.46
	3/11/20 6:31	242.32	27.83	10.57	12.51	211.25	1172.13	4.46
	3/11/20 6:32	241.91	27.87	10.57	12.52	211.75	1171.71	4.46
	3/11/20 6:33	241.96	27.79	10.57	12.52	212.97	1171.98	4.46
	3/11/20 6:34	241.94	27.96	10.57	12.53	213.22	1171.78	4.46
	3/11/20 6:35	242.33	27.88	10.57	12.53	213.79	1171.59	4.46
	3/11/20 6:36	242.15	27.81	10.57	12.54	213.91	1171.44	4.46
	3/11/20 6:37	242.12	27.80	10.57	12.54	213.95	1171.79	4.46
	3/11/20 6:38	241.99	27.90	10.57	12.55	214.03	1171.77	4.46
	3/11/20 6:39	242.43	27.89	10.57	12.55	214.94	1172.52	4.46
	3/11/20 6:40	241.98	27.88	10.57	12.51	216.84	1171.78	4.46
	3/11/20 6:41	241.97	27.95	10.57	12.48	218.89	1171.99	4.46
	3/11/20 6:42	242.56	27.80	10.57	12.45	218.63	1172.47	4.45
	3/11/20 6:43	242.27	27.91	10.57	12.42	217.07	1172.16	4.45
	3/11/20 6:44	242.12	27.89	10.57	12.39	215.76	1172.09	4.45
	3/11/20 6:45	242.13	27.85	10.57	12.35	215.95	1172.25	4.45
	3/11/20 6:46	242.12	27.84	10.57	12.32	217.86	1171.59	4.45
	3/11/20 6:47	242.38	27.93	10.57	12.35	218.31	1172.36	4.45
	3/11/20 6:48	242.33	27.90	10.57	12.40	216.88	1171.41	4.45
	3/11/20 6:49	242.12	27.78	10.57	12.44	215.52	1171.86	4.45
	3/11/20 6:50	242.01	27.88	10.57	12.48	217.38	1171.83	4.45
	3/11/20 6:51	238.67	27.57	10.57	12.57	217.42	1175.48	4.45
	3/11/20 6:52	239.66	27.62	10.57	12.68	178.95	1180.09	4.45
	3/11/20 6:53	240.18	27.71	10.57	12.67	174.46	1176.81	4.45
	3/11/20 6:54	242.04	27.80	10.57	12.66	166.58	1173.63	4.45
	3/11/20 6:55	239.58	27.67	10.57	12.66	197.44	1174.32	4.45
	3/11/20 6:56	240.66	27.64	10.57	12.65	166.61	1178.27	4.44
	3/11/20 6:57	241.80	27.88	10.58	12.65	168.67	1173.64	4.44
	3/11/20 6:58	241.28	27.80	10.58	12.64	210.52	1174.60	4.44
	3/11/20 6:59	241.15	27.83	10.58	12.64	186.52	1174.39	4.44
	3/11/20 7:00	241.25	27.73	10.58	12.63	187.74	1175.37	4.44
	3/11/20 7:01	242.34	27.91	10.58	12.63	188.49	1171.89	4.44
	3/11/20 7:02	242.36	27.95	10.58	12.62	188.32	1172.20	4.44
	3/11/20 7:03	242.19	27.95	10.58	12.62	188.72	1171.35	4.44
	3/11/20 7:04	241.97	27.89	10.58	12.61	188.70	1172.01	4.44
	3/11/20 7:05	242.37	27.91	10.58	12.61	188.57	1172.58	4.44
	3/11/20 7:06	241.73	27.92	10.58	12.60	188.20	1170.79	4.44
	3/11/20 7:07	241.93	27.96	10.58	12.60	188.65	1171.36	4.44
	3/11/20 7:08	242.23	27.91	10.58	12.59	188.40	1170.93	4.44
	3/11/20 7:09	242.32	27.86	10.58	12.59	188.59	1171.59	4.44
	3/11/20 7:10	241.75	27.85	10.58	12.58	188.11	1171.27	4.43
	3/11/20 7:11	242.00	27.88	10.58	12.57	187.41	1170.80	4.43
	3/11/20 7:12	241.89	27.94	10.58	12.57	187.93	1171.33	4.43
	3/11/20 7:13	242.22	27.90	10.58	12.56	187.59	1171.46	4.43
	3/11/20 7:14	241.98	27.84	10.58	12.58	187.60	1171.45	4.43
	3/11/20 7:15	241.85	27.88	10.58	12.63	187.46	1171.05	4.43
	3/11/20 7:16	242.20	27.88	10.58	12.68	187.59	1171.55	4.43
	3/11/20 7:17	241.84	27.88	10.58	12.72	188.21	1171.37	4.43
	3/11/20 7:18	236.96	27.33	10.58	12.77	188.46	1180.71	4.43
	3/11/20 7:19	239.16	27.54	10.58	12.77	188.19	1179.16	4.43
	3/11/20 7:20	239.53	27.63	10.58	12.76	188.56	1177.31	4.43
	3/11/20 7:21	239.58	27.63	10.58	12.76	188.59	1177.58	4.43
	3/11/20 7:22	239.71	27.57	10.58	12.75	187.95	1176.94	4.43
	3/11/20 7:23	239.88	27.74	10.58	12.74	188.01	1175.89	4.43
	3/11/20 7:24	240.41	27.71	10.58	12.74	187.75	1175.10	4.42
	3/11/20 7:25	240.17	27.67	10.58	12.73	188.07	1175.81	4.42
	3/11/20 7:26	240.09	27.68	10.58	12.73	188.12	1175.98	4.42
	3/11/20 7:27	238.06	27.45	10.58	12.72	187.86	1181.10	4.42
	3/11/20 7:28	238.83	27.52	10.58	12.70	187.99	1179.35	4.42
	3/11/20 7:29	238.93	27.57	10.58	12.69	187.37	1179.13	4.42

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 6:23 - 3/11 11:17)	240.66	27.71	10.57	12.65	180.46	1176.26	4.37
COUNT = 295							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 7:30	239.63	27.54	10.58	12.67	187.75	1178.31	4.42
3/11/20 7:31	238.89	27.53	10.58	12.65	188.15	1178.81	4.42
3/11/20 7:32	240.20	27.69	10.58	12.64	188.05	1176.89	4.42
3/11/20 7:33	240.26	27.77	10.58	12.62	188.37	1176.26	4.42
3/11/20 7:34	239.68	27.62	10.58	12.60	188.23	1176.61	4.42
3/11/20 7:35	240.31	27.65	10.58	12.59	188.13	1177.56	4.42
3/11/20 7:36	240.46	27.72	10.58	12.57	188.16	1175.84	4.42
3/11/20 7:37	238.88	27.51	10.58	12.55	187.88	1181.96	4.42
3/11/20 7:38	240.33	27.71	10.58	12.54	187.86	1177.72	4.41
3/11/20 7:39	240.69	27.65	10.58	12.52	187.79	1177.56	4.41
3/11/20 7:40	241.91	27.87	10.58	12.56	184.34	1171.95	4.41
3/11/20 7:41	241.13	27.81	10.58	12.63	219.04	1175.62	4.41
3/11/20 7:42	240.96	27.72	10.58	12.70	199.34	1175.35	4.41
3/11/20 7:43	241.17	27.68	10.58	12.77	185.80	1175.24	4.41
3/11/20 7:44	241.05	27.76	10.58	12.78	185.97	1175.91	4.41
3/11/20 7:45	241.28	27.75	10.58	12.76	183.09	1174.87	4.41
3/11/20 7:46	240.97	27.78	10.58	12.74	179.09	1175.15	4.41
3/11/20 7:47	240.79	27.85	10.58	12.73	176.21	1176.00	4.41
3/11/20 7:48	240.81	27.71	10.58	12.71	174.62	1175.67	4.41
3/11/20 7:49	240.68	27.65	10.58	12.67	171.12	1176.18	4.41
3/11/20 7:50	240.95	27.68	10.58	12.61	166.02	1177.08	4.41
3/11/20 7:51	240.95	27.76	10.58	12.56	164.03	1176.25	4.41
3/11/20 7:52	240.89	27.63	10.58	12.52	163.75	1176.22	4.40
3/11/20 7:53	240.34	27.71	10.58	12.54	163.03	1176.45	4.40
3/11/20 7:54	238.55	27.45	10.58	12.55	159.08	1181.66	4.40
3/11/20 7:55	238.36	27.40	10.58	12.57	156.77	1183.08	4.40
3/11/20 7:56	239.96	27.66	10.58	12.59	154.65	1179.44	4.40
3/11/20 7:57	240.02	27.69	10.58	12.61	152.16	1178.42	4.40
3/11/20 7:58	240.37	27.66	10.58	12.62	151.77	1177.87	4.40
3/11/20 7:59	239.87	27.67	10.58	12.62	146.33	1177.63	4.40
3/11/20 8:00	240.14	27.68	10.58	12.61	145.27	1177.22	4.40
3/11/20 8:01	239.99	27.58	10.58	12.61	145.90	1177.77	4.40
3/11/20 8:02	240.27	27.74	10.58	12.61	146.26	1178.08	4.40
3/11/20 8:03	240.25	27.61	10.58	12.60	146.16	1177.82	4.40
3/11/20 8:04	240.19	27.64	10.58	12.60	145.41	1178.31	4.40
3/11/20 8:05	239.97	27.61	10.58	12.59	144.99	1177.57	4.40
3/11/20 8:06	239.43	27.56	10.58	12.59	145.46	1179.12	4.39
3/11/20 8:07	239.14	27.59	10.58	12.58	141.26	1180.92	4.39
3/11/20 8:08	239.96	27.63	10.58	12.58	135.54	1179.06	4.39
3/11/20 8:09	239.84	27.64	10.58	12.57	133.12	1178.32	4.39
3/11/20 8:10	240.83	27.63	10.58	12.57	135.64	1178.22	4.39
3/11/20 8:11	242.09	27.88	10.58	12.59	156.84	1171.98	4.39
3/11/20 8:12	239.11	27.49	10.58	12.62	212.88	1179.14	4.39
3/11/20 8:13	238.52	27.51	10.58	12.65	132.63	1182.69	4.39
3/11/20 8:14	239.60	27.52	10.58	12.69	131.09	1181.47	4.39
3/11/20 8:15	239.46	27.55	10.58	12.72	160.99	1180.28	4.39
3/11/20 8:16	239.85	27.64	10.58	12.75	168.70	1179.34	4.39
3/11/20 8:17	240.10	27.67	10.58	12.79	163.09	1178.58	4.39
3/11/20 8:18	239.61	27.61	10.58	12.80	154.26	1179.71	4.39
3/11/20 8:19	240.28	27.71	10.58	12.80	146.92	1177.87	4.39
3/11/20 8:20	240.49	27.68	10.58	12.81	143.85	1178.63	4.38
3/11/20 8:21	240.38	27.72	10.58	12.81	143.37	1178.30	4.38
3/11/20 8:22	239.50	27.54	10.58	12.81	144.52	1179.63	4.38
3/11/20 8:23	239.84	27.60	10.58	12.82	143.92	1180.33	4.38
3/11/20 8:24	239.43	27.53	10.58	12.82	140.70	1179.73	4.38
3/11/20 8:25	239.44	27.51	10.58	12.83	136.61	1180.79	4.38
3/11/20 8:26	240.11	27.56	10.58	12.83	135.07	1179.76	4.38
3/11/20 8:27	239.92	27.64	10.58	12.84	134.52	1179.82	4.38
3/11/20 8:28	239.89	27.62	10.58	12.84	137.20	1179.61	4.38
3/11/20 8:29	239.73	27.58	10.58	12.85	138.72	1179.77	4.38
3/11/20 8:30	240.18	27.62	10.58	12.85	139.53	1180.85	4.38
3/11/20 8:31	241.38	27.72	10.58	12.85	136.63	1176.69	4.38
3/11/20 8:32	241.43	27.70	10.58	12.86	173.37	1176.16	4.38
3/11/20 8:33	239.42	27.55	10.58	12.86	179.57	1180.30	4.38
3/11/20 8:34	239.13	27.53	10.58	12.86	148.42	1181.65	4.37
3/11/20 8:35	239.52	27.54	10.58	12.85	148.39	1180.98	4.37
3/11/20 8:36	239.58	27.60	10.58	12.83	150.32	1180.16	4.37

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 6:23 - 3/11 11:17)		240.66	27.71	10.57	12.65	180.46	1176.26	4.37
COUNT = 295								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/11/20 8:37	239.70	27.54	10.58	12.82	152.59	1180.46	4.37
	3/11/20 8:38	240.26	27.66	10.58	12.81	152.26	1178.63	4.37
	3/11/20 8:39	240.23	27.71	10.58	12.80	149.33	1178.30	4.37
	3/11/20 8:40	240.35	27.68	10.58	12.78	146.71	1178.18	4.37
	3/11/20 8:41	240.59	27.67	10.58	12.76	146.36	1177.87	4.37
	3/11/20 8:42	240.40	27.65	10.58	12.74	146.15	1178.25	4.37
	3/11/20 8:43	238.82	27.46	10.58	12.72	146.76	1180.29	4.37
	3/11/20 8:44	238.83	27.54	10.58	12.70	144.07	1182.54	4.37
	3/11/20 8:45	238.94	27.54	10.58	12.68	145.36	1180.68	4.37
	3/11/20 8:46	240.27	27.62	10.58	12.66	142.60	1179.37	4.37
	3/11/20 8:47	240.02	27.62	10.58	12.61	140.94	1178.45	4.37
	3/11/20 8:48	240.09	27.59	10.58	12.52	140.36	1177.73	4.37
	3/11/20 8:49	240.26	27.63	10.58	12.47	143.07	1178.01	4.36
	3/11/20 8:50	238.97	27.54	10.58	12.52	146.79	1181.25	4.36
	3/11/20 8:51	239.21	27.52	10.58	12.56	148.81	1179.95	4.36
	3/11/20 8:52	238.91	27.34	10.58	12.61	144.67	1183.73	4.36
	3/11/20 8:53	240.89	27.67	10.58	12.65	142.16	1176.99	4.36
	3/11/20 8:54	242.21	27.77	10.58	12.64	147.84	1173.13	4.36
	3/11/20 8:55	242.07	27.89	10.58	12.64	199.62	1172.79	4.36
	3/11/20 8:56	242.44	27.92	10.58	12.63	210.15	1173.53	4.36
	3/11/20 8:57	242.23	27.90	10.58	12.63	194.04	1173.61	4.36
	3/11/20 8:58	242.03	27.91	10.58	12.62	205.98	1173.70	4.36
	3/11/20 8:59	242.03	27.81	10.58	12.62	212.41	1173.18	4.36
	3/11/20 9:00	242.29	27.78	10.58	12.61	215.84	1173.97	4.36
	3/11/20 9:01	242.35	27.88	10.58	12.61	222.35	1173.69	4.36
	3/11/20 9:02	241.86	27.84	10.58	12.61	220.66	1173.80	4.36
	3/11/20 9:03	242.26	27.87	10.58	12.63	221.21	1173.27	4.35
	3/11/20 9:04	241.94	27.90	10.58	12.65	220.29	1173.44	4.35
	3/11/20 9:05	242.04	27.84	10.58	12.67	218.11	1174.03	4.35
	3/11/20 9:06	242.23	27.80	10.58	12.69	218.65	1173.63	4.35
	3/11/20 9:07	242.22	27.82	10.58	12.71	216.96	1173.66	4.35
	3/11/20 9:08	241.83	27.93	10.58	12.73	218.49	1173.16	4.35
	3/11/20 9:09	237.79	27.30	10.58	12.74	220.15	1183.64	4.35
	3/11/20 9:10	239.67	27.55	10.58	12.75	178.61	1180.21	4.35
	3/11/20 9:11	239.74	27.63	10.58	12.76	171.04	1179.51	4.35
	3/11/20 9:12	239.52	27.60	10.58	12.77	164.77	1179.78	4.35
	3/11/20 9:13	240.84	27.66	10.58	12.78	157.84	1177.81	4.35
	3/11/20 9:14	240.98	27.75	10.58	12.78	159.13	1175.50	4.35
	3/11/20 9:15	241.23	27.74	10.58	12.79	166.66	1176.51	4.35
	3/11/20 9:16	237.45	27.38	10.58	12.80	172.57	1181.51	4.35
	3/11/20 9:17	241.00	27.71	10.58	12.79	170.68	1177.42	4.34
	3/11/20 9:18	241.11	27.73	10.58	12.78	166.66	1175.83	4.34
	3/11/20 9:19	241.93	27.79	10.58	12.77	172.30	1173.99	4.34
	3/11/20 9:20	242.04	27.85	10.58	12.75	208.65	1173.88	4.34
	3/11/20 9:21	241.89	27.88	10.57	12.74	213.08	1174.02	4.34
	3/11/20 9:22	241.86	27.92	10.57	12.73	214.09	1174.23	4.34
	3/11/20 9:23	241.91	27.85	10.57	12.72	210.73	1173.90	4.34
	3/11/20 9:24	241.78	27.82	10.57	12.71	209.48	1175.18	4.34
	3/11/20 9:25	242.16	27.83	10.57	12.70	208.12	1175.24	4.34
	3/11/20 9:26	241.88	27.74	10.57	12.68	205.52	1174.89	4.34
	3/11/20 9:27	242.26	27.86	10.57	12.67	205.10	1174.78	4.34
	3/11/20 9:28	241.75	27.88	10.57	12.66	210.81	1174.21	4.34
	3/11/20 9:29	242.06	27.85	10.57	12.65	212.56	1174.01	4.34
	3/11/20 9:30	241.92	27.91	10.57	12.64	213.91	1173.96	4.34
	3/11/20 9:31	242.04	27.77	10.57	12.63	214.13	1173.31	4.33
	3/11/20 9:32	242.06	27.83	10.57	12.62	214.53	1174.11	4.33
	3/11/20 9:33	242.09	27.88	10.57	12.60	214.61	1174.17	4.33
	3/11/20 9:34	242.14	27.90	10.57	12.59	214.21	1174.80	4.33
	3/11/20 9:35	241.98	27.83	10.57	12.57	213.38	1174.41	4.33
	3/11/20 9:36	242.11	27.81	10.57	12.55	213.76	1173.99	4.33
	3/11/20 9:37	241.93	27.81	10.57	12.53	213.81	1173.75	4.33
	3/11/20 9:38	242.17	27.78	10.57	12.51	214.77	1174.78	4.33
	3/11/20 9:39	241.99	27.87	10.57	12.49	213.50	1174.08	4.33
	3/11/20 9:40	242.27	27.82	10.57	12.51	213.90	1174.64	4.33
	3/11/20 9:41	242.00	27.83	10.57	12.57	213.44	1173.70	4.33
	3/11/20 9:42	241.86	27.83	10.57	12.62	213.81	1173.89	4.33
	3/11/20 9:43	241.96	27.84	10.57	12.68	214.11	1173.88	4.33

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 6:23 - 3/11 11:17)	240.66	27.71	10.57	12.65	180.46	1176.26	4.37
COUNT = 295							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 9:44	241.74	27.75	10.57	12.74	214.00	1174.51	4.33
3/11/20 9:45	241.65	27.85	10.57	12.79	213.83	1174.02	4.32
3/11/20 9:46	238.87	27.58	10.57	12.85	212.53	1179.78	4.32
3/11/20 9:47	238.30	27.57	10.57	12.82	166.37	1183.73	4.32
3/11/20 9:48	238.16	27.52	10.57	12.79	165.42	1183.37	4.32
3/11/20 9:49	241.17	27.82	10.57	12.77	160.42	1177.20	4.32
3/11/20 9:50	240.90	27.68	10.57	12.74	170.20	1176.77	4.32
3/11/20 9:51	240.55	27.65	10.57	12.72	181.94	1177.46	4.32
3/11/20 9:52	240.46	27.75	10.57	12.72	176.99	1176.95	4.32
3/11/20 9:53	241.52	27.84	10.57	12.71	171.72	1174.49	4.32
3/11/20 9:54	240.44	27.61	10.57	12.71	201.42	1178.29	4.32
3/11/20 9:55	241.74	27.84	10.57	12.71	183.85	1173.76	4.32
3/11/20 9:56	241.62	27.87	10.57	12.71	205.01	1174.20	4.32
3/11/20 9:57	241.67	27.88	10.57	12.70	208.19	1174.07	4.32
3/11/20 9:58	241.72	27.84	10.57	12.70	208.20	1174.28	4.32
3/11/20 9:59	238.49	27.49	10.57	12.69	209.14	1179.95	4.31
3/11/20 10:00	240.39	27.67	10.57	12.68	164.44	1180.24	4.31
3/11/20 10:01	241.50	27.84	10.57	12.66	175.74	1173.94	4.31
3/11/20 10:02	241.98	27.80	10.57	12.64	207.94	1173.24	4.31
3/11/20 10:03	241.80	27.75	10.57	12.63	211.59	1173.91	4.31
3/11/20 10:04	241.63	27.80	10.57	12.61	213.26	1173.45	4.31
3/11/20 10:05	241.35	27.87	10.57	12.60	211.81	1173.74	4.31
3/11/20 10:06	241.62	27.83	10.57	12.60	211.18	1174.73	4.31
3/11/20 10:07	241.69	27.85	10.57	12.60	209.53	1174.39	4.31
3/11/20 10:08	241.89	27.84	10.57	12.59	209.35	1174.41	4.31
3/11/20 10:09	241.34	27.82	10.57	12.59	212.27	1173.96	4.31
3/11/20 10:10	241.78	27.79	10.57	12.59	213.16	1174.35	4.31
3/11/20 10:11	241.33	27.79	10.57	12.58	212.55	1173.99	4.31
3/11/20 10:12	241.31	27.80	10.57	12.58	212.38	1173.11	4.31
3/11/20 10:13	241.28	27.80	10.57	12.58	212.52	1173.37	4.30
3/11/20 10:14	241.32	27.81	10.57	12.57	212.17	1173.89	4.30
3/11/20 10:15	241.35	27.69	10.57	12.57	212.43	1173.95	4.30
3/11/20 10:16	241.32	27.68	10.57	12.57	212.38	1173.28	4.30
3/11/20 10:17	239.41	27.55	10.57	12.56	203.88	1178.37	4.30
3/11/20 10:18	239.41	27.56	10.57	12.56	164.40	1179.53	4.30
3/11/20 10:19	239.75	27.60	10.57	12.56	158.17	1178.95	4.30
3/11/20 10:20	239.59	27.56	10.57	12.55	153.44	1179.42	4.30
3/11/20 10:21	239.40	27.58	10.57	12.55	151.15	1180.07	4.30
3/11/20 10:22	240.24	27.69	10.57	12.55	151.78	1177.49	4.30
3/11/20 10:23	240.77	27.72	10.57	12.54	157.75	1175.64	4.30
3/11/20 10:24	240.60	27.78	10.57	12.54	183.54	1175.88	4.31
3/11/20 10:25	240.60	27.72	10.57	12.54	183.53	1174.86	4.31
3/11/20 10:26	240.36	27.59	10.57	12.54	181.45	1176.24	4.31
3/11/20 10:27	240.63	27.72	10.57	12.53	177.71	1176.15	4.31
3/11/20 10:28	240.43	27.73	10.57	12.53	175.53	1175.03	4.31
3/11/20 10:29	240.43	27.71	10.57	12.53	173.61	1175.72	4.31
3/11/20 10:30	240.34	27.64	10.57	12.52	173.12	1176.01	4.31
3/11/20 10:31	238.86	27.52	10.57	12.52	173.03	1180.98	4.31
3/11/20 10:32	238.86	27.58	10.57	12.52	161.44	1179.59	4.31
3/11/20 10:33	239.53	27.65	10.57	12.51	153.07	1178.91	4.31
3/11/20 10:34	239.54	27.55	10.57	12.51	148.55	1178.69	4.31
3/11/20 10:35	239.37	27.60	10.57	12.51	147.10	1177.39	4.31
3/11/20 10:36	240.20	27.60	10.57	12.50	148.50	1177.55	4.31
3/11/20 10:37	240.17	27.67	10.57	12.51	152.39	1176.72	4.31
3/11/20 10:38	240.20	27.59	10.57	12.53	161.32	1176.86	4.31
3/11/20 10:39	237.27	27.37	10.57	12.54	163.29	1178.48	4.31
3/11/20 10:40	238.23	27.42	10.57	12.55	157.48	1183.35	4.31
3/11/20 10:41	239.32	27.68	10.57	12.56	155.02	1179.98	4.31
3/11/20 10:42	239.09	27.46	10.57	12.57	150.09	1179.59	4.31
3/11/20 10:43	240.22	27.66	10.57	12.59	146.68	1177.29	4.31
3/11/20 10:44	240.12	27.69	10.57	12.62	150.70	1176.68	4.31
3/11/20 10:45	239.49	27.59	10.57	12.65	158.77	1176.47	4.31
3/11/20 10:46	240.01	27.57	10.57	12.69	160.73	1178.36	4.32
3/11/20 10:47	240.02	27.68	10.57	12.72	162.13	1177.38	4.32
3/11/20 10:48	239.92	27.59	10.57	12.76	158.10	1177.33	4.32
3/11/20 10:49	236.53	27.30	10.57	12.79	157.88	1179.73	4.32
3/11/20 10:50	240.39	27.61	10.57	12.83	153.59	1177.10	4.32

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 6:23 - 3/11 11:17)	240.66	27.71	10.57	12.65	180.46	1176.26	4.37
COUNT = 295							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 10:51	237.78	27.38	10.57	12.86	156.96	1180.68	4.32
3/11/20 10:52	238.36	27.43	10.57	12.85	154.07	1182.63	4.32
3/11/20 10:53	238.59	27.47	10.57	12.81	153.50	1179.90	4.32
3/11/20 10:54	240.70	27.69	10.57	12.78	149.60	1175.40	4.32
3/11/20 10:55	239.68	27.61	10.57	12.74	164.56	1177.74	4.32
3/11/20 10:56	239.01	27.53	10.57	12.70	156.02	1180.42	4.32
3/11/20 10:57	240.17	27.71	10.57	12.67	149.44	1176.81	4.32
3/11/20 10:58	237.80	27.40	10.57	12.63	158.75	1181.48	4.32
3/11/20 10:59	239.98	27.59	10.57	12.60	157.54	1176.88	4.32
3/11/20 11:00	240.24	27.69	10.57	12.61	159.37	1176.22	4.32
3/11/20 11:01	240.45	27.68	10.57	12.63	161.93	1176.13	4.32
3/11/20 11:02	240.38	27.70	10.57	12.64	167.49	1176.33	4.32
3/11/20 11:03	240.25	27.70	10.57	12.66	165.60	1176.75	4.32
3/11/20 11:04	240.26	27.61	10.57	12.67	167.67	1177.21	4.32
3/11/20 11:05	240.01	27.64	10.57	12.69	168.11	1175.99	4.32
3/11/20 11:06	240.22	27.67	10.57	12.70	166.38	1176.21	4.32
3/11/20 11:07	241.32	27.80	10.57	12.72	172.59	1174.21	4.32
3/11/20 11:08	241.14	27.74	10.57	12.73	213.56	1173.21	4.33
3/11/20 11:09	238.20	27.42	10.57	12.74	214.92	1179.51	4.33
3/11/20 11:10	238.11	27.43	10.57	12.74	156.92	1182.02	4.33
3/11/20 11:11	238.53	27.44	10.57	12.74	151.93	1181.51	4.33
3/11/20 11:12	238.70	27.53	10.57	12.72	149.40	1180.44	4.33
3/11/20 11:13	240.12	27.66	10.57	12.70	148.25	1177.61	4.33
3/11/20 11:14	240.03	27.54	10.57	12.68	149.41	1176.17	4.33
3/11/20 11:15	240.56	27.65	10.57	12.66	163.62	1174.98	4.33
3/11/20 11:16	240.76	27.69	10.57	12.64	187.82	1175.36	4.33
3/11/20 11:17	240.70	27.68	10.57	12.62	189.19	1173.68	4.33

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 12:30 - 3/11 17:15)	239.41	27.51	10.55	12.65	197.78	1172.84	4.43
COUNT = 286							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 12:30	235.32	27.13	10.56	12.88	170.31	1176.14	4.36
3/11/20 12:31	240.39	27.71	10.56	12.85	161.30	1174.78	4.36
3/11/20 12:32	240.18	27.71	10.56	12.83	198.58	1173.87	4.36
3/11/20 12:33	240.11	27.68	10.56	12.80	212.76	1173.19	4.36
3/11/20 12:34	240.38	27.65	10.56	12.78	213.09	1174.42	4.36
3/11/20 12:35	240.20	27.65	10.56	12.75	209.43	1173.54	4.37
3/11/20 12:36	240.26	27.71	10.56	12.73	207.90	1173.81	4.37
3/11/20 12:37	240.22	27.67	10.56	12.70	208.13	1173.10	4.37
3/11/20 12:38	240.45	27.66	10.56	12.68	208.90	1174.53	4.37
3/11/20 12:39	240.37	27.72	10.56	12.66	208.97	1174.26	4.37
3/11/20 12:40	240.33	27.65	10.56	12.63	209.23	1174.92	4.37
3/11/20 12:41	240.12	27.62	10.56	12.61	208.90	1173.64	4.37
3/11/20 12:42	240.02	27.62	10.56	12.59	208.71	1173.42	4.37
3/11/20 12:43	239.93	27.62	10.56	12.58	207.60	1173.32	4.37
3/11/20 12:44	240.23	27.66	10.56	12.58	206.77	1172.64	4.37
3/11/20 12:45	240.03	27.66	10.56	12.57	206.29	1173.54	4.37
3/11/20 12:46	240.31	27.68	10.56	12.57	206.76	1174.31	4.37
3/11/20 12:47	240.34	27.64	10.56	12.57	206.58	1173.81	4.37
3/11/20 12:48	240.18	27.61	10.56	12.56	205.71	1173.33	4.37
3/11/20 12:49	239.88	27.60	10.56	12.56	204.76	1172.75	4.37
3/11/20 12:50	240.05	27.68	10.56	12.55	204.30	1173.44	4.37
3/11/20 12:51	239.69	27.57	10.56	12.55	204.95	1173.90	4.37
3/11/20 12:52	240.06	27.67	10.56	12.55	205.52	1173.25	4.37
3/11/20 12:53	240.43	27.62	10.56	12.54	204.91	1173.84	4.37
3/11/20 12:54	239.99	27.64	10.56	12.54	203.68	1174.14	4.37
3/11/20 12:55	239.80	27.64	10.56	12.53	202.84	1173.71	4.37
3/11/20 12:56	240.00	27.64	10.56	12.53	200.96	1173.50	4.38
3/11/20 12:57	239.70	27.57	10.56	12.53	200.02	1173.49	4.38
3/11/20 12:58	240.01	27.64	10.56	12.52	201.24	1173.11	4.38
3/11/20 12:59	239.49	27.62	10.56	12.53	201.61	1173.37	4.38
3/11/20 13:00	239.71	27.61	10.56	12.54	200.21	1173.64	4.38
3/11/20 13:01	239.87	27.62	10.56	12.54	199.16	1173.48	4.38
3/11/20 13:02	239.88	27.59	10.56	12.55	198.70	1174.21	4.38
3/11/20 13:03	239.79	27.57	10.56	12.56	201.32	1172.89	4.38
3/11/20 13:04	239.79	27.62	10.56	12.56	203.28	1173.38	4.38
3/11/20 13:05	239.79	27.64	10.56	12.57	203.72	1173.35	4.38
3/11/20 13:06	239.98	27.58	10.56	12.57	203.72	1173.54	4.38
3/11/20 13:07	239.91	27.61	10.56	12.58	203.62	1173.04	4.38
3/11/20 13:08	239.83	27.60	10.56	12.59	203.46	1172.37	4.38
3/11/20 13:09	240.07	27.61	10.56	12.59	204.27	1173.65	4.38
3/11/20 13:10	239.82	27.59	10.56	12.60	204.47	1173.47	4.38
3/11/20 13:11	240.06	27.66	10.56	12.61	202.87	1173.19	4.38
3/11/20 13:12	239.69	27.60	10.56	12.61	201.89	1173.18	4.38
3/11/20 13:13	239.92	27.59	10.56	12.62	204.19	1173.96	4.38
3/11/20 13:14	239.79	27.53	10.56	12.60	203.97	1173.86	4.38
3/11/20 13:15	239.66	27.62	10.56	12.58	204.23	1173.65	4.38
3/11/20 13:16	239.68	27.65	10.56	12.56	203.74	1173.44	4.38
3/11/20 13:17	239.48	27.50	10.56	12.54	200.98	1172.70	4.38
3/11/20 13:18	239.78	27.69	10.56	12.55	202.31	1173.16	4.39
3/11/20 13:19	240.00	27.57	10.56	12.56	203.04	1173.62	4.39
3/11/20 13:20	240.08	27.66	10.56	12.58	203.42	1174.00	4.39
3/11/20 13:21	239.78	27.62	10.56	12.59	204.19	1172.58	4.39
3/11/20 13:22	239.63	27.51	10.56	12.60	204.11	1173.48	4.39
3/11/20 13:23	239.87	27.62	10.56	12.62	202.76	1173.81	4.39
3/11/20 13:24	239.59	27.57	10.56	12.63	202.53	1172.86	4.39
3/11/20 13:25	239.71	27.56	10.56	12.64	201.73	1172.88	4.39
3/11/20 13:26	239.89	27.61	10.56	12.65	202.27	1172.17	4.39
3/11/20 13:27	239.81	27.62	10.56	12.65	204.02	1173.61	4.39
3/11/20 13:28	240.11	27.55	10.56	12.65	203.60	1172.74	4.39
3/11/20 13:29	239.71	27.58	10.56	12.65	204.43	1172.74	4.39
3/11/20 13:30	239.51	27.48	10.56	12.65	204.45	1172.76	4.39
3/11/20 13:31	239.74	27.59	10.56	12.65	202.28	1173.48	4.39
3/11/20 13:32	239.77	27.73	10.56	12.65	200.87	1172.90	4.39
3/11/20 13:33	239.69	27.67	10.56	12.65	201.60	1172.93	4.39
3/11/20 13:34	240.14	27.67	10.55	12.65	202.49	1173.24	4.39
3/11/20 13:35	239.68	27.58	10.55	12.66	203.39	1173.10	4.39
3/11/20 13:36	239.70	27.50	10.55	12.66	203.74	1172.62	4.39

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 12:30 - 3/11 17:15)	239.41	27.51	10.55	12.65	197.78	1172.84	4.43
COUNT = 286							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 13:37	239.85	27.60	10.55	12.66	201.91	1172.90	4.39
3/11/20 13:38	239.96	27.60	10.55	12.66	201.08	1173.52	4.39
3/11/20 13:39	240.23	27.56	10.55	12.66	201.51	1173.16	4.39
3/11/20 13:40	239.44	27.56	10.55	12.66	202.74	1172.66	4.40
3/11/20 13:41	239.49	27.55	10.55	12.66	203.52	1172.93	4.40
3/11/20 13:42	239.84	27.56	10.55	12.66	201.05	1173.69	4.40
3/11/20 13:43	239.81	27.63	10.55	12.66	199.05	1172.55	4.40
3/11/20 13:44	239.73	27.47	10.55	12.64	200.32	1172.56	4.40
3/11/20 13:45	239.49	27.51	10.55	12.61	202.24	1172.75	4.40
3/11/20 13:46	239.47	27.59	10.55	12.57	201.21	1173.52	4.40
3/11/20 13:47	239.61	27.58	10.55	12.54	201.06	1172.92	4.40
3/11/20 13:48	239.52	27.58	10.55	12.50	200.46	1173.25	4.40
3/11/20 13:49	239.22	27.62	10.55	12.47	200.53	1172.79	4.40
3/11/20 13:50	239.77	27.55	10.55	12.51	198.78	1173.18	4.40
3/11/20 13:51	239.76	27.63	10.55	12.55	198.29	1172.90	4.40
3/11/20 13:52	239.65	27.59	10.55	12.55	198.77	1173.51	4.40
3/11/20 13:53	239.60	27.55	10.55	12.53	200.24	1172.35	4.40
3/11/20 13:54	239.58	27.58	10.55	12.52	201.77	1172.45	4.40
3/11/20 13:55	239.50	27.53	10.55	12.50	201.86	1172.56	4.40
3/11/20 13:56	239.81	27.51	10.55	12.48	201.75	1172.82	4.40
3/11/20 13:57	239.62	27.57	10.55	12.47	202.97	1173.09	4.40
3/11/20 13:58	239.49	27.56	10.55	12.47	203.75	1172.41	4.40
3/11/20 13:59	239.85	27.59	10.55	12.49	203.03	1173.39	4.40
3/11/20 14:00	239.82	27.58	10.55	12.52	201.91	1173.15	4.40
3/11/20 14:01	239.93	27.63	10.55	12.54	203.01	1172.19	4.40
3/11/20 14:02	239.81	27.57	10.55	12.60	203.56	1173.10	4.41
3/11/20 14:03	239.83	27.54	10.55	12.57	203.24	1172.73	4.41
3/11/20 14:04	239.89	27.56	10.55	12.55	204.08	1172.82	4.41
3/11/20 14:05	239.74	27.60	10.55	12.52	204.20	1173.07	4.41
3/11/20 14:06	239.78	27.55	10.55	12.49	204.27	1172.79	4.41
3/11/20 14:07	239.81	27.58	10.55	12.46	203.07	1173.36	4.41
3/11/20 14:08	239.63	27.60	10.55	12.43	202.75	1172.68	4.41
3/11/20 14:09	240.12	27.59	10.55	12.43	203.04	1173.05	4.41
3/11/20 14:10	239.35	27.52	10.55	12.46	201.60	1172.62	4.41
3/11/20 14:11	239.33	27.52	10.55	12.49	200.68	1172.43	4.41
3/11/20 14:12	239.73	27.55	10.55	12.52	201.04	1172.93	4.41
3/11/20 14:13	239.40	27.52	10.55	12.55	199.72	1172.53	4.41
3/11/20 14:14	239.59	27.54	10.55	12.59	200.22	1172.95	4.41
3/11/20 14:15	239.42	27.65	10.55	12.71	200.32	1172.82	4.41
3/11/20 14:16	239.96	27.60	10.55	12.78	200.57	1172.99	4.41
3/11/20 14:17	239.43	27.58	10.55	12.76	200.83	1172.85	4.41
3/11/20 14:18	239.63	27.46	10.55	12.74	200.14	1173.06	4.41
3/11/20 14:19	239.95	27.57	10.55	12.72	199.71	1173.06	4.41
3/11/20 14:20	239.68	27.63	10.55	12.70	199.87	1172.68	4.41
3/11/20 14:21	240.10	27.54	10.55	12.69	200.87	1173.12	4.41
3/11/20 14:22	239.76	27.57	10.55	12.67	201.74	1173.39	4.41
3/11/20 14:23	239.87	27.51	10.55	12.67	201.72	1173.01	4.42
3/11/20 14:24	239.82	27.54	10.55	12.67	202.30	1172.75	4.42
3/11/20 14:25	240.09	27.54	10.55	12.67	202.54	1173.12	4.42
3/11/20 14:26	239.72	27.56	10.55	12.67	202.78	1172.71	4.42
3/11/20 14:27	239.92	27.55	10.55	12.67	202.73	1173.50	4.42
3/11/20 14:28	239.85	27.57	10.55	12.67	200.14	1173.69	4.42
3/11/20 14:29	239.78	27.54	10.55	12.67	202.41	1173.01	4.42
3/11/20 14:30	239.74	27.56	10.55	12.67	201.96	1172.42	4.42
3/11/20 14:31	240.23	27.60	10.55	12.67	203.45	1173.51	4.42
3/11/20 14:32	239.46	27.60	10.55	12.67	204.13	1172.63	4.42
3/11/20 14:33	239.83	27.54	10.55	12.67	204.28	1172.36	4.42
3/11/20 14:34	239.37	27.55	10.55	12.67	203.38	1173.33	4.42
3/11/20 14:35	239.57	27.58	10.55	12.66	202.49	1172.31	4.42
3/11/20 14:36	239.74	27.52	10.55	12.65	200.97	1172.65	4.42
3/11/20 14:37	239.81	27.55	10.55	12.63	198.31	1173.11	4.42
3/11/20 14:38	239.31	27.43	10.55	12.62	199.22	1172.89	4.42
3/11/20 14:39	239.71	27.51	10.55	12.60	199.91	1173.79	4.42
3/11/20 14:40	239.17	27.52	10.55	12.59	199.08	1172.28	4.42
3/11/20 14:41	239.68	27.51	10.55	12.58	197.26	1173.24	4.42
3/11/20 14:42	239.62	27.55	10.55	12.56	199.04	1173.04	4.42
3/11/20 14:43	239.49	27.55	10.55	12.55	199.05	1172.93	4.42

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 12:30 - 3/11 17:15)		239.41	27.51	10.55	12.65	197.78	1172.84	4.43
COUNT = 286								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/11/20 14:44	239.46	27.49	10.55	12.53	198.69	1173.08	4.42
	3/11/20 14:45	239.45	27.53	10.55	12.52	196.99	1172.73	4.43
	3/11/20 14:46	239.38	27.57	10.55	12.51	198.35	1171.85	4.43
	3/11/20 14:47	239.69	27.55	10.55	12.49	196.83	1172.70	4.43
	3/11/20 14:48	239.86	27.56	10.55	12.48	198.36	1172.57	4.43
	3/11/20 14:49	239.83	27.47	10.55	12.46	200.12	1173.43	4.43
	3/11/20 14:50	240.12	27.55	10.55	12.46	201.09	1172.64	4.43
	3/11/20 14:51	239.41	27.53	10.55	12.47	202.17	1172.92	4.43
	3/11/20 14:52	239.46	27.55	10.55	12.49	199.82	1172.75	4.43
	3/11/20 14:53	239.61	27.50	10.55	12.50	200.00	1172.14	4.43
	3/11/20 14:54	239.23	27.47	10.55	12.52	197.15	1172.05	4.43
	3/11/20 14:55	239.65	27.60	10.55	12.53	197.69	1172.45	4.43
	3/11/20 14:56	239.40	27.53	10.55	12.55	195.36	1171.55	4.43
	3/11/20 14:57	239.80	27.63	10.55	12.56	197.32	1171.83	4.43
	3/11/20 14:58	239.69	27.60	10.55	12.57	199.38	1171.44	4.43
	3/11/20 14:59	239.35	27.45	10.55	12.58	199.40	1172.08	4.43
	3/11/20 15:00	239.75	27.53	10.55	12.59	200.18	1173.46	4.43
	3/11/20 15:01	239.45	27.51	10.55	12.60	198.33	1172.56	4.43
	3/11/20 15:02	239.47	27.50	10.55	12.61	196.60	1172.19	4.43
	3/11/20 15:03	239.48	27.50	10.55	12.61	197.34	1172.73	4.43
	3/11/20 15:04	239.81	27.56	10.55	12.62	197.36	1172.48	4.43
	3/11/20 15:05	239.38	27.50	10.55	12.63	197.75	1172.16	4.43
	3/11/20 15:06	239.55	27.47	10.55	12.64	198.91	1172.29	4.43
	3/11/20 15:07	239.61	27.45	10.55	12.65	199.04	1172.78	4.44
	3/11/20 15:08	239.65	27.48	10.55	12.66	197.36	1172.32	4.44
	3/11/20 15:09	239.54	27.53	10.55	12.67	199.59	1172.40	4.44
	3/11/20 15:10	239.56	27.56	10.55	12.68	199.58	1171.72	4.44
	3/11/20 15:11	239.14	27.48	10.55	12.69	197.09	1171.87	4.44
	3/11/20 15:12	239.68	27.49	10.55	12.70	196.89	1172.53	4.44
	3/11/20 15:13	239.36	27.48	10.55	12.71	199.25	1172.28	4.44
	3/11/20 15:14	239.63	27.42	10.55	12.72	201.00	1172.50	4.44
	3/11/20 15:15	239.43	27.45	10.55	12.73	197.36	1172.78	4.44
	3/11/20 15:16	239.57	27.52	10.55	12.74	196.84	1172.18	4.44
	3/11/20 15:17	239.45	27.50	10.55	12.75	197.43	1172.71	4.44
	3/11/20 15:18	239.28	27.47	10.55	12.76	195.26	1172.18	4.44
	3/11/20 15:19	239.80	27.53	10.55	12.77	195.42	1172.85	4.44
	3/11/20 15:20	239.39	27.55	10.55	12.78	195.76	1172.22	4.44
	3/11/20 15:21	239.34	27.51	10.55	12.79	196.78	1172.87	4.44
	3/11/20 15:22	239.32	27.41	10.55	12.79	196.55	1172.32	4.44
	3/11/20 15:23	239.79	27.58	10.55	12.77	195.89	1172.55	4.44
	3/11/20 15:24	239.61	27.47	10.55	12.76	197.43	1172.83	4.44
	3/11/20 15:25	239.44	27.46	10.55	12.75	199.17	1172.18	4.44
	3/11/20 15:26	239.04	27.50	10.55	12.73	197.19	1172.83	4.44
	3/11/20 15:27	239.19	27.38	10.55	12.72	195.69	1172.64	4.44
	3/11/20 15:28	238.94	27.44	10.55	12.71	195.10	1172.31	4.44
	3/11/20 15:29	239.18	27.41	10.55	12.69	194.46	1173.12	4.45
	3/11/20 15:30	239.54	27.45	10.55	12.68	194.80	1173.21	4.45
	3/11/20 15:31	238.95	27.46	10.55	12.66	194.65	1172.30	4.45
	3/11/20 15:32	239.18	27.43	10.55	12.65	195.85	1171.81	4.45
	3/11/20 15:33	239.33	27.41	10.55	12.64	195.04	1172.17	4.45
	3/11/20 15:34	239.45	27.49	10.55	12.62	195.85	1172.45	4.45
	3/11/20 15:35	239.79	27.51	10.55	12.61	198.22	1172.39	4.45
	3/11/20 15:36	239.48	27.47	10.55	12.60	199.35	1172.77	4.45
	3/11/20 15:37	239.26	27.46	10.55	12.58	198.65	1172.41	4.45
	3/11/20 15:38	239.34	27.54	10.55	12.59	199.40	1172.09	4.45
	3/11/20 15:39	239.25	27.50	10.55	12.63	196.34	1172.89	4.45
	3/11/20 15:40	239.29	27.47	10.54	12.66	196.39	1172.18	4.45
	3/11/20 15:41	238.94	27.35	10.54	12.69	197.91	1172.28	4.45
	3/11/20 15:42	238.87	27.41	10.54	12.72	195.43	1172.34	4.45
	3/11/20 15:43	239.12	27.40	10.54	12.75	193.05	1172.68	4.45
	3/11/20 15:44	238.83	27.46	10.54	12.78	191.71	1172.41	4.45
	3/11/20 15:45	239.14	27.41	10.54	12.75	191.58	1172.72	4.45
	3/11/20 15:46	238.87	27.49	10.54	12.73	192.61	1172.80	4.45
	3/11/20 15:47	238.93	27.35	10.54	12.71	192.87	1172.48	4.45
	3/11/20 15:48	239.30	27.49	10.54	12.68	191.98	1172.68	4.45
	3/11/20 15:49	239.14	27.45	10.54	12.66	191.93	1172.11	4.45
	3/11/20 15:50	239.12	27.36	10.54	12.64	193.76	1172.44	4.46

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 12:30 - 3/11 17:15)	239.41	27.51	10.55	12.65	197.78	1172.84	4.43
COUNT = 286							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 15:51	239.03	27.41	10.54	12.61	196.31	1172.29	4.46
3/11/20 15:52	238.90	27.33	10.54	12.60	195.17	1172.62	4.46
3/11/20 15:53	239.18	27.53	10.54	12.61	194.69	1172.92	4.46
3/11/20 15:54	239.10	27.46	10.54	12.61	193.45	1171.77	4.46
3/11/20 15:55	239.08	27.39	10.54	12.62	195.10	1173.04	4.46
3/11/20 15:56	239.00	27.48	10.54	12.62	194.45	1172.14	4.46
3/11/20 15:57	239.05	27.37	10.54	12.63	194.14	1172.82	4.46
3/11/20 15:58	239.05	27.42	10.54	12.63	192.01	1172.18	4.46
3/11/20 15:59	238.94	27.50	10.55	12.64	191.36	1172.33	4.46
3/11/20 16:00	238.45	27.37	10.55	12.65	193.68	1171.73	4.46
3/11/20 16:01	238.59	27.44	10.55	12.66	194.25	1172.91	4.46
3/11/20 16:02	238.84	27.39	10.55	12.67	191.52	1172.98	4.46
3/11/20 16:03	238.97	27.40	10.55	12.68	187.14	1172.63	4.46
3/11/20 16:04	238.86	27.47	10.55	12.70	190.29	1172.26	4.46
3/11/20 16:05	238.87	27.38	10.55	12.71	193.44	1172.73	4.46
3/11/20 16:06	239.29	27.43	10.55	12.72	194.00	1172.49	4.46
3/11/20 16:07	238.99	27.47	10.55	12.73	192.43	1172.39	4.46
3/11/20 16:08	238.87	27.42	10.55	12.74	194.13	1172.58	4.46
3/11/20 16:09	239.18	27.48	10.55	12.75	193.14	1172.46	4.46
3/11/20 16:10	238.85	27.40	10.55	12.76	192.53	1171.55	4.46
3/11/20 16:11	239.17	27.43	10.55	12.77	192.55	1172.69	4.46
3/11/20 16:12	239.11	27.52	10.55	12.78	194.55	1172.12	4.47
3/11/20 16:13	239.03	27.36	10.55	12.79	195.53	1172.11	4.47
3/11/20 16:14	238.86	27.39	10.55	12.80	195.04	1172.32	4.47
3/11/20 16:15	238.60	27.46	10.55	12.81	192.34	1172.05	4.47
3/11/20 16:16	238.95	27.43	10.55	12.82	192.12	1172.72	4.47
3/11/20 16:17	238.69	27.43	10.55	12.83	189.09	1172.31	4.47
3/11/20 16:18	238.80	27.46	10.55	12.84	190.13	1172.72	4.47
3/11/20 16:19	239.03	27.36	10.55	12.85	189.55	1172.35	4.47
3/11/20 16:20	238.92	27.46	10.55	12.86	191.93	1172.66	4.47
3/11/20 16:21	238.86	27.36	10.55	12.86	189.88	1172.49	4.47
3/11/20 16:22	238.84	27.36	10.55	12.86	192.50	1173.38	4.47
3/11/20 16:23	238.61	27.50	10.55	12.86	190.86	1172.15	4.47
3/11/20 16:24	238.44	27.33	10.55	12.85	189.02	1172.72	4.47
3/11/20 16:25	238.77	27.39	10.55	12.85	188.73	1172.88	4.47
3/11/20 16:26	239.09	27.45	10.55	12.85	187.18	1172.63	4.47
3/11/20 16:27	238.67	27.40	10.55	12.85	187.89	1171.82	4.47
3/11/20 16:28	238.90	27.52	10.55	12.84	189.90	1171.78	4.47
3/11/20 16:29	239.12	27.44	10.55	12.84	192.65	1174.28	4.47
3/11/20 16:30	238.89	27.51	10.55	12.84	193.66	1175.26	4.47
3/11/20 16:31	238.83	27.52	10.55	12.84	193.79	1175.29	4.47
3/11/20 16:32	239.18	27.42	10.55	12.83	191.15	1176.22	4.47
3/11/20 16:33	238.86	27.51	10.55	12.82	189.22	1175.41	4.47
3/11/20 16:34	239.06	27.48	10.55	12.80	187.53	1174.70	4.48
3/11/20 16:35	239.41	27.57	10.55	12.78	187.10	1175.44	4.48
3/11/20 16:36	239.08	27.53	10.55	12.76	189.14	1174.36	4.48
3/11/20 16:37	239.10	27.41	10.55	12.74	189.39	1174.25	4.48
3/11/20 16:38	238.93	27.48	10.55	12.72	190.20	1174.59	4.48
3/11/20 16:39	239.33	27.43	10.55	12.69	188.15	1174.32	4.48
3/11/20 16:40	238.83	27.46	10.55	12.67	189.46	1174.90	4.48
3/11/20 16:41	238.85	27.44	10.55	12.66	190.12	1175.03	4.48
3/11/20 16:42	238.98	27.45	10.55	12.66	191.67	1173.31	4.48
3/11/20 16:43	238.65	27.43	10.55	12.65	190.67	1171.47	4.48
3/11/20 16:44	238.51	27.39	10.55	12.64	189.53	1171.89	4.48
3/11/20 16:45	238.73	27.39	10.55	12.63	189.98	1171.75	4.48
3/11/20 16:46	238.70	27.44	10.55	12.63	190.92	1172.22	4.48
3/11/20 16:47	238.36	27.34	10.55	12.62	193.21	1171.71	4.48
3/11/20 16:48	238.78	27.50	10.55	12.61	192.17	1171.92	4.48
3/11/20 16:49	238.69	27.33	10.55	12.61	192.10	1171.70	4.48
3/11/20 16:50	238.49	27.37	10.55	12.60	190.70	1171.41	4.48
3/11/20 16:51	238.57	27.41	10.55	12.66	191.52	1171.77	4.48
3/11/20 16:52	238.71	27.35	10.55	12.71	191.44	1171.77	4.48
3/11/20 16:53	238.57	27.34	10.55	12.77	191.59	1171.04	4.48
3/11/20 16:54	238.59	27.27	10.55	12.77	188.97	1171.66	4.48
3/11/20 16:55	238.68	27.35	10.55	12.76	190.20	1170.98	4.48
3/11/20 16:56	238.48	27.36	10.55	12.75	188.07	1171.50	4.49
3/11/20 16:57	238.59	27.39	10.55	12.74	190.48	1172.61	4.49

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 12:30 - 3/11 17:15)	239.41	27.51	10.55	12.65	197.78	1172.84	4.43
COUNT = 286							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 16:58	238.92	27.38	10.55	12.73	188.87	1172.22	4.49
3/11/20 16:59	238.70	27.36	10.55	12.72	188.31	1171.91	4.49
3/11/20 17:00	238.77	27.42	10.55	12.70	189.88	1171.95	4.49
3/11/20 17:01	238.89	27.44	10.55	12.72	191.55	1172.02	4.49
3/11/20 17:02	239.17	27.40	10.55	12.74	192.61	1172.38	4.49
3/11/20 17:03	238.68	27.42	10.55	12.77	192.19	1171.99	4.49
3/11/20 17:04	238.66	27.40	10.55	12.79	192.95	1171.89	4.49
3/11/20 17:05	238.71	27.36	10.55	12.76	192.08	1171.50	4.49
3/11/20 17:06	238.67	27.35	10.55	12.72	192.78	1171.93	4.49
3/11/20 17:07	238.53	27.30	10.55	12.69	191.30	1171.37	4.49
3/11/20 17:08	238.66	27.37	10.55	12.69	191.24	1171.94	4.49
3/11/20 17:09	238.53	27.45	10.55	12.69	192.63	1171.66	4.49
3/11/20 17:10	238.62	27.43	10.55	12.68	192.15	1171.68	4.49
3/11/20 17:11	238.68	27.48	10.55	12.68	191.51	1171.83	4.49
3/11/20 17:12	238.56	27.35	10.55	12.68	190.27	1171.60	4.49
3/11/20 17:13	238.75	27.47	10.55	12.67	189.85	1171.32	4.49
3/11/20 17:14	238.69	27.33	10.55	12.67	189.26	1171.62	4.49
3/11/20 17:15	238.58	27.35	10.55	12.67	189.55	1171.31	4.49

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
SAM

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 5:46 - 3/11 7:46)		240.79	27.73	10.57	12.63	189.62	1174.75	4.45
COUNT = 121								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/11/20 5:46	239.79	27.58	10.57	12.57	165.33	1176.46	4.49
	3/11/20 5:47	239.32	27.47	10.57	12.57	163.78	1176.49	4.49
	3/11/20 5:48	240.09	27.69	10.57	12.58	161.72	1174.94	4.49
	3/11/20 5:49	241.58	27.82	10.57	12.59	157.04	1171.31	4.49
	3/11/20 5:50	238.69	27.45	10.57	12.60	209.83	1176.69	4.49
	3/11/20 5:51	237.33	27.31	10.57	12.61	188.81	1180.10	4.49
	3/11/20 5:52	236.14	27.26	10.57	12.62	186.93	1178.25	4.49
	3/11/20 5:53	239.29	27.57	10.57	12.62	183.44	1178.69	4.49
	3/11/20 5:54	237.75	27.36	10.57	12.63	179.79	1180.20	4.49
	3/11/20 5:55	238.96	27.48	10.57	12.64	170.38	1179.43	4.49
	3/11/20 5:56	239.81	27.64	10.57	12.65	165.27	1177.43	4.49
	3/11/20 5:57	239.54	27.68	10.57	12.66	159.82	1175.40	4.49
	3/11/20 5:58	238.47	27.43	10.57	12.67	158.50	1179.68	4.49
	3/11/20 5:59	238.18	27.44	10.57	12.68	154.82	1181.15	4.49
	3/11/20 6:00	237.17	27.37	10.57	12.70	152.59	1181.69	4.48
	3/11/20 6:01	240.08	27.66	10.57	12.71	148.17	1177.05	4.48
	3/11/20 6:02	237.00	27.42	10.57	12.72	148.34	1181.86	4.48
	3/11/20 6:03	238.13	27.49	10.57	12.72	148.04	1179.65	4.48
	3/11/20 6:04	239.80	27.61	10.57	12.72	146.51	1177.24	4.48
	3/11/20 6:05	240.77	27.77	10.57	12.73	148.81	1174.35	4.48
	3/11/20 6:06	237.81	27.36	10.57	12.73	158.05	1181.97	4.48
	3/11/20 6:07	238.16	27.43	10.57	12.73	160.41	1181.25	4.48
	3/11/20 6:08	240.10	27.61	10.57	12.74	158.75	1176.36	4.48
	3/11/20 6:09	241.93	27.74	10.57	12.74	153.52	1173.78	4.48
	3/11/20 6:10	241.75	27.80	10.57	12.74	197.09	1172.23	4.48
	3/11/20 6:11	241.96	27.78	10.57	12.75	210.50	1171.72	4.48
	3/11/20 6:12	241.94	27.86	10.57	12.75	197.60	1172.49	4.48
	3/11/20 6:13	241.65	27.85	10.57	12.75	197.50	1171.45	4.48
	3/11/20 6:14	242.00	27.85	10.57	12.76	201.72	1171.61	4.47
	3/11/20 6:15	242.04	27.83	10.57	12.76	204.27	1172.10	4.47
	3/11/20 6:16	241.56	27.91	10.57	12.76	206.65	1172.05	4.47
	3/11/20 6:17	241.98	27.79	10.57	12.77	206.48	1172.88	4.47
	3/11/20 6:18	239.53	27.69	10.57	12.77	207.30	1174.23	4.47
	3/11/20 6:19	240.19	27.56	10.57	12.74	166.79	1177.79	4.47
	3/11/20 6:20	241.08	27.77	10.57	12.71	158.05	1174.48	4.47
	3/11/20 6:21	240.97	27.73	10.57	12.68	160.68	1174.90	4.47
	3/11/20 6:22	242.25	27.83	10.57	12.65	174.67	1171.89	4.47
	3/11/20 6:23	241.92	27.81	10.57	12.62	215.51	1172.17	4.47
	3/11/20 6:24	242.26	27.83	10.57	12.59	217.02	1172.23	4.47
	3/11/20 6:25	242.11	27.90	10.57	12.56	212.61	1172.22	4.47
	3/11/20 6:26	241.99	27.83	10.57	12.54	208.34	1171.97	4.47
	3/11/20 6:27	242.18	27.83	10.57	12.51	206.86	1172.03	4.47
	3/11/20 6:28	242.33	27.84	10.57	12.49	207.27	1172.77	4.46
	3/11/20 6:29	242.35	27.89	10.57	12.50	209.88	1171.83	4.46
	3/11/20 6:30	242.17	27.86	10.57	12.50	211.73	1172.31	4.46
	3/11/20 6:31	242.32	27.83	10.57	12.51	211.25	1172.13	4.46
	3/11/20 6:32	241.91	27.87	10.57	12.52	211.75	1171.71	4.46
	3/11/20 6:33	241.96	27.79	10.57	12.52	212.97	1171.98	4.46
	3/11/20 6:34	241.94	27.96	10.57	12.53	213.22	1171.78	4.46
	3/11/20 6:35	242.33	27.88	10.57	12.53	213.79	1171.59	4.46
	3/11/20 6:36	242.15	27.81	10.57	12.54	213.91	1171.44	4.46
	3/11/20 6:37	242.12	27.80	10.57	12.54	213.95	1171.79	4.46
	3/11/20 6:38	241.99	27.90	10.57	12.55	214.03	1171.77	4.46
	3/11/20 6:39	242.43	27.89	10.57	12.55	214.94	1172.52	4.46
	3/11/20 6:40	241.98	27.88	10.57	12.51	216.84	1171.78	4.46
	3/11/20 6:41	241.97	27.95	10.57	12.48	218.89	1171.99	4.46
	3/11/20 6:42	242.56	27.80	10.57	12.45	218.63	1172.47	4.45
	3/11/20 6:43	242.27	27.91	10.57	12.42	217.07	1172.16	4.45
	3/11/20 6:44	242.12	27.89	10.57	12.39	215.76	1172.09	4.45
	3/11/20 6:45	242.13	27.85	10.57	12.35	215.95	1172.25	4.45
	3/11/20 6:46	242.12	27.84	10.57	12.32	217.86	1171.59	4.45
	3/11/20 6:47	242.38	27.93	10.57	12.35	218.31	1172.36	4.45
	3/11/20 6:48	242.33	27.90	10.57	12.40	216.88	1171.41	4.45
	3/11/20 6:49	242.12	27.78	10.57	12.44	215.52	1171.86	4.45
	3/11/20 6:50	242.01	27.88	10.57	12.48	217.38	1171.83	4.45
	3/11/20 6:51	238.67	27.57	10.57	12.57	217.42	1175.48	4.45
	3/11/20 6:52	239.66	27.62	10.57	12.68	178.95	1180.09	4.45

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 5:46 - 3/11 7:46)		240.79	27.73	10.57	12.63	189.62	1174.75	4.45
COUNT = 121								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/11/20 6:53	240.18	27.71	10.57	12.67	174.46	1176.81	4.45
	3/11/20 6:54	242.04	27.80	10.57	12.66	166.58	1173.63	4.45
	3/11/20 6:55	239.58	27.67	10.57	12.66	197.44	1174.32	4.45
	3/11/20 6:56	240.66	27.64	10.57	12.65	166.61	1178.27	4.44
	3/11/20 6:57	241.80	27.88	10.58	12.65	168.67	1173.64	4.44
	3/11/20 6:58	241.28	27.80	10.58	12.64	210.52	1174.60	4.44
	3/11/20 6:59	241.15	27.83	10.58	12.64	186.52	1174.39	4.44
	3/11/20 7:00	241.25	27.73	10.58	12.63	187.74	1175.37	4.44
	3/11/20 7:01	242.34	27.91	10.58	12.63	188.49	1171.89	4.44
	3/11/20 7:02	242.36	27.95	10.58	12.62	188.32	1172.20	4.44
	3/11/20 7:03	242.19	27.95	10.58	12.62	188.72	1171.35	4.44
	3/11/20 7:04	241.97	27.89	10.58	12.61	188.70	1172.01	4.44
	3/11/20 7:05	242.37	27.91	10.58	12.61	188.57	1172.58	4.44
	3/11/20 7:06	241.73	27.92	10.58	12.60	188.20	1170.79	4.44
	3/11/20 7:07	241.93	27.96	10.58	12.60	188.65	1171.36	4.44
	3/11/20 7:08	242.23	27.91	10.58	12.59	188.40	1170.93	4.44
	3/11/20 7:09	242.32	27.86	10.58	12.59	188.59	1171.59	4.44
	3/11/20 7:10	241.75	27.85	10.58	12.58	188.11	1171.27	4.43
	3/11/20 7:11	242.00	27.88	10.58	12.57	187.41	1170.80	4.43
	3/11/20 7:12	241.89	27.94	10.58	12.57	187.93	1171.33	4.43
	3/11/20 7:13	242.22	27.90	10.58	12.56	187.59	1171.46	4.43
	3/11/20 7:14	241.98	27.84	10.58	12.58	187.60	1171.45	4.43
	3/11/20 7:15	241.85	27.88	10.58	12.63	187.46	1171.05	4.43
	3/11/20 7:16	242.20	27.88	10.58	12.68	187.59	1171.55	4.43
	3/11/20 7:17	241.84	27.88	10.58	12.72	188.21	1171.37	4.43
	3/11/20 7:18	236.96	27.33	10.58	12.77	188.46	1180.71	4.43
	3/11/20 7:19	239.16	27.54	10.58	12.77	188.19	1179.16	4.43
	3/11/20 7:20	239.53	27.63	10.58	12.76	188.56	1177.31	4.43
	3/11/20 7:21	239.58	27.63	10.58	12.76	188.59	1177.58	4.43
	3/11/20 7:22	239.71	27.57	10.58	12.75	187.95	1176.94	4.43
	3/11/20 7:23	239.88	27.74	10.58	12.74	188.01	1175.89	4.43
	3/11/20 7:24	240.41	27.71	10.58	12.74	187.75	1175.10	4.42
	3/11/20 7:25	240.17	27.67	10.58	12.73	188.07	1175.81	4.42
	3/11/20 7:26	240.09	27.68	10.58	12.73	188.12	1175.98	4.42
	3/11/20 7:27	238.06	27.45	10.58	12.72	187.86	1181.10	4.42
	3/11/20 7:28	238.83	27.52	10.58	12.70	187.99	1179.35	4.42
	3/11/20 7:29	238.93	27.57	10.58	12.69	187.37	1179.13	4.42
	3/11/20 7:30	239.63	27.54	10.58	12.67	187.75	1178.31	4.42
	3/11/20 7:31	238.89	27.53	10.58	12.65	188.15	1178.81	4.42
	3/11/20 7:32	240.20	27.69	10.58	12.64	188.05	1176.89	4.42
	3/11/20 7:33	240.26	27.77	10.58	12.62	188.37	1176.26	4.42
	3/11/20 7:34	239.68	27.62	10.58	12.60	188.23	1176.61	4.42
	3/11/20 7:35	240.31	27.65	10.58	12.59	188.13	1177.56	4.42
	3/11/20 7:36	240.46	27.72	10.58	12.57	188.16	1175.84	4.42
	3/11/20 7:37	238.88	27.51	10.58	12.55	187.88	1181.96	4.42
	3/11/20 7:38	240.33	27.71	10.58	12.54	187.86	1177.72	4.41
	3/11/20 7:39	240.69	27.65	10.58	12.52	187.79	1177.56	4.41
	3/11/20 7:40	241.91	27.87	10.58	12.56	184.34	1171.95	4.41
	3/11/20 7:41	241.13	27.81	10.58	12.63	219.04	1175.62	4.41
	3/11/20 7:42	240.96	27.72	10.58	12.70	199.34	1175.35	4.41
	3/11/20 7:43	241.17	27.68	10.58	12.77	185.80	1175.24	4.41
	3/11/20 7:44	241.05	27.76	10.58	12.78	185.97	1175.91	4.41
	3/11/20 7:45	241.28	27.75	10.58	12.76	183.09	1174.87	4.41
	3/11/20 7:46	240.97	27.78	10.58	12.74	179.09	1175.15	4.41

Description		CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 8:40 - 3/11 10:40)		240.88	27.72	10.57	12.64	187.45	1176.22	4.33
COUNT = 121								
Signal Tagname		G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
	3/11/20 8:40	240.35	27.68	10.58	12.78	146.71	1178.18	4.37
	3/11/20 8:41	240.59	27.67	10.58	12.76	146.36	1177.87	4.37
	3/11/20 8:42	240.40	27.65	10.58	12.74	146.15	1178.25	4.37
	3/11/20 8:43	238.82	27.46	10.58	12.72	146.76	1180.29	4.37
	3/11/20 8:44	238.83	27.54	10.58	12.70	144.07	1182.54	4.37
	3/11/20 8:45	238.94	27.54	10.58	12.68	145.36	1180.68	4.37
	3/11/20 8:46	240.27	27.62	10.58	12.66	142.60	1179.37	4.37
	3/11/20 8:47	240.02	27.62	10.58	12.61	140.94	1178.45	4.37
	3/11/20 8:48	240.09	27.59	10.58	12.52	140.36	1177.73	4.37
	3/11/20 8:49	240.26	27.63	10.58	12.47	143.07	1178.01	4.36
	3/11/20 8:50	238.97	27.54	10.58	12.52	146.79	1181.25	4.36
	3/11/20 8:51	239.21	27.52	10.58	12.56	148.81	1179.95	4.36
	3/11/20 8:52	238.91	27.34	10.58	12.61	144.67	1183.73	4.36
	3/11/20 8:53	240.89	27.67	10.58	12.65	142.16	1176.99	4.36
	3/11/20 8:54	242.21	27.77	10.58	12.64	147.84	1173.13	4.36
	3/11/20 8:55	242.07	27.89	10.58	12.64	199.62	1172.79	4.36
	3/11/20 8:56	242.44	27.92	10.58	12.63	210.15	1173.53	4.36
	3/11/20 8:57	242.23	27.90	10.58	12.63	194.04	1173.61	4.36
	3/11/20 8:58	242.03	27.91	10.58	12.62	205.98	1173.70	4.36
	3/11/20 8:59	242.03	27.81	10.58	12.62	212.41	1173.18	4.36
	3/11/20 9:00	242.29	27.78	10.58	12.61	215.84	1173.97	4.36
	3/11/20 9:01	242.35	27.88	10.58	12.61	222.35	1173.69	4.36
	3/11/20 9:02	241.86	27.84	10.58	12.61	220.66	1173.80	4.36
	3/11/20 9:03	242.26	27.87	10.58	12.63	221.21	1173.27	4.35
	3/11/20 9:04	241.94	27.90	10.58	12.65	220.29	1173.44	4.35
	3/11/20 9:05	242.04	27.84	10.58	12.67	218.11	1174.03	4.35
	3/11/20 9:06	242.23	27.80	10.58	12.69	218.65	1173.63	4.35
	3/11/20 9:07	242.22	27.82	10.58	12.71	216.96	1173.66	4.35
	3/11/20 9:08	241.83	27.93	10.58	12.73	218.49	1173.16	4.35
	3/11/20 9:09	237.79	27.30	10.58	12.74	220.15	1183.64	4.35
	3/11/20 9:10	239.67	27.55	10.58	12.75	178.61	1180.21	4.35
	3/11/20 9:11	239.74	27.63	10.58	12.76	171.04	1179.51	4.35
	3/11/20 9:12	239.52	27.60	10.58	12.77	164.77	1179.78	4.35
	3/11/20 9:13	240.84	27.66	10.58	12.78	157.84	1177.81	4.35
	3/11/20 9:14	240.98	27.75	10.58	12.78	159.13	1175.50	4.35
	3/11/20 9:15	241.23	27.74	10.58	12.79	166.66	1176.51	4.35
	3/11/20 9:16	237.45	27.38	10.58	12.80	172.57	1181.51	4.35
	3/11/20 9:17	241.00	27.71	10.58	12.79	170.68	1177.42	4.34
	3/11/20 9:18	241.11	27.73	10.58	12.78	166.66	1175.83	4.34
	3/11/20 9:19	241.93	27.79	10.58	12.77	172.30	1173.99	4.34
	3/11/20 9:20	242.04	27.85	10.58	12.75	208.65	1173.88	4.34
	3/11/20 9:21	241.89	27.88	10.57	12.74	213.08	1174.02	4.34
	3/11/20 9:22	241.86	27.92	10.57	12.73	214.09	1174.23	4.34
	3/11/20 9:23	241.91	27.85	10.57	12.72	210.73	1173.90	4.34
	3/11/20 9:24	241.78	27.82	10.57	12.71	209.48	1175.18	4.34
	3/11/20 9:25	242.16	27.83	10.57	12.70	208.12	1175.24	4.34
	3/11/20 9:26	241.88	27.74	10.57	12.68	205.52	1174.89	4.34
	3/11/20 9:27	242.26	27.86	10.57	12.67	205.10	1174.78	4.34
	3/11/20 9:28	241.75	27.88	10.57	12.66	210.81	1174.21	4.34
	3/11/20 9:29	242.06	27.85	10.57	12.65	212.56	1174.01	4.34
	3/11/20 9:30	241.92	27.91	10.57	12.64	213.91	1173.96	4.34
	3/11/20 9:31	242.04	27.77	10.57	12.63	214.13	1173.31	4.33
	3/11/20 9:32	242.06	27.83	10.57	12.62	214.53	1174.11	4.33
	3/11/20 9:33	242.09	27.88	10.57	12.60	214.61	1174.17	4.33
	3/11/20 9:34	242.14	27.90	10.57	12.59	214.21	1174.80	4.33
	3/11/20 9:35	241.98	27.83	10.57	12.57	213.38	1174.41	4.33
	3/11/20 9:36	242.11	27.81	10.57	12.55	213.76	1173.99	4.33
	3/11/20 9:37	241.93	27.81	10.57	12.53	213.81	1173.75	4.33
	3/11/20 9:38	242.17	27.78	10.57	12.51	214.77	1174.78	4.33
	3/11/20 9:39	241.99	27.87	10.57	12.49	213.50	1174.08	4.33
	3/11/20 9:40	242.27	27.82	10.57	12.51	213.90	1174.64	4.33
	3/11/20 9:41	242.00	27.83	10.57	12.57	213.44	1173.70	4.33
	3/11/20 9:42	241.86	27.83	10.57	12.62	213.81	1173.89	4.33
	3/11/20 9:43	241.96	27.84	10.57	12.68	214.11	1173.88	4.33
	3/11/20 9:44	241.74	27.75	10.57	12.74	214.00	1174.51	4.33
	3/11/20 9:45	241.65	27.85	10.57	12.79	213.83	1174.02	4.32
	3/11/20 9:46	238.87	27.58	10.57	12.85	212.53	1179.78	4.32

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 8:40 - 3/11 10:40)	240.88	27.72	10.57	12.64	187.45	1176.22	4.33
COUNT = 121							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 9:47	238.30	27.57	10.57	12.82	166.37	1183.73	4.32
3/11/20 9:48	238.16	27.52	10.57	12.79	165.42	1183.37	4.32
3/11/20 9:49	241.17	27.82	10.57	12.77	160.42	1177.20	4.32
3/11/20 9:50	240.90	27.68	10.57	12.74	170.20	1176.77	4.32
3/11/20 9:51	240.55	27.65	10.57	12.72	181.94	1177.46	4.32
3/11/20 9:52	240.46	27.75	10.57	12.72	176.99	1176.95	4.32
3/11/20 9:53	241.52	27.84	10.57	12.71	171.72	1174.49	4.32
3/11/20 9:54	240.44	27.61	10.57	12.71	201.42	1178.29	4.32
3/11/20 9:55	241.74	27.84	10.57	12.71	183.85	1173.76	4.32
3/11/20 9:56	241.62	27.87	10.57	12.71	205.01	1174.20	4.32
3/11/20 9:57	241.67	27.88	10.57	12.70	208.19	1174.07	4.32
3/11/20 9:58	241.72	27.84	10.57	12.70	208.20	1174.28	4.32
3/11/20 9:59	238.49	27.49	10.57	12.69	209.14	1179.95	4.31
3/11/20 10:00	240.39	27.67	10.57	12.68	164.44	1180.24	4.31
3/11/20 10:01	241.50	27.84	10.57	12.66	175.74	1173.94	4.31
3/11/20 10:02	241.98	27.80	10.57	12.64	207.94	1173.24	4.31
3/11/20 10:03	241.80	27.75	10.57	12.63	211.59	1173.91	4.31
3/11/20 10:04	241.63	27.80	10.57	12.61	213.26	1173.45	4.31
3/11/20 10:05	241.35	27.87	10.57	12.60	211.81	1173.74	4.31
3/11/20 10:06	241.62	27.83	10.57	12.60	211.18	1174.73	4.31
3/11/20 10:07	241.69	27.85	10.57	12.60	209.53	1174.39	4.31
3/11/20 10:08	241.89	27.84	10.57	12.59	209.35	1174.41	4.31
3/11/20 10:09	241.34	27.82	10.57	12.59	212.27	1173.96	4.31
3/11/20 10:10	241.78	27.79	10.57	12.59	213.16	1174.35	4.31
3/11/20 10:11	241.33	27.79	10.57	12.58	212.55	1173.99	4.31
3/11/20 10:12	241.31	27.80	10.57	12.58	212.38	1173.11	4.31
3/11/20 10:13	241.28	27.80	10.57	12.58	212.52	1173.37	4.30
3/11/20 10:14	241.32	27.81	10.57	12.57	212.17	1173.89	4.30
3/11/20 10:15	241.35	27.69	10.57	12.57	212.43	1173.95	4.30
3/11/20 10:16	241.32	27.68	10.57	12.57	212.38	1173.28	4.30
3/11/20 10:17	239.41	27.55	10.57	12.56	203.88	1178.37	4.30
3/11/20 10:18	239.41	27.56	10.57	12.56	164.40	1179.53	4.30
3/11/20 10:19	239.75	27.60	10.57	12.56	158.17	1178.95	4.30
3/11/20 10:20	239.59	27.56	10.57	12.55	153.44	1179.42	4.30
3/11/20 10:21	239.40	27.58	10.57	12.55	151.15	1180.07	4.30
3/11/20 10:22	240.24	27.69	10.57	12.55	151.78	1177.49	4.30
3/11/20 10:23	240.77	27.72	10.57	12.54	157.75	1175.64	4.30
3/11/20 10:24	240.60	27.78	10.57	12.54	183.54	1175.88	4.31
3/11/20 10:25	240.60	27.72	10.57	12.54	183.53	1174.86	4.31
3/11/20 10:26	240.36	27.59	10.57	12.54	181.45	1176.24	4.31
3/11/20 10:27	240.63	27.72	10.57	12.53	177.71	1176.15	4.31
3/11/20 10:28	240.43	27.73	10.57	12.53	175.53	1175.03	4.31
3/11/20 10:29	240.43	27.71	10.57	12.53	173.61	1175.72	4.31
3/11/20 10:30	240.34	27.64	10.57	12.52	173.12	1176.01	4.31
3/11/20 10:31	238.86	27.52	10.57	12.52	173.03	1180.98	4.31
3/11/20 10:32	238.86	27.58	10.57	12.52	161.44	1179.59	4.31
3/11/20 10:33	239.53	27.65	10.57	12.51	153.07	1178.91	4.31
3/11/20 10:34	239.54	27.55	10.57	12.51	148.55	1178.69	4.31
3/11/20 10:35	239.37	27.60	10.57	12.51	147.10	1177.39	4.31
3/11/20 10:36	240.20	27.60	10.57	12.50	148.50	1177.55	4.31
3/11/20 10:37	240.17	27.67	10.57	12.51	152.39	1176.72	4.31
3/11/20 10:38	240.20	27.59	10.57	12.53	161.32	1176.86	4.31
3/11/20 10:39	237.27	27.37	10.57	12.54	163.29	1178.48	4.31
3/11/20 10:40	238.23	27.42	10.57	12.55	157.48	1183.35	4.31

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 11:33 - 3/11 13:33)	239.86	27.62	10.56	12.65	196.91	1174.46	4.36
COUNT = 121							

Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 11:33	240.95	27.80	10.56	12.66	205.42	1173.78	4.34
3/11/20 11:34	240.78	27.75	10.56	12.67	207.29	1174.01	4.34
3/11/20 11:35	240.80	27.72	10.56	12.67	206.69	1173.77	4.34
3/11/20 11:36	240.75	27.71	10.56	12.68	206.08	1173.15	4.34
3/11/20 11:37	240.97	27.71	10.56	12.69	206.16	1173.98	4.34
3/11/20 11:38	240.65	27.73	10.56	12.70	207.18	1173.62	4.34
3/11/20 11:39	240.70	27.71	10.56	12.71	206.98	1173.67	4.34
3/11/20 11:40	240.83	27.77	10.56	12.72	207.34	1173.96	4.34
3/11/20 11:41	240.62	27.62	10.56	12.72	206.34	1174.33	4.34
3/11/20 11:42	240.90	27.72	10.56	12.73	205.44	1174.35	4.34
3/11/20 11:43	241.26	27.81	10.56	12.74	204.29	1174.34	4.34
3/11/20 11:44	240.63	27.70	10.56	12.75	207.25	1173.42	4.34
3/11/20 11:45	240.95	27.64	10.56	12.76	208.82	1174.88	4.34
3/11/20 11:46	240.49	27.67	10.56	12.77	209.05	1174.45	4.34
3/11/20 11:47	240.60	27.73	10.56	12.77	208.01	1174.14	4.34
3/11/20 11:48	239.96	27.65	10.56	12.78	206.97	1174.54	4.34
3/11/20 11:49	237.44	27.32	10.56	12.79	196.51	1182.50	4.34
3/11/20 11:50	237.91	27.54	10.56	12.80	164.56	1179.17	4.34
3/11/20 11:51	240.11	27.71	10.56	12.81	156.40	1175.76	4.35
3/11/20 11:52	240.86	27.76	10.56	12.81	182.67	1174.61	4.35
3/11/20 11:53	240.45	27.68	10.56	12.82	196.66	1172.98	4.35
3/11/20 11:54	240.73	27.78	10.56	12.83	207.20	1174.16	4.35
3/11/20 11:55	238.51	27.43	10.56	12.84	208.77	1179.51	4.35
3/11/20 11:56	238.73	27.54	10.56	12.84	161.14	1178.85	4.35
3/11/20 11:57	236.86	27.36	10.56	12.83	153.56	1180.22	4.35
3/11/20 11:58	239.77	27.63	10.56	12.82	150.96	1176.64	4.35
3/11/20 11:59	239.65	27.59	10.56	12.81	158.77	1175.03	4.35
3/11/20 12:00	239.27	27.55	10.56	12.80	184.10	1176.56	4.35
3/11/20 12:01	240.52	27.70	10.56	12.78	175.93	1174.84	4.35
3/11/20 12:02	240.38	27.68	10.56	12.77	192.05	1172.94	4.35
3/11/20 12:03	239.87	27.66	10.56	12.76	201.15	1172.60	4.35
3/11/20 12:04	240.28	27.66	10.56	12.71	203.68	1173.45	4.35
3/11/20 12:05	240.14	27.69	10.56	12.62	205.81	1173.24	4.35
3/11/20 12:06	240.68	27.72	10.56	12.53	203.43	1173.78	4.35
3/11/20 12:07	239.20	27.58	10.56	12.51	200.89	1176.46	4.35
3/11/20 12:08	240.56	27.65	10.56	12.52	184.20	1174.30	4.35
3/11/20 12:09	240.72	27.60	10.56	12.52	198.43	1174.24	4.35
3/11/20 12:10	240.01	27.70	10.56	12.52	195.40	1174.75	4.35
3/11/20 12:11	239.54	27.64	10.56	12.52	199.63	1175.09	4.35
3/11/20 12:12	238.71	27.49	10.56	12.52	187.50	1179.01	4.35
3/11/20 12:13	239.58	27.54	10.56	12.53	156.61	1175.73	4.36
3/11/20 12:14	239.63	27.58	10.56	12.53	164.72	1175.81	4.36
3/11/20 12:15	239.88	27.57	10.56	12.53	168.27	1175.94	4.36
3/11/20 12:16	240.15	27.59	10.56	12.54	181.23	1174.37	4.36
3/11/20 12:17	239.87	27.67	10.56	12.54	204.93	1174.07	4.36
3/11/20 12:18	240.07	27.62	10.56	12.55	213.37	1175.72	4.36
3/11/20 12:19	239.70	27.64	10.56	12.57	210.99	1175.29	4.36
3/11/20 12:20	239.65	27.58	10.56	12.59	200.45	1176.03	4.36
3/11/20 12:21	236.95	27.27	10.56	12.61	192.64	1180.91	4.36
3/11/20 12:22	239.56	27.64	10.56	12.63	170.95	1176.16	4.36
3/11/20 12:23	239.08	27.59	10.56	12.65	170.98	1177.51	4.36
3/11/20 12:24	239.13	27.55	10.56	12.72	160.89	1176.47	4.36
3/11/20 12:25	239.46	27.60	10.56	12.78	164.53	1176.31	4.36
3/11/20 12:26	239.73	27.58	10.56	12.85	168.02	1177.20	4.36
3/11/20 12:27	239.44	27.53	10.56	12.92	171.92	1176.32	4.36
3/11/20 12:28	238.62	27.50	10.56	12.93	177.73	1175.71	4.36
3/11/20 12:29	237.77	27.31	10.56	12.90	172.62	1181.66	4.36
3/11/20 12:30	235.32	27.13	10.56	12.88	170.31	1176.14	4.36
3/11/20 12:31	240.39	27.71	10.56	12.85	161.30	1174.78	4.36
3/11/20 12:32	240.18	27.71	10.56	12.83	198.58	1173.87	4.36
3/11/20 12:33	240.11	27.68	10.56	12.80	212.76	1173.19	4.36
3/11/20 12:34	240.38	27.65	10.56	12.78	213.09	1174.42	4.36
3/11/20 12:35	240.20	27.65	10.56	12.75	209.43	1173.54	4.37
3/11/20 12:36	240.26	27.71	10.56	12.73	207.90	1173.81	4.37
3/11/20 12:37	240.22	27.67	10.56	12.70	208.13	1173.10	4.37
3/11/20 12:38	240.45	27.66	10.56	12.68	208.90	1174.53	4.37
3/11/20 12:39	240.37	27.72	10.56	12.66	208.97	1174.26	4.37

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/11 11:33 - 3/11 13:33)	239.86	27.62	10.56	12.65	196.91	1174.46	4.36
COUNT = 121							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/11/20 12:40	240.33	27.65	10.56	12.63	209.23	1174.92	4.37
3/11/20 12:41	240.12	27.62	10.56	12.61	208.90	1173.64	4.37
3/11/20 12:42	240.02	27.62	10.56	12.59	208.71	1173.42	4.37
3/11/20 12:43	239.93	27.62	10.56	12.58	207.60	1173.32	4.37
3/11/20 12:44	240.23	27.66	10.56	12.58	206.77	1172.64	4.37
3/11/20 12:45	240.03	27.66	10.56	12.57	206.29	1173.54	4.37
3/11/20 12:46	240.31	27.68	10.56	12.57	206.76	1174.31	4.37
3/11/20 12:47	240.34	27.64	10.56	12.57	206.58	1173.81	4.37
3/11/20 12:48	240.18	27.61	10.56	12.56	205.71	1173.33	4.37
3/11/20 12:49	239.88	27.60	10.56	12.56	204.76	1172.75	4.37
3/11/20 12:50	240.05	27.68	10.56	12.55	204.30	1173.44	4.37
3/11/20 12:51	239.69	27.57	10.56	12.55	204.95	1173.90	4.37
3/11/20 12:52	240.06	27.67	10.56	12.55	205.52	1173.25	4.37
3/11/20 12:53	240.43	27.62	10.56	12.54	204.91	1173.84	4.37
3/11/20 12:54	239.99	27.64	10.56	12.54	203.68	1174.14	4.37
3/11/20 12:55	239.80	27.64	10.56	12.53	202.84	1173.71	4.37
3/11/20 12:56	240.00	27.64	10.56	12.53	200.96	1173.50	4.38
3/11/20 12:57	239.70	27.57	10.56	12.53	200.02	1173.49	4.38
3/11/20 12:58	240.01	27.64	10.56	12.52	201.24	1173.11	4.38
3/11/20 12:59	239.49	27.62	10.56	12.53	201.61	1173.37	4.38
3/11/20 13:00	239.71	27.61	10.56	12.54	200.21	1173.64	4.38
3/11/20 13:01	239.87	27.62	10.56	12.54	199.16	1173.48	4.38
3/11/20 13:02	239.88	27.59	10.56	12.55	198.70	1174.21	4.38
3/11/20 13:03	239.79	27.57	10.56	12.56	201.32	1172.89	4.38
3/11/20 13:04	239.79	27.62	10.56	12.56	203.28	1173.38	4.38
3/11/20 13:05	239.79	27.64	10.56	12.57	203.72	1173.35	4.38
3/11/20 13:06	239.98	27.58	10.56	12.57	203.72	1173.54	4.38
3/11/20 13:07	239.91	27.61	10.56	12.58	203.62	1173.04	4.38
3/11/20 13:08	239.83	27.60	10.56	12.59	203.46	1172.37	4.38
3/11/20 13:09	240.07	27.61	10.56	12.59	204.27	1173.65	4.38
3/11/20 13:10	239.82	27.59	10.56	12.60	204.47	1173.47	4.38
3/11/20 13:11	240.06	27.66	10.56	12.61	202.87	1173.19	4.38
3/11/20 13:12	239.69	27.60	10.56	12.61	201.89	1173.18	4.38
3/11/20 13:13	239.92	27.59	10.56	12.62	204.19	1173.96	4.38
3/11/20 13:14	239.79	27.53	10.56	12.60	203.97	1173.86	4.38
3/11/20 13:15	239.66	27.62	10.56	12.58	204.23	1173.65	4.38
3/11/20 13:16	239.68	27.65	10.56	12.56	203.74	1173.44	4.38
3/11/20 13:17	239.48	27.50	10.56	12.54	200.98	1172.70	4.38
3/11/20 13:18	239.78	27.69	10.56	12.55	202.31	1173.16	4.39
3/11/20 13:19	240.00	27.57	10.56	12.56	203.04	1173.62	4.39
3/11/20 13:20	240.08	27.66	10.56	12.58	203.42	1174.00	4.39
3/11/20 13:21	239.78	27.62	10.56	12.59	204.19	1172.58	4.39
3/11/20 13:22	239.63	27.51	10.56	12.60	204.11	1173.48	4.39
3/11/20 13:23	239.87	27.62	10.56	12.62	202.76	1173.81	4.39
3/11/20 13:24	239.59	27.57	10.56	12.63	202.53	1172.86	4.39
3/11/20 13:25	239.71	27.56	10.56	12.64	201.73	1172.88	4.39
3/11/20 13:26	239.89	27.61	10.56	12.65	202.27	1172.17	4.39
3/11/20 13:27	239.81	27.62	10.56	12.65	204.02	1173.61	4.39
3/11/20 13:28	240.11	27.55	10.56	12.65	203.60	1172.74	4.39
3/11/20 13:29	239.71	27.58	10.56	12.65	204.43	1172.74	4.39
3/11/20 13:30	239.51	27.48	10.56	12.65	204.45	1172.76	4.39
3/11/20 13:31	239.74	27.59	10.56	12.65	202.28	1173.48	4.39
3/11/20 13:32	239.77	27.73	10.56	12.65	200.87	1172.90	4.39
3/11/20 13:33	239.69	27.67	10.56	12.65	201.60	1172.93	4.39

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
Opacity

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 14:30 - 3/10 15:30)	231.74	27.08	9.79	12.60	153.44	1163.25	4.54
COUNT = 61							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 14:30	231.81	27.11	9.71	12.56	155.65	1163.65	4.53
3/10/20 14:31	231.91	27.13	9.71	12.56	155.14	1163.28	4.53
3/10/20 14:32	231.97	27.05	9.72	12.55	154.69	1163.82	4.53
3/10/20 14:33	231.88	27.09	9.72	12.55	154.23	1163.76	4.53
3/10/20 14:34	231.85	27.14	9.72	12.55	154.50	1164.07	4.53
3/10/20 14:35	231.91	27.10	9.72	12.54	154.77	1163.52	4.53
3/10/20 14:36	231.97	27.03	9.73	12.54	154.94	1163.09	4.53
3/10/20 14:37	231.69	27.10	9.73	12.54	154.50	1163.58	4.53
3/10/20 14:38	231.98	27.07	9.73	12.53	153.89	1163.34	4.53
3/10/20 14:39	231.83	27.14	9.73	12.53	153.49	1163.66	4.53
3/10/20 14:40	231.50	27.06	9.74	12.53	154.79	1163.33	4.53
3/10/20 14:41	231.71	27.09	9.74	12.52	155.23	1163.16	4.53
3/10/20 14:42	231.95	27.12	9.74	12.52	155.42	1163.52	4.53
3/10/20 14:43	231.65	27.08	9.74	12.52	156.22	1163.78	4.53
3/10/20 14:44	231.77	27.14	9.75	12.51	155.64	1163.62	4.53
3/10/20 14:45	231.90	27.07	9.75	12.51	155.09	1163.72	4.53
3/10/20 14:46	231.84	27.06	9.75	12.51	154.70	1163.64	4.53
3/10/20 14:47	231.92	27.03	9.76	12.52	154.76	1163.77	4.53
3/10/20 14:48	231.97	27.08	9.76	12.53	154.50	1163.45	4.53
3/10/20 14:49	231.83	27.03	9.76	12.54	154.46	1162.65	4.53
3/10/20 14:50	232.00	27.08	9.76	12.55	153.84	1163.73	4.53
3/10/20 14:51	231.60	27.04	9.77	12.56	154.16	1163.47	4.53
3/10/20 14:52	231.66	27.13	9.77	12.56	153.27	1163.39	4.53
3/10/20 14:53	231.91	27.07	9.77	12.57	153.47	1163.42	4.54
3/10/20 14:54	231.74	27.08	9.77	12.58	153.38	1163.10	4.54
3/10/20 14:55	231.64	27.07	9.78	12.58	154.04	1163.32	4.54
3/10/20 14:56	231.52	27.06	9.78	12.58	153.48	1163.32	4.54
3/10/20 14:57	231.77	27.05	9.78	12.57	153.04	1163.56	4.54
3/10/20 14:58	231.66	27.08	9.78	12.56	152.20	1163.48	4.54
3/10/20 14:59	231.59	27.05	9.79	12.55	152.46	1163.35	4.54
3/10/20 15:00	231.73	27.14	9.79	12.54	152.44	1162.98	4.54
3/10/20 15:01	231.58	27.08	9.79	12.54	152.38	1163.98	4.54
3/10/20 15:02	231.61	27.08	9.79	12.53	153.15	1163.00	4.54
3/10/20 15:03	231.43	27.11	9.80	12.54	153.03	1162.82	4.54
3/10/20 15:04	231.68	27.08	9.80	12.55	152.38	1162.70	4.54
3/10/20 15:05	231.36	27.03	9.80	12.55	152.38	1163.02	4.54
3/10/20 15:06	231.66	27.11	9.80	12.56	152.74	1163.04	4.54
3/10/20 15:07	231.68	27.11	9.81	12.57	152.72	1163.13	4.54
3/10/20 15:08	231.81	27.05	9.81	12.58	152.72	1163.29	4.54
3/10/20 15:09	231.78	27.03	9.81	12.59	153.21	1163.46	4.54
3/10/20 15:10	231.70	27.08	9.81	12.60	152.76	1163.18	4.54
3/10/20 15:11	231.84	27.04	9.82	12.60	152.73	1163.03	4.54
3/10/20 15:12	231.48	27.11	9.82	12.61	152.92	1162.51	4.54
3/10/20 15:13	231.65	27.10	9.82	12.62	153.85	1163.12	4.54
3/10/20 15:14	231.85	27.03	9.82	12.63	153.04	1163.27	4.54
3/10/20 15:15	231.69	27.15	9.83	12.64	152.08	1162.51	4.54
3/10/20 15:16	231.68	27.06	9.83	12.65	151.68	1163.07	4.54
3/10/20 15:17	231.76	27.03	9.83	12.65	151.59	1163.44	4.54
3/10/20 15:18	231.80	27.05	9.83	12.66	152.12	1163.21	4.54
3/10/20 15:19	231.39	27.14	9.84	12.67	152.37	1162.97	4.55
3/10/20 15:20	231.76	27.04	9.84	12.69	152.52	1163.16	4.55
3/10/20 15:21	231.61	27.08	9.84	12.72	152.68	1162.77	4.55
3/10/20 15:22	231.83	27.02	9.84	12.75	152.73	1162.71	4.55
3/10/20 15:23	231.58	27.05	9.85	12.78	152.84	1162.74	4.55
3/10/20 15:24	231.89	27.05	9.85	12.80	152.76	1162.62	4.55
3/10/20 15:25	231.70	27.05	9.85	12.80	153.18	1162.65	4.55
3/10/20 15:26	232.07	27.10	9.85	12.79	152.54	1163.55	4.55
3/10/20 15:27	231.82	27.08	9.86	12.77	153.36	1162.69	4.55
3/10/20 15:28	231.72	27.10	9.86	12.76	153.13	1163.04	4.55
3/10/20 15:29	231.49	27.10	9.86	12.74	151.55	1163.36	4.55
3/10/20 15:30	231.80	27.07	9.86	12.70	150.35	1162.75	4.55

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 15:30 - 3/10 16:30)	231.84	27.09	9.94	12.63	151.51	1162.44	4.56
COUNT = 61							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 15:30	231.80	27.07	9.86	12.70	150.35	1162.75	4.55
3/10/20 15:31	231.67	27.08	9.87	12.70	149.99	1163.10	4.55
3/10/20 15:32	231.74	27.06	9.87	12.71	152.84	1162.12	4.55
3/10/20 15:33	231.79	27.05	9.87	12.72	152.46	1162.82	4.55
3/10/20 15:34	231.65	27.07	9.88	12.74	153.25	1162.62	4.55
3/10/20 15:35	231.63	27.12	9.88	12.75	153.71	1162.53	4.55
3/10/20 15:36	231.73	27.07	9.88	12.76	152.85	1162.39	4.55
3/10/20 15:37	231.82	27.14	9.88	12.77	154.04	1162.57	4.55
3/10/20 15:38	231.61	27.07	9.89	12.78	152.27	1161.98	4.55
3/10/20 15:39	231.67	27.11	9.89	12.79	152.02	1162.48	4.55
3/10/20 15:40	231.83	27.09	9.89	12.80	151.68	1162.50	4.55
3/10/20 15:41	231.67	27.00	9.89	12.81	151.53	1162.63	4.55
3/10/20 15:42	231.52	27.05	9.90	12.82	151.70	1162.49	4.55
3/10/20 15:43	231.75	27.11	9.90	12.83	151.57	1162.39	4.55
3/10/20 15:44	231.67	27.07	9.90	12.83	151.81	1162.45	4.55
3/10/20 15:45	231.72	27.08	9.90	12.83	151.95	1162.89	4.56
3/10/20 15:46	232.07	27.06	9.91	12.83	152.08	1162.81	4.56
3/10/20 15:47	231.91	27.03	9.91	12.83	151.27	1162.53	4.56
3/10/20 15:48	232.09	27.06	9.91	12.83	151.36	1162.60	4.56
3/10/20 15:49	231.76	27.11	9.91	12.75	150.75	1162.71	4.56
3/10/20 15:50	231.82	27.12	9.92	12.61	152.16	1162.74	4.56
3/10/20 15:51	231.59	27.15	9.92	12.55	151.94	1162.86	4.56
3/10/20 15:52	231.65	27.06	9.92	12.54	151.82	1162.32	4.56
3/10/20 15:53	231.88	27.15	9.92	12.54	151.45	1162.04	4.56
3/10/20 15:54	231.67	27.02	9.93	12.54	151.33	1162.77	4.56
3/10/20 15:55	231.59	27.04	9.93	12.55	151.85	1162.18	4.56
3/10/20 15:56	231.77	27.04	9.93	12.55	151.14	1162.22	4.56
3/10/20 15:57	231.58	27.03	9.93	12.55	151.25	1162.41	4.56
3/10/20 15:58	231.82	27.16	9.94	12.55	151.05	1162.67	4.56
3/10/20 15:59	231.78	27.10	9.94	12.56	151.64	1162.54	4.56
3/10/20 16:00	231.88	27.08	9.94	12.56	152.21	1162.71	4.56
3/10/20 16:01	231.73	27.06	9.94	12.56	152.37	1162.28	4.56
3/10/20 16:02	231.37	27.08	9.95	12.56	152.60	1162.23	4.56
3/10/20 16:03	231.77	27.08	9.95	12.56	152.06	1162.44	4.56
3/10/20 16:04	231.99	27.10	9.95	12.57	151.86	1162.69	4.56
3/10/20 16:05	231.95	27.08	9.95	12.57	149.53	1162.41	4.56
3/10/20 16:06	232.15	27.06	9.96	12.57	150.11	1162.59	4.56
3/10/20 16:07	232.10	27.08	9.96	12.57	150.60	1162.26	4.56
3/10/20 16:08	231.82	27.05	9.96	12.58	151.64	1162.18	4.56
3/10/20 16:09	231.97	27.11	9.96	12.58	151.56	1161.92	4.56
3/10/20 16:10	231.77	27.09	9.97	12.57	152.04	1162.09	4.56
3/10/20 16:11	231.99	27.14	9.97	12.57	151.67	1162.68	4.57
3/10/20 16:12	232.27	27.13	9.97	12.57	152.46	1162.18	4.57
3/10/20 16:13	231.93	27.11	9.97	12.57	151.57	1162.32	4.57
3/10/20 16:14	231.85	27.12	9.98	12.56	151.10	1162.52	4.57
3/10/20 16:15	231.72	27.08	9.98	12.56	151.13	1162.17	4.57
3/10/20 16:16	231.75	27.05	9.98	12.56	150.92	1162.43	4.57
3/10/20 16:17	232.22	27.05	9.98	12.56	151.28	1162.64	4.57
3/10/20 16:18	231.87	27.11	9.99	12.55	151.42	1162.36	4.57
3/10/20 16:19	231.84	27.09	9.99	12.55	151.56	1162.37	4.57
3/10/20 16:20	231.85	27.19	9.99	12.55	151.49	1162.37	4.57
3/10/20 16:21	231.94	27.10	10.00	12.55	150.92	1162.55	4.57
3/10/20 16:22	231.97	27.11	10.00	12.54	151.34	1162.44	4.57
3/10/20 16:23	232.20	27.11	10.00	12.54	151.07	1162.21	4.57
3/10/20 16:24	232.02	27.13	10.00	12.54	150.51	1162.47	4.57
3/10/20 16:25	232.00	27.15	10.01	12.53	151.23	1162.02	4.57
3/10/20 16:26	231.96	27.07	10.01	12.53	149.81	1162.08	4.57
3/10/20 16:27	231.97	27.07	10.01	12.53	151.02	1162.44	4.57
3/10/20 16:28	231.84	27.05	10.01	12.53	150.10	1162.60	4.57
3/10/20 16:29	232.02	27.09	10.02	12.54	149.83	1162.01	4.57
3/10/20 16:30	232.07	27.11	10.02	12.54	149.98	1162.13	4.57

Description	CTG2 Gross output	CT2 gas flow	U2 duct burner gas flow	HRSG2 duct inlet pressure	U2 SCR NH3 flow rate	CT2 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (3/10 16:30 - 3/10 17:30)	231.97	27.08	10.09	12.64	150.42	1162.02	4.58
COUNT = 61							
Signal Tagname	G2.DWATT	G2.FQG	H2.02JBFT105_MassFlow	H2.02BAPT001	H2.02BSFIT500	G2.WEXH	BOPC2.00SBFY061
3/10/20 16:30	232.07	27.11	10.02	12.54	149.98	1162.13	4.57
3/10/20 16:31	231.98	27.06	10.02	12.55	150.46	1162.43	4.57
3/10/20 16:32	231.91	27.06	10.02	12.56	150.86	1162.35	4.57
3/10/20 16:33	231.98	27.10	10.03	12.56	151.31	1161.89	4.57
3/10/20 16:34	232.06	27.17	10.03	12.57	151.36	1162.31	4.57
3/10/20 16:35	231.98	27.07	10.03	12.57	151.58	1162.09	4.57
3/10/20 16:36	231.98	27.09	10.03	12.58	151.76	1161.99	4.57
3/10/20 16:37	232.21	27.14	10.04	12.58	151.56	1162.55	4.58
3/10/20 16:38	232.32	27.08	10.04	12.59	151.22	1162.65	4.58
3/10/20 16:39	231.87	27.03	10.04	12.60	152.04	1162.12	4.58
3/10/20 16:40	231.92	27.04	10.04	12.60	152.10	1162.03	4.58
3/10/20 16:41	232.08	27.09	10.05	12.61	150.58	1161.95	4.58
3/10/20 16:42	232.05	27.10	10.05	12.61	150.93	1162.20	4.58
3/10/20 16:43	231.89	27.06	10.05	12.62	150.34	1162.38	4.58
3/10/20 16:44	232.15	27.01	10.05	12.62	150.92	1162.04	4.58
3/10/20 16:45	232.05	27.12	10.06	12.63	150.10	1162.42	4.58
3/10/20 16:46	231.95	27.11	10.06	12.64	150.18	1162.41	4.58
3/10/20 16:47	232.19	27.08	10.06	12.64	149.21	1162.19	4.58
3/10/20 16:48	231.67	27.07	10.06	12.65	150.13	1161.79	4.58
3/10/20 16:49	232.04	27.17	10.07	12.65	150.56	1161.81	4.58
3/10/20 16:50	231.93	27.08	10.07	12.66	151.12	1162.15	4.58
3/10/20 16:51	231.99	27.06	10.07	12.66	150.67	1161.89	4.58
3/10/20 16:52	232.00	27.11	10.07	12.67	150.37	1161.81	4.58
3/10/20 16:53	231.99	27.05	10.08	12.68	150.76	1162.13	4.58
3/10/20 16:54	231.83	27.08	10.08	12.68	150.43	1162.21	4.58
3/10/20 16:55	232.16	27.02	10.08	12.69	150.53	1161.66	4.58
3/10/20 16:56	232.04	27.07	10.08	12.69	150.89	1162.17	4.58
3/10/20 16:57	231.80	27.10	10.09	12.70	150.40	1161.89	4.58
3/10/20 16:58	231.89	27.07	10.09	12.73	150.59	1161.80	4.58
3/10/20 16:59	232.06	27.10	10.09	12.75	150.88	1161.95	4.58
3/10/20 17:00	232.23	27.12	10.09	12.78	150.21	1162.13	4.58
3/10/20 17:01	231.94	27.07	10.10	12.80	149.97	1162.25	4.58
3/10/20 17:02	231.97	26.99	10.10	12.82	149.57	1162.00	4.58
3/10/20 17:03	231.82	27.11	10.10	12.83	149.88	1161.60	4.59
3/10/20 17:04	232.13	27.09	10.10	12.79	150.47	1162.16	4.59
3/10/20 17:05	231.90	27.04	10.11	12.75	150.31	1162.00	4.59
3/10/20 17:06	232.16	27.17	10.11	12.71	150.31	1161.73	4.59
3/10/20 17:07	232.04	27.11	10.11	12.67	150.22	1162.04	4.59
3/10/20 17:08	231.90	27.08	10.11	12.63	150.10	1161.92	4.59
3/10/20 17:09	232.02	27.11	10.12	12.59	150.22	1162.00	4.59
3/10/20 17:10	231.94	27.05	10.12	12.55	150.83	1162.61	4.59
3/10/20 17:11	231.82	27.13	10.12	12.51	149.91	1161.51	4.59
3/10/20 17:12	231.91	27.06	10.13	12.47	150.50	1162.05	4.59
3/10/20 17:13	232.03	27.01	10.13	12.49	150.09	1161.72	4.59
3/10/20 17:14	232.09	27.06	10.13	12.51	150.04	1161.78	4.59
3/10/20 17:15	231.80	27.05	10.13	12.53	150.19	1161.59	4.59
3/10/20 17:16	231.91	27.07	10.14	12.54	150.07	1161.73	4.59
3/10/20 17:17	231.76	27.04	10.14	12.56	150.52	1161.96	4.59
3/10/20 17:18	231.75	27.08	10.14	12.58	150.23	1161.74	4.59
3/10/20 17:19	232.17	27.06	10.14	12.60	149.71	1161.92	4.59
3/10/20 17:20	231.95	27.03	10.15	12.62	149.39	1161.85	4.59
3/10/20 17:21	232.13	27.06	10.15	12.64	149.83	1162.63	4.59
3/10/20 17:22	231.97	27.11	10.15	12.66	149.71	1161.80	4.59
3/10/20 17:23	232.01	27.07	10.15	12.68	149.64	1162.00	4.59
3/10/20 17:24	231.77	27.05	10.16	12.70	150.41	1161.30	4.59
3/10/20 17:25	231.69	27.13	10.16	12.72	151.16	1161.74	4.59
3/10/20 17:26	232.20	27.10	10.16	12.73	150.04	1161.97	4.59
3/10/20 17:27	231.93	27.07	10.16	12.74	149.69	1161.84	4.59
3/10/20 17:28	231.71	27.12	10.17	12.74	150.10	1161.99	4.59
3/10/20 17:29	231.83	27.08	10.17	12.74	148.87	1162.13	4.60
3/10/20 17:30	231.78	27.18	10.17	12.74	149.85	1161.98	4.60

EMISSION DATA RECORDS

Reference Method Data
Base Load
NOx, CO, VOC, and NH_3

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,008	Btu/SCF fuel
Turbine Fuel Flow	1,617	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,195,187	SCFH

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	22	%
Ambient Temperature	66	° F
Specific Humidity	0.002926	lb H_2O / lb air

Unit Data

Unit Load	230.8	megawatts
Heat Input	2,213	MMBtu/hr
NH_3 Flow Rate	127	lb/hr
Meas. Stack Moisture	7.6	%
Stack Exhaust Flow (M19)	51,014,767	SCFH

Data from: From PM Run PM U-00002 Base-2

Base Load, Run - 1-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/09/20 14:44:11	1980	12.90	1.83	0.15	0.35	4.22	1.46
03/09/20 14:44:41	2010	12.91	1.85	0.15	-0.01	4.23	1.48
03/09/20 14:45:11	2040	12.92	1.86	0.14	0.00	4.22	1.43
03/09/20 14:45:41	2070	12.92	1.85	0.15	-0.01	4.22	1.41
03/09/20 14:46:11	2100	12.92	1.86	0.15	-0.01	4.23	1.37
03/09/20 14:46:41	2130	12.93	1.85	0.15	-0.02	4.24	1.39
03/09/20 14:47:11	2160	12.93	1.86	0.14	-0.03	4.24	1.39
03/09/20 14:47:41	2190	12.94	1.85	0.16	-0.04	4.24	1.39
03/09/20 14:48:11	2220	12.93	1.87	0.17	-0.03	4.24	1.39
03/09/20 14:48:41	2250	12.94	1.85	0.15	-0.04	4.21	1.38
03/09/20 14:49:11	2280	12.94	1.88	0.16	-0.04	4.22	1.34
03/09/20 14:49:41	2310	12.94	1.89	0.14	-0.04	4.23	1.35
03/09/20 14:50:11	2340	12.94	1.86	0.16	-0.04	4.20	1.34
03/09/20 14:50:41	2370	12.95	1.89	0.13	-0.04	4.20	1.26
03/09/20 14:51:11	2400	12.96	1.87	0.17	-0.04	4.19	1.30
03/09/20 14:51:41	2430	12.95	1.85	0.15	-0.04	4.21	1.25
03/09/20 14:52:11	2460	12.96	1.86	0.16	-0.03	4.24	1.25
03/09/20 14:52:41	2490	12.97	1.82	0.15	-0.05	4.23	1.25
03/09/20 14:53:11	2520	12.96	1.80	0.15	-0.04	4.19	1.27
03/09/20 14:53:41	2550	12.97	1.81	0.16	-0.03	4.19	1.25
03/09/20 14:54:11	2580	12.96	1.82	0.15	-0.04	4.22	1.23
03/09/20 14:54:41	2610	12.97	1.87	0.16	-0.04	4.24	1.24
03/09/20 14:55:11	2640	12.96	1.87	0.16	-0.03	4.24	1.20
03/09/20 14:55:41	2670	12.96	1.86	0.16	-0.04	4.24	1.17
03/09/20 14:56:11	2700	12.97	1.86	0.13	-0.03	4.24	1.16
03/09/20 14:56:41	2730	12.96	1.87	0.16	-0.04	4.25	1.16
03/09/20 14:57:11	2760	12.97	1.87	0.14	-0.04	4.25	1.14
03/09/20 14:57:41	2790	12.97	1.87	0.15	-0.04	4.24	1.13
03/09/20 14:58:11	2820	12.97	1.84	0.13	-0.05	4.24	1.14
03/09/20 14:58:41	2850	12.97	1.82	0.15	-0.04	4.24	1.14
03/09/20 14:59:11	2880	12.97	1.83	0.16	-0.04	4.24	1.17
03/09/20 14:59:41	2910	12.97	1.83	0.16	-0.04	4.25	1.15
03/09/20 15:00:11	2940	12.96	1.90	0.17	-0.05	4.25	1.13
03/09/20 15:00:41	2970	12.97	1.90	0.15	-0.05	4.25	1.06
03/09/20 15:01:11	3000	12.97	1.88	0.16	-0.04	4.25	1.09
03/09/20 15:01:41	3030	12.97	1.86	0.15	-0.04	4.25	1.11
03/09/20 15:02:11	3060	12.97	1.87	0.15	-0.04	4.25	1.10
03/09/20 15:02:41	3090	12.96	1.86	0.15	-0.04	4.24	1.09
03/09/20 15:03:11	3120	12.96	1.88	0.15	-0.04	4.25	1.17
03/09/20 15:03:41	3150	12.96	1.88	0.15	-0.05	4.25	1.08
03/09/20 15:04:11	3180	12.96	1.89	0.14	-0.04	4.25	1.11
03/09/20 15:04:41	3210	12.96	1.96	0.16	-0.04	4.25	1.12
03/09/20 15:05:11	3240	12.96	1.96	0.15	-0.04	4.26	1.11
03/09/20 15:05:41	3270	12.96	1.95	0.14	-0.04	4.26	1.11
03/09/20 15:06:11	3300	12.96	1.91	0.15	-0.05	4.25	1.11
03/09/20 15:06:41	3330	12.96	1.85	0.16	-0.04	4.27	1.14
03/09/20 15:07:11	3360	12.95	1.86	0.16	-0.04	4.24	1.18
03/09/20 15:07:41	3390	12.96	1.89	0.15	-0.04	4.19	1.18
03/09/20 15:08:11	3420	12.96	1.86	0.14	-0.04	4.19	1.19
03/09/20 15:08:41	3450	12.96	1.88	0.15	-0.04	4.19	1.19
03/09/20 15:09:11	3480	12.96	1.93	0.19	-0.04	4.19	1.20
03/09/20 15:09:41	3510	12.96	1.99	0.16	-0.04	4.20	1.18
03/09/20 15:10:11	3540	12.96	1.97	0.17	-0.04	4.21	1.18
03/09/20 15:10:41	3570	12.96	1.98	0.14	-0.04	4.22	1.20
03/09/20 15:11:11	3600	12.96	1.87	0.16	0.08	4.23	1.17
03/09/20 15:11:41	3630	12.96	1.97	0.15	-0.03	4.24	1.16
03/09/20 15:12:11	3660	12.97	1.84	0.26	0.03	4.26	1.22
03/09/20 15:12:41	3690	12.97	1.99	0.16	0.04	4.26	1.23
03/09/20 15:13:11	3720	12.96	1.90	0.15	-0.02	4.26	1.20
03/09/20 15:13:41	3750	12.96	1.93	0.27	0.01	4.24	1.17
03/09/20 15:14:11	3780	13.01	1.90	0.17	-0.02	4.25	1.15
03/09/20 15:14:41	3810	12.97	2.08	0.19	-0.02	4.24	1.15
03/09/20 15:15:11	3840	12.96	2.61	0.19	0.01	4.24	1.15
03/09/20 15:15:41	3870	12.96	1.97	0.15	0.01	4.36	1.18
03/09/20 15:16:11	3900	12.96	1.87	0.39	0.05	4.36	1.16
03/09/20 15:16:41	3930	12.96	2.07	0.22	0.06	4.25	1.13
03/09/20 15:17:11	3960	12.97	2.36	0.29	0.03	4.25	1.12
03/09/20 15:17:41	3990	13.00	2.50	0.17	-0.02	4.25	1.15
03/09/20 15:18:11	4020	12.96	1.98	0.15	-0.02	4.25	1.15
03/09/20 15:18:41	4050	12.98	2.39	0.27	0.02	4.25	1.14
03/09/20 15:19:11	4080	12.96	1.88	0.14	0.01	4.25	1.14
03/09/20 15:19:41	4110	12.97	1.98	0.19	-0.03	4.24	1.13
03/09/20 15:20:11	4140	12.97	2.23	0.22	0.11	4.24	1.13
03/09/20 15:20:41	4170	13.01	1.93	0.37	0.02	4.25	1.11
03/09/20 15:21:11	4200	13.05	2.74	0.15	-0.02	4.26	1.10
03/09/20 15:21:41	4230	12.97	1.91	0.18	0.01	4.26	1.10
03/09/20 15:22:11	4260	12.97	2.39	0.28	0.04	4.26	1.12

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,008	Btu/SCF fuel
Turbine Fuel Flow	1,617	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,195,187	SCFH

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	22	%
Ambient Temperature	66	°F
Specific Humidity	0.002926	lb H_2O / lb air

Unit Data

Unit Load	230.8	megawatts
Heat Input	2,213	MMBtu/hr
NH_3 Flow Rate	127	lb/hr
Meas. Stack Moisture	7.6	%
Stack Exhaust Flow (M19)	51,014,767	SCFH

Data from: From PM Run PM U-00002 Base-2

Base Load, Run - 1-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/09/20 15:22:41	4290	13.04	1.93	0.26	-0.02	4.25	1.11
03/09/20 15:23:11	4320	12.96	2.33	0.28	0.00	4.26	1.12
03/09/20 15:23:41	4350	12.96	2.37	0.25	0.00	4.27	1.12
03/09/20 15:24:11	4380	12.98	2.66	0.16	-0.03	4.26	1.17
03/09/20 15:24:41	4410	12.99	2.22	0.21	-0.03	4.24	1.15
03/09/20 15:25:11	4440	12.98	2.23	0.16	-0.03	4.25	1.14
03/09/20 15:25:41	4470	12.98	2.33	0.26	-0.03	4.24	1.10
03/09/20 15:26:11	4500	12.98	2.07	0.19	-0.03	4.23	1.15
03/09/20 15:26:41	4530	12.96	3.19	0.34	0.04	4.24	1.17
03/09/20 15:27:11	4560	12.99	1.94	0.19	0.07	4.25	1.17
03/09/20 15:27:41	4590	13.15	3.28	0.34	0.06	4.22	1.18
03/09/20 15:28:11	4620	13.17	2.98	0.16	-0.03	4.22	1.17
03/09/20 15:28:41	4650	12.96	2.34	0.22	-0.01	4.19	1.15
03/09/20 15:29:11	4680	12.97	2.01	0.25	-0.01	4.23	1.21
03/09/20 15:29:41	4710	13.00	2.66	0.18	0.15	4.23	1.23
03/09/20 15:30:11	4740	12.97	2.22	0.18	-0.01	4.23	1.23
03/09/20 15:30:41	4770	12.97	2.49	0.20	0.04	4.25	1.18
03/09/20 15:31:11	4800	12.97	2.35	0.25	-0.02	4.26	1.17
03/09/20 15:31:41	4830	13.01	2.26	0.47	0.01	4.27	1.19
03/09/20 15:32:11	4860	12.99	2.41	0.19	-0.03	4.26	1.19
03/09/20 15:32:41	4890	13.01	2.24	0.17	-0.01	4.26	1.20
03/09/20 15:33:11	4920	12.99	2.87	0.18	-0.03	4.26	1.21
03/09/20 15:33:41	4950	12.97	1.87	0.16	0.15	4.25	1.21
03/09/20 15:34:11	4980	12.96	2.37	0.15	0.03	4.26	1.23
03/09/20 15:34:41	5010	12.97	2.03	0.20	-0.03	4.25	1.24
03/09/20 15:35:11	5040	12.97	2.35	0.21	-0.02	4.25	1.24
03/09/20 15:35:41	5070	12.97	2.11	0.18	-0.02	4.25	1.22
03/09/20 15:36:11	5100	12.97	2.46	0.25	-0.03	4.25	1.22
03/09/20 15:36:41	5130	12.98	3.35	0.16	0.01	4.26	1.23
03/09/20 15:37:11	5160	12.97	2.13	0.19	0.07	4.24	1.29
03/09/20 15:37:41	5190	12.97	2.86	0.25	-0.02	4.22	1.23
03/09/20 15:38:11	5220	12.97	1.91	0.15	-0.01	4.24	1.21
03/09/20 15:38:41	5250	13.04	2.37	0.28	-0.01	4.23	1.23
03/09/20 15:39:11	5280	12.96	1.95	0.22	0.02	4.21	1.24
03/09/20 15:39:41	5310	12.96	2.26	0.14	0.00	4.22	1.26
03/09/20 15:40:11	5340	12.96	2.21	0.18	0.01	4.23	1.32
03/09/20 15:40:41	5370	12.88	2.13	0.24	0.27	4.23	1.26
03/09/20 15:41:11	5400	12.87	2.17	0.27	0.10	4.24	1.27
03/09/20 15:41:41	5430	12.96	2.01	0.35	0.07	4.25	1.24
03/09/20 15:42:11	5460	12.96	1.94	0.26	0.20	4.25	1.23
03/09/20 15:42:41	5490	12.97	2.12	0.31	0.15	4.24	1.28
03/09/20 15:43:11	5520	12.98	2.55	0.15	0.13	4.25	1.28
03/09/20 15:43:41	5550	12.97	1.91	0.15	-0.03	4.23	1.23
RAW AVERAGE		**12.97**	**2.08**	**0.19**	**0.00**	**4.24**	**1.20**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.11	-0.10	-0.01	-0.03	0.01	
Bias	**Final Zero**	0.10	-0.05	-0.04	-0.04	-0.04	
Bias	**Avg. Zero**	0.11	-0.08	-0.03	-0.04	-0.02	
Bias	**Initial UpScale**	11.94	4.84	5.08	3.17	9.06	
Bias	**Final UpScale**	11.89	4.93	5.07	3.23	8.92	
Bias	**Avg. UpScale**	11.92	4.89	5.08	3.20	8.99	
Upscale Cal Gas		12.00	4.91	5.09	3.37	8.94	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	13.07	2.14	0.21	0.00	4.22	1.30
Concentration (ppm@ 15%O_2)	N/A	1.61	0.16	0.00	N/A	0.98

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,008	Btu/SCF fuel
Turbine Fuel Flow	1,624	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,205,298	SCFH

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	25	%
Ambient Temperature	67	°F
Specific Humidity	0.003445	lb H_2O / lb air

Unit Data

Unit Load	230.6	megawatts
Heat Input	2,223	MMBtu/hr
NH_3 Flow Rate	123	lb/hr
Meas. Stack Moisture	7.6	%
Stack Exhaust Flow (M19)	51,447,204	SCFH

Data from: From PM Run PM U-00002 Base-2

Base Load, Run - 1-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/09/20 16:05:11	6840	12.97	1.86	0.16	-0.03	4.89	0.87
03/09/20 16:05:41	6870	12.82	1.93	0.44	0.03	4.72	0.88
03/09/20 16:06:11	6900	12.80	1.89	0.19	-0.03	4.74	0.89
03/09/20 16:06:41	6930	12.98	3.63	0.15	-0.02	4.80	0.89
03/09/20 16:07:11	6960	12.97	1.92	0.17	-0.02	4.79	0.90
03/09/20 16:07:41	6990	12.97	2.20	0.22	0.01	4.80	0.91
03/09/20 16:08:11	7020	12.99	1.86	0.26	0.16	4.80	0.92
03/09/20 16:08:41	7050	12.97	3.25	0.19	0.01	4.75	0.95
03/09/20 16:09:11	7080	12.97	2.23	0.17	-0.01	4.85	0.94
03/09/20 16:09:41	7110	13.02	1.88	0.23	-0.02	4.98	0.96
03/09/20 16:10:11	7140	12.96	1.88	0.19	-0.04	5.03	0.94
03/09/20 16:10:41	7170	12.97	1.84	0.13	-0.05	5.06	0.94
03/09/20 16:11:11	7200	13.00	2.28	0.32	0.17	4.98	0.97
03/09/20 16:11:41	7230	12.97	2.17	0.26	-0.03	4.77	0.91
03/09/20 16:12:11	7260	13.01	2.06	0.16	-0.01	4.74	0.94
03/09/20 16:12:41	7290	12.97	2.11	0.28	-0.01	5.00	0.94
03/09/20 16:13:11	7320	12.96	2.30	0.34	-0.03	4.91	0.94
03/09/20 16:13:41	7350	13.00	2.01	0.21	-0.03	5.08	1.00
03/09/20 16:14:11	7380	12.96	2.11	0.20	-0.01	5.21	0.96
03/09/20 16:14:41	7410	12.97	1.94	0.25	0.07	5.04	0.98
03/09/20 16:15:11	7440	12.97	3.18	0.29	-0.03	5.01	0.98
03/09/20 16:15:41	7470	13.00	2.41	0.19	-0.03	4.98	1.03
03/09/20 16:16:11	7500	13.00	2.00	0.16	-0.01	4.92	1.02
03/09/20 16:16:41	7530	12.98	2.01	0.16	-0.02	4.83	1.06
03/09/20 16:17:11	7560	12.98	1.90	0.20	0.15	4.75	1.04
03/09/20 16:17:41	7590	12.98	2.44	0.22	0.11	4.58	1.06
03/09/20 16:18:11	7620	12.97	1.98	0.14	-0.03	4.60	1.08
03/09/20 16:18:41	7650	12.98	2.26	0.31	0.10	4.61	1.10
03/09/20 16:19:11	7680	12.96	1.91	0.17	-0.01	4.67	1.12
03/09/20 16:19:41	7710	12.95	2.10	0.21	0.25	4.61	1.15
03/09/20 16:20:11	7740	12.97	2.09	0.35	0.00	4.59	1.13
03/09/20 16:20:41	7770	12.97	1.98	0.18	0.02	4.60	1.13
03/09/20 16:21:11	7800	12.99	2.01	0.18	0.06	4.58	1.14
03/09/20 16:21:41	7830	12.99	2.08	0.40	-0.01	4.56	1.11
03/09/20 16:22:11	7860	12.99	1.88	0.24	-0.02	4.56	1.15
03/09/20 16:22:41	7890	12.96	1.97	0.28	0.11	4.55	1.15
03/09/20 16:23:11	7920	12.97	2.63	0.15	0.13	4.54	1.15
03/09/20 16:23:41	7950	12.97	1.99	0.16	0.06	4.54	1.14
03/09/20 16:24:11	7980	12.98	1.96	0.25	0.04	4.55	1.17
03/09/20 16:24:41	8010	12.97	2.10	0.18	-0.03	4.56	1.16
03/09/20 16:25:11	8040	12.97	2.84	0.19	-0.03	4.57	1.14
03/09/20 16:25:41	8070	12.97	1.92	0.14	0.00	4.64	1.18
03/09/20 16:26:11	8100	12.96	2.12	0.23	0.05	5.07	1.18
03/09/20 16:26:41	8130	12.96	2.00	0.15	-0.01	5.14	1.20
03/09/20 16:27:11	8160	12.99	2.38	0.17	0.01	4.85	1.16
03/09/20 16:27:41	8190	12.96	1.91	0.20	-0.03	4.66	1.22
03/09/20 16:28:11	8220	12.98	2.70	0.21	0.01	4.54	1.20
03/09/20 16:28:41	8250	12.97	1.91	0.21	0.00	4.60	1.22
03/09/20 16:29:11	8280	12.97	1.89	0.16	0.04	4.95	1.19
03/09/20 16:29:41	8310	13.01	1.88	0.18	0.06	4.80	1.19
03/09/20 16:30:11	8340	13.03	2.10	0.15	-0.02	4.93	1.20
03/09/20 16:30:41	8370	12.97	2.09	0.38	0.09	4.77	1.20
03/09/20 16:31:11	8400	12.98	1.88	0.21	-0.03	4.71	1.16
03/09/20 16:31:41	8430	12.99	2.26	0.18	0.00	4.99	1.17
03/09/20 16:32:11	8460	12.98	2.34	0.24	0.09	4.92	1.22
03/09/20 16:32:41	8490	12.97	1.99	0.17	0.03	5.07	1.22
03/09/20 16:33:11	8520	12.97	1.94	0.25	-0.01	5.00	1.25
03/09/20 16:33:41	8550	12.96	2.16	0.18	0.04	4.91	1.23
03/09/20 16:34:11	8580	12.96	2.16	0.16	-0.02	4.86	1.21
03/09/20 16:34:41	8610	12.97	2.19	0.20	0.07	4.73	1.18
03/09/20 16:35:11	8640	12.98	2.27	0.19	-0.03	4.79	1.17
03/09/20 16:35:41	8670	12.97	2.12	0.16	0.00	4.78	1.14
03/09/20 16:36:11	8700	12.97	2.11	0.17	-0.02	4.78	1.15
03/09/20 16:36:41	8730	13.00	2.77	0.16	-0.03	4.73	1.14
03/09/20 16:37:11	8760	12.97	1.96	0.19	0.00	4.81	1.16
03/09/20 16:37:41	8790	12.97	2.06	0.17	-0.02	4.83	1.18
03/09/20 16:38:11	8820	12.97	2.08	0.15	0.09	4.84	1.21
03/09/20 16:38:41	8850	12.99	2.10	0.22	-0.02	4.79	1.19
03/09/20 16:39:11	8880	12.98	2.65	0.22	0.13	4.73	1.19
03/09/20 16:39:41	8910	12.99	2.06	0.17	-0.02	4.73	1.19
03/09/20 16:40:11	8940	12.96	2.92	0.30	0.04	4.62	1.19
03/09/20 16:40:41	8970	12.96	1.91	0.15	0.09	4.59	1.20
03/09/20 16:41:11	9000	12.97	1.91	0.25	-0.03	4.59	1.22
03/09/20 16:41:41	9030	13.02	1.91	0.15	-0.02	4.55	1.19
03/09/20 16:42:11	9060	12.99	1.90	0.33	0.01	4.52	1.22
03/09/20 16:42:41	9090	12.97	2.05	0.21	-0.01	4.52	1.24
03/09/20 16:43:11	9120	12.96	1.89	0.17	0.01	4.53	1.24

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,008	Btu/SCF fuel
Turbine Fuel Flow	1,624	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,205,298	SCFH

Weather Data

Barometric Pressure	30.28	in. Hg
Relative Humidity	25	%
Ambient Temperature	67	°F
Specific Humidity	0.003445	lb H_2O / lb air

Unit Data

Unit Load	230.6	megawatts
Heat Input	2,223	MMBtu/hr
NH_3 Flow Rate	123	lb/hr
Meas. Stack Moisture	7.6	%
Stack Exhaust Flow (M19)	51,447,204	SCFH

Data from: From PM Run PM U-00002 Base-2

Base Load, Run - 1-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/09/20 16:43:41	9150	12.97	2.43	0.25	0.03	4.52	1.25
03/09/20 16:44:11	9180	12.96	2.78	0.14	0.07	4.52	1.24
03/09/20 16:44:41	9210	12.97	1.96	0.14	-0.01	4.52	1.23
03/09/20 16:45:11	9240	12.97	1.93	0.17	-0.02	4.53	1.25
03/09/20 16:45:41	9270	12.96	1.93	0.14	-0.03	4.53	1.25
03/09/20 16:46:11	9300	12.96	2.49	0.21	0.00	4.53	1.26
03/09/20 16:46:41	9330	12.97	1.99	0.16	-0.03	4.54	1.23
03/09/20 16:47:11	9360	12.96	2.49	0.19	0.07	4.54	1.21
03/09/20 16:47:41	9390	12.97	2.29	0.19	-0.02	4.54	1.20
03/09/20 16:48:11	9420	12.98	1.98	0.18	-0.03	4.52	1.21
03/09/20 16:48:41	9450	12.96	2.55	0.17	0.05	4.54	1.19
03/09/20 16:49:11	9480	12.95	3.15	0.17	-0.03	4.71	1.21
03/09/20 16:49:41	9510	12.97	2.39	0.24	-0.02	4.99	1.19
03/09/20 16:50:11	9540	12.98	2.66	0.20	0.02	4.97	1.20
03/09/20 16:50:41	9570	12.97	1.91	0.20	-0.03	4.81	1.20
03/09/20 16:51:11	9600	12.97	1.97	0.17	-0.02	4.62	1.23
03/09/20 16:51:41	9630	13.02	2.05	0.17	-0.03	4.62	1.23
03/09/20 16:52:11	9660	12.96	1.99	0.15	0.04	4.55	1.22
03/09/20 16:52:41	9690	12.96	2.11	0.15	-0.03	4.61	1.21
03/09/20 16:53:11	9720	12.97	1.91	0.14	0.02	4.59	1.24
03/09/20 16:53:41	9750	12.96	3.07	0.17	0.22	4.59	1.26
03/09/20 16:54:11	9780	12.97	3.86	0.28	0.01	4.60	1.25
03/09/20 16:54:41	9810	12.96	2.05	0.16	0.01	4.60	1.27
03/09/20 16:55:11	9840	12.95	1.91	0.15	-0.03	4.59	1.27
03/09/20 16:55:41	9870	12.95	1.92	0.16	-0.03	4.57	1.31
03/09/20 16:56:11	9900	12.96	1.92	0.13	0.00	4.60	1.27
03/09/20 16:56:41	9930	12.97	1.73	0.17	0.00	4.58	1.28
03/09/20 16:57:11	9960	12.95	1.79	0.11	-0.03	4.57	1.36
03/09/20 16:57:41	9990	12.94	1.94	0.19	-0.02	4.57	1.33
03/09/20 16:58:11	10020	12.95	2.29	0.17	-0.02	4.61	1.36
03/09/20 16:58:41	10050	13.02	1.96	0.38	-0.02	4.76	1.34
03/09/20 16:59:11	10080	12.95	1.95	0.19	-0.01	4.87	1.33
03/09/20 16:59:41	10110	12.96	2.01	0.20	0.00	4.77	1.32
03/09/20 17:00:11	10140	12.95	2.55	0.17	0.03	4.91	1.37
03/09/20 17:00:41	10170	12.95	1.98	0.15	0.01	4.88	1.36
03/09/20 17:01:11	10200	12.98	2.41	0.16	0.10	4.86	1.36
03/09/20 17:01:41	10230	12.95	2.01	0.16	-0.03	4.87	1.37
03/09/20 17:02:11	10260	12.98	2.47	0.15	-0.04	4.90	1.35
03/09/20 17:02:41	10290	12.98	1.89	0.24	-0.04	4.87	1.33
03/09/20 17:03:11	10320	13.01	1.90	0.18	-0.04	4.88	1.37
03/09/20 17:03:41	10350	12.95	1.87	0.16	-0.04	4.95	1.37
03/09/20 17:04:11	10380	12.96	2.04	0.16	-0.04	4.89	1.37
03/09/20 17:04:41	10410	12.96	1.96	0.20	-0.04	4.92	1.35
RAW AVERAGE		**12.97**	**2.17**	**0.20**	**0.01**	**4.74**	**1.17**

		O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
Bias	**Initial Zero**	0.10	-0.05	-0.04	-0.04	-0.04	
	Final Zero	0.11	0.09	0.01	0.05	0.00	
	Avg. Zero	0.11	0.02	-0.02	0.00	-0.02	
	Initial UpScale	11.89	4.93	5.07	3.23	8.92	
	Final UpScale	11.89	4.91	5.03	3.32	8.96	
	Avg. UpScale	11.89	4.92	5.05	3.28	8.94	
Upscale Cal Gas		12.00	4.91	5.09	3.37	8.94	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	13.10	2.15	0.22	0.01	4.75	1.26
Concentration (ppm@ 15%O_2)	N/A	1.63	0.16	0.01	N/A	0.95

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,008	Btu/SCF fuel
Turbine Fuel Flow	1,622	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,202,317	SCFH

Weather Data

Barometric Pressure	30.30	in. Hg
Relative Humidity	28	%
Ambient Temperature	65	°F
Specific Humidity	0.003599	lb H_2O / lb air

Unit Data

Unit Load	230.5	megawatts
Heat Input	2,220	MMBtu/hr
NH_3 Flow Rate	124	lb/hr
Meas. Stack Moisture	7.6	%
Stack Exhaust Flow (M19)	50,992,328	SCFH

Data from: From PM Run PM U-00002 Base-2

Base Load, Run - 1-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/09/20 17:18:11	11220	12.87	1.92	0.15	-0.02	4.39	1.54
03/09/20 17:18:41	11250	12.89	1.91	0.15	0.00	4.37	1.48
03/09/20 17:19:11	11280	12.88	1.91	0.15	0.00	4.34	1.46
03/09/20 17:19:41	11310	12.89	1.92	0.14	-0.04	4.37	1.49
03/09/20 17:20:11	11340	12.89	1.92	0.14	-0.04	4.35	1.48
03/09/20 17:20:41	11370	12.91	1.91	0.14	-0.05	4.36	1.42
03/09/20 17:21:11	11400	12.89	1.93	0.15	-0.05	4.38	1.38
03/09/20 17:21:41	11430	12.91	1.88	0.16	-0.05	4.39	1.36
03/09/20 17:22:11	11460	12.90	1.86	0.15	0.00	4.39	1.35
03/09/20 17:22:41	11490	12.91	1.88	0.17	-0.05	4.38	1.31
03/09/20 17:23:11	11520	12.90	1.87	0.15	-0.05	4.38	1.33
03/09/20 17:23:41	11550	12.91	1.86	0.16	-0.04	4.39	1.32
03/09/20 17:24:11	11580	12.90	1.90	0.15	-0.04	4.39	1.27
03/09/20 17:24:41	11610	12.91	1.92	0.17	-0.04	4.38	1.24
03/09/20 17:25:11	11640	12.91	1.87	0.15	-0.04	4.38	1.28
03/09/20 17:25:41	11670	12.90	1.91	0.15	-0.05	4.39	1.28
03/09/20 17:26:11	11700	12.92	1.91	0.14	-0.05	4.40	1.26
03/09/20 17:26:41	11730	12.90	1.90	0.15	-0.04	4.39	1.22
03/09/20 17:27:11	11760	12.91	1.90	0.14	-0.03	4.39	1.23
03/09/20 17:27:41	11790	12.90	1.91	0.15	0.01	4.39	1.22
03/09/20 17:28:11	11820	12.90	1.91	0.15	-0.04	4.37	1.22
03/09/20 17:28:41	11850	12.92	1.92	0.13	-0.04	4.38	1.19
03/09/20 17:29:11	11880	12.90	1.91	0.15	-0.05	4.39	1.16
03/09/20 17:29:41	11910	12.91	1.92	0.14	-0.05	4.40	1.19
03/09/20 17:30:11	11940	12.91	1.92	0.16	-0.04	4.40	1.16
03/09/20 17:30:41	11970	12.90	1.92	0.16	-0.04	4.40	1.16
03/09/20 17:31:11	12000	12.92	1.92	0.16	-0.05	4.38	1.14
03/09/20 17:31:41	12030	12.90	1.92	0.16	-0.04	4.37	1.15
03/09/20 17:32:11	12060	12.90	1.93	0.15	-0.05	4.37	1.17
03/09/20 17:32:41	12090	12.91	1.92	0.16	-0.04	4.37	1.14
03/09/20 17:33:11	12120	12.90	1.92	0.14	-0.04	4.37	1.14
03/09/20 17:33:41	12150	12.91	1.90	0.17	-0.04	4.37	1.15
03/09/20 17:34:11	12180	12.90	1.92	0.15	-0.04	4.38	1.17
03/09/20 17:34:41	12210	12.90	1.92	0.16	-0.04	4.38	1.16
03/09/20 17:35:11	12240	12.91	1.91	0.13	-0.05	4.38	1.13
03/09/20 17:35:41	12270	12.91	1.90	0.16	-0.03	4.39	1.16
03/09/20 17:36:11	12300	12.90	1.91	0.13	-0.02	4.39	1.16
03/09/20 17:36:41	12330	12.91	1.95	0.14	-0.02	4.39	1.16
03/09/20 17:37:11	12360	12.90	1.92	0.14	-0.05	4.39	1.19
03/09/20 17:37:41	12390	12.90	1.92	0.12	-0.05	4.40	1.23
03/09/20 17:38:11	12420	12.90	1.91	0.15	-0.04	4.41	1.25
03/09/20 17:38:41	12450	12.90	1.93	0.15	-0.04	4.38	1.23
03/09/20 17:39:11	12480	12.91	1.92	0.15	-0.05	4.39	1.22
03/09/20 17:39:41	12510	12.90	1.94	0.15	-0.04	4.40	1.26
03/09/20 17:40:11	12540	12.89	1.93	0.16	-0.05	4.40	1.27
03/09/20 17:40:41	12570	12.91	1.92	0.24	-0.04	4.41	1.23
03/09/20 17:41:11	12600	12.90	1.92	0.19	-0.04	4.41	1.22
03/09/20 17:41:41	12630	12.90	1.91	0.15	-0.05	4.41	1.20
03/09/20 17:42:11	12660	12.90	1.91	0.15	-0.05	4.40	1.21
03/09/20 17:42:41	12690	12.89	1.92	0.28	-0.04	4.40	1.19
03/09/20 17:43:11	12720	12.90	1.92	0.16	-0.04	4.39	1.17
03/09/20 17:43:41	12750	12.89	1.92	0.16	-0.05	4.40	1.17
03/09/20 17:44:11	12780	12.89	1.92	0.16	-0.04	4.40	1.17
03/09/20 17:44:41	12810	12.91	1.92	0.14	-0.05	4.40	1.19
03/09/20 17:45:11	12840	12.90	1.92	0.17	0.02	4.40	1.20
03/09/20 17:45:41	12870	12.90	1.91	0.15	-0.05	4.41	1.17
03/09/20 17:46:11	12900	12.90	1.91	0.15	-0.03	4.41	1.18
03/09/20 17:46:41	12930	12.89	2.13	0.15	-0.05	4.41	1.18
03/09/20 17:47:11	12960	12.90	2.02	0.14	-0.04	4.41	1.20
03/09/20 17:47:41	12990	12.90	1.99	0.15	-0.05	4.41	1.19
03/09/20 17:48:11	13020	12.89	1.94	0.15	-0.04	4.41	1.14
03/09/20 17:48:41	13050	12.91	1.94	0.15	-0.05	4.41	1.16
03/09/20 17:49:11	13080	12.89	2.00	0.16	-0.05	4.41	1.20
03/09/20 17:49:41	13110	12.90	2.32	0.14	-0.04	4.40	1.18
03/09/20 17:50:11	13140	12.90	1.99	0.16	-0.04	4.36	1.15
03/09/20 17:50:41	13170	12.89	1.94	0.15	0.06	4.35	1.14
03/09/20 17:51:11	13200	12.91	1.94	0.17	-0.04	4.34	1.15
03/09/20 17:51:41	13230	12.90	1.92	0.14	-0.05	4.35	1.18
03/09/20 17:52:11	13260	12.90	1.92	0.14	-0.04	4.36	1.20
03/09/20 17:52:41	13290	12.91	1.91	0.15	-0.04	4.38	1.19
03/09/20 17:53:11	13320	12.90	1.95	0.16	-0.04	4.38	1.19
03/09/20 17:53:41	13350	12.90	1.89	0.14	-0.04	4.38	1.23
03/09/20 17:54:11	13380	12.89	1.90	0.16	-0.04	4.41	1.26
03/09/20 17:54:41	13410	12.89	2.10	0.17	-0.04	4.41	1.27
03/09/20 17:55:11	13440	12.90	2.39	0.14	-0.02	4.41	1.24
03/09/20 17:55:41	13470	12.89	2.22	0.15	-0.04	4.41	1.20
03/09/20 17:56:11	13500	12.90	2.37	0.15	-0.04	4.38	1.25

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,008	Btu/SCF fuel
Turbine Fuel Flow	1,622	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,202,317	SCFH

Weather Data

Barometric Pressure	30.30	in. Hg
Relative Humidity	28	%
Ambient Temperature	65	° F
Specific Humidity	0.003599	lb H_2O / lb air

Unit Data

Unit Load	230.5	megawatts
Heat Input	2,220	MMBtu/hr
NH_3 Flow Rate	124	lb/hr
Meas. Stack Moisture	7.6	%
Stack Exhaust Flow (M19)	50,992,328	SCFH

Data from: From PM Run PM U-00002 Base-2

Base Load, Run - 1-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/09/20 17:56:41	13530	12.90	2.09	0.15	-0.04	4.40	1.26
03/09/20 17:57:11	13560	12.89	1.96	0.14	-0.05	4.41	1.24
03/09/20 17:57:41	13590	12.90	1.98	0.16	-0.05	4.42	1.36
03/09/20 17:58:11	13620	12.88	2.10	0.16	-0.04	4.42	1.38
03/09/20 17:58:41	13650	12.89	1.99	0.15	-0.05	4.42	1.43
03/09/20 17:59:11	13680	12.89	1.99	0.16	-0.04	4.39	1.40
03/09/20 17:59:41	13710	12.88	1.95	0.17	-0.05	4.42	1.39
03/09/20 18:00:11	13740	12.90	1.95	0.18	-0.05	4.42	1.36
03/09/20 18:00:41	13770	12.88	1.95	0.15	-0.05	4.42	1.39
03/09/20 18:01:11	13800	12.89	1.99	0.16	-0.05	4.42	1.38
03/09/20 18:01:41	13830	12.89	1.99	0.14	-0.04	4.43	1.34
03/09/20 18:02:11	13860	12.88	2.02	0.15	-0.05	4.43	1.35
03/09/20 18:02:41	13890	12.89	1.96	0.15	-0.05	4.42	1.36
03/09/20 18:03:11	13920	12.88	1.96	0.15	0.01	4.43	1.36
03/09/20 18:03:41	13950	12.89	1.93	0.15	0.02	4.42	1.38
03/09/20 18:04:11	13980	12.89	1.94	0.16	-0.05	4.42	1.32
03/09/20 18:04:41	14010	12.88	1.92	0.13	-0.05	4.42	1.31
03/09/20 18:05:11	14040	12.89	1.92	0.16	-0.05	4.42	1.36
03/09/20 18:05:41	14070	12.88	1.93	0.15	-0.04	4.41	1.32
03/09/20 18:06:11	14100	12.90	1.93	0.16	-0.04	4.41	1.35
03/09/20 18:06:41	14130	12.89	1.95	0.16	-0.05	4.42	1.26
03/09/20 18:07:11	14160	12.89	1.97	0.14	-0.04	4.42	1.23
03/09/20 18:07:41	14190	12.90	1.96	0.16	-0.04	4.42	1.26
03/09/20 18:08:11	14220	12.88	1.96	0.14	-0.05	4.42	1.26
03/09/20 18:08:41	14250	12.89	1.97	0.15	-0.04	4.42	1.27
03/09/20 18:09:11	14280	12.88	2.00	0.15	-0.05	4.42	1.22
03/09/20 18:09:41	14310	12.89	2.02	0.20	-0.04	4.43	1.14
03/09/20 18:10:11	14340	12.90	2.01	0.16	-0.04	4.43	1.19
03/09/20 18:10:41	14370	12.89	2.43	0.18	-0.04	4.43	1.15
03/09/20 18:11:11	14400	12.89	1.96	0.17	-0.05	4.43	1.15
03/09/20 18:11:41	14430	12.90	1.95	0.15	-0.04	4.38	1.22
03/09/20 18:12:11	14460	12.89	1.95	0.16	-0.05	4.32	1.09
03/09/20 18:12:41	14490	12.90	2.15	0.14	-0.04	4.32	1.13
03/09/20 18:13:11	14520	12.89	1.97	0.16	-0.05	4.33	1.20
03/09/20 18:13:41	14550	12.88	1.96	0.15	-0.04	4.33	1.13
03/09/20 18:14:11	14580	12.89	1.95	0.16	-0.04	4.36	1.18
03/09/20 18:14:41	14610	12.89	1.99	0.16	-0.04	4.36	1.15
03/09/20 18:15:11	14640	12.88	2.02	0.28	-0.04	4.38	1.19
03/09/20 18:15:41	14670	12.88	2.04	0.15	-0.05	4.38	1.09
03/09/20 18:16:11	14700	12.89	2.07	0.16	-0.04	4.40	1.11
03/09/20 18:16:41	14730	12.87	2.00	0.16	-0.05	4.38	1.03
03/09/20 18:17:11	14760	12.88	2.01	0.16	-0.04	4.38	1.10
03/09/20 18:17:41	14790	12.89	1.98	0.17	-0.05	4.37	1.10
RAW AVERAGE		**12.90**	**1.96**	**0.16**	**-0.04**	**4.39**	**1.24**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.11	0.09	0.01	0.05	0.00	
Bias	**Final Zero**	0.09	-0.06	0.00	0.05	-0.03	
Bias	**Avg. Zero**	0.10	0.02	0.01	0.05	-0.02	
Bias	**Initial UpScale**	11.89	4.91	5.03	3.32	8.96	
Bias	**Final UpScale**	11.86	4.93	5.05	3.21	8.85	
Bias	**Avg. UpScale**	11.88	4.92	5.04	3.27	8.91	
Upscale Cal Gas		12.00	4.91	5.09	3.37	8.94	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	13.04	1.95	0.15	0.00	4.42	1.34
Concentration (ppm@ 15%O_2)	N/A	1.46	0.11	0.00	N/A	1.01
Non-Bias Adjusted Averages Include:				*		

EMISSION DATA RECORDS

Reference Method Data
Base Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#2	
Operator		Rob White	
Date for Preliminary Run	(mm/dd/yy)	03/09/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		U-00002	
Base Run Number		PM U-00002 Base	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	03/09/20	03/09/20	03/10/20	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8638.42	8638.42	8638.67	dscf/MMBtu
Meter Box Number	from ACS	Samp-cp-0030	Samp-cp-0030	Samp-cp-0030	
Meter Calibration Factor	(Y)	0.974	0.974	0.974	
Orifice Meter Coefficient	($\Delta H_@$)	1.878	1.878	1.878	in H_2O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	4187/10	4187/10	4187/10	
Pitot Tube Coefficient	(C_p)	0.7240	0.7240	0.7240	
Nozzle Number	from ACS	4b	4b	4b	must match cyc nozz tab (e.g. 3a, 4b, etc.)
Nozzle Diameter	(D_n)	0.156	0.156	0.156	in
Probe Number	from ACS	SAMP-PR-0133	SAMP-PR-0133	SAMP-PR-0133	
Probe Length		120.0	120.0	120.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039	
Impinger Case Number	from ACS	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	03/09/20
Sampling Location	U-00002 Base	**Stack Type**	Circular
Operator	Rob White	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	4
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

○ Method 1 Trav

◉ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
4	**Ports by**	3	**Across**
12	**Pts Used**	12	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.044	10	18
2	0.146	33 2/8	41 2/8
3	0.296	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Cricket Valley Energy Center			
Sampling Location	U-00002 Base			
Operator	Rob White			
Project #	bec-19-cricketvalley.ny-start#2			
Pitot Leak Check	x	**PreTest**	x	**PostTest**

Preliminary Run Date	03/09/20		
Stack Type	Circular		
Ports Available	4		
Thermocouple ID	SAMP-PR-0133		
Pitot Coefficient	0.8198	**Pitot Identification**	A4187

RM 201A or OTM 27 Blckag.	**RM 201A or OTM 27 Pitot Coeff.**
5.39E-04	0.7240

Stack Dimensions			
Area of Stack	(A_s)	283.53	ft²
Diameter of Stack	(D)	228.00	in

Pressures			
Barometric Pressure	(P_b)	30.31	in Hg
Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.24	in Hg

Stack Gas Composition			
Composition Data:	**Estimated Composition**		
Carbon Dioxide Concentration	($\%CO_2$)	4.90	%vd
Oxygen Concentration	($\%O_2$)	13.00	%vd
Carbon Monoxide Concentration	(ppmCO)	0.00	ppmvd
Nitrogen Concentration	($\%N_2$)	82.10	%vd
Stack Moisture Content	(B_{ws})	8.00	%
Stack Dry Molecular Weight	(M_d)	29.30	lb/lb-mole
Stack Wet Molecular Weight	(M_w)	28.40	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v_s)	56.77	ft/sec
Avg Stack Dry Std Flow Rate	(Q_{sd})	43,984,321	dscf/hr
Avg Stack Dry Std Flow Rate	(Q_{sd})	733,072	dscf/min
Avg Stack Wet Flow Rate	(Q_{aw})	965,676	acf/min
Avg Stack Wet Std Flow Rate	(Q_{sw})	47,809,045	ascf/hr

40 CFR 60, Method 2G, Section 8.11.1 (but applies to all Method 2 type static pressure measurements):
If a Type S probe is used for this measurement, position the probe at or between any traverse point(s) and rotate the probe until a null differential pressure reading is obtained. Disconnect the tubing from one of the pressure ports; read and record the ΔP. For pressure devices with one-directional scales, if a deflection in the positive direction is noted with the negative side disconnected, then the static pressure is positive. Likewise, if a deflection in the positive direction is noted with the positive side disconnected, then the static pressure is negative.

Stack Cross Section Schematic

Velocity Traverse Data							
Run Number		PM U-00002 Base-V1					
Run Time		06:44	**Start**	07:11	**End**		
Traverse Point	**Velocity Head** (Δp)	**Null Angle** (N_a)	**Zero Deg Pressure** ($0°_a$)	**Stack Temp** (t_s)	**Local Velocity** ($v_{s(l)}$)	**Adjusted Velocity Pressure**	**Adjusted Velocity Pressure w/BF, if app**
	in H_2O	deg	in H_2O	°F	ft/sec	in H_2O	in H_2O
A-1	1.50	0	0.00	191	74.73	1.17	1.17
A-2	1.40	0	0.00	189	72.08	1.09	1.09
A-3	1.50	-5	0.65	186	74.44	1.17	1.17
B-1	1.40	0	0.00	187	71.97	1.09	1.09
B-2	1.40	0	0.00	186	71.92	1.09	1.09
B-3	1.30	0	0.00	185	69.25	1.01	1.01
C-1	1.50	0	0.00	185	74.38	1.17	1.17
C-2	1.60	-5	0.15	187	76.94	1.25	1.25
C-3	1.50	-5	0.15	188	74.55	1.17	1.17
D-1	1.30	0	0.00	184	69.19	1.01	1.01
D-2	1.40	0	0.00	187	71.97	1.09	1.09
D-3	1.40	0	0.00	187	71.97	1.09	1.09
Average	1.43	1		187		1.12	1.12
	1.20	**= Square roots of Δp**					1.06
Standard deviation of null angles =				2.3			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	PM U-00002 Base-4	PM U-00002 Base-5	PM U-00002 Base-6	
Carbon Dioxide Content	4.9	4.9	4.8	4.8				%
Oxygen Content	13.0	12.7	12.8	12.8				%
Stack Moisture Content	8.0	8.4	7.6	7.2				%
Nitrogen plus CO Content	82.1	82.4	82.4	82.4				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H_2O)	Min.	1.01	Max.	1.25

Stack and Equipment Information	Prelim	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	PM U-00002 Base-4	PM U-00002 Base-5	PM U-00002 Base-6	
Barometric Pressure	30.31	30.30	30.25	30.14				in Hg
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89				in H_2O
Absolute Stack Pressure	30.24	30.23	30.18	30.07				in Hg
Average Stack Temp	187	190	192	190				0.00
Average Stack Temp	647	650	652	650				°R
Average Meter Temp	85	77	88	79				0.00
Orifice Meter Coefficient	1.878	1.878	1.878	1.878				in H_2O
Pitot Coefficient	0.724	0.724	0.724	0.724				
Stack Dry Molecular Weight	29.30	29.29	29.28	29.28				lb/lb mole
Stack Wet Molecular Weight	28.40	28.35	28.42	28.46				lb/lb mole
Stack Viscosity	201.52	201.67	202.96	202.93				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.08							
Cunningham Correction Factor, for a 2.5 µm particle		1.07	1.07	1.07				
Prelim Cut Dia., Cyclone I, D_{50LL}, N_{re}<3162	10.30	2.31	2.37	2.36				µm
Middle Zone Dia., Cyclone I, D_{50T}, N_{re}<3162	10.65							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.), N_{re}<3162	0.48							dscfm
Reynolds Number, Cyc I & IV, N_{re}<3162	2739.94	2802.09	2740.48	2748.34				
Dia. of 50% Prob. (D_{50}) Cyc IV (N_{re}<3162)	2.38	2.32	2.38	2.37				µm
Sampling Rate, Cyc IV, N_{re}<3,162	0.48							dscfm
Reynolds Number, Cyc IV, N_{re}<3162	2739.90	2802.09	2740.48	2748.34				
Prelim Cut Dia., Cyclone I, $D_{50LL\geq3162}$	10.63							µm
Middle Zone Dia., Cyclone I, $D_{50T\geq3162}$	10.81							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.)≥3162	0.47							dscfm
Reynolds Number, Cyc I & IV, N_{re}≥3162	2681.40							
Dia. of 50% Prob. (D_{50}) CIV (N_{re}≥3162)	2.29							µm
Sampling Rate, Cyc IV, N_{re}≥3,162	4.71							dscfm
Reynolds Number ≥ 3162	26814.13							
Cyclone Flow Rate	0.48	0.50	0.49	0.49				ft³/min
Recalculated D_{50-1} for C_{IV}		2.31	2.37	2.36				
Recalculated Cunninham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		97.47	98.79	97.53				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.156	0.156	0.156				in

Orifice Head and Nozzle Selection Calculation											
Nozzle No.	2a	2b	3a	3b	4a	4b	5a	5b	6a	6b	7a
Nozzle diameter, D_n, in.	0.119	0.130	0.130	0.143	0.155	0.156	0.175	0.172	0.197	0.192	0.212
Nozzle velocity, v_n, ft/sec	103.85	87.02	87.02	71.91	61.47	60.43	48.02	49.71	37.89	39.89	32.72
R_{min}	0.77	0.76	0.76	0.74	0.73	0.73	0.69	0.70	0.63	0.65	0.58
v_{min}, ft/sec	79.76	65.95	65.95	53.45	44.70	43.81	33.16	34.63	24.04	25.90	19.03
R_{max}	1.22	1.23	1.23	1.24	1.25	1.25	1.27	1.27	1.30	1.29	1.32
v_{max}, ft/sec	126.95	106.96	106.96	89.07	76.75	75.52	60.95	62.93	49.15	51.47	43.17
Δp_{min}, in. H_2O @ $t_{s-50}{}^oF$	2.39	1.63	1.63	1.07	0.75	0.72	0.41	0.45	0.22	0.25	0.14
Δp_{min}, in. H_2O @ t_s	2.21	1.51	1.51	0.99	0.69	0.67	0.38	0.42	0.20	0.23	0.13
Δp_{max}, in. H_2O @ t_s	5.59	3.97	3.97	2.75	2.04	1.98	1.29	1.37	0.84	0.92	0.65
Δp_{min}, in. H_2O @ $t_{s+50}{}^oF$	5.19	3.68	3.68	2.55	1.90	1.84	1.20	1.27	0.78	0.85	0.60
ΔH, in. H_2O @ t_s+50°F	0.396										
ΔH, in. H_2O @ t_s	**0.459**										
ΔH, in. H_2O @ t_s-50°F	0.539										

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/09/20		
Sampling Location	U-00002 Base	**Operator**	Rob White		
Project #	bec-19-cricketvalley.ny-start#2	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	PM U-00002 Base-1		**Date**	03/09/20	**Run Start Time**	08:15	**Run Stop Time**	13:16
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
05:01	4.9	12.7	0.0	82.4	29.29	1.673	140.3	YES

Gas Analysis Data

Run Number	PM U-00002 Base-2		**Date**	03/09/20	**Run Start Time**	13:30	**Run Stop Time**	19:48
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
06:18	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

Gas Analysis Data

Run Number	PM U-00002 Base-3		**Date**	03/10/20	**Run Start Time**	07:23	**Run Stop Time**	12:15
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:52	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/09/20
Sampling Location	U-00002 Base	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	03/09/20	500	499.7	-0.3	Pass
Test Day 2	03/10/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		PM U-00002 Base-1		**Date**	03/09/20	**Start Time**	08:15	**Stop Time**	13:16
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	103.900	dcf		**Barometric Pressure**	(P_b)	30.30	in Hg
Average Stack Temp		$(t_s)_{avg}$	190	°F		**Stack Static Pressure**	(P_{static})	-0.89	in H_2O
Average Meter Temp		$(t_m)_{avg}$	77	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	519.60	583.00	659.00	868.70				
Initial Value	(V_i),(W_i)	374.10	582.10	641.40	837.00				
Net Value	(V_n),(W_n)	145.5	0.9	17.6	31.7				
Results									
Total Weight		(W_t)	195.70	g		**Water Vol Weighed**	$(V_{wsg(std)})$	9.227	scf
Std Meter Volume		$(V_{m(std)})$	100.816	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	62.33	%
Calc Moisture Content		$(B_{ws(calc)})$	8.39	%		**Final Moisture Content**	(B_{ws})	8.39	%

Moisture Content Data									
Run Number		PM U-00002 Base-2		**Date**	03/09/20	**Start Time**	13:30	**Stop Time**	19:48
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	101.880	dcf		**Barometric Pressure**	(P_b)	30.25	in Hg
Average Stack Temp		$(t_s)_{avg}$	192	°F		**Stack Static Pressure**	(P_{static})	-0.89	in H_2O
Average Meter Temp		$(t_m)_{avg}$	88	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	473.70	587.90	747.60	849.20				
Initial Value	(V_i),(W_i)	359.60	585.50	718.90	825.20				
Net Value	(V_n),(W_n)	114.1	2.4	28.7	24.0				
Results									
Total Weight		(W_t)	169.20	g		**Water Vol Weighed**	$(V_{wsg(std)})$	7.978	scf
Std Meter Volume		$(V_{m(std)})$	96.846	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	65.40	%
Calc Moisture Content		$(B_{ws(calc)})$	7.61	%		**Final Moisture Content**	(B_{ws})	7.61	%

Moisture Content Data									
Run Number		PM U-00002 Base-3		**Date**	03/10/20	**Start Time**	07:23	**Stop Time**	12:15
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	102.820	dcf		**Barometric Pressure**	(P_b)	30.14	in Hg
Average Stack Temp		$(t_s)_{avg}$	190	°F		**Stack Static Pressure**	(P_{static})	-0.89	in H_2O
Average Meter Temp		$(t_m)_{avg}$	79	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	487.90	597.90	684.70	892.00				
Initial Value	(V_i),(W_i)	373.50	597.40	659.00	868.70				
Net Value	(V_n),(W_n)	114.4	0.5	25.7	23.3				
Results									
Total Weight		(W_t)	163.90	g		**Water Vol Weighed**	$(V_{wsg(std)})$	7.728	scf
Std Meter Volume		$(V_{m(std)})$	99.027	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	63.45	%
Calc Moisture Content		$(B_{ws(calc)})$	7.24	%		**Final Moisture Content**	(B_{ws})	7.24	%

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Date	03/09/20
Operator	Rob White
Run Number	PM U-00002 Base-1

Filter #
19031822
PM U-00002 Base-1-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	189.7	°F
Average Meter Temp	(t_m)	77.3	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.19	in H_2O
Stack Moisture Content	(B_{ws})	8.39	%
Stack Dry Molecular Weight	(M_d)	29.29	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.35	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
Pitot	**Pre (+)**	0.00	in H_2O	3.6	in H_2O for	15.0	sec (≥15)
	Pre (-)	0.00	in H_2O	3.8	in H_2O for	15.0	sec (≥15)
PASS	**Post (+)**	0.00	in H_2O	3.6	in H_2O for	15.0	sec (≥15)
	Post (-)	0.00	in H_2O	4.1	in H_2O for	15.0	sec (≥15)

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.2180	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.30	in Hg
Stack Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.23	in Hg
Absolute Meter Pressure	(P_m)	30.44	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	08:15	**End**	13:16

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	374.1	582.1	641.4	837.0				
Post	519.6	583.0	659.0	868.7				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	364.330	1.40	0.459	0.46	191	251	254	52	60	72	62	62	3.5	1.18	63.83	8.410	98.0	101.014
A-2	22.5	00:22:30	372.750	1.40	0.459	0.46	190	251	251	66	77	76	66	66	3.5	1.18	63.78	16.717	97.3	100.392
A-3	45.0	00:45:00	381.130	1.30	0.459	0.46	189	252	254	63	78	77	70	70	3.5	1.14	61.41	24.223	96.6	98.438
B-1	66.5	01:06:30	388.760	1.50	0.459	0.46	190	255	253	64	77	77	74	74	3.5	1.22	66.02	33.684	98.4	101.426
B-2	89.8	01:29:45	398.450	1.40	0.459	0.46	188	250	252	65	77	78	76	76	3.5	1.18	63.68	41.806	97.6	100.651
B-3	112.3	01:52:15	406.800	1.40	0.459	0.46	189	250	251	56	64	73	78	78	3.5	1.18	63.73	49.976	97.2	100.229
C-1	134.8	02:14:45	415.230	1.30	0.459	0.46	190	246	255	58	65	76	80	80	3.5	1.14	61.46	58.018	97.8	100.349
C-2	156.3	02:36:15	423.560	1.50	0.459	0.46	191	259	253	67	74	77	81	81	4.0	1.22	66.07	66.904	97.7	100.729
C-3	179.5	02:59:30	432.780	1.40	0.459	0.46	190	256	250	67	75	78	83	83	4.0	1.18	63.78	75.229	97.6	100.647
D-1	202.0	03:22:00	441.450	1.50	0.459	0.46	189	257	252	63	72	74	84	84	4.0	1.22	65.97	83.644	97.0	100.354
D-2	225.3	03:45:15	450.230	1.40	0.459	0.46	190	255	251	65	74	77	86	86	4.0	1.18	63.78	92.133	97.1	100.501
D-3	247.8	04:07:45	459.120	1.40	0.459	0.46	189	253	251	66	76	77	88	88	4.0	1.18	63.73	100.801	97.5	100.801
Last Pt	270.3	04:30:15	468.230																	
Final Val	270.3	04:30:15	468.230											**Max Vac**	4.0	**Final Values**		100.801	97.5	
Average Values				1.41		0.46	190	253	252	63	72	76	77	77		1.19	63.94			
													77							

Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.35	8.410	98.0	824.1
0.156	0.35	8.306	96.7	803.3
0.156	0.35	7.506	94.8	711.8
0.156	0.35	9.461	103.0	974.3
0.156	0.35	8.122	94.4	766.9
0.156	0.35	8.170	95.0	776.4
0.156	0.35	8.043	101.7	817.9
0.156	0.35	8.886	96.8	860.1
0.156	0.35	8.325	96.9	806.8
0.156	0.35	8.415	91.5	770.2
0.156	0.35	8.489	98.8	839.0
0.156	0.35	8.668	100.8	874.0
0.156	0.35	100.801		

RM 201A Calculations						
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
22.50	22.39	1.40		1.40	0
22.50	22.39	1.40	22.39	1.40	0
21.50	21.58	1.30	21.58	1.30	0
23.25	23.18	1.50		1.50	0
22.50	22.39	1.40	22.39	1.40	0
22.50	22.39	1.40	22.39	1.40	0
21.50	21.58	1.30		1.30	0
23.25	23.18	1.50	23.18	1.50	0
22.50	22.39	1.40	22.39	1.40	0
23.25	23.18	1.50		1.50	0
22.50	22.39	1.40	22.39	1.40	0
22.50	22.39	1.40	22.39	1.40	0

Notes:

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	201.67	μP
	Cyclone Flow Rate (Q_a)	0.50	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.45	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{re}<3162)	10.28	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.64	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.31	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}<3162)	0.50	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2802.09	
	Actual Particle Cut Diameter for CI	10.45	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.32	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.31	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	97.47	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.665	in H_2O
	Δp_{max}	1.977	in H_2O

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Date	03/09/20
Operator	Rob White
Run Number	PM U-00002 Base-2

Filter #
19031835
PM U-00002 Base-2-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	191.8	°F
Average Meter Temp	(t_m)	87.6	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.15	in H_2O
Stack Moisture Content	(B_{ws})	7.61	%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.37	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.36	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.000	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.000	in H_2O	4.0	in H_2O for	15.0	sec [≥15]
	Post (+)	0.000	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
	Post (-)	0.000	in H_2O	4.3	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1535	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.25	in Hg
Stack Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.18	in Hg
Absolute Meter Pressure	(P_m)	30.39	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	13:30	**End**	19:48

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	359.6	585.5	718.9	825.2				
Post	473.7	587.9	747.6	849.2				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1026	8082	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	468.560	1.30	0.459	0.46	189	256	253	60	75	72	83	83	3.5	1.14	61.38	8.215	103.1	100.207
A-2	21.5	00:21:30	477.130	1.50	0.459	0.46	191	257	254	63	77	75	83	83	4.0	1.22	66.03	16.939	98.7	99.266
A-3	44.8	00:44:45	486.230	1.40	0.459	0.46	190	254	250	62	84	78	86	86	4.0	1.18	63.75	25.519	98.9	99.514
B-1	67.3	01:07:15	495.230	1.40	0.459	0.46	189	255	252	63	84	78	91	91	4.5	1.18	63.70	33.917	98.4	99.106
B-2	89.8	01:29:45	504.120	1.30	0.459	0.46	191	250	249	66	85	79	90	90	4.5	1.14	61.48	41.271	97.4	97.287
B-3	111.3	01:51:15	511.890	1.30	0.459	0.46	189	251	247	67	85	80	90	90	4.5	1.14	61.38	49.050	97.4	96.899
C-1	132.8	02:12:45	520.110	1.30	0.459	0.46	190	252	249	65	85	80	91	91	4.5	1.14	61.43	57.231	98.2	97.302
C-2	154.3	02:34:15	528.770	1.40	0.459	0.46	191	250	247	67	83	78	87	87	4.5	1.18	63.80	66.119	98.8	98.103
C-3	176.8	02:56:45	538.110	1.30	0.459	0.46	200	249	248	66	81	81	87	87	4.5	1.14	61.90	74.465	99.6	98.504
D-1	198.3	03:18:15	546.880	1.40	0.459	0.46	198	255	254	66	82	81	88	88	4.5	1.18	64.14	82.795	99.3	98.360
D-2	220.8	03:40:45	555.650	1.20	0.459	0.46	192	254	250	65	80	78	88	88	4.5	1.10	59.11	90.204	99.4	97.954
D-3	241.5	04:01:30	563.450	1.20	0.459	0.46	192	251	250	68	78	77	87	87	4.5	1.10	59.11	96.856	98.8	96.856
Last Pt	262.3	04:22:15	570.440																	
Final Val	262.3	04:22:15	570.440											**Max Vac**	4.5	**Final Values**		96.856	98.8	
Average Values				1.33		0.46	192	253	250	65	82	78	88	88		1.15	62.27			
													88							

Actual Actual Nozzle Diameter (D_{na})	**DP to DP to DH Iso Factor (K)**	**Point-by-point Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.36	8.215	103.1	847.4
0.156	0.36	8.723	94.4	823.8
0.156	0.36	8.580	99.3	851.7
0.156	0.36	8.398	97.1	815.4
0.156	0.36	7.354	92.5	680.0
0.156	0.36	7.779	97.7	759.8
0.156	0.36	8.181	102.8	841.0
0.156	0.36	8.888	102.9	914.7
0.156	0.36	8.346	105.7	881.8
0.156	0.36	8.330	97.0	807.8
0.156	0.36	7.409	100.5	745.0
0.156	0.36	6.652	90.3	600.5
0.156	0.36	96.856		

RM 201A Calculations

Trav. Point Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point First Point Dwell Times Prelim. Trav. (t_1)**	**First Point First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
21.50	21.58	1.30		1.30	0
23.25	23.18	1.50	23.18	1.50	0
22.50	22.39	1.40	22.39	1.40	0
22.50	22.39	1.40		1.40	0
21.50	21.58	1.30	21.58	1.30	0
21.50	21.58	1.30	21.58	1.30	0
21.50	21.58	1.30		1.30	0
22.50	22.39	1.40	22.39	1.40	0
21.50	21.58	1.30	21.58	1.30	0
22.50	22.39	1.40		1.40	0
20.75	20.73	1.20	20.73	1.20	0
20.75	20.73	1.20	20.73	1.20	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	202.96	μP
	Cyclone Flow Rate (Q_a)	0.49	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.60	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.27	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.63	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.37	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2740.48	
	Actual Particle Cut Diameter for CI	10.60	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.38	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.37	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	98.79	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.665	in H_2O
	Δp_{max}	1.977	in H_2O

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Date	03/10/20
Operator	Rob White
Run Number	PM U-00002 Base-3

Filter #
19031823
PM U-00002 Base-3-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	190.3	°F
Average Meter Temp	(t_m)	78.5	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.17	in H_2O
Stack Moisture Content	(B_{ws})	7.24	%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.37	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.36	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
Pitot	**Pre (+)**	0.00	in H_2O	3.7	in H_2O for	15.0	sec (≥15)
PASS	**Pre (-)**	0.00	in H_2O	4.0	in H_2O for	15.0	sec (≥15)
	Post (+)	0.00	in H_2O	3.6	in H_2O for	15.0	sec (≥15)
	Post (-)	0.00	in H_2O	4.2	in H_2O for	15.0	sec (≥15)

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1533	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Stack Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.07	in Hg
Absolute Meter Pressure	(P_m)	30.28	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	07:23	**End**	12:15

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	373.5	597.4	659.0	868.7				
Post	487.9	597.9	684.7	892.0				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	572.380	1.40	0.459	0.46	189	250	252	59	58	70	60	60	3.0	1.18	63.77	8.448	97.5	100.153
A-2	22.5	00:22:30	580.850	1.30	0.459	0.46	191	250	253	58	60	72	64	64	3.0	1.14	61.54	16.623	100.0	100.778
A-3	44.0	00:44:00	589.110	1.40	0.459	0.46	191	250	252	57	61	73	72	72	3.0	1.18	63.87	25.495	100.9	102.266
B-1	66.5	01:06:30	598.210	1.40	0.459	0.46	190	249	251	59	62	74	76	76	3.0	1.18	63.82	33.352	98.5	99.961
B-2	89.0	01:29:00	606.330	1.30	0.459	0.46	191	250	251	60	61	75	78	78	3.0	1.14	61.54	41.468	99.2	100.106
B-3	110.5	01:50:30	614.750	1.40	0.459	0.46	190	251	253	63	65	76	80	80	3.0	1.18	63.82	49.872	98.8	100.026
C-1	133.0	02:13:00	623.500	1.40	0.459	0.46	190	251	245	65	70	76	78	78	3.0	1.18	63.82	58.182	98.4	99.807
C-2	155.5	02:35:30	632.120	1.50	0.459	0.46	191	250	244	64	71	77	82	82	3.0	1.22	66.11	67.426	98.6	100.620
C-3	178.8	02:58:45	641.780	1.40	0.459	0.46	190	251	249	66	69	76	85	85	3.0	1.18	63.82	75.467	98.0	100.029
D-1	201.3	03:21:15	650.230	1.30	0.459	0.46	191	252	252	67	71	77	88	88	3.0	1.14	61.54	83.246	98.0	99.690
D-2	222.8	03:42:45	658.450	1.40	0.459	0.46	190	250	251	67	71	77	89	89	3.0	1.18	63.82	91.626	97.9	99.658
D-3	245.3	04:05:15	667.320	1.30	0.459	0.46	189	251	250	68	71	78	90	90	3.0	1.14	61.45	99.056	97.5	99.056
Last Pt	266.8	04:26:45	675.200																	
Final Val	266.8	04:26:45	675.200											**Max Vac**	3.0	**Final Values**		99.056	97.5	
Average Values				1.38		0.46	190	250	250	63	66	75	79	79		1.17	63.24			
													79							

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.36	8.448	97.5	823.8
0.156	0.36	8.175	102.7	839.2
0.156	0.36	8.871	102.6	909.9
0.156	0.36	7.857	90.8	713.2
0.156	0.36	8.117	101.9	827.3
0.156	0.36	8.404	97.1	815.9
0.156	0.36	8.310	96.0	797.7
0.156	0.36	9.244	99.9	923.6
0.156	0.36	8.041	92.9	747.0
0.156	0.36	7.780	97.7	759.9
0.156	0.36	8.379	96.8	811.2
0.156	0.36	7.431	93.2	692.2
0.156	0.36	99.056		

RM 201A Calculations

Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**	
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times Prelim. Trav. (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
22.50	22.39	1.40		1.40	0
21.50	21.58	1.30	21.58	1.30	0
22.50	22.39	1.40	22.39	1.40	0
22.50	22.39	1.40		1.40	0
21.50	21.58	1.30	21.58	1.30	0
22.50	22.39	1.40	22.39	1.40	0
22.50	22.39	1.40		1.40	0
23.25	23.18	1.50	23.18	1.50	0
22.50	22.39	1.40	22.39	1.40	0
21.50	21.58	1.30		1.30	0
22.50	22.39	1.40	22.39	1.40	0
21.50	21.58	1.30	21.58	1.30	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	202.93	μP
	Cyclone Flow Rate (Q_s)	0.49	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.58	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.27	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.64	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.36	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2748.34	
	Actual Particle Cut Diameter for CI	10.58	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.37	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.36	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	97.53	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.665	in H_2O
	Δp_{max}	1.977	in H_2O

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#2	
Operator		TW	
Date for Preliminary Run	(mm/dd/yy)	03/09/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	10 L/min	10.6	scf
Run Duration	8a, 2.4.1.3	120	minutes
Unit Number		U-00002	
Base Run Number		SAM U-00002 Base	
Number of Ports Available		4	
Number of Ports Used		1	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	03/09/20	03/09/20	03/09/20	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8638.42	8638.42	8638.42	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0007	samp-cp-0007	samp-cp-0007	
Meter Calibration Factor	(Y)	0.985	0.985	0.985	
Orifice Meter Coefficient	($\Delta H_@$)	1.731	1.731	1.731	in H_2O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-SAM-01	SAMP-SAM-01	SAMP-SAM-01	
Probe Length		72.0	72.0	72.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-ha-0005	samp-ha-0005	samp-ha-0005	
Impinger Case Number	from ACS	samp-bc-0032	samp-bc-0032	samp-bc-0032	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	03/09/20
Sampling Location	U-00002 Base	**Stack Type**	Circular
Operator	TW	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	1
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

- (•) Method 1 Trav
- ( ) 12 Point PM Trav (M201a ONLY)
- ( ) Velocity

Number of Traverse Points Used			
1	**Ports by**	1	**Across**
1	**Pts Used**	1	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.275	62 6/8	70 6/8
2			
3			
4			
5			
6			
7			
8			
9			

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/09/20		
Sampling Location	U-00002 Base	**Operator**	TW		
Project #	bec-19-cricketvalley.ny-start#2	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	SAM U-00002 Base-1		**Date**	03/09/20	**Run Start Time**	08:06	**Run Stop Time**	10:06
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.8	12.7	0.0	82.5	29.28	1.708	139.9	YES

Gas Analysis Data

Run Number	SAM U-00002 Base-2		**Date**	03/09/20	**Run Start Time**	11:49	**Run Stop Time**	13:49
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

Gas Analysis Data

Run Number	SAM U-00002 Base-3		**Date**	03/09/20	**Run Start Time**	15:17	**Run Stop Time**	17:17
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/09/20
Sampling Location	U-00002 Base	**Operator**	TW
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	1

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 2	03/09/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		SAM U-00002 Base-1		**Date**	03/09/20	**Start Time**	08:06	**Stop Time**	10:06
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	42.560	dcf		**Barometric Pressure**	(P_b)	30.30	in Hg
Average Stack Temp		(t_s)$_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		(t_m)$_{avg}$	87	°F		**Avg Orifice Pressure**	(ΔH)$_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	753.20	743.70	618.30	971.60				
Initial Value	(V_i),(W_i)	703.60	734.10	614.40	963.30				
Net Value	(V_n),(W_n)	49.6	9.6	3.9	8.3				
Results									
Total Weight		(W_t)	71.40	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.367	scf
Std Meter Volume		($V_{m(std)}$)	41.004	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	7.59	%		**Final Moisture Content**	(B_{ws})		%

Moisture Content Data									
Run Number		SAM U-00002 Base-2		**Date**	03/09/20	**Start Time**	11:49	**Stop Time**	13:49
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	42.410	dcf		**Barometric Pressure**	(P_b)	29.88	in Hg
Average Stack Temp		(t_s)$_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		(t_m)$_{avg}$	88	°F		**Avg Orifice Pressure**	(ΔH)$_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	814.10	750.00	621.00	918.00				
Initial Value	(V_i),(W_i)	753.20	743.70	618.30	905.80				
Net Value	(V_n),(W_n)	60.9	6.3	2.7	12.2				
Results									
Total Weight		(W_t)	82.10	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.871	scf
Std Meter Volume		($V_{m(std)}$)	40.235	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	8.78	%		**Final Moisture Content**	(B_{ws})		%

Moisture Content Data									
Run Number		SAM U-00002 Base-3		**Date**	03/09/20	**Start Time**	15:17	**Stop Time**	17:17
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	42.580	dcf		**Barometric Pressure**	(P_b)	30.12	in Hg
Average Stack Temp		(t_s)$_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		(t_m)$_{avg}$	91	°F		**Avg Orifice Pressure**	(ΔH)$_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	869.90	751.10	621.60	925.30				
Initial Value	(V_i),(W_i)	814.10	750.00	621.00	918.00				
Net Value	(V_n),(W_n)	55.8	1.1	0.6	7.3				
Results									
Total Weight		(W_t)	64.80	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.055	scf
Std Meter Volume		($V_{m(std)}$)	40.514	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	7.01	%		**Final Moisture Content**	(B_{ws})		%

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Date	03/09/20
Operator	TW
Run Number	SAM U-00002 Base-1

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	87.1	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.30	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.37	in Hg
Absolute Meter Pressure	(P_m)	30.43	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	08:06	**End**	10:06

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	703.6	734.1	614.4	963.3				
Post	753.2	743.7	618.3	971.6				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	892.500	--	0.342	0.34	--	350	504	54	115	--	80	76	1.0			1.685		40.445
A-2	5.0	00:05:00	894.220	--	0.342	0.34	--	350	538	56	120	--	85	77	1.0			3.381		40.567
A-3	10.0	00:10:00	895.960	--	0.342	0.34	--	350	538	60	122	--	87	77	1.0			5.121		40.971
A-4	15.0	00:15:00	897.750	--	0.342	0.34	--	350	510	53	121	--	89	79	1.0			6.827		40.961
A-5	20.0	00:20:00	899.510	--	0.342	0.34	--	350	536	64	121	--	91	79	1.0			8.539		40.986
A-6	25.0	00:25:00	901.280	--	0.342	0.34	--	350	536	64	120	--	92	78	1.0			10.251		41.003
A-7	30.0	00:30:00	903.050	--	0.342	0.34	--	350	526	64	120	--	91	80	1.0			11.855		40.645
A-8	35.0	00:35:00	904.710	--	0.342	0.34	--	350	507	63	120	--	92	81	1.0			13.639		40.917
A-9	40.0	00:40:00	906.560	--	0.342	0.34	--	350	517	59	119	--	93	80	1.0			15.366		40.975
A-10	45.0	00:45:00	908.350	--	0.342	0.34	--	350	538	58	119	--	95	81	1.0			17.073		40.975
A-11	50.0	00:50:00	910.125	--	0.342	0.34	--	350	530	59	120	--	94	82	1.0			18.790		40.996
A-12	55.0	00:55:00	911.910	--	0.342	0.34	--	350	523	59	120	--	94	82	1.0			20.493		40.985
A-13	60.0	01:00:00	913.680	--	0.342	0.34	--	350	532	61	120	--	95	83	1.0			22.192		40.970
A-14	65.0	01:05:00	915.450	--	0.342	0.34	--	350	533	62	151	--	96	82	1.0			23.872		40.924
A-15	70.0	01:10:00	917.200	--	0.342	0.34	--	350	537	65	122	--	95	84	1.0			25.599		40.958
A-16	75.0	01:15:00	919.000	--	0.342	0.34	--	350	530	64	123	--	96	84	1.0			27.276		40.914
A-17	80.0	01:20:00	920.750	--	0.342	0.34	--	350	530	62	120	--	97	83	1.0			28.973		40.902
A-18	85.0	01:25:00	922.520	--	0.342	0.34	--	350	532	62	122	--	95	84	1.0			30.805		41.073
A-19	90.0	01:30:00	924.430	--	0.342	0.34	--	350	531	62	124	--	94	84	1.0			32.408		40.937
A-20	95.0	01:35:00	926.100	--	0.342	0.34	--	350	531	64	126	--	96	84	1.0			34.119		40.943
A-21	100.0	01:40:00	927.885	--	0.342	0.34	--	350	536	65	131	--	95	84	1.0			35.802		40.917
A-22	105.0	01:45:00	929.640	--	0.342	0.34	--	350	538	66	136	--	93	85	1.0			37.521		40.932
A-23	110.0	01:50:00	931.430	--	0.342	0.34	--	350	533	65	137	--	95	84	1.0			39.267		40.974
A-24	115.0	01:55:00	933.250	--	0.342	0.34	--	350	536	65	139	--	95	84	1.0			41.003		41.003
Last Pt	120.0	02:00:00	935.060																	
Final Val	120.0	02:00:00	935.060											**Max Vac**	1.0	**Final Values**		41.003		
Average Values						0.34		350	529	62	125		93	82						
													87							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Date	03/09/20
Operator	TW
Run Number	SAM U-00002 Base-2

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	87.9	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.34	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	29.88	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	29.95	in Hg
Absolute Meter Pressure	(P_m)	30.01	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	11:49	**End**	13:49

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	753.2	743.7	618.3	905.8				
Post	814.1	750.0	621.0	918.0				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	942.200	--	0.342	0.34	--	350	506	66	117	--	85	81	1.0			1.608		38.599
A-2	5.0	00:05:00	943.880	--	0.342	0.34	--	350	511	67	121	--	91	81	1.0			3.312		39.749
A-3	10.0	00:10:00	945.670	--	0.342	0.34	--	350	543	68	120	--	92	82	1.0			4.975		39.804
A-4	15.0	00:15:00	947.420	--	0.342	0.34	--	350	514	68	121	--	91	81	1.0			6.640		39.841
A-5	20.0	00:20:00	949.169	--	0.342	0.34	--	350	504	67	119	--	92	82	1.0			8.314		39.908
A-6	25.0	00:25:00	950.930	--	0.342	0.34	--	350	514	68	120	--	95	81	1.0			10.183		40.731
A-7	30.0	00:30:00	952.900	--	0.342	0.34	--	350	508	67	118	--	93	82	1.0			11.673		40.023
A-8	35.0	00:35:00	954.470	--	0.342	0.34	--	350	513	66	119	--	92	83	1.0			13.354		40.062
A-9	40.0	00:40:00	956.240	--	0.342	0.34	--	350	501	65	118	--	93	83	1.0			15.061		40.164
A-10	45.0	00:45:00	958.040	--	0.342	0.34	--	350	510	66	120	--	92	84	1.0			16.736		40.165
A-11	50.0	00:50:00	959.805	--	0.342	0.34	--	350	502	65	121	--	93	84	1.0			18.418		40.184
A-12	55.0	00:55:00	961.580	--	0.342	0.34	--	350	504	65	118	--	93	84	1.0			20.124		40.247
A-13	60.0	01:00:00	963.380	--	0.342	0.34	--	350	520	65	119	--	92	84	1.0			21.812		40.269
A-14	65.0	01:05:00	965.160	--	0.342	0.34	--	350	509	67	121	--	93	83	1.0			23.539		40.352
A-15	70.0	01:10:00	966.980	--	0.342	0.34	--	350	508	68	120	--	93	84	1.0			25.178		40.285
A-16	75.0	01:15:00	968.710	--	0.342	0.34	--	350	502	68	119	--	94	84	1.0			26.854		40.281
A-17	80.0	01:20:00	970.480	--	0.342	0.34	--	350	514	66	119	--	92	84	1.0			28.533		40.282
A-18	85.0	01:25:00	972.250	--	0.342	0.34	--	350	505	68	120	--	93	84	1.0			30.220		40.293
A-19	90.0	01:30:00	974.030	--	0.342	0.34	--	350	505	67	119	--	94	84	1.0			32.142		40.600
A-20	95.0	01:35:00	976.060	--	0.342	0.34	--	350	506	68	121	--	93	84	1.0			33.554		40.265
A-21	100.0	01:40:00	977.550	--	0.342	0.34	--	350	526	68	121	--	94	84	1.0			34.605		39.549
A-22	105.0	01:45:00	978.660	--	0.342	0.34	--	350	504	67	118	--	95	85	1.0			36.902		40.256
A-23	110.0	01:50:00	981.090	--	0.342	0.34	--	350	514	67	118	--	95	85	1.0			38.688		40.370
A-24	115.0	01:55:00	982.980	--	0.342	0.34	--	350	516	68	120	--	93	84	1.0			40.233		40.233
Last Pt	120.0	02:00:00	984.610																	
Final Val	120.0	02:00:00	984.610											**Max Vac**	1.0	**Final Values**		40.233		
Average Values						0.34		350	511	67	119		93	83						
													88							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Date	03/09/20
Operator	TW
Run Number	SAM U-00002 Base-3

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	90.7	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.34	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.12	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.19	in Hg
Absolute Meter Pressure	(P_m)	30.25	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	15:17	**End**	17:17

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	814.1	750.0	621.0	918.0				
Post	869.9	751.1	621.6	925.3				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	995.600	--	0.342	0.34	--	350	518	68	120	--	88	82	1.0			1.721		41.304
A-2	5.0	00:05:00	997.390	--	0.342	0.34	--	350	531	68	122	--	89	83	1.0			3.352		40.230
A-3	10.0	00:10:00	999.090	--	0.342	0.34	--	350	501	60	122	--	91	82	1.5			5.002		40.013
A-4	15.0	00:15:00	1000.810	--	0.342	0.34	--	350	515	64	126	--	92	83	1.5			6.743		40.461
A-5	20.0	00:20:00	1002.630	--	0.342	0.34	--	350	527	66	128	--	93	83	1.5			8.455		40.584
A-6	25.0	00:25:00	1004.420	--	0.342	0.34	--	350	501	68	134	--	94	85	1.5			10.133		40.533
A-7	30.0	00:30:00	1006.180	--	0.342	0.34	--	350	507	68	134	--	94	85	1.5			11.907		40.824
A-8	35.0	00:35:00	1008.040	--	0.342	0.34	--	350	511	68	136	--	95	86	1.5			13.601		40.804
A-9	40.0	00:40:00	1009.820	--	0.342	0.34	--	350	538	67	131	--	94	85	1.5			15.327		40.873
A-10	45.0	00:45:00	1011.630	--	0.342	0.34	--	350	506	67	132	--	95	86	1.5			17.031		40.875
A-11	50.0	00:50:00	1013.420	--	0.342	0.34	--	350	521	66	134	--	96	86	1.5			18.743		40.893
A-12	55.0	00:55:00	1015.220	--	0.342	0.34	--	350	520	66	133	--	96	87	1.5			20.444		40.887
A-13	60.0	01:00:00	1017.010	--	0.342	0.34	--	350	514	67	137	--	97	87	1.5			22.143		40.879
A-14	65.0	01:05:00	1018.800	--	0.342	0.34	--	350	529	52	139	--	97	88	1.5			23.831		40.853
A-15	70.0	01:10:00	1020.580	--	0.342	0.34	--	350	513	63	139	--	96	88	1.5			25.549		40.878
A-16	75.0	01:15:00	1022.390	--	0.342	0.34	--	350	517	64	140	--	97	88	1.5			27.237		40.856
A-17	80.0	01:20:00	1024.170	--	0.342	0.34	--	350	529	65	141	--	97	88	1.5			28.916		40.822
A-18	85.0	01:25:00	1025.940	--	0.342	0.34	--	350	522	63	140	--	97	88	1.5			30.623		40.831
A-19	90.0	01:30:00	1027.740	--	0.342	0.34	--	350	535	63	140	--	97	88	1.5			32.321		40.826
A-20	95.0	01:35:00	1029.530	--	0.342	0.34	--	350	527	64	140	--	97	89	1.5			33.941		40.729
A-21	100.0	01:40:00	1031.240	--	0.342	0.34	--	350	514	65	138	--	97	89	1.5			35.628		40.717
A-22	105.0	01:45:00	1033.020	--	0.342	0.34	--	350	525	65	135	--	97	89	1.5			37.352		40.748
A-23	110.0	01:50:00	1034.840	--	0.342	0.34	--	350	507	67	131	--	97	89	1.5			39.020		40.716
A-24	115.0	01:55:00	1036.600	--	0.342	0.34	--	350	506	67	128	--	98	89	1.5			40.516		40.516
Last Pt	120.0	02:00:00	1038.180																	
Final Val	120.0	02:00:00	1038.180											**Max Vac**	1.5	**Final Values**		40.516		
Average Values						0.34		350	518	65	133		95	86						
													91							

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base Load
Opacity

W/O DB

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 16000 N Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process | Unit # 2 | Operating Mode
Control Equipment | Operating Mode No Det

Describe Emissions Pont


Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 5 End 5
Direction to Emiss. Pt. (Degrees) Start N End N

Vertical Angle to Obs. Pt. Start 10° End 10°
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145 End 145

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Sky Blue End Sky Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start N End N
Ambient Temp. Start End
Wet Bulb Temp.
RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 6
Continued on Form Number (AHI Project Code)

Observation Date 3/9/2020 | Time Zone | Start Time 10:52 | End Time 11:22

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print) SEAN FIELDS
Observer's Signature Date 3/9/20
Organization Air Hygiene
Certified By CAA Date 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 2 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Pont:
Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 5 End 5
Direction to Emiss. Pt. (Degrees) Start N End N

Vetical Angle to Obs. Pt. Start 10° End 10°
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145 End 145

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Sky Blue End Sky Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start N End N
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 6
Continued on Form Number (AHI Project Code)

Observation Date 3/9/2020 Time Zone Start Time 11:22 End Time 11:52

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 3/9/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 16600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: _____ Unit #: 2 Operating Mode: _____
Control Equipment: _____ Operating Mode: _____

Describe Emissions Pont


Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 5" End 5"
Direction to Emiss. Pt. (Degrees) Start N End N

Vetical Angle to Obs. Pt. Start 10° End 10°
Direction to Obs. Pt. (Degrees) Start _____ End _____
Distance and Direction to Observation Point from Emission Point Start 145" End 145"

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start _____ End _____
Background Color Start Sky Blue End Sky Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start N End N
Ambient Temp. Start _____ End _____
Wet Bulb Temp. _____ RH Percent _____

Source Layout Sketch



Latitude _____ Longitude _____ Declination _____

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) _____ Page 2 of 6
Continued on Form Number (AHI Project Code) _____

Observation Date 3/9/2020 Time Zone _____ Start Time 11:52 End Time 12:22

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print) SEAN FIELDS
Observer's Signature _____ Date 3/9/20
Organization Air Hygiene
Certified By CAA Date 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process | Unit # 2 | Operating Mode
Control Equipment | Operating Mode

Describe Emissions Pont


Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 5 End 5
Direction to Emiss. Pt. (Degrees) Start N End N

Vetical Angle to Obs. Pt. Start 10° End 10°
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145 End 145

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Sky Blue End Sky Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start N End N
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 11 of 16
Continued on Form Number (AHI Project Code)

Observation Date: 3/9/2020 Time Zone: Start Time: 12:22 End Time: 12:52

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 3/9/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 11000 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process | Unit # 2 | Operating Mode
Control Equipment | Operating Mode

Describe Emissions Pont


Height of Emiss. Pt.		Height of Emiss. Pt. Rel. to Observer	
Start 140	End 140	Start 150	End 150
Distance to Emiss. Pt.		Direction to Emiss. Pt. (Degrees)	
Start 5	End 5	Start N	End N

Vetical Angle to Obs. Pt.		Direction to Obs. Pt. (Degrees)	
Start 10°	End 10°	Start	End
Distance and Direction to Observation Point from Emission Point			
Start 145		End 145	

Describe Emissions			
Start NA		End NA	
Emission Color		Water Droplet Plume	
Start NA	End NA	Start NA	End NA

Describe Plume Background			
Start	End		
Background Color		Sky Conditions	
Start Sky Blue	End Sky Blue	Start Clear	End Cloud
Wind Speed		Wind Direction	
Start 9	End 9	Start N	End N
Ambient Temp.		Wet Bulb Temp.	RH Percent
Start	End		

Source Layout Sketch



Latitude	Longitude	Declination

Addition Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 5 of 6
Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time
3/9/2020		12:52	1:22

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print)	SEAN FIELDS
Observer's Signature	[signature] Date 3/9/20
Organization	Air Hygiene
Certified By	CAA Date 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 2 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Point:
Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 5 End 5
Direction to Emiss. Pt. (Degrees) Start N End N

Vertical Angle to Obs. Pt. Start 10° End 10°
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145' End 145'

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Sky Blue End Sky Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start N End N
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 6 of 6
Continued on Form Number (AHI Project Code)

Observation Date 3/9/2020 Time Zone Start Time 1122 End Time 1152

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 3/9/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/2020

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
NOx, CO, VOC, and NH_3

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,639	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,011	Btu/SCF fuel
Turbine Fuel Flow	1,625	lb/min
Duct Burner Fuel Flow	166	lb/min
Total Fuel Flow	2,431,495	SCFH

Weather Data

Barometric Pressure	30.17	in. Hg
Relative Humidity	53	%
Ambient Temperature	52	° F
Specific Humidity	0.004296	lb H_2O / lb air

Unit Data

Unit Load	231.8	megawatts
Heat Input	2,459	MMBtu/hr
NH_3 Flow Rate	152	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	50,273,314	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/10/20 15:27:20	30	12.04	2.37	0.16	-0.05	5.01	1.49
03/10/20 15:27:50	60	12.03	2.30	0.24	-0.04	5.01	1.41
03/10/20 15:28:20	90	12.08	2.36	0.17	-0.05	5.01	1.33
03/10/20 15:28:50	120	12.03	2.31	0.16	-0.02	5.01	1.31
03/10/20 15:29:20	150	12.04	2.27	0.17	-0.05	5.01	1.31
03/10/20 15:29:50	180	12.03	2.45	0.21	-0.04	5.01	1.29
03/10/20 15:30:20	210	12.04	2.27	0.19	-0.05	5.01	1.26
03/10/20 15:30:50	240	12.06	2.53	0.18	-0.04	5.01	1.21
03/10/20 15:31:20	270	12.06	2.34	0.17	-0.05	5.02	1.24
03/10/20 15:31:50	300	12.05	2.32	0.16	-0.05	5.01	1.28
03/10/20 15:32:20	330	12.04	2.34	0.15	-0.05	5.01	1.20
03/10/20 15:32:50	360	12.04	2.36	0.16	-0.05	5.01	1.20
03/10/20 15:33:20	390	12.03	2.40	0.17	-0.04	5.02	1.22
03/10/20 15:33:50	420	12.03	2.86	0.33	-0.03	5.02	1.23
03/10/20 15:34:20	450	12.04	2.43	0.15	-0.04	5.02	1.22
03/10/20 15:34:50	480	12.05	2.37	0.17	0.07	5.02	1.22
03/10/20 15:35:20	510	12.05	2.31	0.16	-0.02	5.01	1.22
03/10/20 15:35:50	540	12.03	2.35	0.16	-0.04	5.01	1.26
03/10/20 15:36:20	570	12.03	2.26	0.16	-0.04	5.01	1.29
03/10/20 15:36:50	600	12.04	2.35	0.23	-0.04	5.01	1.35
03/10/20 15:37:20	630	12.04	2.33	0.15	-0.05	5.02	1.25
03/10/20 15:37:50	660	12.02	2.80	0.18	-0.04	5.02	1.28
03/10/20 15:38:20	690	12.03	2.34	0.17	-0.04	5.01	1.30
03/10/20 15:38:50	720	12.04	2.33	0.19	-0.05	5.02	1.35
03/10/20 15:39:20	750	12.04	2.32	0.19	-0.04	5.01	1.31
03/10/20 15:39:50	780	12.04	2.47	0.17	-0.04	5.01	1.35
03/10/20 15:40:20	810	12.05	3.14	0.18	0.00	5.01	1.33
03/10/20 15:40:50	840	12.05	2.64	0.19	0.01	5.02	1.38
03/10/20 15:41:20	870	12.09	2.37	0.17	-0.05	5.02	1.42
03/10/20 15:41:50	900	12.05	2.39	0.17	-0.05	5.02	1.43
03/10/20 15:42:20	930	12.05	2.45	0.16	-0.04	5.03	1.42
03/10/20 15:42:50	960	12.03	2.37	0.20	-0.04	5.02	1.51
03/10/20 15:43:20	990	12.05	2.46	0.16	-0.04	5.02	1.55
03/10/20 15:43:50	1020	12.05	2.46	0.15	-0.04	5.02	1.54
03/10/20 15:44:20	1050	12.05	2.37	0.16	-0.04	5.03	1.58
03/10/20 15:44:50	1080	12.03	2.40	0.16	-0.04	5.02	1.63
03/10/20 15:45:20	1110	12.04	2.34	0.16	-0.04	5.02	1.71
03/10/20 15:45:50	1140	12.04	2.37	0.14	-0.04	5.02	1.70
03/10/20 15:46:20	1170	12.04	2.90	0.20	-0.02	5.02	1.67
03/10/20 15:46:50	1200	12.05	2.31	0.17	0.04	5.01	1.61
03/10/20 15:47:20	1230	12.06	2.38	0.31	-0.03	5.01	1.63
03/10/20 15:47:50	1260	12.05	2.34	0.16	-0.05	5.02	1.64
03/10/20 15:48:20	1290	12.04	2.32	0.15	-0.05	5.02	1.69
03/10/20 15:48:50	1320	12.03	2.29	0.16	-0.04	5.01	1.68
03/10/20 15:49:20	1350	12.03	2.63	0.16	-0.04	5.03	1.67
03/10/20 15:49:50	1380	12.03	2.40	0.16	-0.02	5.02	1.61
03/10/20 15:50:20	1410	12.11	2.39	0.25	-0.04	5.03	1.55
03/10/20 15:50:50	1440	12.05	2.38	0.16	-0.03	5.02	1.60
03/10/20 15:51:20	1470	12.05	2.30	0.17	-0.04	5.01	1.65
03/10/20 15:51:50	1500	12.06	2.31	0.16	-0.01	5.02	1.69
03/10/20 15:52:20	1530	12.06	2.34	0.16	-0.04	5.02	1.61
03/10/20 15:52:50	1560	12.06	2.31	0.15	-0.04	5.02	1.61
03/10/20 15:53:20	1590	12.06	2.42	0.17	-0.04	5.02	1.57
03/10/20 15:53:50	1620	12.05	2.34	0.16	-0.04	5.02	1.63
03/10/20 15:54:20	1650	12.04	2.39	0.17	0.05	5.01	1.67
03/10/20 15:54:50	1680	12.03	2.36	0.17	-0.04	5.02	1.72
03/10/20 15:55:20	1710	12.03	2.41	0.16	-0.04	5.02	1.68
03/10/20 15:55:50	1740	12.03	2.44	0.16	0.10	5.02	1.67
03/10/20 15:56:20	1770	12.05	2.36	0.15	-0.04	5.02	1.75
03/10/20 15:56:50	1800	12.05	2.46	0.24	-0.04	5.02	1.76
03/10/20 15:57:20	1830	12.05	2.41	0.17	-0.04	5.02	1.76
03/10/20 15:57:50	1860	12.04	2.36	0.16	-0.04	5.02	1.75
03/10/20 15:58:20	1890	12.03	2.41	0.16	-0.04	5.02	1.75
03/10/20 15:58:50	1920	12.03	2.35	0.17	-0.04	5.02	1.70
03/10/20 15:59:20	1950	12.03	2.42	0.17	-0.03	5.02	1.66
03/10/20 15:59:50	1980	12.03	2.43	0.16	0.03	5.02	1.66
03/10/20 16:00:20	2010	12.03	2.45	0.26	-0.04	5.02	1.81
03/10/20 16:00:50	2040	12.04	2.39	0.17	-0.04	5.01	1.80
03/10/20 16:01:20	2070	12.05	2.37	0.17	-0.04	5.02	1.84
03/10/20 16:01:50	2100	12.06	2.40	0.15	-0.04	5.02	1.83
03/10/20 16:02:20	2130	12.04	2.35	0.27	-0.04	5.02	1.82
03/10/20 16:02:50	2160	12.03	2.38	0.17	-0.04	5.02	1.77
03/10/20 16:03:20	2190	12.04	2.36	0.17	-0.02	5.02	1.81
03/10/20 16:03:50	2220	12.03	2.23	0.15	-0.05	5.01	1.77
03/10/20 16:04:20	2250	12.04	2.33	0.18	-0.04	5.02	1.77
03/10/20 16:04:50	2280	12.04	2.31	0.16	0.06	5.02	1.79
03/10/20 16:05:20	2310	12.03	2.33	0.17	-0.05	5.02	1.83

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,639	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,011	Btu/SCF fuel
Turbine Fuel Flow	1,625	lb/min
Duct Burner Fuel Flow	166	lb/min
Total Fuel Flow	2,431,495	SCFH

Weather Data

Barometric Pressure	30.17	in. Hg
Relative Humidity	53	%
Ambient Temperature	52	°F
Specific Humidity	0.004296	lb H_2O / lb air

Unit Data

Unit Load	231.8	megawatts
Heat Input	2,459	MMBtu/hr
NH_3 Flow Rate	152	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	50,273,314	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/10/20 16:05:50	2340	12.03	2.30	0.16	-0.04	5.02	1.80
03/10/20 16:06:20	2370	12.02	2.39	0.16	-0.04	5.03	1.73
03/10/20 16:06:50	2400	12.03	2.40	0.16	-0.05	5.03	1.73
03/10/20 16:07:20	2430	12.03	2.39	0.14	-0.04	5.02	1.74
03/10/20 16:07:50	2460	12.03	2.43	0.17	-0.04	5.02	1.75
03/10/20 16:08:20	2490	12.03	2.40	0.17	-0.04	5.02	1.73
03/10/20 16:08:50	2520	12.03	2.32	0.19	-0.02	5.01	1.68
03/10/20 16:09:20	2550	12.05	2.61	0.20	-0.04	5.02	1.62
03/10/20 16:09:50	2580	12.05	2.35	0.16	-0.04	5.02	1.65
03/10/20 16:10:20	2610	12.03	2.37	0.18	-0.04	5.02	1.65
03/10/20 16:10:50	2640	12.02	2.45	0.16	-0.04	5.03	1.65
03/10/20 16:11:20	2670	12.13	2.77	0.18	-0.04	5.02	1.58
03/10/20 16:11:50	2700	12.04	3.15	0.24	-0.02	5.01	1.62
03/10/20 16:12:20	2730	12.07	2.35	0.17	-0.04	5.02	1.67
03/10/20 16:12:50	2760	12.02	2.30	0.16	-0.04	5.02	1.68
03/10/20 16:13:20	2790	12.02	2.37	0.16	-0.04	5.02	1.69
03/10/20 16:13:50	2820	12.03	2.33	0.17	-0.04	5.02	1.66
03/10/20 16:14:20	2850	12.02	3.04	0.17	-0.04	5.02	1.64
03/10/20 16:14:50	2880	12.03	2.43	0.16	-0.04	5.02	1.72
03/10/20 16:15:20	2910	12.03	2.38	0.17	-0.04	5.02	1.82
03/10/20 16:15:50	2940	12.02	3.09	0.16	-0.03	5.02	1.78
03/10/20 16:16:20	2970	12.03	2.31	0.16	-0.04	5.02	1.76
03/10/20 16:16:50	3000	12.02	2.29	0.15	-0.04	5.02	1.77
03/10/20 16:17:20	3030	12.03	2.31	0.18	-0.05	5.02	1.85
03/10/20 16:17:50	3060	12.02	2.40	0.19	-0.05	5.03	1.83
03/10/20 16:18:20	3090	12.03	2.45	0.16	-0.05	5.03	1.81
03/10/20 16:18:50	3120	12.02	2.41	0.19	-0.04	5.02	1.75
03/10/20 16:19:20	3150	12.03	2.30	0.15	-0.04	5.03	1.72
03/10/20 16:19:50	3180	12.03	2.31	0.17	-0.04	5.03	1.69
03/10/20 16:20:20	3210	12.04	2.98	0.17	0.02	5.04	1.72
03/10/20 16:20:50	3240	12.04	2.55	0.20	-0.04	5.02	1.65
03/10/20 16:21:20	3270	12.02	2.45	0.16	-0.04	5.03	1.63
03/10/20 16:21:50	3300	12.02	2.33	0.18	-0.04	5.02	1.64
03/10/20 16:22:20	3330	12.03	2.58	0.17	-0.05	5.03	1.64
03/10/20 16:22:50	3360	12.03	2.33	0.17	-0.03	5.03	1.68
03/10/20 16:23:20	3390	12.03	2.50	0.18	-0.01	5.02	1.65
03/10/20 16:23:50	3420	12.02	2.35	0.18	-0.05	5.03	1.61
03/10/20 16:24:20	3450	12.03	2.37	0.17	-0.04	5.02	1.61
03/10/20 16:24:50	3480	12.02	2.31	0.17	-0.04	5.02	1.64
03/10/20 16:25:20	3510	12.02	2.62	0.27	-0.04	5.03	1.66
03/10/20 16:25:50	3540	12.03	2.66	0.16	-0.05	5.03	1.70
03/10/20 16:26:20	3570	12.02	2.36	0.14	-0.04	5.02	1.70
03/10/20 16:26:50	3600	12.03	2.37	0.09	-0.04	5.02	1.65
RAW AVERAGE		**12.04**	**2.43**	**0.17**	**-0.03**	**5.02**	**1.59**

		O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
Bias	**Initial Zero**	0.06	-0.05	0.03	0.02	0.04	
	Final Zero	0.07	0.09	-0.10	-0.04	0.00	
	Avg. Zero	0.07	0.02	-0.04	-0.01	0.02	
	Initial UpScale	11.96	4.86	5.05	3.40	8.80	
	Final UpScale	11.98	4.88	4.98	3.30	8.87	
	Avg. UpScale	11.97	4.87	5.02	3.35	8.83	
Upscale Cal Gas		12.00	4.91	5.09	3.37	8.94	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	12.07	2.44	0.21	0.00	5.07	1.70
Concentration (ppm@ 15%O_2)	N/A	1.63	0.14	0.00	N/A	1.14

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,639	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,011	Btu/SCF fuel
Turbine Fuel Flow	1,625	lb/min
Duct Burner Fuel Flow	171	lb/min
Total Fuel Flow	2,438,066	SCFH

Weather Data

Barometric Pressure	30.15	in. Hg
Relative Humidity	70	%
Ambient Temperature	49	°F
Specific Humidity	0.005086	lb H_2O / lb air

Unit Data

Unit Load	232.1	megawatts
Heat Input	2,465	MMBtu/hr
NH_3 Flow Rate	150	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,918,813	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/10/20 17:35:20	7710	12.00	2.33	0.13	-0.04	4.99	1.78
03/10/20 17:35:50	7740	12.00	2.34	0.09	0.03	4.99	1.70
03/10/20 17:36:20	7770	11.98	2.78	0.07	0.09	4.97	1.61
03/10/20 17:36:50	7800	12.02	2.92	0.13	0.00	4.98	1.59
03/10/20 17:37:20	7830	11.98	2.34	0.09	-0.03	4.98	1.53
03/10/20 17:37:50	7860	11.99	2.30	0.14	-0.02	4.98	1.52
03/10/20 17:38:20	7890	11.98	2.90	0.12	-0.02	4.98	1.47
03/10/20 17:38:50	7920	12.07	2.39	0.11	-0.04	4.98	1.46
03/10/20 17:39:20	7950	12.00	2.39	0.09	0.07	4.98	1.44
03/10/20 17:39:50	7980	12.01	2.54	0.16	0.03	4.98	1.40
03/10/20 17:40:20	8010	11.99	2.54	0.08	-0.02	5.00	1.40
03/10/20 17:40:50	8040	12.00	2.66	0.09	0.05	5.00	1.35
03/10/20 17:41:20	8070	11.99	2.43	0.07	0.09	5.00	1.33
03/10/20 17:41:50	8100	12.04	3.28	0.07	-0.02	5.01	1.30
03/10/20 17:42:20	8130	11.99	2.33	0.10	-0.02	5.01	1.31
03/10/20 17:42:50	8160	12.02	2.30	0.08	-0.02	5.00	1.32
03/10/20 17:43:20	8190	12.04	2.28	0.06	-0.04	5.00	1.33
03/10/20 17:43:50	8220	11.99	2.36	0.15	-0.01	5.00	1.36
03/10/20 17:44:20	8250	11.98	3.10	0.09	-0.01	5.02	1.33
03/10/20 17:44:50	8280	11.99	2.52	0.20	-0.04	5.01	1.37
03/10/20 17:45:20	8310	12.05	2.44	0.21	0.00	5.01	1.43
03/10/20 17:45:50	8340	12.02	3.17	0.12	-0.04	5.01	1.38
03/10/20 17:46:20	8370	12.00	3.19	0.19	0.03	5.01	1.34
03/10/20 17:46:50	8400	12.05	2.45	0.23	-0.04	5.01	1.37
03/10/20 17:47:20	8430	12.01	2.52	0.12	-0.03	5.00	1.36
03/10/20 17:47:50	8460	12.03	2.29	0.09	-0.04	5.01	1.36
03/10/20 17:48:20	8490	11.99	2.26	0.14	-0.04	5.02	1.38
03/10/20 17:48:50	8520	12.00	2.76	0.07	0.12	5.01	1.37
03/10/20 17:49:20	8550	12.03	2.78	0.17	-0.01	5.00	1.37
03/10/20 17:49:50	8580	12.02	2.38	0.08	-0.04	5.01	1.38
03/10/20 17:50:20	8610	11.99	2.47	0.08	-0.03	5.01	1.42
03/10/20 17:50:50	8640	12.00	2.34	0.11	-0.04	5.03	1.51
03/10/20 17:51:20	8670	12.00	2.37	0.08	-0.03	5.01	1.50
03/10/20 17:51:50	8700	12.00	2.35	0.11	-0.01	5.01	1.51
03/10/20 17:52:20	8730	11.99	2.34	0.07	-0.04	5.02	1.49
03/10/20 17:52:50	8760	12.00	3.18	0.23	0.03	5.02	1.53
03/10/20 17:53:20	8790	11.99	2.32	0.07	-0.04	5.00	1.55
03/10/20 17:53:50	8820	12.03	2.30	0.15	0.02	5.02	1.55
03/10/20 17:54:20	8850	12.01	2.29	0.12	0.01	5.02	1.55
03/10/20 17:54:50	8880	12.00	2.67	0.08	0.03	5.01	1.60
03/10/20 17:55:20	8910	12.06	2.69	0.16	0.06	5.00	1.67
03/10/20 17:55:50	8940	12.06	2.40	0.13	0.10	5.02	1.65
03/10/20 17:56:20	8970	12.00	2.31	0.08	0.00	5.01	1.61
03/10/20 17:56:50	9000	12.05	2.50	0.06	-0.03	5.01	1.62
03/10/20 17:57:20	9030	12.01	2.38	0.08	0.01	5.01	1.65
03/10/20 17:57:50	9060	12.02	2.67	0.23	-0.01	5.01	1.64
03/10/20 17:58:20	9090	12.00	2.58	0.30	0.10	5.01	1.61
03/10/20 17:58:50	9120	12.00	2.64	0.10	-0.04	5.01	1.56
03/10/20 17:59:20	9150	12.00	2.57	0.17	-0.03	5.01	1.53
03/10/20 17:59:50	9180	12.05	2.32	0.07	-0.01	5.01	1.60
03/10/20 18:00:20	9210	12.00	2.42	0.07	-0.04	5.02	1.58
03/10/20 18:00:50	9240	12.00	2.75	0.31	0.09	5.02	1.59
03/10/20 18:01:20	9270	12.04	2.42	0.09	-0.04	5.01	1.55
03/10/20 18:01:50	9300	12.02	3.47	0.13	-0.03	5.01	1.55
03/10/20 18:02:20	9330	12.01	2.75	0.10	-0.03	5.02	1.59
03/10/20 18:02:50	9360	12.00	2.33	0.08	-0.04	5.02	1.58
03/10/20 18:03:20	9390	12.01	2.33	0.16	-0.04	5.02	1.55
03/10/20 18:03:50	9420	12.00	2.41	0.08	0.00	5.01	1.64
03/10/20 18:04:20	9450	12.00	2.64	0.22	0.02	5.01	1.71
03/10/20 18:04:50	9480	12.01	3.32	0.09	-0.03	5.01	1.75
03/10/20 18:05:20	9510	12.01	2.82	0.14	0.02	5.01	1.77
03/10/20 18:05:50	9540	11.99	2.73	0.10	-0.03	5.01	1.74
03/10/20 18:06:20	9570	12.00	2.42	0.11	-0.04	5.02	1.78
03/10/20 18:06:50	9600	12.01	3.15	0.12	-0.04	5.00	1.80
03/10/20 18:07:20	9630	12.00	2.40	0.10	0.00	5.01	1.82
03/10/20 18:07:50	9660	11.99	2.39	0.18	-0.03	5.02	1.76
03/10/20 18:08:20	9690	12.00	3.47	0.22	0.26	5.01	1.71
03/10/20 18:08:50	9720	12.04	2.44	0.21	0.01	5.02	1.77
03/10/20 18:09:20	9750	12.01	2.40	0.09	-0.02	5.01	1.76
03/10/20 18:09:50	9780	12.00	2.42	0.11	0.02	5.01	1.73
03/10/20 18:10:20	9810	12.00	2.40	0.09	0.01	5.02	1.67
03/10/20 18:10:50	9840	12.01	2.34	0.16	-0.04	5.01	1.65
03/10/20 18:11:20	9870	12.01	2.52	0.16	-0.01	5.02	1.65
03/10/20 18:11:50	9900	12.01	2.57	0.10	-0.04	5.03	1.67
03/10/20 18:12:20	9930	12.00	2.36	0.08	-0.04	5.02	1.58
03/10/20 18:12:50	9960	12.00	2.76	0.13	-0.04	5.02	1.61
03/10/20 18:13:20	9990	11.99	2.59	0.07	-0.04	5.05	1.58

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,639	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,011	Btu/SCF fuel
Turbine Fuel Flow	1,625	lb/min
Duct Burner Fuel Flow	171	lb/min
Total Fuel Flow	2,438,066	SCFH

Weather Data

Barometric Pressure	30.15	in. Hg
Relative Humidity	70	%
Ambient Temperature	49	°F
Specific Humidity	0.005086	lb H_2O / lb air

Unit Data

Unit Load	232.1	megawatts
Heat Input	2,465	MMBtu/hr
NH_3 Flow Rate	150	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,918,813	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/10/20 18:13:50	10020	12.02	2.60	0.08	-0.04	5.04	1.57
03/10/20 18:14:20	10050	11.99	2.39	0.15	0.10	5.02	1.57
03/10/20 18:14:50	10080	12.02	2.48	0.10	-0.04	5.01	1.58
03/10/20 18:15:20	10110	12.01	2.57	0.08	-0.04	5.02	1.64
03/10/20 18:15:50	10140	12.00	2.62	0.08	0.00	5.02	1.63
03/10/20 18:16:20	10170	11.98	2.45	0.07	-0.02	5.02	1.57
03/10/20 18:16:50	10200	11.96	2.37	0.07	-0.03	5.02	1.59
03/10/20 18:17:20	10230	12.00	2.53	0.15	-0.04	4.97	1.64
03/10/20 18:17:50	10260	11.99	2.56	0.12	-0.03	4.97	1.65
03/10/20 18:18:20	10290	12.02	2.54	0.11	0.04	4.97	1.62
03/10/20 18:18:50	10320	12.02	2.53	0.13	-0.02	4.94	1.60
03/10/20 18:19:20	10350	12.00	2.93	0.22	0.02	4.93	1.60
03/10/20 18:19:50	10380	12.01	2.94	0.19	-0.02	4.92	1.62
03/10/20 18:20:20	10410	11.99	2.31	0.11	-0.02	4.94	1.61
03/10/20 18:20:50	10440	12.04	2.35	0.11	0.01	4.95	1.57
03/10/20 18:21:20	10470	12.01	2.46	0.09	-0.04	4.94	1.54
03/10/20 18:21:50	10500	12.03	2.51	0.17	-0.02	4.93	1.62
03/10/20 18:22:20	10530	12.01	2.87	0.07	-0.03	4.93	1.56
03/10/20 18:22:50	10560	12.01	3.30	0.14	0.03	4.94	1.56
03/10/20 18:23:20	10590	12.02	2.50	0.08	-0.02	4.94	1.55
03/10/20 18:23:50	10620	12.01	2.35	0.10	-0.04	4.95	1.54
03/10/20 18:24:20	10650	12.00	2.41	0.10	-0.04	4.95	1.66
03/10/20 18:24:50	10680	11.99	2.54	0.11	-0.04	4.97	1.63
03/10/20 18:25:20	10710	12.06	2.55	0.10	-0.03	5.01	1.63
03/10/20 18:25:50	10740	11.99	2.68	0.11	-0.01	5.02	1.61
03/10/20 18:26:20	10770	12.08	2.37	0.08	-0.04	5.02	1.65
03/10/20 18:26:50	10800	12.06	2.36	0.09	-0.02	5.02	1.68
03/10/20 18:27:20	10830	12.02	2.63	0.13	0.01	5.02	1.71
03/10/20 18:27:50	10860	12.00	2.43	0.09	-0.04	5.02	1.68
03/10/20 18:28:20	10890	12.01	2.37	0.25	-0.04	5.02	1.64
03/10/20 18:28:50	10920	12.01	2.38	0.08	-0.03	5.03	1.63
03/10/20 18:29:20	10950	12.00	2.84	0.09	-0.04	5.02	1.65
03/10/20 18:29:50	10980	11.99	2.90	0.10	0.01	5.02	1.65
03/10/20 18:30:20	11010	11.99	3.23	0.08	-0.03	5.02	1.69
03/10/20 18:30:50	11040	12.00	2.59	0.08	0.08	5.01	1.72
03/10/20 18:31:20	11070	12.25	2.47	0.06	-0.02	5.02	1.68
03/10/20 18:31:50	11100	12.25	2.60	0.10	-0.04	5.02	1.64
03/10/20 18:32:20	11130	12.01	2.33	0.13	-0.04	5.03	1.58
03/10/20 18:32:50	11160	11.99	2.33	0.18	-0.03	5.03	1.60
03/10/20 18:33:20	11190	11.99	2.30	0.13	0.17	5.02	1.63
03/10/20 18:33:50	11220	12.09	2.44	0.10	0.01	5.02	1.63
03/10/20 18:34:20	11250	11.99	2.80	0.18	-0.04	5.03	1.64
03/10/20 18:34:50	11280	12.00	2.47	0.10	0.02	5.02	1.60
RAW AVERAGE		**12.01**	**2.57**	**0.12**	**-0.01**	**5.00**	**1.57**

		O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
Bias	**Initial Zero**	0.07	0.09	-0.10	-0.04	0.00	
	Final Zero	0.08	0.06	-0.07	-0.04	-0.01	
	Avg. Zero	0.08	0.08	-0.09	-0.04	-0.01	
	Initial UpScale	11.98	4.88	4.98	3.30	8.87	
	Final UpScale	12.08	4.94	5.02	3.32	8.82	
	Avg. UpScale	12.03	4.91	5.00	3.31	8.84	
Upscale Cal Gas		12.00	4.91	5.09	3.37	8.94	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.98	2.53	0.21	0.00	5.06	1.69
Concentration (ppm@ 15%O_2)	N/A	1.68	0.14	0.00	N/A	1.12

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,639	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,011	Btu/SCF fuel
Turbine Fuel Flow	1,627	lb/min
Duct Burner Fuel Flow	174	lb/min
Total Fuel Flow	2,444,977	SCFH

Weather Data

Barometric Pressure	30.12	in. Hg
Relative Humidity	73	%
Ambient Temperature	46	°F
Specific Humidity	0.004740	lb H_2O / lb air

Unit Data

Unit Load	232.6	megawatts
Heat Input	2,472	MMBtu/hr
NH_3 Flow Rate	149	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,882,005	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/10/20 18:35:20	11310	12.00	2.45	0.15	-0.01	5.02	1.59
03/10/20 18:35:50	11340	11.99	2.35	0.10	-0.04	5.01	1.65
03/10/20 18:36:20	11370	12.00	2.89	0.09	-0.03	5.03	1.65
03/10/20 18:36:50	11400	11.99	2.67	0.23	0.03	5.02	1.64
03/10/20 18:37:20	11430	12.01	2.48	0.33	0.07	5.01	1.63
03/10/20 18:37:50	11460	12.00	2.49	0.07	-0.04	5.02	1.69
03/10/20 18:38:20	11490	12.03	2.41	0.17	-0.01	5.03	1.71
03/10/20 18:38:50	11520	12.00	2.76	0.10	-0.02	5.02	1.66
03/10/20 18:39:20	11550	12.00	3.11	0.16	-0.04	5.02	1.64
03/10/20 18:39:50	11580	12.00	2.91	0.14	-0.04	5.03	1.62
03/10/20 18:40:20	11610	12.07	2.86	0.09	-0.02	5.03	1.65
03/10/20 18:40:50	11640	12.00	2.35	0.10	0.00	5.03	1.67
03/10/20 18:41:20	11670	12.01	2.96	0.19	0.01	5.02	1.63
03/10/20 18:41:50	11700	12.04	2.88	0.22	-0.03	5.02	1.59
03/10/20 18:42:20	11730	12.02	2.52	0.10	-0.02	5.02	1.53
03/10/20 18:42:50	11760	12.01	2.55	0.11	-0.03	5.03	1.55
03/10/20 18:43:20	11790	12.00	2.37	0.08	-0.05	5.03	1.54
03/10/20 18:43:50	11820	12.03	2.78	0.17	-0.03	5.02	1.52
03/10/20 18:44:20	11850	12.01	2.46	0.08	-0.05	5.03	1.47
03/10/20 18:44:50	11880	11.99	2.49	0.09	-0.04	5.02	1.47
03/10/20 18:45:20	11910	12.06	2.91	0.07	-0.04	5.03	1.49
03/10/20 18:45:50	11940	12.00	2.48	0.09	-0.03	5.03	1.60
03/10/20 18:46:20	11970	12.00	2.49	0.11	-0.02	5.04	1.68
03/10/20 18:46:50	12000	12.01	2.53	0.21	-0.01	5.02	1.72
03/10/20 18:47:20	12030	11.99	2.43	0.13	-0.02	5.03	1.77
03/10/20 18:47:50	12060	12.00	2.44	0.11	0.09	5.03	1.82
03/10/20 18:48:20	12090	12.02	3.69	0.11	-0.04	5.02	1.87
03/10/20 18:48:50	12120	11.99	2.47	0.08	-0.04	5.02	1.83
03/10/20 18:49:20	12150	12.00	2.87	0.20	0.01	5.02	1.82
03/10/20 18:49:50	12180	11.99	2.47	0.08	-0.04	5.02	1.84
03/10/20 18:50:20	12210	11.99	2.79	0.10	0.03	5.04	1.79
03/10/20 18:50:50	12240	11.99	2.43	0.08	-0.04	5.04	1.76
03/10/20 18:51:20	12270	11.98	2.49	0.17	0.01	5.03	1.71
03/10/20 18:51:50	12300	12.00	2.52	0.07	0.13	5.04	1.70
03/10/20 18:52:20	12330	11.99	2.45	0.09	-0.04	5.03	1.71
03/10/20 18:52:50	12360	11.98	2.34	0.09	-0.04	5.04	1.64
03/10/20 18:53:20	12390	11.96	2.38	0.09	0.03	5.04	1.60
03/10/20 18:53:50	12420	11.96	2.41	0.27	0.11	5.05	1.58
03/10/20 18:54:20	12450	11.98	2.51	0.18	0.10	5.04	1.61
03/10/20 18:54:50	12480	11.97	2.51	0.12	0.01	5.04	1.60
03/10/20 18:55:20	12510	12.03	2.84	0.19	-0.03	5.04	1.61
03/10/20 18:55:50	12540	11.99	2.88	0.19	0.05	5.04	1.60
03/10/20 18:56:20	12570	12.00	2.50	0.14	-0.04	5.03	1.63
03/10/20 18:56:50	12600	11.99	2.36	0.16	-0.04	5.04	1.63
03/10/20 18:57:20	12630	11.98	2.72	0.08	-0.04	5.04	1.70
03/10/20 18:57:50	12660	11.99	2.42	0.12	-0.04	5.04	1.67
03/10/20 18:58:20	12690	11.99	2.79	0.12	-0.02	5.04	1.69
03/10/20 18:58:50	12720	11.99	2.34	0.10	-0.04	5.06	1.74
03/10/20 18:59:20	12750	11.99	2.40	0.25	0.03	5.04	1.75
03/10/20 18:59:50	12780	11.99	2.98	0.28	-0.03	5.03	1.74
03/10/20 19:00:20	12810	12.02	3.64	0.28	0.05	5.01	1.69
03/10/20 19:00:50	12840	11.99	2.38	0.14	-0.01	5.03	1.68
03/10/20 19:01:20	12870	11.98	2.88	0.18	-0.04	5.02	1.74
03/10/20 19:01:50	12900	12.02	2.61	0.36	-0.02	5.03	1.76
03/10/20 19:02:20	12930	11.99	2.44	0.20	0.04	5.04	1.74
03/10/20 19:02:50	12960	12.01	3.26	0.19	-0.03	5.04	1.70
03/10/20 19:03:20	12990	12.02	2.61	0.26	-0.01	5.03	1.72
03/10/20 19:03:50	13020	11.98	3.53	0.11	-0.02	5.04	1.69
03/10/20 19:04:20	13050	11.99	2.79	0.11	0.01	5.04	1.68
03/10/20 19:04:50	13080	11.97	2.39	0.08	0.02	5.04	1.65
03/10/20 19:05:20	13110	11.98	3.15	0.10	-0.04	5.05	1.67
03/10/20 19:05:50	13140	11.98	2.43	0.11	-0.04	5.05	1.72
03/10/20 19:06:20	13170	11.99	2.86	0.09	-0.02	5.04	1.75
03/10/20 19:06:50	13200	11.98	2.38	0.29	-0.04	5.04	1.73
03/10/20 19:07:20	13230	12.02	3.63	0.10	-0.04	5.04	1.69
03/10/20 19:07:50	13260	11.99	2.52	0.11	-0.02	5.03	1.68
03/10/20 19:08:20	13290	11.99	2.57	0.14	-0.04	5.04	1.70
03/10/20 19:08:50	13320	11.99	2.78	0.15	-0.04	5.03	1.70
03/10/20 19:09:20	13350	11.97	2.49	0.08	-0.04	5.03	1.68
03/10/20 19:09:50	13380	11.98	2.76	0.08	-0.02	5.04	1.64
03/10/20 19:10:20	13410	11.98	2.41	0.10	0.02	5.03	1.66
03/10/20 19:10:50	13440	11.99	2.47	0.11	-0.03	5.03	1.70
03/10/20 19:11:20	13470	11.98	2.34	0.09	-0.03	5.03	1.71
03/10/20 19:11:50	13500	12.03	2.74	0.19	-0.01	5.03	1.68
03/10/20 19:12:20	13530	12.00	2.38	0.12	0.13	5.03	1.70
03/10/20 19:12:50	13560	11.99	2.71	0.14	0.12	5.03	1.76
03/10/20 19:13:20	13590	11.98	3.08	0.10	0.02	5.03	1.80

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,639	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,011	Btu/SCF fuel
Turbine Fuel Flow	1,627	lb/min
Duct Burner Fuel Flow	174	lb/min
Total Fuel Flow	2,444,977	SCFH

Weather Data

Barometric Pressure	30.12	in. Hg
Relative Humidity	73	%
Ambient Temperature	46	°F
Specific Humidity	0.004740	lb H_2O / lb air

Unit Data

Unit Load	232.6	megawatts
Heat Input	2,472	MMBtu/hr
NH_3 Flow Rate	149	lb/hr
Meas. Stack Moisture	6.7	%
Stack Exhaust Flow (M19)	49,882,005	SCFH

Data from: From PM Run PM U-00001 Base+DB-2

Base+Db Load, Run - 2-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
03/10/20 19:13:50	13620	11.98	2.86	0.11	-0.04	5.04	1.76
03/10/20 19:14:20	13650	11.98	3.01	0.12	-0.04	5.04	1.69
03/10/20 19:14:50	13680	11.97	2.49	0.24	-0.01	5.04	1.67
03/10/20 19:15:20	13710	11.98	2.34	0.10	-0.04	5.04	1.78
03/10/20 19:15:50	13740	11.97	2.37	0.10	0.03	5.03	1.85
03/10/20 19:16:20	13770	11.99	2.56	0.20	-0.03	5.04	1.89
03/10/20 19:16:50	13800	11.97	2.45	0.15	-0.02	5.04	1.91
03/10/20 19:17:20	13830	11.99	2.56	0.16	-0.04	5.04	1.85
03/10/20 19:17:50	13860	11.99	2.38	0.12	-0.04	5.04	1.86
03/10/20 19:18:20	13890	11.97	2.62	0.08	0.04	5.04	1.83
03/10/20 19:18:50	13920	11.98	2.33	0.08	-0.05	5.04	1.79
03/10/20 19:19:20	13950	11.98	2.32	0.08	-0.04	5.03	1.77
03/10/20 19:19:50	13980	11.98	2.40	0.08	-0.04	5.03	1.82
03/10/20 19:20:20	14010	11.99	2.33	0.27	0.07	5.04	1.84
03/10/20 19:20:50	14040	11.99	3.01	0.12	-0.03	5.04	1.84
03/10/20 19:21:20	14070	11.98	2.87	0.11	-0.03	5.04	1.81
03/10/20 19:21:50	14100	11.98	2.36	0.12	0.01	5.04	1.81
03/10/20 19:22:20	14130	12.01	2.91	0.09	0.03	5.04	1.83
03/10/20 19:22:50	14160	11.98	2.40	0.18	-0.04	5.04	1.80
03/10/20 19:23:20	14190	11.99	2.88	0.16	0.00	5.05	1.73
03/10/20 19:23:50	14220	11.98	2.83	0.14	-0.04	5.05	1.74
03/10/20 19:24:20	14250	11.99	2.98	0.08	-0.04	5.05	1.76
03/10/20 19:24:50	14280	12.02	3.36	0.18	0.03	5.04	1.74
03/10/20 19:25:20	14310	12.00	3.02	0.09	-0.05	5.05	1.69
03/10/20 19:25:50	14340	12.01	2.42	0.26	-0.03	5.04	1.71
03/10/20 19:26:20	14370	11.99	2.38	0.15	-0.04	5.03	1.73
03/10/20 19:26:50	14400	11.98	2.41	0.10	0.03	5.04	1.71
03/10/20 19:27:20	14430	11.99	3.29	0.10	-0.04	5.04	1.73
03/10/20 19:27:50	14460	11.98	2.83	0.20	-0.01	5.04	1.72
03/10/20 19:28:20	14490	12.00	2.51	0.12	-0.04	5.04	1.72
03/10/20 19:28:50	14520	11.99	2.51	0.10	0.01	5.03	1.72
03/10/20 19:29:20	14550	11.98	2.39	0.38	-0.04	5.03	1.73
03/10/20 19:29:50	14580	11.99	2.34	0.11	0.01	5.04	1.68
03/10/20 19:30:20	14610	12.02	2.79	0.11	0.07	5.04	1.72
03/10/20 19:30:50	14640	11.98	2.42	0.13	-0.04	5.04	1.77
03/10/20 19:31:20	14670	12.00	2.92	0.22	-0.04	5.04	1.82
03/10/20 19:31:50	14700	11.97	2.81	0.11	-0.04	5.04	1.79
03/10/20 19:32:20	14730	12.01	2.58	0.11	-0.04	5.04	1.78
03/10/20 19:32:50	14760	11.99	2.43	0.08	-0.04	5.04	1.78
03/10/20 19:33:20	14790	12.00	3.21	0.17	-0.04	5.03	1.77
03/10/20 19:33:50	14820	11.98	3.02	0.27	-0.04	5.03	1.81
03/10/20 19:34:20	14850	12.00	2.45	0.18	0.00	5.04	1.73
03/10/20 19:34:50	14880	11.98	2.41	0.08	-0.04	5.04	1.69
RAW AVERAGE		**11.99**	**2.66**	**0.14**	**-0.01**	**5.03**	**1.71**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.08	0.06	-0.07	-0.04	-0.01	
Bias	**Final Zero**	0.07	0.06	-0.06	-0.04	-0.03	
Bias	**Avg. Zero**	0.08	0.06	-0.07	-0.04	-0.02	
Bias	**Initial UpScale**	12.08	4.94	5.02	3.32	8.82	
Bias	**Final UpScale**	12.01	5.17	5.03	3.21	8.94	
Bias	**Avg. UpScale**	12.04	5.06	5.03	3.27	8.88	
Upscale Cal Gas		12.00	4.91	5.09	3.37	8.94	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.95	2.55	0.21	0.00	5.08	1.83
Concentration (ppm@ 15%O_2)	N/A	1.68	0.14	0.00	N/A	1.21

Non-Bias Adjusted Averages Include: *

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#2	
Operator		Rob White	
Date for Preliminary Run	(mm/dd/yy)	03/10/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		U-00002	
Base Run Number		PM U-00002 Base+DB	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	03/10/20	03/11/20	03/11/20	
Load		Base+DB	Base+DB	Base+DB	% or w/DB
Fuel F-Factor		8638.67	8636.30	8636.30	dscf/MMBtu
Meter Box Number	from ACS	Samp-cp-0030	Samp-cp-0030	Samp-cp-0030	
Meter Calibration Factor	(Y)	0.974	0.974	0.974	
Orifice Meter Coefficient	($\Delta H_@$)	1.878	1.878	1.878	in H_2O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	4187/10	4187/10	4187/10	
Pitot Tube Coefficient	(C_p)	0.7240	0.7240	0.7240	
Nozzle Number	from ACS	4b	4b	4b	must match cyc nozz tab (e.g. 3a, 4b, etc.)
Nozzle Diameter	(D_n)	0.156	0.156	0.156	in
Probe Number	from ACS	SAMP-PR-0133	SAMP-PR-0133	SAMP-PR-0133	
Probe Length		120.0	120.0	120.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039	
Impinger Case Number	from ACS	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	03/10/20
Sampling Location	U-00002 Base+DB	**Stack Type**	Circular
Operator	Rob White	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	4
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

○ Method 1 Trav

◉ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
4	**Ports by**	3	**Across**
12	**Pts Used**	12	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.044	10	18
2	0.146	33 2/8	41 2/8
3	0.296	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Cricket Valley Energy Center			
Sampling Location	U-00002 Base+DB			
Operator	Rob White			
Project #	bec-19-cricketvalley.ny-start#2			
Pitot Leak Check	x	**PreTest**	x	**PostTest**

Preliminary Run Date	03/10/20		
Stack Type	Circular		
Ports Available	4		
Thermocouple ID	SAMP-PR-0133		
Pitot Coefficient	0.8198	**Pitot Identification**	A4187

RM 201A or OTM 27 Blckag.	**RM 201A or OTM 27 Pitot Coeff.**
5.39E-04	0.7240

Stack Dimensions			
Area of Stack	(A_s)	283.53	ft²
Diameter of Stack	(D)	228.00	in

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.07	in Hg

Stack Gas Composition			
Composition Data:	**Estimated Composition**		
Carbon Dioxide Concentration	($\%CO_2$)	11.90	%vd
Oxygen Concentration	($\%O_2$)	5.20	%vd
Carbon Monoxide Concentration	(ppmCO)	0.00	ppmvd
Nitrogen Concentration	($\%N_2$)	82.90	%vd
Stack Moisture Content	(B_{ws})	8.00	%
Stack Dry Molecular Weight	(M_d)	30.11	lb/lb-mole
Stack Wet Molecular Weight	(M_w)	29.14	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v_s)	52.41	ft/sec
Avg Stack Dry Std Flow Rate	(Q_{sd})	40,756,962	dscf/hr
Avg Stack Dry Std Flow Rate	(Q_{sd})	679,283	dscf/min
Avg Stack Wet Flow Rate	(Q_{aw})	891,531	acf/min
Avg Stack Wet Std Flow Rate	(Q_{sw})	44,301,046	ascf/hr

40 CFR 60, Method 2G, Section 8.11.1 (but applies to all Method 2 type static pressure measurements):
If a Type S probe is used for this measurement, position the probe at or between any traverse point(s) and rotate the probe until a null differential pressure reading is obtained. Disconnect the tubing from one of the pressure ports; read and record the ΔP. For pressure devices with one-directional scales, if a deflection in the positive direction is noted with the negative side disconnected, then the static pressure is positive. Likewise, if a deflection in the positive direction is noted with the positive side disconnected, then the static pressure is negative.

Stack Cross Section Schematic

Velocity Traverse Data							
Run Number		PM U-00002 Base+DB-V1					
Run Time		13:08	**Start**	13:24	**End**		
Traverse Point	**Velocity Head** (Δp)	**Null Angle** (N_a)	**Zero Deg Pressure** ($0°_a$)	**Stack Temp** (t_s)	**Local Velocity** ($v_{s(l)}$)	**Adjusted Velocity Pressure**	**Adjusted Velocity Pressure w/BF, if app**
	in H_2O	deg	in H_2O	°F	ft/sec	in H_2O	in H_2O
A-1	1.30	0	0.00	186	68.60	1.01	1.01
A-2	1.20	-5	0.15	185	65.86	0.94	0.94
A-3	1.10	0	0.00	183	62.96	0.86	0.86
B-1	1.30	0	0.00	182	68.39	1.01	1.01
B-2	1.30	-5	0.11	182	68.39	1.01	1.01
B-3	1.20	0	0.00	180	65.60	0.94	0.94
C-1	1.30	0	0.00	180	68.28	1.01	1.01
C-2	1.40	0	0.00	179	70.81	1.09	1.09
C-3	1.20	0	0.00	178	65.50	0.94	0.94
D-1	1.30	0	0.00	177	68.12	1.01	1.01
D-2	1.30	0	0.00	179	68.23	1.01	1.01
D-3	1.20	-5	0.14	179	65.55	0.94	0.94
Average	1.26	1		181		0.98	0.98
	1.12	**= Square roots of Δp**					0.99
Standard deviation of null angles =				2.3			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	PM U-00002 Base+DB-4	PM U-00002 Base+DB-5	PM U-00002 Base+DB-6	
Carbon Dioxide Content	11.9	5.3	5.3	5.3				%
Oxygen Content	5.2	11.7	11.7	11.7				%
Stack Moisture Content	8.0	9.2	10.3	10.0				%
Nitrogen plus CO Content	82.9	83.0	83.0	83.0				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H_2O)	Min.	0.86	Max.	1.09

Stack and Equipment Information	Prelim	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	PM U-00002 Base+DB-4	PM U-00002 Base+DB-5	PM U-00002 Base+DB-6	
Barometric Pressure	30.14	30.14	30.12	30.11				in Hg
Stack Static Pressure	-0.89	-0.89	-0.89	-0.89				in H_2O
Absolute Stack Pressure	30.07	30.07	30.05	30.04				in Hg
Average Stack Temp	181	189	182	181				0.00
Average Stack Temp	641	649	642	641				°R
Average Meter Temp	85	87	81	83				0.00
Orifice Meter Coefficient	1.878	1.878	1.878	1.878				in H_2O
Pitot Coefficient	0.724	0.724	0.724	0.724				
Stack Dry Molecular Weight	30.11	29.32	29.31	29.31				lb/lb mole
Stack Wet Molecular Weight	29.14	28.28	28.15	28.18				lb/lb mole
Stack Viscosity	195.85	200.23	197.41	197.64				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.08							
Cunningham Correction Factor, for a 2.5 µm particle		1.07	1.07	1.07				
Prelim Cut Dia., Cyclone I, D_{50LL}, N_{re}<3162	10.35	2.42	2.28	2.36				µm
Middle Zone Dia., Cyclone I, D_{50T}, N_{re}<3162	10.67							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.), N_{re}<3162	0.46							dscfm
Reynolds Number, Cyc I & IV, N_{re}<3162	2788.06	2692.23	2834.63	2759.69				
Dia. of 50% Prob. (D_{50}) Cyc IV (N_{re}<3162)	2.37	2.42	2.29	2.36				µm
Sampling Rate, Cyc IV, N_{re}<3,162	0.46							dscfm
Reynolds Number, Cyc IV, N_{re}<3162	2788.01	2692.23	2834.63	2759.69				
Prelim Cut Dia., Cyclone I, $D_{50LL\geq3162}$	10.63							µm
Middle Zone Dia., Cyclone I, $D_{50T\geq3162}$	10.82							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.)≥3162	0.45							dscfm
Reynolds Number, Cyc I & IV, N_{re}≥3162	2736.91							
Dia. of 50% Prob. (D_{50}) CIV (N_{re}≥3162)	2.29							µm
Sampling Rate, Cyc IV, N_{re}≥3,162	4.54							dscfm
Reynolds Number ≥ 3162	27369.31							
Cyclone Flow Rate	0.46	0.48	0.49	0.48				ft³/min
Recalculated D_{50-1} for C_{IV}		2.42	2.28	2.36				
Recalculated Cunninham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		98.77	100.19	98.57				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.156	0.156	0.156				in

Orifice Head and Nozzle Selection Calculation											
Nozzle No.	2a	2b	3a	3b	4a	4b	5a	5b	6a	6b	7a
Nozzle diameter, D_n, in.	0.119	0.130	0.130	0.143	0.155	0.156	0.175	0.172	0.197	0.192	0.212
Nozzle velocity, v_n, ft/sec	99.71	83.55	83.55	69.05	59.03	58.02	46.11	47.73	36.38	38.30	31.42
R_{min}	0.77	0.76	0.76	0.74	0.73	0.72	0.69	0.70	0.63	0.65	0.58
v_{min}, ft/sec	76.54	63.28	63.28	51.27	42.86	42.01	31.77	33.18	23.00	24.78	18.16
R_{max}	1.22	1.23	1.23	1.24	1.25	1.25	1.27	1.27	1.30	1.29	1.32
v_{max}, ft/sec	121.92	102.73	102.73	85.56	73.73	72.55	58.56	60.46	47.24	49.46	41.50
Δp_{min}, in. H_2O @ $t_{s-50}o_F$	2.27	1.55	1.55	1.02	0.71	0.68	0.39	0.43	0.20	0.24	0.13
Δp_{min}, in. H_2O @ t_s	2.09	1.43	1.43	0.94	0.66	0.63	0.36	0.39	0.19	0.22	0.12
Δp_{max}, in. H_2O @ t_s	5.31	3.77	3.77	2.61	1.94	1.88	1.22	1.31	0.80	0.87	0.61
Δp_{min}, in. H_2O @ $t_{s+50}o_F$	4.92	3.50	3.50	2.42	1.80	1.74	1.14	1.21	0.74	0.81	0.57
ΔH, in. H_2O @ t_s+50°F	0.379										
ΔH, in. H_2O @ t_s	**0.441**										
ΔH, in. H_2O @ t_s-50°F	0.519										

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/10/20		
Sampling Location	U-00002 Base+DB	**Operator**	Rob White		
Project #	bec-19-cricketvalley.ny-start#2	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	PM U-00002 Base+DB-1		**Date**	03/10/20	**Run Start Time**	14:12	**Run Stop Time**	18:40
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:28	5.3	11.7	0.0	83.0	29.32	1.740	114.1	YES

Gas Analysis Data

Run Number	PM U-00002 Base+DB-2		**Date**	03/11/20	**Run Start Time**	06:23	**Run Stop Time**	11:17
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:54	5.3	11.7	0.0	83.0	29.31	1.742	113.9	YES

Gas Analysis Data

Run Number	PM U-00002 Base+DB-3		**Date**	03/11/20	**Run Start Time**	12:30	**Run Stop Time**	17:15
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:45	5.3	11.7	0.0	83.0	29.31	1.746	114.0	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/10/20
Sampling Location	U-00002 Base+DB	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Preliminary Date	03/10/20	500	499.7	-0.3	Pass
Test Day 1	03/11/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		PM U-00002 Base+DB-1		**Date**	03/10/20	**Start Time**	14:12	**Stop Time**	18:40
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	101.590	dcf		**Barometric Pressure**	(P_b)	30.14	in Hg
Average Stack Temp		$(t_s)_{avg}$	189	°F		**Stack Static Pressure**	(P_{static})	-0.89	in H_2O
Average Meter Temp		$(t_m)_{avg}$	87	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.44	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	515.40	590.10	777.00	868.30				
Initial Value	(V_i),(W_i)	358.70	590.10	747.40	848.50				
Net Value	(V_n),(W_n)	156.7	0.0	29.6	19.8				
Results									
Total Weight		(W_t)	206.10	g		**Water Vol Weighed**	$(V_{wsg(std)})$	9.718	scf
Std Meter Volume		$(V_{m(std)})$	96.288	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	61.77	%
Calc Moisture Content		$(B_{ws(calc)})$	9.17	%		**Final Moisture Content**	(B_{ws})	9.17	%

Moisture Content Data									
Run Number		PM U-00002 Base+DB-2		**Date**	03/11/20	**Start Time**	06:23	**Stop Time**	11:17
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	105.540	dcf		**Barometric Pressure**	(P_b)	30.12	in Hg
Average Stack Temp		$(t_s)_{avg}$	182	°F		**Stack Static Pressure**	(P_{static})	-0.89	in H_2O
Average Meter Temp		$(t_m)_{avg}$	81	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.44	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	569.60	597.00	687.40	912.10				
Initial Value	(V_i),(W_i)	373.70	596.80	658.00	891.60				
Net Value	(V_n),(W_n)	195.9	0.2	29.4	20.5				
Results									
Total Weight		(W_t)	246.00	g		**Water Vol Weighed**	$(V_{wsg(std)})$	11.599	scf
Std Meter Volume		$(V_{m(std)})$	101.167	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	52.49	%
Calc Moisture Content		$(B_{ws(calc)})$	10.29	%		**Final Moisture Content**	(B_{ws})	10.29	%

Moisture Content Data									
Run Number		PM U-00002 Base+DB-3		**Date**	03/11/20	**Start Time**	12:30	**Stop Time**	17:15
Meter Box Number		Samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	102.600	dcf		**Barometric Pressure**	(P_b)	30.11	in Hg
Average Stack Temp		$(t_s)_{avg}$	181	°F		**Stack Static Pressure**	(P_{static})	-0.89	in H_2O
Average Meter Temp		$(t_m)_{avg}$	83	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.44	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	540.00	589.30	806.30	888.80				
Initial Value	(V_i),(W_i)	359.10	589.50	777.00	868.30				
Net Value	(V_n),(W_n)	180.9	-0.2	29.3	20.5				
Results									
Total Weight		(W_t)	230.50	g		**Water Vol Weighed**	$(V_{wsg(std)})$	10.868	scf
Std Meter Volume		$(V_{m(std)})$	97.841	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	52.31	%
Calc Moisture Content		$(B_{ws(calc)})$	10.00	%		**Final Moisture Content**	(B_{ws})	10.00	%

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Date	03/10/20
Operator	Rob White
Run Number	PM U-00002 Base+DB-1

Filter #
19031837
PM U-00002 Base+DB-1-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	189.0	°F
Average Meter Temp	(t_m)	87.2	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.12	in H_2O
Stack Moisture Content	(B_{ws})	9.17	%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.35	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.00	in H_2O	3.4	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.00	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
	Post (+)	0.00	in H_2O	3.6	in H_2O for	15.0	sec [≥15]
	Post (-)	0.00	in H_2O	4.0	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.2187	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Stack Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.07	in Hg
Absolute Meter Pressure	(P_m)	30.28	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	14:12	**End**	18:40

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	358.7	590.1	747.4	848.5				
Post	515.4	590.1	777.0	868.3				

Wash Volumes						ml
						ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	675.750	1.30	0.441	0.44	187	245	251	64	76	73	78	78	3.5	1.14	61.55	8.483	101.0	100.411
A-2	23.0	00:23:00	684.550	1.20	0.441	0.44	188	250	252	65	77	76	81	81	3.5	1.10	59.18	15.816	97.8	95.159
A-3	45.3	00:45:15	692.200	1.20	0.441	0.44	186	250	248	66	78	78	82	82	3.5	1.10	59.09	23.902	99.7	96.403
B-1	67.5	01:07:30	700.650	1.30	0.441	0.44	188	254	250	65	77	78	86	86	3.5	1.14	61.60	31.614	97.8	95.105
B-2	90.5	01:30:30	708.770	1.10	0.441	0.44	187	248	251	62	78	79	88	88	3.5	1.05	56.62	38.504	97.6	93.804
B-3	111.8	01:51:45	716.050	1.30	0.441	0.44	189	248	254	64	75	77	90	90	3.5	1.14	61.65	46.424	97.1	93.796
C-1	134.8	02:14:45	724.450	1.30	0.441	0.44	190	250	251	65	76	77	89	89	3.5	1.14	61.70	54.605	97.2	94.239
C-2	157.8	02:37:45	733.110	1.40	0.441	0.44	191	253	255	66	77	78	91	91	3.5	1.18	64.07	64.262	98.6	96.260
C-3	181.8	03:01:45	743.370	1.30	0.441	0.44	190	256	251	63	71	75	91	91	3.5	1.14	61.70	72.507	98.6	96.410
D-1	204.8	03:24:45	752.130	1.20	0.441	0.44	191	254	251	64	72	73	90	90	3.5	1.10	59.32	80.559	99.1	96.618
D-2	227.0	03:47:00	760.670	1.20	0.441	0.44	190	252	250	63	74	76	90	90	4.0	1.10	59.28	87.980	98.7	96.099
D-3	249.3	04:09:15	768.540	1.30	0.441	0.44	191	251	250	66	76	77	90	90	4.0	1.14	61.74	96.278	98.8	96.278
Last Pt	272.3	04:32:15	777.340																	
Final Val	272.3	04:32:15	777.340											**Max Vac**	4.0	**Final Values**		96.278	98.8	
Average Values				1.26		0.44	189	251	251	64	76	76	87	87		1.12	60.63			
													87							

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.35	8.483	101.0	857.1
0.156	0.35	7.333	94.0	689.7
0.156	0.35	8.085	103.5	837.1
0.156	0.35	7.713	91.9	709.1
0.156	0.35	6.890	96.6	665.2
0.156	0.35	7.921	94.5	748.4
0.156	0.35	8.181	97.7	798.9
0.156	0.35	9.657	106.5	1028.9
0.156	0.35	8.245	98.4	811.6
0.156	0.35	8.053	103.5	833.5
0.156	0.35	7.421	95.3	707.3
0.156	0.35	8.298	99.1	822.6
0.156	0.35	96.278		

RM 201A Calculations					
Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**	
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Prelim. Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
23.00	23.03	1.30		1.30	0
22.25	22.13	1.20	22.13	1.20	0
22.25	22.13	1.20	22.13	1.20	0
23.00	23.03	1.30		1.30	0
21.25	21.18	1.10	21.18	1.10	0
23.00	23.03	1.30	23.03	1.30	0
23.00	23.03	1.30		1.30	0
24.00	23.90	1.40	23.90	1.40	0
23.00	23.03	1.30	23.03	1.30	0
22.25	22.13	1.20		1.20	0
22.25	22.13	1.20	22.13	1.20	0
23.00	23.03	1.30	23.03	1.30	0

Notes:

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	200.23	μP
	Cyclone Flow Rate (Q_a)	0.48	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.71	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{re}<3162)	10.25	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.63	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.42	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}<3162)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2692.23	
	Actual Particle Cut Diameter for CI	10.71	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.42	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.42	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	98.77	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.630	in H_2O
	Δp_{max}	1.879	in H_2O

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Date	03/11/20
Operator	Rob White
Run Number	PM U-00002 Base+DB-2

Filter #
19031838
PM U-00002 Base+DB-2-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	181.5	°F
Average Meter Temp	(t_m)	80.7	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.14	in H_2O
Stack Moisture Content	(B_{ws})	10.29	%
Stack Dry Molecular Weight	(M_d)	29.31	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.35	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.35	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
Pitot	**Pre (+)**	0.000	in H_2O	3.2	in H_2O for	15.0	sec ≥15]
PASS	**Pre (-)**	0.000	in H_2O	3.5	in H_2O for	15.0	sec ≥15]
	Post (+)	0.000	in H_2O	3.4	in H_2O for	15.0	sec ≥15]
	Post (-)	0.000	in H_2O	4.1	in H_2O for	15.0	sec ≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1497	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.12	in Hg
Stack Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.05	in Hg
Absolute Meter Pressure	(P_m)	30.26	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	06:23	**End**	11:17

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	373.7	596.8	658.0	891.6				
Post	569.6	597.0	687.4	912.1				

Wash Volumes					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1026	8082	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	778.770	1.30	0.441	0.44	183	250	250	42	58	72	67	67	3.5	1.14	61.52	8.162	97.9	98.570
A-2	23.0	00:23:00	787.070	1.20	0.441	0.44	181	252	260	42	41	70	71	71	3.5	1.10	59.02	16.019	99.6	98.329
A-3	45.3	00:45:15	795.120	1.40	0.441	0.44	182	253	261	42	42	72	75	75	3.5	1.18	63.79	25.474	101.5	102.172
B-1	69.3	01:09:15	804.880	1.30	0.441	0.44	181	251	248	45	47	71	81	81	4.0	1.14	61.43	33.473	100.1	100.782
B-2	92.3	01:32:15	813.230	1.30	0.441	0.44	182	250	251	45	48	72	81	81	4.0	1.14	61.47	42.296	101.3	101.933
B-3	115.3	01:55:15	822.440	1.40	0.441	0.44	182	252	248	45	49	70	81	81	4.0	1.18	63.79	51.263	100.9	102.250
C-1	139.3	02:19:15	831.800	1.30	0.441	0.44	179	251	249	47	45	71	80	80	4.0	1.14	61.33	59.766	101.1	102.312
C-2	162.3	02:42:15	840.660	1.20	0.441	0.44	182	253	250	47	46	72	83	83	4.0	1.10	59.06	67.068	100.3	100.965
C-3	184.5	03:04:30	848.310	1.30	0.441	0.44	181	254	251	48	48	73	84	84	4.0	1.14	61.43	75.937	101.0	101.646
D-1	207.5	03:27:30	857.620	1.40	0.441	0.44	181	255	253	50	51	73	87	87	4.0	1.18	63.74	84.616	100.5	101.521
D-2	231.5	03:51:30	866.780	1.40	0.441	0.44	183	249	252	51	52	74	89	89	4.0	1.18	63.84	93.424	100.2	101.560
D-3	255.5	04:15:30	876.110	1.20	0.441	0.44	181	250	251	52	54	75	89	89	4.0	1.10	59.02	101.165	100.2	101.165
Last Pt	277.8	04:37:45	884.310																	
Final Val	277.8	04:37:45	884.310											**Max Vac**	4.0	**Final Values**		101.165	100.2	
Average Values				1.31		0.44	182	252	252	46	48	72	81	81		1.14	61.62			
													81							

Actual Actual Nozzle Diameter (D_{na})	**DP to DP to DH Iso Factor (K)**	**Point-by-point Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.35	8.162	97.9	799.4
0.156	0.35	7.857	101.3	795.7
0.156	0.35	9.455	104.7	989.7
0.156	0.35	7.999	95.8	766.6
0.156	0.35	8.823	105.8	933.3
0.156	0.35	8.967	99.3	890.2
0.156	0.35	8.503	101.7	864.9
0.156	0.35	7.302	94.2	687.7
0.156	0.35	8.870	106.3	942.5
0.156	0.35	8.679	96.0	833.3
0.156	0.35	8.808	97.6	859.6
0.156	0.35	7.741	99.8	772.4
0.156	0.35	101.165		

RM 201A Calculations					
Trav. Point Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point First Point Dwell Times (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
23.00	23.03	1.30		1.30	0
22.25	22.13	1.20	22.13	1.20	0
24.00	23.90	1.40	23.90	1.40	0
23.00	23.03	1.30		1.30	0
23.00	23.03	1.30	23.03	1.30	0
24.00	23.90	1.40	23.90	1.40	0
23.00	23.03	1.30		1.30	0
22.25	22.13	1.20	22.13	1.20	0
23.00	23.03	1.30	23.03	1.30	0
24.00	23.90	1.40		1.40	0
24.00	23.90	1.40	23.90	1.40	0
22.25	22.13	1.20	22.13	1.20	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	197.41	μP
	Cyclone Flow Rate (Q_s)	0.49	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.36	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.28	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.64	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.47	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.28	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2834.63	
	Actual Particle Cut Diameter for CI	10.36	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.29	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.28	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	100.19	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.630	in H_2O
	Δp_{max}	1.879	in H_2O

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Date	03/11/20
Operator	Rob White
Run Number	PM U-00002 Base+DB-3

Filter #
19031825
PM U-00002 Base+DB-3-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7240	4187/10
Average Stack Temp	(t_s)	181.3	°F
Average Meter Temp	(t_m)	83.3	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.13	in H_2O
Stack Moisture Content	(B_{ws})	10.00	%
Stack Dry Molecular Weight	(M_d)	29.31	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.36	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.35	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.00	in H_2O	3.1	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.00	in H_2O	3.3	in H_2O for	15.0	sec [≥15]
	Post (+)	0.00	in H_2O	3.2	in H_2O for	15.0	sec [≥15]
	Post (-)	0.00	in H_2O	3.6	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	4b		
Average Nozzle Diameter	(D_{ns})	0.1560	in
Suggested Nozzle Diameter	(D_n)	0.1519	in
Probe Number	SAMP-PR-0133		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.11	in Hg
Stack Static Pressure	(P_{static})	-0.89	in H_2O
Absolute Stack Pressure	(P_s)	30.04	in Hg
Absolute Meter Pressure	(P_m)	30.25	in Hg

Nozzle Measurements			**ID: 4b**	
Pre	0.156	0.156	0.156	**PASS**
Post	0.156	0.156	0.156	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	12:30	**End**	17:15

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	359.1	589.5	777.0	868.3				
Post	540.0	589.3	806.3	888.8				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0030	Samp-cp-0030	Samp-cp-0030			SAMP-PR-0133	SAMP-PR-0133	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0030		Samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	884.600	1.30	0.441	0.44	182	252	260	55	59	71	78	78	3.5	1.14	61.45	8.108	97.0	96.949
A-2	23.0	00:23:00	893.020	1.40	0.441	0.44	181	250	261	56	61	73	78	78	3.5	1.18	63.72	17.507	100.6	102.437
A-3	47.0	00:47:00	902.780	1.30	0.441	0.44	180	252	261	57	62	71	82	82	3.5	1.14	61.36	25.690	99.7	100.924
B-1	70.0	01:10:00	911.340	1.30	0.441	0.44	182	250	254	54	62	72	82	82	3.5	1.14	61.45	34.063	99.8	100.725
B-2	93.0	01:33:00	920.100	1.20	0.441	0.44	183	251	255	55	56	73	84	85	4.0	1.10	59.09	41.685	99.5	99.465
B-3	115.3	01:55:15	928.110	1.40	0.441	0.44	181	250	253	57	57	74	86	86	4.0	1.18	63.72	50.642	99.4	100.012
C-1	139.3	02:19:15	937.550	1.40	0.441	0.44	180	252	254	50	53	72	85	85	4.0	1.18	63.67	59.502	99.1	100.234
C-2	163.3	02:43:15	946.870	1.20	0.441	0.44	181	250	251	51	54	73	85	85	4.0	1.10	58.99	66.803	98.6	99.034
C-3	185.5	03:05:30	954.550	1.30	0.441	0.44	183	252	253	55	55	74	85	85	4.0	1.14	61.50	75.055	98.6	98.993
D-1	208.5	03:28:30	963.230	1.30	0.441	0.44	182	251	252	54	55	75	84	84	4.0	1.14	61.45	84.045	99.5	99.838
D-2	231.5	03:51:30	972.670	1.20	0.441	0.44	181	253	255	55	55	75	85	85	4.0	1.10	58.99	91.222	99.0	98.862
D-3	253.8	04:13:45	980.220	1.10	0.441	0.44	180	251	262	56	57	74	85	85	4.0	1.05	56.44	97.858	98.6	97.858
Last Pt	275.0	04:35:00	987.200																	
Final Val	275.0	04:35:00	987.200											**Max Vac**	4.0	**Final Values**		97.858	98.6	
Average Values				1.28		0.44	181	251	256	55	57	73	83	83		1.13	60.99			
													83							

Actual Nozzle Diameter (D_{na})	**DP to DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.156	0.35	8.108	97.0	786.3
0.156	0.35	9.399	103.7	974.9
0.156	0.35	8.182	97.7	799.5
0.156	0.35	8.374	100.1	838.6
0.156	0.35	7.622	98.1	748.0
0.156	0.35	8.958	98.9	885.5
0.156	0.35	8.860	97.7	865.6
0.156	0.35	7.301	93.9	685.3
0.156	0.35	8.251	98.8	814.9
0.156	0.35	8.990	107.5	966.7
0.156	0.35	7.177	92.3	662.3
0.156	0.35	6.635	93.2	618.6
0.156	0.35	97.858		

RM 201A Calculations						
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Prelim. Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
23.00	23.03	1.30		1.30	0
24.00	23.90	1.40	23.90	1.40	0
23.00	23.03	1.30	23.03	1.30	0
23.00	23.03	1.30		1.30	0
22.25	22.13	1.20	22.13	1.20	0
24.00	23.90	1.40	23.90	1.40	0
24.00	23.90	1.40		1.40	0
22.25	22.13	1.20	22.13	1.20	0
23.00	23.03	1.30	23.03	1.30	0
23.00	23.03	1.30		1.30	0
22.25	22.13	1.20	22.13	1.20	0
21.25	21.18	1.10	21.18	1.10	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	197.64	μP
	Cyclone Flow Rate (Q_s)	0.48	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.56	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.27	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.64	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.47	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.36	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2759.69	
	Actual Particle Cut Diameter for CI	10.56	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.36	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.36	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	98.57	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.156	in
	Δp_{min}	0.630	in H_2O
	Δp_{max}	1.879	in H_2O

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#2	
Operator		TW	
Date for Preliminary Run	(mm/dd/yy)	03/11/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	10 L/min	10.6	scf
Run Duration	8a, 2.4.1.3	120	minutes
Unit Number		U-00002	
Base Run Number		SAM U-00002 Base+DB	
Number of Ports Available		4	
Number of Ports Used		1	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	03/11/20	03/11/20	03/11/20	
Load		Base+DB	Base+DB	Base+DB	% or w/DB
Fuel F-Factor		8636.30	8636.30	8636.30	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0007	samp-cp-0007	samp-cp-0007	
Meter Calibration Factor	(Y)	0.985	0.985	0.985	
Orifice Meter Coefficient	($\Delta H_@$)	1.731	1.731	1.731	in H_2O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-SAM-01	SAMP-SAM-01	SAMP-SAM-01	
Probe Length		72.0	72.0	72.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-ha-0005	samp-ha-0005	samp-ha-0005	
Impinger Case Number	from ACS	samp-bc-0032	samp-bc-0032	samp-bc-0032	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	03/11/20
Sampling Location	U-00002 Base+DB	**Stack Type**	Circular
Operator	TW	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	1
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

◉ Method 1 Trav

○ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
1	**Ports by**	1	**Across**
1	**Pts Used**	1	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
Number	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.275	62 6/8	70 6/8
2			
3			
4			
5			
6			
7			
8			
9			

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/11/20		
Sampling Location	U-00002 Base+DB	**Operator**	TW		
Project #	bec-19-cricketvalley.ny-start#2	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	SAM U-00002 Base+DB-1		**Date**	03/11/20	**Run Start Time**	05:46	**Run Stop Time**	07:46
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	5.3	11.7	0.0	83.0	29.32	1.736	114.6	YES

Gas Analysis Data

Run Number	SAM U-00002 Base+DB-2		**Date**	03/11/20	**Run Start Time**	08:40	**Run Stop Time**	10:40
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	5.3	11.7	0.0	83.0	29.32	1.736	114.6	YES

Gas Analysis Data

Run Number	SAM U-00002 Base+DB-3		**Date**	03/11/20	**Run Start Time**	11:33	**Run Stop Time**	13:33
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	5.3	11.7	0.0	83.0	29.32	1.736	114.6	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	03/11/20
Sampling Location	U-00002 Base+DB	**Operator**	TW
Project #	bec-19-cricketvalley.ny-start#2	**Ports Used**	1

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	03/11/20	500	499.7	-0.3	Pass
Test Day 2	03/12/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		SAM U-00002 Base+DB-1		**Date**	03/11/20	**Start Time**	05:46	**Stop Time**	07:46
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	40.960	dcf		**Barometric Pressure**	(P_b)	30.09	in Hg
Average Stack Temp		$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	83	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	752.50	753.60	621.70	933.70				
Initial Value	(V_i),(W_i)	698.30	751.10	621.60	925.30				
Net Value	(V_n),(W_n)	54.2	2.5	0.1	8.4				
Results									
Total Weight		(W_t)	65.20	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.074	scf
Std Meter Volume		($V_{m(std)}$)	39.479	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	7.22	%		**Final Moisture Content**	(B_{ws})		%

Moisture Content Data									
Run Number		SAM U-00002 Base+DB-2		**Date**	03/11/20	**Start Time**	08:40	**Stop Time**	10:40
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	41.810	dcf		**Barometric Pressure**	(P_b)	30.15	in Hg
Average Stack Temp		$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	86	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	808.40	761.40	624.10	942.00				
Initial Value	(V_i),(W_i)	752.50	753.60	621.70	933.70				
Net Value	(V_n),(W_n)	55.9	7.8	2.4	8.3				
Results									
Total Weight		(W_t)	74.40	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.508	scf
Std Meter Volume		($V_{m(std)}$)	40.149	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	8.04	%		**Final Moisture Content**	(B_{ws})		%

Moisture Content Data									
Run Number		SAM U-00002 Base+DB-3		**Date**	03/11/20	**Start Time**	11:33	**Stop Time**	13:33
Meter Box Number		samp-cp-0007				**Meter Cal Factor**	(Y)	0.985	
Total Meter Volume		(V_m)	41.300	dcf		**Barometric Pressure**	(P_b)	30.14	in Hg
Average Stack Temp		$(t_s)_{avg}$		°F		**Stack Static Pressure**	(P_{static})	0.95	in H_2O
Average Meter Temp		$(t_m)_{avg}$	89	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.34	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	861.00	767.80	626.70	948.80				
Initial Value	(V_i),(W_i)	808.40	761.40	624.10	942.00				
Net Value	(V_n),(W_n)	52.6	6.4	2.6	6.8				
Results									
Total Weight		(W_t)	68.40	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.225	scf
Std Meter Volume		($V_{m(std)}$)	39.466	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)		%
Calc Moisture Content		($B_{ws(calc)}$)	7.55	%		**Final Moisture Content**	(B_{ws})		%

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Date	03/11/20
Operator	TW
Run Number	SAM U-00002 Base+DB-1

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	83.1	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.09	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.16	in Hg
Absolute Meter Pressure	(P_m)	30.22	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	05:46	**End**	07:46

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	698.3	751.1	621.6	925.3				
Post	752.5	753.6	621.7	933.7				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	46.270	--	0.342	0.34	--	350	534	47	78	--	75	75	1.0			1.751		42.034
A-2	5.0	00:05:00	48.060	--	0.342	0.34	--	350	506	48	87	--	81	74	1.0			3.446		41.352
A-3	10.0	00:10:00	49.800	--	0.342	0.34	--	350	504	49	95	--	84	74	1.0			5.155		41.242
A-4	15.0	00:15:00	51.560	--	0.342	0.34	--	350	500	50	101	--	85	74	1.0			6.863		41.178
A-5	20.0	00:20:00	53.320	--	0.342	0.34	--	350	507	51	104	--	85	76	1.0			8.664		41.589
A-6	25.0	00:25:00	55.180	--	0.342	0.34	--	350	512	50	106	--	86	76	1.0			10.338		41.353
A-7	30.0	00:30:00	56.910	--	0.342	0.34	--	350	504	51	108	--	89	77	1.0			11.968		41.032
A-8	35.0	00:35:00	58.600	--	0.342	0.34	--	350	511	52	108	--	87	77	1.0			13.590		40.770
A-9	40.0	00:40:00	60.280	--	0.342	0.34	--	350	509	54	110	--	89	78	1.0			15.362		40.966
A-10	45.0	00:45:00	62.120	--	0.342	0.34	--	350	502	53	109	--	90	77	1.0			17.057		40.938
A-11	50.0	00:50:00	63.880	--	0.342	0.34	--	350	509	52	109	--	90	78	1.0			18.741		40.890
A-12	55.0	00:55:00	65.630	--	0.342	0.34	--	350	507	52	109	--	90	79	1.0			20.462		40.925
A-13	60.0	01:00:00	67.420	--	0.342	0.34	--	350	500	52	109	--	89	79	1.0			22.079		40.761
A-14	65.0	01:05:00	69.100	--	0.342	0.34	--	350	504	52	109	--	90	79	1.0			23.761		40.734
A-15	70.0	01:10:00	70.850	--	0.342	0.34	--	350	503	51	108	--	92	79	1.0			25.575		40.920
A-16	75.0	01:15:00	72.740	--	0.342	0.34	--	350	506	51	108	--	91	80	1.0			27.235		40.853
A-17	80.0	01:20:00	74.470	--	0.342	0.34	--	350	501	50	107	--	90	80	1.0			28.993		40.931
A-18	85.0	01:25:00	76.300	--	0.342	0.34	--	350	503	50	108	--	90	80	1.0			30.626		40.834
A-19	90.0	01:30:00	78.000	--	0.342	0.34	--	350	502	50	110	--	90	80	1.0			31.721		40.068
A-20	95.0	01:35:00	79.140	--	0.342	0.34	--	350	506	50	108	--	90	80	1.0			33.507		40.209
A-21	100.0	01:40:00	81.000	--	0.342	0.34	--	350	511	50	108	--	90	80	1.0			34.909		39.896
A-22	105.0	01:45:00	82.460	--	0.342	0.34	--	350	507	51	109	--	91	80	1.0			36.493		39.810
A-23	110.0	01:50:00	84.110	--	0.342	0.34	--	350	510	50	108	--	91	80	1.0			37.587		39.221
A-24	115.0	01:55:00	85.250	--	0.342	0.34	--	350	501	50	109	--	91	81	1.0			39.485		39.485
Last Pt	120.0	02:00:00	87.230																	
Final Val	120.0	02:00:00	87.230											**Max Vac**	1.0	**Final Values**		39.485		
Average Values						0.34		350	507	51	105		88	78						
													83							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Date	03/11/20
Operator	TW
Run Number	SAM U-00002 Base+DB-2

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	86.2	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.33	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.15	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.22	in Hg
Absolute Meter Pressure	(P_m)	30.28	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	08:40	**End**	10:40

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	752.5	753.6	621.7	933.7				
Post	808.4	761.4	624.1	942.0				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	94.400	--	0.342	0.34	--	350	500	49	87	--	81	79	1.0			1.797		43.127
A-2	5.0	00:05:00	96.250	--	0.342	0.34	--	350	505	52	154	--	86	78	1.0			3.510		42.118
A-3	10.0	00:10:00	98.020	--	0.342	0.34	--	350	510	55	180	--	89	78	1.0			5.228		41.821
A-4	15.0	00:15:00	99.800	--	0.342	0.34	--	350	504	56	181	--	88	78	1.0			6.928		41.566
A-5	20.0	00:20:00	101.560	--	0.342	0.34	--	350	500	59	172	--	89	80	1.0			8.652		41.530
A-6	25.0	00:25:00	103.350	--	0.342	0.34	--	350	504	57	178	--	91	78	1.0			10.319		41.274
A-7	30.0	00:30:00	105.080	--	0.342	0.34	--	350	506	57	178	--	91	79	1.0			11.916		40.855
A-8	35.0	00:35:00	106.740	--	0.342	0.34	--	350	509	58	177	--	91	79	1.0			13.562		40.685
A-9	40.0	00:40:00	108.450	--	0.342	0.34	--	350	511	58	178	--	91	79	1.0			15.227		40.605
A-10	45.0	00:45:00	110.180	--	0.342	0.34	--	350	514	58	178	--	91	80	1.0			16.958		40.698
A-11	50.0	00:50:00	111.980	--	0.342	0.34	--	350	507	59	178	--	92	80	1.0			18.648		40.687
A-12	55.0	00:55:00	113.740	--	0.342	0.34	--	350	506	59	179	--	92	80	1.0			20.301		40.601
A-13	60.0	01:00:00	115.460	--	0.342	0.34	--	350	510	59	156	--	92	81	1.0			21.951		40.526
A-14	65.0	01:05:00	117.180	--	0.342	0.34	--	350	509	59	145	--	92	81	1.0			23.612		40.477
A-15	70.0	01:10:00	118.910	--	0.342	0.34	--	350	508	59	137	--	93	82	1.0			25.307		40.492
A-16	75.0	01:15:00	120.680	--	0.342	0.34	--	350	503	61	135	--	94	82	1.0			27.155		40.732
A-17	80.0	01:20:00	122.610	--	0.342	0.34	--	350	503	61	136	--	94	83	1.0			28.866		40.753
A-18	85.0	01:25:00	124.400	--	0.342	0.34	--	350	502	61	134	--	94	83	1.0			30.540		40.720
A-19	90.0	01:30:00	126.150	--	0.342	0.34	--	350	505	60	132	--	94	83	1.0			32.185		40.654
A-20	95.0	01:35:00	127.870	--	0.342	0.34	--	350	500	61	131	--	94	83	1.0			33.743		40.492
A-21	100.0	01:40:00	129.500	--	0.342	0.34	--	350	501	61	130	--	94	83	1.0			35.350		40.400
A-22	105.0	01:45:00	131.180	--	0.342	0.34	--	350	500	61	129	--	94	84	1.0			36.945		40.304
A-23	110.0	01:50:00	132.850	--	0.342	0.34	--	350	502	62	128	--	94	85	1.0			38.520		40.195
A-24	115.0	01:55:00	134.500	--	0.342	0.34	--	350	504	63	128	--	94	85	1.0			40.153		40.153
Last Pt	120.0	02:00:00	136.210																	
Final Val	120.0	02:00:00	136.210											**Max Vac**	1.0	**Final Values**		40.153		
Average Values						0.34		350	505	59	152		91	81						
													86							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Date	03/11/20
Operator	TW
Run Number	SAM U-00002 Base+DB-3

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)		°F
Average Meter Temp	(t_m)	88.7	
Orifice Meter Coefficient	($\Delta H@$)	1.731	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})		%
Stack Dry Molecular Weight	(M_d)	29.32	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.33	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0007		
Meter Cal Factor	(Y)	0.985	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-SAM-01		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-ha-0005		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.14	in Hg
Stack Static Pressure	(P_{static})	0.95	in H_2O
Absolute Stack Pressure	(P_s)	30.21	in Hg
Absolute Meter Pressure	(P_m)	30.27	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	11:33	**End**	13:33

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	808.4	761.4	624.1	942.0				
Post	861.0	767.8	626.7	948.8				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0007	samp-cp-0007	samp-cp-0007			SAMP-SAM-01	SAMP-SAM-01	samp-ha-0005	samp-bc-0032	TCSAM1		samp-cp-0007		samp-cp-0007					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	142.600	--	0.342	0.34	--	350	506	57	75	--	85	83	1.5			1.745		41.870
A-2	5.0	00:05:00	144.410	--	0.342	0.34	--	350	507	56	88	--	87	82	1.5			3.468		41.620
A-3	10.0	00:10:00	146.200	--	0.342	0.34	--	350	506	57	101	--	91	82	1.5			5.195		41.562
A-4	15.0	00:15:00	148.000	--	0.342	0.34	--	350	507	57	110	--	92	83	1.5			6.785		40.711
A-5	20.0	00:20:00	149.660	--	0.342	0.34	--	350	509	57	114	--	93	83	1.5			8.402		40.330
A-6	25.0	00:25:00	151.350	--	0.342	0.34	--	350	511	58	115	--	93	83	1.5			9.981		39.923
A-7	30.0	00:30:00	153.000	--	0.342	0.34	--	350	506	59	117	--	94	83	1.5			11.721		40.185
A-8	35.0	00:35:00	154.820	--	0.342	0.34	--	350	506	60	118	--	94	83	1.5			13.336		40.009
A-9	40.0	00:40:00	156.510	--	0.342	0.34	--	350	506	61	122	--	94	83	1.5			14.665		39.107
A-10	45.0	00:45:00	157.900	--	0.342	0.34	--	350	514	61	123	--	94	84	1.5			16.814		40.354
A-11	50.0	00:50:00	160.150	--	0.342	0.34	--	350	509	62	124	--	94	85	1.5			18.484		40.328
A-12	55.0	00:55:00	161.900	--	0.342	0.34	--	350	507	62	126	--	95	84	1.5			20.135		40.269
A-13	60.0	01:00:00	163.630	--	0.342	0.34	--	350	504	62	126	--	95	84	1.5			21.614		39.902
A-14	65.0	01:05:00	165.180	--	0.342	0.34	--	350	510	61	125	--	96	84	1.5			23.349		40.026
A-15	70.0	01:10:00	167.000	--	0.342	0.34	--	350	507	60	123	--	96	84	1.5			25.065		40.104
A-16	75.0	01:15:00	168.800	--	0.342	0.34	--	350	508	60	124	--	95	86	1.5			26.684		40.026
A-17	80.0	01:20:00	170.500	--	0.342	0.34	--	350	510	60	124	--	94	85	1.5			28.211		39.827
A-18	85.0	01:25:00	172.100	--	0.342	0.34	--	350	508	58	123	--	95	85	1.5			29.955		39.940
A-19	90.0	01:30:00	173.930	--	0.342	0.34	--	350	503	59	122	--	96	85	1.5			31.555		39.860
A-20	95.0	01:35:00	175.610	--	0.342	0.34	--	350	501	58	119	--	95	84	1.5			33.187		39.825
A-21	100.0	01:40:00	177.320	--	0.342	0.34	--	350	502	58	118	--	94	85	1.5			34.790		39.760
A-22	105.0	01:45:00	179.000	--	0.342	0.34	--	350	501	56	116	--	95	85	1.5			36.420		39.731
A-23	110.0	01:50:00	180.710	--	0.342	0.34	--	350	506	56	115	--	94	84	1.5			38.035		39.688
A-24	115.0	01:55:00	182.400	--	0.342	0.34	--	350	510	55	127	--	94	84	1.5			39.467		39.467
Last Pt	120.0	02:00:00	183.900																	
Final Val	120.0	02:00:00	183.900											**Max Vac**	1.5	**Final Values**		39.467		
Average Values						0.34		350	507	59	116		94	84						
													89							

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
Opacity

W/DB

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: ~~AirHygiene~~ Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 16000 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 2 Operating Mode:
Control Equipment: Duct Fan Operating Mode:


Describe Emissions Pont:
Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start SW End SW

Vetical Angle to Obs. Pt. Start 140 End 140
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 1453-0 End 1440

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A
Water Droplet Plume Start N/A End N/A

Describe Plume Background Start End
Background Color Start White End Dark
Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 13 End 13
Wind Direction Start SW End SW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

Form Number (AHI Project Code) Page 1 of 6
Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time
3/10/2020		2:30	3:00

Min \ Sec	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Sean Fields
Observer's Signature: [signature] Date: 3/10/20
Organization: Air Hygiene CAA
Certified By: Date: 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 2 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Pont:
Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start SW End SW

Vetical Angle to Obs. Pt. Start 14° End 14°
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145 End 144

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Clear End Clear
Sky Conditions Start Clear End Clear
Wind Speed Start 13 End 13
Wind Direction Start SW End SW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 6
Continued on Form Number (AHI Project Code)
Observation Date 3/10/2020 Time Zone Start Time 3:00 End Time 3:30

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 3/10/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # - 2 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Pont
Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start SW End SW

Vetical Angle to Obs. Pt. Start 14° End 14°
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145' End 145'

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Clear End Cloudy
Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 12 End 12
Wind Direction Start SW End SW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 3 of 6
Continued on Form Number (AHI Project Code)

Observation Date 3/10/2020 Time Zone Start Time 3:30 End Time 4:30

Min \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 3/10/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process | Unit # 2 | Operating Mode
Control Equipment | Operating Mode

Describe Emissions Pont


Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 149 End 149
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start SW End SW

Vetical Angle to Obs. Pt. Start 140 End 140
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 146' End 145'

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Cloudy End Clear
Sky Conditions Start Clear End Cloudy
Wind Speed Start 12 End 12
Wind Direction Start SW End SW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 4 of 6
Continued on Form Number (AHI Project Code)

Observation Date 3/10/2020 | Time Zone | Start Time 4:00 | End Time 4:30

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print) Seven Fields
Observer's Signature
Date 3/10/20
Organization Air Hygiene
Certified By CAA
Date 1/3/2020

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One): Method 9 | 203A | 203B | Other: _____

Form Number (AHI Project Code) | Page 5 of 6

Continued on Form Number (AHI Project Code)

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow | State: OK | Zip: 74012

Observation Date: 3/10/2020 | Time Zone | Start Time: 4:30 | End Time: 5:00

Process | Unit #: 2 | Operating Mode
Control Equipment | Operating Mode

Describe Emissions Point


Height of Emiss. Pt. Start 140 End 140 | Height of Emiss. Pt. Rel. to Observer Start 141° End 141°
Distance to Emiss. Pt. Start 6 End 6 | Direction to Emiss. Pt. (Degrees) Start SW End SW

Vetical Angle to Obs. Pt. Start 14° End 14° | Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145 End 145

Describe Emissions Start N/A End N/A
Emission Color Start N/A End N/A | Water Droplet Plume Start N/A End N/A

Describe Plume Background Start End
Background Color Start ~~Light~~ Dark End ~~Cloudy~~ Dark | Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 12 End 12 | Wind Direction Start SW End SW
Ambient Temp. Start End | Wet Bulb Temp. | RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature | Date: 3/10/20
Organization: Air Hygiene
Certified By: CAA | Date: 1/3/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 2 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Pont:
Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start SWS End SW

Vetical Angle to Obs. Pt. Start 140 End 140
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 145 End 145

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Dark End Dark
Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 13 End 13
Wind Direction Start SW End SW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 7 of 6
Continued on Form Number (AHI Project Code)
Observation Date 3/10/2020 Time Zone Start Time 5:00 End Time 5:30

Min. \ Sec	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 3/10/20
Organization: Air Hygiene
Certified By: CAA Date: 1/3/2020

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

CERTIFICATE OF ANALYSIS
(Zero Ambient Nitrogen)

Cylinder Number:	EB0072934	**Certification Date:**	05/21/2019
Product ID Number:	121026	**Expiration Date:**	05/19/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0072934.20190521-0	**Lot Number:**	EB0072934.20190521
Customer PO. NO.:		**Tracking Number:**	084249399
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
PGVP Vendor ID # G12019
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

Anthony Cyr
Assistant Operations Manager

Version 02-B, Revised on 2015-05-27

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC721614	**Certification Date**:	11/13/2018
Product ID Number:	124605	**Expiration Date:**	11/11/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC721614.20181109-0	**Lot Number:**	CC721614.20181109
Customer PO. NO.:		**Tracking Number:**	098499636
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**19.0 %**	±0.16 %	NDIR	11/13/2018
Oxygen	**21.0 %**	±0.12 %	MPA	11/13/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004987	EB0004987.20180323	07/15/2026	GMIS	N2	CO2	19.5 %	0.767	101001
EB0005996	EB0005996.20170209	05/09/2026	GMIS	N2	O2	20 %	0.077	071001
EB0032246	EB0032246.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	11/06/2018
CO2	NDIR	Thermo	410i	1162980025	10/24/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC729922	**Certification Date**:	08/30/2019
Product ID Number:	124606	**Expiration Date:**	08/28/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC729922.20190826-0	**Lot Number:**	CC729922.20190826
Customer PO. NO.:		**Tracking Number:**	098857760
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.94 %**	±0.05 %	NDIR	08/30/2019
Oxygen	**12.00 %**	±0.08 %	MPA	08/30/2019
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
D687685	D687685	11/05/2023	PRM	N2	CO2	25.033 %	0.0998	C1579010.02
EB0004987	EB0004987.20190327	06/18/2027	GMIS	N2	CO2	9.52 %	0.191	C1579010.02
EB0005592	EB0005592.20180118	07/21/2026	GMIS	N2	O2	11.98 %	0.507	071001
EB0069971	EB0069971.20180504	07/21/2026	GMIS	N2	O2	24 %	0.497	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CO2	NDIR	Thermo	410i	1162980025	08/01/2019
O2	MPA	Thermo	410i	1162980025	08/06/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0040961	**Certification Date**:	10/31/2019
Product ID Number:	124737	**Expiration Date:**	10/30/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0040961.20191017-0	**Lot Number:**	EB0040961.20191017
Customer PO. NO.:		**Tracking Number:**	065159907
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**9.1 PPM**	±0.12 PPM	FTIR	10/30/2019
Nitric Oxide	**8.8 PPM**	±0.10 PPM	Chemiluminescence	10/23/2019, 10/31/2019
Total Oxides of Nitrogen	8.9 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM005307	ALM0053007.20181025	10/09/2022	GMIS	N2	NO	34.2 PPM	1.062	1684B
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002
EB0089797	EB0089797.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.085	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	10/18/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/30/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0065964	**Certification Date**:	07/23/2019
Product ID Number:	125564	**Expiration Date:**	07/22/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0065964.20190611-0	**Lot Number:**	EB0065964.20190611
Customer PO. NO.:		**Tracking Number:**	083030934
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**5.09 PPM**	±0.07 PPM	FTIR	06/19/2019
Nitric Oxide	**4.88 PPM**	±0.06 PPM	Chemiluminescence	06/18/2019, 07/08/2019, 07/23/2019
Total Oxides of Nitrogen	4.91 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM066143	ALM066143.20171116	11/09/2022	GMIS	N2	NO	9.6 PPM	1.062	12100115
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0032297	EB0032297.20160725	09/06/2025	GMIS	N2	CO	6.15 PPM	1.067	091002
EB0060662	EB0060662.20151012	01/02/2022	GMIS	N2	NO	2.97 PPM	1.062	12100115
EB0078555	EB0078555.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.113	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	05/30/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	05/30/2019
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0038438	**Certification Date:**	11/27/2018
Product ID Number:	126123	**Expiration Date:**	11/25/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0038438.20181121-0	**Lot Number:**	EB0038438.20181121
Customer PO. NO.:		**Tracking Number:**	056853515
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**8.77 PPM**	±0.05 PPM	FTIR	11/27/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0042063	EB0042063.20171231	03/17/2023	GMIS	N2	CH4	30.37 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	11/27/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0060640	**Certification Date:**	06/08/2018
Product ID Number:	124609	**Expiration Date:**	06/06/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0060640.20180604-0	**Lot Number:**	EB0060640.20180604
Customer PO. NO.:		**Tracking Number:**	082997030
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**4.90 PPM**	±0.03 PPM	FTIR	06/08/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/08/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0057200	**Certification Date:**	09/18/2018
Product ID Number:	125892	**Expiration Date:**	09/16/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0057200.20180913-0	**Lot Number:**	EB0057200.20180913
Customer PO. NO.:		**Tracking Number:**	074329951
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**3.37 PPM**	±0.03 PPM	FTIR	09/18/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/18/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

CERTIFIED GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0100161	**Certification Date**:	12/30/2019
Product ID Number:	125123	**Expiration Date:**	12/29/2020
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0100161.20191230-0	**Lot Number:**	EB0100161.20191230
Customer PO. NO.:		**Tracking Number:**	095703088
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Ammonia	**50.4 PPM**	± 2% NIST	FTIR
Sulfur Hexafluoride	**9.02 PPM**	± 2% NIST	FTIR
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
SA18481	70086910005	04/12/2020	PS	N2	NH3	21.1 PPM	1.2	73248226
EB0079029	EB0079029	06/27/2020	PS	N2	SF6	10.1 PPM	5	191064

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NH3	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	
SF6	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-G, Revised on 2017-07-02

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0098845	**Certification Date**:	05/03/2019
Product ID Number:	124731	**Expiration Date:**	05/02/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0098845.20190416-0	**Lot Number:**	EB0098845.20190416
Customer PO. NO.:		**Tracking Number:**	095689140
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	**48.7 PPM**	±0.6 PPM	FTIR	04/26/2019, 05/03/2019

Air Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003640	EB0003640.20190102	03/20/2022	GMIS	AIR	NO2	87.8 PPM	1.061	C1579010.01
EB0096848	EB0096848.20190102	03/21/2022	GMIS	AIR	NO2	61.1 PPM	1.072	C1579010.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/26/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the “hands of the test” on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the “hands of the test” on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene’s review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer’s instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3 A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

Data Provided by Client

Data provided by the Client is clearly identified in the report. Air Hygiene accepts data provided by the Client as accurate.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO_2 to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO_2 in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS
QUALITY ASSURANCE DATA

Date: March 9-11, 2020
Company: Cricket Valley Energy Center LLC
Location: Dover Plains, New York
Techs: RW / SB / AM / MW / AB / MJ / JJ

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
March 9-11, 2020	1	0

Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This laboratory also meets the A2LA *R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (*refer to joint ISO-ILAC-IAF Communiqué dated April 2017*).

Presented this 18th day of December 2019

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2021

For the tests to which this accreditation applies, please refer to the laboratory's Envrionmental Scope of Accreditation.

STAC STACK TESTING ACCREDITATION COUNCIL

A2LA American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 18th day of December 2019.

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2021

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY

Qualified Source Testing Individual

LET IT BE KNOWN THAT

ROBERT C. WHITE, Jr.

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 25TH DAY OF OCTOBER 2019 AND EFFECTIVE UNTIL OCTOBER 24TH, 2024

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Tina Sanderson, QSTI/QSTO Review Board

J. Wade Bice, QSTI/QSTO Review Board

Karen D. Kajiya-Mills , QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board

CERTIFICATE NO. 2015-898

Compliance Assurance Associates Inc.

Helping Industry Comply with Environmental Regulations

This is to acknowledge that

Sean Fields

BRO200103-17227

Certificate verification is available at www.Compliance.Assurance.com/certs.php using the last name and 17227

successfully participated in Visible Emissions Evaluation field training and certification and pursuant to US EPA 40 CFR 60 Appendix A, Reference Method 9, as amended, is certified to evaluate Visible Emissions for a period of six (6) months from the date of this certification.



Anthony Ferro - Field Manager	Broken Arrow, OK	01/03/2020
	Location	Date

Compliance Assurance Associates, Inc. 682 Orvil Smith Rd, Harvest, AL, 35749. 901-381-9960. compliance-assurance.com

QUALITY ASSURANCE AND QUALITY CONTROL DATA


Daily Reference Method Analyzer Calibration Data

Calibration Date: March 9, 2020 **Location:** Cricket Valley Energy Center - Unit U-00002

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 8.90

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.02	0.22	0.02	YES (%)
4.88	5.05	1.91	0.17	YES (%)
8.90	9.02	1.35	0.12	YES (%)
Linearity = 0.988				




CO Span (ppm) = 9.11

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.04	0.44	0.04	YES (%)
5.09	5.04	-0.55	0.05	YES (%)
9.11	9.11	0.00	0.00	YES (%)
Linearity = 1.005				



O_2 Span (%) = 21.00


SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.03	0.14	0.03	YES (%)
12.00	12.00	0.00	0.00	YES (%)
21.00	20.95	-0.24	0.05	YES (%)
Linearity = 1.004				



VOC (as C1) Range (ppm) = 10.5


VIG 210 (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass (±2,5%)[1]
0.00	0.00	0.01	N/A	YES
3.37	3.43	1.19	3.39	YES
4.84	4.73	-2.85	4.87	YES
8.77	8.82	0.48	N/A	YES
Linearity = 0.992				

[1]-zero/high based on 2% of span, low/mid based on 5% of concentration



CO_2 Span (%) = 19.00

SERVOMEX 1440 (CO_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.01	0.05	0.01	YES (%)
8.94	9.15	1.11	0.21	YES (%)
19.00	19.00	0.00	0.00	YES (%)
Linearity = 1.001				




Calibration Date: March 10, 2020 **Location:** Cricket Valley Energy Center - Unit U-00002

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 8.90

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.02	-0.22	0.02	YES (%)
4.88	4.88	0.00	0.00	YES (%)
8.90	8.86	-0.45	0.04	YES (%)
Linearity = 1.002				




CO Span (ppm) = 9.11

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.08	-0.88	0.08	YES (%)
5.09	5.08	-0.11	0.01	YES (%)
9.11	8.65	-5.05	0.46	YES (abs)
Linearity = 1.039				



O_2 Span (%) = 21.00


SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	-0.03	-0.14	0.03	YES (%)
12.00	12.07	0.33	0.07	YES (%)
21.00	21.17	0.81	0.17	YES (%)
Linearity = 0.991				



VOC (as C1) Range (ppm) = 10.5


VIG 210 (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass (±2,5%)[1]
0.00	-0.05	-0.43	N/A	YES
3.37	3.26	-1.30	3.30	YES
4.84	4.74	-0.51	4.76	YES
8.77	8.67	-0.95	N/A	YES
Linearity = 0.999				

[1]-zero/high based on 2% of span,low/mid based on 5% of concentration



CO_2 Span (%) = 19.00

SERVOMEX 1440 (CO_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	-0.09	-0.47	0.09	YES (%)
8.94	9.06	0.63	0.12	YES (%)
19.00	19.00	-0.01	0.00	YES (%)
Linearity = 0.996				



NOx Converter Efficiency

Date: March 9, 2020

Analyzer: inst-nx-0020

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**48.70**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**1.29**
	Analyzer Reading, NOx Channel, ppmvd	**47.15**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**45.86**
	Converter Efficiency, %	**94.17**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{45.86 \text{ ppmvd}}{48.70 \text{ ppmvd}}$ x 100 = 94.17%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
03/09/20 05:26:09	130	37.75	1.41
03/09/20 05:26:19	140	38.18	1.41
03/09/20 05:26:29	150	37.58	1.40
03/09/20 05:26:39	160	41.23	1.39
03/09/20 05:26:49	170	46.64	1.36
03/09/20 05:26:59	180	47.25	1.35
03/09/20 05:27:09	190	47.15	1.31
03/09/20 05:27:19	***200***	***47.15***	***1.29***
03/09/20 05:27:29	***210***	***47.15***	***1.29***
03/09/20 05:27:39	220	47.14	1.26
03/09/20 05:27:49	230	47.11	1.21
03/09/20 05:27:59	240	43.86	1.21
03/09/20 05:28:09	250	38.56	1.21
03/09/20 05:28:19	260	37.69	1.22
03/09/20 05:28:29	270	35.45	1.21

NOx Converter Efficiency

Date: March 10, 2020

Analyzer: inst-nx-0020

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**48.70**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**1.13**
	Analyzer Reading, NOx Channel, ppmvd	**49.17**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**48.04**
	Converter Efficiency, %	**98.64**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{48.04 \text{ ppmvd}}{48.70 \text{ ppmvd}}$ x 100 = 98.64%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
03/10/20 05:17:33	90	35.97	1.07
03/10/20 05:17:43	100	36.04	1.36
03/10/20 05:17:53	110	37.45	1.36
03/10/20 05:18:03	120	49.05	1.36
03/10/20 05:18:13	130	49.13	1.34
03/10/20 05:18:23	140	49.19	1.30
03/10/20 05:18:33	150	49.21	1.24
03/10/20 05:18:43	160	49.21	1.19
03/10/20 05:18:53	170	49.17	1.14
03/10/20 05:19:03	***180***	***49.17***	***1.13***
03/10/20 05:19:13	190	49.18	1.11
03/10/20 05:19:23	200	49.12	1.08
03/10/20 05:19:33	210	49.12	1.03
03/10/20 05:19:43	220	49.11	1.03
03/10/20 05:19:53	230	49.11	1.00
03/10/20 05:20:03	240	49.09	0.99
03/10/20 05:20:13	250	49.04	0.99

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
03/09/20	13:42:20	SPIKE_0339.LAB	9.1650
03/09/20	13:42:30	SPIKE_0340.LAB	9.1581
03/09/20	13:42:41	SPIKE_0341.LAB	9.1757
03/09/20	13:42:51	SPIKE_0342.LAB	9.1604
03/09/20	13:43:02	SPIKE_0343.LAB	9.1610

PRE TEST AVERAGE **9.16**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
03/09/20	19:21:10	UNIT2ND RUN1_0502.LAB	8.8916
03/09/20	19:21:40	UNIT2ND RUN1_0503.LAB	8.8711
03/09/20	19:22:10	UNIT2ND RUN1_0504.LAB	8.8976
03/09/20	19:22:40	UNIT2ND RUN1_0505.LAB	8.9130
03/09/20	19:23:10	UNIT2ND RUN1_0506.LAB	8.9418

POST TEST AVERAGE **8.90**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.94

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.16	2.51	PASS
Post Test	8.90	-0.41	PASS

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
03/09/20	13:54:13	SPIKE_0408.LAB	47.9536
03/09/20	13:54:23	SPIKE_0409.LAB	48.0893
03/09/20	13:54:34	SPIKE_0410.LAB	48.0554
03/09/20	13:54:44	SPIKE_0411.LAB	48.0837
03/09/20	13:54:54	SPIKE_0412.LAB	48.2405

PRE TEST AVERAGE **48.08**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
03/09/20	19:34:52	UNIT2ND RUN1_0529.LAB	48.0999
03/09/20	19:35:23	UNIT2ND RUN1_0530.LAB	48.1780
03/09/20	19:35:53	UNIT2ND RUN1_0531.LAB	48.1290
03/09/20	19:36:23	UNIT2ND RUN1_0532.LAB	48.0657
03/09/20	19:36:53	UNIT2ND RUN1_0533.LAB	48.0589

POST TEST AVERAGE **48.11**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 50.40

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	48.08	-4.59	PASS
Post Test	48.11	-4.55	PASS

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd
03/09/20	13:53:42	SPIKE_0405.LAB	47.7809
03/09/20	13:53:52	SPIKE_0406.LAB	47.8611
03/09/20	13:54:03	SPIKE_0407.LAB	47.8723
03/09/20	13:54:13	SPIKE_0408.LAB	47.9536
03/09/20	13:54:23	SPIKE_0409.LAB	48.0893
03/09/20	13:54:34	SPIKE_0410.LAB	48.0554
03/09/20	13:54:44	SPIKE_0411.LAB	48.0837
03/09/20	13:54:54	SPIKE_0412.LAB	48.2405
RAW AVERAGE			**47.992**

Calibration Gas #2

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	SF_6 ppmvd
03/09/20	13:53:42	SPIKE_0405.LAB	9.7269
03/09/20	13:53:52	SPIKE_0406.LAB	9.7324
03/09/20	13:54:03	SPIKE_0407.LAB	9.7234
03/09/20	13:54:13	SPIKE_0408.LAB	9.7409
03/09/20	13:54:23	SPIKE_0409.LAB	9.7452
03/09/20	13:54:34	SPIKE_0410.LAB	9.7502
03/09/20	13:54:44	SPIKE_0411.LAB	9.7599
03/09/20	13:54:54	SPIKE_0412.LAB	9.7648
RAW AVERAGE			**9.743**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
03/09/20	14:11:10	SPIKE_0504.LAB	4.3427	6.7363	1.4308	0.0038
03/09/20	14:11:20	SPIKE_0505.LAB	4.3443	6.7328	1.3905	0.0040
03/09/20	14:11:31	SPIKE_0506.LAB	4.3472	6.7151	1.4359	0.0055
03/09/20	14:11:41	SPIKE_0507.LAB	4.3423	6.6539	1.4080	0.0044
03/09/20	14:11:52	SPIKE_0508.LAB	4.3514	6.5591	1.3615	0.0006
03/09/20	14:12:02	SPIKE_0509.LAB	4.3691	6.4441	1.3455	0.0043
03/09/20	14:12:12	SPIKE_0510.LAB	4.3811	6.3868	1.3463	0.0042
03/09/20	14:12:22	SPIKE_0511.LAB	4.3627	6.3898	1.3151	0.0024
RAW AVERAGE			**4.355**	**6.577**	**1.379**	**0.004**

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
03/09/20	14:18:24	SPIKE_0546.LAB	3.9544	6.1146	0.8793	4.5836
03/09/20	14:18:35	SPIKE_0547.LAB	3.9395	6.1224	0.8964	4.5124
03/09/20	14:18:45	SPIKE_0548.LAB	3.9503	6.1453	0.8953	4.4736
03/09/20	14:18:55	SPIKE_0549.LAB	3.9431	6.1733	0.8986	4.4263
03/09/20	14:19:06	SPIKE_0550.LAB	3.9468	6.1991	0.8976	4.4081
03/09/20	14:19:16	SPIKE_0551.LAB	3.9307	6.1724	0.8962	4.3876
03/09/20	14:19:26	SPIKE_0552.LAB	3.9409	6.1148	0.8945	4.3085
03/09/20	14:19:36	SPIKE_0553.LAB	3.9331	6.0627	0.8981	4.3190
RAW AVERAGE			**3.942**	**6.138**	**0.894**	**4.427**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
03/09/20	14:27:01	SPIKE_0596.LAB	4.2505	7.9140	1.6867	0.0027
03/09/20	14:27:11	SPIKE_0597.LAB	4.2539	7.9076	1.7241	0.0050
03/09/20	14:27:21	SPIKE_0598.LAB	4.2790	7.8449	1.6798	0.0023
03/09/20	14:27:32	SPIKE_0599.LAB	4.2658	7.7870	1.6623	0.0027
03/09/20	14:27:42	SPIKE_0600.LAB	4.2727	7.7503	1.6512	0.0013
03/09/20	14:27:52	SPIKE_0601.LAB	4.2744	7.7181	1.6616	0.0033
03/09/20	14:28:03	SPIKE_0602.LAB	4.2791	7.7011	1.6553	0.0046
03/09/20	14:28:13	SPIKE_0603.LAB	4.2631	7.9102	1.6437	0.0028
RAW AVERAGE			**4.267**	**7.817**	**1.671**	**0.003**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
03/09/20	14:46:08	SPIKE_0707.LAB	3.8520	8.1124	0.8035	4.8077
03/09/20	14:46:18	SPIKE_0708.LAB	3.8848	7.8650	0.7998	4.6513
03/09/20	14:46:28	SPIKE_0709.LAB	3.8762	7.7307	0.8035	4.6812
03/09/20	14:46:39	SPIKE_0710.LAB	3.8880	7.6559	0.8037	4.5874
03/09/20	14:46:49	SPIKE_0711.LAB	3.8983	7.5171	0.8036	4.5530
03/09/20	14:46:59	SPIKE_0712.LAB	3.9088	7.3068	0.7972	4.4767
03/09/20	14:47:10	SPIKE_0713.LAB	3.9011	7.1650	0.8025	4.4083
03/09/20	14:47:20	SPIKE_0714.LAB	3.9226	7.1113	0.8004	4.4259
RAW AVERAGE			**3.891**	**7.558**	**0.802**	**4.574**

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
03/09/20	14:53:32	SPIKE_0750.LAB	4.1550	9.4120	2.1136	0.0028
03/09/20	14:53:42	SPIKE_0751.LAB	4.1568	9.3515	2.1554	0.0039
03/09/20	14:53:53	SPIKE_0752.LAB	4.1743	9.2783	2.1189	0.0014
03/09/20	14:54:03	SPIKE_0753.LAB	4.1790	9.1890	2.0849	-0.0011
03/09/20	14:54:14	SPIKE_0754.LAB	4.1861	9.0972	2.1291	0.0034
03/09/20	14:54:24	SPIKE_0755.LAB	4.1829	9.0146	2.1246	0.0051
03/09/20	14:54:34	SPIKE_0756.LAB	4.2057	8.9412	2.1323	0.0045
03/09/20	14:54:44	SPIKE_0757.LAB	4.2154	8.8814	2.1108	0.0035
RAW AVERAGE			**4.182**	**9.146**	**2.121**	**0.003**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
03/09/20	15:03:52	SPIKE_0810.LAB	3.8999	7.1080	0.8270	4.9377
03/09/20	15:04:03	SPIKE_0811.LAB	3.8870	7.1844	0.8271	4.8873
03/09/20	15:04:13	SPIKE_0812.LAB	3.8870	7.2632	0.8277	4.8112
03/09/20	15:04:23	SPIKE_0813.LAB	3.8735	7.3758	0.8248	4.7575
03/09/20	15:04:33	SPIKE_0814.LAB	3.8649	7.6814	0.8272	4.7971
03/09/20	15:04:44	SPIKE_0815.LAB	3.8454	7.7866	0.8276	4.7845
03/09/20	15:04:54	SPIKE_0816.LAB	3.8593	7.9070	0.8299	4.7497
03/09/20	15:05:05	SPIKE_0817.LAB	3.8599	7.9467	0.8245	4.8081
RAW AVERAGE			**3.872**	**7.532**	**0.827**	**4.817**

Cricket Valley Energy Center LLC
March 9, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	47.99	47.99	47.99
Concentration of SF_6 Cylinder	ppmvd	9.74	9.74	9.74

Spike A

Stack CO_2 Concentration	%vd	4.355	4.267	4.182
Stack H_2O Concentration	%	6.577	7.817	9.146
Stack NH_3 Concentration	ppmvw	1.379	1.671	2.121
Stack SF_6 Concentration	ppmvw	0.004	0.003	0.003
Stack + Spike CO_2 Concentration	%vd	3.942	3.891	3.872
Stack + Spike H_2O Concentration	%	6.138	7.558	7.532
Stack + Spike NH_3 Concentration	ppmvw	4.427	4.574	4.817
Stack + Spike SF_6 Concentration	ppmvw	0.894	0.802	0.827
Dilution Ratio		0.098	0.089	0.092
Ideal NH_3 Spike Yield	ppmvd	6.026	5.923	6.526
Percent Recovery NH_3	%	72.11%	77.17%	70.11%

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
03/10/20	5:50:17	CAL20200310_0028.LAB	9.1098
03/10/20	5:50:27	CAL20200310_0029.LAB	9.1270
03/10/20	5:50:37	CAL20200310_0030.LAB	9.1523
03/10/20	5:50:48	CAL20200310_0031.LAB	9.1478
03/10/20	5:50:58	CAL20200310_0032.LAB	9.1373

PRE TEST AVERAGE **9.13**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
03/10/20	19:39:16	RUN20200310_1825.LAB	9.1629
03/10/20	19:39:27	RUN20200310_1826.LAB	9.1967
03/10/20	19:39:37	RUN20200310_1827.LAB	9.1198
03/10/20	19:39:47	RUN20200310_1828.LAB	9.1054
03/10/20	19:39:58	RUN20200310_1829.LAB	9.2130

POST TEST AVERAGE **9.16**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.94

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.13	2.18	PASS
Post Test	9.16	2.46	PASS

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
03/10/20	5:54:35	CAL20200310_0053.LAB	48.0507
03/10/20	5:54:45	CAL20200310_0054.LAB	48.0672
03/10/20	5:54:55	CAL20200310_0055.LAB	48.1462
03/10/20	5:55:06	CAL20200310_0056.LAB	48.1023
03/10/20	5:55:16	CAL20200310_0057.LAB	48.1750

PRE TEST AVERAGE **48.11**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
03/10/20	19:55:27	RUN20200310_1919.LAB	48.6194
03/10/20	19:55:38	RUN20200310_1920.LAB	48.6626
03/10/20	19:55:48	RUN20200310_1921.LAB	48.6869
03/10/20	19:55:59	RUN20200310_1922.LAB	48.9556
03/10/20	19:56:09	RUN20200310_1923.LAB	48.7549

POST TEST AVERAGE **48.74**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 50.40

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	48.11	-4.55	PASS
Post Test	48.74	-3.30	PASS

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd
03/10/20	5:53:43	CAL20200310_0048.LAB	47.4675
03/10/20	5:53:54	CAL20200310_0049.LAB	47.6681
03/10/20	5:54:04	CAL20200310_0050.LAB	47.7388
03/10/20	5:54:15	CAL20200310_0051.LAB	47.7531
03/10/20	5:54:25	CAL20200310_0052.LAB	47.9393
03/10/20	5:54:35	CAL20200310_0053.LAB	48.0507
03/10/20	5:54:45	CAL20200310_0054.LAB	48.0672
03/10/20	5:54:55	CAL20200310_0055.LAB	48.1462
RAW AVERAGE			**47.854**

Calibration Gas #2

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	SF_6 ppmvd
03/10/20	5:53:43	CAL20200310_0048.LAB	9.7913
03/10/20	5:53:54	CAL20200310_0049.LAB	9.7980
03/10/20	5:54:04	CAL20200310_0050.LAB	9.7928
03/10/20	5:54:15	CAL20200310_0051.LAB	9.7888
03/10/20	5:54:25	CAL20200310_0052.LAB	9.7935
03/10/20	5:54:35	CAL20200310_0053.LAB	9.7856
03/10/20	5:54:45	CAL20200310_0054.LAB	9.7838
03/10/20	5:54:55	CAL20200310_0055.LAB	9.7693
RAW AVERAGE			**9.788**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
03/10/20	6:02:30	CAL20200310_0099.LAB	4.3015	8.4797	0.9684	0.0020
03/10/20	6:02:41	CAL20200310_0100.LAB	4.3158	8.4360	0.9388	0.0005
03/10/20	6:02:51	CAL20200310_0101.LAB	4.3043	8.4200	0.9325	0.0012
03/10/20	6:03:01	CAL20200310_0102.LAB	4.3115	8.4585	0.9054	0.0016
03/10/20	6:03:12	CAL20200310_0103.LAB	4.3151	8.4352	0.9153	0.0048
03/10/20	6:03:22	CAL20200310_0104.LAB	4.3121	8.4805	0.8900	-0.0019
03/10/20	6:03:32	CAL20200310_0105.LAB	4.3096	8.4854	0.8705	0.0007
03/10/20	6:03:42	CAL20200310_0106.LAB	4.3010	8.7531	0.8786	0.0003
RAW AVERAGE			**4.309**	**8.494**	**0.912**	**0.001**

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
03/10/20	6:14:34	CAL20200310_0169.LAB	3.8837	8.6230	0.8386	4.8203
03/10/20	6:14:44	CAL20200310_0170.LAB	3.8784	8.6792	0.8421	4.7276
03/10/20	6:14:54	CAL20200310_0171.LAB	3.8687	8.6402	0.8419	4.5760
03/10/20	6:15:04	CAL20200310_0172.LAB	3.8740	8.5922	0.8359	4.5015
03/10/20	6:15:15	CAL20200310_0173.LAB	3.8902	8.5365	0.8398	4.4671
03/10/20	6:15:25	CAL20200310_0174.LAB	3.8869	8.4298	0.8398	4.4642
03/10/20	6:15:35	CAL20200310_0175.LAB	3.8814	8.3824	0.8389	4.4269
03/10/20	6:15:46	CAL20200310_0176.LAB	3.8805	8.3635	0.8391	4.3583
RAW AVERAGE			**3.880**	**8.531**	**0.840**	**4.543**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
03/10/20	6:24:02	CAL20200310_0224.LAB	4.3051	8.7971	1.5958	0.0003
03/10/20	6:24:12	CAL20200310_0225.LAB	4.3115	8.7306	1.5854	-0.0016
03/10/20	6:24:22	CAL20200310_0226.LAB	4.3261	8.6339	1.5257	-0.0027
03/10/20	6:24:33	CAL20200310_0227.LAB	4.3117	8.5664	1.5802	0.0018
03/10/20	6:24:44	CAL20200310_0228.LAB	4.3089	8.6480	1.5693	0.0010
03/10/20	6:24:54	CAL20200310_0229.LAB	4.2970	8.8186	1.5823	0.0019
03/10/20	6:25:04	CAL20200310_0230.LAB	4.3021	8.9058	1.5665	0.0003
03/10/20	6:25:14	CAL20200310_0231.LAB	4.2761	9.1412	1.5885	-0.0005
RAW AVERAGE			**4.305**	**8.780**	**1.574**	**0.000**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
03/10/20	6:36:15	CAL20200310_0295.LAB	3.9524	7.5613	0.8351	5.0092
03/10/20	6:36:26	CAL20200310_0296.LAB	3.9484	7.5978	0.8320	4.9628
03/10/20	6:36:36	CAL20200310_0297.LAB	3.9638	7.5180	0.8350	4.9963
03/10/20	6:36:47	CAL20200310_0298.LAB	3.9607	7.4574	0.8350	4.9615
03/10/20	6:36:57	CAL20200310_0299.LAB	3.9487	7.4233	0.8400	4.9970
03/10/20	6:37:07	CAL20200310_0300.LAB	3.9554	7.4886	0.8393	5.0146
03/10/20	6:37:18	CAL20200310_0301.LAB	3.9534	7.5352	0.8354	5.0378
03/10/20	6:37:28	CAL20200310_0302.LAB	3.9623	7.4953	0.8294	5.0133
RAW AVERAGE			**3.956**	**7.510**	**0.835**	**4.999**

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
03/10/20	6:53:29	CAL20200310_0395.LAB	4.2874	8.8630	1.9617	-0.0001
03/10/20	6:53:39	CAL20200310_0396.LAB	4.3052	8.7319	1.9673	-0.0006
03/10/20	6:53:50	CAL20200310_0397.LAB	4.2870	8.6017	1.9294	-0.0019
03/10/20	6:54:00	CAL20200310_0398.LAB	4.3082	8.5000	1.9315	-0.0018
03/10/20	6:54:10	CAL20200310_0399.LAB	4.3145	8.4517	1.8742	-0.0013
03/10/20	6:54:21	CAL20200310_0400.LAB	4.3054	8.3687	1.8920	-0.0008
03/10/20	6:54:31	CAL20200310_0401.LAB	4.3170	8.3016	1.8709	-0.0022
03/10/20	6:54:42	CAL20200310_0402.LAB	4.3359	8.2077	1.9219	0.0002
RAW AVERAGE			**4.308**	**8.503**	**1.919**	**-0.001**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
03/10/20	7:04:40	CAL20200310_0460.LAB	3.9266	7.9162	0.8387	5.8419
03/10/20	7:04:51	CAL20200310_0461.LAB	3.9146	7.9760	0.8396	5.8087
03/10/20	7:05:01	CAL20200310_0462.LAB	3.9187	7.9475	0.8394	5.7310
03/10/20	7:05:12	CAL20200310_0463.LAB	3.9118	8.0489	0.8402	5.7370
03/10/20	7:05:22	CAL20200310_0464.LAB	3.9044	8.0993	0.8401	5.6852
03/10/20	7:05:32	CAL20200310_0465.LAB	3.9116	8.0309	0.8368	5.5275
03/10/20	7:05:42	CAL20200310_0466.LAB	3.9182	8.0022	0.8419	5.4911
03/10/20	7:05:53	CAL20200310_0467.LAB	3.9259	7.9475	0.8400	5.4342
RAW AVERAGE			**3.916**	**7.996**	**0.840**	**5.657**

Cricket Valley Energy Center LLC
March 10, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	47.85	47.85	47.85
Concentration of SF_6 Cylinder	ppmvd	9.79	9.79	9.79

Spike A

Stack CO_2 Concentration	%vd	4.309	4.305	4.308
Stack H_2O Concentration	%	8.494	8.780	8.503
Stack NH_3 Concentration	ppmvw	0.912	1.574	1.919
Stack SF_6 Concentration	ppmvw	0.001	0.000	-0.001
Stack + Spike CO_2 Concentration	%vd	3.880	3.956	3.916
Stack + Spike H_2O Concentration	%	8.531	7.510	7.996
Stack + Spike NH_3 Concentration	ppmvw	4.543	4.999	5.657
Stack + Spike SF_6 Concentration	ppmvw	0.840	0.835	0.840
Dilution Ratio		0.094	0.092	0.093
Ideal NH_3 Spike Yield	ppmvd	5.391	5.981	6.363
Percent Recovery NH_3	%	90.54%	86.94%	95.20%

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	-0.02	-0.02
Final Zero	-0.01	0.02
Avg. Zero	-0.02	0.00
Initial UpScale	12.13	5.05
Final UpScale	12.02	4.83
Avg. UpScale	12.08	4.94
Sys Resp (Zero)	-0.01	0.00
Sys Resp (Upscale)	12.28	5.09
Upscale Cal Gas	11.97	4.91
Initial Zero Bias	-0.05%	-0.22%
Final Zero Bias	0.00%	0.22%
Zero Drift	0.05%	0.43%
Initial Upscale Bias	-0.71%	-0.43%
Final Upscale Bias	-1.24%	-2.83%
Upscale Drift	0.52%	2.39%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.02
Alternative Specification Abs Diff **Final Zero**	0.00	0.02
Alternative Specification Abs Diff **Initial Upscale**	0.15	0.04
Alternative Specification Abs Diff **Final Upscale**	0.26	0.26
Calibration Span	21.00	9.20
3% of Cal. Span (drift)	0.63	0.28
5% of Cal. Span (bias)	1.05	0.46

Respone Time (min)	1.3	2.0
Sys. Response (min)	2.0	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
02/25/20 06:05:32		13.44			1.36		x
02/25/20 06:05:42		13.38			1.35		
02/25/20 06:05:52		13.39			1.33		
02/25/20 06:06:02		13.39			1.34		
02/25/20 06:06:12		13.38			1.38		
02/25/20 06:06:22		8.55			1.38		
02/25/20 06:06:32		0.72			1.24		
02/25/20 06:06:42	x	**0.16**			2.29		
02/25/20 06:06:52		**0.11**			4.25		
02/25/20 06:07:02		**0.07**			**4.95**	x	
02/25/20 06:07:12		**0.05**			**4.89**		
02/25/20 06:07:22		**0.04**			**4.94**		
02/25/20 06:07:32		**0.02**			**4.91**		
02/25/20 06:07:42		**0.01**			**4.95**		
02/25/20 06:07:52		**0.01**			**4.94**		
02/25/20 06:08:02		**0.00**			**4.94**		x
02/25/20 06:08:12		**-0.01**			**4.94**		
02/25/20 06:08:22		**-0.01**			**4.94**		
02/25/20 06:08:32		**-0.02**			**4.94**		
02/25/20 06:08:42		**-0.03**			**4.92**		
02/25/20 06:08:52		**-0.02**			**4.89**		
02/25/20 06:09:02		**-0.03**			**4.94**		
02/25/20 06:09:12		5.12			**4.93**		
02/25/20 06:09:22		**11.55**	x		4.06		
02/25/20 06:09:32		**11.85**			3.07		
02/25/20 06:09:42		**11.89**			2.25		
02/25/20 06:09:52		**11.91**			0.84		
02/25/20 06:10:02		**11.93**		x	**0.12**		
02/25/20 06:10:12		**11.94**			**0.09**		
02/25/20 06:10:22		**11.95**			**0.05**		

DRIFT AND BIAS CHECK					
Base Load, Run - 1-1	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.97	2.08	0.19	0.00	4.24
Corrected Average	13.07	2.12	0.21	0.00	4.22
Initial Zero	0.11	-0.10	-0.01	-0.03	0.01
Final Zero	0.10	-0.05	-0.04	-0.04	-0.04
Avg. Zero	0.11	-0.08	-0.03	-0.04	-0.02
Initial UpScale	11.94	4.84	5.08	3.17	9.06
Final UpScale	11.89	4.93	5.07	3.23	8.92
Avg. UpScale	11.92	4.89	5.08	3.20	8.99
Sys Resp (Zero)	0.03	0.02	0.04	0.00	0.01
Sys Resp (Upscale)	12.00	5.05	5.04	3.43	9.15
Upscale Cal Gas	12.00	4.88	5.09	3.37	8.94
Initial Zero Bias	0.38%	-1.35%	-0.55%	-0.30%	0.01%
Final Zero Bias	0.33%	-0.79%	-0.88%	-0.39%	-0.26%
Zero Drift	0.05%	0.56%	0.33%	0.10%	0.26%
Initial Upscale Bias	-0.29%	-2.36%	0.44%	-2.48%	-0.47%
Final Upscale Bias	-0.52%	-1.35%	0.33%	-1.90%	-1.21%
Upscale Drift	0.24%	1.01%	0.11%	0.57%	0.74%
Alternative Specification Abs Diff **Initial Zero**	0.08	0.12	0.05	--	0.00
Alternative Specification Abs Diff **Final Zero**	0.07	0.07	0.08	--	0.05
Alternative Specification Abs Diff **Initial Upscale**	0.06	0.21	0.04	--	0.09
Alternative Specification Abs Diff **Final Upscale**	0.11	0.12	0.03	--	0.23
Calibration Span	21.00	8.90	9.11	10.50	19.00
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base Load, Run - 1-2	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.97	2.17	0.20	0.01	4.74
Corrected Average	13.10	2.14	0.22	0.01	4.75
Initial Zero	0.10	-0.05	-0.04	-0.04	-0.04
Final Zero	0.11	0.09	0.01	0.05	0.00
Avg. Zero	0.11	0.02	-0.02	0.00	-0.02
Initial UpScale	11.89	4.93	5.07	3.23	8.92
Final UpScale	11.89	4.91	5.03	3.32	8.96
Avg. UpScale	11.89	4.92	5.05	3.28	8.94
Sys Resp (Zero)	0.03	0.02	0.04	0.00	0.01
Sys Resp (Upscale)	12.00	5.05	5.04	3.43	9.15
Upscale Cal Gas	12.00	4.88	5.09	3.37	8.94
Initial Zero Bias	0.33%	-0.79%	-0.88%	-0.39%	-0.26%
Final Zero Bias	0.38%	0.79%	-0.33%	0.43%	-0.05%
Zero Drift	0.05%	1.57%	0.55%	0.82%	0.21%
Initial Upscale Bias	-0.52%	-1.35%	0.33%	-1.90%	-1.21%
Final Upscale Bias	-0.52%	-1.57%	-0.11%	-1.05%	-1.00%
Upscale Drift	0.00%	0.22%	0.44%	0.86%	0.21%
Alternative Specification Abs Diff **Initial Zero**	0.07	0.07	0.08	--	0.05
Alternative Specification Abs Diff **Final Zero**	0.08	0.07	0.03	--	0.01
Alternative Specification Abs Diff **Initial Upscale**	0.11	0.12	0.03	--	0.23
Alternative Specification Abs Diff **Final Upscale**	0.11	0.14	0.01	--	0.19
Calibration Span	21.00	8.90	9.11	10.50	19.00
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base Load, Run - 1-3	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.90	1.96	0.16	-0.04	4.39
Corrected Average	13.04	1.94	0.15	0.00	4.42
Initial Zero	0.11	0.09	0.01	0.05	0.00
Final Zero	0.09	-0.06	0.00	0.05	-0.03
Avg. Zero	0.10	0.02	0.01	0.05	-0.02
Initial UpScale	11.89	4.91	5.03	3.32	8.96
Final UpScale	11.86	4.93	5.05	3.21	8.85
Avg. UpScale	11.88	4.92	5.04	3.27	8.91
Sys Resp (Zero)	0.03	0.02	0.04	0.00	0.01
Sys Resp (Upscale)	12.00	5.05	5.04	3.43	9.15
Upscale Cal Gas	12.00	4.88	5.09	3.37	8.94
Initial Zero Bias	0.38%	0.79%	-0.33%	0.43%	-0.05%
Final Zero Bias	0.29%	-0.90%	-0.44%	0.47%	-0.21%
Zero Drift	0.10%	1.69%	0.11%	0.04%	0.16%
Initial Upscale Bias	-0.52%	-1.57%	-0.11%	-1.05%	-1.00%
Final Upscale Bias	-0.67%	-1.35%	0.11%	-2.10%	-1.58%
Upscale Drift	0.14%	0.22%	0.22%	1.05%	0.58%
Alternative Specification Abs Diff **Initial Zero**	0.08	0.07	0.03	--	0.01
Alternative Specification Abs Diff **Final Zero**	0.06	0.08	0.04	--	0.04
Alternative Specification Abs Diff **Initial Upscale**	0.11	0.14	0.01	--	0.19
Alternative Specification Abs Diff **Final Upscale**	0.14	0.12	0.01	--	0.30
Calibration Span	21.00	8.90	9.11	10.50	19.00
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-1	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.04	2.43	0.17	-0.03	5.02
Corrected Average	12.07	2.42	0.21	0.00	5.07
Initial Zero	0.06	-0.05	0.03	0.02	0.04
Final Zero	0.07	0.09	-0.10	-0.04	0.00
Avg. Zero	0.07	0.02	-0.04	-0.01	0.02
Initial UpScale	11.96	4.86	5.05	3.40	8.80
Final UpScale	11.98	4.88	4.98	3.30	8.87
Avg. UpScale	11.97	4.87	5.02	3.35	8.83
Sys Resp (Zero)	-0.03	-0.02	-0.08	-0.05	-0.09
Sys Resp (Upscale)	12.07	4.88	5.08	3.26	9.06
Upscale Cal Gas	12.00	4.88	5.09	3.37	8.94
Initial Zero Bias	0.43%	-0.34%	1.21%	0.62%	0.68%
Final Zero Bias	0.48%	1.24%	-0.22%	0.05%	0.47%
Zero Drift	0.05%	1.57%	1.43%	0.57%	0.21%
Initial Upscale Bias	-0.52%	-0.22%	-0.33%	1.33%	-1.37%
Final Upscale Bias	-0.43%	0.00%	-1.10%	0.38%	-1.02%
Upscale Drift	0.10%	0.22%	0.77%	0.95%	0.35%
Alternative Specification Abs Diff **Initial Zero**	0.09	0.03	0.11	--	0.13
Alternative Specification Abs Diff **Final Zero**	0.10	0.11	0.02	--	0.09
Alternative Specification Abs Diff **Initial Upscale**	0.11	0.02	0.03	--	0.26
Alternative Specification Abs Diff **Final Upscale**	0.09	0.00	0.10	--	0.19
Calibration Span	21.00	8.90	9.11	10.50	19.00
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-2	O_2	NOx	CO	VOC (as C1)	CO_2
Raw Average	12.01	2.57	0.12	-0.01	5.00
Corrected Average	11.98	2.52	0.21	0.00	5.06
Initial Zero	0.07	0.09	-0.10	-0.04	0.00
Final Zero	0.08	0.06	-0.07	-0.04	-0.01
Avg. Zero	0.08	0.08	-0.09	-0.04	-0.01
Initial UpScale	11.98	4.88	4.98	3.30	8.87
Final UpScale	12.08	4.94	5.02	3.32	8.82
Avg. UpScale	12.03	4.91	5.00	3.31	8.84
Sys Resp (Zero)	-0.03	-0.02	-0.08	-0.05	-0.09
Sys Resp (Upscale)	12.07	4.88	5.08	3.26	9.06
Upscale Cal Gas	12.00	4.88	5.09	3.37	8.94
Initial Zero Bias	0.48%	1.24%	-0.22%	0.05%	0.47%
Final Zero Bias	0.52%	0.90%	0.11%	0.05%	0.42%
Zero Drift	0.05%	0.34%	0.33%	0.00%	0.05%
Initial Upscale Bias	-0.43%	0.00%	-1.10%	0.38%	-1.02%
Final Upscale Bias	0.05%	0.67%	-0.66%	0.57%	-1.26%
Upscale Drift	0.48%	0.67%	0.44%	0.19%	0.25%
Alternative Specification Abs Diff: Initial Zero	0.10	0.11	0.02	--	0.09
Alternative Specification Abs Diff: Final Zero	0.11	0.08	0.01	--	0.08
Alternative Specification Abs Diff: Initial Upscale	0.09	0.00	0.10	--	0.19
Alternative Specification Abs Diff: Final Upscale	0.01	0.06	0.06	--	0.24
Calibration Span	21.00	8.90	9.11	10.50	19.00
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-3	O_2	NOx	CO	VOC (as C1)	CO_2
Raw Average	11.99	2.66	0.14	-0.01	5.03
Corrected Average	11.95	2.54	0.21	0.00	5.08
Initial Zero	0.08	0.06	-0.07	-0.04	-0.01
Final Zero	0.07	0.06	-0.06	-0.04	-0.03
Avg. Zero	0.08	0.06	-0.07	-0.04	-0.02
Initial UpScale	12.08	4.94	5.02	3.32	8.82
Final UpScale	12.01	5.17	5.03	3.21	8.94
Avg. UpScale	12.04	5.06	5.03	3.27	8.88
Sys Resp (Zero)	-0.03	-0.02	-0.08	-0.05	-0.09
Sys Resp (Upscale)	12.07	4.88	5.08	3.26	9.06
Upscale Cal Gas	12.00	4.88	5.09	3.37	8.94
Initial Zero Bias	0.52%	0.90%	0.11%	0.05%	0.42%
Final Zero Bias	0.48%	0.90%	0.22%	0.05%	0.32%
Zero Drift	0.05%	0.00%	0.11%	0.00%	0.11%
Initial Upscale Bias	0.05%	0.67%	-0.66%	0.57%	-1.26%
Final Upscale Bias	-0.31%	3.26%	-0.55%	-0.48%	-0.63%
Upscale Drift	0.36%	2.58%	0.11%	1.05%	0.63%
Alternative Specification Abs Diff: Initial Zero	0.11	0.08	0.01	--	0.08
Alternative Specification Abs Diff: Final Zero	0.10	0.08	0.02	--	0.06
Alternative Specification Abs Diff: Initial Upscale	0.01	0.06	0.06	--	0.24
Alternative Specification Abs Diff: Final Upscale	0.06	0.29	0.05	--	0.12
Calibration Span	21.00	8.90	9.11	10.50	19.00
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

SINGLE LOAD TEST - FIELD DATA SHEET

AIR HYGIENE

Company:	Bechtel		
Location:	Cricket Valley, New York		
Date:	3/9/2020	**Project Code:**	bec-19-cricketvalley.ny-start#2
Unit Make and Model:			
Unit Number:			
Serial Number:			
Data Recorded By:			
Tested With AHI Unit(s):	**Truck(s):** 163	**Trailer(s):**	215
LDEQ Warmup/Cal Req:	**On (Day/Time):**	**Cal (Day/Time):**	

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0072934	EB0072934	EB0072934
	Mid	CC729922	EB0065964	EB0065964
	High	CC721614	EB0040961	EB0040961

Stack Dia. = _____
Measured By: _____
Measured With: _____

CYLINDER SERIAL NUMBERS		THC	CO_2	SO_2
	Low	EB0057200	EB0072934	N/a
	Mid	EB0060640	CC729922	N/a
	High	EB0038438	CC721614	N/a

RUN INFORMATION	**Load**		
	_____% #1	_____% #2	_____% #3
Time Start (hh:mm:ss)	14:44:11	16:05:11	17:18:11
Time Stop (hh:mm:ss)	15:43:41	17:04:41	18:17:41
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)			
Ambient Temperature (°F)			
Relative Humidity (%)			
Fuel Flow (lb/min)			
Fuel Flow (SCF/hr)=(lb/min)*21.7			
Specific Humidity (gr/lb)			
Spec. Hum. (lb H_2O/lb air)=(gr/lb)/7000			
PCD (psi)			
PCD (mm Hg)=(psi+14.24)*51.71493			
NOx Water Injection (gpm)			

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	1.34
NOx Reading (ppm)	47.15
Cylinder Num	EB0098845

REPORT INFORMATION		
	INSTRUMENT	**SERIAL #**
O_2	Sevromex 1440	Inst-O2-0024
NOx	Thermo 42c	Inst-Nx-0031
CO	Thermo 48c	Inst-Co-0029
THC	Thermo 51i	Inst-Th-0013
CO_2	Sevromex 1440	Inst-C2-0016
SO_2	N/a	N/a

RESPONSE TIME		
	TIME (hh:mm)	**RESP (min)**
1st Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
2nd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
3rd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		

CALIBRATION	O_2		NOx		CO		THC		CO_2		SO_2	
	Conc.	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**
Zero Gas	0	0.03	0	0.02	0	0.04	0	0	0	0.01	N/a	N/a
Low Gas	N/a	N/a	N/a	N/a	N/a	N/a	3.37	3.43	N/a	N/a	N/a	N/a
Mid Gas	12	12	4.9	5.05	5.09	5.04	4.9	4.73	8.94	9.15	N/a	N/a
High Gas	21	20.95	8.9	9.02	9.1	9.11	8.77	8.82	19	19	N/a	N/a

BIAS	O_2		NOx		CO		THC		CO_2		SO_2	
	Zero	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**
Initial Run #1	0.11	11.94	-0.1	4.84	-0.01	5.08	-0.01	3.17	0.01	9.06	N/a	N/a
Run #1 / Run #2	0.1	11.89	-0.05	4.93	-0.04	5.07	-0.04	3.23	-0.04	8.92	N/a	N/a
Run #2 / Run #3	0.11	11.89	0.09	4.91	0.01	5.03	0.05	3.32	0	8.96	N/a	N/a
Run #3 / Final	0.09	11.86	-0.06	4.93	0	5.05	0.05	3.21	-0.03	8.85	N/a	N/a
Bias Gas Actual Conc.		12		4.9		5.09		3.37		8.94		N/a

Signature _____

SINGLE LOAD TEST - FIELD DATA SHEET

AIR HYGIENE

Company:	Bechtel		
Location:	Cricket Valley, New York		
Date:	3/10/2020	**Project Code:**	bec-19-cricketvalley.ny-start#2
Unit Make and Model:			
Unit Number:			
Serial Number:			
Data Recorded By:			
Tested With AHI Unit(s):	**Truck(s):** 163	**Trailer(s):**	215
LDEQ Warmup/Cal Req:	**On (Day/Time):**	**Cal (Day/Time):**	

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0072934	EB0072934	EB0072934
	Mid	CC729922	EB0065964	EB0065964
	High	CC721614	EB0040961	EB0040961

CYLINDER SERIAL NUMBERS		THC	CO_2	SO_2
	Low	EB0057200	EB0072934	N/a
	Mid	EB0060640	CC729922	N/a
	High	EB0038438	CC721614	N/a

Stack Dia. = _____
Measured By: _____
Measured With: _____

RUN INFORMATION	**Load**		
	_____% #1	_____% #2	_____% #3
Time Start (hh:mm:ss)	15:27:20	17:35:20	18:35:20
Time Stop (hh:mm:ss)	16:26:50	18:34:50	19:34:50
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)			
Ambient Temperature (°F)			
Relative Humidity (%)			
Fuel Flow (lb/min)			
Fuel Flow (SCF/hr)=(lb/min)*21.7			
Specific Humidity (gr/lb)			
Spec. Hum. (lb H_2O/lb air)=(gr/lb)/7000			
PCD (psi)			
PCD (mm Hg)=(psi+14.24)*51.71493			
NOx Water Injection (gpm)			

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	1.13
NOx Reading (ppm)	49.17
Cylinder Num	EB0098845

REPORT INFORMATION		
	INSTRUMENT	**SERIAL #**
O_2	Sevromex 1440	Inst-O2-0024
NOx	Thermo 42c	Inst-Nx-0031
CO	Thermo 48c	Inst-Co-0029
THC	Thermo 51i	Inst-Th-0013
CO_2	Sevromex 1440	Inst-C2-0016
SO_2	N/a	N/a

RESPONSE TIME		
	TIME (hh:mm)	**RESP (min)**
1st Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
2nd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
3rd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		

CALIBRATION	O_2		NOx		CO		THC		CO_2		SO_2	
	Conc.	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**
Zero Gas	0	-0.03	0	-0.02	0	-0.08	0	-0.05	0	-0.9	N/a	N/a
Low Gas	N/a	N/a	N/a	N/a	N/a	N/a	3.37	3.26	N/a	N/a	N/a	N/a
Mid Gas	12	12.07	4.9	4.88	5.09	5.08	4.9	4.74	8.94	9.06	N/a	N/a
High Gas	21	21.17	8.9	8.86	9.1	8.65	8.77	8.67	19	19	N/a	N/a

BIAS	O_2		NOx		CO		THC		CO_2		SO_2	
	Zero	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**
Initial Run #1	0.06	11.96	-0.05	4.86	0.03	5.05	0.03	3.4	0.04	8.8	N/a	N/a
Run #1 / Run #2	0.07	11.98	0.09	4.88	-0.1	4.98	-0.1	3.3	0	8.87	N/a	N/a
Run #2 / Run #3	0.08	12.08	0.06	4.94	-0.07	5.02	-0.04	3.32	-0.01	8.82	N/a	N/a
Run #3 / Final	0.07	12.01	0.06	5.17	-0.06	5.03	-0.04	3.21	-0.03	8.94	N/a	N/a
Bias Gas Actual Conc.		12		4.9		5.09		3.37		8.94		N/a

Signature _____

SINGLE LOAD TEST - FIELD DATA SHEET

AIR HYGIENE

Company:	Bechtel		
Location:	Cricket Valley, New York		
Date:	3/11/2020	**Project Code:**	bec-19-cricketvalley.ny-start#2
Unit Make and Model:			
Unit Number:			
Serial Number:			
Data Recorded By:			
Tested With AHI Unit(s):	**Truck(s):** 163	**Trailer(s):**	215
LDEQ Warmup/Cal Req:	**On (Day/Time):**	**Cal (Day/Time):**	

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0072934	EB0072934	EB0072934
	Mid	CC729922	EB0065964	EB0065964
	High	CC721614	EB0040961	EB0040961

Stack Dia. = _____
Measured By: _____
Measured With: _____

CYLINDER SERIAL NUMBERS		THC	CO_2	SO_2
	Low	EB0057200	EB0072934	N/a
	Mid	EB0003761	CC729922	N/a
	High	EB0038438	CC721614	N/a

RUN INFORMATION	**Load**		
	_____% #1	_____% #2	_____% #3
Time Start (hh:mm:ss)			
Time Stop (hh:mm:ss)			
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)			
Ambient Temperature (°F)			
Relative Humidity (%)			
Fuel Flow (lb/min)			
Fuel Flow (SCF/hr)=(lb/min)*21.7			
Specific Humidity (gr/lb)			
Spec. Hum. (lb H_2O/lb air)=(gr/lb)/7000			
PCD (psi)			
PCD (mm Hg)=(psi+14.24)*51.71493			
NOx Water Injection (gpm)			

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	
NOx Reading (ppm)	
Cylinder Num	EB0098845

REPORT INFORMATION		
	INSTRUMENT	**SERIAL #**
O_2	Sevromex 1440	Inst-O2-0024
NOx	Thermo 42c	Inst-Nx-0031
CO	Thermo 48c	Inst-Co-0029
THC	Thermo 51i	Inst-Th-0013
CO_2	Sevromex 1440	Inst-C2-0016
SO_2	N/a	N/a

RESPONSE TIME		
	TIME (hh:mm)	**RESP (min)**
1st Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
2nd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
3rd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		

CALIBRATION	O_2		NOx		CO		THC		CO_2		SO_2	
	Conc.	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**
Zero Gas	0	0	0		0		0		0	-0.08	N/a	N/a
Low Gas	N/a	N/a	N/a	N/a	N/a	N/a	3.37		N/a	N/a	N/a	N/a
Mid Gas	12	12.05	4.91		5.09		4.84		8.94	9.03	N/a	N/a
High Gas	21	21.18	8.9		9.1		8.77		19	19.09	N/a	N/a

BIAS	O_2		NOx		CO		THC		CO_2		SO_2	
	Zero	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**
Initial Run #1	0.1	12.02							0.12	9.07	N/a	N/a
Run #1 / Run #2	0.09	11.99							0.07	9.14	N/a	N/a
Run #2 / Run #3											N/a	N/a
Run #3 / Final											N/a	N/a
Bias Gas Actual Conc.												N/a

Signature _____

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data Summary Base Load PM_{10}

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	03/09/20
Sampling Location	U-00002 Base	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#2		

Run History Data				
Run Number	PM U-00002 Base-1	PM U-00002 Base-2	PM U-00002 Base-3	
Run Start Time	08:15	13:30	07:23	(hh:mm)
Run Stop Time	13:16	19:48	12:15	(hh:mm)
Train Prepared By	RW	RW	RW	
Train Recovered By	RW	RW	RW	
Recovery Date	03/09/20	03/09/20	03/10/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	03/12/20	03/12/20	03/12/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039
Sample Box	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099
PM Filter	19031822	19031835	19031823
CPM Filter	PM U-00002 Base-1-CPM	PM U-00002 Base-2-CPM	PM U-00002 Base-3-CPM

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	1761.6	1809.2	1770.5	g
Initial Weight	(W_i)	1597.6	1664.0	1629.9	g
Net Weight	(W_n)	164.0	145.2	140.6	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	868.7	849.2	892.0	g
Initial Weight	(W_i)	837.0	825.2	868.7	g
Net Weight	(W_n)	31.7	24.0	23.3	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	195.7	169.2	163.9	g
Total Volume	(V_{lc})	196.1	169.5	164.2	ml

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base-1		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

Gravimetric Concentrations			**Run**		1	**Start Time**	08:15
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.6000	--	--	0.6000	
Filter Beaker				--	--		
Nozzle Wash PM>10			9.1	61	0.0000	9.1000	
Cyclone Wash 2.5<PM<10			0.8	65	0.0000	0.8000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.3	62	0.0000	1.3000	
Inorganic Impinger Contents			1.7	381	1.4762	0.2238	
Organic Impinger Contents			6.7	410	0.5238	6.1762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base-2		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL

Gravimetric Concentrations			**Run**		2	**Start Time**	13:30
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.2	87	0.0000	1.2000	
Cyclone Wash 2.5<PM<10			1.0	67	0.0000	1.0000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.8	79	0.0000	1.8000	
Inorganic Impinger Contents			2.2	461	1.4762	0.7238	
Organic Impinger Contents			6.5	410	0.5238	5.9762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base-3		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL

Gravimetric Concentrations			**Run**		3	**Start Time**	07:23
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			14.9	75	0.0000	14.9000	
Cyclone Wash 2.5<PM<10			0.6	56	0.0000	0.6000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.8	80	0.0000	0.8000	
Inorganic Impinger Contents			2.7	461	1.4762	1.2238	
Organic Impinger Contents			5.2	410	0.5238	4.6762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base-FB		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Gravimetric Concentrations					
Sample Portion	**Final**	**Tare**	**Gain**		**Actual Gain**
	(g)	(g)	(mg)		(mg)
Inorganic Impinger Contents	0.0031	0.0000	1.4762	max 2 mg total blank adjustment, proportioned	3.1000
Organic Impinger Contents	0.0011	0.0000	0.5238		1.1000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data Summary Base+DB Load PM_{10}

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	03/10/20
Sampling Location	U-00002 Base+DB	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#2		

Run History Data				
Run Number	PM U-00002 Base+DB-1	PM U-00002 Base+DB-2	PM U-00002 Base+DB-3	
Run Start Time	14:12	06:23	12:30	(hh:mm)
Run Stop Time	18:40	11:17	17:15	(hh:mm)
Train Prepared By	RW	RW	RW	
Train Recovered By	RW	RW	RW	
Recovery Date	03/10/20	03/11/20	03/11/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	03/12/20	03/12/20	03/12/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039
Sample Box	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099
PM Filter	19031837	19031838	19031825
CPM Filter	PM U-00002 Base+DB-1-CPM	PM U-00002 Base+DB-2-CPM	PM U-00002 Base+DB-3-CPM

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	1882.5	1854.0	1935.6	g
Initial Weight	(W_i)	1696.2	1628.5	1725.6	g
Net Weight	(W_n)	186.3	225.5	210.0	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	868.3	912.1	888.8	g
Initial Weight	(W_i)	848.5	891.6	868.3	g
Net Weight	(W_n)	19.8	20.5	20.5	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	206.1	246.0	230.5	g
Total Volume	(V_{lc})	206.5	246.4	230.9	ml

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base+DB-1		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

Gravimetric Concentrations			**Run**		1	**Start Time**	14:12
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			1.2000	--	--	1.2000	
Filter Beaker				--	--		
Nozzle Wash PM>10			10.8	96	0.0000	10.8000	
Cyclone Wash 2.5<PM<10			0.8	88	0.0000	0.8000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.9	86	0.0000	0.9000	
Inorganic Impinger Contents			2.0	451	1.4762	0.5238	
Organic Impinger Contents			4.9	364	0.5238	4.3762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base+DB-2		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL

Gravimetric Concentrations			**Run**		2	**Start Time**	06:23
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			7.4	85	0.0000	7.4000	
Cyclone Wash 2.5<PM<10			0.6	86	0.0000	0.6000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.0	89	0.0000	1.0000	
Inorganic Impinger Contents			1.7	481	1.4762	0.2238	
Organic Impinger Contents			3.6	288	0.5238	3.0762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base+DB-3		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL

Gravimetric Concentrations			**Run**		3	**Start Time**	12:30
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			6.5	68	0.0000	6.5000	
Cyclone Wash 2.5<PM<10			0.7	59	0.0000	0.7000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			0.9	97	0.0000	0.9000	
Inorganic Impinger Contents			1.8	421	1.4762	0.3238	
Organic Impinger Contents			6.6	395	0.5238	6.0762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00002 Base+DB
Project #	bec-19-cricketvalley.ny-start#2

Analytical Data		**Run**	PM U-00002 Base+DB-FB		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Gravimetric Concentrations					
Sample Portion	**Final**	**Tare**	**Gain**		**Actual Gain**
	(g)	(g)	(mg)		(mg)
Inorganic Impinger Contents	0.0031	0.0000	1.4762	max 2 mg total blank adjustment, proportioned	3.1000
Organic Impinger Contents	0.0011	0.0000	0.5238		1.1000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Field Collection Data QA SAM

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	03/09/20
Sampling Location	U-00002 Base	**Operator**	TW
Project #	bec-19-cricketvalley.ny-start#2		

Run History Data				
Run Number	SAM U-00002 Base-1	SAM U-00002 Base-2	SAM U-00002 Base-3	
Run Start Time	08:06	11:49	15:17	(hh:mm)
Run Stop Time	10:06	13:49	17:17	(hh:mm)
Train Prepared By	AM	AM	AM	
Train Recovered By	AM	AM	AM	
Recovery Date	03/09/20	03/09/20	03/09/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	03/12/20	03/12/20	03/12/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	samp-ha-0005	samp-ha-0005	samp-ha-0005
Sample Box	samp-bc-0032	samp-bc-0032	samp-bc-0032
Filter	R0001	R0001	R0001

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	2115.2	2185.1	2242.6	g
Initial Weight	(W_i)	2052.1	2115.2	2185.1	g
Net Weight	(W_n)	63.1	69.9	57.5	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	971.6	918.0	925.3	g
Initial Weight	(W_i)	963.3	905.8	918.0	g
Net Weight	(W_n)	8.3	12.2	7.3	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	71.4	82.1	64.8	g
Total Volume	(V_{lc})	71.5	82.2	64.9	ml

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	03/11/20
Sampling Location	U-00002 Base+DB	**Operator**	TW
Project #	bec-19-cricketvalley.ny-start#2		

Run History Data				
Run Number	SAM U-00002 Base+DB-1	SAM U-00002 Base+DB-2	SAM U-00002 Base+DB-3	
Run Start Time	05:46	08:40	11:33	(hh:mm)
Run Stop Time	07:46	10:40	13:33	(hh:mm)
Train Prepared By	TW	TW	TW	
Train Recovered By	TW	TW	TW	
Recovery Date	03/11/20	03/11/20	03/11/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	03/12/20	03/12/20	03/12/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	samp-ha-0005	samp-ha-0005	samp-ha-0005
Sample Box	samp-bc-0032	samp-bc-0032	samp-bc-0032
Filter	R0001	R0001	R0001

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	2127.8	2193.9	2255.5	g
Initial Weight	(W_i)	2071.0	2127.8	2193.9	g
Net Weight	(W_n)	56.8	66.1	61.6	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	933.7	942.0	948.8	g
Initial Weight	(W_i)	925.3	933.7	942.0	g
Net Weight	(W_n)	8.4	8.3	6.8	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	65.2	74.4	68.4	g
Total Volume	(V_{lc})	65.3	74.5	68.5	ml

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data PM_{10} and SAM
BV Labs

Your Project #: BEC-19-CRICKETVALLEY.NY-START

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/27
Report #: R6126806
Version: 2 - Revision

CERTIFICATE OF ANALYSIS – REVISED REPORT

BV LABS JOB #: C067891
Received: 2020/03/12, 21:30

Sample Matrix: Stack Sampling Train
Samples Received: 18

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Extractable Condensables (M202)	6	2020/03/16	2020/03/19	BRL SOP-00118	EPA 202 m
Non Extractable Condensibles (M202)	6	2020/03/16	2020/03/19	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
>10um Particulates in Rinse	6	2020/03/16	2020/03/18	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	6	2020/03/16	2020/03/18	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	6	N/A	2020/03/16	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	6	2020/03/16	2020/03/18	BRL SOP-00109	EPA M201A
H2SO4 Acid Mist in IPA Impinger (M8mod)	5	2020/03/17	2020/03/17	BRL SOP-00105	EPA 8 m
H2SO4 Acid Mist in IPA Impinger (M8mod)	1	2020/03/20	2020/03/20	BRL SOP-00105	EPA 8 m
Sulphuric Acid Mist by Titration (M8A)	6	2020/03/27	2020/03/27	BRL SOP-00116	EPA CFR PTM 8 m
Final Volume of Acetone Probe Rinse	6	N/A	2020/03/16	BRL SOP-00109	
Final Volume of Impinger	6	N/A	2020/03/19		
Weight of Solvent from Impingers	6	N/A	2020/03/16		
Weight of Water from Impingers	6	N/A	2020/03/16		

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.
Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

Your Project #: BEC-19-CRICKETVALLEY.NY-START

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/27
Report #: R6126806
Version: 2 - Revision

CERTIFICATE OF ANALYSIS – REVISED REPORT

BV LABS JOB #: C067891
Received: 2020/03/12, 21:30

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key

Marinela Sim
Project Manager
27 Mar 2020 18:41:51

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: Clayton.Johnson@bvlabs.com
Phone# (905)817-5769

==========

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

BV Labs ID		MFT289	MFT290	MFT291		
Sampling Date		2020/03/10	2020/03/11	2020/03/11		
	UNITS	M201A- U2 BASE W/DB- R1	M201A- U2 BASE W/DB- R2	M201A- U2 BASE W/DB- R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	10.8	7.4	6.5	0.5	6637962
< 2.5 Particulate Weight in Acetone Rinse	mg	0.9	1.0	0.9	0.5	6637939
2.5 - 10 Particulate Weight in Acetone Rinse	mg	0.8	0.6	0.7	0.5	6637959
< 2.5 Particulate Weight on Filter	mg	1.20	<0.30	<0.30	0.30	6637643
Acetone Rinse Volume (10)	ml	96	85	68	1	6637965
Acetone Rinse Volume (2.5 - 10)	ml	88	86	59	1	6637965
Acetone Rinse Volume (2.5)	ml	86	89	97	1	6637965

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MFT292	MFT293	MFT294		
Sampling Date		2020/03/09	2020/03/09	2020/02/19		
	UNITS	M201A- U2 BASE-R1	M201A- U2 BASE-R2	M201A- U2 BASE-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	9.1	1.2	14.9	0.5	6637962
< 2.5 Particulate Weight in Acetone Rinse	mg	1.3	1.8	0.8	0.5	6637939
2.5 - 10 Particulate Weight in Acetone Rinse	mg	0.8	1.0	0.6	0.5	6637959
< 2.5 Particulate Weight on Filter	mg	0.60	<0.30	<0.30	0.30	6637643
Acetone Rinse Volume (10)	ml	61	87	75	1	6637965
Acetone Rinse Volume (2.5 - 10)	ml	65	67	56	1	6637965
Acetone Rinse Volume (2.5)	ml	62	79	80	1	6637965

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

BV Labs ID		MFT282	MFT283	MFT284		
Sampling Date		2020/03/10	2020/03/11	2020/03/11		
	UNITS	M202- U2 BASE W/DB-R1	M202- U2 BASE W/DB-R2	M202- U2 BASE W/DB-R3	RDL	QC Batch
Weight	g	450	480	420	0.1	6637919
Weight of Solvent	g	240	190	260	0.1	6637918
Miscellaneous Parameters						
Inorganic Condensibles	mg	2.0	1.7	1.8	0.5	6637921
Organic Condensibles	mg	4.9	3.6	6.6	1.0	6637916

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MFT285	MFT286	MFT287		
Sampling Date		2020/03/09	2020/03/09	2020/02/19		
	UNITS	M202- U2 BASE-R1	M202- U2 BASE-R2	M202- U2 BASE-R3	RDL	QC Batch
Weight	g	380	460	460	0.1	6637919
Weight of Solvent	g	270	270	270	0.1	6637918
Miscellaneous Parameters						
Inorganic Condensibles	mg	1.7	2.2	2.7	0.5	6637921
Organic Condensibles	mg	6.7	6.5	5.2	1.0	6637916

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

BV Labs ID		MFT295	MFT296	MFT296		
Sampling Date		2020/03/11	2020/03/11	2020/03/11		
	UNITS	M8A- U1 BASE W/DB-R1	M8A- U1 BASE W/DB-R2	M8A- U1 BASE W/DB-R2 Lab-Dup	RDL	QC Batch
Impinger Volume	ml	154	160	N/A	1	6644533
Miscellaneous Parameters						
Sulphuric Acid Mist	mg	0.027	<0.016	<0.016	0.016	6639735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

BV Labs ID		MFT297			MFT298	MFT298		
Sampling Date		2020/03/11			2020/03/09	2020/03/09		
	UNITS	M8A- U1 BASE W/DB-R3	RDL	QC Batch	M8A- U2 BASE- R1 -CW	M8A- U2 BASE- R1 -CW Lab-Dup	RDL	QC Batch
Impinger Volume	ml	144	1	6644533	201	N/A	1	6647009
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	0.026	0.015	6639735	<0.021	<0.021	0.021	6646564

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

BV Labs ID		MFT299	MFT300		
Sampling Date		2020/03/09	2020/03/09		
	UNITS	M8A- U2 BASE- R2 -CW	M8A- U2 BASE- R3 -CW	RDL	QC Batch
Impinger Volume	ml	138	139	1	6644533
Miscellaneous Parameters					
Sulphuric Acid Mist	mg	0.028	0.017	0.014	6639735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

INDUSTRIAL HYGIENE (STACK SAMPLING TRAIN)

BV Labs ID		MFT295		MFT296	MFT296		
Sampling Date		2020/03/11		2020/03/11	2020/03/11		
	UNITS	M8A- U1 BASE W/DB-R1	RDL	M8A- U1 BASE W/DB-R2	M8A- U1 BASE W/DB-R2 Lab-Dup	RDL	QC Batch
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.62	0.62	<0.64	<0.64	0.64	6657221

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate

BV Labs ID		MFT297		MFT298		MFT299		
Sampling Date		2020/03/11		2020/03/09		2020/03/09		
	UNITS	M8A- U1 BASE W/DB-R3	RDL	M8A- U2 BASE- R1 -CW	RDL	M8A- U2 BASE- R2 -CW	RDL	QC Batch
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	<0.58	0.58	<0.8	0.8	<0.55	0.55	6657221

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MFT300		
Sampling Date		2020/03/09		
	UNITS	M8A- U2 BASE- R3 -CW	RDL	QC Batch
Miscellaneous Parameters				
Sulphuric Acid Mist	mg	<0.56	0.56	6657221

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MFT282
Sample ID: M202- U2 BASE W/DB- R1
Matrix: Stack Sampling Train

Collected: 2020/03/10
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6637916	2020/03/16	2020/03/19	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6637921	2020/03/16	2020/03/19	Muhammad M Rahman
Weight of Solvent from Impingers		6637918	N/A	2020/03/16	Muhammad M Rahman
Weight of Water from Impingers		6637919	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT283
Sample ID: M202- U2 BASE W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/03/11
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6637916	2020/03/16	2020/03/19	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6637921	2020/03/16	2020/03/19	Muhammad M Rahman
Weight of Solvent from Impingers		6637918	N/A	2020/03/16	Muhammad M Rahman
Weight of Water from Impingers		6637919	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT284
Sample ID: M202- U2 BASE W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/03/11
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6637916	2020/03/16	2020/03/19	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6637921	2020/03/16	2020/03/19	Muhammad M Rahman
Weight of Solvent from Impingers		6637918	N/A	2020/03/16	Muhammad M Rahman
Weight of Water from Impingers		6637919	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT285
Sample ID: M202- U2 BASE- R1
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6637916	2020/03/16	2020/03/19	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6637921	2020/03/16	2020/03/19	Muhammad M Rahman
Weight of Solvent from Impingers		6637918	N/A	2020/03/16	Muhammad M Rahman
Weight of Water from Impingers		6637919	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT286
Sample ID: M202- U2 BASE- R2
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6637916	2020/03/16	2020/03/19	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6637921	2020/03/16	2020/03/19	Muhammad M Rahman
Weight of Solvent from Impingers		6637918	N/A	2020/03/16	Muhammad M Rahman
Weight of Water from Impingers		6637919	N/A	2020/03/16	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MFT287 **Collected:** 2020/02/19
Sample ID: M202- U2 BASE- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6637916	2020/03/16	2020/03/19	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6637921	2020/03/16	2020/03/19	Muhammad M Rahman
Weight of Solvent from Impingers		6637918	N/A	2020/03/16	Muhammad M Rahman
Weight of Water from Impingers		6637919	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT289 **Collected:** 2020/03/10
Sample ID: M201A- U2 BASE W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6637962	2020/03/16	2020/03/18	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6637959	2020/03/16	2020/03/18	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6637643	N/A	2020/03/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	6637939	2020/03/16	2020/03/18	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6637965	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT290 **Collected:** 2020/03/11
Sample ID: M201A- U2 BASE W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6637962	2020/03/16	2020/03/18	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6637959	2020/03/16	2020/03/18	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6637643	N/A	2020/03/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	6637939	2020/03/16	2020/03/18	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6637965	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT291 **Collected:** 2020/03/11
Sample ID: M201A- U2 BASE W/DB- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6637962	2020/03/16	2020/03/18	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6637959	2020/03/16	2020/03/18	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6637643	N/A	2020/03/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	6637939	2020/03/16	2020/03/18	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6637965	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT292 **Collected:** 2020/03/09
Sample ID: M201A- U2 BASE- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6637962	2020/03/16	2020/03/18	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6637959	2020/03/16	2020/03/18	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6637643	N/A	2020/03/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	6637939	2020/03/16	2020/03/18	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MFT292
Sample ID: M201A- U2 BASE- R1
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Final Volume of Acetone Probe Rinse		6637965	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT293
Sample ID: M201A- U2 BASE- R2
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6637962	2020/03/16	2020/03/18	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6637959	2020/03/16	2020/03/18	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6637643	N/A	2020/03/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	6637939	2020/03/16	2020/03/18	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6637965	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT294
Sample ID: M201A- U2 BASE- R3
Matrix: Stack Sampling Train

Collected: 2020/02/19
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6637962	2020/03/16	2020/03/18	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6637959	2020/03/16	2020/03/18	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6637643	N/A	2020/03/16	Brenda Moore
<2.5um Particulates in Rinse	BAL	6637939	2020/03/16	2020/03/18	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6637965	N/A	2020/03/16	Muhammad M Rahman

BV Labs ID: MFT295
Sample ID: M8A- U1 BASE W/DB- R1
Matrix: Stack Sampling Train

Collected: 2020/03/11
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6639735	2020/03/17	2020/03/17	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6657221	2020/03/27	2020/03/27	Rupinder Sihota
Final Volume of Impinger		6644533	N/A	2020/03/19	Ann-Marie Stern

BV Labs ID: MFT296
Sample ID: M8A- U1 BASE W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/03/11
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6639735	2020/03/17	2020/03/17	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6657221	2020/03/27	2020/03/27	Rupinder Sihota
Final Volume of Impinger		6644533	N/A	2020/03/19	Ann-Marie Stern

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MFT296 Dup
Sample ID: M8A- U1 BASE W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/03/11
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6639735	2020/03/17	2020/03/17	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6657221	2020/03/27	2020/03/27	Rupinder Sihota

BV Labs ID: MFT297
Sample ID: M8A- U1 BASE W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/03/11
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6639735	2020/03/17	2020/03/17	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6657221	2020/03/27	2020/03/27	Rupinder Sihota
Final Volume of Impinger		6644533	N/A	2020/03/19	Ann-Marie Stern

BV Labs ID: MFT298
Sample ID: M8A- U2 BASE- R1 -CW
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6646564	2020/03/20	2020/03/20	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6657221	2020/03/27	2020/03/27	Rupinder Sihota
Final Volume of Impinger		6647009	N/A	2020/03/19	Ann-Marie Stern

BV Labs ID: MFT298 Dup
Sample ID: M8A- U2 BASE- R1 -CW
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6646564	2020/03/20	2020/03/20	Lang Le

BV Labs ID: MFT299
Sample ID: M8A- U2 BASE- R2 -CW
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6639735	2020/03/17	2020/03/17	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6657221	2020/03/27	2020/03/27	Rupinder Sihota
Final Volume of Impinger		6644533	N/A	2020/03/19	Ann-Marie Stern

BV Labs ID: MFT300
Sample ID: M8A- U2 BASE- R3 -CW
Matrix: Stack Sampling Train

Collected: 2020/03/09
Shipped:
Received: 2020/03/12

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6639735	2020/03/17	2020/03/17	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6657221	2020/03/27	2020/03/27	Rupinder Sihota
Final Volume of Impinger		6644533	N/A	2020/03/19	Ann-Marie Stern

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

GENERAL COMMENTS

Sample MFT282 [M202- U2 BASE W/DB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MFT283 [M202- U2 BASE W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MFT284 [M202- U2 BASE W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MFT285 [M202- U2 BASE- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MFT286 [M202- U2 BASE- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MFT287 [M202- U2 BASE- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Results relate only to the items tested.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
6637916	MOR	Spiked Blank	Organic Condensibles	2020/03/19		99	%	70 - 130
6637916	MOR	Method Blank	Organic Condensibles	2020/03/19	<1.0		mg	
6637921	MOR	Method Blank	Inorganic Condensibles	2020/03/19	<0.5		mg	
6637939	MOR	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2020/03/18	<0.5		mg	
6637959	MOR	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2020/03/18	<0.5		mg	
6637962	MOR	Method Blank	> 10 Particulate Weight in Acetone Rinse	2020/03/18	<0.5		mg	
6639735	LLE	Matrix Spike(MFT296)	Sulphuric Acid Mist	2020/03/17		95	%	80 - 120
6639735	LLE	Spiked Blank	Sulphuric Acid Mist	2020/03/17		100	%	90 - 110
6639735	LLE	Method Blank	Sulphuric Acid Mist	2020/03/17	<0.01		mg	
6639735	LLE	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/17	NC		%	20
6646564	LLE	Matrix Spike(MFT298)	Sulphuric Acid Mist	2020/03/20		93	%	80 - 120
6646564	LLE	Spiked Blank	Sulphuric Acid Mist	2020/03/20		98	%	90 - 110
6646564	LLE	Method Blank	Sulphuric Acid Mist	2020/03/20	<0.01		mg	
6646564	LLE	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/20	NC		%	20
6657221	RSU	Matrix Spike(MFT296)	Sulphuric Acid Mist	2020/03/27		99	%	80 - 120
6657221	RSU	Spiked Blank	Sulphuric Acid Mist	2020/03/27		101	%	90 - 110
6657221	RSU	Method Blank	Sulphuric Acid Mist	2020/03/27	<0.4		mg	
6657221	RSU	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/27	NC		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.


NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com


Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Ann-Marie Stern, Team Lead, Inorganic



Brenda Moore, Team Lead, Inorganic

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

C067891

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number: bec-19-cricketvalley.ny-start#1

Person Taking Samples: Rob White

Laboratory Analysis Requested: Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	--	--
PM U-00002 Base+DB-1-F	Unit PM U-00002 Base+DB - Run 1 - Filter	03/10/20	N/A	X			
PM U-00002 Base+DB-1-C2	Unit PM U-00002 Base+DB - Run 1 - Nozzle Wash PM>10	03/10/20		X			
PM U-00002 Base+DB-1-C3	Unit PM U-00002 Base+DB - Run 1 - Cyclone Wash 2.5<PM<10	03/10/20		X			
PM U-00002 Base+DB-1-C4	Unit PM U-00002 Base+DB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	03/10/20	N/A	X			
PM U-00002 Base+DB-1-C5	Unit PM U-00002 Base+DB - Run 1 - Inorganic Impinger Contents	03/10/20			X		
PM U-00002 Base+DB-1-C6	Unit PM U-00002 Base+DB - Run 1 - Organic Impinger Contents	03/10/20			X		
PM U-00002 Base+DB-1-CPM	Unit PM U-00002 Base+DB - Run 1 - CPM Filter	03/10/20	N/A		X		
PM U-00002 Base+DB-2-F	Unit PM U-00002 Base+DB - Run 2 - Filter	03/11/20	N/A	X			
PM U-00002 Base+DB-2-C2	Unit PM U-00002 Base+DB - Run 2 - Nozzle Wash PM>10	03/11/20		X			
PM U-00002 Base+DB-2-C3	Unit PM U-00002 Base+DB - Run 2 - Cyclone Wash 2.5<PM<10	03/11/20		X			
PM U-00002 Base+DB-2-C4	Unit PM U-00002 Base+DB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	03/11/20	N/A	X			
PM U-00002 Base+DB-2-C5	Unit PM U-00002 Base+DB - Run 2 - Inorganic Impinger Contents	03/11/20			X		
PM U-00002 Base+DB-2-C6	Unit PM U-00002 Base+DB - Run 2 - Organic Impinger Contents	03/11/20			X		
PM U-00002 Base+DB-2-CPM	Unit PM U-00002 Base+DB - Run 2 - CPM Filter	03/11/20	N/A		X		
PM U-00002 Base+DB-3-F	Unit PM U-00002 Base+DB - Run 3 - Filter	03/11/20	N/A	X			
PM U-00002 Base+DB-3-C2	Unit PM U-00002 Base+DB - Run 3 - Nozzle Wash PM>10	03/11/20		X			
PM U-00002 Base+DB-3-C3	Unit PM U-00002 Base+DB - Run 3 - Cyclone Wash 2.5<PM<10	03/11/20		X			
PM U-00002 Base+DB-3-C4	Unit PM U-00002 Base+DB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	03/11/20	N/A	X			
PM U-00002 Base+DB-3-C5	Unit PM U-00002 Base+DB - Run 3 - Inorganic Impinger Contents	03/11/20			X		
PM U-00002 Base+DB-3-C6	Unit PM U-00002 Base+DB - Run 3 - Organic Impinger Contents	03/11/20			X		
PM U-00002 Base+DB-3-CPM	Unit PM U-00002 Base+DB - Run 3 - CPM Filter	03/11/20	N/A		X		

Signature 3/10/20 Date 1350 Time

Signature 3/12/2020 Date 21:30 Time

Signature Date Time

Signature Date Time

bec-19-cricketvalley.ny-start#2-U-00002-PMBaseDB

SD&L

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number: bec-19-cricketvalley.ny-start#2
Person Taking Samples: Rob White
Laboratory Analysis Requested:

Sample Number	Location	Date	Volume	Gravimetric Analysis Method			
				RM 201A	RM 202	--	--
PM U-00002 Base-1-F	Unit PM U-00002 Base - Run 1 - Filter	03/09/20	N/A	X			
PM U-00002 Base-1-C2	Unit PM U-00002 Base - Run 1 - Nozzle Wash PM>10	03/09/20		X			
PM U-00002 Base-1-C3	Unit PM U-00002 Base - Run 1 - Cyclone Wash 2.5<PM<10	03/09/20		X			
PM U-00002 Base-1-C4	Unit PM U-00002 Base - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	03/09/20	N/A	X			
PM U-00002 Base-1-C5	Unit PM U-00002 Base - Run 1 - Inorganic Impinger Contents	03/09/20			X		
PM U-00002 Base-1-C6	Unit PM U-00002 Base - Run 1 - Organic Impinger Contents	03/09/20			X		
PM U-00002 Base-1-CPM	Unit PM U-00002 Base - Run 1 - CPM Filter	03/09/20	N/A		X		
PM U-00002 Base-2-F	Unit PM U-00002 Base - Run 2 - Filter	03/09/20	N/A	X			
PM U-00002 Base-2-C2	Unit PM U-00002 Base - Run 2 - Nozzle Wash PM>10	03/09/20		X			
PM U-00002 Base-2-C3	Unit PM U-00002 Base - Run 2 - Cyclone Wash 2.5<PM<10	03/09/20		X			
PM U-00002 Base-2-C4	Unit PM U-00002 Base - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	03/09/20	N/A	X			
PM U-00002 Base-2-C5	Unit PM U-00002 Base - Run 2 - Inorganic Impinger Contents	03/09/20			X		
PM U-00002 Base-2-C6	Unit PM U-00002 Base - Run 2 - Organic Impinger Contents	03/09/20			X		
PM U-00002 Base-2-CPM	Unit PM U-00002 Base - Run 2 - CPM Filter	03/09/20	N/A		X		
PM U-00002 Base-3-F	Unit PM U-00002 Base - Run 3 - Filter	02/19/20	N/A	X			
PM U-00002 Base-3-C2	Unit PM U-00002 Base - Run 3 - Nozzle Wash PM>10	02/19/20		X			
PM U-00002 Base-3-C3	Unit PM U-00002 Base - Run 3 - Cyclone Wash 2.5<PM<10	02/19/20		X			
PM U-00002 Base-3-C4	Unit PM U-00002 Base - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/19/20	N/A	X			
PM U-00002 Base-3-C5	Unit PM U-00002 Base - Run 3 - Inorganic Impinger Contents	02/19/20			X		
PM U-00002 Base-3-C6	Unit PM U-00002 Base - Run 3 - Organic Impinger Contents	02/19/20			X		
PM U-00002 Base-3-CPM	Unit PM U-00002 Base - Run 3 - CPM Filter	02/19/20	N/A		X		
PM U-00002 Base-FB-C3	Unit PM U-00002 Base - Run FB - Cyclone Wash 2.5<PM<10	FB		X			
PM U-00002 Base-FB-C4	Unit PM U-00002 Base - Run FB - Cyclone Exit to Front Half of Filter Wash (<2.5)	FB	N/A	X			
PM U-00002 Base-FB-C5	Unit PM U-00002 Base - Run FB - Inorganic Impinger Contents	FB			X		

Signature Date Time

Signature Date Time

Signature Date Time

Signature Date Time

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email:

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1			Laboratory Analysis Requested:			
Person Taking Samples:	TW			Titration			
Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
SAM U-00001 Base+DB-1-CW	Unit SAM U-00001 Base+DB - Run 1 - Condenser Wash	03/11/20					
SAM U-00001 Base+DB-2-CW	Unit SAM U-00001 Base+DB - Run 2 - Condenser Wash	03/11/20					
SAM U-00001 Base+DB-3-CW	Unit SAM U-00001 Base+DB - Run 3 - Condenser Wash	03/11/20					

Signature	Date	Time	Signature	Date	Time
[signature]	3/10/20	1300	[signature]	20201031 12	21:30
Signature	Date	Time	Signature	Date	Time

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1			Laboratory Analysis Requested:			
Person Taking Samples:	TW			Titration			
Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
SAM U-00002 Base-1-CW	Unit SAM U-00002 Base - Run 1 - Condenser Wash	03/09/20					
SAM U-00002 Base-2-CW	Unit SAM U-00002 Base - Run 2 - Condenser Wash	03/09/20					
SAM U-00002 Base-3-CW	Unit SAM U-00002 Base - Run 3 - Condenser Wash	03/09/20					

Signature	Date	Time	Signature	Date	Time
[signature]	3/12/20	1300	[signature]	20200313	2130
Signature	Date	Time	Signature	Date	Time

bec-19-cricketvalley.ny-start#2-U-00002-SAMBase

SD&L

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data PM_{10} and SAM Blanks
BV Labs [U-00001 Report]

Your Project #: BEC-19-CRICKETVALLEY.NY-START1

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/03
Report #: R6096087
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C048069
Received: 2020/02/21, 17:15

Sample Matrix: Stack Sampling Train
Samples Received: 23

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Extractable Condensables (M202)	9	2020/02/27	2020/02/26	BRL SOP-00118	EPA 202 m
Non Extractable Condensibles (M202)	8	2020/02/27	2020/02/27	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
>10um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	7	N/A	2020/02/26	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
Sulphuric Acid Mist by Titration (M8A)	7	2020/03/02	2020/03/02	BRL SOP-00116	EPA CFR PTM 8 m
Final Volume of Acetone Probe Rinse	7	N/A	2020/02/26	BRL SOP-00109	
Final Volume of Impinger	7	N/A	2020/03/02		
Weight of Solvent from Impingers	9	N/A	2020/02/26		
Weight of Water from Impingers	8	N/A	2020/02/26		

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.
Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.
This Certificate shall not be reproduced except in full, without the written approval of the laboratory.
Reference Method suffix “m” indicates test methods incorporate validated modifications from specific reference methods to improve performance.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

Your Project #: BEC-19-CRICKETVALLEY.NY-START1

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/03
Report #: R6096087
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C048069
Received: 2020/02/21, 17:15

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key



Bureau Veritas Laboratories
03 Mar 2020 16:17:38

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: Clayton.Johnson@bvlabs.com
Phone# (905)817-5769

==========

This report has been generated and distributed using a secure automated process.
BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

BV Labs ID		MBP551	MBP552	MBP553	MBP554		
Sampling Date			2020/02/18	2020/02/18	2020/02/18		
	UNITS	M201A- BLANK	M201A- W/DB-R1	M201A- W/DB-R2	M201A- W/DB-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	1.2	1.1	13.9	1.2	0.5	6608986
< 2.5 Particulate Weight in Acetone Rinse	mg	1.9	1.7	1.7	1.4	0.5	6608981
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.7	0.9	1.4	1.8	0.5	6608984
< 2.5 Particulate Weight on Filter	mg	<0.30	<0.30 (1)	<0.30	<0.30 (2)	0.30	6607770
Acetone Rinse Volume (10)	ml	110	140	110	120	1	6608983
Acetone Rinse Volume (2.5 - 10)	ml	91	120	99	130	1	6608983
Acetone Rinse Volume (2.5)	ml	100	120	120	130	1	6608983

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative weight observed

LFT Loose filter material in the petri dish
DE Edges of the filter are frayed
(2) Negative weight observed

BV Labs ID		MBP556	MBP557	MBP558		
Sampling Date		2020/02/17	2020/02/17	2020/02/17		
	UNITS	M201A- W/ODB-R1	M201A- W/ODB-R2	M201A- W/ODB-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	16.2	14.5	14.0	0.5	6608986
< 2.5 Particulate Weight in Acetone Rinse	mg	1.7	2.7	1.7	0.5	6608981
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.3	1.7	1.5	0.5	6608984
< 2.5 Particulate Weight on Filter	mg	<0.30 (1)	<0.30 (2)	<0.30 (3)	0.30	6607770
Acetone Rinse Volume (10)	ml	100	110	97	1	6608983
Acetone Rinse Volume (2.5 - 10)	ml	130	130	85	1	6608983
Acetone Rinse Volume (2.5)	ml	130	130	63	1	6608983

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative weight observed

WET Filters was received wet
(2) Negative weight observed
(3) Negtive results observed

WET Filters were received wet
LFT Loose filter material in the petri dish
DE Edges of the filter are frayed

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

BV Labs ID		MBP535	MBP536	MBP537	MBP538		
Sampling Date							
	UNITS	M8A/M202- DI WATER BLANK	M202- HEXANE BLANK	M202- ACETONE BLANK	M202- FB	RDL	QC Batch
Weight	g	200	N/A	N/A	440	0.1	6608740
Weight of Solvent	g	N/A	130	150	320	0.1	6608738
Miscellaneous Parameters							
Inorganic Condensibles	mg	<0.5	N/A	N/A	3.1	0.5	6608739
Organic Condensibles	mg	N/A	<1.0	<1.0	1.1	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
N/A = Not Applicable

BV Labs ID		MBP539	MBP540	MBP541	MBP543	MBP544		
Sampling Date		2020/02/18	2020/02/18	2020/02/18	2020/02/17	2020/02/17		
	UNITS	M202- W/DB-R1	M202- W/DB-R2	M202- W/DB-R3	M202- W/ODB-R1	M202- W/ODB-R2	RDL	QC Batch
Weight	g	370	470	390	500	440	0.1	6608740
Weight of Solvent	g	220	280	210	150	230	0.1	6608738
Miscellaneous Parameters								
Inorganic Condensibles	mg	4.6	3.7	3.8	4.6	4.2	0.5	6608739
Organic Condensibles	mg	1.3	1.2	<1.0	1.6	2.4	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MBP545		
Sampling Date		2020/02/17		
	UNITS	M202- W/ODB-R3	RDL	QC Batch
Weight	g	440	0.1	6608740
Weight of Solvent	g	230	0.1	6608738
Miscellaneous Parameters				
Inorganic Condensibles	mg	3.6	0.5	6608739
Organic Condensibles	mg	<1.0	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

BV Labs ID		MBP535		MBP785	MBP785		
Sampling Date				2020/02/17	2020/02/17		
	UNITS	M8A/M202- DI WATER BLANK	RDL	M8A- W/DB- R1-CW	M8A- W/DB- R1-CW Lab-Dup	RDL	QC Batch
Impinger Volume	ml	196	1	232	N/A	1	6613884
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.78	0.78	<0.93	<0.93	0.93	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

BV Labs ID		MBP801		MBP802		MBP805		
Sampling Date		2020/02/17		2020/02/17		2020/02/18		
	UNITS	M8A- W/DB- R2-CW	RDL	M8A- W/DB- R3-CW	RDL	M8A- W/ODB- R1-CW	RDL	QC Batch
Impinger Volume	ml	194	1	254	1	191	1	6613884
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	<0.78	0.78	<1	1	<0.76	0.76	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MBP806		MBP807		
Sampling Date		2020/02/18		2020/02/18		
	UNITS	M8A- W/ODB- R2-CW	RDL	M8A- W/ODB- R3-CW	RDL	QC Batch
Impinger Volume	ml	197	1	232	1	6613884
Miscellaneous Parameters						
Sulphuric Acid Mist	mg	<0.79	0.79	<0.93	0.93	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP535 **Collected:**
Sample ID: M8A/M202- DI WATER BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP536 **Collected:**
Sample ID: M202- HEXANE BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP537 **Collected:**
Sample ID: M202- ACETONE BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP538 **Collected:**
Sample ID: M202- FB **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP539 **Collected:** 2020/02/18
Sample ID: M202- W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP540 **Collected:** 2020/02/18
Sample ID: M202- W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP540
Sample ID: M202- W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP541
Sample ID: M202- W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP543
Sample ID: M202- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP544
Sample ID: M202- W/ODB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP545
Sample ID: M202- W/ODB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP551
Sample ID: M201A- BLANK
Matrix: Stack Sampling Train

Collected:
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP552
Sample ID: M201A- W/DB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP553
Sample ID: M201A- W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP554
Sample ID: M201A- W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP556
Sample ID: M201A- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP556
Sample ID: M201A- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP557
Sample ID: M201A- W/ODB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP558
Sample ID: M201A- W/ODB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP785
Sample ID: M8A- W/DB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP785 Dup
Sample ID: M8A- W/DB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP801
Sample ID: M8A- W/DB- R2- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP802
Sample ID: M8A- W/DB- R3- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP805
Sample ID: M8A- W/ODB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP806
Sample ID: M8A- W/ODB- R2- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP807
Sample ID: M8A- W/ODB- R3- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

GENERAL COMMENTS

Sample MBP535 [M8A/M202- DI WATER BLANK] : INORGANIC EXTRACTION: No residue noted in Teflon dish.

Sample MBP536 [M202- HEXANE BLANK] : ORGANIC EXTRACTION: No residue noted in vial.

Sample MBP537 [M202- ACETONE BLANK] : ORGANIC EXTRACTION: No residue noted in vial.

Sample MBP538 [M202- FB] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP539 [M202- W/DB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP540 [M202- W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP541 [M202- W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP543 [M202- W/ODB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP544 [M202- W/ODB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP545 [M202- W/ODB- R3] : ORGANIC EXTRACTION : Light oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Results relate only to the items tested.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
6608735	MOR	Spiked Blank	Organic Condensibles	2020/02/28		98	%	70 - 130
6608735	MOR	Method Blank	Organic Condensibles	2020/02/26	<1.0		mg	
6608739	MOR	Method Blank	Inorganic Condensibles	2020/03/02	<0.5		mg	
6608981	MOR	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6608984	MOR	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6608986	MOR	Method Blank	> 10 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6613883	RSU	Matrix Spike(MBP785)	Sulphuric Acid Mist	2020/03/02		97	%	80 - 120
6613883	RSU	Spiked Blank	Sulphuric Acid Mist	2020/03/02		99	%	90 - 110
6613883	RSU	Method Blank	Sulphuric Acid Mist	2020/03/02	<0.2		mg	
6613883	RSU	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/02	NC		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Brenda Moore

Brenda Moore, Team Lead, Inorganic

Frank Mo, B.Sc., Inorganic Lab. Manager

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports.
For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

5048089

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1
Person Taking Samples:	Aaron Blum

Sample Number	Location	Date	Volume	Laboratory Analysis Requested: Gravimetric: Analysis Method: RM 201A	RM 202	–	–
CTG-0001_W/DB-1-F	Unit CTG-0001_W/DB - Run 1 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-1-C2	Unit CTG-0001_W/DB - Run 1 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-1-C3	Unit CTG-0001_W/DB - Run 1 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-1-C4	Unit CTG-0001_W/DB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-1-C5	Unit CTG-0001_W/DB - Run 1 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-1-C6	Unit CTG-0001_W/DB - Run 1 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-1-CPM	Unit CTG-0001_W/DB - Run 1 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-2-F	Unit CTG-0001_W/DB - Run 2 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-2-C2	Unit CTG-0001_W/DB - Run 2 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-2-C3	Unit CTG-0001_W/DB - Run 2 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-2-C4	Unit CTG-0001_W/DB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-2-C5	Unit CTG-0001_W/DB - Run 2 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-2-C6	Unit CTG-0001_W/DB - Run 2 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-2-CPM	Unit CTG-0001_W/DB - Run 2 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-3-F	Unit CTG-0001_W/DB - Run 3 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-3-C2	Unit CTG-0001_W/DB - Run 3 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-3-C3	Unit CTG-0001_W/DB - Run 3 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-3-C4	Unit CTG-0001_W/DB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-3-C5	Unit CTG-0001_W/DB - Run 3 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-3-C6	Unit CTG-0001_W/DB - Run 3 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-3-CPM	Unit CTG-0001_W/DB - Run 3 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-FB-C3	Unit CTG-0001_W/DB - Run FB - Cyclone Wash 2.5<PM<10	FB		X			
CTG-0001_W/DB-FB-C4	Unit CTG-0001_W/DB - Run FB - Cyclone Exit to Front Half of Filter Wash (<2.5)	FB	N/A	X			
CTG-0001_W/DB-FB-C5	Unit CTG-0001_W/DB - Run FB - Inorganic Impinger Contents	FB			X		
CTG-0001_W/DB-B1-Acetone	Unit CTG-0001_W/DB - Blank - Acetone		200		X		
CTG-0001_W/DB-B2-DI Water	Unit CTG-0001_W/DB - Blank - DI Water		200	X			
CTG-0001_W/DB-B3-Hexane	Unit CTG-0001_W/DB - Blank - Hexane		200		X		

Signature	Date	Time	Signature	Date	Time
			ODBIÓR NTAMWEMEZI	2020/02/21	17:15
			ODBIÓR NTAMWEMEZI	2020/02/25	13:40

C048-069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number: bec-19-cricketvalley.ny-start#1

Laboratory Analysis Requested:

Person Taking Samples: Aaron Blum

Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	–	–
CTG-0001_W/ODB-1-F	Unit CTG-0001_W/ODB - Run 1 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-1-C2	Unit CTG-0001_W/ODB - Run 1 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-1-C3	Unit CTG-0001_W/ODB - Run 1 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-1-C4	Unit CTG-0001_W/ODB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-1-C5	Unit CTG-0001_W/ODB - Run 1 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-1-C6	Unit CTG-0001_W/ODB - Run 1 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-1-CPM	Unit CTG-0001_W/ODB - Run 1 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-2-F	Unit CTG-0001_W/ODB - Run 2 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-2-C2	Unit CTG-0001_W/ODB - Run 2 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-2-C3	Unit CTG-0001_W/ODB - Run 2 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-2-C4	Unit CTG-0001_W/ODB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-2-C5	Unit CTG-0001_W/ODB - Run 2 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-2-C6	Unit CTG-0001_W/ODB - Run 2 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-2-CPM	Unit CTG-0001_W/ODB - Run 2 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-3-F	Unit CTG-0001_W/ODB - Run 3 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-3-C2	Unit CTG-0001_W/ODB - Run 3 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-3-C3	Unit CTG-0001_W/ODB - Run 3 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-3-C4	Unit CTG-0001_W/ODB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-3-C5	Unit CTG-0001_W/ODB - Run 3 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-3-C6	Unit CTG-0001_W/ODB - Run 3 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-3-CPM	Unit CTG-0001_W/ODB - Run 3 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-FB-C3	Unit CTG-0001_W/ODB - Run FB - Cyclone Wash 2.5<PM<10	FB		X			
CTG-0001_W/ODB-FB-C4	Unit CTG-0001_W/ODB - Run FB - Cyclone Exit to Front Half of Filter Wash (<2.5)	FB	N/A	X			
CTG-0001_W/ODB-FB-C5	Unit CTG-0001_W/ODB - Run FB - Inorganic Impinger Contents	FB			X		
CTG-0001_W/ODB-B1-Acetone	Unit CTG-0001_W/ODB - Blank - Acetone		200		X		
CTG-0001_W/ODB-B2-DI Water	Unit CTG-0001_W/ODB - Blank - DI Water		200	X			
CTG-0001_W/ODB-B3-Hexane	Unit CTG-0001_W/ODB - Blank - Hexane		200		X		

Signature Date Time

FIDELE NTAMWEMEZI 2020/02/21 17:15
Signature Date Time

Signature Date Time

FIDELE NTAMWEMEZI 2020/02/25 13:40
Signature Date Time

C048069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:
Person Taking Samples:	Atlas Melchert	Titration

Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
CT-0001W/DB-1-CW	Unit CT-0001W/DB - Run 1 - Condenser Wash	02/17/20					
CT-0001W/DB-2-CW	Unit CT-0001W/DB - Run 2 - Condenser Wash	02/17/20					
CT-0001W/DB-3-CW	Unit CT-0001W/DB - Run 3 - Condenser Wash	02/17/20					
CT-0001W/DB-B2-DI Water	Unit CT-0001W/DB - Blank - DI Water		100				
CT-0001W/DB-B3-H_2O_2	Unit CT-0001W/DB - Blank - H_2O_2		100				

Signature	Date	Time	Signature	Date	Time
[signature]	2/20/20	1420	FIDELE NTAMWEMEZI [signature]	2020/02/21	17:15
			FIDELE NTAMWEMEZI [signature]	2020/02/25	13:40

bec-19-cricketvally.ny-start#1-M8a-wDB

SD&L

C048069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number: bec-19-cricketvalley.ny-start#1

Person Taking Samples:

Laboratory Analysis Requested: Titration

Sample Number	Location	Date	Volume	Analysis Method: Cont Cond	--	--	--
CT-0001w/oDB-1-CW	Unit CT-0001w/oDB - Run 1 - Condenser Wash	02/18/20					
CT-0001w/oDB-2-CW	Unit CT-0001w/oDB - Run 2 - Condenser Wash	02/18/20					
CT-0001w/oDB-3-CW	Unit CT-0001w/oDB - Run 3 - Condenser Wash	02/18/20					
CT-0001w/oDB-B2-DI Water	Unit CT-0001w/oDB - Blank - DI Water		100				
CT-0001w/oDB-B3-H_2O_2	Unit CT-0001w/oDB - Blank - H_2O_2		100				

Signature	Date	Time	Signature	Date	Time
[signature]	2/20/20	1900	FIDELE NTAMWEMEZI [signature]	2020/02/21	17:15
			FIDELE NTAMWEMEZI [signature]	2020/02/25	13:40

bec-19-cricketvalley.ny-start#1-woDB-M8A

SD&L

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Supplemental Laboratory Data PM_{10} Filters
BV Labs

Inorganic Analysis Action / Comment Form

Client ID	Air Hygiene
Maxxam Job #	C067891
Maxxam Sample ID's (start)	MFT289-01R

Analytical Worksheet(s)			
	Filters	6637643	
	Solvent Rinse	6637939	
	Solvent Volumes	6637965	

Analysis	Particulates
Analyst ID	

Actions:	*Impacted Sample ID's
Bottle discrepancies	
Filters damaged	
Solvent rinse anomalies	
Water impinger anomalies	
Filter blank submitted	No
Solvent blank submitted	No
Water blank submitted	
Other	

Comments

See data sheets for any anomalies of samples

Filter
Particulate Weight Log

Job #	C067891		Metals	No	supplier	Pall	N/A	
Client	Air Hygiene		Filter Blank Submitted	No	p/n	61631	N/A	
Analysis	Particulate Weight on Filter		Date of Dessication	2020/03/13	lot #	T83173	N/A	Type
Balance ID	220-BALANAL4		Time of Dessication	1:24 PM				M5
Condition	Dickson THDX S/N 6003123							

DE Edges of filter frayed
LPC Loose particulate material in filter containe
FT Filter torn
FCL Filter contains liquid after dessication
LFT Loose filter material

Increment 1

Analyst	B Moore	B Moore	B Moore					
Weighing Date	2019.03.18	2020/03/16	2020/03/17					
Weighing Time	12:38 PM	12:19 PM	10:00 AM					
Temperature (ºC)	23	22	23					
Humidity (%)	37	32	41					

Worksheet #	#	Maxxam #	Filter Condition	Filter ID #	Pre Weight gm	Weight #1 gm	Weight #2 gm	Weight #3 gm	Weight #4 gm	Weight #5 gm	Weight #6 gm	Weight #7 gm	Final Weight gm	Particulate mg	RDL mg
6637643	1	MFT289-01R	NORMAL	19031837	0.11590	0.1171	0.1171						0.1171	1.2	0.3
6637643	2	MFT290-01R	NORMAL	19031838	0.11690	0.1167	0.1167						0.1167	-0.2	0.3
6637643	3	MFT291-01R	NORMAL	19031825	0.11320	0.1133	0.1133						0.1133	0.1	0.3
6637643	4	MFT292-01R	NORMAL	19031822	0.11315	0.1137	0.1138						0.1138	0.6	0.3
6637643	5	MFT293-01R	NORMAL	19031835	0.11355	0.1129	0.1128						0.1128	-0.8	0.3
6637643	6	MFT294-01R	NORMAL	19031823	0.11365	0.1134	0.1134						0.1134	-0.3	0.3
	7														
	8														
	9														
	10														
				zero	0.0000	0.0000	0.0000								
				0.3000 gm	0.3000	0.3000	0.3000								
	11														
	12														
	13														
	14														
	15														
	16														
	17														
	18														
	19														
	20														
				zero											
				0.3000 gm											
	21														
	22														
	23														
	24														
	25														
	26														
	27														
	28														
	29														
	30														
				zero											
				0.3000 gm											
	31														
	32														
	33														
	34														
	35														
	36														
	37														
	38														
	39														
	40														
				zero											
				0.3000 gm											

Filters are placed in a dessicator for 24 hours minimum prior to beginning weighing cycle.
Filters are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity of≥50 %.
Verification Weight 5mg S/N 1000144533
Verification Weight 100mg S/N 29785
Verification Weight 300mg S/N 1000112492

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Audit Sample Data
(not required for this scope of work)

APPENDIX E

FUEL ANALYSIS RECORDS

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: March 9, 2020
Project #: bec-19-cricketvalley.ny-start#2

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	93.5021	16.0430	15.00	88.12	994.85	930.20	895.75	837.55
Ethane	C_2H_6	4.2045	30.0700	1.26	7.43	1,743.15	73.29	1,594.41	67.04
Propane	C_3H_8	0.1470	44.0970	0.06	0.38	2,478.35	3.64	2,280.17	3.35
iso-Butane	iC_4H_{10}	0.0094	58.1230	0.01	0.03	3,203.11	0.30	2,955.38	0.28
n-Butane	nC_4H_{10}	0.0102	58.1230	0.01	0.03	3,213.35	0.33	2,965.62	0.30
Iso-Pentane	iC_5H_{12}	0.0021	72.1500	0.00	0.01	3,940.87	0.08	3,643.50	0.08
n-Pentane	nC_5H_{12}	0.0012	72.1500	0.00	0.01	3,948.75	0.05	3,648.32	0.04
Hexanes	C_6H_{14}	0.0010	86.1770	0.00	0.01	4,684.54	0.05	4,337.82	0.04
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.4353	44.0100	0.19	1.13	0.00	0.00	0.00	0.00
Nitrogen	N_2	1.3202	28.0134	0.37	2.17	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.3670	31.9988	0.12	0.69	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		**100.000**		**17.02**	**100.00**	**dry**	**1,007.94**	**dry**	**908.68**
						wet[2,5]	**984.70**	**wet[2,5]**	**887.73**

Characteristics of Fuel Gas		
Molecular Weight of gas =	17.023	lb/lb-mole
Btu per lb. of gas[4] =	22,809.483	gross (HHV)
Btu per lb. of gas[4] =	20,563.285	net (LHV)
Density of fuel gas[2] =	0.0442	lb/cu. ft
Wt % VOC in fuel gas =	0.47	%
Specific Gravity[1] =	0.5878	

Component	Wt%
carbon	72.59
oxygen	1.51
hydrogen	23.72
nitrogen	2.17
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) =	**8,638.42**
(Based on EPA RM-19) at 68 deg F and 14.696 psia	

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: March 10, 2020
Project #: bec-19-cricketvalley.ny-start#2

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	94.0739	16.0430	15.09	89.06	994.85	935.89	895.75	842.67
Ethane	C_2H_6	4.0762	30.0700	1.23	7.23	1,743.15	71.05	1,594.41	64.99
Propane	C_3H_8	0.1404	44.0970	0.06	0.37	2,478.35	3.48	2,280.17	3.20
iso-Butane	iC_4H_{10}	0.0090	58.1230	0.01	0.03	3,203.11	0.29	2,955.38	0.27
n-Butane	nC_4H_{10}	0.0099	58.1230	0.01	0.03	3,213.35	0.32	2,965.62	0.29
Iso-Pentane	iC_5H_{12}	0.0021	72.1500	0.00	0.01	3,940.87	0.08	3,643.50	0.08
n-Pentane	nC_5H_{12}	0.0012	72.1500	0.00	0.01	3,948.75	0.05	3,648.32	0.04
Hexanes	C_6H_{14}	0.0012	86.1770	0.00	0.01	4,684.54	0.06	4,337.82	0.05
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.4343	44.0100	0.19	1.13	0.00	0.00	0.00	0.00
Nitrogen	N_2	0.9895	28.0134	0.28	1.64	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.2623	31.9988	0.08	0.50	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		**100.000**		**16.95**	**100.00**	**dry**	**1,011.22**	**dry**	**911.60**
						wet[2,5]	**987.90**	**wet[2,5]**	**890.58**

Characteristics of Fuel Gas		
Molecular Weight of gas =	16.947	lb/lb-mole
Btu per lb. of gas[4] =	22,987.006	gross (HHV)
Btu per lb. of gas[4] =	20,722.438	net (LHV)
Density of fuel gas[2] =	0.0440	lb/cu. ft
Wt % VOC in fuel gas =	0.45	%
Specific Gravity[1] =	0.5851	

Component	Wt%
carbon	73.13
oxygen	1.32
hydrogen	23.92
nitrogen	1.64
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,638.67
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: March 11, 2020
Project #: bec-19-cricketvalley.ny-start#2

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	94.8355	16.0430	15.21	90.43	994.85	943.47	895.75	849.49
Ethane	C_2H_6	3.5130	30.0700	1.06	6.28	1,743.15	61.24	1,594.41	56.01
Propane	C_3H_8	0.1242	44.0970	0.05	0.33	2,478.35	3.08	2,280.17	2.83
iso-Butane	iC_4H_{10}	0.0074	58.1230	0.00	0.03	3,203.11	0.24	2,955.38	0.22
n-Butane	nC_4H_{10}	0.0084	58.1230	0.00	0.03	3,213.35	0.27	2,965.62	0.25
Iso-Pentane	iC_5H_{12}	0.0017	72.1500	0.00	0.01	3,940.87	0.07	3,643.50	0.06
n-Pentane	nC_5H_{12}	0.0010	72.1500	0.00	0.00	3,948.75	0.04	3,648.32	0.04
Hexanes	C_6H_{14}	0.0010	86.1770	0.00	0.01	4,684.54	0.05	4,337.82	0.04
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.3476	44.0100	0.15	0.91	0.00	0.00	0.00	0.00
Nitrogen	N_2	0.9125	28.0134	0.26	1.52	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.2477	31.9988	0.08	0.47	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		**100.000**		**16.83**	**100.00**	**dry**	**1,008.44**	**dry**	**908.95**
						wet[2,5]	**985.19**	**wet[2,5]**	**887.99**

Characteristics of Fuel Gas		
Molecular Weight of gas =	16.825	lb/lb-mole
Btu per lb. of gas[4] =	23,088.954	gross (HHV)
Btu per lb. of gas[4] =	20,810.952	net (LHV)
Density of fuel gas[2] =	0.0437	lb/cu. ft
Wt % VOC in fuel gas =	0.40	%
Specific Gravity[1] =	0.5809	

Component	Wt%
carbon	73.29
oxygen	1.13
hydrogen	24.06
nitrogen	1.52
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,636.30
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-001 Page 1 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_3920_FuelGas A Cricket Valley-R1-NoDuct Natural Gas Sample 2020-03-09		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography, ASTM D 1945.a

	Results, Mol %
Hydrogen	0.0000
Oxygen	0.3670
Nitrogen	1.3202
Carbon Dioxide	0.4353
Methane	93.5021
Ethane	4.2045
Propane	0.1470
iso-Butane	0.0094
n-Butane	0.0102
iso-Pentane	0.0021
n-Pentane	0.0012
Hexanes Plus	0.0010
TOTAL	**100.0000**

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 60°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	922.5
Gross (Dry basis), BTU/scf	1,023
NET (Dry basis), BTU/lb	20,568
Gross (Dry basis), BTU/lb	22,813

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 68°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	908.5
Gross (Dry basis), BTU/scf	1,007
NET (Dry basis), BTU/lb	20,568
Gross (Dry basis), BTU/lb	22,813

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-001 Page 2 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_3920_FuelGas A Cricket Valley-R1-NoDuct Natural Gas Sample 2020-03-09		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	0.3
Carbonyl Sulfide	0.2
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.4
Methyl Mercaptan	0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.2
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	1.5
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-001 Page 3 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_3920_FuelGas A Cricket Valley-R1-NoDuct Natural Gas Sample 2020-03-09		

TEST **RESULT**

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	4.5×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	4.4×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	4.5
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	4.4
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.14
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.13

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-002 Page 1 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_31020_FuelGas A Cricket Valley-R1-Duct Natural Gas Sample 2020-03-10		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography. ASTM D 1945.a

	Results, Mol %
Hydrogen	0.0000
Oxygen	0.2623
Nitrogen	0.9895
Carbon Dioxide	0.4343
Methane	94.0739
Ethane	4.0762
Propane	0.1404
iso-Butane	0.0090
n-Butane	0.0099
iso-Pentane	0.0021
n-Pentane	0.0012
Hexanes Plus	0.0012
TOTAL	**100.0000**

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 60°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	925.5
Gross (Dry basis), BTU/scf	1,027
NET (Dry basis), BTU/lb	20,727
Gross (Dry basis), BTU/lb	22,990

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 68°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	911.5
Gross (Dry basis), BTU/scf	1,011
NET (Dry basis), BTU/lb	20,727
Gross (Dry basis), BTU/lb	22,990

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-002 Page 2 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_31020_FuelGas A Cricket Valley-R1-Duct Natural Gas Sample 2020-03-10		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	0.4
Carbonyl Sulfide	0.2
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.4
Methyl Mercaptan	0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.2
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	1.5
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-002 Page 3 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_31020_FuelGas A Cricket Valley-R1-Duct Natural Gas Sample 2020-03-10		

TEST **RESULT**

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	4.2×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	4.1×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	4.2
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	4.1
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.13
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.12

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-003 Page 1 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_31120_FuelGas A Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample 2020-03-11		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography. ASTM D 1945.a

	Results, Mol %
Hydrogen	0.0000
Oxygen	0.2477
Nitrogen	0.9125
Carbon Dioxide	0.3476
Methane	94.8355
Ethane	3.5130
Propane	0.1242
iso-Butane	0.0074
n-Butane	0.0084
iso-Pentane	0.0017
n-Pentane	0.0010
Hexanes Plus	0.0010
TOTAL	**100.0000**

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 60°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	922.8
Gross (Dry basis), BTU/scf	1,024
NET (Dry basis), BTU/lb	20,816
Gross (Dry basis), BTU/lb	23,092

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 68°F. ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	908.8
Gross (Dry basis), BTU/scf	1,008
NET (Dry basis), BTU/lb	20,816
Gross (Dry basis), BTU/lb	23,092

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-003 Page 2 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_31120_FuelGas A Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample 2020-03-11		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	1.0
Carbonyl Sulfide	0.2
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	<0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.5
Methyl Mercaptan	0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.2
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	1.8
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92168-003 Page 3 of 3	**REPORT DATE:**	March 27, 2020
SAMPLE:	Unit2_31120_FuelGas A Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample 2020-03-11		

TEST **RESULT**

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	4.2×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	4.1×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	4.2
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	4.1
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.12
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.12

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

SINCE 1985
Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

Conversion Factors (Gas Analysis) to adjust BTU/ft^3 and Sulfur content @60ºF and 68ºF

NET (Dry Basis) BTU/scf @60ºF, factor= 1

NET (Dry Basis) BTU/scf @68ºF, factor= 0.984839

Gross (Dry Basis) BTU/scf @60ºF, factor = 1

Gross (Dry Basis) BTU/scf @68ºF, factor = 0.984839

NET (Dry Basis) BTU/lb @60ºF, factor = 1

NET (Dry Basis) BTU/lb @68ºF, factor = 1

GROSS (Dry Basis) BTU/lb @60ºF, factor= 1

GROSS (Dry Basis) BTU/lb @68ºF, factor= 1

Sulfur Total Volatile, ASTM D 6667 @60ºF, wt% or ppmwt, factor= 1

Sulfur Total Volatile, ASTM D 6667 @68ºF, wt% or ppmwt, factor= 0.984839

Sulfur Total Volatile, ASTM D 6667 @60ºF, grains/100scf = ppmwt @60ºF x 0.0300

Sulfur Total Volatile, ASTM D 6667 @68ºF, grains/100scf = ppmwt @60ºF x 0.0295

Conversion Factors (Liquid Fuel Analysis)

Liquid Fuel BTU/lb @60ºF= Liquid fuel BTU/lb @68ºF

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:	
Person Taking Samples:	Swanson B., R. White	Fuel Component and Sulfur Analysis	

Sample Number	Location	Date	Volume	Analysis Method(s) [and target(s)]						
				GPA2261/ASTM 1945 [component analysis]	GPA 2172 Calculation @ 60 F & 68 F [HHV]	ASTM 5504 [speciated sulfur content]				
UNIT2_3920_FUELGAS A	Cricket Valley-R1-NoDuct Natural Gas Sample [primary]	03/09/20	10L	X	X	X				
UNIT2_3920_FUELGAS B	Cricket Valley-R1-NoDuct Natural Gas Sample [backup]	03/09/20	10L	as necessary	as necessary	as necessary				
UNIT2_31020_FUELGAS A	Cricket Valley-R1-Duct Natural Gas Sample [primary]	03/10/20	10L	X	X	X				
UNIT2_31020_FUELGAS B	Cricket Valley-R1-Duct Natural Gas Sample [backup]	03/10/20	10L	as necessary	as necessary	as necessary				
UNIT2_31120_FUELGAS A	Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample [primary]	03/11/20	10L	X	X	X				
UNIT2_31120_FUELGAS B	Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample [backup]	03/11/20	10L	as necessary	as necessary	as necessary				

Relinquished by: (Signature) — Date: 3/16/20 — Time: 1400

Relinquished by: (Signature) — Date: — Time:

Received by: (Signature) — Date: — Time:

Received by: G. Morrow (Signature) — Date: 3/17/20 — Time: 11:30

APPENDIX F

STRATIFICATION TEST DATA

STRATIFICATION TEST DATA

Stratification Test Data Base Load

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric 7F.05
Location	Dover Plains, New York

Test Information	
Date	02/25/20
Project #	cis-19-cricketvalley.ny-start#1
Unit Number	U-00002
Load	Base
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type				
○	Isokinetic Traverse (Wet Chemistry Testing)			**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)			
○	Stratification Traverse (Compliance Test)		☐ RM 20	
◉	**Stratification Traverse (RATA)**	☐ Part 60	☑ Part 75	


Created with Traverse-AHI v20190211

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2


Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
					points


[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	6:14:22	**Run End**	7:12:22

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	4.00	6:14:22	6:18:22	13.43	0.75%	1.52	4.45%
D-2	4.00	6:18:22	6:22:22	13.40	0.52%	1.50	5.70%
D-1	4.00	6:22:22	6:26:22	13.39	0.45%	1.48	6.96%
C-3	8.00	6:26:22	6:34:22	13.32	0.07%	1.49	6.33%
C-2	4.00	6:30:22	6:34:22	13.31	0.15%	1.49	6.33%
C-1	4.00	6:34:22	6:38:22	13.31	0.15%	1.58	0.68%
B-3	10.00	6:38:22	6:48:22	13.47	1.05%	1.47	7.59%
B-2	4.00	6:48:22	6:52:22	13.45	0.90%	1.45	8.85%
B-1	4.00	6:52:22	6:56:22	13.43	0.75%	1.49	6.33%
A-3	8.00	6:56:22	7:04:22	13.03	**2.25%**	1.91	**20.07%**
A-2	4.00	7:04:22	7:08:22	13.21	0.90%	1.91	**20.07%**
A-1	4.00	7:08:22	7:12:22	13.21	0.90%	1.80	13.09%
Average				13.33		1.59	

			O_2		NOx		
			Criteria	**Results**	**Criteria**	**Results**	**AND criteria**
RATA Part 75	Non-Stratified %	≤	5%	Non (%)	5%	Non (Δ)	Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.
	Non-Stratified Δ	≤	0.3		3		
	Minimally-Stratified %	≤	10%		10%		
	Minimally-Stratified Δ	≤	0.5		5		
	Stratified	>	10%		10%		
	Outcome		1 point		1 point		
	Location		any point		any point		
	Maximum Concentration		13.47		1.91		
	Upscale Δ = Max Concentration - Average		0.14	Non	0.32	Non	
	Upscale % Difference		1.05%	Non	20.07%	Strat	
	Minimum Concentration		13.03		1.45		
	Downscale Δ = Average - Min Concentration		0.30	Non	0.14	Non	
	Downscale % Difference		2.25%	Non	8.85%	Mini	
	First Point on List Closest to Average		C-2		B-3		
Port Averages with Maximum Concentration Indicator	**Port A Average**		13.15		1.87	<max	
	Port B Average		13.45	<max	1.47		
	Port C Average		13.31		1.52		
	Port D Average		13.41		1.50		
	Port E Average						
	Port F Average						
	Port G Average						

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	6:14:22	**Run End**	7:12:22


40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	20.07 % for NOx
Maximum Pollutant Conc. Diff.	0.32 ppm for NOx
Maximum Diluent Conc. Diff.	0.30 % for O_2
Stratification Conclusions	
Comparison	all diluents/pollutants
Stack Diameter	D > 93.6 in.

Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	16.7%	38 1/8	46 1/8
2	50.0%	114	122
3	83.3%	189 7/8	197 7/8

Test Type
- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas
- ☐ 6.5.6(b)(2) alt. points do not apply



STRATIFICATION TEST DATA

Stratification Test Data Base+DB Load

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric 7F.05
Location	Dover Plains, New York

Test Information	
Date	03/10/20
Project #	bec-19-cricketvalley.ny-start#2
Unit Number	U-00002
Load	Base+DB
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)** ☐ Part 60	☑ Part 75	

Created with Traverse-AHI v20200108

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	03/10/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#2
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4


Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2


Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
				12 points	

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.


[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches





Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	03/10/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#2
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	12:32:13	**Run End**	14:11:13

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	8.00	12:32:13	12:40:13	11.92	1.18%	2.39	1.56%
D-2	8.00	12:40:13	12:48:13	11.92	1.18%	2.34	0.57%
D-1	8.00	12:48:13	12:56:13	12.12	0.48%	2.37	0.71%
C-3	8.00	12:56:13	13:04:13	11.97	0.77%	2.40	1.98%
C-2	8.00	13:04:13	13:12:13	11.93	1.10%	2.34	0.57%
C-1	8.00	13:12:13	13:20:13	11.90	1.35%	2.46	**4.53%**
B-3	11.00	13:20:13	13:31:13	12.16	0.81%	2.36	0.28%
B-2	8.00	13:31:13	13:39:13	12.15	0.73%	2.31	1.84%
B-1	8.00	13:39:13	13:47:13	12.03	0.27%	2.34	0.57%
A-3	8.00	13:47:13	13:55:13	12.09	0.23%	2.33	0.99%
A-2	8.00	13:55:13	14:03:13	12.20	1.14%	2.27	3.54%
A-1	8.00	14:03:13	14:11:13	12.36	**2.47%**	2.33	0.99%
Average				12.06		2.35	

			O_2		NOx		
			Criteria	**Results**	**Criteria**	**Results**	**AND criteria**
RATA Part 75	Non-Stratified %	≤	5%	Non (%)	5%	Non (%)	Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.
	Non-Stratified Δ	≤	0.3		3		
	Minimally-Stratified %	≤	10%		10%		
	Minimally-Stratified Δ	≤	0.5		5		
	Stratified	>	10%		10%		
	Outcome		1 point		1 point		
	Location		any point		any point		
	Maximum Concentration		12.36		2.46		
	Upscale Δ = Max Concentration - Average		0.30	Non	0.11	Non	
	Upscale % Difference		2.47%	Non	4.53%	Non	
	Minimum Concentration		11.90		2.27		
	Downscale Δ = Average - Min Concentration		0.16	Non	0.08	Non	
	Downscale % Difference		1.35%	Non	3.54%	Non	
	First Point on List Closest to Average		A-2		B-2		
Port Averages with Maximum Concentration Indicator	**Port A Average**		12.22	<max	2.31		
	Port B Average		12.11		2.34		
	Port C Average		11.93		2.40	<max	
	Port D Average		11.99		2.37		
	Port E Average						
	Port F Average						
	Port G Average						

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	03/10/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#2
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	12:32:13	**Run End**	14:11:13

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	4.53 % for NOx
Maximum Pollutant Conc. Diff.	0.11 ppm for NOx
Maximum Diluent Conc. Diff.	0.30 % for O_2

Stratification Conclusions	
Comparison	all diluents/pollutants
Stack Diameter	D > 93.6 in.


Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type
- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

☐ Use 6.5.6.3(a) points?

☐ 6.5.6(b)(2) alt. points could apply



APPENDIX G

EQUIPMENT CALIBRATION RECORDS

APEX SOURCE TESTING EQUIPMENT INSTRUMENTS

Apex Instruments, Inc.
204 Technology Park Lane
Fuquay-Varina, NC 27526

S-TYPE PITOT TUBE CALIBRATION SHEET

Reference USEPA Reference Method 2 (40CFR60, App. A, Meth. 2)

PITOT SERIAL#	4187	CALIBRATION DATE:	10-Jan-13
PITOT TYPE:	S-Type	BAROMETRIC PRESSURE:	29.74 in Hg
STD. PITOT TYPE:	Ellipsoidal	STATIC PRESSURE	1.4 in H_20
Cp(std):	0.990	BLOCKAGE %:	N/A
PROBE SERIAL#	NICK	CORRECTION FACTOR:	1.00

	SIDE "A" CALIBRATION			
RUN NO.	Δ Pstd in H_2O	Δ Ps in H_2O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.560	0.820	0.818	-0.001
2	0.560	0.815	0.821	0.002
3	0.560	0.820	0.818	-0.001
		"A" AVERAGE	0.819	0.0014 (must be ≤ 0.01)

	SIDE "B" CALIBRATION			
RUN NO.	Δ Pstd in H_2O	Δ Ps in H_2O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.560	0.815	0.821	0.000
2	0.560	0.815	0.821	0.000
3	0.560	0.815	0.821	0.000
		"B" AVERAGE	0.821	0.0000 (must be ≤ 0.01)

ACCEPTANCE CRITERIA

AVERAGE -0.0017 AVG. Cp (A) - AVG. Cp (B) must be ≤ 0.01

If the Average and both Deviation Averages "A" & "B" are ≤ 0.01, then the OVERALL AVERAGE below may be used.
*** If NOT, use the "A" Average OR "B" Average.**

OVERALL AVERAGE 0.8198



I certify that the above pitot tube was tested in accordance with the US EPA Method 2 standards.
See the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 2, Item 4.

Print Name: Nick Allen

Signature:

Date 1.11.13

Wind Tunnel Pitot Calibration

S-type Pitot ID:	**A4187**	Date:	**2-Mar-15**
Standard Pitot ID:	**001**	Personnel:	**KMR MF**
Cp(std):	**0.99**	Cp(actual):	**0.724**
Part Number:		P_{bar}(in Hg):	**29.71**
Test Velocity (fps):	**50**	T(°F):	**55**
Wind Tunnel Location:	**Calera, AL**	Tunnel Size:	**20" x 40"**
Customer:	**Air Hygiene**		

A-SIDE

ΔP_{std} (in. H_2O)	ΔP_s (in. H_2O)	Cp(s)	Deviation*
0.563	**1.053**	**0.723**	0.002
0.561	**1.048**	**0.724**	-0.001
0.561	**1.050**	**0.724**	0.000
	AVERAGE	**0.724**	0.001
		Std deviation	0.002

NOTES:

1. **Pitot calibrated with an Environmental Supply Co. PM10 cyclone.**
2. **C_p is only valid when used with PM10 cyclone.**
3. **C_p is only valid with 1" spacing from PM10 cyclone.**

$$Cp(s) = Cp(std)\sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

*Deviation = {Cp(s) - *AVG* Cp(s)} {must be <0.010}

Standard deviation of the deviations must be less than 0.02 for both sides.

Pitot tube S/N A4187 was calibrated in accordance with the CFR 40, Part 60 Appendix A, Method 2, Section 10.

Signature

3/2/15
Date

METERING SYSTEM DRY GAS METER CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0007

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0007 Calibration 2-20-19.xls]Original (5 point)

Make: Thermo Environmental
Model #: MST-C1
Serial #: 90704

Date: 02/20/19
Barometric Pressure: 29.03 (in. Hg)
Theoretical Critical Vacuum: 13.69 (in. Hg)

DRY GAS METER READINGS

ΔH	Time	Volume			Initial Temperature	
		Initial	Final	Total	Inlet	Outlet
(in. H2O)	(min)	(ft³)	(ft³)	(ft³)	(°F)	(°F)
0.26	17.00	280.930	286.280	5.350	80.0	71.0
0.55	12.00	286.280	291.690	5.410	80.0	73.0
1.10	10.00	291.690	297.800	6.110	86.0	74.0
1.80	10.00	297.800	305.720	7.920	89.0	75.0
3.50	10.00	305.720	316.650	10.930	94.0	76.0

Final Temperature		Orifice	K' Orifice	Actual	Ambient Temperature		
Inlet	Outlet	Serial#	Coefficient	Vacuum	Initial	Final	Average
(°F)	(°F)	(number)	(see above)	(in. Hg)	(°F)	(°F)	(°F)
81.0	73.0	40	0.2341	16.0	68.7	69.4	69.1
86.0	74.0	48	0.3350	16.0	69.4	69.5	69.5
89.0	75.0	55	0.4531	16.0	69.5	69.5	69.5
94.0	76.0	63	0.5888	16.0	69.6	69.5	69.6
93.0	77.0	73	0.8077	16.0	69.5	69.5	69.5

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
5.112	144.78	5.023	142.2	5.189
5.154	145.97	5.072	143.6	5.244
5.800	164.24	5.716	161.9	5.911
7.496	212.30	7.428	210.4	7.681
10.361	293.42	10.190	288.6	10.536

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
-0.003	0.982	1.613	40.98	-0.118
-0.001	0.984	1.663	42.24	-0.068
0.000	0.986	1.815	46.10	0.083
0.006	0.991	1.756	44.59	0.024
-0.002	0.983	1.811	45.99	0.079
AVERAGE:	**0.985**	**1.731**	43.98	**PASSED**

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter,acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H_20 that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)^3*(deg R)^0.5/((in.Hg)*(min)).

SIGNATURE: Craig McCarty _____ DATE: 02/20/19 02/20/19

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0007

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0007 Calibration 2-20-19.xls]Original (5 point)

Make: Thermo Environmental
Model #: MST-C1
Serial #: 90704

Date: 02/20/19
Barometric Pressure: 29.03 (in. Hg)
Temperature (ASTM cal): 68.70 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	602.00	0.33	1205.00	0.42
Probe	101.00	0.50	602.00	0.33	1205.00	0.42
Filter	101.00	0.50	602.00	0.33	1205.00	0.42
Dryer	101.00	0.50	602.00	0.33	1205.00	0.42
Aux.	101.00	0.50	602.00	0.33	1205.00	0.42

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	68.70 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	68.0	0.70	yes
DGM Out	67.0	1.70	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 02/20/19 02/20/19

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
Appendix A, Method 5
10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration

Air Hygiene Assett ID(s): **Probe:** samp-hp-0086 **Hotbox:** samp-bh-0012 **Gooseneck:** samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0007 Calibration 2-20-19.xls]Original (5 point)

Barometric Pressure: 29.03

Thermo-couples		Temps (°F)	Signature		Date	
Stack	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	70.00				
	±°F	1.10				
Probe	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	70.00				
	±°F	1.10				
Filter	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	69.00				
	±°F	0.10				
Cond.	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	69.00				
	±°F	0.10				
CPM	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	69.00				
	±°F	0.10				
Exit	Ref	68.90	Craig McCarty		02/20/19	02/20/19
	Read	70.00				
	±°F	1.10				

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	120.00	120.00	120.00	minutes
Actual Meter Volume	V_m	42.56	42.41	42.58	dcf
Meter Temperature	T_m	547.13	547.92	550.71	°R
Meter Pressure at 0.75 cfm	ΔH@	1.731	1.731	1.731	in. H_2O
Barometric Pressure	P_{bar}	30.30	29.88	30.12	in. Hg
Average Meter Pressure	ΔH_{avg}	0.34	0.34	0.34	in. H_2O
Dry Molecular Weight	M_d	29.28	29.28	29.28	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.58	0.58	0.58	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9435	0.9541	0.9489	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9488
Y_i	0.9850
%Diff	3.67%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{120.00}{42.56} \times \sqrt{\frac{0.0319 \times 547.13}{1.731 \times \left(30.30 + \frac{0.34}{13.6}\right)}} \times \frac{29}{29.28} \times 0.5831 = 0.9435$$

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	120.00	120.00	120.00	minutes
Actual Meter Volume	V_m	40.96	41.81	41.3	dcf
Meter Temperature	T_m	543.10	546.21	548.71	°R
Meter Pressure at 0.75 cfm	ΔH@	1.731	1.731	1.731	in. H_2O
Barometric Pressure	P_{bar}	30.09	30.15	30.14	in. Hg
Average Meter Pressure	ΔH_{avg}	0.34	0.34	0.34	in. H_2O
Dry Molecular Weight	M_d	29.24	29.24	29.24	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.58	0.58	0.58	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9808	0.9626	0.9769	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9734
Y_i	0.9850
%Diff	1.17%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{120.00}{40.96} \times \sqrt{\frac{0.0319 \times 543.10}{1.731 \times \left(30.09 + \frac{0.34}{13.6}\right)}} \times \frac{29}{29.24} \times 0.5831 = 0.9808$$

METERING SYSTEM DRY GAS METER CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1706009

Date: 07/03/19
Barometric Pressure: 29.10 (in. Hg)
Theoretical Critical Vacuum: 13.73 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume Initial (ft³)	Volume Final (ft³)	Volume Total (ft³)	Initial Temperature Inlet (°F)	Initial Temperature Outlet (°F)
0.32	17.00	443.350	448.680	5.330	71.0	71.0
0.63	12.00	448.680	454.070	5.390	73.0	73.0
1.10	10.00	454.070	460.140	6.070	74.0	74.0
1.90	10.00	460.140	468.070	7.930	76.0	76.0
3.50	10.00	468.070	479.010	10.940	77.0	77.0

Final Temperature Inlet (°F)	Final Temperature Outlet (°F)	Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature Initial (°F)	Ambient Temperature Final (°F)	Ambient Temperature Average (°F)
73.0	73.0	40	0.2341	16.0	71.3	72.0	71.7
74.0	74.0	48	0.3350	16.0	72.0	72.5	72.3
76.0	76.0	55	0.4531	16.0	72.5	72.7	72.6
77.0	77.0	63	0.5888	16.0	72.7	72.8	72.8
80.0	80.0	73	0.8077	16.0	72.8	73.0	72.9

RESULTS

DRY GAS METER VOLUME CORRECTED Vm(std) (ft³)	DRY GAS METER VOLUME CORRECTED Vm(std) (liters)	ORIFICE VOLUME CORRECTED Vcr(std) (ft³)	ORIFICE VOLUME CORRECTED Vcr(std) (liters)	ORIFICE VOLUME NOMINAL Vcr (ft³)
5.147	145.76	5.023	142.2	5.202
5.194	147.11	5.071	143.6	5.258
5.840	165.40	5.713	161.8	5.928
7.624	215.91	7.423	210.2	7.704
10.521	297.95	10.182	288.3	10.570

DRY GAS METER CALIBRATION FACTOR Y Variation (number)	DRY GAS METER CALIBRATION FACTOR Y Value (number)	ORIFICE CALIBRATION FACTOR ΔH@ Value (in. H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Value (mm H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Variation (in. H2O)
0.001	0.976	1.990	50.56	0.113
0.002	0.976	1.910	48.52	0.033
0.004	0.978	1.819	46.21	-0.058
-0.001	0.974	1.856	47.15	-0.021
-0.007	0.968	1.811	46.00	-0.067
AVERAGE:	**0.974**	**1.878**	47.69	**PASSED**

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter,acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H_20 that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)^3*(deg R)^0.5/((in.Hg)*(min)).

SIGNATURE: Craig McCarty DATE: 07/03/19 07/03/19

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1706009

Date: 07/03/19
Barometric Pressure: 29.28 (in. Hg)
Temperature (ASTM cal): 75.40 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	603.00	0.50	1206.00	0.50
Probe	101.00	0.50	603.00	0.50	1206.00	0.50
Filter	101.00	0.50	603.00	0.50	1206.00	0.50
Dryer	101.00	0.50	603.00	0.50	1206.00	0.50
Aux.	101.00	0.50	603.00	0.50	1206.00	0.50

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	75.40 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	74.0	1.40	yes
DGM Out	74.0	1.40	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 07/03/19 07/03/19

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
Appendix A, Method 5
10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration

Air Hygiene Assett ID(s): **Probe:** samp-hp-0086 **Hotbox:** samp-bh-0012 **Gooseneck:** samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Barometric Pressure: 29.10

Thermo-couples		Temps (°F)	Signature		Date	
Stack	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Probe	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Filter	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Cond.	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
CPM	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Exit	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319 T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	270.25	262.25	266.75	minutes
Actual Meter Volume	V_m	103.9	101.88	102.82	dcf
Meter Temperature	T_m	537.33	547.58	538.50	°R
Meter Pressure at 0.75 cfm	ΔH@	1.878	1.878	1.878	in. H_2O
Barometric Pressure	P_{bar}	30.30	30.25	30.14	in. Hg
Average Meter Pressure	ΔH_{avg}	0.46	0.46	0.46	in. H_2O
Dry Molecular Weight	M_d	29.29	29.28	29.28	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.68	0.68	0.68	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9629	0.9629	0.9641	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9633
Y_i	0.9740
%Diff	1.10%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{270.25}{103.9} \times \sqrt{\frac{0.0319 \times 537.33}{1.878 \times \left(30.30 + \frac{0.46}{13.6}\right)}} \times \frac{29}{29.29} \times 0.6782 = 0.9629$$

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319 T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}\frac{29}{M_d}}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	272.25	277.75	275.00	minutes
Actual Meter Volume	V_m	101.59	105.54	102.6	dcf
Meter Temperature	T_m	547.17	540.67	543.29	°R
Meter Pressure at 0.75 cfm	ΔH@	1.878	1.878	1.878	in. H_2O
Barometric Pressure	P_{bar}	30.14	30.12	30.11	in. Hg
Average Meter Pressure	ΔH_{avg}	0.44	0.44	0.44	in. H_2O
Dry Molecular Weight	M_d	29.32	29.31	29.31	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.66	0.66	0.66	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9813	0.9582	0.9785	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9727
Y_i	0.9740
%Diff	0.14%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{272.25}{101.59} \times \sqrt{\frac{0.0319 \times 547.17}{1.878 \times \left(30.14 + \frac{0.44}{13.6}\right)} \times \frac{29}{29.32}} \times 0.6633 = 0.9813$$

Field Balance Weight Verfication
Annual 500g Field Balance Stock Weight vs. 500g ISO 17025 Traceable Weight
Air Hygiene Asset ID: samp-sc-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\Field Balance Weights\2020\[samp-sc-0028-Extra.xlsm]Balance
Make: Ohaus
Model #: Scout Pro SP2001-US
Serial #: B228113219
Field Weight #: sc-0028
Trailer #: Extra

ISO 17025 Weight ID LABS-WT-0005
ISO S/N 1000128090
ISO Cal Due 7/29/2020

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.90	0.10

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.50	0.50

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.80	0.20

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

Note: Calibrated against ISO 17025 Certified weight LABS-WT-0005

EPA Method 4 - Section 10.3, EPA Method 5 - Section 10.7, EPA Method 202 - Section 10.3: Field Balance Calibration Check. Check the calibration of the balance used to weigh impingers with a weight that is at least 500g or within 50g of a loaded impinger. The weight must be ASTM E617-13 "Standard Specification for Laboratory Weights and Precision Mass Standards" Class 6 (or better). Daily before used, the field balance must meausure within ±0.5g of the certified mass. If the daily balance calibration check fails, perform corrective measures and repeat the check before using balance.

ISO 17025 Certified 500g Weight is certified annually. Certified weight is used to verify Class 6 or better weight that accompanies each field balance on the balance it will be used. Acceptance critieria is certified weight must be within ±0.5g of Class 6 or better weight.

WEATHER STATION CALIBRATION SHEET
Temperature, Barometric Pressure, and Relative Humidity Periodic Calibration
Air Hygiene Asset ID: samp-we-0014

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\Weather Stations\2020\[SAMP-WE-0014_224.xlsm]112013
Make: Kestrel — ISO 17025 Weather Station ID: SAMP-WE-0033
Model #: 4000 — ISO 17025 S/N: A026334
Serial #: 671144 — ISO 17025 Cal Due: 7/23/2020

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.10	69.70	0.40	29.11	29.13	0.02	15:08

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.50	70.40	0.10	29.11	29.12	0.01	15:26

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.80	70.40	0.40	29.11	29.12	0.01	15:41

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.60	69.00	1.60	29.10	29.12	0.02	16:00

Sean Barnes — Sean Barnes — 01/27/20
(signature) *(date)*

Note: Verified against ISO 17025 Traceable Barometer and Thermometer (SAMP-WE-0033).

this page intentionally left blank
end of report

BECHTEL
Document Number
26068-000-VEN-JQ11-00013
Revision 002
1 - Work May Proceed
Peter Carr - Bechtel Global
May 18, 2020, 9:54 AM GMT-4:00
Permission to proceed does not constitute acceptance or approval of design detail, calculations, analyses, test methods or materials developed or selected by the Supplier and does not relieve the Supplier from full compliance with contractual obligations.

EMISSION COMPLIANCE TEST
FOR THE
GENERAL ELECTRIC, 7F.05, UNIT #U-00003
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
APRIL 15-17, 2020

Permit No: 3-1326-00275/00009
Facility DEC ID: 3132600275
Report Date: May 12, 2020



Corporate Headquarters
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012

AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices
Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

EMISSION COMPLIANCE TEST
FOR THE
GENERAL ELECTRIC, 7F.05, UNIT #U-00003
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
APRIL 15-17, 2020


Prepared and Reviewed by:



Darin Grimes
Sr. Testing Solutions Specialist



Thomas K. Graham, PE, QSTI
Director of AHU


I, 

Rob White, QSTI
Test Manager
certify that this testing was conducted and this report was created in conformance with the requirements of ASTM D7036

(this page intentionally left blank)

CERTIFICATION OF INFORMATION

I certify under penalty of law that I believe the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.



Rob White, QSTI
Test Manager
Air Hygiene International, Inc.

April 20, 2020
Date

FACILITY CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attached documents and, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.

I am the responsible official with direct knowledge and overall responsibility for the information contained in this report.

Name

Title

Signature

Date

(this page intentionally left blank)

Table of Contents

1.0 INTRODUCTION 1

1.1 TEST PURPOSE AND OBJECTIVES 1

1.2 SUMMARY OF TEST PROGRAM 1

1.2.1 Participating Organizations 1
1.2.2 Industry 1
1.2.3 Air Permit Requirements 1
1.2.4 Plant Location 1
1.2.5 Equipment Tested 1
1.2.6 Emission Points 2
1.2.7 Emission Parameters Measured 2
1.2.8 Dates of Emission Test 2
1.2.9 Federal Certifications 2

1.3 KEY PERSONNEL 2

2.0 SUMMARY OF TEST RESULTS 2

3.0 SOURCE OPERATION 4

3.1 PROCESS DESCRIPTION 4

3.2 SAMPLING LOCATION 4

4.0 SAMPLING AND ANALYTICAL PROCEDURES 4

4.1 TEST METHODS 4

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS 5

APPENDICES

Appendix A Test Results and Calculations
Table A.1: Emissions Testing Schedule (Sampling Log)
Emissions Results Base Load NOx, CO, VOC, and NH_3
Emissions Results Base Load PM_{10}
Emissions Results Base Load SAM
Emissions Results Base+DB Load NOx, CO, VOC, and NH_3
Emissions Results Base+DB Load PM_{10}
Emissions Results Base+DB Load SAM

Appendix B Emission Data Records
Operating Data Base Load NOx, CO, VOC, and NH_3
Operating Data Base Load PM_{10}
Operating Data Base Load SAM
Operating Data Base Load Opacity
Operating Data Base+DB Load NOx, CO, VOC, and NH_3
Operating Data Base+DB Load PM_{10}
Operating Data Base+DB Load SAM
Operating Data Base+DB Load Opacity

Table of Contents
(continued)

APPENDICES

Appendix B Emission Data Records
- Reference Method Data Base Load NOx, CO, VOC, and NH_3
- Reference Method Data Base Load PM_{10}
- Reference Method Data Base Load SAM
- Reference Method Data Base Load Opacity
- Reference Method Data Base+DB Load NOx, CO, VOC, and NH_3
- Reference Method Data Base+DB Load PM_{10}
- Reference Method Data Base+DB Load SAM
- Reference Method Data Base+DB Load Opacity

Appendix C Calibration Gas Certifications

Appendix D Quality Assurance and Quality Control Data
- Daily Reference Method Analyzer Calibration Data
- Laboratory Data Summary Base Load PM_{10}
- Laboratory Data Summary Base+DB Load PM_{10}
- Field Collection Data QA SAM
- Laboratory Data PM_{10} and SAM, BV Labs
- Laboratory Data PM_{10} and SAM Blanks, BV Labs [U-00001 Report]
- Supplemental Laboratory Data, BV Labs
- Audit Sample Data

Appendix E Fuel Analysis Records

Appendix F Stratification Test Data
- Stratification Test Data Base Load
- Stratification Test Data Base+DB Load

Appendix G Equipment Calibration Records

Emissions Compliance Test
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center LLC
Cricket Valley Energy Center
Dover Plains, New York
April 15-17, 2020

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Emissions Compliance Test for nitrogen oxides (NOx), carbon monoxide (CO), total hydrocarbons/volatile organic compounds (THC/VOC), sulfur dioxide (SO_2) [by fuel analysis], ammonia (NH_3), particulate matter (PM_{10}), sulfuric acid mist (SAM), opacity / visual emissions (VE), flow, moisture (H_2O), carbon dioxide (CO_2), and oxygen (O_2) from the exhaust of the General Electric, 7F.05, Unit #U-00003 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on April 15-17, 2020.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to conduct an initial compliance emission test to document levels of selected pollutants at two test loads, base loaded with duct burners on and base loaded with duct burners off (Base+DB and Base). The information will be used to confirm compliance with the operating permit issued by the New York State Department of Environmental Conservation (NYSDEC). The specific objective was to determine the emission concentrations and rates of NOx, CO, THC/VOC, SO_2 [fuel analysis], NH_3, PM_{10}, SAM, VE, flow, H_2O, CO_2, and O_2 from the exhaust of Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00003 at Base+DB and Base.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations
- New York State Department of Environmental Conservation (NYSDEC)
- Cricket Valley Energy Center LLC
- Bechtel Corporation
- Air Hygiene

1.2.2 Industry
- Electric Utility / Electric Services

1.2.3 Air Permit Requirements
- Permit Number: 3-1326-00275/00009

1.2.4 Plant Location
- Cricket Valley Energy Center in Dover Plains, New York
  - GPS Coordinates [Latitude 41.67721, Longitude -73.57992]
  - Physical Address: 2241 ST RTE 22, Dover Plains, New York 12522
  - Federal Registry System / Facility Registry Service (FRS) No. – 110043340364
  - Source Classification Code (SCC) – 10200602

1.2.5 Equipment Tested
- General Electric, 7F.05, Unit #U-00003

1.2.6 Emission Points

- Exhaust from the General Electric, 7F.05, Unit #U-00003
- For all gases, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00003, determined after conducting a 12-point stratification test
- For all PM_{10} testing, 12 sampling points in the exhaust duct from the General Electric, 7F.05, Unit #U-00003
- For all SAM testing, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00003
- For opacity, one sample visual observation point from the exit of the exhaust duct to the atmosphere from the General Electric, 7F.05, Unit #U-00003

1.2.7 Emission Parameters Measured

- NOx
- CO
- THC/VOC
- SO_2 [fuel analysis]
- NH_3
- PM_{10}
- SAM
- Opacity
- Flow
- H_2O
- CO_2
- O_2

1.2.8 Dates of Emission Test

- April 15-17, 2020

1.2.9 Federal Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Cricket Valley Energy Center LLC:	Marc Duquette (mduquette@cricketvalley.com)	617-320-5219
Bechtel Corporation:	John Curran	772-678-1878
Bechtel Corporation:	Peter Carr (pcarr@bechtel.com)	571-392-6737
Air Hygiene:	Rob White (rwhite@airhygiene.com)	918-307-8865
Air Hygiene:	Swanson Bierman (swanson@airhygiene.com)	918-307-8865
Air Hygiene:	Andrew McMahan	918-307-8865
Air Hygiene:	Sean Fields	918-307-8865
Air Hygiene:	Jeremy Johnson	918-307-8865
Air Hygiene:	Matt Jones	918-307-8865
Air Hygiene:	Gharabet Torossian	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00003 located at the Cricket Valley Energy Center on April 15-17, 2020 are summarized in the following table and relate only to the items tested.

TABLE 2.1
SUMMARY OF GENERAL ELECTRIC, 7F.05, UNIT #U-00003 RESULTS

Parameter	Base Load	Base+DB Load	Permit Limits Base	Permit Limits Base+DB
Heat Input (MMBtu/hr)	2,320.7	2,602.2	--	--
CT Power Output (megawatts)	237.4	240.1	--	--
Load Condition	Nominal base load, w/o DB[1]	Nominal base load, w/ DB[2]	--	--
NOx (ppmvd)	1.76	2.26	--	--
NOx (ppm@15%O_2)	1.30	1.49	2.0	2.0
CO (ppmvd)	0.00	0.06	--	--
CO (ppm@15%O_2)	0.00	0.04	2.0	2.0
VOC (as C1) (ppmvd)	0.00	0.00	--	--
VOC (as C1) (ppm@15%O_2)	0.00	0.00	0.7	1.8
Total PM_{10} (mg)	5.37	5.50	--	--
Total PM_{10} (lb/MMBtu)	0.0028	0.0027	0.005	0.006
Fuel Sulfur (grains / 100 scf)	0.04	0.11	0.4	0.4
SAM (as H_2SO_4) (mg)	0.05	0.03	--	--
SAM (as H_2SO_4) (lb/MMBtu)	0.00006	0.00004	0.00065	0.00065
NH_3 (ppmvd)	0.34	1.54	--	--
NH_3 (ppm@15%O_2)	0.25	1.02	5.0	5.0
Opacity (%)	0	0	20	20

Notes: [1]Air permit specifically indicates design capacity heat input of 2395.7 MMBtu/hr [ISO Conditions, 1 atm (29.923 in Hg), temperature 15 C or 59 F, and RH 60%] for the gas turbine. [2]Air permit specifically indicates design capacity heat input of 247 mmBtu/hr [ISO Conditions, 1 atm (29.923 in Hg), temperature 15 C or 59 F, and RH 60%] for the duct burner.

The results of all measured pollutant emissions were below the required limits. All testing was conducted according to the approved testing protocol. All testing was performed without any real or apparent errors with the following exceptions:

The PM_{10} filter weights were reported by the laboratory at the reportable detection limit (RDL). Supplemental laboratory data was provided and additional data analysis indicated minor filter losses, which were accounted for in either the sample train section cleanup just prior to the filter or the sample train cleanup in the section just after the filter. As a result, the PM results are considered valid with accounting for all minor filter weight losses in other fractions of the sample train results.

The SAM analysis was conducted by titration, per the requirements of CTM-013 with all results reported below the reportable detection limits (RDLs). However, when reporting emission rates using the titration based RDL values, the SAM results exceeded permitted limits. To remedy, the SAM analysis was also conducted by ion chromatography (IC). The supplemental IC analysis (Appendix D) yielded lower RDLs and also all results that were below the permitted limits. Emission rates were calculated based on the supplemental IC data.

The fuel sample collected by Air Hygiene on April 15, 2020 demonstrated a substantial level of nitrogen indicative of contamination from the atmosphere or a leak in the sampling system. A subsequent sample is presented, along with the original, in Appendix E and used for calculations.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

Cricket Valley Energy Center LLC owns and operates the Cricket Valley Energy Center located at 2241 ST RTE 22 in Dover Plains, New York. Located on the Cricket Valley Energy Center are three General Electric 7F.05 Combustion Turbine Generators (CTGs), designated as Emission Units U-00001, U-00002, and U-00003. The CTGs and associated heat recovery steam generators (HRSGs) which are equipped with dry low NOx burners in combination with selective catalytic reduction systems (SCRs). The CTG-HRSGs are also equipped with oxidation catalysts which reduce CO and VOC emissions.

3.2 SAMPLING LOCATION

The sample ports were located approximately vertical, circular and measures 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 265.8 ft above grade level with an exit elevation of approximately 282.5 ft above grade level. The test ports are located approximately 70.8 ft (850 inches) downstream and approximately 16.7 ft (200.4 inches) upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by Cricket Valley Energy Center LLC. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test. During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time. For PM_{10} testing, an initial velocity traverse was performed across the stack from 12 total points at each test load. All PM_{10} sampling occurred from the same 12 points. All SAM testing occurred from a simple sample point. All opacity observations were made by viewing the point where the exhaust system exited to the atmosphere at the top of the exhaust stack.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the General Electric, 7F.05, Unit #U-00003 at the Cricket Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on April 15-17, 2020.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	S-Type Pitot Tube
Oxygen	EPA Method 3A	Paramagnetic Cell
Carbon Dioxide	EPA Method 3A	Nondispersive Infrared Analyzer
Stack Moisture Content	EPA Method 4	Gravimetric Analysis

Pollutant or Parameter	Sampling Method	Analysis Method
Sulfur Dioxide	GPA 2261	Fuel Sulfur Content
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Sulfuric Acid Mist	CTM-013 (EPA Method 8A)	Wet Chemistry Solubility
Opacity	EPA Method 9	Visual Observation
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Volatile Organic Compounds	EPA Method 18/25A	Gas Chromatograph and Flame Ionization Detector
Stack Flow Rate	EPA Method 19	ASTM 5504 and Dry Oxygen F Factor
Particulate Matter	EPA Method 201A	Front Half Filterables
Particulate Matter	EPA Method 202	Back Half Condensables
Ammonia Slip	EPA Method 320	Fourier Transform Infrared

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3A, 4, 7E, 9, 10, 18, 19, 25A; 40 CFR 51, Appendix M, Methods 201A and 202; 40 CFR 63, Appendix A, Method 320; Conditional Test Method (CTM)-013 [Method 8A]; ASTM 5504; and GPA 2261.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless-steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample. Exhaust samples were routed to the wet based analyzer prior to gas conditioning.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer,

interferograms consisting of 27 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations. Spectral data was analyzed by the MKS MG2000 software.

Figure 4.2 represents the sample system used for the PM_{10} tests. A heated stainless-steel probe with a glass liner and stainless-steel nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter. Glassware that is used to collect and analyze Method 202 condensable particulate samples is cleaned prior to the test with soap and water, and rinsed using tap water, deionized water, acetone, and finally, hexane. After cleaning, Air Hygiene incorporates a glassware bake at 300ºC for six hours rather than the alternative of collecting a field train proof blank.

Figure 4.3 represents the sample system used for the SAM tests. A heated stainless-steel probe with a glass liner was inserted into a sample port of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter.

The stack gas analysis for O_2 and CO_2 concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O_2 analyzer uses a paramagnetic cell detector and the CO_2 analyzer uses a continuous nondispersive infrared analyzer.

EPA Method 7E was used to determine concentrations of NOx. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO_2 in nitrogen certified gas cylinder was used to verify at least a 90 percent NO_2 conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.


THC emission concentrations were quantified in accordance with procedures set forth in EPA Method 25A. A continuous flame ionization (FID) analyzer was used for this purpose. THC emissions concentrations were below VOC limits and all assumed as VOCs. EPA Method 18 for Tedlar bag sampling and analysis of methane and ethane content was not analyzed or subtracted from the THC concentrations to determine VOC concentrations.

An MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer, or equivalent, was used for NH_3 analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm^{-1}. The system employed a silicon carbide infrared source at 1200ºC, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191ºC. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 10.0 liters per minute, the sample gas in the cell is refreshed at least five times each minute. Interferograms consisting of 27 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations.

TABLE 4.2
ANALYTICAL INSTRUMENTATION

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NOx	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO_2 to NO. Chemiluminescence of reaction of NO with O_3. Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor-based linearization.
CO_2	SERVOMEX 1440	0-20%	0.1%	Nondispersive infrared
NH_3	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
VOC	THERMO 51 series	User may select up to 10,000 ppm	0.1 ppm	Flame Ionization Detector
O_2	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

COPYRIGHT © 2011 AIR HYGIENE INTERNATIONAL, INC.




PROBE

HEATED PROBE FILTER

LEGEND

- Heated Teflon Tubing (pre-conditioned sample)
- Unheated Teflon Tubing (conditioned sample)
- Diluted Calibration Gas
- Calibration Gas
- Electronic Input/Output



HEATED PROBE FILTER

PROBE

STACK EXHAUST

PROCESS INLET OR 2ND STACK

dual line heated sample umbilical

TEST TRAILER EXTERIOR

TEST TRAILER INTERIOR


DATA RECORDER



COMPUTER




GAS CONDITIONER



dual line heated sample umbilical

MOBILE SECONDARY ANALYZERS

MANIFOLD





GAS DILUTER

THC, VOC



HOT/WET ANALYZERS

COLD/DRY ANALYZERS

O_2, CO_2, NOx, CO, SO_2




COLD/DRY ANALYZERS HOT/WET





O_2, CO_2, NOx, CO, SO_2



FLOW CONTROL MANIFOLD




FTIR

THC, VOC



CONDITIONER

VENT



CALIBRATION/ BIAS GAS BOTTLES

VENT

FIXED PRIMARY ANALYZERS


Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.

AIR HYGIENE

Figure 4.1
EMISSIONS TESTING LAB

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

COPYRIGHT © 2009 AIR HYGIENE INTERNATIONAL, INC.




Wet Chemistry Assembly
(photo)





Figure 4.2
RM201A / 202 ASSEMBLY

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

COPYRIGHT © 2013 AIR HYGIENE INTERNATIONAL, INC.



TEST NOTES:
10 LPM SAMPLE FLOW
Delta H @ 0.35 IS ABOUT 10 LPM ON STANDARD CONSOLE
15 MIN AMBIENT AIR PURGE

AIR HYGIENE

Figure 4.3
METHOD 8A ASSEMBLY

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1: EMISSIONS TESTING SCHEDULE

Unit	Load	Component	Run	Date	Start	Stop	Time Sync	Duration
U-00003	Base	Stratification Test	Base-1	04/15/20	10:33	11:39	DAHS	01:06
U-00003	Base	Cyclonic Flow Check	PM U-00003 Base-V1	04/15/20	06:45	07:10	DAHS	00:25
U-00003	Base	NOx, CO, VOC, NH_3	1-1	04/15/20	12:10	13:09	DAHS	01:00
U-00003	Base	NOx, CO, VOC, NH_3	1-2	04/15/20	13:23	14:22	DAHS	01:00
U-00003	Base	NOx, CO, VOC, NH_3	1-3	04/15/20	14:35	15:34	DAHS	01:00
U-00003	Base	Opacity	Op-1-1	04/15/20	06:00	07:00	DAHS	01:00
U-00003	Base	Opacity	Op-1-2	04/15/20	07:00	08:00	DAHS	01:00
U-00003	Base	Opacity	Op-1-3	04/15/20	08:00	09:00	DAHS	01:00
U-00003	Base	PM_{10}	PM U-00003 Base-1	04/15/20	08:23	12:46	DAHS	04:23
U-00003	Base	PM_{10}	PM U-00003 Base-2	04/15/20	13:45	18:02	DAHS	04:17
U-00003	Base	PM_{10}	PM U-00003 Base-3	04/16/20	06:46	11:15	DAHS	04:29
U-00003	Base	SAM	SAM U-00003 Base-1	04/15/20	13:56	15:56	DAHS	02:00
U-00003	Base	SAM	SAM U-00003 Base-2	04/16/20	06:24	08:24	DAHS	02:00
U-00003	Base	SAM	SAM U-00003 Base-3	04/16/20	08:57	10:57	DAHS	02:00
U-00003	Base+DB	Stratification Test	BaseDB-1	04/16/20	12:29	13:35	DAHS	01:06
U-00003	Base+DB	Cyclonic Flow Check	PM U-00003 Base+DB-V1	04/16/20	12:09	12:21	DAHS	00:12
U-00003	Base+DB	NOx, CO, VOC, NH_3	2-1	04/16/20	14:04	15:03	DAHS	01:00
U-00003	Base+DB	NOx, CO, VOC, NH_3	2-2	04/16/20	15:23	16:22	DAHS	01:00
U-00003	Base+DB	NOx, CO, VOC, NH_3	2-3	04/16/20	17:41	18:40	DAHS	01:00
U-00003	Base+DB	Opacity	Op-2-1	04/17/20	10:00	11:00	DAHS	01:00
U-00003	Base+DB	Opacity	Op-2-2	04/17/20	11:00	12:00	DAHS	01:00
U-00003	Base+DB	Opacity	Op-2-3	04/17/20	12:00	13:00	DAHS	01:00
U-00003	Base+DB	PM_{10}	PM U-00003 Base+DB-1	04/16/20	12:23	16:49	DAHS	04:26
U-00003	Base+DB	PM_{10}	PM U-00003 Base+DB-2	04/17/20	04:15	08:34	DAHS	04:19
U-00003	Base+DB	PM_{10}	PM U-00003 Base+DB-3	04/17/20	09:35	14:03	DAHS	04:28
U-00003	Base+DB	SAM	SAM U-00003 Base+DB-1	04/16/20	13:10	15:10	DAHS	02:00
U-00003	Base+DB	SAM	SAM U-00003 Base+DB-2	04/17/20	03:58	05:58	DAHS	02:00
U-00003	Base+DB	SAM	SAM U-00003 Base+DB-3	04/17/20	07:00	09:00	DAHS	02:00

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
NOx, CO, VOC, and NH_3

GENERAL ELECTRIC, 7F.05, UNIT #U-00003 BASE LOAD DATA SUMMARY

Parameter	Base Load, Run - 1-1	Base Load, Run - 1-2	Base Load, Run - 1-3	Average
Date (mm/dd/yy)	04/15/20	04/15/20	04/15/20	04/15/20
Start Time (hh:mm:ss)	12:10:05	13:23:05	14:35:05	12:10:05
End Time (hh:mm:ss)	13:09:35	14:22:35	15:34:35	15:34:35
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.99	30.11	30.09	30.06
Amb. Temp. (°F)	53	54	50	52
Rel. Humidity (%)	23	25	29	26
Spec. Humidity (lb water / lb air)	0.001939	0.002178	0.002181	0.002099
NH_3 Flow Rate (lb/hr)	141.6	135.3	137.4	138.1
Turbine Fuel Flow (lb/min)	1,651	1,646	1,643	1,646
Duct Burner Fuel Flow (lb/min)	0	0	0	0
Total Fuel Flow (SCFH)	2,293,723	2,287,005	2,282,441	2,287,723
Stack Flow (RM19) (SCFH)	52,372,088	52,469,624	52,110,077	52,317,263
Stack Moisture (% Method 4)	8.8	8.8	8.6	8.8
Heat Input (MMBtu/hr)	2,326.8	2,320.0	2,315.3	2,320.7
CT Power Output (megawatts)	237.6	237.1	237.5	237.4
NOx (ppmvd)	1.73	1.81	1.76	1.76
NOx (ppm@15%O_2)	1.27	1.34	1.29	1.30
CO (ppmvd)	0.00	0.00	0.00	0.00
CO (ppm@15%O_2)	0.00	0.00	0.00	0.00
VOC (as C1) (ppmvd)	0.00	0.00	0.01	0.00
VOC (as C1) (ppm@15%O_2)	0.00	0.00	0.01	0.00
Fuel Sulfur (grains / 100 scf)	0.04	0.04	0.04	0.04
CO_2 (%)	4.62	4.89	4.78	4.76
O_2 (%)	12.88	12.92	12.88	12.89

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO_2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH_3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO_2 (lb/lb-mole) =	44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO_2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH_3 =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO_2 =	0.0000001142434

NOTE: units are lb/ppm*ft^3

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$

2. Correction to % O_2, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$

3. Correction to % O_2 and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_O - 0.00633))} \times \left(\frac{288}{T_a}\right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000}\right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}}\right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O_2 based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp \cdot hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} \; or \; \frac{E_{lb/hr} \times 453.6}{hp}$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO_2 to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H_2O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
$\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
$\%_{CO2d}$,$\%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g.,24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO_2 rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O_2.
E_{jo},E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft^3 = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
$\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
$\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = $2x10^4$ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p,L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
$\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
$M_{\%}$ = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)[1]
NCM = net Btu per SCF (constant based on compound)
$\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
$\%_{O2d}$, $\%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO2 emissions, percent.
$\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
$\%_{Sf}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
$\%S_p$, $\%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
$t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2}=CO_2 Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

EXAMPLE CALCULATIONS (FFACTOR)

RM 19, (02-27-14),
2.0 Summary of Method,
2.1 Emission Rates. Oxygen (O_2) or carbon dioxide (CO_2) concentrations and appropriate F factors (ratios of combustion gas volumes to heat inputs) are used to calculate pollutant emission rates from pollutant concentrations.

RM 19, (02-27-14),
12.2 Emission Rates of PM, SO_2, and NOx. Select from the following sections the applicable procedure to compute the PM, SO_2, or NOx emission rate (E) in lb/MMBtu. The pollutant concentration must be in lb/scf and the F factor must be in scf/MMBtu. If the pollutant concentration (C) is not in the appropriate units, use Table 19–1 in Section 17.0 to make the proper conversion. An F factor is the ratio of the gas volume of the products of combustion to the heat content of the fuel. The dry F factor (F_d) includes all components of combustion less water, the wet F factor (F_w) includes all components of combustion, and the carbon F factor (F_c) includes only carbon dioxide.

Mark's Std Hdbk, 10th ed.,pg 4-26
High Heat Value Dry (HHV_{dry}), calc for Methane (single component for the fuel gas)

$$HHV_{dry}\left(Btu / SCF\right) = \left[\left(\frac{M_{\%}}{100}\right) \times GCM\right]$$

HHV_{dry} = 96.10 % / 100.00 x 994.85 Btu / SCF = 956.09 Btu / SCF

Mark's Std Hdbk, 10th ed., pg 4-26
Low Heat Value Dry (LHV_{dry}), calc for Methane (single component for the fuel gas)

$$LHV_{dry}\left(Btu / SCF\right) = \left[\left(\frac{M_{\%}}{100}\right) \times NCM\right]$$

LHV_{dry} = 96.10 % / 100.00 x 895.75 Btu / SCF = 860.86 Btu / SCF

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
High Heat Value Wet (HHV_{wet}), calc for entire sample (all components of the fuel gas)

$$HHV_{wet}\left(Btu / SCF\right) = \frac{HHV_{dry}}{W / D.factor}$$

HHV_{wet} = 1,014.41 Btu/SCF / 1.0236 = 991.02 Btu/SCF

Civil Eng. Ref. Man.,7th Ed.,pg 14-9/GPA Ref. Bulletin 181-86, App. C
Low Heat Value Wet (LHV_{wet}), calc for entire sample (all components of the fuel gas)

$$LHV_{wet}\left(Btu / SCF\right) = \frac{LHV_{dry}}{W / D.factor}$$

LHV_{wet} = 914.22 Btu/SCF / 1.0236 = 893.14 Btu/SCF

Lbs Component per Lb-Mol of Gas (CM), calc for Methane (single component for the fuel gas)

$$CM\left(lb / lb - mol\right) = \left[\left(\frac{M_{\%}}{100}\right) \times MW\right]$$

CM = 96.10 % / 100.00 x 16.04 lb / lb-mol = 15.42 lb/lb-mol

ASTM D 3588
Fuel Molecular Weight (MW_{Fuel})

$$MW_{Fuel}\left(lb / lb \cdot mol\right) = \left[\sum\left(CM\right)\right]$$

MW_{Fuel} = 15.42 lb/lb-mol
\+ 0.94 lb/lb-mol
+ etc. = 16.634 lb/lb-mol

Btu per Lb of Gas Gross (**GCV**)

$$GCV\left(Btu / lb\right) = \left[\frac{HHV_{dry} \times G}{MW_{Fuel}}\right]$$

GCV = 1,014.41 Btu/SCF x 385.23 ft^3/lbmol / 16.634 lb/lb-mol = 23,492.65 Btu/lb

ASTM D 3588 (SG)
Specific Gravity

$$SG = \left[\frac{MW_{Fuel}}{MW_{AIR}}\right]$$

SG = 16.63 lb/lb-mol / 28.96 lb/lb-mol = 0.5743

Btu per Lb of Gas Net (**NCV**)

$$NCV\left(Btu / lb\right) = \left[\frac{LHV_{dry} \times G}{MW_{Fuel}}\right]$$

NCV = 914.22 Btu/SCF x 385.23 ft^3/lbmol / 16.634 lb/lb-mol = 21,172.38 Btu/lb

Weight Percent of Component ($C_{\%}$), methane

$$C_{\%}\left(\%\right) = \left[\left(\frac{CM}{MW_{Fuel}}\right) \times 100\right]$$

$C_{\%}$ = 15.42 lb/lb-mol / 16.63 lb/lb-mol x 100 = 92.69 %

Weight Percent of Volatile Organic Compounds ($VOC_{\%}$)

$$VOC_{\%}(\%) = \left[\sum_{C_3H_8}^{C_8H_{18}} Wt_{\%}\right]$$

$VOC_{\%}$ = 0.37 % + 0.01 % + 0.02 % + etc. = 0.41 %

RM 19, (02-27-14), 12.3.2 Determined **F Factors**. If the fuel burned is not listed in Table 19–2 or if the owner or operator chooses to determine an F factor rather than use the values in Table 19–2, use the procedure below: 12.3.2.1 Equations. Use the eq

RM 19, (02-27-14),
12.1 Nomenclature

K (scf/lb)/%	
H	3.64
C	1.53
S	0.57
N_2	0.14
O_2	0.46

$$F_d = \frac{K\left(K_{hd}\%H + K_c\%C + K_s\%S + K_n\%N - K_o\%O\right)}{GCV} \qquad \text{Eq. 19-13}$$

F_d = 10^6Btu / MMBtu x [3.64 SCF / lb · % x 24.51 % + 1.53 SCF / lb · % x 74.42 % + 0.57 SCF / lb · % x 0.00 % + 0.14 SCF / lb · % x 0.60 % - 0.46 SCF / lb · % x 0.48 %] x lb / 23,492.65 Btu = 8,638.02 SCF / MMBtu

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RHsp (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp}(lb/lb) = \left[\left(\frac{gr}{lb}\right) \times \frac{lb}{7000\,gr}\right]$$

RH_{sp}= 13.57 gr / lb x 1 lb / 7000 gr = 0.001939 lb H_2O / lb Air

Fuel Flow Conversion (Q_f)

Note: Qf(lb/min) is a value obtained from the source operator.

$$Q_f = \left[Q_f \times G \times \left(\frac{1}{MW_{Fuel}}\right)\right]$$

Q_f = 1,650.71 lb / min x 60 min / hr x 385.23 ft^3 / lb-mol x lb-mol / 16.63 lb = 2,293,723 SCFH

Heat Rate (MMBtu/hr)

$$HR = \frac{HHV_{DRY} \times Q_f}{1{,}000{,}000}$$

Heat Rate = 1,014.41 Btu / SCF x 2,293,723.12 SCF / hr x MMBtu / 10^6 Btu = 2,326.77 MMBtu / hr

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

ACE = (4.85 ppm - 4.55 ppm) / 8.90 ppm x 100 = 3.37 %

Calibration Error and Estimated Point, RM 25A, THC/VOC Analyzer

RM 25A, (02-27-14), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC/VOC analyzer mid gas, if applicable)

$$E_P = \frac{C_{Dir(H)} - C_{Dir(Z)}}{C_{V(H)} - C_{V(Z)}} \times C_{Dir(M)} + C_{Dir(Z)}$$

Eq. of a line y=mx+b

E_p = (8.70 ppm - 0.00 ppm) / (8.78 ppm - 0.00 ppm) x 5.19 ppm + 0.00 = 5.14 ppm

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

ACE_{VOC} = (4.97 ppm - 5.14 ppm) / 5.19 ppm x 100 = -3.33 %

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS}\right) \times 100$$ Eq. 7E-2

SB = $\frac{4.60 \text{ ppm} - 4.85 \text{ ppm}}{8.90 \text{ ppm}}$ x 100 = -2.81 %

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = \left|SB_{final} - SB_i\right|$$ Eq. 7E-4

D = | -2.58 % - -2.81 % | = 0.22 %

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs – Cdir| is ≤ 0.5 ppmv or if |Cs – Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = \left|C_S - C_{Dir}\right|$$ Eq. Section 13.2 and 13.3

SB / D_{Alt} = | 4.60 ppm - 4.85 ppm | = 0.25 ppm

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$ Eq. 7E-5b

C_{Gas} = (1.78 ppm - 0.06 ppm) $\left(\frac{4.55 \text{ ppm}}{4.61 \text{ ppm} - 0.06 \text{ ppm}}\right)$ = 1.73 ppm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_W}{1 - B_{WS}}$$ Eq. 7E-10

C_D = $\frac{1.57 \text{ ppmvw}}{1 - 0.09}$ = 1.73 ppmvd or inversely, $C_W = C_D \times \left(1 - B_{WS}\right)$

C_W = 1.73 ppmvd x (1 - 0.09) = 1.57 ppmvw

Diluent-Corrected Pollutant Concentration, O_2 Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O_2 Concentration. Calculate the O_2 corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$ Eq. 20-4

C_{adj} = 1.73 ppm x $\left(\frac{20.9\% - 15.00\ \%}{20.9\% - 12.88\ \%}\right)$ = 1.27 ppm@15%O_2

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Historical Data	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
Run Start Time	08:23	13:45	06:46		hh:mm	
Run Stop Time	12:46	18:02	11:15		hh:mm	
Test Date	04/15/20	04/15/20	04/16/20		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.978	0.978	0.978			
Pitot Tube Coefficient	0.7720	0.7720	0.7720			
Average Nozzle Diameter	0.157	0.157	0.157		in	
Stack Test Data	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
Initial Meter Volume	258.170	358.270	461.100		ft^3	
Final Meter Volume	355.010	454.000	555.000		ft^3	
Total Meter Volume	96.840	95.730	93.900	95.490	ft^3	
Total Sampling Time	245.25	243.00	240.75	243.00	min	
Average Meter Temperature	80.08	82.33	69.50	77.31	°F	
Average Stack Temperature	209.08	191.92	184.58	195.19	°F	
Barometric Pressure	29.94	30.11	29.95	30.00	in Hg	
Stack Static Pressure	-0.92	-0.92	-0.92	-0.92	in H_2O	
Absolute Stack Pressure	29.87	30.04	29.88	29.93	in Hg	
Average Orifice Pressure Drop	0.46	0.47	0.46	0.46	in H_2O	
Absolute Meter Pressure	30.08	30.25	30.09	30.14	in Hg	
Avg Square Root Pitot Pressure	1.19	1.18	1.17	1.18	$\sqrt{(in\ H_2O)}$	
Moisture Content Data	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	167.20	157.20	44.60	123.00	g	
Silica Gel Weight Gain	23.80	27.20	107.70	52.90	g	
Total Water Volume Collected	191.34	184.73	152.57	176.22	ml	
Standard Water Vapor Volume	9.01	8.69	7.18	8.29	scf	
Standard Meter Volume	92.8	91.8	91.8	92.1	dscf	
Standard Metric Meter Volume	2.6	2.6	2.6	2.6	dscm	
Calculated Stack Moisture	8.85	8.65	7.26	8.25	%	
Saturated Stack Moisture	94.46	65.83	56.49	72.26	%	
Reported Stack Moisture Content	8.85	8.65	7.26	8.25	%	
Gas Analysis Data	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	4.9	4.8	4.8	4.8	%	
Oxygen Content	12.7	12.8	12.8	12.8	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.4	82.4	82.4	82.4	%	
Stack Dry Molecular Weight	29.29	29.28	29.28	29.28	lb/lb-mole	
Stack Wet Molecular Weight	28.29	28.30	28.46	28.35	lb/lb-mole	
Calculated Fuel Factor	1.673	1.688	1.688	1.683		
Fuel F-Factor	8638.02	8638.02	8641.42	8639.15	dscf/MMBtu	
Percent Excess Air	140.3	143.0	143.0	142.1	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Volumetric Flow Rate Data	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
Average Stack Gas Velocity	70.08	68.35	67.34	68.59	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft²	
Actual Stack Flow Rate	1,192,120	1,162,684	1,145,607	1,166,804	acfm	
Wet Standard Stack Flow Rate	56,355	56,732	56,233	56,440	wkscfh	
Dry Standard Stack Flow Rate	51,367,821	51,825,243	52,152,549	51,781,871	dscfh	
Percent of Isokinetic Rate	93.4	92.6	92.7	92.9	%	
Gravimetric Analysis	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	ml	
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	mg	
Emission Rate Data	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
Total PM_{10} Mass	6.60	5.30	4.20	5.37	mg	--
Total PM_{10} Concentration	7.12E-05	5.77E-05	4.58E-05	5.82E-05	g/dscf	--
	1.10E-03	8.91E-04	7.06E-04	8.98E-04	gr/dscf	--
Total PM_{10} Emission Rate	3.66	2.99	2.39	3.01	kg/hr	--
	8.06	6.59	5.26	6.64	lb/hr	--
	35.29	28.88	23.05	29.07	tpy	--
	0.0035	0.0028	0.0022	0.0028	lb/MMBtu	0.005
Filterable PM_{10} Mass	2.90	3.20	2.50	2.87	mg	--
Filterable PM_{10} Concentration	3.13E-05	3.48E-05	2.72E-05	3.11E-05	g/dscf	--
	4.82E-04	5.38E-04	4.20E-04	4.80E-04	gr/dscf	--
Filterable PM_{10} Emission Rate	1.61	1.81	1.42	1.61	kg/hr	--
	3.54	3.98	3.13	3.55	lb/hr	--
	15.51	17.44	13.72	15.56	tpy	--
	0.0015	0.0017	0.0013	0.0015	lb/MMBtu	--
Condensable PM_{10} Mass	3.70	2.10	1.70	2.50	mg	--
Condensable PM_{10} Concentration	3.99E-05	2.29E-05	1.85E-05	2.71E-05	g/dscf	--
	6.16E-04	3.53E-04	2.86E-04	4.18E-04	gr/dscf	--
Condensable PM_{10} Emission Rate	2.05	1.19	0.97	1.40	kg/hr	--
	4.52	2.61	2.13	3.09	lb/hr	--
	19.79	11.44	9.33	13.52	tpy	--
	0.0019	0.0011	0.0009	0.0013	lb/MMBtu	--
RM 201A Quality Control	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	**Average**	**Units**	**Limits**
Stack Viscosity	205.84	202.01	201.57	203.14	µP	
Cyclone Flow Rate	0.527	0.509	0.502	0.513	ft³/min	
Dry Gas Sampling Rate	0.378	0.378	0.381	0.379	dscfm	
Reynolds Number	2792.37	2837.93	2841.40	2,823.90		
Recalculated Cunninham	1.084	1.081	1.080	1.082		
Dia. of 50% Prob. (D50) CI	10.25	10.29	10.34	10.29		
Recalculated D50-1 for CIV	2.27	2.26	2.27	2.27		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Δp	0	0	0	0	points	

Nomenclature

- %CO = carbon monoxide concentration (%)
- $\%CO_2$ = carbon dioxide concentration (%)
- $\%N_2$ = nitrogen concentration (%)
- $\%O_2$ = oxygen concentration (%)
- $\%O_{2,wet}$ = Oxygen content of gas stream, % by volume of wet gas. (Note: The oxygen percentage used in Method 201A, Equation 3 is on a wet gas basis. That means that since oxygen is typically measured on a dry gas basis, the measured percent O2 must be multiplied by the quantity (1 - B_{ws}) to convert to the actual volume fraction. Therefore, $\%O_{2,wet} = (1 - B_{ws}) * \%O_{2, dry}$)
- $(\%EA)_{avg}$ = average excess air (%)
- $(F_o)_{avg}$ = average calculated fuel factor
- $[(\Delta p)^{0.5}]_{avg}$ = Average of square roots of the velocity pressures measured during the preliminary traverse, inches W.C.
- μ = Gas viscosity, micropoise
- 12.0 = Constant calculated as 60 percent of 20.5 square inch cross-sectional area of combined cyclone head, square inches
- 17.03 = mg/milliequivalents for ammonium ion
- 22.4 = liters of ideal gas per lb-mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 24.04 = liters of ideal gas per lb-mol of substance at 20°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 5.02×10^4 = constant derived from the molecular weight and correcting standard temperature and pressure (ref. Bay Area Air Quality Management District, Source Test Procedure ST-1B, Ammonia Integrated Sampling, Adopted January 20, 1982, Regulation 7-303)
- A = distance upstream (in.)
- A_D = stack diameters upstream (dia.)
- An = Area of nozzle, square feet
- A_s = area of stack (ft^2)
- B = distance downstream (in.)
- B_D = stack diameters downstream (dia.)
- b_f = Average blockage factor calculated in Equation 26, dimensionless
- B_{wm} = meter moisture content (%)
- B_{ws} = stack moisture content (%)
- C = Cunningham correction factor for particle diameter, Dp, and calculated using the actual stack gas temperature, dimensionless
- C_1 = -150.3162 (micropoise)
- C_2 = 18.0614 (micropoise/$K^{0.5}$) = 13.4622 (micropoise/$R^{0.5}$)
- C_3 = 1.19183×10^6 (micropoise/K^2) = 3.86153×10^6 (micropoise/R^2)
- C_4 = 0.591123 (micropoise)
- C_5 = 91.9723 (micropoise)
- C_6 = 4.91705×10^{-5} (micropoise/K^2) = 1.51761×10^{-5} (micropoise/R^2)
- C_a = Acetone blank concentration, mg/mg
- C_b = Concentration of NH3 ion in the back half of train (breakthrough)
- C_f = Concentration of NH3 ion in the front half of train (main catch)
- C_{fPM10} = Conc. of filterable PM_{10}, gr/dscf
- $C_{fPM2.5}$ = Conc. of filterable $PM_{2.5}$, gr/dscf
- C_k = K Factor Constant, 849.8

Nomenclature

- C_n = nozzle diameter constant, 0.03575
- C_p' = Coefficient for the pitot used in the preliminary traverse, dimensionless
- C_p = Pitot coefficient for the combined cyclone pitot, dimensionless
- C_{cpm} = Concentration of the condensable PM in the stack gas, dry basis, corrected to standard conditions, milligrams/dry standard cubic foot.
- C_r = Re-estimated Cunningham correction factor for particle diameter equivalent to the actual cut size diameter and calculated using the actual stack gas temperature, dimensionless
- D_{50} = Particle cut diameter, micrometers
- $D_{50(N+1)}$ = D_{50} value for cyclone IV calculated during the N+1 iterative step, micrometers
- D_{50-1} = Re-calculated particle cut diameters based on re-estimated C_r, micrometers
- D_{50LL} = Cut diameter for cyclone I corresponding to the 2.25 micrometer cut diameter for cyclone IV, micrometer
- D_{50N} = D_{50} value for cyclone IV calculated during the Nth iterative step, micrometers
- D_{50T} = Cyclone I cut diameter corresponding to the middle of the overlap zone shown in Method 201A, Figure 10 of Section 17, micrometers
- D_e = equivalent stack diameter (in.)
- ΔH@ = ΔH @ 0.75 scfm (in. H2O)
- ΔH_{avg} = average orifice pressure (in. H_2O)
- D_n = Inner diameter of sampling nozzle mounted on Cyclone I, inches
- D_{na} = actual nozzle diameter (in.)
- D_p = Physical particle size, micrometers
- Δp = velocity head (in. H_2O)
- Δp_1 = velocity head at first current traverse point (in. H_2O)
- $\Delta p'_1$ = velocity head at first preliminary traverse point (in. H_2O)
- Δp_{avg} = average pitot tube differential pressure (in. H_2O)
- Δp_n = velocity head at subsequent current traverse point (in. H_2O)
- Δp_{RM2} = method 2 velocity head (in. H_2O)
- D_s = diameter of stack (in.)
- F_d = fuel f-factor (dscf/MMBtu)
- f_{O2} = stack gas fraction of O_2, by volume, dry basis
- I = Percent isokinetic sampling, dimensionless
- K_1 = standard volume correction, 17.65^{o}R/in. Hg
- K_4 = isokinetic conversion constant, 0.0945min•in.Hg/sec•^{o}R
- K_5 = water mass to std water vapor, 0.04715 ft^3/g
- K_p = 85.49, ((ft/sec)/(pounds/mole -^{o}R))
- L = length of stack (in.)
- L_{fw} = distance to far wall of stack (in.)
- L_{nw} = distance to near wall of stack (in.) [reference]
- $m_{\#x}$ = weight measurements (g)
- M_1 = Milligrams of PM collected on the filter, less than or equal to 2.5 micrometers
- M_2 = Milligrams of PM recovered from Container #2 (acetone blank corrected), greater than 10 micrometers
- M_3 = Milligrams of PM recovered from Container #3 (acetone blank corrected), less than or equal to 10 and greater than 2.5 micrometers
- M_4 = Milligrams of PM recovered from Container #4 (acetone blank corrected), less than or equal to 2.5 micrometers

Nomenclature

- m_a = Mass of residue of acetone after evaporation, mg
- m_c = Mass of the NH4+ added to sample to form ammonium sulfate, mg
- m_{cpm} = Mass of the total condensable PM, mg
- M_d = Molecular weight of dry gas, pounds/pound mole
- m_{fb} = Mass of total CPM in field train recovery blank, mg
- m_{fx} = final weight, avg of last two measurements (g)
- mg = Milligram
- mg/L = Milligram per liter
- m_i = Mass of inorganic CPM, mg
- m_{ib} = Mass of inorganic CPM in field train recovery blank, mg
- M_n = total particulates (mg)
- m_o = Mass of organic CPM, mg
- m_{ob} = Mass of organic CPM in field train blank, mg
- m_r = Mass of dried sample from inorganic fraction, mg
- m_{tx} = tare weight (g)
- MW = molecular weight (lb/lb-mole)
- M_w = Molecular weight of wet gas, pounds/pound mole
- N = Normality of ammonium hydroxide titrant
- N_a = null angle (deg.)
- N_{re} = Reynolds number, dimensionless
- N_{tp} = Number of iterative steps or total traverse points
- P_b = P_{bar} = barometric pressure (in. Hg)
- P_{bar} = barometric pressure (in. Hg)
- ppmCO = carbon monoxide concentration (ppm)
- ppmv = Parts per million by volume
- ppmw = Parts per million by weight
- P_s = absolute stack pressure (in. Hg)
- P_{static} = static pressure (in. H_2O)
- P_{std} = standard pressure, 29.92 in. Hg
- Θ = total sampling time (min)
- Q_{aw} = average stack wet flow rate (ascf/min)
- Q_I = Sampling rate for cyclone I to achieve specified D_{50}
- Q_m = estimated orifice flow rate, 0.750 acfm, else Vm/Q from previous run
- Q_s = Sampling rate for cyclone I to achieve specified D_{50}
- $Q_{s(std)}$ = total cyclone flow rate at standard conditions (dscf/min)
- Q_{sd} = dry standard stack flow rate (dscfm)
- Q_{sST} = Dry gas sampling rate through the sampling assembly, dscfm
- Q_{sw} = wet standard stack flow rate (ascfm)
- R_{max} = Nozzle/stack velocity ratio parameter, dimensionless
- R_{min} = Nozzle/stack velocity ratio parameter, dimensionless
- t_1 = Sampling time at point 1, min
- t_m = average gas meter temperature (^oF)
- t_m = average meter temperature (^oF)
- T_m = Meter box and orifice gas temperature, ^oR
- t_n = Sampling time at point n, min

Nomenclature

- t_r = Total projected run time, min
- T_s = Absolute stack gas temperature, ^oR
- T_{std} = standard temperature, 68^oF, 528^oR
- T_u = absolute temperature offset, 460^oR
- V_a = Volume of acetone blank, ml
- V_{aw} = Volume of acetone used in sample recovery wash, ml
- V_b = Volume of aliquot taken for IC analysis, ml
- V_c = Quantity of water captured in impingers and silica gel, ml
- V_f = final impinger volume (ml)
- V_i = initial impinger volume (ml)
- V_{ic} = Volume of impinger contents sample, ml
- V_m = Dry gas meter volume sampled, acf
- $V_{m(std)}$ = standard meter volume (dscf)
- v_{max} = Maximum gas velocity calculated from Equations 18 or 19, ft/sec
- v_{max} = maximum nozzle velocity (ft/sec)
- V_{mf} = final dry gas meter reading (dcf)
- V_{mi} = initial dry gas meter reading (dcf)
- v_{min} = Minimum gas velocity calculated from Method 201A, Equations 16 or 17, ft/sec
- V_{ms} = Dry gas meter volume sampled, corrected to standard conditions, dscf
- v_n = Sample gas velocity in the nozzle, ft/sec
- v_{org} = organics wash volume (ml)
- V_p = Volume of water added during train purge
- v_s = average stack gas velocity (ft/sec)
- v_{sl} = local velocity (ft/sec)
- V_t = total impinger volume (ml) = ;(V_f-V_i)
- V_t = Volume of NH4OH titrant, ml
- $V_{w(std)}$ = volume of water vapor in gas sample at standard conditions (scf)
- v_x = blank volume (ml)
- W = width of stack (in.)
- $W_{2,3,4}$ = Weight of PM recovered from Containers #2, #3, and #4, mg
- W_a = Weight of blank residue in acetone used to recover samples, mg
- W_f = final impinger weight (g)
- W_i = initial impinger weight (g)
- W_t = total impinger weight (g) = ;(W_f-W_i)
- w_x = blank weight of solids (g)
- Y = meter calibration factor (a.k.a gamma)
- Z = Ratio between estimated cyclone IV D_{50} values, dimensionless
- γ = Dry gas meter gamma value, dimensionless
- ΔH = Meter box orifice pressure drop, inches W.C.
- ΔH@ = Pressure drop across orifice at flow rate of 0.75 scfm at standard conditions, inches W.C. (Note: Specific to each orifice and meter box.)
- Δp_1 = Velocity pressure measured at point 1, inches W.C.
- Δp_{avg} = Average velocity pressure, inches W.C.
- Δp_m = Observed velocity pressure using S-type pitot tube in preliminary traverse, inches W.C.
- Δp_{max} = Maximum velocity pressure, inches W.C.

Nomenclature

- Δp_{min} = Minimum velocity pressure, inches W.C.
- Δp_n = Velocity pressure measured at point n during the test run, inches W.C.
- Δp_s = Velocity pressure calculated in Method 201a, Equation 25, inches W.C.
- Δp_{s1} = Velocity pressure adjusted for combined cyclone pitot tube, inches W.C.
- Δp_{s2} = Velocity pressure corrected for blockage, inches W.C.
- θ = Total run time, min
- ρ_a = Density of acetone, mg/ml (see label on bottle)
- Σ_n = total number of sampling points

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{mw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]

Carbon Monoxide Concentration (%)

$$\%CO = \frac{ppmCO}{10{,}000}$$

$$\%CO\ (\%) = \frac{0.00 \quad ppm}{10{,}000\ ppm/\%} = 0.0000\ \%$$

Nitrogen Concentration (%)

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$\%N_2$ (%) = 100 - 4.90 % - 12.70 % - 0.00 / 10,000 % = 82.4 %

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d\,(lb/lb-mol) = \sum\left(\frac{MW_{comp}}{100} \times \%component\right)$$

$$M_d\ (lb/lb\text{-}mol) = \left(\frac{44\ lb/lb\text{-}mol}{100} \times 4.90\ \%\right) +$$

$$\left(\frac{32\ lb/lb\text{-}mol}{100} \times 12.70\ \%\right) + \left(\frac{28\ lb/lb\text{-}mol}{100} \times \left[\frac{0.00}{10{,}000} + 82.40\ \right]\right) = \frac{29.29\ lb}{lb\text{-}mol}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_S\,(lb/lb-mol) = \left[M_d \times \left(1 - \frac{B_{WS}}{100}\right)\right] + \left[MW_{H_2O} \times \frac{B_{WS}}{100}\right]$$

$$M_S\ (lb/lb\text{-}mol) = \left\{\frac{29.29\ lb}{lb\text{-}mol} \times \left(1 - \frac{8.85\ \%}{100}\right)\right\} + \left\{\frac{18\ lb}{lb\text{-}mol} \times \frac{8.85\ \%}{100}\right\} = \frac{28.29\ lb}{lb\text{-}mol}$$

Average Calculated Fuel Factor (F_o)

$$F_{o(avg)} = \frac{\left[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - 12.70\ \% - (0.5 \times 0.000\ \%)}{4.90\ \% + 0.000\ \%} = 1.673$$

Average Excess Air (%)

$$\%EA_{avg}\,(\%) = \frac{100 \times \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(0.264 \times (N_2)_{avg}) - \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{\ 12.70\ \% - (0.5 \times 0.000\ \%)\ \}}{(\ 0.264 \times 82.40\ \%) - \{\ 12.70\ \% - (0.5 \times 0.000\ \%)\}} = 140.28\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]

Absolute Stack Pressure (in. Hg)

$$P_S(in.Hg) = P_b + \frac{P_{static}}{13.6}$$

P_s (in. Hg) = 29.94 in. Hg + $\frac{\text{-0.92 in. } H_2O}{\text{13.6 in. } H_2O/\text{in. Hg}}$ = 29.87 in. Hg

Average Stack Gas Velocity (ft/sec)

$$v_s(ft/\sec) = K_p \times C_p \times \left(\sqrt{\Delta p}\right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

v_{sl} (ft/sec) =

$\left(\frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\text{sec } (^oR)(\text{in. } H_2O)}\right)^{1/2}$ x 0.77 x 1.19 in.$H_2O^{1/2}$ x $\sqrt{\frac{209.08 + 460\ ^oR}{29.87 \text{ in. Hg x } 28.29 \text{ lb/lb-mol}}}$ = $\frac{70.0 \text{ ft}}{\text{sec}}$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd}(dscfh) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sd} (dscf/hr) = $\frac{3600 \text{ sec}}{\text{hr}}$ x (1 - $\frac{8.85\ \%}{100}$) x $\frac{70.08 \text{ ft}}{\text{sec}}$ x 283.53 ft^2 x $\frac{68.00 + 460\ ^oR}{209.08 + 460\ ^oR}$ x $\frac{29.87 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{51{,}367{,}821.40 \text{ dscf}}{\text{hr}}$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw}(acfm) = 60 \times v_s \times A_s$$

Q_{aw} (acf/min) = $\frac{60 \text{ sec}}{\text{min}}$ x $\frac{70.08 \text{ ft}}{\text{sec}}$ x 283.53 ft^2 = $\frac{1{,}192{,}120.07 \text{ acf}}{\text{min}}$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw}(ascfh) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sw} (ascf/hr) = $\frac{60 \text{ min}}{\text{hr}}$ x $\frac{1{,}192{,}120.07 \text{ acf}}{\text{min}}$ x $\frac{68.00 + 460\ ^oR}{209.08 + 460\ ^oR}$ x $\frac{29.87 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{56{,}355{,}045.37 \text{ ascf}}{\text{hr}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 191.00 g x 0.04715 ft^3/g = 9.006 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65\ ^\circ R}{\text{in. Hg}} \times 0.98 \times 96.84\ \text{dcf} \times \frac{(29.94\ \text{in. Hg} + \frac{0.46\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}})}{80.08\ ^\circ F + 460\ ^\circ R} = 92.76\ \text{dscf}$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{9.01\ \text{dscf}}{9.01\ \text{dscf} + 92.76\ \text{dscf}} = 8.85\ \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)}(\%) = 100 \times \frac{10^{6.691 - \frac{3144}{t_{s(avg)} + 390.86}}}{P_b + \frac{P_{static}}{13.6}} \leq 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{(6.691 - \frac{3144}{209.08\ ^\circ F + 390.86})}}{29.94\ \text{in. Hg} + \frac{-0.92\ \text{in. } H_2O}{13.6\ \text{in. } H_2O / \text{in. Hg}}} \leq 100 = 94.46\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Desired Orifice (in. H_2O) (first point)

$$\Delta H_d\,(in.H_2O) = K \times \Delta p$$

ΔH_d (in. H_2O) = x

in. H_2O = in. H_2O

Absolute Meter Pressure (in. Hg)

$$P_m\,(in.Hg) = P_b + \frac{\Delta H\,@}{13.6}$$

P_m (in. Hg) = 29.94 in. Hg + $\frac{1.85 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.08 in. Hg

Recommended Nozzle Diameter (in.)

$$D_{nt}\,(in.) = \sqrt{\frac{C_{ti} \times Q_{mi} \times P_{mi}}{(t_{mi} + T_{ti}) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}}\right)} \times \sqrt{(t_s + T_{ti}) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}{P_s \times \Delta p_{avg}}\right]}$$

$$D_{ni}\,(in.) = \sqrt{\frac{0.03575 \text{ (lb-mole•°R•in. } H_2O)^{1/2}\text{•min•in.}^2}{\text{acf•in. Hg}^{3/4}\text{•lb}^{1/2}} \text{ x } 0.75 \text{ acf x } 30.08 \text{ in. Hg } \left(1 - \frac{0.00\ \%}{100}\right) \text{ x } \left(\frac{1}{1 - \frac{8.85\ \%}{100}}\right) \text{ x } \sqrt{(209.08\ ^\circ\text{F} + 460^\circ\text{R}) \text{ x } \frac{\frac{29.29 \text{ lb}}{\text{lb-mole}} \text{ x } \left(1 - \frac{8.85\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{8.85\ \%}{100}\right)}{29.87 \text{ in. Hg x } 1.19 \text{ in. } H_2O}}} \text{ x } \left(\frac{80.08\ ^\circ\text{F} + 460^\circ\text{R}}{0.77}\right)} = 0.211 \text{ in.}$$

ΔP to ΔH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H\,@ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100}\right) + \left(18 \times \frac{B_{wm}}{100}\right)}{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}\right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}}\right)^2 \times \left(\frac{t_m + T_u}{ts + T_u}\right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. } H_2O\text{•in.}^4} \text{ x } 0.77^2 \text{ x } 1.85 \text{ in. } H_2O \text{ x } 0.16^4 \text{ x } \left(\frac{1 - \frac{8.85\ \%}{100}}{1 - \frac{0.00\ \%}{100}}\right)^2 \text{ x } \frac{80.08\ ^\circ\text{F} + 460^\circ\text{R}}{209.08\ ^\circ\text{F} + 460^\circ\text{R}} \text{ x } \left(\frac{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{0.00\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{0.00\ \%}{100}\right)}{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{8.85\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{8.85\ \%}{100}\right)}\right) \text{ x } \frac{29.87 \text{ in. Hg}}{30.08 \text{ in. Hg}} = 0.39$$

Percent Isokinetic (%) (first point)

$$I\,(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I\,(\%) = \frac{\frac{0.0945 \text{ min•in. Hg}}{\text{sec•°R}} \text{ x } (212.00\ ^\circ\text{F} + 460\ ^\circ\text{R}) \text{ x } 8.07 \text{ dscf}}{21.00 \text{ min x } \frac{72.08 \text{ ft}}{\text{sec}} \text{ x } 29.87 \text{ in. Hg x } 3.14 \text{ x } \left(\frac{0.16 \text{ in.}}{2} \text{ x } \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \text{ x } \left(1 - \frac{8.85\ \%}{100}\right)} = 92.53\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Cumulative Percent Isokinetic (%) (weighted average of all points)

$$I(\%) = \sum_{1-n} \frac{\left[I(\%) \times V_{m(std)}\right]_{1-n}}{V_{m(std)_{1-n}}}$$

Using Method 5, Eq 5-8 to determine intermediate isokinetics at each point, weighted averaging of the cumulative isokinetics is necessary since all points are not equal, and determined by using the dry standard meter volume collected at each point to weight the cumulative average. Intermediate isokinetics and dry standard meter volumes are found at each point. At each point the cumulative sum is found of each value and the quotient of the two used to determine the cumulative isokinetics for each residual point (n).

Pt	In (%)	x	Vm(std)n	=	I (%)n	∑(I (%)n)	/	∑(Vm(std)n)	=	I (%)
A-1	92.53	x	8.073	=	747.02	747.02	/	8.07	=	92.5
A-2	93.28	x	7.570	=	706.15	1453.17	/	15.64	=	92.9
A-3	104.65	x	8.481	=	887.52	2340.69	/	24.12	=	97.0
B-1	93.73	x	8.172	=	765.91	3106.60	/	32.30	=	96.2
B-2	91.43	x	7.965	=	728.26	3834.86	/	40.26	=	95.2
B-3	92.51	x	6.977	=	645.41	4480.27	/	47.24	=	94.8
C-1	95.77	x	7.779	=	745.00	5225.27	/	55.02	=	95.0
C-2	91.58	x	8.003	=	732.92	5958.19	/	63.02	=	94.5
C-3	98.62	x	8.064	=	795.27	6753.46	/	71.08	=	95.0
D-1	88.81	x	7.284	=	646.94	7400.40	/	78.37	=	94.4
D-2	87.98	x	7.745	=	681.42	8081.81	/	86.11	=	93.9
D-3	87.57	x	6.659	=	583.14	8664.95	/	92.77	=>	93.4

Last Pt

Percent Isokinetic (%) (intermediate equation, all points)
[equivalent to taking an average of point-by-point isokinetics without weighting the average (e.g. all points equal)]

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I(\%) = \frac{\frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^{\circ}\text{R}} \times (209.08\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times 92.76 \text{ dscf}}{245.25 \text{ min} \times \frac{70.08 \text{ ft}}{\text{sec}} \times 29.87 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \times \left(1 - \frac{8.85\ \%}{100}\right)} = 93.22\ \%$$

Raw Data Percent Isokinetic (%)
[utilizes the raw data equation for isokinetics from Method 5]

$$I(\%) = \frac{100\left((t_s)_{avg} + T_u\right)\left[K_4 V_{1c} + \frac{V_m Y}{(t_m)_{avg} + T_u}\left(P_{bar} + \frac{\Delta H}{13.6}\right)\right]}{60\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right)}$$

$$I(\%) = \frac{100 \times (209.08\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times \left[\frac{0.002669 \text{ ft}^3\text{•in. Hg}}{\text{ml•}^{\circ}\text{R}} \times 191.3 \text{ ml} + \frac{96.84 \text{ dcf} \times 0.978}{80.08\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}} \times \left(29.94 \text{ in Hg} + \frac{1.193}{13.6}\right)\right]}{60 \times 245.25 \text{ min} \times \frac{70.08 \text{ ft}}{\text{sec}} \times 29.87 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2} = 93.33\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Gravimetric Analysis) [Values from Run 1 test]

Blank Concentration [Acetone Blank Weight of Solids] (mg/ml)

$$C_x\,(mg/ml) = \frac{1000 \times w_x}{v_x}$$

C_x (mg/ml) = $\frac{1000\ mg}{g}$ x $\frac{0.0000\ g}{200.60\ ml}$ = $\frac{0.0000\ mg}{ml}$ = $\frac{\quad mg}{ml}$

Blank Adjustment [Acetone Blank Weight of Solids and Nozzle Wash PM>10] (mg)

$$W_x\,(mg) = v_x \times C_x$$

W_x (mg) = 78.00 ml x 0.0000 mg/ml = 0.00 mg < Sample Gain

Sample Gain [Nozzle Wash PM>10] (mg)

$$m_x\,(mg) = \left(m_{fx} - m_{tx}\right) \times 1000$$

m_x (mg) = $\frac{1000\ mg}{g}$ x (0.0175 g - 0.00 g) = 17.50 mg

Adjusted Sample Gain [Nozzle Wash PM>10] (mg)

$$m_{xadj}\,(mg) = m_x - W_x$$

m_{xadj} (mg) = 17.50 mg - 0.00 mg = 17.50 mg

0.1N NH_4OH Correction (mg)

$$m_c\,(mg) = 17.03 \times V_t \times N$$

m_c (mg) = 17.03 x 0.00 ml x 0.1 N = 0.00 mg

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - Total PM_{10} Mass]

Stack Total Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s \text{ (g/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{6.60 mg}}{\text{92.76 dscf}} = \frac{\text{7.12E-05 g}}{\text{dscf}}$$

Stack Total Concentration (gr/dscf)

$$c_s'(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s \text{ (gr/dscf)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{6.60 mg}}{\text{92.76 dscf}} \times \frac{\text{7000 gr}}{\text{lb}} \times \frac{\text{lb}}{\text{453.592 g}} = \frac{\text{1.10E-03 gr}}{\text{dscf}}$$

Total Emissions Rate (kg/hr)

$$E(kg/hr) = c_s \times Q_{sd} \times \frac{kg}{1000\ g}$$

$$E \text{ (kg/hr)} = \frac{\text{kg}}{\text{1000 g}} \times \frac{\text{7.12E-05 g}}{\text{dscf}} \times \frac{\text{51,367,821 dscf}}{\text{hr}} = \frac{\text{3.66 kg}}{\text{hr}}$$

Total Emissions Rate (lb/hr)

$$E'(lb/hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{lb \times g}{453.592 g \times 1000 mg}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{6.60 mg}}{\text{92.76 dscf}} \times \frac{\text{51,367,821 dscf}}{\text{hr}} = \frac{\text{8.06 lb}}{\text{hr}}$$

Total Emissions Rate (tpy)

$$E''(ton/yr) = E' \times \frac{8760}{2000}$$

$$E'' \text{ (tpy)} = \frac{\text{ton}}{\text{2000 lb}} \times \frac{\text{8,760 hr}}{\text{yr}} \times \frac{\text{8.06 lb}}{\text{hr}} = \frac{\text{35.29 ton}}{\text{yr}}$$

Total Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{\text{1000 mg}} \times \frac{\text{lb}}{\text{453.592 g}} \times \frac{\text{6.60 mg}}{\text{92.76 dscf}} \times \frac{\text{8,638.02 dscf}}{\text{MMBtu}} \times \left(\frac{\text{20.9}}{\text{20.9 - 12.7 \%}}\right) = \frac{\text{0.0035 lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Stack Gas Viscosity (μP) [based on preliminary data] [RM 201A, Eq. 3]

$$\mu(\mu P) = C_1 + C_2\sqrt{T_s} + C_3 T_s^{-2} + C4(\%O_{2,wet}) - C_5 B_{ws} + C_6 B_{ws} T_s^2$$

μ (μP) = -150.3162 μP + 13.4622 $\sqrt{\quad 213 \quad + 460}$ + 3.86153x10^{6} (213 + 460)$^{-2}$ + 0.591123 (13.0 x (1 - 8.00 /100)
- 91.9723 (8.00 /100) + 1.51761x10^{-5} (8.00 /100)(213 + 460)^2 = 207.77 μP

Cunningham Correction Factor [RM 201A, Eq. 4]
[based on preliminary data for a 2.25 micrometer diameter particle]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{207.77\ \mu P}{29.87\ \text{in Hg} \times 2.25\ \mu m}\right)\left(\frac{213 + 460\ ^{o}R}{28.40\ \text{lb / lb-mole}}\right)^{0.5} = 1.09$$

First calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}<3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 5]
[assumes N_{re}<3,162]

$$D_{50LL}(\mu m) = 9.507 C^{0.3007}\left[\frac{M_w P_s}{T_s}\right]^{0.1993}$$

$$D_{50LL}\ (\mu m) = 9.507 \times 1.09^{\,0.3007} \times \left(\frac{29.87\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{213 + 460\ ^{o}R}\right)^{0.1993} = 10.21\ \mu m$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}<3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

$$D_{50T}\ (\mu m) = \frac{11 + 10.21\ \mu m}{2} = 10.60\ \mu m$$

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}<3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu)\left[\frac{T_S}{M_w P_S}\right]^{0.2949}\left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

$$0.07296 \times 207.77\ \mu P \times \left(\frac{213 + 460\ ^{o}R}{29.87\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}\right)^{0.2949} \times \left(\frac{1}{10.60\ \mu m}\right)^{1.4102} = 0.51\ \text{acfm}$$

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5\left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

$$N_{re} = 8.64 \times 10^5 \times \frac{29.87\ \text{in Hg} \times 28.40\ \text{lb / lb-mole}}{213 + 460\ ^{o}R} \times \frac{0.51\ \text{acfm}}{207.77\ \mu P} = 2656.73 < 3,162$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Second calculation set using Cyclone IV, assuming N_{re}<3,162

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]
[assumes N_{re}<3,162]

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) =

0.0024302 x (207.77 µP / 0.51 acfm)$^{1.1791}$ x (1 / 1.09)$^{0.5}$ x (213 + 460 °R / 29.87 in Hg x 28.40 lb / lb-mole)$^{0.6790}$ = 2.40 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Less than 3,162 (acfm) [RM 201A, Eq. 8]

$$Q_{IV}(acfm) = 0.0060639 \left(\frac{\mu}{C^{0.4242}}\right) \left[\frac{P_s M_w}{T_s}\right]^{-.05759} \left[\frac{1}{D_{50}}\right]^{0.8481}$$

Q_{IV} (acfm) =

0.0060639 x (207.77 µP / 1.09 $^{0.4242}$) x (29.87 in Hg x 28.40 lb / lb-mole / 213 + 460 °R)$^{-0.5759}$ x (1 / 2.40 µm)$^{0.8481}$ = 0.51 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

N_{re} = 8.64 x 10^5 x 29.87 in Hg x 28.40 lb / lb-mole / 213 + 460 °R x 0.51 acfm / 207.77 µP = 2656.69 < 3,162

Third calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}≥3,162

Lower Limit Cut Diameter for Cyclone I (µm) [RM 201A, Eq. 12]
[assumes N_{re}≥3,162]

$$D_{50LL}(\mu m) = 10.0959 C^{0.4400} \left[\frac{M_w P_s}{T_s}\right]^{0.0600}$$

D_{50LL} (µm) = 10.0959 x 1.09 $^{0.4400}$ x (29.87 in Hg x 28.40 lb / lb-mole / 213 + 460 °R)$^{0.0600}$ = 10.62 µm

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (µm) [RM 201A, Eq. 6]
[assumes N_{re}≥3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

D_{50T} (µm) = (11 + 10.62 µm) / 2 = 10.81 µm

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}≥3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu) \left[\frac{T_s}{M_w P_s}\right]^{0.2949} \left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

0.07296 x 207.77 µP x (213 + 460 °R / 29.87 in Hg x 28.40 lb / lb-mole)$^{0.2949}$ x (1 / 10.81 µm)$^{1.4102}$ = 0.49 acfm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (29.87 in Hg x 28.40 lb / lb-mole) / (213 + 460 °R) x (0.49 acfm) / (207.77 µP) = 2585.93 < 3,162

Fourth calculation set using Cyclone IV, assuming N_{re}≥3,162

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]
[assumes N_{re}≥3,162]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x (207.77 µP / 0.49 acfm)$^{0.8058}$ x (1 / 1.09)$^{0.5}$
x (213 + 460 °R / 29.87 in Hg x 28.40 lb / lb-mole)$^{0.3058}$ = 2.30 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Greater than or Equal to 3,162 (acfm) [RM 201A, Eq. 9]

$$Q_{IV}(acfm) = 0.007657 \left(\frac{\mu}{C^{0.6205}}\right)\left[\frac{P_s M_w}{T_s}\right]^{-0.3795}\left[\frac{1}{D_{50}}\right]^{1.241}$$

Q_{IV} (acfm) =

0.007657 x (207.77 µP / 1.09 $^{0.6205}$) x (29.87 in Hg x 28.40 lb / lb-mole / 213 + 460 °R)$^{-0.3795}$
x (1 / 2.30 µm)$^{1.241}$ = 0.49 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (29.87 in Hg x 28.40 lb / lb-mole) / (213 + 460 °R) x (0.51 acfm) / (207.77 µP) = 2656.73 < 3,162

Meter Box Orifice Pressure Drop (in H_2O) [RM 201A, Eq. 11]
As calculated using applicable calculation set 1, 2, 3, or 4

$$\Delta H(inH_2O) = \left[\frac{Q_s(1-B_{ws})P_s}{T_s}\right]^2\left[\frac{1.083 T_m M_d \Delta H_@}{P_{bar}}\right]$$

ΔH (in H_2O) = (0.51 acfm x (1 - 8.00 /100) x 29.87 in Hg / 213 + 460 °R)^2
x (1.083 x (85.00 + 460 °R) x 29.30 lb / lb-mole x 1.846 in H_2O / 29.94 in Hg) = 0.457 in H_2O

50 °F above stack temperature	T_{s+50} =	263	ΔH_{+50} =	0.396 in H_2O
50 °F below stack temperature	T_{s+50} =	163	ΔH_{+50} =	0.533 in H_2O

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Adjusted Velocity Pressure (in H_2O) [point A-1] [RM201A, Eq. 25]

$$\Delta p_s\,(inH_2O) = \Delta p_m \left[\frac{C_p}{C'_p}\right]^2$$

Δp_s (in H_2O) = 1.70 in H_2O x (0.7720 / 0.8198)^2 = 1.51 in H_2O

Average Probe Blockage Factor [RM201A, Eq. 26]

$$b_f = \frac{22.0}{A}$$

b_f = 22.0 / 40828.14 in^2 = 5.39E-04

Velocity Pressure Adjusted for Blockage Factor (in H_2O) [point A-1] [RM201A, Eq. 27]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$\Delta p_{s2}\,(inH_2O) = \Delta p_{s1}\left[\frac{1}{(1-b_f)}\right]^2$$

Δp_s (in H_2O) = 1.51 in H_2O x (1 / (1 - 0.00E+00))^2 = 1.51 in H_2O

Velocity of Stack Gas Adjusted for Blockage Factor and/or C_p / C'_p (ft/sec) [RM201A, Eq. 13]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$v_s = K_p C_p \left(\sqrt{(\Delta p)}\right)_{avg}\left[\sqrt{\frac{T_s}{P_s M_w}}\right]$$

v_s (ft/sec) =

85.49 ft/sec / lb/mole - °R x 0.7720 x 1.17 x (213 + 460 °R / 29.87 in Hg x 28.40 lb / lb-mole)$^{0.5}$ = 68.88 ft/sec

Calculated Nozzle Diameter for Acceptable Sampling Rate (in) [RM201A, Eq. 14]

$$D(in) = \left[\frac{3.056 Q_s}{v_s}\right]^{0.5}$$

D (in) = (3.056 x 0.51 acfm / 68.88 ft/sec)$^{0.5}$ = 0.150 in

Represents ideal diameter, which we then compare to capabilities of all nozzles from multiple sets

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Velocity of Gas in Nozzle 4a (diam. = 0.157 in), (ft/sec) [RM201A, Eq. 15]

v_n (ft/sec) = $\frac{0.51 \text{ acfm}}{60 \text{ min / sec}} \div 1.34\text{E-}04 \text{ ft}^2$ = 62.85 $\frac{\text{ft}}{\text{sec}}$

Example set of calculations for nozzle used with run 1

$$v_n = \frac{\left(\frac{Q_s}{60\frac{\text{min}}{\text{sec}}}\right)}{A_n}$$

Minimum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 16]

Nozzle 4a (diam. = 0.157 in)

$$R_{min} = \left[0.2457 + \left(0.3072 - \frac{0.2603\,(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{min} =

$0.2457 + (0.3072 - \frac{0.2603 \times 207.77 \text{ µP} \times (0.51 \text{ acfm})^{0.5}}{62.85 \text{ in}^{1.5}})^{0.5}$ = 0.73

Maximum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 17]

Nozzle 4a (diam. = 0.157 in)

$$R_{max} = \left[0.4457 + \left(0.5690 + \frac{0.2603\,(\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{max} =

$0.4457 + (0.5690 + \frac{0.2603 \times 207.77 \text{ µP} \times (0.51 \text{ acfm})^{0.5}}{62.85 \text{ in}^{1.5}})^{0.5}$ = 1.25

Minimum Gas Velocity for R_{min} Less than 0.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$v_{min}\,(ft/sec) = v_n(0.5)$ v_{min} (ft/sec) = 0.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 18]**

Not Applicable

Minimum Gas Velocity for R_{min} Greater than or Equal to 0.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$v_{min}\,(ft/sec) = v_n R_{min}$ v_{min} (ft/sec) = 62.85 $\frac{\text{ft}}{\text{sec}}$ x 0.73 = 45.58 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 19]**

Maximum Gas Velocity for R_{max} Less than 1.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$v_{max}\,(ft/sec) = v_n R_{max}$ v_{max} (ft/sec) = 62.85 $\frac{\text{ft}}{\text{sec}}$ x 1.25 = 78.54 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 20]**

Maximum Gas Velocity for R_{max} Greater than or Equal to 1.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$v_{max}\,(ft/sec) = v_n(1.5)$ v_{max} (ft/sec) = 1.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 21]**

Not Applicable

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Minimum Velocity Pressure (in H_2O) [RM201A, Eq. 22] **Nozzle 4a (diam. = 0.157 in)**

Run 1 nozzle is able to achieve Δp_{min} below preliminary data minimum

$$\Delta p_{min}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{min}}{C_p}\right]^2$$

Δp_{min} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{29.87 \text{ in Hg} \times 28.40 \text{ lb / lb-mole}}{213 + 460\ ^{o}R}\right) \times \left(\frac{45.58 \text{ ft/sec}}{0.7720}\right)^2 =$ 0.60 in H_2O vs. 1.15

Maximum Velocity Pressure (in H_2O) [RM201A, Eq. 23] **Nozzle 4a (diam. = 0.157 in)**

Run 1 nozzle is able to achieve Δp_{max} above preliminary data maximum

$$\Delta p_{max}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{max}}{C_p}\right]^2$$

Δp_{max} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{29.87 \text{ in Hg} \times 28.40 \text{ lb / lb-mole}}{213 + 460\ ^{o}R}\right) \times \left(\frac{78.54 \text{ ft/sec}}{0.7720}\right)^2 =$ 1.79 in H_2O vs. 1.51

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sampling Dwell Time at Each Point (minutes) [point A-1] [RM201A, Eq. 24]

$$t_n(\text{min}) = \left[\frac{C_p\sqrt{\Delta p_n}}{C_p'\left(\sqrt{\Delta p_n}\right)_{avg}}\right]\left[\frac{t_r}{N_{tp}}\right]$$

t_n (min) = $\left(\frac{0.7720 \times (1.50)^{0.5}}{0.7720 \times 1.17}\right) \times \left(\frac{240.00 \text{ min}}{12.00}\right) =$ 20.91 minutes

Dry Gas Volume Sampled at Standard Conditions (dscf) [point A-1] [RM201A, Eq. 28]

v_{ms} (dscf) = $\left(\frac{528}{29.92}\right)\left(0.978 \times 8.24 \text{ dcf}\right) \times \left(\frac{29.94 \text{ in Hg} + 0.46 \text{ in } H_2O / 13.6}{68.00 + 460\ ^{o}R}\right) =$ 8.07 dscf

$$v_{ms}(dscf) = \left[\frac{528}{29.92}\right]\left[\gamma \cdot v_m\right]\left[\frac{\left(P_{bar} + \frac{\Delta H}{13.6}\right)}{T_m}\right]$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sample Flow Rate at Standard Conditions (dscfm) [RM201A, Eq. 29]

$$Q_{sST}\,(dscfm) = \frac{v_{ms}}{\Theta}$$

Q_{sST} (dscfm) = $\frac{92.76 \text{ dscf}}{245.25 \text{ min}}$ = $\frac{0.38 \text{ dscf}}{\text{min}}$

Sampling Rate (acfm) [e.g. cyclone flow rate] [RM201A, Eq. 32]

$$Q_s(acfm) = \frac{29.92}{528} Q_{sST} \left[\frac{1}{(1 - B_{ws})}\right]\left[\frac{T_s}{P_s}\right]$$

Q_s (acfm) = $\frac{29.92 \text{ in Hg}}{528\ ^{o}\text{R}}$ x $\frac{0.38 \text{ dscf}}{\text{min}}$ x $\frac{1}{(1- 8.85 /100)}$ x $\frac{209 + 460\ ^{o}\text{R}}{29.87 \text{ in Hg}}$ = 0.53 acfm

Actual Conditions Reynolds Number (dimensionless) [RM 201A, Eq. 10]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

N_{re} = 8.64 x 10^5 x $\frac{29.87 \text{ in Hg x } 28.29 \text{ lb / lb-mole}}{209 + 460\ ^{o}\text{R}}$ x $\frac{0.53 \text{ acfm}}{205.84 \text{ µP}}$ = 2792.37

Actual Conditions Particle Cut Diameter for Cyclone I (µm) [RM201A, Eq. 33]

$$D_{50}(\mu m) = 0.15625 \left[\frac{T_s}{M_w P_s}\right]^{0.2091}\left[\frac{\mu}{Q_s}\right]^{0.7091}$$

D_{50} (µm) = 0.15625 x ($\frac{209 + 460\ ^{o}\text{R}}{29.87 \text{ in Hg x } 28.29 \text{ lb / lb-mole}}$)$^{0.2091}$ x ($\frac{205.84 \text{ µP}}{0.53 \text{ acfm}}$)$^{0.7091}$ = 10.25 µm

Actual Particle Cut Diameter for Cyclone IV is determined by:

Actual Conditions Cunningham Correction Factor [RM 201A, Eq. 4]
[for a 2.5 micrometer diameter particle (estimated size)]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x ($\frac{205.84 \text{ µP}}{29.87 \text{ in Hg x } 2.5 \text{ µm}}$)($\frac{209 + 460\ ^{o}\text{R}}{28.29 \text{ lb / lb-mole}}$)$^{0.5}$ = 1.08

Actual Conditions Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]

$$D_{50}(\mu m) = 0.0024302\left[\frac{\mu}{Q_s}\right]^{1.1791}\left[\frac{1}{C}\right]^{0.5}\left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) =

0.0024302 x ($\frac{205.84 \text{ µP}}{0.53 \text{ acfm}}$)$^{1.1791}$ x ($\frac{1}{1.08}$)$^{0.5}$

x ($\frac{209 + 460\ ^{o}\text{R}}{29.87 \text{ in Hg x } 28.29 \text{ lb / lb-mole}}$)$^{0.6790}$ = 2.27 µm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Actual Conditions Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Re-calculated Cunningham Correction Factor (dimensionless) [RM 201A, Eq. 36]

$$C_r = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x (205.84 µP / 29.87 in Hg x 2.27 µm)(209 + 460 °R / 28.29 lb / lb-mole)$^{0.5}$ = 1.08

Re-calculated Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 37]

$$D_{50-1}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50-1} (µm) =

0.0024302 x (205.84 µP / 0.53 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (209 + 460 °R / 29.87 in Hg x 28.29 lb / lb-mole)$^{0.6790}$ = 2.27 µm

Re-Calculated Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 38]

$$D_{50-1}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50-1} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Ratio (Z) Between D_{50} and D_{50-1} Values (dimensionless) [RM 201A, Eq. 39]

$$Z = \frac{D_{50-1}}{D_{50}} \qquad 0.99 \le \left[Z = \left(\frac{D_{50}}{D_{50-1}}\right)\right] \le 1.01$$

Z = 2.27 µm / 2.27 µm = 1.00

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Historical Data	SAM U-00003 Base-1	SAM U-00003 Base-2	SAM U-00003 Base-3	**Average**	**Units**	**Limits**
Run Start Time	13:56	06:24	08:57		hh:mm	
Run Stop Time	15:56	08:24	10:57		hh:mm	
Test Date	04/15/20	04/16/20	04/16/20		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.974	0.974	0.974			
Stack Test Data	SAM U-00003 Base-1	SAM U-00003 Base-2	SAM U-00003 Base-3	**Average**	**Units**	**Limits**
Initial Meter Volume	829.310	871.950	914.590		ft^3	
Final Meter Volume	871.720	913.990	956.230		ft^3	
Total Meter Volume	42.410	42.040	41.640	42.030	ft^3	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	68.54	66.54	58.38	64.49	°F	
Barometric Pressure	29.91	30.04	30.06	30.00	in Hg	
Stack Static Pressure	-0.92	-0.92	-0.92	-0.92	in H_2O	
Absolute Stack Pressure	29.84	29.97	29.99	29.94	in Hg	
Average Orifice Pressure Drop	0.41	0.41	0.41	0.41	in H_2O	
Absolute Meter Pressure	30.05	30.18	30.20	30.14	in Hg	
Moisture Content Data	SAM U-00003 Base-1	SAM U-00003 Base-2	SAM U-00003 Base-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	64.60	71.70	67.20	67.83	g	
Silica Gel Weight Gain	13.40	8.90	11.10	11.13	g	
Total Water Volume Collected	78.14	80.75	78.44	79.11	ml	
Standard Water Vapor Volume	3.68	3.80	3.69	3.72	scf	
Standard Meter Volume	41.3	41.3	41.5	41.4	dscf	
Standard Metric Meter Volume	1.2	1.2	1.2	1.2	dscm	
Calculated Stack Moisture	8.18	8.43	8.16	8.26	%	
Gas Analysis Data	SAM U-00003 Base-1	SAM U-00003 Base-2	SAM U-00003 Base-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	4.5	4.5	4.5	4.5	%	
Oxygen Content	12.9	12.9	12.9	12.9	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.6	82.6	82.6	82.6	%	
Stack Dry Molecular Weight	29.24	29.24	29.24	29.24	lb/lb-mole	
Calculated Fuel Factor	1.778	1.778	1.778	1.778		
Fuel F-Factor	8638.02	8641.42	8641.42	8640.29	dscf/MMBtu	
Sulfuric Acid Mist IC Analysis	SAM U-00003 Base-1	SAM U-00003 Base-2	SAM U-00003 Base-3	**Average**	**Units**	**Limits**
H_2SO_4 (IC) Sample Volume - Front Half Rinse	125.0	132.0	183.0	146.67	ml	--
H_2SO_4 (IC) Sample - Mass Per Volume	0.4	0.7	0.1	0.40	mg/L	--
H_2SO_4 (IC) Mass	0.05	0.09	0.02	0.05	mg	--
H_2SO_4 (IC) Concentration	1.14E-06	2.28E-06	4.57E-07	1.29E-06	g/dscf	--
	1.76E-05	3.52E-05	7.06E-06	1.99E-05	gr/dscf	--
	4.02E-08	8.04E-08	1.62E-08	4.56E-08	g/L	--
	0.01	0.02	0.00	0.01	ppmvd	--
H_2SO_4 (IC) Emission Rate	0.00006	0.00011	0.00002	0.00006	lb/MMBtu	0.00065

Note: Run 3 reported at the RDL (0.019 mg)

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12 \text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 78.00 g x 0.04715 ft^3/g = 3.678 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{\frac{17.65\ ^\circ R}{in.\ Hg} \times 0.97 \times 42.41\ dcf \times \left(29.91\ in.\ Hg + \frac{0.41\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{68.54\ ^\circ F + 460\ ^\circ R} = 41.29\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{3.68\ dscf}{3.68\ dscf + 41.29\ dscf} = 8.18\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - H_2SO_4 (IC)]

Stack H_2SO_4 Mass (mg)

$$M_n(mg) = \frac{M_{n(lab)}}{V_{s(lab)}} \times V_{sample} \times \frac{L}{1000ml}$$

M_n (mg) = $\frac{\text{L}}{\text{1000 ml}}$ x 0.38 $\frac{\text{mg}}{\text{L}}$ x 125.00 ml = 0.05 mg

Stack H_2SO_4 Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

c_s (g/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.05 mg}}{\text{41.29 dscf}}$ = $\frac{\text{1.14E-06 g}}{\text{dscf}}$

Stack H_2SO_4 Concentration (gr/dscf)

$$c'_s(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

c'$_s$ (gr/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.05 mg}}{\text{41.29 dscf}}$ x $\frac{\text{7000 gr}}{\text{lb}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ = $\frac{\text{1.76E-05 gr}}{\text{dscf}}$

Stack H_2SO_4 Concentration (g/L)

$$c''_s(g/L) = c'_s \times \frac{dscf}{28.31685 dsL}$$

c'$_s$ (gr/dscf) = 1.14E-06 $\frac{\text{g}}{\text{dscf}}$ x $\frac{\text{dscf}}{\text{28.31685 dsL}}$ = $\frac{\text{4.00E-08 g}}{\text{L}}$

Stack H_2SO_4 Concentration (ppmvd)

$$c'''_s(ppmvd) = \frac{M_n}{V_{m(std)}} \times Ideal\ Gas\ Constant \times \frac{10^6 parts}{million\ parts} \times \frac{1}{Mol\ Wt}$$

c'''$_s$ (ppmvd) = 4.02E-08 $\frac{\text{g}}{\text{L}}$ x $\frac{\text{24.04 L gas}}{\text{lb-mol}}$ x $\frac{10^6 \text{ parts}}{\text{MM parts}}$ x $\frac{\text{lb-mol}}{\text{98.0790 lb}}$ = 0.010 ppmvd

H_2SO_4 Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

E''' (lb/MMBtu) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ x $\frac{\text{0.05 mg}}{\text{41.29 dscf}}$ x $\frac{\text{8,638.02 dscf}}{\text{MMBtu}}$ x ($\frac{\text{20.9}}{\text{20.9 - 12.9 \%}}$) = $\frac{\text{0.00006 lb}}{\text{MMBtu}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
NOx, CO, VOC, and NH_3

GENERAL ELECTRIC, 7F.05, UNIT #U-00003 BASE+DB LOAD DATA SUMMARY

Parameter	Base+DB Load, Run - 2-1	Base+DB Load, Run - 2-2	Base+DB Load, Run - 2-3	Average
Date (mm/dd/yy)	04/16/20	04/16/20	04/16/20	04/16/20
Start Time (hh:mm:ss)	14:04:12	15:23:12	17:41:12	14:04:12
End Time (hh:mm:ss)	15:03:42	16:22:42	18:40:42	18:40:42
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.99	30.04	30.10	30.04
Amb. Temp. (°F)	43	44	46	44
Rel. Humidity (%)	54	55	53	54
Spec. Humidity (lb water / lb air)	0.003133	0.003311	0.003436	0.003293
NH_3 Flow Rate (lb/hr)	163.9	159.1	163.9	162.3
Turbine Fuel Flow (lb/min)	1,681	1,678	1,681	1,680
Duct Burner Fuel Flow (lb/min)	174	175	175	175
Total Fuel Flow (SCFH)	2,578,392	2,573,884	2,579,455	2,577,244
Stack Flow (RM19) (SCFH)	52,449,328	52,688,699	52,766,594	52,634,874
Stack Moisture (% Method 4)	9.5	9.5	9.5	9.5
Heat Input (MMBtu/hr)	2,603.4	2,598.8	2,604.5	2,602.2
CT Power Output (megawatts)	240.3	239.6	240.5	240.1
NOx (ppmvd)	2.35	2.26	2.17	2.26
NOx (ppm@15%O_2)	1.54	1.50	1.44	1.49
CO (ppmvd)	0.13	0.03	0.00	0.06
CO (ppm@15%O_2)	0.08	0.02	0.00	0.04
VOC (as C1) (ppmvd)	0.00	0.00	0.00	0.00
VOC (as C1) (ppm@15%O_2)	0.00	0.00	0.00	0.00
Fuel Sulfur (grains / 100 scf)	0.11	0.11	0.11	0.11
CO_2 (%)	5.12	5.11	5.13	5.12
O_2 (%)	11.94	11.99	11.99	11.97

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Historical Data	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Run Start Time	12:23	04:15	09:35		hh:mm	
Run Stop Time	16:49	08:34	14:03		hh:mm	
Test Date	04/16/20	04/17/20	04/17/20		mm/dd/yy	
Load	Base+DB	Base+DB	Base+DB		% or w/DB	--
Meter Calibration Factor	0.978	0.978	0.978			
Pitot Tube Coefficient	0.7720	0.7720	0.7720			
Average Nozzle Diameter	0.157	0.157	0.157		in	
Stack Test Data	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Initial Meter Volume	558.350	657.110	756.100		ft^3	
Final Meter Volume	652.000	749.000	849.500		ft^3	
Total Meter Volume	93.650	91.890	93.400	92.980	ft^3	
Total Sampling Time	244.50	246.00	246.75	245.75	min	
Average Meter Temperature	80.33	69.75	74.50	74.86	°F	
Average Stack Temperature	182.33	177.17	177.75	179.08	°F	
Barometric Pressure	30.05	30.21	30.22	30.16	in Hg	
Stack Static Pressure	-0.96	-0.96	-0.96	-0.96	in H_2O	
Absolute Stack Pressure	29.98	30.14	30.15	30.09	in Hg	
Average Orifice Pressure Drop	0.45	0.45	0.45	0.45	in H_2O	
Absolute Meter Pressure	30.19	30.35	30.36	30.30	in Hg	
Avg Square Root Pitot Pressure	1.18	1.18	1.19	1.18	$\sqrt{(in\ H_2O)}$	
Moisture Content Data	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	171.60	186.00	189.00	182.20	g	
Silica Gel Weight Gain	28.60	24.60	25.90	26.37	g	
Total Water Volume Collected	200.56	210.98	215.29	208.94	ml	
Standard Water Vapor Volume	9.44	9.93	10.13	9.83	scf	
Standard Meter Volume	90.0	90.5	91.2	90.6	dscf	
Standard Metric Meter Volume	2.5	2.6	2.6	2.6	dscm	
Calculated Stack Moisture	9.49	9.88	10.00	9.79	%	
Saturated Stack Moisture	53.59	47.52	48.13	49.75	%	
Reported Stack Moisture Content	9.49	9.88	10.00	9.79	%	
Gas Analysis Data	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	5.1	5.1	5.1	5.1	%	
Oxygen Content	11.8	11.8	11.8	11.8	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	83.1	83.1	83.1	83.1	%	
Stack Dry Molecular Weight	29.29	29.29	29.29	29.29	lb/lb-mole	
Stack Wet Molecular Weight	28.22	28.18	28.16	28.19	lb/lb-mole	
Calculated Fuel Factor	1.772	1.768	1.773	1.771		
Fuel F-Factor	8641.42	8663.09	8663.09	8655.87	dscf/MMBtu	
Percent Excess Air	116.7	116.8	116.9	116.8	%	

METHOD 201A (FRONT) AND 202 (BACK) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Volumetric Flow Rate Data	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Average Stack Gas Velocity	67.61	67.61	67.85	67.69	ft/sec	
Stack Cross-Sectional Area	283.53	283.53	283.53	283.53	ft²	
Actual Stack Flow Rate	1,150,138	1,150,152	1,154,186	1,151,492	acfm	
Wet Standard Stack Flow Rate	56,838	57,605	57,773	57,405	wkscfh	
Dry Standard Stack Flow Rate	51,441,564	51,911,646	51,998,672	51,783,961	dscfh	
Percent of Isokinetic Rate	91.1	90.3	90.5	90.6	%	
Gravimetric Analysis	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	ml	
NH_4OH Correction	0.0000	0.0000	0.0000	0.0000	mg	
Emission Rate Data	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Total PM_{10} Mass	4.20	5.80	6.50	5.50	mg	--
Total PM_{10} Concentration	4.67E-05	6.41E-05	7.12E-05	6.07E-05	g/dscf	--
	7.20E-04	9.89E-04	1.10E-03	9.36E-04	gr/dscf	--
Total PM_{10} Emission Rate	2.40	3.33	3.70	3.14	kg/hr	--
	5.29	7.33	8.17	6.93	lb/hr	--
	23.18	32.11	35.77	30.36	tpy	--
	0.0020	0.0028	0.0031	0.0027	lb/MMBtu	0.006
Filterable PM_{10} Mass	3.10	3.00	5.00	3.70	mg	--
Filterable PM_{10} Concentration	3.44E-05	3.31E-05	5.48E-05	4.08E-05	g/dscf	--
	5.32E-04	5.11E-04	8.46E-04	6.30E-04	gr/dscf	--
Filterable PM_{10} Emission Rate	1.77	1.72	2.85	2.11	kg/hr	--
	3.91	3.79	6.28	4.66	lb/hr	--
	17.11	16.61	27.52	20.41	tpy	--
	0.0015	0.0015	0.0024	0.0018	lb/MMBtu	--
Condensable PM_{10} Mass	1.10	2.80	1.50	1.80	mg	--
Condensable PM_{10} Concentration	1.22E-05	3.09E-05	1.64E-05	1.99E-05	g/dscf	--
	1.89E-04	4.77E-04	2.54E-04	3.07E-04	gr/dscf	--
Condensable PM_{10} Emission Rate	0.63	1.61	0.85	1.03	kg/hr	--
	1.39	3.54	1.88	2.27	lb/hr	--
	6.07	15.50	8.25	9.94	tpy	--
	0.0005	0.0014	0.0007	0.0009	lb/MMBtu	--
RM 201A Quality Control	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Stack Viscosity	198.41	196.82	196.86	197.37	µP	
Cyclone Flow Rate	0.494	0.489	0.492	0.492	ft³/min	
Dry Gas Sampling Rate	0.368	0.368	0.370	0.369	dscfm	
Reynolds Number	2831.81	2862.75	2877.55	2,857.37		
Recalculated Cunninham	1.079	1.078	1.079	1.079		
Dia. of 50% Prob. (D50) CI	10.36	10.34	10.30	10.33		
Recalculated D50-1 for CIV	2.28	2.27	2.25	2.27		
Z	1.00	1.00	1.00	1.00		
No. Sampling Pts. Outside Δp	0	0	0	0	points	

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{mw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12\text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]

Carbon Monoxide Concentration (%)

$$\%CO = \frac{ppmCO}{10{,}000}$$

$$\%CO\ (\%) = \frac{0.00 \quad ppm}{10{,}000\ ppm/\%} = 0.0000\ \%$$

Nitrogen Concentration (%)

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$\%N_2$ (%) = 100 - 5.13 % - 11.81 % - 0.00 / 10,000 % = 83.06 %

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d\,(lb/lb-mol) = \sum\left(\frac{MW_{comp}}{100} \times \%component\right)$$

$$M_d\ (lb/lb\text{-}mol) = \left(\frac{44\ lb/lb\text{-}mol}{100} \times 5.13\ \%\right) +$$

$$\left(\frac{32\ lb/lb\text{-}mol}{100} \times 11.81\ \%\right) + \left(\frac{28\ lb/lb\text{-}mol}{100} \times \left[\frac{0.00}{10{,}000} + 83.06\ \right]\right) = \frac{29.29\ lb}{lb\text{-}mol}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_S\,(lb/lb-mol) = \left[M_d \times \left(1 - \frac{B_{WS}}{100}\right)\right] + \left[MW_{H_2O} \times \frac{B_{WS}}{100}\right]$$

$$M_S\ (lb/lb\text{-}mol) = \left\{\frac{29.29\ lb}{lb\text{-}mol} \times \left(1 - \frac{9.49\ \%}{100}\right)\right\} + \left\{\frac{18\ lb}{lb\text{-}mol} \times \frac{9.49\ \%}{100}\right\} = \frac{28.22\ lb}{lb\text{-}mol}$$

Average Calculated Fuel Factor (F_o)

$$F_{o(avg)} = \frac{\left[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(\%CO_2)_{avg} + (\%CO)_{avg}}$$

$$F_{o(avg)} = \frac{20.9\% - 11.81\ \% - (0.5 \times 0.000\ \%)}{5.13\ \% + 0.000\ \%} = 1.772$$

Average Excess Air (%)

$$\%EA_{avg}\,(\%) = \frac{100 \times \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}{(0.264 \times (N_2)_{avg}) - \left[(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})\right]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{\ 11.81\ \% - (0.5 \times 0.000\ \%)\}}{(0.264 \times 83.06\ \%) - \{\ 11.81\ \% - (0.5 \times 0.000\ \%)\}} = 116.72\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]

Absolute Stack Pressure (in. Hg)

$$P_S(in.Hg) = P_b + \frac{P_{static}}{13.6}$$

P_s (in. Hg) = 30.05 in. Hg + $\frac{\text{-0.96 in. } H_2O}{\text{13.6 in. } H_2O/\text{in. Hg}}$ = 29.98 in. Hg

Average Stack Gas Velocity (ft/sec)

$$v_s(ft/\sec) = K_p \times C_p \times \left(\sqrt{\Delta p}\right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

v_{sl} (ft/sec) =

$\left(\frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\text{sec } (^oR)(\text{in. } H_2O)}\right)^{1/2}$ x 0.77 x 1.18 in.$H_2O^{1/2}$ x $\sqrt{\frac{182.33 + 460\ ^oR}{29.98 \text{ in. Hg x } 28.22 \text{ lb/lb-mol}}}$ = $\frac{67.6 \text{ ft}}{\text{sec}}$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd}(dscfh) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sd} (dscf/hr) = $\frac{3600 \text{ sec}}{\text{hr}}$ x (1 - $\frac{9.49\ \%}{100}$) x $\frac{67.61 \text{ ft}}{\text{sec}}$ x 283.53 ft^2 x $\frac{68.00 + 460\ ^oR}{182.33 + 460\ ^oR}$ x $\frac{29.98 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{51{,}441{,}564.41 \text{ dscf}}{\text{hr}}$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw}(acfm) = 60 \times v_s \times A_s$$

Q_{aw} (acf/min) = $\frac{60 \text{ sec}}{\text{min}}$ x $\frac{67.61 \text{ ft}}{\text{sec}}$ x 283.53 ft^2 = $\frac{1{,}150{,}138.19 \text{ acf}}{\text{min}}$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw}(ascfh) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

Q_{sw} (ascf/hr) = $\frac{60 \text{ min}}{\text{hr}}$ x $\frac{1{,}150{,}138.19 \text{ acf}}{\text{min}}$ x $\frac{68.00 + 460\ ^oR}{182.33 + 460\ ^oR}$ x $\frac{29.98 \text{ in. Hg}}{29.92 \text{ in. Hg}}$ = $\frac{56{,}837{,}668.40 \text{ ascf}}{\text{hr}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 200.20 g x 0.04715 ft^3/g = 9.439 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65\ ^\circ R}{in.\ Hg} \times 0.98 \times 93.65\ dcf \times \frac{\left(30.05\ in.\ Hg + \frac{0.45\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{80.33\ ^\circ F + 460\ ^\circ R} = 89.99\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{9.44\ dscf}{9.44\ dscf + 89.99\ dscf} = 9.49\ \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)}(\%) = 100 \times \frac{10^{\left(6.691 - \frac{3144}{t_{s(avg)} + 390.86}\right)}}{P_b + \frac{P_{static}}{13.6}} \leq 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left(6.691 - \frac{3144}{182.33\ ^\circ F + 390.86}\right)}}{30.05\ in.\ Hg + \frac{-0.96\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}} \leq 100 = 53.59\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Desired Orifice (in. H_2O) (first point)

$$\Delta H_d\,(in.H_2O) = K \times \Delta p$$

ΔH_d (in. H_2O) = x

in. H_2O = in. H_2O

Absolute Meter Pressure (in. Hg)

$$P_m\,(in.Hg) = P_b + \frac{\Delta H\,@}{13.6}$$

P_m (in. Hg) = 30.05 in. Hg + $\frac{1.85 \text{ in. } H_2O}{13.6 \text{ in. } H_2O/\text{in. Hg}}$ = 30.19 in. Hg

Recommended Nozzle Diameter (in.)

$$D_{nt}\,(in.) = \sqrt{\frac{C_{ti} \times Q_{mi} \times P_{mi}}{(t_{mi} + T_{ti}) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}}\right)} \times \sqrt{(t_s + T_{ti}) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}{P_s \times \Delta p_{avg}}\right]}$$

D_{ni} (in.) = $\sqrt{\frac{0.03575 \text{ (lb-mole•°R•in. } H_2O)^{1/2}\text{•min•in.}^2}{\text{acf•in. Hg}^{3/4}\text{•lb}^{1/2}} \text{ x } 0.75 \text{ acf x } 30.19 \text{ in. Hg } \left(1 - \frac{0.00\ \%}{100}\right) \text{ x } \left(\frac{1 - \frac{0.00\ \%}{100}}{1 - \frac{9.49\ \%}{100}}\right) \text{ x } \sqrt{\left(80.33\ ^\circ\text{F} + 460^\circ\text{R}\right) \text{x } 0.77 \text{ x } \left(182.33\ ^\circ\text{F} + 460^\circ\text{R}\right) \text{ x } \frac{\frac{29.29 \text{ lb}}{\text{lb-mole}} \text{ x } \left(1 - \frac{9.49\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{9.49\ \%}{100}\right)}{29.98 \text{ in. Hg x } 1.18 \text{ in. } H_2O}}}$ = 0.210 in.

ΔP to ΔH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H\,@ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100}\right) + \left(18 \times \frac{B_{wm}}{100}\right)}{M_d \times \left(1 - \frac{B_{ws}}{100}\right) + \left(18 \times \frac{B_{ws}}{100}\right)}\right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}}\right)^2 \times \left(\frac{t_m + T_u}{ts + T_u}\right) \times \frac{P_s}{P_m}$$

K = $\frac{849.8}{\text{in. } H_2O\text{•in.}^4}$ x 0.77 ^{2} x 1.85 in. H_2O x 0.16 ^{4} x $\left(\frac{1 - \frac{9.49\ \%}{100}}{1 - \frac{0.00\ \%}{100}}\right)^2$ x $\frac{80.33\ ^\circ\text{F} + 460^\circ\text{R}}{182.33\ ^\circ\text{F} + 460^\circ\text{R}}$) x

$\left(\frac{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{0.00\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{0.00\ \%}{100}\right)}{\frac{29.29 \text{ lb}}{\text{lb/mole}} \text{ x } \left(1 - \frac{9.49\ \%}{100}\right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \text{ x } \frac{9.49\ \%}{100}\right)}\right)$ x $\frac{29.98 \text{ in. Hg}}{30.19 \text{ in. Hg}}$ = 0.40

Percent Isokinetic (%) (first point)

$$I\,(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

I (%) = $\frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^\circ\text{R}}$ x (181.00 °F + 460 °R) x 7.75 dscf

19.75 min x $\frac{65.50 \text{ ft}}{\text{sec}}$ x 29.98 in. Hg x 3.14 x $\left(\frac{0.16 \text{ in.}}{2} \text{ x } \frac{\text{ft.}}{12 \text{ in.}}\right)^2$ x $\left(1 - \frac{9.49\ \%}{100}\right)$ = 99.54 %

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]

Cumulative Percent Isokinetic (%) (weighted average of all points)

$$I(\%) = \sum_{1-n} \frac{\left[I(\%) \times V_{m(std)}\right]_{1-n}}{V_{m(std)_{1-n}}}$$

Using Method 5, Eq 5-8 to determine intermediate isokinetics at each point, weighted averaging of the cumulative isokinetics is necessary since all points are not equal, and determined by using the dry standard meter volume collected at each point to weight the cumulative average. Intermediate isokinetics and dry standard meter volumes are found at each point. At each point the cumulative sum is found of each value and the quotient of the two used to determine the cumulative isokinetics for each residual point (n).

Pt	In (%)	x	Vm(std)n	=	I (%)n	∑(I (%)n)	/	∑(Vm(std)n)	=	I (%)
A-1	99.54	x	7.754	=	771.81	771.81	/	7.75	=	99.5
A-2	93.16	x	7.817	=	728.20	1500.02	/	15.57	=	96.3
A-3	102.91	x	8.004	=	823.65	2323.67	/	23.57	=	98.6
B-1	91.04	x	8.190	=	745.65	3069.31	/	31.77	=	96.6
B-2	97.47	x	8.185	=	797.73	3867.04	/	39.95	=	96.8
B-3	96.37	x	7.507	=	723.41	4590.46	/	47.46	=	96.7
C-1	93.22	x	8.380	=	781.14	5371.60	/	55.84	=	96.2
C-2	82.91	x	6.951	=	576.34	5947.93	/	62.79	=	94.7
C-3	80.82	x	6.286	=	508.03	6455.97	/	69.07	=	93.5
D-1	84.78	x	7.610	=	645.19	7101.16	/	76.68	=	92.6
D-2	80.28	x	6.244	=	501.24	7602.40	/	82.93	=	91.7
D-3	84.15	x	7.045	=	592.85	8195.25	/	89.97	=>	91.1

Last Pt

Percent Isokinetic (%) (intermediate equation, all points)
[equivalent to taking an average of point-by-point isokinetics without weighting the average (e.g. all points equal)]

$$I(\%) = \frac{K_4 \times \left((t_s)_{avg} + T_u\right) \times V_{m(std)}}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right) \times \left(1 - \frac{B_{ws}}{100}\right)}$$

$$I(\%) = \frac{0.0945 \text{ min•in. Hg}}{\text{sec•}^{\circ}\text{R}} \times (182.33\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times 89.99 \text{ dscf}$$

$$\frac{}{244.50 \text{ min} \times \frac{67.61 \text{ ft}}{\text{sec}} \times 29.98 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2 \times \left(1 - \frac{9.49\ \%}{100}\right)} = 90.59\ \%$$

Raw Data Percent Isokinetic (%)
[utilizes the raw data equation for isokinetics from Method 5]

$$I(\%) = \frac{100\left((t_s)_{avg} + T_u\right)\left[K_4 V_{1c} + \frac{V_m Y}{(t_m)_{avg} + T_u}\left(P_{bar} + \frac{\Delta H}{13.6}\right)\right]}{60\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12}\right)^2\right)}$$

$$I(\%) = \frac{100 \times (182.33\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}) \times \left[\frac{0.002669 \text{ ft}^3\text{•in. Hg}}{\text{ml•}^{\circ}\text{R}} \times 200.6 \text{ ml} + \frac{93.65 \text{ dcf} \times 0.978}{80.33\ ^{\circ}\text{F} + 460\ ^{\circ}\text{R}} \times \left(30.05 \text{ in Hg} + \frac{1.176}{13.6}\right)\right]}{}$$

$$\frac{}{60 \times 244.50 \text{ min} \times \frac{67.61 \text{ ft}}{\text{sec}} \times 29.98 \text{ in. Hg} \times 3.14 \times \left(\frac{0.16 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}}\right)^2} = 90.68\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Gravimetric Analysis) [Values from Run 1 test]

Blank Concentration [Acetone Blank Weight of Solids] (mg/ml)

$$C_x\,(mg/ml) = \frac{1000 \times w_x}{v_x}$$

C_x (mg/ml) = $\frac{1000\ mg}{g}$ x $\frac{0.0000\ g}{200.60\ ml}$ = $\frac{0.0000\ mg}{ml}$ = $\frac{\quad mg}{ml}$

Blank Adjustment [Acetone Blank Weight of Solids and Nozzle Wash PM>10] (mg)

$$W_x\,(mg) = v_x \times C_x$$

W_x (mg) = 70.00 ml x 0.0000 mg/ml = 0.00 mg < Sample Gain

Sample Gain [Nozzle Wash PM>10] (mg)

$$m_x\,(mg) = \left(m_{fx} - m_{tx}\right) \times 1000$$

m_x (mg) = $\frac{1000\ mg}{g}$ x (0.0083 g - 0.00 g) = 8.30 mg

Adjusted Sample Gain [Nozzle Wash PM>10] (mg)

$$m_{xadj}\,(mg) = m_x - W_x$$

m_{xadj} (mg) = 8.30 mg - 0.00 mg = 8.30 mg

0.1N NH_4OH Correction (mg)

$$m_c\,(mg) = 17.03 \times V_t \times N$$

m_c (mg) = 17.03 x 0.00 ml x 0.1 N = 0.00 mg

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - Total PM_{10} Mass]

Stack Total Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s \text{ (g/dscf)} = \frac{\text{g}}{\text{1000 mg}} \text{ x } \frac{\text{4.20 mg}}{\text{89.99 dscf}} = \frac{\text{4.67E-05 g}}{\text{dscf}}$$

Stack Total Concentration (gr/dscf)

$$c_s'(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s \text{ (gr/dscf)} = \frac{\text{g}}{\text{1000 mg}} \text{ x } \frac{\text{4.20 mg}}{\text{89.99 dscf}} \text{ x } \frac{\text{7000 gr}}{\text{lb}} \text{ x } \frac{\text{lb}}{\text{453.592 g}} = \frac{\text{7.20E-04 gr}}{\text{dscf}}$$

Total Emissions Rate (kg/hr)

$$E(kg/hr) = c_s \times Q_{sd} \times \frac{kg}{1000\ g}$$

$$E \text{ (kg/hr)} = \frac{\text{kg}}{\text{1000 g}} \text{ x } \frac{\text{4.67E-05 g}}{\text{dscf}} \text{ x } \frac{\text{51,441,564 dscf}}{\text{hr}} = \frac{\text{2.40 kg}}{\text{hr}}$$

Total Emissions Rate (lb/hr)

$$E'(lb/hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{lb \times g}{453.592 g \times 1000 mg}$$

$$E' \text{ (lb/hr)} = \frac{\text{g}}{\text{1000 mg}} \text{ x } \frac{\text{lb}}{\text{453.592 g}} \text{ x } \frac{\text{4.20 mg}}{\text{89.99 dscf}} \text{ x } \frac{\text{51,441,564 dscf}}{\text{hr}} = \frac{\text{5.29 lb}}{\text{hr}}$$

Total Emissions Rate (tpy)

$$E''(ton/yr) = E' \times \frac{8760}{2000}$$

$$E'' \text{ (tpy)} = \frac{\text{ton}}{\text{2000 lb}} \text{ x } \frac{\text{8,760 hr}}{\text{yr}} \text{ x } \frac{\text{5.29 lb}}{\text{hr}} = \frac{\text{23.18 ton}}{\text{yr}}$$

Total Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

$$E''' \text{ (lb/MMBtu)} = \frac{\text{g}}{\text{1000 mg}} \text{ x } \frac{\text{lb}}{\text{453.592 g}} \text{ x } \frac{\text{4.20 mg}}{\text{89.99 dscf}} \text{ x } \frac{\text{8,641.42 dscf}}{\text{MMBtu}} \text{ x } \left(\frac{\text{20.9}}{\text{20.9 - 11.8 \%}}\right) = \frac{\text{0.0020 lb}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Stack Gas Viscosity (μP) [based on preliminary data] [RM 201A, Eq. 3]

$$\mu(\mu P) = C_1 + C_2\sqrt{T_s} + C_3 T_s^{-2} + C4(\%O_{2,wet}) - C_5 B_{ws} + C_6 B_{ws} T_s^2$$

μ (μP) = -150.3162 μP + 13.4622 $\sqrt{\quad 180 \quad + 460}$ + 3.86153x10^{6} (180 + 460)$^{-2}$ + 0.591123 (12.8 x (1 - 8.00 /100)
- 91.9723 (8.00 /100) + 1.51761x10^{-5} (8.00 /100)(180 + 460)^2 = 199.79 μP

Cunningham Correction Factor [RM 201A, Eq. 4]
[based on preliminary data for a 2.25 micrometer diameter particle]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

$$C = 1 + 0.0057193 \times \left(\frac{199.79\ \mu P}{29.92\ \text{in Hg} \times 2.25\ \mu m}\right)\left(\frac{180 + 460\ ^{o}R}{28.52\ \text{lb / lb-mole}}\right)^{0.5} = 1.08$$

First calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}<3,162

Lower Limit Cut Diameter for Cyclone I (μm) [RM 201A, Eq. 5]
[assumes N_{re}<3,162]

$$D_{50LL}(\mu m) = 9.507 C^{0.3007}\left[\frac{M_w P_s}{T_s}\right]^{0.1993}$$

$$D_{50LL}\ (\mu m) = 9.507 \times 1.08^{\,0.3007} \times \left(\frac{29.92\ \text{in Hg} \times 28.52\ \text{lb / lb-mole}}{180 + 460\ ^{o}R}\right)^{0.1993} = 10.30\ \mu m$$

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (μm) [RM 201A, Eq. 6]
[assumes N_{re}<3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

$$D_{50T}\ (\mu m) = \frac{11 + 10.30\ \mu m}{2} = 10.65\ \mu m$$

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}<3,162]

Qs (acfm) =

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu)\left[\frac{T_s}{M_w P_s}\right]^{0.2949}\left[\frac{1}{D_{50T}}\right]^{1.4102}$$

$$0.07296 \times 199.79\ \mu P \times \left(\frac{180 + 460\ ^{o}R}{29.92\ \text{in Hg} \times 28.52\ \text{lb / lb-mole}}\right)^{0.2949} \times \left(\frac{1}{10.65\ \mu m}\right)^{1.4102} = 0.48\ \text{acfm}$$

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5\left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

$$N_{re} = 8.64 \times 10^5 \times \frac{29.92\ \text{in Hg} \times 28.52\ \text{lb / lb-mole}}{180 + 460\ ^{o}R} \times \frac{0.48\ \text{acfm}}{199.79\ \mu P} = 2746.16 < 3{,}162$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Second calculation set using Cyclone IV, assuming N_{re}<3,162

Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]
[assumes N_{re}<3,162]

$$D_{50}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) =

0.0024302 x (199.79 µP / 0.48 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (180 + 460 °R / 29.92 in Hg x 28.52 lb / lb-mole)$^{0.6790}$ = 2.38 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Less than 3,162 (acfm) [RM 201A, Eq. 8]

$$Q_{IV}(acfm) = 0.0060639 \left(\frac{\mu}{C^{0.4242}}\right) \left[\frac{P_s M_w}{T_s}\right]^{-.05759} \left[\frac{1}{D_{50}}\right]^{0.8481}$$

Q_{IV} (acfm) =

0.0060639 x (199.79 µP / 1.08 $^{0.4242}$) x (29.92 in Hg x 28.52 lb / lb-mole / 180 + 460 °R)$^{-0.5759}$ x (1 / 2.38 µm)$^{0.8481}$ = 0.48 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}<3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Correct

N_{re} = 8.64 x 10^5 x 29.92 in Hg x 28.52 lb / lb-mole / 180 + 460 °R x 0.48 acfm / 199.79 µP = 2746.12 < 3,162

Third calculation set using Cyclone I or Cyclone I and IV, assuming N_{re}≥3,162

Lower Limit Cut Diameter for Cyclone I (µm) [RM 201A, Eq. 12]
[assumes N_{re}≥3,162]

$$D_{50LL}(\mu m) = 10.0959 C^{0.4400} \left[\frac{M_w P_s}{T_s}\right]^{0.0600}$$

D_{50LL} (µm) = 10.0959 x 1.08 $^{0.4400}$ x (29.92 in Hg x 28.52 lb / lb-mole / 180 + 460 °R)$^{0.0600}$ = 10.63 µm

Cut Diameter for Cyclone I for the Middle of the Overlap Zone (µm) [RM 201A, Eq. 6]
[assumes N_{re}≥3,162]

$$D_{50T}(\mu m) = \left(\frac{11 + D_{50LL}}{2}\right)$$

D_{50T} (µm) = (11 + 10.63 µm) / 2 = 10.81 µm

Sampling Rate Using Both PM_{10} and $PM_{2.5}$ Cyclones (acfm) [RM 201A, Eq. 7]
[assumes N_{re}≥3,162]

$$Q_s(acfm) = Q_I(acfm) = 0.07296(\mu) \left[\frac{T_s}{M_w P_s}\right]^{0.2949} \left[\frac{1}{D_{50T}}\right]^{1.4102}$$

Qs (acfm) =

0.07296 x 199.79 µP x (180 + 460 °R / 29.92 in Hg x 28.52 lb / lb-mole)$^{0.2949}$ x (1 / 10.81 µm)$^{1.4102}$ = 0.47 acfm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone I and IV]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (29.92 in Hg x 28.52 lb / lb-mole) / (180 + 460 °R) x (0.47 acfm) / (199.79 µP) = 2688.56 < 3,162

Fourth calculation set using Cyclone IV, assuming N_{re}≥3,162

Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]
[assumes N_{re}≥3,162]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058}\left[\frac{1}{C}\right]^{0.5}\left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x ((199.79 µP) / (0.47 acfm))$^{0.8058}$ x ((1) / (1.08))$^{0.5}$
x ((180 + 460 °R) / (29.92 in Hg x 28.52 lb / lb-mole))$^{0.3058}$ = 2.29 µm

Sampling Rate Using Only $PM_{2.5}$ Cyclone for N_{re} Greater than or Equal to 3,162 (acfm) [RM 201A, Eq. 9]

$$Q_{IV}(acfm) = 0.007657\left(\frac{\mu}{C^{0.6205}}\right)\left[\frac{P_s M_w}{T_s}\right]^{-0.3795}\left[\frac{1}{D_{50}}\right]^{1.241}$$

Q_{IV} (acfm) =

0.007657 x ((199.79 µP) / (1.08 $^{0.6205}$)) x ((29.92 in Hg x 28.52 lb / lb-mole) / (180 + 460 °R))$^{-0.3795}$
x ((1) / (2.29 µm))$^{1.241}$ = 0.47 acfm

Reynolds Number (dimensionless) [RM 201A, Eq. 10]
[verification of N_{re}≥3,162, using Cyclone IV only]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

Wrong Assumption

N_{re} = 8.64 x 10^5 x (29.92 in Hg x 28.52 lb / lb-mole) / (180 + 460 °R) x (0.48 acfm) / (199.79 µP) = 2746.16 < 3,162

Meter Box Orifice Pressure Drop (in H_2O) [RM 201A, Eq. 11]
As calculated using applicable calculation set 1, 2, 3, or 4

$$\Delta H(inH_2O) = \left[\frac{Q_s(1-B_{ws})P_s}{T_s}\right]^2\left[\frac{1.083 T_m M_d \Delta H_@}{P_{bar}}\right]$$

ΔH (in H_2O) = (0.48 acfm x (1 - 8.00 /100) x 29.92 in Hg) / (180 + 460 °R))^2
x (1.083 x (85.00 + 460 °R) x 29.43 lb / lb-mole x 1.846 in H_2O) / (29.99 in Hg)) = 0.449 in H_2O

50 °F above stack temperature	T_{s+50} =	230	ΔH_{+50} =	0.386 in H_2O
50 °F below stack temperature	T_{s+50} =	130	ΔH_{+50} =	0.528 in H_2O

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Adjusted Velocity Pressure (in H_2O) [point A-1] [RM201A, Eq. 25]

$$\Delta p_s\,(inH_2O) = \Delta p_m \left[\frac{C_p}{C'_p}\right]^2$$

Δp_s (in H_2O) = 1.70 in H_2O x (0.7720 / 0.8198)^2 = 1.51 in H_2O

Average Probe Blockage Factor [RM201A, Eq. 26]

$$b_f = \frac{22.0}{A}$$

b_f = 22.0 / 40828.14 in^2 = 5.39E-04

Velocity Pressure Adjusted for Blockage Factor (in H_2O) [point A-1] [RM201A, Eq. 27]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$\Delta p_{s2}\,(inH_2O) = \Delta p_{s1}\left[\frac{1}{(1-b_f)}\right]^2$$

Δp_s (in H_2O) = 1.51 in H_2O x (1 / (1 - 0.00E+00))^2 = 1.51 in H_2O

Velocity of Stack Gas Adjusted for Blockage Factor and/or C_p / C'_p (ft/sec) [RM201A, Eq. 13]

Target PM and/or Stack Size Not Applicable to Blockage Factor Calculation

$$v_s = K_p C_p \left(\sqrt{(\Delta p)}\right)_{avg}\left[\sqrt{\frac{T_s}{P_s M_w}}\right]$$

v_s (ft/sec) =

85.49 ft/sec / lb/mole - °R x 0.7720 x 1.16 x (180 + 460 °R / 29.92 in Hg x 28.52 lb / lb-mole)$^{0.5}$ = 66.24 ft/sec

Calculated Nozzle Diameter for Acceptable Sampling Rate (in) [RM201A, Eq. 14]

$$D(in) = \left[\frac{3.056 Q_s}{v_s}\right]^{0.5}$$

D (in) = (3.056 x 0.48 acfm / 66.24 ft/sec)$^{0.5}$ = 0.148 in

Represents ideal diameter, which we then compare to capabilities of all nozzles from multiple sets

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Velocity of Gas in Nozzle 4a (diam. = 0.157 in), (ft/sec) [RM201A, Eq. 15]

$$v_n = \frac{\left(\frac{Q_s}{60\ \frac{\text{min}}{\text{sec}}}\right)}{A_n}$$

v_n (ft/sec) = $\frac{0.48 \quad \text{acfm}}{60 \text{ min / sec}}$ / 1.34E-04 ft^2 = 59.06 $\frac{\text{ft}}{\text{sec}}$

Example set of calculations for nozzle used with run 1

Minimum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 16]

Nozzle 4a (diam. = 0.157 in)

$$R_{\text{min}} = \left[0.2457 + \left(0.3072 - \frac{0.2603\ (\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{min} =

$0.2457 + (0.3072 - \frac{0.2603 \text{ x } 199.79 \text{ µP x } (0.48 \text{ acfm})^{0.5}}{59.06 \text{ in}^{1.5}})^{0.5}$ = 0.72

Maximum Nozzle Velocity to Stack Velocity Ratio Parameter (dimensionless) [RM201A, Eq. 17]

Nozzle 4a (diam. = 0.157 in)

$$R_{\text{max}} = \left[0.4457 + \left(0.5690 + \frac{0.2603\ (\mu)(Q_s)^{0.5}}{v_n^{1.5}}\right)^{0.5}\right]$$

R_{max} =

$0.4457 + (0.5690 + \frac{0.2603 \text{ x } 199.79 \text{ µP x } (0.48 \text{ acfm})^{0.5}}{59.06 \text{ in}^{1.5}})^{0.5}$ = 1.25

Minimum Gas Velocity for R_{min} Less than 0.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$$v_{\text{min}}\ (ft / \text{sec}) = v_n (0.5)$$

v_{min} (ft/sec) = 0.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 18]**

Not Applicable

Minimum Gas Velocity for R_{min} Greater than or Equal to 0.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$$v_{\text{min}}\ (ft / \text{sec}) = v_n R_{\text{min}}$$

v_{min} (ft/sec) = 59.06 $\frac{\text{ft}}{\text{sec}}$ x 0.72 = 42.72 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 19]**

Maximum Gas Velocity for R_{max} Less than 1.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$$v_{\text{max}}\ (ft / \text{sec}) = v_n R_{\text{max}}$$

v_{max} (ft/sec) = 59.06 $\frac{\text{ft}}{\text{sec}}$ x 1.25 = 73.86 $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 20]**

Maximum Gas Velocity for R_{max} Greater than or Equal to 1.5 (ft/sec) **Nozzle 4a (diam. = 0.157 in)**

$$v_{\text{max}}\ (ft / \text{sec}) = v_n (1.5)$$

v_{max} (ft/sec) = 1.5 x $\frac{\text{ft}}{\text{sec}}$ = $\frac{\text{ft}}{\text{sec}}$ **[RM201A, Eq. 21]**

Not Applicable

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Preliminary test]

Minimum Velocity Pressure (in H_2O) [RM201A, Eq. 22] **Nozzle 4a (diam. = 0.157 in)**

Run 1 nozzle is able to achieve Δp_{min} below preliminary data minimum

$$\Delta p_{min}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{min}}{C_p}\right]^2$$

Δp_{min} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{29.92 \text{ in Hg} \times 28.52 \text{ lb / lb-mole}}{180 + 460\ ^{o}R}\right) \times \left(\frac{42.72 \text{ ft/sec}}{0.7720}\right)^2 =$ 0.56 in H_2O vs. 1.15

Maximum Velocity Pressure (in H_2O) [RM201A, Eq. 23] **Nozzle 4a (diam. = 0.157 in)**

Run 1 nozzle is able to achieve Δp_{max} above preliminary data maximum

$$\Delta p_{max}\ (inH_2O) = 1.3686 \times 10^{-4}\left[\frac{P_s M_w}{T_s}\right]\left[\frac{v_{max}}{C_p}\right]^2$$

Δp_{max} (in H_2O) =

$1.3686 \times 10^{-4} \times \left(\frac{29.92 \text{ in Hg} \times 28.52 \text{ lb / lb-mole}}{180 + 460\ ^{o}R}\right) \times \left(\frac{73.86 \text{ ft/sec}}{0.7720}\right)^2 =$ 1.67 in H_2O vs. 1.51

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sampling Dwell Time at Each Point (minutes) [point A-1] [RM201A, Eq. 24]

$$t_n(\text{min}) = \left[\frac{C_p\sqrt{\Delta p_n}}{C_p'\left(\sqrt{\Delta p_n}\right)_{avg}}\right]\left[\frac{t_r}{N_{tp}}\right]$$

t_n (min) = $\left(\frac{0.7720 \times \left(\frac{1.30}{1.16}\right)^{0.5}}{0.7720}\right) \times \left(\frac{240.00 \text{ min}}{12.00}\right) =$ 19.68 minutes

Dry Gas Volume Sampled at Standard Conditions (dscf) [point A-1] [RM201A, Eq. 28]

$$v_{ms}(dscf) = \left[\frac{528}{29.92}\right][\gamma \cdot v_m]\left[\frac{\left(P_{bar} + \frac{\Delta H}{13.6}\right)}{T_m}\right]$$

v_{ms} (dscf) = $\left(\frac{528}{29.92}\right)$ (0.978 x 7.99 dcf) x

$\left(\frac{30.05 \text{ in Hg} + 0.45 \text{ in } H_2O / 13.6}{75.00 + 460\ ^{o}R}\right) =$ 7.75 dscf

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Sample Flow Rate at Standard Conditions (dscfm) [RM201A, Eq. 29]

$$Q_{sST}\,(dscfm) = \frac{v_{ms}}{\Theta}$$

Q_{sST} (dscfm) = $\frac{89.99 \text{ dscf}}{244.50 \text{ min}}$ = $\frac{0.37 \text{ dscf}}{\text{min}}$

Sampling Rate (acfm) [e.g. cyclone flow rate] [RM201A, Eq. 32]

$$Q_s(acfm) = \frac{29.92}{528} Q_{sST} \left[\frac{1}{(1 - B_{ws})}\right]\left[\frac{T_s}{P_s}\right]$$

Q_s (acfm) = $\frac{29.92 \text{ in Hg}}{528\ ^{o}\text{R}}$ x $\frac{0.37 \text{ dscf}}{\text{min}}$ x $\frac{1}{(1- 9.49 /100)}$ x $\frac{182 + 460\ ^{o}\text{R}}{29.98 \text{ in Hg}}$ = 0.49 acfm

Actual Conditions Reynolds Number (dimensionless) [RM 201A, Eq. 10]

$$N_{re} = 8.64 \times 10^5 \left[\frac{P_s M_w}{T_s}\right]\left[\frac{Q_s}{\mu}\right]$$

N_{re} = 8.64 x 10^5 x $\frac{29.98 \text{ in Hg x } 28.22 \text{ lb / lb-mole}}{182 + 460\ ^{o}\text{R}}$ x $\frac{0.49 \text{ acfm}}{198.41 \text{ µP}}$ = 2831.81

Actual Conditions Particle Cut Diameter for Cyclone I (µm) [RM201A, Eq. 33]

$$D_{50}(\mu m) = 0.15625 \left[\frac{T_s}{M_w P_s}\right]^{0.2091}\left[\frac{\mu}{Q_s}\right]^{0.7091}$$

D_{50} (µm) = 0.15625 x ($\frac{182 + 460\ ^{o}\text{R}}{29.98 \text{ in Hg x } 28.22 \text{ lb / lb-mole}}$)$^{0.2091}$ x ($\frac{198.41 \text{ µP}}{0.49 \text{ acfm}}$)$^{0.7091}$ = 10.36 µm

Actual Particle Cut Diameter for Cyclone IV is determined by:

Actual Conditions Cunningham Correction Factor [RM 201A, Eq. 4]
[for a 2.5 micrometer diameter particle (estimated size)]

$$C = 1 + 0.0057193\left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x ($\frac{198.41 \text{ µP}}{29.98 \text{ in Hg x } 2.5 \text{ µm}}$)($\frac{182 + 460\ ^{o}\text{R}}{28.22 \text{ lb / lb-mole}}$)$^{0.5}$ = 1.07

Actual Conditions Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 34]

$$D_{50}(\mu m) = 0.0024302\left[\frac{\mu}{Q_s}\right]^{1.1791}\left[\frac{1}{C}\right]^{0.5}\left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50} (µm) =

0.0024302 x ($\frac{198.41 \text{ µP}}{0.49 \text{ acfm}}$)$^{1.1791}$ x ($\frac{1}{1.07}$)$^{0.5}$

x ($\frac{182 + 460\ ^{o}\text{R}}{29.98 \text{ in Hg x } 28.22 \text{ lb / lb-mole}}$)$^{0.6790}$ = 2.29 µm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Constant Flow, Variable Time Isokinetic QA/QC) [Values from Run 1 test]

Actual Conditions Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 35]

$$D_{50}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Re-calculated Cunningham Correction Factor (dimensionless) [RM 201A, Eq. 36]

$$C_r = 1 + 0.0057193 \left[\frac{\mu}{P_s D_{50}}\right]\left[\frac{T_s}{M_w}\right]^{0.5}$$

C = 1 + 0.0057193 x (198.41 µP / 29.98 in Hg x 2.29 µm)(182 + 460 °R / 28.22 lb / lb-mole)$^{0.5}$ = 1.08

Re-calculated Particle Cut Diameter for N_{re} Less than 3,162 for Cyclone IV (µm) [RM 201A, Eq. 37]

$$D_{50-1}(\mu m) = 0.0024302 \left[\frac{\mu}{Q_s}\right]^{1.1791} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.6790}$$

D_{50-1} (µm) =

0.0024302 x (198.41 µP / 0.49 acfm)$^{1.1791}$ x (1 / 1.08)$^{0.5}$ x (182 + 460 °R / 29.98 in Hg x 28.22 lb / lb-mole)$^{0.6790}$ = 2.28 µm

Re-Calculated Particle Cut Diameter for N_{re} Greater than or Equal to 3,162 for Cyclone IV (µm) [RM 201A, Eq. 38]

$$D_{50-1}(\mu m) = 0.019723 \left[\frac{\mu}{Q_s}\right]^{0.8058} \left[\frac{1}{C}\right]^{0.5} \left[\frac{T_s}{P_s M_w}\right]^{0.3058}$$

D_{50-1} (µm) =

0.019723 x (µP / acfm)$^{0.8058}$ x (1)$^{0.5}$ x (+ 460 °R / in Hg x lb / lb-mole)$^{0.3058}$ = µm

Ratio (Z) Between D_{50} and D_{50-1} Values (dimensionless) [RM 201A, Eq. 39]

$$Z = \frac{D_{50-1}}{D_{50}} \qquad 0.99 \le \left[Z = \left(\frac{D_{50}}{D_{50-1}}\right)\right] \le 1.01$$

Z = 2.28 µm / 2.28 µm = 1.00

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Emissions Results
Base+DB Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) - RESULTS

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Historical Data	SAM U-00003 Base+DB-1	SAM U-00003 Base+DB-2	SAM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Run Start Time	13:10	03:58	07:00		hh:mm	
Run Stop Time	15:10	05:58	09:00		hh:mm	
Test Date	04/16/20	04/17/20	04/17/20		mm/dd/yy	
Load	Base	Base	Base		% or w/DB	--
Meter Calibration Factor	0.974	0.974	0.974			
Stack Test Data	SAM U-00003 Base+DB-1	SAM U-00003 Base+DB-2	SAM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Initial Meter Volume	961.540	11.320	61.770		ft^3	
Final Meter Volume	1003.270	53.100	103.560		ft^3	
Total Meter Volume	41.730	41.780	41.790	41.767	ft^3	
Total Sampling Time	120.00	120.00	120.00	120.00	min	
Average Meter Temperature	62.79	82.54	82.17	75.83	°F	
Barometric Pressure	30.07	30.22	30.27	30.19	in Hg	
Stack Static Pressure	-0.92	-0.92	-0.92	-0.92	in H_2O	
Absolute Stack Pressure	30.00	30.15	30.20	30.12	in Hg	
Average Orifice Pressure Drop	0.41	0.41	0.41	0.41	in H_2O	
Absolute Meter Pressure	30.21	30.36	30.41	30.32	in Hg	
Moisture Content Data	SAM U-00003 Base+DB-1	SAM U-00003 Base+DB-2	SAM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Impinger Water Weight Gain	76.50	80.20	79.80	78.83	g	
Silica Gel Weight Gain	14.60	10.10	7.80	10.83	g	
Total Water Volume Collected	91.26	90.46	87.76	89.83	ml	
Standard Water Vapor Volume	4.30	4.26	4.13	4.23	scf	
Standard Meter Volume	41.3	40.0	40.1	40.5	dscf	
Standard Metric Meter Volume	1.2	1.1	1.1	1.1	dscm	
Calculated Stack Moisture	9.42	9.61	9.33	9.45	%	
Gas Analysis Data	SAM U-00003 Base+DB-1	SAM U-00003 Base+DB-2	SAM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
Carbon Dioxide Content	4.5	4.5	4.5	4.5	%	
Oxygen Content	12.9	12.9	12.9	12.9	%	
Carbon Monoxide Content	0.0	0.0	0.0	0.0	ppm	
Nitrogen Content	82.6	82.6	82.6	82.6	%	
Stack Dry Molecular Weight	29.24	29.24	29.24	29.24	lb/lb-mole	
Calculated Fuel Factor	1.778	1.778	1.778	1.778		
Fuel F-Factor	8641.42	8663.09	8663.09	8655.87	dscf/MMBtu	
Sulfuric Acid Mist IC Analysis	SAM U-00003 Base+DB-1	SAM U-00003 Base+DB-2	SAM U-00003 Base+DB-3	**Average**	**Units**	**Limits**
H_2SO_4 (IC) Sample Volume - Front Half Rinse	166.0	103.0	108.0	125.67	ml	--
H_2SO_4 (IC) Sample - Mass Per Volume	0.1	0.6	0.2	0.28	mg/L	--
H_2SO_4 (IC) Mass	0.02	0.06	0.02	0.03	mg	--
H_2SO_4 (IC) Concentration	4.12E-07	1.50E-06	4.23E-07	7.78E-07	g/dscf	--
	6.35E-06	2.31E-05	6.54E-06	1.20E-05	gr/dscf	--
	1.45E-08	5.29E-08	1.50E-08	2.75E-08	g/L	--
	0.00	0.01	0.00	0.01	ppmvd	--
H_2SO_4 (IC) Emission Rate	0.00002	0.00007	0.00002	0.00004	lb/MMBtu	0.00065

Note: Run 1 reported at the RDL (0.017 mg)

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 236.00 in. - 8.00 in. = 228.00 in.

Stack Diameters Downstream

$$B_D\,(dia.) = \frac{B}{D}$$

B_D (dia.) = $\frac{850.00 \text{ in.}}{228.00 \text{ in.}}$ = 3.73 diameters

Area of Stack (ft^2)

$$A_s\,(ft^2) = \pi \times \left(\frac{D}{2 \times 12}\right)^2$$

A_s (ft^2) = 3.14 x ($\frac{228.00 \text{ in.}}{2 \text{ x } 12 \text{in./ft}}$)^2 = 283.53 ft^2

Stack Diameters Upstream

$$A_D\,(dia.) = \frac{A}{D}$$

A_D (dia.) = $\frac{200.40 \text{ in.}}{228.00 \text{ in.}}$ = 0.88 diameters

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]

Water Volume Weighed (scf)

$$V_{wsg\ (std)}(scf) = W_t \times K_5$$

$V_{wsg(std)}$ = 91.10 g x 0.04715 ft^3/g = 4.295 scf

Standard Meter Volume (dscf)

$$V_{m(std)}(dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6}\right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{\frac{17.65\ ^\circ R}{in.\ Hg} \times 0.97 \times 41.73\ dcf \times \left(30.07\ in.\ Hg + \frac{0.41\ in.\ H_2O}{13.6\ in.\ H_2O / in.\ Hg}\right)}{62.79\ ^\circ F + 460\ ^\circ R} = 41.30\ dscf$$

Calculated Moisture Content (%)

$$B_{ws(calc)}(\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{4.30\ dscf}{4.30\ dscf + 41.30\ dscf} = 9.42\ \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Analysis) [Values from Run 1 test - H_2SO_4 (IC)]

Stack H_2SO_4 Mass (mg)

$$M_n(mg) = \frac{M_{n(lab)}}{V_{s(lab)}} \times V_{sample} \times \frac{L}{1000ml}$$

M_n (mg) = $\frac{\text{L}}{\text{1000 ml}}$ x 0.10 $\frac{\text{mg}}{\text{L}}$ x 166.00 ml = 0.02 mg

Stack H_2SO_4 Concentration (g/dscf)

$$c_s(g/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

c_s (g/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{41.30 dscf}}$ = $\frac{\text{4.10E-07 g}}{\text{dscf}}$

Stack H_2SO_4 Concentration (gr/dscf)

$$c'_s(gr/dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

c'$_s$ (gr/dscf) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{0.02 mg}}{\text{41.30 dscf}}$ x $\frac{\text{7000 gr}}{\text{lb}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ = $\frac{\text{6.35E-06 gr}}{\text{dscf}}$

Stack H_2SO_4 Concentration (g/L)

$$c''_s(g/L) = c'_s \times \frac{dscf}{28.31685 dsL}$$

c'$_s$ (gr/dscf) = 4.12E-07 $\frac{\text{g}}{\text{dscf}}$ x $\frac{\text{dscf}}{\text{28.31685 dsL}}$ = $\frac{\text{1.00E-08 g}}{\text{L}}$

Stack H_2SO_4 Concentration (ppmvd)

$$c'''_s(ppmvd) = \frac{M_n}{V_{m(std)}} \times Ideal\ Gas\ Constant \times \frac{10^6 parts}{million\ parts} \times \frac{1}{Mol\ Wt}$$

c'''$_s$ (ppmvd) = 1.45E-08 $\frac{\text{g}}{\text{L}}$ x $\frac{\text{24.04 L gas}}{\text{lb-mol}}$ x $\frac{10^6 \text{ parts}}{\text{MM parts}}$ x $\frac{\text{lb-mol}}{\text{98.0790 lb}}$ = 0.004 ppmvd

H_2SO_4 Emissions Rate (lb/MMBtu)

Oxygen Based:

$$E'''(lb/MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2}\right)$$

E''' (lb/MMBtu) = $\frac{\text{g}}{\text{1000 mg}}$ x $\frac{\text{lb}}{\text{453.592 g}}$ x $\frac{\text{0.02 mg}}{\text{41.30 dscf}}$ x $\frac{\text{8,641.42 dscf}}{\text{MMBtu}}$ x ($\frac{\text{20.9}}{\text{20.9 - 12.9 \%}}$) = $\frac{\text{0.00002 lb}}{\text{MMBtu}}$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B

EMISSION DATA RECORDS

Cricket Valley Energy Center LLC

Air Permit Number:	3-1326-00275/00009
Plant Name or Location:	Cricket Valley Energy Center
Date:	April 15, 2020
Project Number:	bec-19-cricketvalley.ny-start#3
Manufacturer & Equipment:	General Electric
Model:	7F.05
Unit Number:	U-00003
Test Load:	Multiple
Tester(s) / Test Unit(s):	RW/AB/220/213

		RUN					
	UNITS	**1-1**	**1-2**	**1-3**	**2-1**	**2-2**	**2-3**
Start Time	hh:mm:ss	12:10:05	13:23:05	14:35:05	14:04:12	15:23:12	17:41:12
End Time	hh:mm:ss	13:09:35	14:22:35	15:34:35	15:03:42	16:22:42	18:40:42
Bar. Pressure	in. Hg	29.99	30.11	30.09	29.99	30.04	30.10
Amb. Temp.	°F	53	54	50	43	44	46
Rel. Humidity	%	23	25	29	54	55	53
Spec. Humidity	lb water / lb air	0.001939	0.002178	0.002181	0.003133	0.003311	0.003436
Date	mm/dd/yy	04/15/20	04/15/20	04/15/20	04/16/20	04/16/20	04/16/20
Load Designator		Base	Base	Base	Base+DB	Base+DB	Base+DB
NH_3 Flow Rate	lb/hr	141.6	135.3	137.4	163.9	159.1	163.9
Turbine Fuel Flow	lb/min	1,651	1,646	1,643	1,681	1,678	1,681
Duct Burner Fuel Flow	lb/min	0	0	0	174	175	175
Total Fuel Flow	SCFH	2,293,723	2,287,005	2,282,441	2,578,392	2,573,884	2,579,455
Stack Moisture	% Method 4	8.85	8.85	8.65	9.49	9.49	9.49
Heat Input	MMBtu/hr	2326.8	2320.0	2315.3	2603.4	2598.8	2604.5
CT Power Output	megawatts	237.6	237.1	237.5	240.3	239.6	240.5

Note: Base load DB fuel flows originally reported in operating data assumed as noise. Zero values presented in Appendix B and used for calcs.

Created with Comp&RATA&Eng-AHI v20190529

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
NOx, CO, VOC, and NH_3

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 12:10 - 4/15 13:09)	237.63	27.51	0.00	13.77	141.59	1167.96	3.84
COUNT = 60							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 12:10	238.28	27.53	0.00	13.65	147.34	1169.02	3.86
4/15/20 12:11	237.92	27.53	0.00	13.79	137.78	1168.84	3.86
4/15/20 12:12	237.72	27.59	0.00	13.74	146.47	1168.16	3.86
4/15/20 12:13	237.75	27.60	0.00	13.85	144.03	1167.90	3.86
4/15/20 12:14	237.53	27.49	0.00	13.85	139.50	1167.69	3.86
4/15/20 12:15	238.02	27.53	0.00	13.98	135.25	1169.18	3.86
4/15/20 12:16	237.97	27.59	0.00	13.77	134.14	1167.41	3.86
4/15/20 12:17	238.49	27.61	0.00	13.64	145.00	1168.17	3.86
4/15/20 12:18	237.68	27.55	0.00	13.71	146.47	1167.96	3.86
4/15/20 12:19	237.30	27.46	0.00	13.94	140.78	1168.22	3.86
4/15/20 12:20	237.76	27.51	0.00	13.69	138.87	1167.46	3.85
4/15/20 12:21	237.80	27.53	0.00	13.78	137.94	1168.10	3.85
4/15/20 12:22	237.64	27.55	0.00	13.66	139.87	1167.36	3.85
4/15/20 12:23	237.57	27.52	0.00	13.73	135.73	1168.75	3.85
4/15/20 12:24	237.96	27.46	0.00	13.81	144.83	1168.20	3.85
4/15/20 12:25	237.36	27.58	0.00	13.70	138.81	1168.10	3.85
4/15/20 12:26	237.73	27.54	0.00	13.76	135.25	1168.93	3.85
4/15/20 12:27	237.76	27.51	0.00	13.86	140.64	1167.50	3.85
4/15/20 12:28	238.33	27.54	0.00	13.93	132.74	1168.55	3.85
4/15/20 12:29	237.73	27.56	0.00	13.55	142.74	1167.25	3.85
4/15/20 12:30	238.39	27.56	0.00	14.16	140.60	1169.17	3.85
4/15/20 12:31	237.89	27.53	0.00	13.31	135.05	1168.25	3.85
4/15/20 12:32	237.60	27.51	0.00	13.67	138.15	1166.77	3.85
4/15/20 12:33	237.83	27.47	0.00	13.48	143.39	1167.44	3.84
4/15/20 12:34	237.44	27.47	0.00	14.00	145.63	1169.13	3.84
4/15/20 12:35	237.79	27.62	0.00	13.79	169.84	1167.54	3.84
4/15/20 12:36	237.66	27.53	0.00	13.83	165.86	1168.38	3.84
4/15/20 12:37	237.77	27.48	0.00	13.71	176.08	1167.46	3.84
4/15/20 12:38	237.67	27.51	0.00	13.60	177.90	1168.55	3.84
4/15/20 12:39	238.34	27.52	0.00	13.71	161.73	1168.17	3.84
4/15/20 12:40	238.32	27.54	0.00	14.02	169.70	1169.11	3.84
4/15/20 12:41	238.01	27.55	0.00	13.91	162.48	1168.16	3.84
4/15/20 12:42	237.77	27.50	0.00	13.92	157.56	1167.91	3.84
4/15/20 12:43	237.96	27.57	0.00	13.71	150.12	1168.56	3.84
4/15/20 12:44	238.00	27.55	0.00	13.96	139.80	1168.36	3.84
4/15/20 12:45	238.29	27.50	0.00	13.84	147.69	1168.20	3.84
4/15/20 12:46	237.73	27.49	0.00	13.76	136.52	1168.68	3.83
4/15/20 12:47	237.74	27.48	0.00	13.75	139.64	1167.65	3.83
4/15/20 12:48	237.46	27.52	0.00	13.55	134.99	1167.83	3.83
4/15/20 12:49	237.06	27.56	0.00	13.72	136.43	1167.96	3.83
4/15/20 12:50	237.47	27.51	0.00	13.69	130.41	1167.17	3.83
4/15/20 12:51	237.55	27.40	0.00	13.75	126.18	1167.23	3.83
4/15/20 12:52	237.19	27.53	0.00	14.05	134.95	1167.83	3.83
4/15/20 12:53	236.93	27.47	0.00	13.67	128.06	1167.01	3.83
4/15/20 12:54	237.23	27.53	0.00	13.93	137.84	1168.04	3.83
4/15/20 12:55	237.25	27.47	0.00	13.59	126.40	1167.51	3.83
4/15/20 12:56	237.97	27.56	0.00	13.57	137.81	1167.87	3.83
4/15/20 12:57	237.58	27.52	0.00	13.84	130.25	1168.26	3.83
4/15/20 12:58	237.53	27.53	0.00	13.72	135.28	1165.94	3.82
4/15/20 12:59	237.64	27.45	0.00	13.58	141.29	1168.97	3.82
4/15/20 13:00	237.86	27.46	0.00	13.82	143.68	1167.89	3.82
4/15/20 13:01	237.36	27.44	0.00	13.78	139.29	1168.19	3.82
4/15/20 13:02	236.78	27.47	0.00	13.87	133.21	1167.75	3.82
4/15/20 13:03	237.13	27.45	0.00	13.70	131.71	1167.17	3.82
4/15/20 13:04	236.89	27.43	0.00	13.77	138.78	1166.86	3.82
4/15/20 13:05	236.77	27.44	0.00	13.69	129.47	1167.77	3.82
4/15/20 13:06	236.64	27.44	0.00	13.88	123.85	1167.52	3.82
4/15/20 13:07	237.07	27.44	0.00	13.78	131.45	1167.92	3.82
4/15/20 13:08	237.11	27.46	0.00	13.71	130.76	1167.24	3.82
4/15/20 13:09	237.07	27.48	0.00	13.77	131.50	1167.44	3.82

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 13:23 - 4/15 14:22)	237.10	27.43	0.02	13.77	135.28	1167.37	3.78
COUNT = 60							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 13:23	236.80	27.38	0.00	13.50	133.16	1167.21	3.81
4/15/20 13:24	236.54	27.45	0.00	13.83	138.99	1167.76	3.80
4/15/20 13:25	236.69	27.40	0.00	13.90	127.81	1167.84	3.80
4/15/20 13:26	236.26	27.43	0.00	13.77	126.33	1167.04	3.80
4/15/20 13:27	236.84	27.40	0.00	13.74	123.09	1167.55	3.80
4/15/20 13:28	237.00	27.36	0.00	13.59	130.93	1166.64	3.80
4/15/20 13:29	237.16	27.41	0.00	13.74	124.53	1167.63	3.80
4/15/20 13:30	237.04	27.43	0.00	13.61	126.19	1168.07	3.80
4/15/20 13:31	237.35	27.46	0.00	13.72	129.03	1167.30	3.80
4/15/20 13:32	237.08	27.45	0.00	14.07	130.14	1167.65	3.80
4/15/20 13:33	237.20	27.46	0.00	13.60	129.23	1167.05	3.80
4/15/20 13:34	237.47	27.44	0.00	13.39	132.71	1167.50	3.80
4/15/20 13:35	237.52	27.45	0.00	13.87	138.80	1167.98	3.80
4/15/20 13:36	237.62	27.43	0.00	13.95	141.57	1167.73	3.79
4/15/20 13:37	237.12	27.44	0.00	13.60	142.30	1167.12	3.79
4/15/20 13:38	236.96	27.41	0.00	13.68	143.63	1166.83	3.79
4/15/20 13:39	237.19	27.58	0.00	13.84	132.50	1167.70	3.79
4/15/20 13:40	237.25	27.45	0.00	13.73	140.11	1167.21	3.79
4/15/20 13:41	237.53	27.44	0.00	13.90	137.12	1167.31	3.79
4/15/20 13:42	237.62	27.37	0.00	13.68	131.12	1166.55	3.79
4/15/20 13:43	236.89	27.41	0.00	13.70	140.85	1166.86	3.79
4/15/20 13:44	236.80	27.45	0.00	13.72	146.98	1166.51	3.79
4/15/20 13:45	236.98	27.39	0.01	13.76	158.14	1167.62	3.79
4/15/20 13:46	237.15	27.39	0.01	13.79	152.70	1167.86	3.79
4/15/20 13:47	237.20	27.46	0.02	13.63	149.90	1166.74	3.79
4/15/20 13:48	237.43	27.48	0.02	13.99	151.46	1168.14	3.79
4/15/20 13:49	237.46	27.51	0.03	13.86	143.28	1167.55	3.78
4/15/20 13:50	237.70	27.47	0.04	13.77	137.71	1168.55	3.78
4/15/20 13:51	236.85	27.42	0.04	13.91	134.99	1167.89	3.78
4/15/20 13:52	237.83	27.42	0.04	13.67	140.11	1168.58	3.78
4/15/20 13:53	237.05	27.52	0.04	13.55	131.46	1167.25	3.78
4/15/20 13:54	237.25	27.40	0.04	13.83	127.86	1166.82	3.78
4/15/20 13:55	237.37	27.41	0.04	13.83	127.70	1167.66	3.78
4/15/20 13:56	236.95	27.42	0.04	13.74	132.48	1167.66	3.78
4/15/20 13:57	237.32	27.45	0.04	13.72	135.90	1168.10	3.78
4/15/20 13:58	237.39	27.40	0.04	13.94	149.02	1167.12	3.78
4/15/20 13:59	236.68	27.39	0.04	13.62	139.59	1167.18	3.78
4/15/20 14:00	236.97	27.43	0.04	13.91	142.03	1166.78	3.78
4/15/20 14:01	237.25	27.48	0.04	13.80	146.52	1167.63	3.78
4/15/20 14:02	237.21	27.43	0.04	13.84	135.82	1166.80	3.77
4/15/20 14:03	237.69	27.48	0.04	13.78	140.45	1167.74	3.77
4/15/20 14:04	237.23	27.39	0.04	13.76	140.88	1167.47	3.77
4/15/20 14:05	237.26	27.40	0.04	13.62	132.97	1167.80	3.77
4/15/20 14:06	237.51	27.55	0.04	13.91	139.69	1168.06	3.77
4/15/20 14:07	237.45	27.46	0.04	13.72	133.09	1167.44	3.77
4/15/20 14:08	237.27	27.42	0.04	13.78	130.99	1167.23	3.77
4/15/20 14:09	236.91	27.44	0.04	13.69	130.46	1166.80	3.77
4/15/20 14:10	237.18	27.39	0.04	13.83	130.35	1167.55	3.77
4/15/20 14:11	237.11	27.43	0.04	13.93	133.85	1166.85	3.77
4/15/20 14:12	237.27	27.42	0.04	13.81	135.13	1166.93	3.77
4/15/20 14:13	236.55	27.44	0.04	14.22	134.52	1167.35	3.77
4/15/20 14:14	236.87	27.39	0.04	13.49	131.80	1167.02	3.76
4/15/20 14:15	236.82	27.43	0.04	13.61	126.88	1167.51	3.76
4/15/20 14:16	236.82	27.41	0.04	14.10	131.74	1166.90	3.76
4/15/20 14:17	236.40	27.41	0.04	13.84	129.33	1166.46	3.76
4/15/20 14:18	236.62	27.39	0.04	13.84	125.65	1167.04	3.76
4/15/20 14:19	236.59	27.37	0.04	13.49	125.14	1167.67	3.76
4/15/20 14:20	236.51	27.46	0.04	13.83	128.16	1166.99	3.76
4/15/20 14:21	236.84	27.41	0.04	14.04	124.10	1167.50	3.76
4/15/20 14:22	237.02	27.40	0.04	13.73	127.90	1166.81	3.76

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 14:35 - 4/15 15:34)		237.53	27.38	0.04	13.85	137.41	1168.08	854.53
COUNT = 60								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/15/20 14:35	236.39	27.36	0.04	13.99	133.97	1167.20	3.75
	4/15/20 14:36	236.31	27.32	0.04	13.69	130.99	1167.04	3.75
	4/15/20 14:37	237.02	27.40	0.04	14.03	128.59	1167.60	3.75
	4/15/20 14:38	237.06	27.39	0.04	14.17	129.87	1168.01	3.75
	4/15/20 14:39	236.85	27.31	0.04	13.84	130.07	1168.24	3.75
	4/15/20 14:40	236.76	27.31	0.04	13.81	130.88	1167.30	3.74
	4/15/20 14:41	237.37	27.40	0.04	13.72	131.84	1167.88	3.74
	4/15/20 14:42	237.54	27.31	0.04	14.17	134.17	1169.57	3.74
	4/15/20 14:43	237.40	27.38	0.04	13.69	136.85	1166.84	3.74
	4/15/20 14:44	237.34	27.38	0.04	13.92	136.85	1167.62	3.74
	4/15/20 14:45	237.15	27.37	0.04	13.55	137.90	1167.67	3.74
	4/15/20 14:46	236.93	27.33	0.04	13.74	131.37	1167.89	3.74
	4/15/20 14:47	237.70	27.37	0.04	13.87	129.58	1168.39	3.74
	4/15/20 14:48	236.78	27.45	0.04	13.90	129.19	1167.24	3.74
	4/15/20 14:49	236.99	27.24	0.04	13.70	138.72	1167.33	540.40
	4/15/20 14:50	237.13	27.35	0.04	13.86	128.88	1167.98	609.73
	4/15/20 14:51	237.47	27.44	0.04	13.98	126.78	1167.68	648.18
	4/15/20 14:52	237.34	27.37	0.04	13.67	134.85	1167.64	691.31
	4/15/20 14:53	237.56	27.32	0.04	13.65	128.82	1167.97	748.24
	4/15/20 14:54	237.08	27.33	0.04	13.72	130.39	1167.81	797.79
	4/15/20 14:55	237.51	27.42	0.04	13.90	128.29	1167.94	853.61
	4/15/20 14:56	236.86	27.39	0.04	13.87	137.29	1168.04	902.71
	4/15/20 14:57	237.29	27.37	0.04	13.93	135.08	1168.39	947.99
	4/15/20 14:58	236.92	27.45	0.04	13.75	134.03	1167.67	1011.59
	4/15/20 14:59	237.59	27.25	0.04	13.93	131.57	1168.33	1070.11
	4/15/20 15:00	237.75	27.42	0.04	14.25	127.11	1168.73	1129.20
	4/15/20 15:01	237.62	27.43	0.04	14.14	131.54	1169.23	1187.93
	4/15/20 15:02	237.97	27.38	0.04	13.80	135.04	1168.70	1261.64
	4/15/20 15:03	237.52	27.35	0.04	14.04	136.57	1168.62	1210.41
	4/15/20 15:04	237.30	27.41	0.04	13.66	136.15	1167.51	1081.46
	4/15/20 15:05	237.70	27.41	0.04	14.10	140.71	1167.58	1013.81
	4/15/20 15:06	237.62	27.35	0.04	13.88	139.73	1168.12	952.65
	4/15/20 15:07	237.70	27.35	0.04	13.54	133.27	1167.80	908.23
	4/15/20 15:08	237.99	27.38	0.04	13.81	132.47	1168.44	834.77
	4/15/20 15:09	237.54	27.46	0.04	13.99	130.15	1168.49	794.18
	4/15/20 15:10	237.35	27.42	0.04	13.75	131.10	1168.00	730.29
	4/15/20 15:11	237.81	27.39	0.04	13.48	133.34	1168.44	690.96
	4/15/20 15:12	237.87	27.36	0.04	13.94	140.79	1168.43	651.64
	4/15/20 15:13	238.03	27.35	0.04	13.87	139.19	1169.40	680.23
	4/15/20 15:14	237.92	27.45	0.04	13.85	133.82	1168.71	783.51
	4/15/20 15:15	237.69	27.38	0.04	13.87	137.28	1168.33	850.10
	4/15/20 15:16	237.83	27.40	0.04	13.81	133.06	1168.22	900.11
	4/15/20 15:17	237.29	27.31	0.04	13.96	135.12	1167.89	959.22
	4/15/20 15:18	237.85	27.42	0.04	13.93	129.19	1168.53	1039.73
	4/15/20 15:19	237.77	27.44	0.04	13.88	135.94	1168.30	1095.10
	4/15/20 15:20	237.74	27.39	0.04	13.89	127.68	1168.00	1158.64
	4/15/20 15:21	237.76	27.34	0.04	13.82	135.01	1167.49	1216.38
	4/15/20 15:22	237.87	27.37	0.04	13.51	130.35	1167.34	1296.81
	4/15/20 15:23	238.24	27.44	0.04	14.10	132.96	1169.60	1347.24
	4/15/20 15:24	237.97	27.38	0.04	13.61	134.75	1167.28	1403.85
	4/15/20 15:25	237.57	27.37	0.04	13.67	136.42	1167.85	1475.28
	4/15/20 15:26	238.13	27.37	0.04	13.83	133.67	1167.89	1527.54
	4/15/20 15:27	238.71	27.38	0.04	13.88	141.59	1168.52	1564.75
	4/15/20 15:28	238.04	27.46	0.04	13.73	133.92	1168.70	1618.81
	4/15/20 15:29	237.60	27.37	0.04	13.82	173.71	1168.30	1713.15
	4/15/20 15:30	238.00	27.35	0.04	13.62	187.33	1168.23	1727.20
	4/15/20 15:31	237.96	27.38	0.04	14.04	180.61	1168.19	1850.32
	4/15/20 15:32	237.79	27.42	0.04	13.81	170.98	1167.96	1886.19
	4/15/20 15:33	238.07	27.37	0.04	14.13	164.48	1167.89	1902.55
	4/15/20 15:34	237.68	27.34	0.04	13.84	163.04	1168.57	1953.86

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
PM_{10}

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 8:23 - 4/15 12:46)		239.07	27.51	0.00	13.78	148.84	1169.13	3.95
COUNT = 264								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/15/20 8:23	240.44	27.49	0.00	13.76	156.61	1170.68	4.19
	4/15/20 8:24	240.57	27.68	0.00	13.98	155.87	1170.76	4.18
	4/15/20 8:25	240.62	27.56	0.00	13.60	150.57	1170.60	4.18
	4/15/20 8:26	240.81	27.40	0.00	13.89	155.81	1170.96	4.17
	4/15/20 8:27	240.55	27.70	0.00	13.78	151.44	1169.98	4.17
	4/15/20 8:28	240.90	27.62	0.00	14.00	147.54	1169.50	4.16
	4/15/20 8:29	240.60	27.66	0.00	13.69	146.95	1169.87	4.16
	4/15/20 8:30	240.23	27.51	0.00	13.68	150.29	1169.80	4.16
	4/15/20 8:31	240.22	27.54	0.00	13.72	149.58	1169.82	4.15
	4/15/20 8:32	240.90	27.61	0.00	13.87	147.67	1170.00	4.15
	4/15/20 8:33	240.49	27.62	0.00	13.80	158.12	1170.97	4.14
	4/15/20 8:34	240.72	27.45	0.00	13.77	148.97	1170.34	4.14
	4/15/20 8:35	240.39	27.48	0.00	13.85	153.12	1169.90	4.13
	4/15/20 8:36	240.46	27.58	0.00	13.81	159.83	1170.29	4.13
	4/15/20 8:37	240.40	27.66	0.00	13.85	150.10	1170.14	4.12
	4/15/20 8:38	240.86	27.58	0.00	14.21	152.79	1170.60	4.12
	4/15/20 8:39	240.64	27.47	0.00	14.21	155.49	1170.56	4.12
	4/15/20 8:40	240.58	27.47	0.00	14.04	152.05	1170.00	4.11
	4/15/20 8:41	240.97	27.57	0.00	13.67	150.99	1170.48	4.11
	4/15/20 8:42	240.74	27.57	0.00	13.71	157.06	1169.72	4.10
	4/15/20 8:43	240.46	27.35	0.00	13.71	151.48	1169.66	4.10
	4/15/20 8:44	240.26	27.55	0.00	13.69	146.45	1169.82	4.09
	4/15/20 8:45	240.43	27.55	0.00	13.88	155.65	1169.54	4.09
	4/15/20 8:46	240.03	27.70	0.00	13.64	160.39	1169.68	4.08
	4/15/20 8:47	240.78	27.47	0.00	14.18	162.75	1170.65	4.08
	4/15/20 8:48	240.72	27.48	0.00	14.00	154.00	1170.95	4.07
	4/15/20 8:49	240.44	27.53	0.00	13.98	150.03	1170.49	4.07
	4/15/20 8:50	240.52	27.65	0.00	13.94	159.71	1170.06	4.07
	4/15/20 8:51	240.36	27.48	0.00	13.77	155.45	1170.68	4.06
	4/15/20 8:52	240.24	27.46	0.00	13.62	146.27	1169.95	4.06
	4/15/20 8:53	240.04	27.47	0.00	13.96	146.86	1169.52	4.05
	4/15/20 8:54	240.32	27.62	0.00	13.73	145.95	1169.04	4.05
	4/15/20 8:55	240.25	27.65	0.00	14.20	143.89	1170.00	4.04
	4/15/20 8:56	240.46	27.52	0.00	13.76	145.98	1169.37	4.04
	4/15/20 8:57	240.06	27.48	0.00	13.82	150.13	1168.93	4.03
	4/15/20 8:58	239.81	27.45	0.00	13.99	151.65	1169.72	4.03
	4/15/20 8:59	239.92	27.61	0.00	13.88	149.20	1169.76	4.03
	4/15/20 9:00	239.67	27.48	0.00	13.73	146.61	1169.60	4.02
	4/15/20 9:01	240.09	27.45	0.00	13.80	145.84	1169.32	4.02
	4/15/20 9:02	240.16	27.46	0.00	13.72	151.00	1169.58	4.01
	4/15/20 9:03	240.14	27.55	0.00	13.86	155.16	1169.23	4.01
	4/15/20 9:04	239.98	27.52	0.00	13.65	156.81	1169.78	4.01
	4/15/20 9:05	240.14	27.39	0.00	14.03	148.64	1170.51	4.01
	4/15/20 9:06	240.02	27.43	0.00	13.76	144.15	1169.68	4.01
	4/15/20 9:07	239.65	27.48	0.00	13.60	155.58	1169.02	4.01
	4/15/20 9:08	239.82	27.57	0.00	13.81	153.24	1169.73	4.01
	4/15/20 9:09	239.73	27.43	0.00	13.64	144.15	1169.32	4.01
	4/15/20 9:10	240.00	27.45	0.00	13.91	150.42	1170.27	4.00
	4/15/20 9:11	239.97	27.49	0.00	13.84	156.95	1170.39	4.00
	4/15/20 9:12	239.94	27.53	0.00	13.69	155.52	1170.09	4.00
	4/15/20 9:13	239.60	27.54	0.00	13.65	157.07	1169.94	4.00
	4/15/20 9:14	239.48	27.41	0.00	13.56	144.28	1169.48	4.00
	4/15/20 9:15	239.42	27.40	0.00	13.93	145.23	1170.20	4.00
	4/15/20 9:16	239.93	27.45	0.00	13.50	147.12	1169.82	4.00
	4/15/20 9:17	239.93	27.52	0.00	13.85	143.97	1170.12	4.00
	4/15/20 9:18	239.72	27.49	0.00	13.87	155.41	1169.85	4.00
	4/15/20 9:19	239.70	27.37	0.00	13.65	158.47	1169.87	4.00
	4/15/20 9:20	239.74	27.48	0.00	13.75	144.77	1169.67	4.00
	4/15/20 9:21	239.99	27.48	0.00	13.66	149.93	1169.54	4.00
	4/15/20 9:22	239.88	27.57	0.00	13.64	156.85	1169.68	4.00
	4/15/20 9:23	239.46	27.49	0.00	13.65	148.13	1169.33	3.99
	4/15/20 9:24	239.68	27.41	0.00	13.63	146.58	1169.12	3.99
	4/15/20 9:25	239.62	27.46	0.00	13.49	155.94	1168.99	3.99
	4/15/20 9:26	239.75	27.55	0.00	13.90	160.40	1169.28	3.99
	4/15/20 9:27	239.37	27.51	0.00	13.75	156.23	1169.71	3.99
	4/15/20 9:28	239.44	27.51	0.00	13.64	153.63	1169.43	3.99
	4/15/20 9:29	239.59	27.54	0.00	13.61	159.71	1169.09	3.99

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 8:23 - 4/15 12:46)	239.07	27.51	0.00	13.78	148.84	1169.13	3.95
COUNT = 264							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 9:30	239.62	27.46	0.00	14.01	144.45	1169.97	3.99
4/15/20 9:31	239.37	27.48	0.00	13.90	153.87	1168.59	3.99
4/15/20 9:32	239.69	27.49	0.00	13.78	151.72	1170.21	3.99
4/15/20 9:33	239.82	27.47	0.00	13.90	142.42	1170.02	3.99
4/15/20 9:34	239.94	27.44	0.00	13.88	151.67	1170.22	3.99
4/15/20 9:35	239.34	27.47	0.00	14.07	153.57	1170.17	3.99
4/15/20 9:36	239.65	27.59	0.00	13.80	149.70	1170.02	3.98
4/15/20 9:37	239.73	27.42	0.00	13.81	147.81	1169.33	3.98
4/15/20 9:38	239.81	27.45	0.00	14.00	149.35	1170.56	3.98
4/15/20 9:39	240.00	27.51	0.00	13.76	160.14	1170.18	3.98
4/15/20 9:40	239.31	27.49	0.00	13.45	157.24	1168.37	3.98
4/15/20 9:41	239.25	27.44	0.00	13.70	151.89	1169.13	3.98
4/15/20 9:42	239.04	27.47	0.00	13.76	145.20	1168.94	3.98
4/15/20 9:43	238.90	27.41	0.00	13.68	157.51	1168.77	3.98
4/15/20 9:44	239.22	27.40	0.00	13.96	143.28	1169.04	3.98
4/15/20 9:45	239.14	27.45	0.00	13.78	153.15	1169.88	3.98
4/15/20 9:46	239.55	27.49	0.00	13.53	141.01	1168.91	3.98
4/15/20 9:47	239.13	27.40	0.00	13.70	142.31	1168.84	3.98
4/15/20 9:48	239.60	27.48	0.00	13.73	151.35	1170.57	3.97
4/15/20 9:49	239.68	27.45	0.00	13.88	153.23	1169.86	3.97
4/15/20 9:50	239.18	27.43	0.00	14.12	145.83	1169.44	3.97
4/15/20 9:51	239.40	27.42	0.00	13.68	144.45	1169.95	3.97
4/15/20 9:52	239.26	27.45	0.00	13.82	151.49	1168.29	3.97
4/15/20 9:53	238.93	27.42	0.00	13.78	157.05	1169.68	3.97
4/15/20 9:54	238.91	27.40	0.00	13.90	151.77	1168.08	3.97
4/15/20 9:55	239.20	27.43	0.00	14.00	146.95	1169.42	3.97
4/15/20 9:56	238.97	27.43	0.00	13.91	145.89	1169.54	3.97
4/15/20 9:57	239.17	27.41	0.00	13.65	154.21	1169.61	3.97
4/15/20 9:58	238.89	27.36	0.00	13.78	156.39	1169.45	3.97
4/15/20 9:59	239.15	27.39	0.00	13.94	153.24	1169.59	3.97
4/15/20 10:00	239.31	27.47	0.00	14.02	152.80	1169.61	3.97
4/15/20 10:01	239.28	27.41	0.00	13.72	151.65	1169.45	3.96
4/15/20 10:02	239.15	27.42	0.00	13.68	155.72	1169.68	3.96
4/15/20 10:03	239.14	27.42	0.00	13.72	148.90	1169.29	3.96
4/15/20 10:04	239.21	27.35	0.00	13.93	151.01	1169.39	3.96
4/15/20 10:05	239.09	27.38	0.00	13.88	155.68	1169.89	3.96
4/15/20 10:06	238.79	27.43	0.00	13.69	144.73	1169.72	3.96
4/15/20 10:07	239.14	27.43	0.00	13.70	153.33	1169.02	3.96
4/15/20 10:08	239.45	27.40	0.00	13.72	146.01	1169.16	3.96
4/15/20 10:09	239.17	27.37	0.00	13.57	142.75	1169.15	3.96
4/15/20 10:10	239.52	27.50	0.00	13.66	151.23	1169.07	3.96
4/15/20 10:11	239.16	27.38	0.00	13.88	151.76	1168.11	3.96
4/15/20 10:12	239.38	27.43	0.00	13.87	145.45	1169.60	3.96
4/15/20 10:13	239.18	27.41	0.00	13.39	146.98	1168.56	3.96
4/15/20 10:14	239.13	27.44	0.00	13.48	152.46	1169.14	3.95
4/15/20 10:15	239.03	27.40	0.00	13.86	154.17	1169.17	3.95
4/15/20 10:16	239.53	27.43	0.00	13.75	147.66	1168.83	3.95
4/15/20 10:17	238.92	27.39	0.00	13.58	145.86	1168.37	3.95
4/15/20 10:18	239.64	27.42	0.00	14.07	157.53	1169.20	3.95
4/15/20 10:19	238.92	27.44	0.00	13.58	159.55	1168.81	3.95
4/15/20 10:20	238.88	27.52	0.00	13.70	158.66	1168.50	3.95
4/15/20 10:21	238.48	27.39	0.00	13.70	149.06	1168.31	3.95
4/15/20 10:22	238.70	27.39	0.00	14.20	156.09	1169.04	3.95
4/15/20 10:23	239.44	27.52	0.00	13.70	154.00	1169.21	3.95
4/15/20 10:24	239.28	27.41	0.00	13.67	150.39	1168.99	3.95
4/15/20 10:25	238.64	27.46	0.00	13.44	149.06	1168.77	3.95
4/15/20 10:26	238.88	27.41	0.00	13.95	143.22	1169.45	3.94
4/15/20 10:27	239.35	27.43	0.00	13.79	153.70	1169.26	3.94
4/15/20 10:28	239.09	27.48	0.00	13.69	156.16	1169.06	3.94
4/15/20 10:29	239.25	27.48	0.00	13.59	152.30	1169.61	3.94
4/15/20 10:30	239.37	27.48	0.00	13.94	146.39	1169.70	3.94
4/15/20 10:31	238.97	27.46	0.00	13.88	153.54	1169.67	3.94
4/15/20 10:32	239.22	27.44	0.00	14.24	158.41	1170.03	3.94
4/15/20 10:33	238.92	27.42	0.00	13.58	156.30	1167.88	3.94
4/15/20 10:34	239.00	27.45	0.00	13.81	152.05	1169.21	3.94
4/15/20 10:35	238.99	27.41	0.00	13.79	148.73	1169.26	3.94
4/15/20 10:36	239.24	27.40	0.00	13.63	148.86	1169.30	3.94

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 8:23 - 4/15 12:46)	239.07	27.51	0.00	13.78	148.84	1169.13	3.95
COUNT = 264							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 10:37	238.79	27.47	0.00	13.51	149.24	1168.59	3.94
4/15/20 10:38	239.09	27.36	0.00	13.85	153.37	1169.33	3.94
4/15/20 10:39	238.63	27.49	0.00	13.81	151.43	1168.89	3.93
4/15/20 10:40	239.18	27.45	0.00	13.76	145.42	1169.16	3.93
4/15/20 10:41	238.51	27.45	0.00	13.78	147.93	1168.62	3.93
4/15/20 10:42	238.76	27.48	0.00	13.84	145.27	1169.16	3.93
4/15/20 10:43	238.82	27.48	0.00	13.67	141.74	1169.11	3.93
4/15/20 10:44	239.43	27.44	0.00	13.63	171.93	1169.42	3.93
4/15/20 10:45	239.39	27.51	0.00	14.21	157.84	1169.59	3.93
4/15/20 10:46	239.19	27.51	0.00	13.75	168.24	1168.89	3.93
4/15/20 10:47	239.03	27.50	0.00	13.93	151.19	1169.11	3.93
4/15/20 10:48	239.31	27.44	0.00	14.06	160.53	1168.67	3.93
4/15/20 10:49	239.12	27.43	0.00	13.58	159.91	1168.20	3.93
4/15/20 10:50	239.30	27.46	0.00	13.61	156.42	1168.91	3.93
4/15/20 10:51	238.95	27.50	0.00	13.81	141.74	1169.06	3.93
4/15/20 10:52	238.85	27.44	0.00	13.66	142.01	1168.98	3.92
4/15/20 10:53	238.81	27.47	0.00	13.63	143.10	1168.26	3.92
4/15/20 10:54	239.11	27.46	0.00	13.61	140.37	1167.93	3.92
4/15/20 10:55	238.53	27.60	0.00	13.57	140.37	1167.84	3.92
4/15/20 10:56	239.23	27.49	0.00	13.70	149.14	1169.10	3.92
4/15/20 10:57	239.02	27.52	0.00	13.78	143.47	1168.82	3.92
4/15/20 10:58	239.30	27.56	0.00	13.83	140.30	1169.82	3.92
4/15/20 10:59	238.72	27.40	0.00	13.53	141.91	1169.19	3.92
4/15/20 11:00	238.61	27.47	0.00	13.69	141.15	1167.91	3.92
4/15/20 11:01	239.33	27.52	0.00	13.98	141.54	1169.24	3.92
4/15/20 11:02	238.63	27.53	0.00	13.62	147.45	1168.78	3.92
4/15/20 11:03	239.12	27.56	0.00	13.58	146.97	1170.09	3.92
4/15/20 11:04	238.66	27.51	0.00	13.62	153.91	1168.65	3.91
4/15/20 11:05	238.88	27.52	0.00	13.82	153.36	1170.23	3.91
4/15/20 11:06	239.76	27.57	0.00	13.76	155.01	1170.70	3.91
4/15/20 11:07	238.95	27.53	0.00	13.70	150.02	1169.67	3.91
4/15/20 11:08	239.25	27.54	0.00	13.46	154.54	1168.71	3.91
4/15/20 11:09	238.75	27.53	0.00	13.59	153.82	1168.71	3.91
4/15/20 11:10	238.74	27.56	0.00	13.82	148.66	1168.81	3.91
4/15/20 11:11	238.64	27.56	0.00	13.89	143.15	1168.40	3.91
4/15/20 11:12	239.03	27.59	0.00	13.63	151.75	1169.17	3.91
4/15/20 11:13	238.62	27.58	0.00	13.65	141.35	1168.45	3.91
4/15/20 11:14	238.71	27.60	0.00	13.87	150.60	1169.58	3.91
4/15/20 11:15	238.63	27.52	0.00	13.63	142.28	1168.57	3.91
4/15/20 11:16	238.42	27.57	0.00	13.62	138.61	1168.46	3.91
4/15/20 11:17	238.17	27.51	0.00	13.59	148.48	1168.06	3.90
4/15/20 11:18	237.91	27.54	0.00	13.90	142.98	1168.58	3.90
4/15/20 11:19	238.19	27.54	0.00	13.67	137.71	1168.63	3.90
4/15/20 11:20	238.19	27.59	0.00	13.85	137.72	1168.27	3.90
4/15/20 11:21	238.92	27.61	0.00	13.57	140.47	1169.79	3.90
4/15/20 11:22	238.41	27.53	0.00	13.72	138.01	1169.43	3.90
4/15/20 11:23	238.17	27.61	0.00	13.85	144.00	1169.12	3.90
4/15/20 11:24	238.48	27.56	0.00	13.77	136.72	1168.73	3.90
4/15/20 11:25	238.90	27.60	0.00	13.67	140.81	1168.24	3.90
4/15/20 11:26	238.77	27.62	0.00	13.69	147.14	1168.97	3.90
4/15/20 11:27	239.33	27.63	0.00	13.93	149.53	1169.26	3.90
4/15/20 11:28	238.84	27.61	0.00	13.72	152.80	1168.85	3.90
4/15/20 11:29	238.90	27.59	0.00	13.68	149.94	1168.47	3.90
4/15/20 11:30	238.81	27.67	0.00	13.70	152.79	1169.14	3.89
4/15/20 11:31	238.80	27.59	0.00	13.97	149.91	1168.81	3.89
4/15/20 11:32	238.64	27.59	0.00	13.70	153.00	1169.21	3.89
4/15/20 11:33	238.97	27.57	0.00	13.61	146.72	1168.62	3.89
4/15/20 11:34	238.90	27.65	0.00	13.69	150.48	1169.37	3.89
4/15/20 11:35	238.87	27.56	0.00	13.65	154.37	1169.18	3.89
4/15/20 11:36	238.65	27.58	0.00	13.89	145.08	1168.64	3.89
4/15/20 11:37	238.58	27.63	0.00	13.53	149.23	1168.66	3.89
4/15/20 11:38	238.70	27.63	0.00	13.81	155.78	1168.55	3.89
4/15/20 11:39	238.81	27.59	0.00	13.60	146.09	1169.13	3.89
4/15/20 11:40	238.38	27.66	0.00	13.91	142.69	1169.29	3.89
4/15/20 11:41	238.94	27.54	0.00	14.04	145.72	1169.44	3.89
4/15/20 11:42	238.60	27.61	0.00	13.81	148.48	1169.20	3.88
4/15/20 11:43	237.94	27.56	0.00	13.61	148.13	1168.34	3.88

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 8:23 - 4/15 12:46)	239.07	27.51	0.00	13.78	148.84	1169.13	3.95
COUNT = 264							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 11:44	238.95	27.58	0.00	13.70	138.04	1168.36	3.88
4/15/20 11:45	238.42	27.59	0.00	14.10	135.42	1169.07	3.88
4/15/20 11:46	238.44	27.60	0.00	13.72	144.90	1169.11	3.88
4/15/20 11:47	238.45	27.55	0.00	13.97	145.44	1169.03	3.88
4/15/20 11:48	238.31	27.54	0.00	13.63	146.33	1168.01	3.88
4/15/20 11:49	238.46	27.56	0.00	14.12	147.24	1168.66	3.88
4/15/20 11:50	238.87	27.59	0.00	13.77	146.90	1169.22	3.88
4/15/20 11:51	237.86	27.57	0.00	13.66	140.19	1167.94	3.88
4/15/20 11:52	238.34	27.53	0.00	13.57	141.63	1168.26	3.88
4/15/20 11:53	238.42	27.57	0.00	13.60	148.14	1168.15	3.88
4/15/20 11:54	237.70	27.53	0.00	13.88	148.21	1168.61	3.88
4/15/20 11:55	237.41	27.54	0.00	13.84	138.67	1167.94	3.87
4/15/20 11:56	237.85	27.49	0.00	13.89	141.10	1168.96	3.87
4/15/20 11:57	238.20	27.60	0.00	13.81	143.13	1168.06	3.87
4/15/20 11:58	238.04	27.55	0.00	14.02	134.73	1168.60	3.87
4/15/20 11:59	238.54	27.58	0.00	13.58	134.47	1169.01	3.87
4/15/20 12:00	238.48	27.51	0.00	13.83	137.14	1168.11	3.87
4/15/20 12:01	238.38	27.58	0.00	13.73	138.85	1168.68	3.87
4/15/20 12:02	238.23	27.55	0.00	13.82	138.74	1168.58	3.87
4/15/20 12:03	237.94	27.60	0.00	13.92	145.52	1168.53	3.87
4/15/20 12:04	238.02	27.55	0.00	13.70	148.70	1168.51	3.87
4/15/20 12:05	238.08	27.59	0.00	13.63	139.07	1169.18	3.87
4/15/20 12:06	238.03	27.53	0.00	13.82	146.02	1168.05	3.87
4/15/20 12:07	237.97	27.56	0.00	13.62	135.97	1168.62	3.87
4/15/20 12:08	238.36	27.61	0.00	14.04	135.02	1169.28	3.86
4/15/20 12:09	238.05	27.54	0.00	13.77	135.54	1169.19	3.86
4/15/20 12:10	238.28	27.53	0.00	13.65	147.34	1169.02	3.86
4/15/20 12:11	237.92	27.53	0.00	13.79	137.78	1168.84	3.86
4/15/20 12:12	237.72	27.59	0.00	13.74	146.47	1168.16	3.86
4/15/20 12:13	237.75	27.60	0.00	13.85	144.03	1167.90	3.86
4/15/20 12:14	237.53	27.49	0.00	13.85	139.50	1167.69	3.86
4/15/20 12:15	238.02	27.53	0.00	13.98	135.25	1169.18	3.86
4/15/20 12:16	237.97	27.59	0.00	13.77	134.14	1167.41	3.86
4/15/20 12:17	238.49	27.61	0.00	13.64	145.00	1168.17	3.86
4/15/20 12:18	237.68	27.55	0.00	13.71	146.47	1167.96	3.86
4/15/20 12:19	237.30	27.46	0.00	13.94	140.78	1168.22	3.86
4/15/20 12:20	237.76	27.51	0.00	13.69	138.87	1167.46	3.85
4/15/20 12:21	237.80	27.53	0.00	13.78	137.94	1168.10	3.85
4/15/20 12:22	237.64	27.55	0.00	13.66	139.87	1167.36	3.85
4/15/20 12:23	237.57	27.52	0.00	13.73	135.73	1168.75	3.85
4/15/20 12:24	237.96	27.46	0.00	13.81	144.83	1168.20	3.85
4/15/20 12:25	237.36	27.58	0.00	13.70	138.81	1168.10	3.85
4/15/20 12:26	237.73	27.54	0.00	13.76	135.25	1168.93	3.85
4/15/20 12:27	237.76	27.51	0.00	13.86	140.64	1167.50	3.85
4/15/20 12:28	238.33	27.54	0.00	13.93	132.74	1168.55	3.85
4/15/20 12:29	237.73	27.56	0.00	13.55	142.74	1167.25	3.85
4/15/20 12:30	238.39	27.56	0.00	14.16	140.60	1169.17	3.85
4/15/20 12:31	237.89	27.53	0.00	13.31	135.05	1168.25	3.85
4/15/20 12:32	237.60	27.51	0.00	13.67	138.15	1166.77	3.85
4/15/20 12:33	237.83	27.47	0.00	13.48	143.39	1167.44	3.84
4/15/20 12:34	237.44	27.47	0.00	14.00	145.63	1169.13	3.84
4/15/20 12:35	237.79	27.62	0.00	13.79	169.84	1167.54	3.84
4/15/20 12:36	237.66	27.53	0.00	13.83	165.86	1168.38	3.84
4/15/20 12:37	237.77	27.48	0.00	13.71	176.08	1167.46	3.84
4/15/20 12:38	237.67	27.51	0.00	13.60	177.90	1168.55	3.84
4/15/20 12:39	238.34	27.52	0.00	13.71	161.73	1168.17	3.84
4/15/20 12:40	238.32	27.54	0.00	14.02	169.70	1169.11	3.84
4/15/20 12:41	238.01	27.55	0.00	13.91	162.48	1168.16	3.84
4/15/20 12:42	237.77	27.50	0.00	13.92	157.56	1167.91	3.84
4/15/20 12:43	237.96	27.57	0.00	13.71	150.12	1168.56	3.84
4/15/20 12:44	238.00	27.55	0.00	13.96	139.80	1168.36	3.84
4/15/20 12:45	238.29	27.50	0.00	13.84	147.69	1168.20	3.84
4/15/20 12:46	237.73	27.49	0.00	13.76	136.52	1168.68	3.83

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 13:45 - 4/15 18:02)	237.40	27.35	0.04	13.80	135.92	1167.54	448.36
COUNT = 258							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 13:45	236.98	27.39	0.01	13.76	158.14	1167.62	3.79
4/15/20 13:46	237.15	27.39	0.01	13.79	152.70	1167.86	3.79
4/15/20 13:47	237.20	27.46	0.02	13.63	149.90	1166.74	3.79
4/15/20 13:48	237.43	27.48	0.02	13.99	151.46	1168.14	3.79
4/15/20 13:49	237.46	27.51	0.03	13.86	143.28	1167.55	3.78
4/15/20 13:50	237.70	27.47	0.04	13.77	137.71	1168.55	3.78
4/15/20 13:51	236.85	27.42	0.04	13.91	134.99	1167.89	3.78
4/15/20 13:52	237.83	27.42	0.04	13.67	140.11	1168.58	3.78
4/15/20 13:53	237.05	27.52	0.04	13.55	131.46	1167.25	3.78
4/15/20 13:54	237.25	27.40	0.04	13.83	127.86	1166.82	3.78
4/15/20 13:55	237.37	27.41	0.04	13.83	127.70	1167.66	3.78
4/15/20 13:56	236.95	27.42	0.04	13.74	132.48	1167.66	3.78
4/15/20 13:57	237.32	27.45	0.04	13.72	135.90	1168.10	3.78
4/15/20 13:58	237.39	27.40	0.04	13.94	149.02	1167.12	3.78
4/15/20 13:59	236.68	27.39	0.04	13.62	139.59	1167.18	3.78
4/15/20 14:00	236.97	27.43	0.04	13.91	142.03	1166.78	3.78
4/15/20 14:01	237.25	27.48	0.04	13.80	146.52	1167.63	3.78
4/15/20 14:02	237.21	27.43	0.04	13.84	135.82	1166.80	3.77
4/15/20 14:03	237.69	27.48	0.04	13.78	140.45	1167.74	3.77
4/15/20 14:04	237.23	27.39	0.04	13.76	140.88	1167.47	3.77
4/15/20 14:05	237.26	27.40	0.04	13.62	132.97	1167.80	3.77
4/15/20 14:06	237.51	27.55	0.04	13.91	139.69	1168.06	3.77
4/15/20 14:07	237.45	27.46	0.04	13.72	133.09	1167.44	3.77
4/15/20 14:08	237.27	27.42	0.04	13.78	130.99	1167.23	3.77
4/15/20 14:09	236.91	27.44	0.04	13.69	130.46	1166.80	3.77
4/15/20 14:10	237.18	27.39	0.04	13.83	130.35	1167.55	3.77
4/15/20 14:11	237.11	27.43	0.04	13.93	133.85	1166.85	3.77
4/15/20 14:12	237.27	27.42	0.04	13.81	135.13	1166.93	3.77
4/15/20 14:13	236.55	27.44	0.04	14.22	134.52	1167.35	3.77
4/15/20 14:14	236.87	27.39	0.04	13.49	131.80	1167.02	3.76
4/15/20 14:15	236.82	27.43	0.04	13.61	126.88	1167.51	3.76
4/15/20 14:16	236.82	27.41	0.04	14.10	131.74	1166.90	3.76
4/15/20 14:17	236.40	27.41	0.04	13.84	129.33	1166.46	3.76
4/15/20 14:18	236.62	27.39	0.04	13.84	125.65	1167.04	3.76
4/15/20 14:19	236.59	27.37	0.04	13.49	125.14	1167.67	3.76
4/15/20 14:20	236.51	27.46	0.04	13.83	128.16	1166.99	3.76
4/15/20 14:21	236.84	27.41	0.04	14.04	124.10	1167.50	3.76
4/15/20 14:22	237.02	27.40	0.04	13.73	127.90	1166.81	3.76
4/15/20 14:23	237.24	27.35	0.04	13.58	128.12	1167.25	3.76
4/15/20 14:24	237.12	27.49	0.04	13.87	134.41	1167.78	3.76
4/15/20 14:25	236.20	27.36	0.04	13.74	131.64	1166.39	3.76
4/15/20 14:26	236.62	27.32	0.04	13.73	137.11	1166.24	3.76
4/15/20 14:27	236.28	27.37	0.04	14.15	139.22	1168.14	3.75
4/15/20 14:28	236.61	27.40	0.04	13.84	131.92	1167.90	3.75
4/15/20 14:29	236.56	27.40	0.04	13.63	139.37	1166.31	3.75
4/15/20 14:30	236.42	27.36	0.04	13.66	128.99	1166.79	3.75
4/15/20 14:31	236.27	27.33	0.04	13.78	133.56	1167.06	3.75
4/15/20 14:32	236.72	27.36	0.04	14.05	136.44	1167.33	3.75
4/15/20 14:33	236.26	27.42	0.04	13.53	127.98	1167.03	3.75
4/15/20 14:34	236.76	27.38	0.04	13.67	125.99	1167.82	3.75
4/15/20 14:35	236.39	27.36	0.04	13.99	133.97	1167.20	3.75
4/15/20 14:36	236.31	27.32	0.04	13.69	130.99	1167.04	3.75
4/15/20 14:37	237.02	27.40	0.04	14.03	128.59	1167.60	3.75
4/15/20 14:38	237.06	27.39	0.04	14.17	129.87	1168.01	3.75
4/15/20 14:39	236.85	27.31	0.04	13.84	130.07	1168.24	3.75
4/15/20 14:40	236.76	27.31	0.04	13.81	130.88	1167.30	3.74
4/15/20 14:41	237.37	27.40	0.04	13.72	131.84	1167.88	3.74
4/15/20 14:42	237.54	27.31	0.04	14.17	134.17	1169.57	3.74
4/15/20 14:43	237.40	27.38	0.04	13.69	136.85	1166.84	3.74
4/15/20 14:44	237.34	27.38	0.04	13.92	136.85	1167.62	3.74
4/15/20 14:45	237.15	27.37	0.04	13.55	137.90	1167.67	3.74
4/15/20 14:46	236.93	27.33	0.04	13.74	131.37	1167.89	3.74
4/15/20 14:47	237.70	27.37	0.04	13.87	129.58	1168.39	3.74
4/15/20 14:48	236.78	27.45	0.04	13.90	129.19	1167.24	3.74
4/15/20 14:49	236.99	27.24	0.04	13.70	138.72	1167.33	540.40
4/15/20 14:50	237.13	27.35	0.04	13.86	128.88	1167.98	609.73
4/15/20 14:51	237.47	27.44	0.04	13.98	126.78	1167.68	648.18

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 13:45 - 4/15 18:02)		237.40	27.35	0.04	13.80	135.92	1167.54	448.36
COUNT = 258								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/15/20 14:52	237.34	27.37	0.04	13.67	134.85	1167.64	691.31
	4/15/20 14:53	237.56	27.32	0.04	13.65	128.82	1167.97	748.24
	4/15/20 14:54	237.08	27.33	0.04	13.72	130.39	1167.81	797.79
	4/15/20 14:55	237.51	27.42	0.04	13.90	128.29	1167.94	853.61
	4/15/20 14:56	236.86	27.39	0.04	13.87	137.29	1168.04	902.71
	4/15/20 14:57	237.29	27.37	0.04	13.93	135.08	1168.39	947.99
	4/15/20 14:58	236.92	27.45	0.04	13.75	134.03	1167.67	1011.59
	4/15/20 14:59	237.59	27.25	0.04	13.93	131.57	1168.33	1070.11
	4/15/20 15:00	237.75	27.42	0.04	14.25	127.11	1168.73	1129.20
	4/15/20 15:01	237.62	27.43	0.04	14.14	131.54	1169.23	1187.93
	4/15/20 15:02	237.97	27.38	0.04	13.80	135.04	1168.70	1261.64
	4/15/20 15:03	237.52	27.35	0.04	14.04	136.57	1168.62	1210.41
	4/15/20 15:04	237.30	27.41	0.04	13.66	136.15	1167.51	1081.46
	4/15/20 15:05	237.70	27.41	0.04	14.10	140.71	1167.58	1013.81
	4/15/20 15:06	237.62	27.35	0.04	13.88	139.73	1168.12	952.65
	4/15/20 15:07	237.70	27.35	0.04	13.54	133.27	1167.80	908.23
	4/15/20 15:08	237.99	27.38	0.04	13.81	132.47	1168.44	834.77
	4/15/20 15:09	237.54	27.46	0.04	13.99	130.15	1168.49	794.18
	4/15/20 15:10	237.35	27.42	0.04	13.75	131.10	1168.00	730.29
	4/15/20 15:11	237.81	27.39	0.04	13.48	133.34	1168.44	690.96
	4/15/20 15:12	237.87	27.36	0.04	13.94	140.79	1168.43	651.64
	4/15/20 15:13	238.03	27.35	0.04	13.87	139.19	1169.40	680.23
	4/15/20 15:14	237.92	27.45	0.04	13.85	133.82	1168.71	783.51
	4/15/20 15:15	237.69	27.38	0.04	13.87	137.28	1168.33	850.10
	4/15/20 15:16	237.83	27.40	0.04	13.81	133.06	1168.22	900.11
	4/15/20 15:17	237.29	27.31	0.04	13.96	135.12	1167.89	959.22
	4/15/20 15:18	237.85	27.42	0.04	13.93	129.19	1168.53	1039.73
	4/15/20 15:19	237.77	27.44	0.04	13.88	135.94	1168.30	1095.10
	4/15/20 15:20	237.74	27.39	0.04	13.89	127.68	1168.00	1158.64
	4/15/20 15:21	237.76	27.34	0.04	13.82	135.01	1167.49	1216.38
	4/15/20 15:22	237.87	27.37	0.04	13.51	130.35	1167.34	1296.81
	4/15/20 15:23	238.24	27.44	0.04	14.10	132.96	1169.60	1347.24
	4/15/20 15:24	237.97	27.38	0.04	13.61	134.75	1167.28	1403.85
	4/15/20 15:25	237.57	27.37	0.04	13.67	136.42	1167.85	1475.28
	4/15/20 15:26	238.13	27.37	0.04	13.83	133.67	1167.89	1527.54
	4/15/20 15:27	238.71	27.38	0.04	13.88	141.59	1168.52	1564.75
	4/15/20 15:28	238.04	27.46	0.04	13.73	133.92	1168.70	1618.81
	4/15/20 15:29	237.60	27.37	0.04	13.82	173.71	1168.30	1713.15
	4/15/20 15:30	238.00	27.35	0.04	13.62	187.33	1168.23	1727.20
	4/15/20 15:31	237.96	27.38	0.04	14.04	180.61	1168.19	1850.32
	4/15/20 15:32	237.79	27.42	0.04	13.81	170.98	1167.96	1886.19
	4/15/20 15:33	238.07	27.37	0.04	14.13	164.48	1167.89	1902.55
	4/15/20 15:34	237.68	27.34	0.04	13.84	163.04	1168.57	1953.86
	4/15/20 15:35	237.70	27.29	0.04	13.91	151.97	1168.38	1840.89
	4/15/20 15:36	238.18	27.34	0.04	13.76	148.63	1167.64	1814.19
	4/15/20 15:37	238.56	27.49	0.04	13.82	139.05	1169.00	1874.69
	4/15/20 15:38	237.64	27.32	0.04	13.69	135.41	1167.67	1938.40
	4/15/20 15:39	238.11	27.30	0.04	13.91	130.86	1168.34	2002.92
	4/15/20 15:40	238.14	27.37	0.04	13.93	131.47	1168.56	2039.57
	4/15/20 15:41	237.75	27.48	0.04	13.66	126.57	1167.23	2105.81
	4/15/20 15:42	237.19	27.32	0.04	13.82	125.57	1167.31	2154.46
	4/15/20 15:43	237.75	27.32	0.04	13.62	125.58	1167.26	2216.29
	4/15/20 15:44	237.76	27.34	0.04	13.81	127.78	1168.35	2247.23
	4/15/20 15:45	237.86	27.44	0.04	13.81	125.88	1167.94	2275.57
	4/15/20 15:46	237.11	27.43	0.04	13.80	126.39	1166.96	2182.75
	4/15/20 15:47	237.27	27.30	0.04	13.55	127.08	1166.88	2101.45
	4/15/20 15:48	237.17	27.35	0.04	13.78	131.83	1167.33	2066.55
	4/15/20 15:49	237.48	27.32	0.04	13.98	134.16	1167.58	2054.37
	4/15/20 15:50	237.36	27.42	0.04	13.71	139.01	1167.39	1996.12
	4/15/20 15:51	237.52	27.38	0.04	13.99	139.74	1167.18	1940.55
	4/15/20 15:52	237.29	27.26	0.04	13.80	141.18	1167.17	1900.39
	4/15/20 15:53	237.49	27.31	0.04	13.93	132.90	1167.65	1912.97
	4/15/20 15:54	237.43	27.39	0.04	13.88	139.05	1167.37	1863.70
	4/15/20 15:55	237.54	27.39	0.04	13.91	129.39	1167.86	1884.71
	4/15/20 15:56	237.79	27.38	0.04	13.53	136.19	1167.25	1848.92
	4/15/20 15:57	238.22	27.30	0.04	13.67	132.88	1167.78	1851.34
	4/15/20 15:58	237.68	27.43	0.04	13.91	136.88	1167.92	1862.21

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 13:45 - 4/15 18:02)		237.40	27.35	0.04	13.80	135.92	1167.54	448.36
COUNT = 258								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/15/20 15:59	237.17	27.34	0.04	13.70	129.93	1166.57	1858.37
	4/15/20 16:00	237.55	27.39	0.04	13.52	136.81	1167.92	1831.24
	4/15/20 16:01	237.89	27.27	0.04	13.65	130.09	1167.15	1849.09
	4/15/20 16:02	237.37	27.25	0.04	14.01	130.49	1167.36	1870.67
	4/15/20 16:03	237.80	27.41	0.04	13.74	133.25	1167.50	1905.93
	4/15/20 16:04	237.88	27.31	0.04	13.92	131.61	1167.54	1905.91
	4/15/20 16:05	237.57	27.32	0.04	13.84	141.31	1167.00	1891.81
	4/15/20 16:06	237.72	27.33	0.04	13.75	136.03	1167.15	1882.29
	4/15/20 16:07	237.89	27.39	0.04	13.77	135.51	1167.15	547.49
	4/15/20 16:08	237.67	27.47	0.04	13.91	141.64	1167.32	6.36
	4/15/20 16:09	237.90	27.32	0.04	13.47	137.26	1167.26	6.36
	4/15/20 16:10	237.45	27.32	0.04	13.85	134.92	1167.68	6.35
	4/15/20 16:11	237.95	27.36	0.04	13.67	141.60	1167.08	6.35
	4/15/20 16:12	237.50	27.39	0.04	13.55	141.60	1166.42	6.34
	4/15/20 16:13	237.35	27.43	0.04	14.13	140.48	1167.48	6.34
	4/15/20 16:14	237.78	27.34	0.04	14.10	142.79	1168.03	6.33
	4/15/20 16:15	237.18	27.31	0.04	13.61	139.85	1167.19	6.33
	4/15/20 16:16	237.20	27.39	0.04	13.58	140.67	1167.25	6.32
	4/15/20 16:17	237.51	27.39	0.04	14.15	137.50	1168.23	6.32
	4/15/20 16:18	236.94	27.35	0.04	13.73	135.17	1166.54	6.31
	4/15/20 16:19	237.34	27.35	0.04	13.81	129.50	1167.48	6.31
	4/15/20 16:20	237.21	27.35	0.04	13.76	127.76	1166.79	6.30
	4/15/20 16:21	237.38	27.36	0.04	13.92	125.22	1167.49	6.30
	4/15/20 16:22	237.08	27.37	0.04	13.73	124.27	1166.32	6.29
	4/15/20 16:23	237.45	27.38	0.04	13.72	130.50	1167.33	6.28
	4/15/20 16:24	237.42	27.35	0.04	13.60	128.92	1167.18	6.28
	4/15/20 16:25	237.54	27.31	0.04	13.69	123.39	1166.90	6.27
	4/15/20 16:26	237.61	27.35	0.04	13.61	125.00	1166.81	6.27
	4/15/20 16:27	237.23	27.38	0.04	13.74	129.18	1167.36	6.26
	4/15/20 16:28	237.32	27.36	0.04	13.77	136.73	1166.58	6.26
	4/15/20 16:29	237.17	27.32	0.04	13.74	129.84	1167.29	6.25
	4/15/20 16:30	237.20	27.30	0.04	13.78	129.16	1166.94	6.25
	4/15/20 16:31	237.36	27.32	0.04	13.98	132.21	1167.77	6.24
	4/15/20 16:32	237.20	27.39	0.04	13.64	134.48	1167.67	6.24
	4/15/20 16:33	237.14	27.30	0.04	13.84	131.06	1167.16	6.23
	4/15/20 16:34	237.12	27.32	0.04	14.00	134.20	1167.57	6.23
	4/15/20 16:35	237.41	27.31	0.04	13.63	133.51	1168.13	6.22
	4/15/20 16:36	237.63	27.38	0.04	14.25	132.48	1168.31	6.22
	4/15/20 16:37	237.69	27.38	0.04	13.88	136.35	1167.84	6.21
	4/15/20 16:38	237.47	27.36	0.04	13.76	128.66	1167.17	6.21
	4/15/20 16:39	237.95	27.32	0.04	13.89	135.11	1168.10	6.20
	4/15/20 16:40	237.55	27.38	0.04	13.76	129.14	1167.68	6.20
	4/15/20 16:41	236.86	27.38	0.04	13.59	133.94	1167.55	6.19
	4/15/20 16:42	237.51	27.36	0.04	13.86	130.51	1167.34	6.19
	4/15/20 16:43	237.27	27.34	0.04	13.74	134.51	1167.29	6.18
	4/15/20 16:44	237.55	27.34	0.04	14.12	131.23	1168.28	6.18
	4/15/20 16:45	237.60	27.37	0.04	13.80	127.61	1166.40	6.17
	4/15/20 16:46	237.93	27.32	0.04	13.82	137.32	1168.63	6.16
	4/15/20 16:47	237.77	27.33	0.04	13.83	131.70	1168.32	6.16
	4/15/20 16:48	237.65	27.27	0.04	13.55	131.41	1167.64	6.15
	4/15/20 16:49	237.74	27.33	0.04	13.80	140.20	1167.11	6.15
	4/15/20 16:50	237.54	27.34	0.04	13.82	139.51	1168.04	6.14
	4/15/20 16:51	237.58	27.31	0.04	13.85	128.65	1166.90	6.14
	4/15/20 16:52	237.65	27.28	0.04	13.77	131.50	1168.15	6.13
	4/15/20 16:53	237.63	27.33	0.04	13.94	132.23	1167.73	6.13
	4/15/20 16:54	237.65	27.33	0.04	14.09	135.63	1167.69	6.12
	4/15/20 16:55	237.35	27.38	0.04	13.61	140.51	1166.90	6.12
	4/15/20 16:56	237.19	27.25	0.04	13.70	138.18	1167.20	6.11
	4/15/20 16:57	237.51	27.25	0.04	13.81	150.76	1167.20	6.11
	4/15/20 16:58	237.69	27.29	0.04	13.83	155.34	1167.01	6.10
	4/15/20 16:59	237.14	27.33	0.04	13.68	146.95	1167.61	6.10
	4/15/20 17:00	237.73	27.20	0.04	13.77	150.38	1166.89	6.09
	4/15/20 17:01	237.76	27.26	0.04	13.70	136.45	1166.67	6.09
	4/15/20 17:02	237.48	27.35	0.04	13.65	142.58	1167.26	6.08
	4/15/20 17:03	237.28	27.40	0.04	13.53	135.15	1166.90	6.08
	4/15/20 17:04	237.51	27.19	0.04	13.59	136.10	1167.22	6.07
	4/15/20 17:05	237.55	27.29	0.04	13.68	133.68	1167.45	6.07

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 13:45 - 4/15 18:02)	237.40	27.35	0.04	13.80	135.92	1167.54	448.36
COUNT = 258							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 17:06	237.35	27.29	0.04	13.51	134.78	1166.77	6.06
4/15/20 17:07	237.73	27.29	0.04	13.60	129.89	1166.83	6.06
4/15/20 17:08	237.57	27.29	0.04	13.51	127.63	1167.38	6.05
4/15/20 17:09	237.65	27.30	0.04	13.99	124.67	1167.63	6.04
4/15/20 17:10	237.65	27.24	0.04	13.77	124.36	1167.32	6.04
4/15/20 17:11	237.35	27.24	0.04	13.97	138.33	1166.23	6.03
4/15/20 17:12	237.35	27.26	0.04	13.90	136.02	1167.44	6.03
4/15/20 17:13	237.64	27.33	0.04	13.81	142.91	1167.72	6.02
4/15/20 17:14	237.47	27.23	0.04	13.61	134.14	1167.40	6.02
4/15/20 17:15	237.23	27.27	0.04	13.79	142.41	1167.36	6.01
4/15/20 17:16	237.65	27.30	0.04	13.58	133.16	1166.98	6.01
4/15/20 17:17	237.39	27.29	0.04	13.71	143.40	1167.38	6.00
4/15/20 17:18	237.63	27.36	0.04	13.99	138.31	1167.52	6.00
4/15/20 17:19	237.75	27.32	0.04	13.96	133.53	1168.14	5.99
4/15/20 17:20	237.33	27.27	0.04	13.78	135.85	1167.15	5.99
4/15/20 17:21	238.20	27.32	0.04	13.77	131.74	1167.59	5.98
4/15/20 17:22	237.76	27.30	0.04	13.88	130.47	1167.85	5.98
4/15/20 17:23	237.66	27.35	0.04	13.88	130.16	1167.23	5.97
4/15/20 17:24	237.19	27.18	0.04	13.73	131.04	1166.87	5.97
4/15/20 17:25	237.77	27.21	0.04	13.72	140.59	1168.01	5.96
4/15/20 17:26	237.83	27.32	0.04	13.73	139.02	1166.64	5.96
4/15/20 17:27	237.48	27.25	0.04	13.75	136.28	1166.70	5.95
4/15/20 17:28	237.73	27.33	0.04	13.77	136.04	1167.40	5.95
4/15/20 17:29	237.38	27.22	0.04	13.97	140.20	1167.33	5.94
4/15/20 17:30	237.35	27.26	0.04	13.42	135.54	1167.19	5.94
4/15/20 17:31	237.49	27.35	0.04	13.99	144.22	1167.31	5.93
4/15/20 17:32	237.48	27.35	0.04	13.68	134.78	1166.79	5.92
4/15/20 17:33	238.14	27.31	0.04	13.95	139.11	1167.89	5.92
4/15/20 17:34	237.36	27.20	0.04	13.61	144.82	1166.85	5.91
4/15/20 17:35	237.48	27.29	0.04	13.77	146.73	1167.07	5.91
4/15/20 17:36	237.53	27.29	0.04	13.96	136.10	1167.20	5.90
4/15/20 17:37	237.29	27.23	0.04	13.73	144.16	1167.43	5.90
4/15/20 17:38	237.23	27.21	0.04	13.66	138.29	1166.75	5.89
4/15/20 17:39	237.37	27.20	0.04	13.68	139.60	1166.72	5.89
4/15/20 17:40	237.61	27.33	0.04	13.86	131.92	1167.18	5.88
4/15/20 17:41	236.92	27.25	0.04	13.98	135.94	1166.67	5.88
4/15/20 17:42	237.33	27.23	0.04	13.75	137.68	1167.50	5.87
4/15/20 17:43	237.63	27.23	0.04	13.71	126.94	1167.95	5.87
4/15/20 17:44	237.19	27.19	0.04	13.97	133.95	1167.22	5.86
4/15/20 17:45	237.38	27.21	0.04	14.11	159.13	1167.36	5.86
4/15/20 17:46	237.40	27.26	0.04	13.67	143.43	1167.30	5.85
4/15/20 17:47	237.32	27.17	0.04	13.79	153.28	1166.78	5.85
4/15/20 17:48	237.44	27.22	0.04	13.83	141.85	1167.82	5.84
4/15/20 17:49	236.73	27.24	0.04	13.73	151.07	1166.89	5.84
4/15/20 17:50	237.31	27.23	0.04	13.93	143.30	1167.27	5.83
4/15/20 17:51	237.22	27.24	0.04	14.00	137.72	1167.73	5.83
4/15/20 17:52	237.52	27.25	0.04	13.86	141.56	1167.66	5.82
4/15/20 17:53	237.69	27.23	0.04	13.89	128.37	1167.83	5.82
4/15/20 17:54	237.44	27.26	0.04	13.81	134.69	1167.54	5.81
4/15/20 17:55	236.96	27.23	0.04	13.99	135.00	1167.36	5.80
4/15/20 17:56	236.71	27.26	0.04	13.91	127.00	1167.11	5.80
4/15/20 17:57	237.30	27.23	0.04	13.73	136.62	1167.43	5.79
4/15/20 17:58	236.87	27.21	0.04	13.75	130.81	1167.87	5.79
4/15/20 17:59	236.80	27.19	0.04	14.02	133.55	1166.68	5.78
4/15/20 18:00	237.36	27.30	0.04	13.78	138.16	1167.88	5.78
4/15/20 18:01	237.38	27.24	0.04	13.78	132.84	1167.73	5.77
4/15/20 18:02	237.35	27.16	0.04	13.79	131.89	1167.09	5.77

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 6:46 - 4/16 11:15)		242.37	28.02	0.00	13.80	153.49	1174.44	3.72
COUNT = 270								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 6:46	242.59	27.80	0.00	13.71	160.84	1172.17	3.78
	4/16/20 6:47	242.78	27.89	0.00	13.77	160.90	1172.43	3.78
	4/16/20 6:48	242.49	27.93	0.00	13.88	161.01	1172.44	3.78
	4/16/20 6:49	242.75	27.94	0.00	13.94	166.77	1172.44	3.78
	4/16/20 6:50	242.75	27.96	0.00	13.79	164.72	1172.16	3.78
	4/16/20 6:51	242.50	27.91	0.00	13.55	157.99	1171.62	3.78
	4/16/20 6:52	242.38	27.80	0.00	13.86	167.80	1173.10	3.78
	4/16/20 6:53	242.55	28.02	0.00	13.93	192.86	1172.61	3.78
	4/16/20 6:54	242.78	28.01	0.00	13.82	179.35	1172.69	3.78
	4/16/20 6:55	242.88	27.90	0.00	13.98	169.24	1173.05	3.78
	4/16/20 6:56	242.72	27.85	0.00	13.72	170.42	1171.94	3.78
	4/16/20 6:57	242.61	27.93	0.00	13.56	172.84	1173.00	3.78
	4/16/20 6:58	242.57	27.94	0.00	13.75	166.65	1173.06	3.78
	4/16/20 6:59	242.56	27.88	0.00	13.27	168.75	1172.32	3.78
	4/16/20 7:00	242.36	27.90	0.00	13.80	151.33	1171.90	3.78
	4/16/20 7:01	242.72	27.94	0.00	13.55	155.05	1172.63	3.78
	4/16/20 7:02	242.72	27.98	0.00	13.81	160.87	1173.12	3.78
	4/16/20 7:03	242.51	28.00	0.00	13.74	143.95	1172.62	3.78
	4/16/20 7:04	243.13	27.88	0.00	13.76	159.21	1173.58	3.78
	4/16/20 7:05	242.74	27.89	0.00	13.66	144.48	1172.46	3.77
	4/16/20 7:06	242.73	27.94	0.00	13.92	157.17	1173.16	3.77
	4/16/20 7:07	243.06	27.99	0.00	14.25	152.90	1174.48	3.77
	4/16/20 7:08	242.72	27.92	0.00	13.85	156.65	1173.96	3.77
	4/16/20 7:09	242.73	27.86	0.00	13.94	150.56	1173.82	3.77
	4/16/20 7:10	243.10	27.94	0.00	13.72	158.55	1173.86	3.77
	4/16/20 7:11	242.50	27.98	0.00	13.66	145.37	1173.59	3.77
	4/16/20 7:12	242.91	27.96	0.00	14.05	155.82	1174.27	3.77
	4/16/20 7:13	242.75	27.88	0.00	13.69	162.52	1173.74	3.77
	4/16/20 7:14	242.81	27.84	0.00	13.69	151.14	1173.70	3.77
	4/16/20 7:15	242.66	28.00	0.00	13.80	153.51	1173.42	3.77
	4/16/20 7:16	242.71	28.00	0.00	14.02	156.27	1174.35	3.77
	4/16/20 7:17	243.08	27.94	0.00	13.89	148.01	1173.73	3.77
	4/16/20 7:18	242.76	27.94	0.00	13.69	158.51	1173.22	3.77
	4/16/20 7:19	242.82	27.97	0.00	13.69	161.15	1173.81	3.77
	4/16/20 7:20	242.87	27.91	0.00	13.84	161.43	1172.73	3.77
	4/16/20 7:21	242.72	27.90	0.00	13.60	150.22	1172.56	3.77
	4/16/20 7:22	242.76	27.93	0.00	13.80	154.96	1173.63	3.77
	4/16/20 7:23	242.82	27.99	0.00	13.74	161.38	1173.03	3.77
	4/16/20 7:24	242.60	27.97	0.00	13.81	149.84	1174.09	3.77
	4/16/20 7:25	243.02	28.00	0.00	13.75	158.33	1174.16	3.77
	4/16/20 7:26	242.10	28.00	0.00	13.68	175.21	1172.63	3.77
	4/16/20 7:27	242.94	27.91	0.00	13.89	178.53	1173.87	3.77
	4/16/20 7:28	242.57	27.93	0.00	13.57	160.99	1172.86	3.77
	4/16/20 7:29	243.17	28.02	0.00	14.09	173.62	1174.62	3.77
	4/16/20 7:30	242.73	28.02	0.00	13.87	160.83	1173.85	3.77
	4/16/20 7:31	243.02	27.90	0.00	13.53	159.21	1174.58	3.77
	4/16/20 7:32	242.64	27.93	0.00	13.76	163.11	1173.87	3.77
	4/16/20 7:33	242.77	28.02	0.00	14.01	163.90	1174.33	3.77
	4/16/20 7:34	242.90	28.05	0.00	14.07	150.76	1174.60	3.77
	4/16/20 7:35	242.76	27.93	0.00	13.49	159.71	1174.02	3.76
	4/16/20 7:36	242.96	27.86	0.00	13.69	158.21	1173.28	3.76
	4/16/20 7:37	242.67	27.88	0.00	13.45	154.59	1173.71	3.76
	4/16/20 7:38	242.72	28.00	0.00	13.75	156.93	1173.59	3.76
	4/16/20 7:39	243.18	27.92	0.00	14.00	144.95	1174.20	3.76
	4/16/20 7:40	242.80	27.91	0.00	13.80	157.27	1173.62	3.76
	4/16/20 7:41	242.68	27.94	0.00	13.75	159.58	1173.77	3.76
	4/16/20 7:42	243.09	27.96	0.00	13.88	161.07	1174.23	3.76
	4/16/20 7:43	242.82	27.97	0.00	14.02	157.70	1174.36	3.76
	4/16/20 7:44	242.81	27.85	0.00	13.73	148.90	1174.63	3.76
	4/16/20 7:45	243.00	27.95	0.00	13.95	149.36	1174.50	3.76
	4/16/20 7:46	242.42	27.96	0.00	13.65	152.51	1173.55	3.76
	4/16/20 7:47	242.66	27.97	0.00	13.66	158.80	1173.76	3.76
	4/16/20 7:48	242.60	27.94	0.00	13.80	160.75	1173.44	3.76
	4/16/20 7:49	242.97	27.84	0.00	13.72	151.10	1174.33	3.76
	4/16/20 7:50	242.94	27.90	0.00	13.69	153.22	1173.47	3.76
	4/16/20 7:51	242.43	27.93	0.00	13.88	163.48	1173.82	3.76
	4/16/20 7:52	242.89	27.99	0.00	13.84	147.90	1174.33	3.76

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 6:46 - 4/16 11:15)		242.37	28.02	0.00	13.80	153.49	1174.44	3.72
COUNT = 270								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 7:53	242.59	27.95	0.00	13.89	160.55	1173.48	3.76
	4/16/20 7:54	242.94	27.94	0.00	13.86	163.97	1174.92	3.76
	4/16/20 7:55	242.56	27.96	0.00	13.78	158.44	1172.52	3.76
	4/16/20 7:56	242.59	27.98	0.00	13.88	149.10	1173.95	3.76
	4/16/20 7:57	242.83	28.01	0.00	13.67	161.52	1175.12	3.76
	4/16/20 7:58	242.68	27.91	0.00	13.85	156.34	1174.25	3.76
	4/16/20 7:59	242.76	27.92	0.00	13.65	148.28	1174.01	3.75
	4/16/20 8:00	242.84	27.97	0.00	14.04	147.06	1174.62	3.75
	4/16/20 8:01	243.05	27.97	0.00	13.74	159.99	1174.04	3.75
	4/16/20 8:02	242.49	27.85	0.00	13.87	157.30	1174.41	3.75
	4/16/20 8:03	242.75	27.86	0.00	13.52	161.73	1174.21	3.75
	4/16/20 8:04	243.02	27.95	0.00	13.63	159.72	1174.89	3.75
	4/16/20 8:05	243.00	28.01	0.00	13.82	147.60	1174.74	3.75
	4/16/20 8:06	242.81	27.88	0.00	13.72	150.85	1174.75	3.75
	4/16/20 8:07	242.65	27.87	0.00	13.99	159.68	1173.72	3.75
	4/16/20 8:08	242.60	27.89	0.00	13.59	148.93	1175.14	3.75
	4/16/20 8:09	242.78	27.96	0.00	13.64	149.88	1174.24	3.75
	4/16/20 8:10	242.86	27.95	0.00	14.07	159.29	1174.36	3.75
	4/16/20 8:11	242.90	27.80	0.00	13.99	162.79	1174.64	3.75
	4/16/20 8:12	242.78	27.84	0.00	13.77	162.01	1174.19	3.75
	4/16/20 8:13	242.58	27.79	0.00	13.70	157.28	1173.83	3.75
	4/16/20 8:14	242.45	27.89	0.00	13.81	149.12	1174.15	3.75
	4/16/20 8:15	242.48	27.86	0.00	13.85	162.16	1173.58	3.75
	4/16/20 8:16	242.75	27.83	0.00	13.91	162.25	1174.83	3.75
	4/16/20 8:17	242.99	27.84	0.00	13.66	183.51	1175.12	3.75
	4/16/20 8:18	243.01	27.91	0.00	13.69	172.89	1174.59	3.75
	4/16/20 8:19	243.08	27.92	0.00	13.60	168.78	1174.41	3.74
	4/16/20 8:20	242.75	27.81	0.00	13.96	175.03	1174.61	3.74
	4/16/20 8:21	242.44	27.85	0.00	13.68	168.28	1174.51	3.74
	4/16/20 8:22	242.88	27.82	0.00	13.89	169.55	1174.60	3.74
	4/16/20 8:23	242.36	27.91	0.00	13.78	157.34	1174.26	3.74
	4/16/20 8:24	242.62	27.90	0.00	13.70	164.91	1174.90	3.74
	4/16/20 8:25	242.71	27.86	0.00	13.63	145.58	1174.17	3.74
	4/16/20 8:26	242.63	27.86	0.00	13.87	154.05	1174.90	3.74
	4/16/20 8:27	242.63	27.97	0.00	13.89	157.14	1174.81	3.74
	4/16/20 8:28	242.60	27.94	0.00	13.61	143.09	1174.40	3.74
	4/16/20 8:29	242.42	27.88	0.00	13.89	152.86	1174.53	3.74
	4/16/20 8:30	242.20	27.85	0.00	13.66	148.22	1174.26	3.74
	4/16/20 8:31	242.52	27.89	0.00	13.95	150.47	1174.66	3.74
	4/16/20 8:32	242.35	28.00	0.00	14.05	146.21	1174.29	3.74
	4/16/20 8:33	242.75	27.99	0.00	13.83	142.91	1174.24	3.74
	4/16/20 8:34	242.45	27.87	0.00	13.50	148.39	1174.06	3.74
	4/16/20 8:35	242.63	27.90	0.00	13.78	147.53	1174.28	3.74
	4/16/20 8:36	242.58	28.01	0.00	13.73	141.35	1174.80	3.74
	4/16/20 8:37	242.20	28.11	0.00	14.05	154.99	1174.23	3.74
	4/16/20 8:38	242.18	27.99	0.00	13.60	148.08	1174.26	3.74
	4/16/20 8:39	242.56	27.99	0.00	13.85	148.32	1174.65	3.73
	4/16/20 8:40	242.51	28.08	0.00	14.06	156.09	1174.74	3.73
	4/16/20 8:41	242.40	28.03	0.00	13.99	147.67	1174.73	3.73
	4/16/20 8:42	242.91	28.04	0.00	13.94	144.12	1175.62	3.73
	4/16/20 8:43	242.69	27.95	0.00	13.88	149.10	1175.12	3.73
	4/16/20 8:44	242.51	28.05	0.00	13.86	156.77	1173.88	3.73
	4/16/20 8:45	242.66	28.08	0.00	14.07	158.38	1174.65	3.73
	4/16/20 8:46	242.47	28.13	0.00	13.76	151.76	1173.72	3.73
	4/16/20 8:47	242.40	28.00	0.00	14.10	150.95	1175.10	3.73
	4/16/20 8:48	242.60	28.05	0.00	13.79	148.09	1174.57	3.73
	4/16/20 8:49	242.55	28.14	0.00	13.80	151.88	1174.94	3.73
	4/16/20 8:50	242.46	28.13	0.00	13.57	156.41	1173.96	3.73
	4/16/20 8:51	242.42	28.03	0.00	13.66	155.07	1175.25	3.73
	4/16/20 8:52	242.12	28.08	0.00	13.71	145.00	1175.13	3.73
	4/16/20 8:53	242.15	28.09	0.00	13.68	139.13	1174.33	3.73
	4/16/20 8:54	242.40	28.10	0.00	14.04	150.24	1175.01	3.73
	4/16/20 8:55	241.98	28.02	0.00	13.83	137.82	1173.90	3.73
	4/16/20 8:56	242.60	27.96	0.00	13.83	141.35	1174.46	3.73
	4/16/20 8:57	242.41	28.07	0.00	13.70	152.49	1174.69	3.73
	4/16/20 8:58	242.48	28.19	0.00	13.85	146.42	1174.38	3.73
	4/16/20 8:59	242.28	28.04	0.00	13.53	140.57	1173.93	3.72

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 6:46 - 4/16 11:15)		242.37	28.02	0.00	13.80	153.49	1174.44	3.72
COUNT = 270								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 9:00	242.91	28.02	0.00	13.86	148.89	1174.92	3.72
	4/16/20 9:01	242.39	28.09	0.00	13.66	152.63	1174.44	3.72
	4/16/20 9:02	242.29	28.13	0.00	13.69	156.81	1174.38	3.72
	4/16/20 9:03	242.47	28.17	0.00	13.85	153.59	1174.36	3.72
	4/16/20 9:04	242.29	28.07	0.00	13.53	147.32	1174.12	3.72
	4/16/20 9:05	242.55	28.08	0.00	13.79	150.17	1174.14	3.72
	4/16/20 9:06	242.34	28.05	0.00	13.87	158.59	1174.98	3.72
	4/16/20 9:07	242.45	28.14	0.00	13.94	153.17	1176.03	3.72
	4/16/20 9:08	242.27	28.12	0.00	14.43	143.48	1175.70	3.72
	4/16/20 9:09	242.26	28.03	0.00	14.10	154.71	1174.71	3.72
	4/16/20 9:10	242.27	28.05	0.00	13.63	154.30	1174.50	3.72
	4/16/20 9:11	242.29	28.09	0.00	13.78	146.94	1174.98	3.72
	4/16/20 9:12	242.29	28.11	0.00	14.32	144.03	1175.34	3.72
	4/16/20 9:13	242.12	28.09	0.00	13.84	141.96	1174.34	3.72
	4/16/20 9:14	242.07	28.04	0.00	13.76	143.65	1174.08	3.72
	4/16/20 9:15	242.88	28.13	0.00	13.98	171.54	1175.47	3.72
	4/16/20 9:16	242.64	28.20	0.00	14.12	158.67	1175.23	3.72
	4/16/20 9:17	242.25	28.14	0.00	13.81	160.13	1174.65	3.72
	4/16/20 9:18	242.28	28.10	0.00	13.71	160.02	1174.63	3.71
	4/16/20 9:19	242.18	28.11	0.00	13.79	163.11	1174.88	3.71
	4/16/20 9:20	242.33	28.18	0.00	13.62	146.94	1174.90	3.71
	4/16/20 9:21	242.05	28.15	0.00	14.14	150.49	1175.78	3.71
	4/16/20 9:22	242.46	28.14	0.00	14.01	156.70	1174.92	3.71
	4/16/20 9:23	242.09	28.08	0.00	13.84	151.81	1174.93	3.71
	4/16/20 9:24	242.21	28.12	0.00	13.86	148.18	1174.05	3.71
	4/16/20 9:25	242.37	28.14	0.00	14.15	146.53	1175.08	3.71
	4/16/20 9:26	242.60	28.11	0.00	13.86	146.97	1174.80	3.71
	4/16/20 9:27	242.27	28.12	0.00	13.62	140.54	1174.38	3.71
	4/16/20 9:28	242.39	28.12	0.00	13.66	145.36	1175.27	3.71
	4/16/20 9:29	241.94	28.15	0.00	13.58	140.84	1174.16	3.71
	4/16/20 9:30	242.06	28.11	0.00	13.77	144.98	1174.43	3.71
	4/16/20 9:31	242.43	28.04	0.00	14.10	152.74	1174.90	3.71
	4/16/20 9:32	242.60	28.03	0.00	13.80	152.09	1174.84	3.71
	4/16/20 9:33	242.56	28.21	0.00	13.95	149.37	1174.79	3.71
	4/16/20 9:34	242.62	28.17	0.00	13.79	148.69	1175.52	3.71
	4/16/20 9:35	242.29	28.02	0.00	13.89	148.89	1174.95	3.71
	4/16/20 9:36	242.44	28.04	0.00	13.68	155.92	1174.50	3.71
	4/16/20 9:37	242.25	28.09	0.00	13.95	152.00	1174.49	3.71
	4/16/20 9:38	242.49	28.11	0.00	13.84	145.21	1175.42	3.70
	4/16/20 9:39	242.02	28.08	0.00	13.68	146.30	1174.32	3.70
	4/16/20 9:40	242.14	28.08	0.00	14.04	144.45	1175.45	3.70
	4/16/20 9:41	242.32	28.15	0.00	13.73	145.29	1175.12	3.70
	4/16/20 9:42	242.23	28.17	0.00	13.48	145.79	1174.64	3.70
	4/16/20 9:43	242.90	28.17	0.00	13.90	150.15	1175.57	3.70
	4/16/20 9:44	242.55	28.00	0.00	13.76	153.58	1175.46	3.70
	4/16/20 9:45	242.36	28.07	0.00	13.91	155.16	1174.68	3.70
	4/16/20 9:46	242.07	28.18	0.00	13.73	156.89	1174.29	3.70
	4/16/20 9:47	242.28	28.16	0.00	13.80	147.56	1174.93	3.70
	4/16/20 9:48	241.96	28.03	0.00	13.71	148.70	1174.44	3.70
	4/16/20 9:49	242.33	28.11	0.00	14.05	152.81	1175.40	3.70
	4/16/20 9:50	242.43	28.07	0.00	14.01	152.27	1174.75	3.70
	4/16/20 9:51	242.62	28.19	0.00	14.18	148.49	1175.11	3.70
	4/16/20 9:52	241.96	28.16	0.00	13.97	149.39	1174.11	3.70
	4/16/20 9:53	242.35	28.06	0.00	13.70	155.69	1175.10	3.70
	4/16/20 9:54	242.11	28.13	0.00	13.61	148.93	1174.34	3.70
	4/16/20 9:55	242.26	28.16	0.00	13.92	142.85	1174.89	3.70
	4/16/20 9:56	242.36	28.15	0.00	13.75	142.17	1175.21	3.70
	4/16/20 9:57	242.37	28.06	0.00	13.78	143.73	1175.21	3.70
	4/16/20 9:58	242.29	28.12	0.00	14.07	151.29	1174.82	3.69
	4/16/20 9:59	242.20	28.21	0.00	13.77	154.39	1174.68	3.69
	4/16/20 10:00	242.53	28.18	0.00	14.18	155.14	1175.50	3.69
	4/16/20 10:01	242.61	28.01	0.00	13.55	149.86	1174.89	3.69
	4/16/20 10:02	242.27	28.06	0.00	13.60	148.60	1174.69	3.69
	4/16/20 10:03	242.51	28.13	0.00	13.95	155.86	1175.88	3.69
	4/16/20 10:04	242.23	28.08	0.00	13.70	154.27	1174.95	3.69
	4/16/20 10:05	242.54	28.11	0.00	13.72	153.03	1174.17	3.69
	4/16/20 10:06	242.34	28.06	0.00	13.57	146.30	1174.69	3.69

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 6:46 - 4/16 11:15)	242.37	28.02	0.00	13.80	153.49	1174.44	3.72
COUNT = 270							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 10:07	242.08	28.05	0.00	13.71	150.97	1173.62	3.69
4/16/20 10:08	242.53	28.19	0.00	13.56	159.28	1173.93	3.69
4/16/20 10:09	242.54	28.14	0.00	13.79	161.56	1175.55	3.69
4/16/20 10:10	242.27	28.12	0.00	13.79	156.07	1175.38	3.69
4/16/20 10:11	242.20	28.08	0.00	13.91	157.32	1174.81	3.69
4/16/20 10:12	242.13	28.15	0.00	13.72	147.69	1174.76	3.69
4/16/20 10:13	242.48	28.18	0.00	13.57	147.90	1174.67	3.69
4/16/20 10:14	242.21	28.16	0.00	13.86	147.19	1174.20	3.69
4/16/20 10:15	242.23	28.08	0.00	13.62	149.26	1174.10	3.69
4/16/20 10:16	242.26	28.07	0.00	13.59	149.00	1174.61	3.69
4/16/20 10:17	242.38	28.18	0.00	13.97	146.26	1174.91	3.68
4/16/20 10:18	242.15	28.15	0.00	13.70	144.01	1174.27	3.68
4/16/20 10:19	242.13	28.07	0.00	13.74	153.52	1174.50	3.68
4/16/20 10:20	242.03	28.08	0.00	13.73	156.19	1174.81	3.68
4/16/20 10:21	242.36	28.16	0.00	13.76	156.35	1174.89	3.68
4/16/20 10:22	242.36	28.19	0.00	13.61	149.85	1175.13	3.68
4/16/20 10:23	242.22	28.10	0.00	13.94	142.62	1175.23	3.68
4/16/20 10:24	242.35	28.13	0.00	13.94	143.61	1175.01	3.68
4/16/20 10:25	242.59	28.10	0.00	13.90	145.17	1175.28	3.68
4/16/20 10:26	242.14	28.17	0.00	13.75	152.75	1175.03	3.68
4/16/20 10:27	242.35	28.11	0.00	13.87	154.70	1175.75	3.68
4/16/20 10:28	242.42	28.13	0.00	13.85	161.21	1175.66	3.68
4/16/20 10:29	242.38	28.11	0.00	14.12	175.48	1175.95	3.68
4/16/20 10:30	241.76	28.10	0.00	13.94	160.82	1175.46	3.68
4/16/20 10:31	241.94	28.12	0.00	13.49	159.06	1174.40	3.68
4/16/20 10:32	241.75	28.06	0.00	13.79	163.41	1175.37	3.68
4/16/20 10:33	241.82	28.00	0.00	13.74	155.01	1174.71	3.68
4/16/20 10:34	241.91	28.15	0.00	13.89	151.64	1175.18	3.68
4/16/20 10:35	241.79	28.13	0.00	13.69	146.14	1174.65	3.68
4/16/20 10:36	241.96	28.06	0.00	13.80	153.30	1175.05	3.68
4/16/20 10:37	242.06	28.04	0.00	13.71	147.98	1175.39	3.67
4/16/20 10:38	241.76	28.06	0.00	13.47	139.12	1175.15	3.67
4/16/20 10:39	241.86	28.13	0.00	13.90	146.59	1175.73	3.67
4/16/20 10:40	241.73	28.20	0.00	13.65	138.29	1174.42	3.67
4/16/20 10:41	241.51	28.06	0.00	14.16	133.80	1175.79	3.67
4/16/20 10:42	241.99	28.06	0.00	13.73	138.57	1174.56	3.67
4/16/20 10:43	241.82	28.03	0.00	13.70	147.34	1175.04	3.67
4/16/20 10:44	241.76	28.11	0.00	13.47	148.05	1175.04	3.67
4/16/20 10:45	241.52	28.07	0.00	13.68	150.13	1174.27	3.67
4/16/20 10:46	241.57	28.08	0.00	13.49	143.67	1174.74	3.67
4/16/20 10:47	241.99	28.09	0.00	13.73	146.67	1175.12	3.67
4/16/20 10:48	241.91	28.11	0.00	13.89	141.24	1175.18	3.67
4/16/20 10:49	241.30	28.07	0.00	13.78	153.10	1174.79	3.67
4/16/20 10:50	241.41	28.01	0.00	13.81	150.10	1174.45	3.67
4/16/20 10:51	241.35	28.10	0.00	13.89	144.13	1175.42	3.67
4/16/20 10:52	241.75	28.14	0.00	13.85	142.14	1174.84	3.67
4/16/20 10:53	241.37	28.03	0.00	13.83	142.69	1174.68	3.67
4/16/20 10:54	241.33	28.03	0.00	13.70	141.97	1175.00	3.67
4/16/20 10:55	241.43	28.07	0.00	13.97	146.87	1175.81	3.67
4/16/20 10:56	241.68	28.13	0.00	13.80	147.34	1174.61	3.67
4/16/20 10:57	241.36	28.10	0.00	13.90	148.09	1174.95	3.66
4/16/20 10:58	241.15	28.04	0.00	13.97	149.10	1174.66	3.66
4/16/20 10:59	241.72	28.03	0.00	13.95	147.19	1175.36	3.66
4/16/20 11:00	242.06	28.08	0.00	13.79	150.79	1175.36	3.66
4/16/20 11:01	241.14	28.10	0.00	13.57	149.75	1174.98	3.66
4/16/20 11:02	241.57	28.10	0.00	14.02	148.92	1175.68	3.66
4/16/20 11:03	241.52	28.06	0.00	13.76	147.52	1175.07	3.66
4/16/20 11:04	241.58	28.04	0.00	13.84	154.84	1175.15	3.66
4/16/20 11:05	241.12	28.10	0.00	13.76	155.19	1175.44	3.66
4/16/20 11:06	241.81	28.18	0.00	13.93	161.72	1175.41	3.66
4/16/20 11:07	241.45	28.05	0.00	13.83	163.25	1175.33	3.66
4/16/20 11:08	241.33	28.01	0.00	13.82	167.82	1175.69	3.66
4/16/20 11:09	240.98	28.06	0.00	13.95	162.44	1175.68	3.66
4/16/20 11:10	240.67	28.11	0.00	13.76	157.60	1174.98	3.66
4/16/20 11:11	241.32	28.04	0.00	13.59	151.04	1174.78	3.66
4/16/20 11:12	241.13	27.99	0.00	13.73	151.78	1175.45	3.66
4/16/20 11:13	241.40	28.11	0.00	13.77	141.99	1174.71	3.66

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 6:46 - 4/16 11:15)	242.37	28.02	0.00	13.80	153.49	1174.44	3.72
COUNT = 270							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 11:14	241.46	28.13	0.00	13.98	134.98	1175.18	3.66
4/16/20 11:15	241.34	28.01	0.00	13.81	137.81	1175.17	3.66

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
SAM

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 13:56 - 4/15 15:56)	237.34	27.38	0.04	13.82	135.54	1167.73	790.75
COUNT = 121							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 13:56	236.95	27.42	0.04	13.74	132.48	1167.66	3.78
4/15/20 13:57	237.32	27.45	0.04	13.72	135.90	1168.10	3.78
4/15/20 13:58	237.39	27.40	0.04	13.94	149.02	1167.12	3.78
4/15/20 13:59	236.68	27.39	0.04	13.62	139.59	1167.18	3.78
4/15/20 14:00	236.97	27.43	0.04	13.91	142.03	1166.78	3.78
4/15/20 14:01	237.25	27.48	0.04	13.80	146.52	1167.63	3.78
4/15/20 14:02	237.21	27.43	0.04	13.84	135.82	1166.80	3.77
4/15/20 14:03	237.69	27.48	0.04	13.78	140.45	1167.74	3.77
4/15/20 14:04	237.23	27.39	0.04	13.76	140.88	1167.47	3.77
4/15/20 14:05	237.26	27.40	0.04	13.62	132.97	1167.80	3.77
4/15/20 14:06	237.51	27.55	0.04	13.91	139.69	1168.06	3.77
4/15/20 14:07	237.45	27.46	0.04	13.72	133.09	1167.44	3.77
4/15/20 14:08	237.27	27.42	0.04	13.78	130.99	1167.23	3.77
4/15/20 14:09	236.91	27.44	0.04	13.69	130.46	1166.80	3.77
4/15/20 14:10	237.18	27.39	0.04	13.83	130.35	1167.55	3.77
4/15/20 14:11	237.11	27.43	0.04	13.93	133.85	1166.85	3.77
4/15/20 14:12	237.27	27.42	0.04	13.81	135.13	1166.93	3.77
4/15/20 14:13	236.55	27.44	0.04	14.22	134.52	1167.35	3.77
4/15/20 14:14	236.87	27.39	0.04	13.49	131.80	1167.02	3.76
4/15/20 14:15	236.82	27.43	0.04	13.61	126.88	1167.51	3.76
4/15/20 14:16	236.82	27.41	0.04	14.10	131.74	1166.90	3.76
4/15/20 14:17	236.40	27.41	0.04	13.84	129.33	1166.46	3.76
4/15/20 14:18	236.62	27.39	0.04	13.84	125.65	1167.04	3.76
4/15/20 14:19	236.59	27.37	0.04	13.49	125.14	1167.67	3.76
4/15/20 14:20	236.51	27.46	0.04	13.83	128.16	1166.99	3.76
4/15/20 14:21	236.84	27.41	0.04	14.04	124.10	1167.50	3.76
4/15/20 14:22	237.02	27.40	0.04	13.73	127.90	1166.81	3.76
4/15/20 14:23	237.24	27.35	0.04	13.58	128.12	1167.25	3.76
4/15/20 14:24	237.12	27.49	0.04	13.87	134.41	1167.78	3.76
4/15/20 14:25	236.20	27.36	0.04	13.74	131.64	1166.39	3.76
4/15/20 14:26	236.62	27.32	0.04	13.73	137.11	1166.24	3.76
4/15/20 14:27	236.28	27.37	0.04	14.15	139.22	1168.14	3.75
4/15/20 14:28	236.61	27.40	0.04	13.84	131.92	1167.90	3.75
4/15/20 14:29	236.56	27.40	0.04	13.63	139.37	1166.31	3.75
4/15/20 14:30	236.42	27.36	0.04	13.66	128.99	1166.79	3.75
4/15/20 14:31	236.27	27.33	0.04	13.78	133.56	1167.06	3.75
4/15/20 14:32	236.72	27.36	0.04	14.05	136.44	1167.33	3.75
4/15/20 14:33	236.26	27.42	0.04	13.53	127.98	1167.03	3.75
4/15/20 14:34	236.76	27.38	0.04	13.67	125.99	1167.82	3.75
4/15/20 14:35	236.39	27.36	0.04	13.99	133.97	1167.20	3.75
4/15/20 14:36	236.31	27.32	0.04	13.69	130.99	1167.04	3.75
4/15/20 14:37	237.02	27.40	0.04	14.03	128.59	1167.60	3.75
4/15/20 14:38	237.06	27.39	0.04	14.17	129.87	1168.01	3.75
4/15/20 14:39	236.85	27.31	0.04	13.84	130.07	1168.24	3.75
4/15/20 14:40	236.76	27.31	0.04	13.81	130.88	1167.30	3.74
4/15/20 14:41	237.37	27.40	0.04	13.72	131.84	1167.88	3.74
4/15/20 14:42	237.54	27.31	0.04	14.17	134.17	1169.57	3.74
4/15/20 14:43	237.40	27.38	0.04	13.69	136.85	1166.84	3.74
4/15/20 14:44	237.34	27.38	0.04	13.92	136.85	1167.62	3.74
4/15/20 14:45	237.15	27.37	0.04	13.55	137.90	1167.67	3.74
4/15/20 14:46	236.93	27.33	0.04	13.74	131.37	1167.89	3.74
4/15/20 14:47	237.70	27.37	0.04	13.87	129.58	1168.39	3.74
4/15/20 14:48	236.78	27.45	0.04	13.90	129.19	1167.24	3.74
4/15/20 14:49	236.99	27.24	0.04	13.70	138.72	1167.33	540.40
4/15/20 14:50	237.13	27.35	0.04	13.86	128.88	1167.98	609.73
4/15/20 14:51	237.47	27.44	0.04	13.98	126.78	1167.68	648.18
4/15/20 14:52	237.34	27.37	0.04	13.67	134.85	1167.64	691.31
4/15/20 14:53	237.56	27.32	0.04	13.65	128.82	1167.97	748.24
4/15/20 14:54	237.08	27.33	0.04	13.72	130.39	1167.81	797.79
4/15/20 14:55	237.51	27.42	0.04	13.90	128.29	1167.94	853.61
4/15/20 14:56	236.86	27.39	0.04	13.87	137.29	1168.04	902.71
4/15/20 14:57	237.29	27.37	0.04	13.93	135.08	1168.39	947.99
4/15/20 14:58	236.92	27.45	0.04	13.75	134.03	1167.67	1011.59
4/15/20 14:59	237.59	27.25	0.04	13.93	131.57	1168.33	1070.11
4/15/20 15:00	237.75	27.42	0.04	14.25	127.11	1168.73	1129.20
4/15/20 15:01	237.62	27.43	0.04	14.14	131.54	1169.23	1187.93
4/15/20 15:02	237.97	27.38	0.04	13.80	135.04	1168.70	1261.64

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 13:56 - 4/15 15:56)	237.34	27.38	0.04	13.82	135.54	1167.73	790.75
COUNT = 121							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/15/20 15:03	237.52	27.35	0.04	14.04	136.57	1168.62	1210.41
4/15/20 15:04	237.30	27.41	0.04	13.66	136.15	1167.51	1081.46
4/15/20 15:05	237.70	27.41	0.04	14.10	140.71	1167.58	1013.81
4/15/20 15:06	237.62	27.35	0.04	13.88	139.73	1168.12	952.65
4/15/20 15:07	237.70	27.35	0.04	13.54	133.27	1167.80	908.23
4/15/20 15:08	237.99	27.38	0.04	13.81	132.47	1168.44	834.77
4/15/20 15:09	237.54	27.46	0.04	13.99	130.15	1168.49	794.18
4/15/20 15:10	237.35	27.42	0.04	13.75	131.10	1168.00	730.29
4/15/20 15:11	237.81	27.39	0.04	13.48	133.34	1168.44	690.96
4/15/20 15:12	237.87	27.36	0.04	13.94	140.79	1168.43	651.64
4/15/20 15:13	238.03	27.35	0.04	13.87	139.19	1169.40	680.23
4/15/20 15:14	237.92	27.45	0.04	13.85	133.82	1168.71	783.51
4/15/20 15:15	237.69	27.38	0.04	13.87	137.28	1168.33	850.10
4/15/20 15:16	237.83	27.40	0.04	13.81	133.06	1168.22	900.11
4/15/20 15:17	237.29	27.31	0.04	13.96	135.12	1167.89	959.22
4/15/20 15:18	237.85	27.42	0.04	13.93	129.19	1168.53	1039.73
4/15/20 15:19	237.77	27.44	0.04	13.88	135.94	1168.30	1095.10
4/15/20 15:20	237.74	27.39	0.04	13.89	127.68	1168.00	1158.64
4/15/20 15:21	237.76	27.34	0.04	13.82	135.01	1167.49	1216.38
4/15/20 15:22	237.87	27.37	0.04	13.51	130.35	1167.34	1296.81
4/15/20 15:23	238.24	27.44	0.04	14.10	132.96	1169.60	1347.24
4/15/20 15:24	237.97	27.38	0.04	13.61	134.75	1167.28	1403.85
4/15/20 15:25	237.57	27.37	0.04	13.67	136.42	1167.85	1475.28
4/15/20 15:26	238.13	27.37	0.04	13.83	133.67	1167.89	1527.54
4/15/20 15:27	238.71	27.38	0.04	13.88	141.59	1168.52	1564.75
4/15/20 15:28	238.04	27.46	0.04	13.73	133.92	1168.70	1618.81
4/15/20 15:29	237.60	27.37	0.04	13.82	173.71	1168.30	1713.15
4/15/20 15:30	238.00	27.35	0.04	13.62	187.33	1168.23	1727.20
4/15/20 15:31	237.96	27.38	0.04	14.04	180.61	1168.19	1850.32
4/15/20 15:32	237.79	27.42	0.04	13.81	170.98	1167.96	1886.19
4/15/20 15:33	238.07	27.37	0.04	14.13	164.48	1167.89	1902.55
4/15/20 15:34	237.68	27.34	0.04	13.84	163.04	1168.57	1953.86
4/15/20 15:35	237.70	27.29	0.04	13.91	151.97	1168.38	1840.89
4/15/20 15:36	238.18	27.34	0.04	13.76	148.63	1167.64	1814.19
4/15/20 15:37	238.56	27.49	0.04	13.82	139.05	1169.00	1874.69
4/15/20 15:38	237.64	27.32	0.04	13.69	135.41	1167.67	1938.40
4/15/20 15:39	238.11	27.30	0.04	13.91	130.86	1168.34	2002.92
4/15/20 15:40	238.14	27.37	0.04	13.93	131.47	1168.56	2039.57
4/15/20 15:41	237.75	27.48	0.04	13.66	126.57	1167.23	2105.81
4/15/20 15:42	237.19	27.32	0.04	13.82	125.57	1167.31	2154.46
4/15/20 15:43	237.75	27.32	0.04	13.62	125.58	1167.26	2216.29
4/15/20 15:44	237.76	27.34	0.04	13.81	127.78	1168.35	2247.23
4/15/20 15:45	237.86	27.44	0.04	13.81	125.88	1167.94	2275.57
4/15/20 15:46	237.11	27.43	0.04	13.80	126.39	1166.96	2182.75
4/15/20 15:47	237.27	27.30	0.04	13.55	127.08	1166.88	2101.45
4/15/20 15:48	237.17	27.35	0.04	13.78	131.83	1167.33	2066.55
4/15/20 15:49	237.48	27.32	0.04	13.98	134.16	1167.58	2054.37
4/15/20 15:50	237.36	27.42	0.04	13.71	139.01	1167.39	1996.12
4/15/20 15:51	237.52	27.38	0.04	13.99	139.74	1167.18	1940.55
4/15/20 15:52	237.29	27.26	0.04	13.80	141.18	1167.17	1900.39
4/15/20 15:53	237.49	27.31	0.04	13.93	132.90	1167.65	1912.97
4/15/20 15:54	237.43	27.39	0.04	13.88	139.05	1167.37	1863.70
4/15/20 15:55	237.54	27.39	0.04	13.91	129.39	1167.86	1884.71
4/15/20 15:56	237.79	27.38	0.04	13.53	136.19	1167.25	1848.92

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 6:24 - 4/16 8:24)		242.73	27.92	0.00	13.78	159.13	1173.46	3.77
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 6:24	242.59	27.85	0.00	13.53	156.73	1172.18	3.79
	4/16/20 6:25	242.35	27.82	0.00	13.43	170.06	1170.87	3.79
	4/16/20 6:26	242.77	27.92	0.00	13.56	156.13	1172.13	3.79
	4/16/20 6:27	242.54	27.90	0.00	13.81	170.23	1171.48	3.79
	4/16/20 6:28	242.51	27.90	0.00	13.77	153.97	1172.26	3.79
	4/16/20 6:29	242.46	27.91	0.00	13.75	164.40	1171.70	3.79
	4/16/20 6:30	242.57	27.86	0.00	13.96	150.44	1171.65	3.79
	4/16/20 6:31	242.80	27.97	0.00	13.88	160.57	1171.65	3.79
	4/16/20 6:32	242.60	27.87	0.00	13.51	146.38	1172.01	3.79
	4/16/20 6:33	242.51	27.89	0.00	13.76	162.24	1172.05	3.79
	4/16/20 6:34	242.41	27.88	0.00	13.68	147.16	1172.63	3.78
	4/16/20 6:35	242.71	27.89	0.00	13.84	157.89	1172.44	3.78
	4/16/20 6:36	242.40	27.94	0.00	13.75	160.56	1171.59	3.78
	4/16/20 6:37	242.77	27.95	0.00	13.58	146.76	1171.97	3.78
	4/16/20 6:38	242.73	27.94	0.00	13.91	152.84	1172.96	3.78
	4/16/20 6:39	242.63	27.89	0.00	13.58	160.62	1172.82	3.78
	4/16/20 6:40	242.57	28.00	0.00	13.85	163.24	1172.81	3.78
	4/16/20 6:41	242.59	27.92	0.00	13.55	149.76	1172.45	3.78
	4/16/20 6:42	242.92	27.91	0.00	13.49	161.17	1171.89	3.78
	4/16/20 6:43	242.83	27.91	0.00	14.15	159.35	1172.98	3.78
	4/16/20 6:44	242.78	27.99	0.00	14.08	157.39	1173.24	3.78
	4/16/20 6:45	242.68	27.97	0.00	14.30	168.67	1173.08	3.78
	4/16/20 6:46	242.59	27.80	0.00	13.71	160.84	1172.17	3.78
	4/16/20 6:47	242.78	27.89	0.00	13.77	160.90	1172.43	3.78
	4/16/20 6:48	242.49	27.93	0.00	13.88	161.01	1172.44	3.78
	4/16/20 6:49	242.75	27.94	0.00	13.94	166.77	1172.44	3.78
	4/16/20 6:50	242.75	27.96	0.00	13.79	164.72	1172.16	3.78
	4/16/20 6:51	242.50	27.91	0.00	13.55	157.99	1171.62	3.78
	4/16/20 6:52	242.38	27.80	0.00	13.86	167.80	1173.10	3.78
	4/16/20 6:53	242.55	28.02	0.00	13.93	192.86	1172.61	3.78
	4/16/20 6:54	242.78	28.01	0.00	13.82	179.35	1172.69	3.78
	4/16/20 6:55	242.88	27.90	0.00	13.98	169.24	1173.05	3.78
	4/16/20 6:56	242.72	27.85	0.00	13.72	170.42	1171.94	3.78
	4/16/20 6:57	242.61	27.93	0.00	13.56	172.84	1173.00	3.78
	4/16/20 6:58	242.57	27.94	0.00	13.75	166.65	1173.06	3.78
	4/16/20 6:59	242.56	27.88	0.00	13.27	168.75	1172.32	3.78
	4/16/20 7:00	242.36	27.90	0.00	13.80	151.33	1171.90	3.78
	4/16/20 7:01	242.72	27.94	0.00	13.55	155.05	1172.63	3.78
	4/16/20 7:02	242.72	27.98	0.00	13.81	160.87	1173.12	3.78
	4/16/20 7:03	242.51	28.00	0.00	13.74	143.95	1172.62	3.78
	4/16/20 7:04	243.13	27.88	0.00	13.76	159.21	1173.58	3.78
	4/16/20 7:05	242.74	27.89	0.00	13.66	144.48	1172.46	3.77
	4/16/20 7:06	242.73	27.94	0.00	13.92	157.17	1173.16	3.77
	4/16/20 7:07	243.06	27.99	0.00	14.25	152.90	1174.48	3.77
	4/16/20 7:08	242.72	27.92	0.00	13.85	156.65	1173.96	3.77
	4/16/20 7:09	242.73	27.86	0.00	13.94	150.56	1173.82	3.77
	4/16/20 7:10	243.10	27.94	0.00	13.72	158.55	1173.86	3.77
	4/16/20 7:11	242.50	27.98	0.00	13.66	145.37	1173.59	3.77
	4/16/20 7:12	242.91	27.96	0.00	14.05	155.82	1174.27	3.77
	4/16/20 7:13	242.75	27.88	0.00	13.69	162.52	1173.74	3.77
	4/16/20 7:14	242.81	27.84	0.00	13.69	151.14	1173.70	3.77
	4/16/20 7:15	242.66	28.00	0.00	13.80	153.51	1173.42	3.77
	4/16/20 7:16	242.71	28.00	0.00	14.02	156.27	1174.35	3.77
	4/16/20 7:17	243.08	27.94	0.00	13.89	148.01	1173.73	3.77
	4/16/20 7:18	242.76	27.94	0.00	13.69	158.51	1173.22	3.77
	4/16/20 7:19	242.82	27.97	0.00	13.69	161.15	1173.81	3.77
	4/16/20 7:20	242.87	27.91	0.00	13.84	161.43	1172.73	3.77
	4/16/20 7:21	242.72	27.90	0.00	13.60	150.22	1172.56	3.77
	4/16/20 7:22	242.76	27.93	0.00	13.80	154.96	1173.63	3.77
	4/16/20 7:23	242.82	27.99	0.00	13.74	161.38	1173.03	3.77
	4/16/20 7:24	242.60	27.97	0.00	13.81	149.84	1174.09	3.77
	4/16/20 7:25	243.02	28.00	0.00	13.75	158.33	1174.16	3.77
	4/16/20 7:26	242.10	28.00	0.00	13.68	175.21	1172.63	3.77
	4/16/20 7:27	242.94	27.91	0.00	13.89	178.53	1173.87	3.77
	4/16/20 7:28	242.57	27.93	0.00	13.57	160.99	1172.86	3.77
	4/16/20 7:29	243.17	28.02	0.00	14.09	173.62	1174.62	3.77
	4/16/20 7:30	242.73	28.02	0.00	13.87	160.83	1173.85	3.77

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 6:24 - 4/16 8:24)		242.73	27.92	0.00	13.78	159.13	1173.46	3.77
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 7:31	243.02	27.90	0.00	13.53	159.21	1174.58	3.77
	4/16/20 7:32	242.64	27.93	0.00	13.76	163.11	1173.87	3.77
	4/16/20 7:33	242.77	28.02	0.00	14.01	163.90	1174.33	3.77
	4/16/20 7:34	242.90	28.05	0.00	14.07	150.76	1174.60	3.77
	4/16/20 7:35	242.76	27.93	0.00	13.49	159.71	1174.02	3.76
	4/16/20 7:36	242.96	27.86	0.00	13.69	158.21	1173.28	3.76
	4/16/20 7:37	242.67	27.88	0.00	13.45	154.59	1173.71	3.76
	4/16/20 7:38	242.72	28.00	0.00	13.75	156.93	1173.59	3.76
	4/16/20 7:39	243.18	27.92	0.00	14.00	144.95	1174.20	3.76
	4/16/20 7:40	242.80	27.91	0.00	13.80	157.27	1173.62	3.76
	4/16/20 7:41	242.68	27.94	0.00	13.75	159.58	1173.77	3.76
	4/16/20 7:42	243.09	27.96	0.00	13.88	161.07	1174.23	3.76
	4/16/20 7:43	242.82	27.97	0.00	14.02	157.70	1174.36	3.76
	4/16/20 7:44	242.81	27.85	0.00	13.73	148.90	1174.63	3.76
	4/16/20 7:45	243.00	27.95	0.00	13.95	149.36	1174.50	3.76
	4/16/20 7:46	242.42	27.96	0.00	13.65	152.51	1173.55	3.76
	4/16/20 7:47	242.66	27.97	0.00	13.66	158.80	1173.76	3.76
	4/16/20 7:48	242.60	27.94	0.00	13.80	160.75	1173.44	3.76
	4/16/20 7:49	242.97	27.84	0.00	13.72	151.10	1174.33	3.76
	4/16/20 7:50	242.94	27.90	0.00	13.69	153.22	1173.47	3.76
	4/16/20 7:51	242.43	27.93	0.00	13.88	163.48	1173.82	3.76
	4/16/20 7:52	242.89	27.99	0.00	13.84	147.90	1174.33	3.76
	4/16/20 7:53	242.59	27.95	0.00	13.89	160.55	1173.48	3.76
	4/16/20 7:54	242.94	27.94	0.00	13.86	163.97	1174.92	3.76
	4/16/20 7:55	242.56	27.96	0.00	13.78	158.44	1172.52	3.76
	4/16/20 7:56	242.59	27.98	0.00	13.88	149.10	1173.95	3.76
	4/16/20 7:57	242.83	28.01	0.00	13.67	161.52	1175.12	3.76
	4/16/20 7:58	242.68	27.91	0.00	13.85	156.34	1174.25	3.76
	4/16/20 7:59	242.76	27.92	0.00	13.65	148.28	1174.01	3.75
	4/16/20 8:00	242.84	27.97	0.00	14.04	147.06	1174.62	3.75
	4/16/20 8:01	243.05	27.97	0.00	13.74	159.99	1174.04	3.75
	4/16/20 8:02	242.49	27.85	0.00	13.87	157.30	1174.41	3.75
	4/16/20 8:03	242.75	27.86	0.00	13.52	161.73	1174.21	3.75
	4/16/20 8:04	243.02	27.95	0.00	13.63	159.72	1174.89	3.75
	4/16/20 8:05	243.00	28.01	0.00	13.82	147.60	1174.74	3.75
	4/16/20 8:06	242.81	27.88	0.00	13.72	150.85	1174.75	3.75
	4/16/20 8:07	242.65	27.87	0.00	13.99	159.68	1173.72	3.75
	4/16/20 8:08	242.60	27.89	0.00	13.59	148.93	1175.14	3.75
	4/16/20 8:09	242.78	27.96	0.00	13.64	149.88	1174.24	3.75
	4/16/20 8:10	242.86	27.95	0.00	14.07	159.29	1174.36	3.75
	4/16/20 8:11	242.90	27.80	0.00	13.99	162.79	1174.64	3.75
	4/16/20 8:12	242.78	27.84	0.00	13.77	162.01	1174.19	3.75
	4/16/20 8:13	242.58	27.79	0.00	13.70	157.28	1173.83	3.75
	4/16/20 8:14	242.45	27.89	0.00	13.81	149.12	1174.15	3.75
	4/16/20 8:15	242.48	27.86	0.00	13.85	162.16	1173.58	3.75
	4/16/20 8:16	242.75	27.83	0.00	13.91	162.25	1174.83	3.75
	4/16/20 8:17	242.99	27.84	0.00	13.66	183.51	1175.12	3.75
	4/16/20 8:18	243.01	27.91	0.00	13.69	172.89	1174.59	3.75
	4/16/20 8:19	243.08	27.92	0.00	13.60	168.78	1174.41	3.74
	4/16/20 8:20	242.75	27.81	0.00	13.96	175.03	1174.61	3.74
	4/16/20 8:21	242.44	27.85	0.00	13.68	168.28	1174.51	3.74
	4/16/20 8:22	242.88	27.82	0.00	13.89	169.55	1174.60	3.74
	4/16/20 8:23	242.36	27.91	0.00	13.78	157.34	1174.26	3.74
	4/16/20 8:24	242.62	27.90	0.00	13.70	164.91	1174.90	3.74

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 8:57 - 4/16 10:57)		242.19	28.11	0.00	13.81	150.10	1174.88	3.70
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 8:57	242.41	28.07	0.00	13.70	152.49	1174.69	3.73
	4/16/20 8:58	242.48	28.19	0.00	13.85	146.42	1174.38	3.73
	4/16/20 8:59	242.28	28.04	0.00	13.53	140.57	1173.93	3.72
	4/16/20 9:00	242.91	28.02	0.00	13.86	148.89	1174.92	3.72
	4/16/20 9:01	242.39	28.09	0.00	13.66	152.63	1174.44	3.72
	4/16/20 9:02	242.29	28.13	0.00	13.69	156.81	1174.38	3.72
	4/16/20 9:03	242.47	28.17	0.00	13.85	153.59	1174.36	3.72
	4/16/20 9:04	242.29	28.07	0.00	13.53	147.32	1174.12	3.72
	4/16/20 9:05	242.55	28.08	0.00	13.79	150.17	1174.14	3.72
	4/16/20 9:06	242.34	28.05	0.00	13.87	158.59	1174.98	3.72
	4/16/20 9:07	242.45	28.14	0.00	13.94	153.17	1176.03	3.72
	4/16/20 9:08	242.27	28.12	0.00	14.43	143.48	1175.70	3.72
	4/16/20 9:09	242.26	28.03	0.00	14.10	154.71	1174.71	3.72
	4/16/20 9:10	242.27	28.05	0.00	13.63	154.30	1174.50	3.72
	4/16/20 9:11	242.29	28.09	0.00	13.78	146.94	1174.98	3.72
	4/16/20 9:12	242.29	28.11	0.00	14.32	144.03	1175.34	3.72
	4/16/20 9:13	242.12	28.09	0.00	13.84	141.96	1174.34	3.72
	4/16/20 9:14	242.07	28.04	0.00	13.76	143.65	1174.08	3.72
	4/16/20 9:15	242.88	28.13	0.00	13.98	171.54	1175.47	3.72
	4/16/20 9:16	242.64	28.20	0.00	14.12	158.67	1175.23	3.72
	4/16/20 9:17	242.25	28.14	0.00	13.81	160.13	1174.65	3.72
	4/16/20 9:18	242.28	28.10	0.00	13.71	160.02	1174.63	3.71
	4/16/20 9:19	242.18	28.11	0.00	13.79	163.11	1174.88	3.71
	4/16/20 9:20	242.33	28.18	0.00	13.62	146.94	1174.90	3.71
	4/16/20 9:21	242.05	28.15	0.00	14.14	150.49	1175.78	3.71
	4/16/20 9:22	242.46	28.14	0.00	14.01	156.70	1174.92	3.71
	4/16/20 9:23	242.09	28.08	0.00	13.84	151.81	1174.93	3.71
	4/16/20 9:24	242.21	28.12	0.00	13.86	148.18	1174.05	3.71
	4/16/20 9:25	242.37	28.14	0.00	14.15	146.53	1175.08	3.71
	4/16/20 9:26	242.60	28.11	0.00	13.86	146.97	1174.80	3.71
	4/16/20 9:27	242.27	28.12	0.00	13.62	140.54	1174.38	3.71
	4/16/20 9:28	242.39	28.12	0.00	13.66	145.36	1175.27	3.71
	4/16/20 9:29	241.94	28.15	0.00	13.58	140.84	1174.16	3.71
	4/16/20 9:30	242.06	28.11	0.00	13.77	144.98	1174.43	3.71
	4/16/20 9:31	242.43	28.04	0.00	14.10	152.74	1174.90	3.71
	4/16/20 9:32	242.60	28.03	0.00	13.80	152.09	1174.84	3.71
	4/16/20 9:33	242.56	28.21	0.00	13.95	149.37	1174.79	3.71
	4/16/20 9:34	242.62	28.17	0.00	13.79	148.69	1175.52	3.71
	4/16/20 9:35	242.29	28.02	0.00	13.89	148.89	1174.95	3.71
	4/16/20 9:36	242.44	28.04	0.00	13.68	155.92	1174.50	3.71
	4/16/20 9:37	242.25	28.09	0.00	13.95	152.00	1174.49	3.71
	4/16/20 9:38	242.49	28.11	0.00	13.84	145.21	1175.42	3.70
	4/16/20 9:39	242.02	28.08	0.00	13.68	146.30	1174.32	3.70
	4/16/20 9:40	242.14	28.08	0.00	14.04	144.45	1175.45	3.70
	4/16/20 9:41	242.32	28.15	0.00	13.73	145.29	1175.12	3.70
	4/16/20 9:42	242.23	28.17	0.00	13.48	145.79	1174.64	3.70
	4/16/20 9:43	242.90	28.17	0.00	13.90	150.15	1175.57	3.70
	4/16/20 9:44	242.55	28.00	0.00	13.76	153.58	1175.46	3.70
	4/16/20 9:45	242.36	28.07	0.00	13.91	155.16	1174.68	3.70
	4/16/20 9:46	242.07	28.18	0.00	13.73	156.89	1174.29	3.70
	4/16/20 9:47	242.28	28.16	0.00	13.80	147.56	1174.93	3.70
	4/16/20 9:48	241.96	28.03	0.00	13.71	148.70	1174.44	3.70
	4/16/20 9:49	242.33	28.11	0.00	14.05	152.81	1175.40	3.70
	4/16/20 9:50	242.43	28.07	0.00	14.01	152.27	1174.75	3.70
	4/16/20 9:51	242.62	28.19	0.00	14.18	148.49	1175.11	3.70
	4/16/20 9:52	241.96	28.16	0.00	13.97	149.39	1174.11	3.70
	4/16/20 9:53	242.35	28.06	0.00	13.70	155.69	1175.10	3.70
	4/16/20 9:54	242.11	28.13	0.00	13.61	148.93	1174.34	3.70
	4/16/20 9:55	242.26	28.16	0.00	13.92	142.85	1174.89	3.70
	4/16/20 9:56	242.36	28.15	0.00	13.75	142.17	1175.21	3.70
	4/16/20 9:57	242.37	28.06	0.00	13.78	143.73	1175.21	3.70
	4/16/20 9:58	242.29	28.12	0.00	14.07	151.29	1174.82	3.69
	4/16/20 9:59	242.20	28.21	0.00	13.77	154.39	1174.68	3.69
	4/16/20 10:00	242.53	28.18	0.00	14.18	155.14	1175.50	3.69
	4/16/20 10:01	242.61	28.01	0.00	13.55	149.86	1174.89	3.69
	4/16/20 10:02	242.27	28.06	0.00	13.60	148.60	1174.69	3.69
	4/16/20 10:03	242.51	28.13	0.00	13.95	155.86	1175.88	3.69

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 8:57 - 4/16 10:57)		242.19	28.11	0.00	13.81	150.10	1174.88	3.70
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 10:04	242.23	28.08	0.00	13.70	154.27	1174.95	3.69
	4/16/20 10:05	242.54	28.11	0.00	13.72	153.03	1174.17	3.69
	4/16/20 10:06	242.34	28.06	0.00	13.57	146.30	1174.69	3.69
	4/16/20 10:07	242.08	28.05	0.00	13.71	150.97	1173.62	3.69
	4/16/20 10:08	242.53	28.19	0.00	13.56	159.28	1173.93	3.69
	4/16/20 10:09	242.54	28.14	0.00	13.79	161.56	1175.55	3.69
	4/16/20 10:10	242.27	28.12	0.00	13.79	156.07	1175.38	3.69
	4/16/20 10:11	242.20	28.08	0.00	13.91	157.32	1174.81	3.69
	4/16/20 10:12	242.13	28.15	0.00	13.72	147.69	1174.76	3.69
	4/16/20 10:13	242.48	28.18	0.00	13.57	147.90	1174.67	3.69
	4/16/20 10:14	242.21	28.16	0.00	13.86	147.19	1174.20	3.69
	4/16/20 10:15	242.23	28.08	0.00	13.62	149.26	1174.10	3.69
	4/16/20 10:16	242.26	28.07	0.00	13.59	149.00	1174.61	3.69
	4/16/20 10:17	242.38	28.18	0.00	13.97	146.26	1174.91	3.68
	4/16/20 10:18	242.15	28.15	0.00	13.70	144.01	1174.27	3.68
	4/16/20 10:19	242.13	28.07	0.00	13.74	153.52	1174.50	3.68
	4/16/20 10:20	242.03	28.08	0.00	13.73	156.19	1174.81	3.68
	4/16/20 10:21	242.36	28.16	0.00	13.76	156.35	1174.89	3.68
	4/16/20 10:22	242.36	28.19	0.00	13.61	149.85	1175.13	3.68
	4/16/20 10:23	242.22	28.10	0.00	13.94	142.62	1175.23	3.68
	4/16/20 10:24	242.35	28.13	0.00	13.94	143.61	1175.01	3.68
	4/16/20 10:25	242.59	28.10	0.00	13.90	145.17	1175.28	3.68
	4/16/20 10:26	242.14	28.17	0.00	13.75	152.75	1175.03	3.68
	4/16/20 10:27	242.35	28.11	0.00	13.87	154.70	1175.75	3.68
	4/16/20 10:28	242.42	28.13	0.00	13.85	161.21	1175.66	3.68
	4/16/20 10:29	242.38	28.11	0.00	14.12	175.48	1175.95	3.68
	4/16/20 10:30	241.76	28.10	0.00	13.94	160.82	1175.46	3.68
	4/16/20 10:31	241.94	28.12	0.00	13.49	159.06	1174.40	3.68
	4/16/20 10:32	241.75	28.06	0.00	13.79	163.41	1175.37	3.68
	4/16/20 10:33	241.82	28.00	0.00	13.74	155.01	1174.71	3.68
	4/16/20 10:34	241.91	28.15	0.00	13.89	151.64	1175.18	3.68
	4/16/20 10:35	241.79	28.13	0.00	13.69	146.14	1174.65	3.68
	4/16/20 10:36	241.96	28.06	0.00	13.80	153.30	1175.05	3.68
	4/16/20 10:37	242.06	28.04	0.00	13.71	147.98	1175.39	3.67
	4/16/20 10:38	241.76	28.06	0.00	13.47	139.12	1175.15	3.67
	4/16/20 10:39	241.86	28.13	0.00	13.90	146.59	1175.73	3.67
	4/16/20 10:40	241.73	28.20	0.00	13.65	138.29	1174.42	3.67
	4/16/20 10:41	241.51	28.06	0.00	14.16	133.80	1175.79	3.67
	4/16/20 10:42	241.99	28.06	0.00	13.73	138.57	1174.56	3.67
	4/16/20 10:43	241.82	28.03	0.00	13.70	147.34	1175.04	3.67
	4/16/20 10:44	241.76	28.11	0.00	13.47	148.05	1175.04	3.67
	4/16/20 10:45	241.52	28.07	0.00	13.68	150.13	1174.27	3.67
	4/16/20 10:46	241.57	28.08	0.00	13.49	143.67	1174.74	3.67
	4/16/20 10:47	241.99	28.09	0.00	13.73	146.67	1175.12	3.67
	4/16/20 10:48	241.91	28.11	0.00	13.89	141.24	1175.18	3.67
	4/16/20 10:49	241.30	28.07	0.00	13.78	153.10	1174.79	3.67
	4/16/20 10:50	241.41	28.01	0.00	13.81	150.10	1174.45	3.67
	4/16/20 10:51	241.35	28.10	0.00	13.89	144.13	1175.42	3.67
	4/16/20 10:52	241.75	28.14	0.00	13.85	142.14	1174.84	3.67
	4/16/20 10:53	241.37	28.03	0.00	13.83	142.69	1174.68	3.67
	4/16/20 10:54	241.33	28.03	0.00	13.70	141.97	1175.00	3.67
	4/16/20 10:55	241.43	28.07	0.00	13.97	146.87	1175.81	3.67
	4/16/20 10:56	241.68	28.13	0.00	13.80	147.34	1174.61	3.67
	4/16/20 10:57	241.36	28.10	0.00	13.90	148.09	1174.95	3.66

EMISSION DATA RECORDS

Operating Data Base Load
(provided by Cricket Valley Energy Center LLC)
Opacity

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 6:00 - 4/15 7:00)		240.09	27.50	0.00	13.91	144.52	1170.59	4.69
COUNT = 61								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/15/20 6:00	237.90	27.27	0.00	13.91	113.84	1175.40	4.82
	4/15/20 6:01	240.37	27.47	0.00	13.74	107.58	1171.09	4.82
	4/15/20 6:02	239.53	27.52	0.00	14.15	122.43	1170.13	4.82
	4/15/20 6:03	239.65	27.44	0.00	13.93	149.39	1170.33	4.81
	4/15/20 6:04	238.81	27.28	0.00	13.84	155.44	1172.72	4.81
	4/15/20 6:05	239.40	27.40	0.00	13.67	132.25	1170.58	4.80
	4/15/20 6:06	240.35	27.62	0.00	14.06	155.46	1169.84	4.80
	4/15/20 6:07	240.17	27.62	0.00	13.79	156.93	1169.74	4.79
	4/15/20 6:08	240.08	27.41	0.00	14.11	160.37	1169.45	4.79
	4/15/20 6:09	239.46	27.40	0.00	14.02	157.17	1169.91	4.78
	4/15/20 6:10	239.69	27.42	0.00	14.09	149.71	1171.86	4.78
	4/15/20 6:11	239.84	27.58	0.00	13.83	140.56	1170.74	4.78
	4/15/20 6:12	239.90	27.39	0.00	13.72	138.68	1169.84	4.77
	4/15/20 6:13	240.64	27.47	0.00	13.99	136.04	1173.75	4.77
	4/15/20 6:14	239.74	27.46	0.00	13.86	133.41	1170.55	4.76
	4/15/20 6:15	239.92	27.71	0.00	13.97	125.99	1170.15	4.76
	4/15/20 6:16	240.19	27.49	0.00	13.97	128.53	1172.16	4.75
	4/15/20 6:17	240.22	27.41	0.00	13.84	130.61	1171.03	4.75
	4/15/20 6:18	239.34	27.30	0.00	14.11	133.86	1171.31	4.74
	4/15/20 6:19	240.53	27.56	0.00	13.67	133.02	1170.72	4.74
	4/15/20 6:20	239.92	27.52	0.00	13.96	132.81	1171.71	4.73
	4/15/20 6:21	239.49	27.39	0.00	13.89	132.69	1170.42	4.73
	4/15/20 6:22	239.53	27.41	0.00	14.03	134.63	1171.65	4.73
	4/15/20 6:23	239.12	27.37	0.00	13.96	132.38	1174.53	4.72
	4/15/20 6:24	239.52	27.60	0.00	13.68	122.56	1170.00	4.72
	4/15/20 6:25	239.68	27.48	0.00	13.81	128.38	1171.48	4.71
	4/15/20 6:26	238.84	27.30	0.00	14.04	126.31	1172.26	4.71
	4/15/20 6:27	240.25	27.55	0.00	13.87	115.55	1169.56	4.70
	4/15/20 6:28	240.00	27.68	0.00	13.81	130.32	1169.99	4.70
	4/15/20 6:29	239.64	27.44	0.00	13.76	133.15	1172.05	4.69
	4/15/20 6:30	240.80	27.42	0.00	14.03	133.63	1169.91	4.69
	4/15/20 6:31	239.95	27.56	0.00	14.16	140.75	1170.55	4.69
	4/15/20 6:32	240.48	27.70	0.00	14.01	142.57	1170.16	4.68
	4/15/20 6:33	239.05	27.48	0.00	14.09	145.97	1172.12	4.68
	4/15/20 6:34	240.28	27.44	0.00	13.82	133.59	1170.07	4.67
	4/15/20 6:35	240.17	27.50	0.00	14.09	146.71	1170.33	4.67
	4/15/20 6:36	240.96	27.60	0.00	14.08	147.09	1170.83	4.66
	4/15/20 6:37	240.33	27.60	0.00	14.10	151.39	1169.78	4.66
	4/15/20 6:38	240.54	27.45	0.00	14.12	155.99	1170.03	4.65
	4/15/20 6:39	240.72	27.45	0.00	14.12	158.10	1170.09	4.65
	4/15/20 6:40	240.43	27.53	0.00	13.94	158.64	1171.21	4.65
	4/15/20 6:41	240.51	27.65	0.00	14.18	156.92	1169.48	4.64
	4/15/20 6:42	240.16	27.47	0.00	14.19	154.62	1170.47	4.64
	4/15/20 6:43	240.51	27.45	0.00	13.73	155.40	1170.00	4.63
	4/15/20 6:44	240.88	27.54	0.00	13.78	150.94	1170.77	4.63
	4/15/20 6:45	240.39	27.62	0.00	13.85	172.86	1169.99	4.62
	4/15/20 6:46	240.80	27.63	0.00	13.88	174.40	1170.01	4.62
	4/15/20 6:47	240.67	27.35	0.00	13.86	172.73	1170.38	4.61
	4/15/20 6:48	240.71	27.50	0.00	13.82	170.67	1169.89	4.61
	4/15/20 6:49	240.74	27.63	0.00	13.80	167.30	1170.11	4.61
	4/15/20 6:50	240.06	27.64	0.00	13.85	162.57	1169.61	4.60
	4/15/20 6:51	240.32	27.44	0.00	13.87	155.19	1169.42	4.60
	4/15/20 6:52	240.63	27.47	0.00	14.02	154.85	1170.16	4.59
	4/15/20 6:53	240.37	27.52	0.00	13.67	150.09	1169.22	4.59
	4/15/20 6:54	240.15	27.62	0.00	13.89	150.03	1169.30	4.58
	4/15/20 6:55	240.18	27.50	0.00	13.68	150.47	1168.80	4.58
	4/15/20 6:56	241.00	27.47	0.00	14.03	150.05	1170.24	4.57
	4/15/20 6:57	240.75	27.55	0.00	13.73	148.67	1169.24	4.57
	4/15/20 6:58	240.31	27.67	0.00	13.76	148.81	1169.75	4.57
	4/15/20 6:59	240.49	27.60	0.00	13.74	150.55	1169.45	4.56
	4/15/20 7:00	240.64	27.45	0.00	13.59	154.20	1169.68	4.56

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 7:00 - 4/15 8:00)		240.66	27.55	0.00	13.83	157.80	1170.41	4.42
COUNT = 61								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/15/20 7:00	240.64	27.45	0.00	13.59	154.20	1169.68	4.56
	4/15/20 7:01	240.58	27.51	0.00	14.06	151.56	1170.78	4.55
	4/15/20 7:02	240.27	27.62	0.00	13.96	150.61	1169.89	4.55
	4/15/20 7:03	240.35	27.66	0.00	13.65	152.04	1169.69	4.54
	4/15/20 7:04	240.80	27.48	0.00	14.42	156.06	1171.26	4.54
	4/15/20 7:05	240.36	27.52	0.00	13.76	156.86	1169.96	4.53
	4/15/20 7:06	240.73	27.70	0.00	13.74	157.78	1170.83	4.53
	4/15/20 7:07	240.65	27.60	0.00	13.87	156.42	1170.41	4.53
	4/15/20 7:08	240.45	27.54	0.00	13.79	154.43	1169.82	4.52
	4/15/20 7:09	240.90	27.47	0.00	14.01	151.96	1170.24	4.52
	4/15/20 7:10	240.64	27.50	0.00	13.60	150.49	1169.55	4.51
	4/15/20 7:11	240.76	27.65	0.00	13.76	147.12	1169.83	4.51
	4/15/20 7:12	240.39	27.55	0.00	13.54	148.10	1169.29	4.50
	4/15/20 7:13	240.76	27.53	0.00	13.88	151.31	1170.06	4.50
	4/15/20 7:14	240.91	27.52	0.00	13.61	152.62	1170.36	4.49
	4/15/20 7:15	240.27	27.66	0.00	14.01	155.60	1169.95	4.49
	4/15/20 7:16	240.69	27.67	0.00	13.69	155.29	1170.62	4.49
	4/15/20 7:17	240.10	27.45	0.00	13.86	155.86	1169.91	4.48
	4/15/20 7:18	240.68	27.51	0.00	13.92	157.79	1170.58	4.48
	4/15/20 7:19	240.43	27.60	0.00	13.96	156.03	1170.23	4.47
	4/15/20 7:20	240.98	27.65	0.00	13.87	154.22	1170.54	4.47
	4/15/20 7:21	240.64	27.51	0.00	13.89	156.38	1170.26	4.46
	4/15/20 7:22	240.54	27.43	0.00	14.19	155.75	1170.92	4.46
	4/15/20 7:23	240.93	27.52	0.00	13.85	156.20	1170.29	4.45
	4/15/20 7:24	240.29	27.68	0.00	13.82	155.30	1170.06	4.45
	4/15/20 7:25	240.53	27.57	0.00	13.63	155.94	1170.80	4.45
	4/15/20 7:26	240.36	27.42	0.00	13.78	155.39	1171.19	4.44
	4/15/20 7:27	240.61	27.49	0.00	14.12	151.19	1170.06	4.44
	4/15/20 7:28	240.89	27.67	0.00	13.64	151.34	1170.44	4.43
	4/15/20 7:29	240.26	27.64	0.00	14.16	150.34	1171.13	4.43
	4/15/20 7:30	240.92	27.40	0.00	13.84	150.22	1170.70	4.42
	4/15/20 7:31	240.83	27.47	0.00	13.81	151.33	1170.07	4.42
	4/15/20 7:32	240.75	27.54	0.00	13.71	150.20	1170.32	4.41
	4/15/20 7:33	240.79	27.66	0.00	13.64	152.01	1170.50	4.41
	4/15/20 7:34	240.49	27.47	0.00	13.83	170.55	1170.60	4.40
	4/15/20 7:35	241.18	27.51	0.00	13.74	168.08	1171.40	4.40
	4/15/20 7:36	240.80	27.59	0.00	13.83	170.89	1170.80	4.40
	4/15/20 7:37	240.68	27.66	0.00	13.81	168.72	1170.50	4.39
	4/15/20 7:38	240.63	27.50	0.00	13.90	165.11	1170.90	4.39
	4/15/20 7:39	240.76	27.35	0.00	13.82	164.84	1170.66	4.38
	4/15/20 7:40	240.88	27.52	0.00	14.13	160.40	1171.66	4.38
	4/15/20 7:41	240.78	27.62	0.00	14.09	161.72	1170.52	4.37
	4/15/20 7:42	240.24	27.64	0.00	13.98	157.64	1170.85	4.37
	4/15/20 7:43	240.75	27.46	0.00	13.74	157.29	1170.93	4.36
	4/15/20 7:44	240.68	27.47	0.00	13.84	155.78	1170.82	4.36
	4/15/20 7:45	240.58	27.57	0.00	13.49	181.32	1170.38	4.36
	4/15/20 7:46	241.12	27.69	0.00	13.86	176.21	1170.85	4.35
	4/15/20 7:47	240.94	27.53	0.00	13.78	175.16	1170.23	4.35
	4/15/20 7:48	241.00	27.46	0.00	13.83	172.72	1170.54	4.34
	4/15/20 7:49	240.30	27.61	0.00	13.81	173.28	1169.44	4.34
	4/15/20 7:50	240.88	27.68	0.00	14.15	168.50	1171.12	4.33
	4/15/20 7:51	240.97	27.55	0.00	13.78	164.85	1170.47	4.33
	4/15/20 7:52	240.68	27.48	0.00	13.65	162.93	1170.69	4.32
	4/15/20 7:53	241.02	27.49	0.00	13.87	159.75	1169.76	4.32
	4/15/20 7:54	240.69	27.69	0.00	13.65	153.33	1170.77	4.32
	4/15/20 7:55	240.45	27.60	0.00	13.82	151.72	1169.88	4.31
	4/15/20 7:56	240.45	27.49	0.00	13.91	152.11	1170.05	4.31
	4/15/20 7:57	240.65	27.48	0.00	13.66	152.36	1170.36	4.30
	4/15/20 7:58	240.79	27.60	0.00	13.68	152.17	1170.11	4.30
	4/15/20 7:59	240.50	27.66	0.00	13.77	155.98	1170.09	4.29
	4/15/20 8:00	240.78	27.41	0.00	13.80	154.32	1170.16	4.29

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/15 8:00 - 4/15 9:00)		240.50	27.55	0.00	13.85	153.36	1170.01	4.16
COUNT = 61								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/15/20 8:00	240.78	27.41	0.00	13.80	154.32	1170.16	4.29
	4/15/20 8:01	240.64	27.62	0.00	13.76	157.07	1170.02	4.28
	4/15/20 8:02	240.44	27.59	0.00	13.96	156.16	1169.35	4.28
	4/15/20 8:03	240.75	27.70	0.00	13.85	155.52	1170.40	4.28
	4/15/20 8:04	240.39	27.42	0.00	13.72	155.70	1169.48	4.27
	4/15/20 8:05	240.84	27.46	0.00	13.64	157.95	1170.36	4.27
	4/15/20 8:06	240.47	27.57	0.00	13.88	155.14	1170.16	4.26
	4/15/20 8:07	240.90	27.65	0.00	13.81	156.83	1170.51	4.26
	4/15/20 8:08	240.52	27.50	0.00	13.76	157.16	1169.87	4.25
	4/15/20 8:09	240.80	27.53	0.00	13.96	155.77	1170.08	4.25
	4/15/20 8:10	240.72	27.51	0.00	13.86	158.27	1170.37	4.24
	4/15/20 8:11	240.16	27.64	0.00	13.59	156.13	1168.73	4.24
	4/15/20 8:12	240.51	27.56	0.00	13.62	155.31	1169.71	4.24
	4/15/20 8:13	240.72	27.44	0.00	14.00	155.07	1170.28	4.23
	4/15/20 8:14	240.74	27.52	0.00	13.90	155.66	1169.35	4.23
	4/15/20 8:15	240.48	27.64	0.00	14.10	151.68	1169.83	4.22
	4/15/20 8:16	240.43	27.64	0.00	13.96	151.19	1169.75	4.22
	4/15/20 8:17	240.55	27.44	0.00	13.67	156.89	1169.27	4.21
	4/15/20 8:18	240.99	27.44	0.00	13.80	156.59	1170.24	4.21
	4/15/20 8:19	240.43	27.73	0.00	13.73	155.71	1169.60	4.20
	4/15/20 8:20	240.44	27.68	0.00	13.79	154.38	1170.16	4.20
	4/15/20 8:21	240.58	27.48	0.00	13.82	155.99	1170.19	4.20
	4/15/20 8:22	240.62	27.51	0.00	14.30	157.48	1170.51	4.19
	4/15/20 8:23	240.44	27.49	0.00	13.76	156.61	1170.68	4.19
	4/15/20 8:24	240.57	27.68	0.00	13.98	155.87	1170.76	4.18
	4/15/20 8:25	240.62	27.56	0.00	13.60	150.57	1170.60	4.18
	4/15/20 8:26	240.81	27.40	0.00	13.89	155.81	1170.96	4.17
	4/15/20 8:27	240.55	27.70	0.00	13.78	151.44	1169.98	4.17
	4/15/20 8:28	240.90	27.62	0.00	14.00	147.54	1169.50	4.16
	4/15/20 8:29	240.60	27.66	0.00	13.69	146.95	1169.87	4.16
	4/15/20 8:30	240.23	27.51	0.00	13.68	150.29	1169.80	4.16
	4/15/20 8:31	240.22	27.54	0.00	13.72	149.58	1169.82	4.15
	4/15/20 8:32	240.90	27.61	0.00	13.87	147.67	1170.00	4.15
	4/15/20 8:33	240.49	27.62	0.00	13.80	158.12	1170.97	4.14
	4/15/20 8:34	240.72	27.45	0.00	13.77	148.97	1170.34	4.14
	4/15/20 8:35	240.39	27.48	0.00	13.85	153.12	1169.90	4.13
	4/15/20 8:36	240.46	27.58	0.00	13.81	159.83	1170.29	4.13
	4/15/20 8:37	240.40	27.66	0.00	13.85	150.10	1170.14	4.12
	4/15/20 8:38	240.86	27.58	0.00	14.21	152.79	1170.60	4.12
	4/15/20 8:39	240.64	27.47	0.00	14.21	155.49	1170.56	4.12
	4/15/20 8:40	240.58	27.47	0.00	14.04	152.05	1170.00	4.11
	4/15/20 8:41	240.97	27.57	0.00	13.67	150.99	1170.48	4.11
	4/15/20 8:42	240.74	27.57	0.00	13.71	157.06	1169.72	4.10
	4/15/20 8:43	240.46	27.35	0.00	13.71	151.48	1169.66	4.10
	4/15/20 8:44	240.26	27.55	0.00	13.69	146.45	1169.82	4.09
	4/15/20 8:45	240.43	27.55	0.00	13.88	155.65	1169.54	4.09
	4/15/20 8:46	240.03	27.70	0.00	13.64	160.39	1169.68	4.08
	4/15/20 8:47	240.78	27.47	0.00	14.18	162.75	1170.65	4.08
	4/15/20 8:48	240.72	27.48	0.00	14.00	154.00	1170.95	4.07
	4/15/20 8:49	240.44	27.53	0.00	13.98	150.03	1170.49	4.07
	4/15/20 8:50	240.52	27.65	0.00	13.94	159.71	1170.06	4.07
	4/15/20 8:51	240.36	27.48	0.00	13.77	155.45	1170.68	4.06
	4/15/20 8:52	240.24	27.46	0.00	13.62	146.27	1169.95	4.06
	4/15/20 8:53	240.04	27.47	0.00	13.96	146.86	1169.52	4.05
	4/15/20 8:54	240.32	27.62	0.00	13.73	145.95	1169.04	4.05
	4/15/20 8:55	240.25	27.65	0.00	14.20	143.89	1170.00	4.04
	4/15/20 8:56	240.46	27.52	0.00	13.76	145.98	1169.37	4.04
	4/15/20 8:57	240.06	27.48	0.00	13.82	150.13	1168.93	4.03
	4/15/20 8:58	239.81	27.45	0.00	13.99	151.65	1169.72	4.03
	4/15/20 8:59	239.92	27.61	0.00	13.88	149.20	1169.76	4.03
	4/15/20 9:00	239.67	27.48	0.00	13.73	146.61	1169.60	4.02

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
NOx, CO, VOC, and NH_3

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 14:04 - 4/16 15:03)	240.30	28.02	10.46	14.23	163.94	1175.98	3.56
COUNT = 60							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 14:04	240.56	28.01	10.46	14.17	165.79	1175.82	3.57
4/16/20 14:05	240.71	27.98	10.46	14.31	159.26	1175.91	3.57
4/16/20 14:06	240.89	28.12	10.46	14.27	160.78	1176.24	3.57
4/16/20 14:07	240.68	28.07	10.46	14.19	159.41	1175.94	3.57
4/16/20 14:08	240.56	27.96	10.46	14.46	159.41	1175.86	3.57
4/16/20 14:09	240.90	28.08	10.46	14.22	159.50	1176.64	3.57
4/16/20 14:10	240.37	28.08	10.46	14.34	162.17	1175.62	3.57
4/16/20 14:11	240.45	28.09	10.46	14.41	169.83	1175.71	3.57
4/16/20 14:12	240.58	27.99	10.46	14.21	169.79	1176.15	3.57
4/16/20 14:13	240.86	27.98	10.46	14.52	173.42	1176.26	3.57
4/16/20 14:14	240.73	28.10	10.46	13.95	169.17	1175.33	3.56
4/16/20 14:15	240.92	28.14	10.46	14.29	167.74	1176.75	3.56
4/16/20 14:16	240.84	28.04	10.46	14.15	168.81	1175.77	3.56
4/16/20 14:17	240.83	27.96	10.46	13.93	170.03	1175.80	3.56
4/16/20 14:18	240.91	27.96	10.46	14.27	169.49	1175.38	3.56
4/16/20 14:19	240.69	28.09	10.46	14.37	163.69	1176.03	3.56
4/16/20 14:20	240.37	28.09	10.46	14.01	166.58	1175.79	3.56
4/16/20 14:21	240.85	27.99	10.46	13.92	174.10	1176.40	3.56
4/16/20 14:22	240.59	28.05	10.46	14.18	167.11	1175.63	3.56
4/16/20 14:23	241.09	28.11	10.46	14.10	165.62	1176.20	3.56
4/16/20 14:24	240.35	28.12	10.46	14.12	172.23	1176.49	3.56
4/16/20 14:25	240.68	27.99	10.46	14.39	173.17	1176.52	3.56
4/16/20 14:26	240.09	28.04	10.46	13.98	174.46	1175.22	3.56
4/16/20 14:27	240.59	28.01	10.46	14.60	164.68	1176.22	3.56
4/16/20 14:28	239.93	28.10	10.46	14.53	162.81	1175.91	3.56
4/16/20 14:29	240.08	28.07	10.46	14.76	158.81	1176.28	3.56
4/16/20 14:30	240.43	27.98	10.46	14.26	160.86	1176.21	3.56
4/16/20 14:31	240.12	27.95	10.46	14.46	170.28	1176.04	3.56
4/16/20 14:32	240.08	28.16	10.46	14.10	160.56	1176.00	3.56
4/16/20 14:33	240.62	28.04	10.46	14.61	163.69	1176.25	3.56
4/16/20 14:34	239.79	27.95	10.46	14.01	169.69	1174.93	3.55
4/16/20 14:35	240.42	27.99	10.46	14.24	162.96	1176.03	3.55
4/16/20 14:36	240.28	28.02	10.46	14.52	163.25	1175.70	3.55
4/16/20 14:37	240.18	28.06	10.46	14.53	166.15	1175.59	3.55
4/16/20 14:38	240.67	28.00	10.46	14.12	157.24	1176.52	3.55
4/16/20 14:39	239.96	28.02	10.46	14.16	156.65	1175.42	3.55
4/16/20 14:40	240.37	27.99	10.46	14.25	157.29	1175.90	3.55
4/16/20 14:41	240.09	28.05	10.47	14.04	159.17	1176.19	3.55
4/16/20 14:42	239.94	28.07	10.47	14.17	164.58	1174.75	3.55
4/16/20 14:43	240.29	27.91	10.47	13.88	168.24	1175.82	3.55
4/16/20 14:44	240.23	27.99	10.47	14.55	167.11	1176.45	3.55
4/16/20 14:45	240.50	28.01	10.47	14.66	168.25	1176.53	3.55
4/16/20 14:46	240.43	28.08	10.47	14.07	170.64	1176.15	3.55
4/16/20 14:47	240.16	28.04	10.47	14.14	164.07	1175.73	3.55
4/16/20 14:48	240.11	27.95	10.47	14.23	174.75	1176.42	3.55
4/16/20 14:49	240.45	27.99	10.47	14.31	174.71	1176.40	3.55
4/16/20 14:50	240.27	28.13	10.47	14.29	172.37	1176.55	3.55
4/16/20 14:51	239.36	27.97	10.47	14.05	161.32	1174.94	3.55
4/16/20 14:52	239.25	27.88	10.47	14.09	155.33	1174.93	3.55
4/16/20 14:53	239.82	27.89	10.47	14.66	158.90	1176.81	3.55
4/16/20 14:54	239.66	28.03	10.47	14.28	164.82	1177.13	3.54
4/16/20 14:55	239.28	28.00	10.47	13.91	151.05	1176.21	3.54
4/16/20 14:56	239.61	27.93	10.47	14.21	156.80	1176.32	3.54
4/16/20 14:57	240.11	27.95	10.47	13.99	152.70	1175.28	3.54
4/16/20 14:58	240.06	28.00	10.47	14.05	150.30	1176.10	3.54
4/16/20 14:59	239.80	28.09	10.47	14.30	149.78	1176.14	3.54
4/16/20 15:00	240.02	27.97	10.47	14.02	150.95	1176.66	3.54
4/16/20 15:01	239.61	27.89	10.47	14.00	158.69	1175.32	3.54
4/16/20 15:02	239.70	27.94	10.47	14.15	165.09	1174.82	3.54
4/16/20 15:03	240.40	28.04	10.47	14.02	160.26	1176.49	3.54

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 15:23 - 4/16 16:22)		239.61	27.96	10.48	14.21	159.08	1175.94	3.53
COUNT = 60								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 15:23	239.53	27.92	10.48	14.24	151.42	1176.02	3.53
	4/16/20 15:24	239.57	27.88	10.48	14.53	161.55	1176.27	3.53
	4/16/20 15:25	240.04	28.08	10.48	14.47	158.97	1175.61	3.53
	4/16/20 15:26	239.63	28.00	10.48	14.30	164.71	1176.60	3.53
	4/16/20 15:27	239.95	27.86	10.48	14.29	159.76	1176.61	3.53
	4/16/20 15:28	239.58	27.92	10.48	14.29	156.58	1176.35	3.53
	4/16/20 15:29	239.19	28.09	10.48	14.01	155.83	1174.60	3.53
	4/16/20 15:30	239.26	28.00	10.48	13.84	161.27	1175.28	3.53
	4/16/20 15:31	238.80	27.88	10.48	14.00	163.13	1174.99	3.53
	4/16/20 15:32	239.23	27.84	10.48	14.00	163.12	1175.80	3.53
	4/16/20 15:33	239.07	27.90	10.48	14.03	156.31	1175.43	3.52
	4/16/20 15:34	239.02	28.03	10.48	14.11	150.54	1175.25	3.52
	4/16/20 15:35	238.83	27.99	10.48	14.49	149.54	1175.82	3.52
	4/16/20 15:36	239.46	27.87	10.48	14.15	148.83	1176.24	3.52
	4/16/20 15:37	239.76	27.92	10.48	14.18	149.39	1176.35	3.52
	4/16/20 15:38	239.18	27.96	10.48	14.06	150.36	1175.28	3.52
	4/16/20 15:39	239.47	28.05	10.48	14.42	151.20	1176.22	3.52
	4/16/20 15:40	239.61	27.87	10.48	14.18	149.24	1175.85	3.52
	4/16/20 15:41	239.41	27.96	10.48	13.98	154.81	1176.09	3.52
	4/16/20 15:42	239.55	27.90	10.48	14.55	165.26	1176.13	3.53
	4/16/20 15:43	239.48	28.05	10.48	14.12	165.41	1176.15	3.53
	4/16/20 15:44	239.16	27.94	10.48	14.13	155.06	1175.82	3.53
	4/16/20 15:45	240.12	27.89	10.48	14.44	154.37	1176.87	3.53
	4/16/20 15:46	239.70	27.92	10.48	13.97	163.93	1176.04	3.53
	4/16/20 15:47	239.69	28.08	10.48	14.03	160.16	1175.61	3.53
	4/16/20 15:48	239.81	27.96	10.48	14.13	154.06	1176.84	3.53
	4/16/20 15:49	239.74	27.89	10.48	14.22	162.42	1176.18	3.53
	4/16/20 15:50	239.57	27.97	10.48	14.26	163.11	1175.15	3.53
	4/16/20 15:51	239.93	28.03	10.48	14.45	164.79	1175.44	3.53
	4/16/20 15:52	239.63	27.94	10.48	13.97	164.61	1175.45	3.53
	4/16/20 15:53	240.02	27.96	10.48	14.21	159.99	1176.39	3.53
	4/16/20 15:54	239.52	27.91	10.48	14.15	154.80	1176.03	3.53
	4/16/20 15:55	239.64	27.99	10.48	14.11	166.86	1175.84	3.53
	4/16/20 15:56	239.82	28.06	10.48	14.10	158.08	1176.74	3.53
	4/16/20 15:57	239.39	27.91	10.48	13.99	154.19	1175.28	3.53
	4/16/20 15:58	239.72	27.89	10.48	14.43	154.32	1176.88	3.53
	4/16/20 15:59	239.38	27.92	10.49	14.35	161.79	1176.43	3.53
	4/16/20 16:00	239.10	28.02	10.49	14.01	151.91	1176.14	3.53
	4/16/20 16:01	239.61	27.92	10.49	14.26	151.27	1175.51	3.54
	4/16/20 16:02	239.64	27.87	10.49	13.98	159.59	1176.15	3.54
	4/16/20 16:03	240.03	27.92	10.49	14.32	161.95	1175.66	3.54
	4/16/20 16:04	239.90	28.01	10.49	14.31	161.09	1176.47	3.54
	4/16/20 16:05	239.90	28.00	10.49	14.26	152.33	1175.82	3.54
	4/16/20 16:06	240.22	27.96	10.49	14.34	163.69	1176.00	3.54
	4/16/20 16:07	239.80	27.92	10.49	14.25	164.35	1176.56	3.54
	4/16/20 16:08	239.15	28.02	10.49	13.99	165.06	1174.23	3.54
	4/16/20 16:09	239.50	28.06	10.49	14.09	165.48	1175.49	3.54
	4/16/20 16:10	239.74	27.95	10.49	14.03	161.66	1175.96	3.54
	4/16/20 16:11	239.74	27.86	10.49	14.30	153.28	1176.58	3.54
	4/16/20 16:12	239.24	27.96	10.49	14.22	153.46	1175.27	3.54
	4/16/20 16:13	240.31	28.01	10.49	14.41	154.91	1176.67	3.54
	4/16/20 16:14	240.02	27.94	10.49	14.62	166.52	1176.41	3.54
	4/16/20 16:15	239.76	27.95	10.49	14.21	161.55	1174.94	3.54
	4/16/20 16:16	239.88	27.88	10.49	14.10	167.36	1177.20	3.54
	4/16/20 16:17	239.84	28.05	10.49	14.27	160.70	1175.39	3.54
	4/16/20 16:18	239.86	28.15	10.49	14.15	167.20	1175.83	3.54
	4/16/20 16:19	239.74	27.96	10.49	14.02	166.52	1175.59	3.54
	4/16/20 16:20	239.51	27.92	10.49	14.18	162.23	1176.62	3.54
	4/16/20 16:21	239.78	27.96	10.49	14.49	167.67	1176.12	3.55
	4/16/20 16:22	239.62	28.07	10.49	14.43	165.14	1175.80	3.55

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 17:41 - 4/16 18:40)	240.46	28.02	10.52	14.20	163.89	1176.68	3.60
COUNT = 60							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 17:41	240.62	28.05	10.51	14.07	162.16	1177.16	3.59
4/16/20 17:42	240.78	28.05	10.51	14.27	158.05	1177.03	3.59
4/16/20 17:43	240.16	27.93	10.51	14.38	166.80	1176.78	3.59
4/16/20 17:44	240.28	27.95	10.51	14.25	170.32	1176.18	3.59
4/16/20 17:45	240.65	27.99	10.51	14.20	167.04	1177.04	3.59
4/16/20 17:46	240.29	28.08	10.51	14.02	161.25	1176.67	3.59
4/16/20 17:47	240.48	27.99	10.51	14.19	156.85	1177.00	3.59
4/16/20 17:48	240.51	27.92	10.51	13.96	157.73	1177.09	3.59
4/16/20 17:49	240.44	28.02	10.51	14.14	166.23	1177.25	3.59
4/16/20 17:50	240.01	28.06	10.51	14.65	159.45	1176.46	3.59
4/16/20 17:51	240.18	28.03	10.51	13.86	157.40	1175.91	3.59
4/16/20 17:52	240.67	27.92	10.51	14.24	159.20	1177.10	3.59
4/16/20 17:53	240.26	27.94	10.51	14.06	161.01	1176.79	3.59
4/16/20 17:54	239.91	28.02	10.51	14.32	164.22	1176.15	3.59
4/16/20 17:55	240.12	28.07	10.52	14.62	161.86	1177.28	3.59
4/16/20 17:56	240.45	27.99	10.52	14.20	158.02	1176.55	3.59
4/16/20 17:57	240.67	27.92	10.52	14.03	154.36	1177.06	3.60
4/16/20 17:58	240.49	28.01	10.52	14.13	161.04	1176.88	3.60
4/16/20 17:59	240.40	28.14	10.52	14.31	168.06	1175.77	3.60
4/16/20 18:00	240.41	27.99	10.52	14.25	169.86	1176.73	3.60
4/16/20 18:01	240.13	27.96	10.52	14.33	167.73	1176.05	3.60
4/16/20 18:02	240.34	28.02	10.52	14.22	162.60	1175.98	3.60
4/16/20 18:03	240.34	28.08	10.52	14.29	160.04	1176.66	3.60
4/16/20 18:04	240.31	27.97	10.52	14.59	164.60	1176.99	3.60
4/16/20 18:05	240.45	27.97	10.52	14.29	164.37	1176.96	3.60
4/16/20 18:06	240.36	28.01	10.52	14.24	165.84	1177.52	3.60
4/16/20 18:07	240.78	27.98	10.52	14.14	160.05	1177.00	3.60
4/16/20 18:08	240.58	28.13	10.52	14.40	161.93	1176.81	3.60
4/16/20 18:09	240.87	27.98	10.52	14.03	162.57	1177.15	3.60
4/16/20 18:10	240.58	27.97	10.52	14.19	160.86	1176.58	3.60
4/16/20 18:11	240.56	28.03	10.52	13.92	158.58	1177.06	3.60
4/16/20 18:12	240.22	28.06	10.52	14.17	164.27	1176.18	3.60
4/16/20 18:13	240.07	28.00	10.52	14.32	168.56	1176.47	3.60
4/16/20 18:14	240.70	27.96	10.52	14.15	163.91	1177.07	3.60
4/16/20 18:15	240.23	27.96	10.52	14.25	167.92	1176.05	3.60
4/16/20 18:16	240.59	28.02	10.52	14.17	168.59	1176.54	3.61
4/16/20 18:17	240.43	28.05	10.52	14.20	163.71	1176.66	3.61
4/16/20 18:18	240.52	28.04	10.52	14.27	166.95	1176.79	3.61
4/16/20 18:19	240.69	28.03	10.52	14.17	169.77	1176.92	3.61
4/16/20 18:20	240.43	28.03	10.52	14.13	166.86	1176.40	3.61
4/16/20 18:21	240.77	28.14	10.52	14.09	163.51	1176.57	3.61
4/16/20 18:22	240.62	27.97	10.52	14.00	169.72	1176.68	3.61
4/16/20 18:23	240.39	28.02	10.52	14.22	167.33	1177.10	3.61
4/16/20 18:24	240.78	28.06	10.52	14.03	160.41	1176.91	3.61
4/16/20 18:25	240.08	28.04	10.52	14.23	161.43	1176.20	3.61
4/16/20 18:26	240.30	28.00	10.52	14.20	163.65	1176.18	3.61
4/16/20 18:27	240.42	27.96	10.52	14.41	164.38	1176.38	3.61
4/16/20 18:28	240.49	28.03	10.52	14.09	167.26	1176.55	3.61
4/16/20 18:29	240.34	28.02	10.52	14.22	166.85	1176.93	3.61
4/16/20 18:30	240.63	28.16	10.52	14.32	160.82	1176.68	3.61
4/16/20 18:31	240.16	28.00	10.52	14.31	160.98	1175.87	3.61
4/16/20 18:32	240.54	28.03	10.52	14.11	159.35	1176.14	3.61
4/16/20 18:33	240.45	28.00	10.52	14.19	163.03	1176.55	3.61
4/16/20 18:34	240.34	28.10	10.53	14.18	164.55	1176.77	3.61
4/16/20 18:35	240.65	28.04	10.53	14.23	168.35	1177.08	3.62
4/16/20 18:36	240.37	28.01	10.53	14.16	167.04	1176.59	3.62
4/16/20 18:37	241.02	28.01	10.53	14.25	170.35	1176.36	3.62
4/16/20 18:38	240.57	28.07	10.53	13.93	166.95	1176.61	3.62
4/16/20 18:39	240.72	28.08	10.53	14.28	168.19	1177.13	3.62
4/16/20 18:40	240.89	27.98	10.53	14.17	168.65	1176.95	3.62

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
PM_{10}

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 12:23 - 4/16 16:49)		240.19	28.00	10.46	14.20	163.87	1175.97	3.56
COUNT = 267								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/16/20 12:23	241.27	28.04	9.89	13.87	179.13	1175.62	3.62
	4/16/20 12:24	241.11	28.09	10.01	14.14	169.41	1176.91	3.62
	4/16/20 12:25	241.52	28.02	10.12	14.61	173.63	1177.78	3.62
	4/16/20 12:26	241.23	28.03	10.24	14.13	167.38	1175.87	3.62
	4/16/20 12:27	241.56	27.99	10.36	13.96	165.06	1175.82	3.62
	4/16/20 12:28	240.90	28.11	10.43	14.70	178.53	1176.20	3.62
	4/16/20 12:29	241.49	28.11	10.43	14.63	179.36	1176.93	3.62
	4/16/20 12:30	241.45	28.05	10.43	14.17	169.47	1175.67	3.62
	4/16/20 12:31	241.47	28.04	10.43	14.17	169.47	1176.15	3.62
	4/16/20 12:32	241.18	28.08	10.43	14.21	180.35	1176.10	3.62
	4/16/20 12:33	240.67	28.09	10.43	13.98	179.45	1175.77	3.62
	4/16/20 12:34	241.11	28.11	10.43	14.27	176.90	1175.82	3.62
	4/16/20 12:35	240.92	28.01	10.43	14.47	165.20	1176.40	3.62
	4/16/20 12:36	240.78	27.97	10.43	14.00	159.79	1176.43	3.61
	4/16/20 12:37	241.03	28.05	10.43	14.09	173.31	1176.21	3.61
	4/16/20 12:38	241.17	28.04	10.43	14.34	161.36	1176.24	3.61
	4/16/20 12:39	240.77	28.02	10.43	14.26	185.54	1176.31	3.61
	4/16/20 12:40	240.78	27.92	10.43	14.02	177.42	1175.92	3.61
	4/16/20 12:41	240.91	28.00	10.43	14.16	172.46	1175.79	3.61
	4/16/20 12:42	241.09	28.12	10.43	13.94	183.82	1175.79	3.61
	4/16/20 12:43	240.82	28.01	10.43	14.18	167.24	1175.28	3.61
	4/16/20 12:44	240.57	27.90	10.44	14.08	180.71	1175.23	3.61
	4/16/20 12:45	240.37	28.01	10.44	14.15	168.50	1175.94	3.61
	4/16/20 12:46	240.24	28.10	10.44	13.98	171.72	1176.42	3.61
	4/16/20 12:47	240.90	28.07	10.44	14.72	171.08	1176.51	3.61
	4/16/20 12:48	240.92	27.90	10.44	14.24	159.83	1176.49	3.61
	4/16/20 12:49	240.44	28.03	10.44	14.02	164.62	1175.22	3.61
	4/16/20 12:50	240.09	28.05	10.44	14.07	168.99	1175.20	3.61
	4/16/20 12:51	240.48	28.05	10.44	14.15	157.77	1176.44	3.61
	4/16/20 12:52	240.53	28.00	10.44	14.05	161.59	1175.69	3.61
	4/16/20 12:53	240.94	28.00	10.44	14.27	168.64	1175.95	3.61
	4/16/20 12:54	241.00	28.07	10.44	14.09	170.88	1175.79	3.61
	4/16/20 12:55	241.13	28.07	10.44	14.31	171.26	1176.77	3.60
	4/16/20 12:56	240.93	28.07	10.44	14.57	163.82	1177.40	3.60
	4/16/20 12:57	240.46	28.03	10.44	14.21	160.78	1175.56	3.60
	4/16/20 12:58	240.90	28.02	10.44	14.06	160.07	1176.78	3.60
	4/16/20 12:59	240.99	28.08	10.44	14.24	157.28	1175.64	3.60
	4/16/20 13:00	240.33	28.10	10.44	14.08	159.22	1175.85	3.60
	4/16/20 13:01	240.71	27.95	10.44	14.33	158.75	1176.06	3.60
	4/16/20 13:02	240.70	28.01	10.44	14.40	201.07	1176.63	3.60
	4/16/20 13:03	240.94	28.01	10.44	14.58	180.17	1176.12	3.60
	4/16/20 13:04	240.76	28.09	10.44	14.28	207.06	1175.51	3.60
	4/16/20 13:05	240.31	28.02	10.44	14.24	176.56	1175.51	3.60
	4/16/20 13:06	240.95	27.98	10.44	14.00	170.50	1175.93	3.60
	4/16/20 13:07	240.75	28.05	10.44	14.11	174.21	1175.18	3.60
	4/16/20 13:08	240.81	28.07	10.44	14.24	173.08	1175.72	3.60
	4/16/20 13:09	240.95	28.12	10.44	14.08	172.95	1175.65	3.60
	4/16/20 13:10	240.39	27.96	10.44	14.20	172.70	1175.16	3.60
	4/16/20 13:11	240.41	27.95	10.44	14.17	175.11	1175.28	3.60
	4/16/20 13:12	240.71	28.07	10.44	14.42	172.64	1176.26	3.60
	4/16/20 13:13	240.63	28.05	10.44	14.09	172.30	1175.95	3.60
	4/16/20 13:14	240.27	28.01	10.44	14.20	165.51	1175.18	3.60
	4/16/20 13:15	240.50	27.96	10.44	14.17	158.85	1175.33	3.59
	4/16/20 13:16	240.52	27.99	10.44	14.10	157.07	1176.35	3.59
	4/16/20 13:17	240.36	28.09	10.44	14.02	159.40	1176.62	3.59
	4/16/20 13:18	240.55	28.10	10.44	14.14	160.64	1175.92	3.59
	4/16/20 13:19	240.51	27.93	10.44	14.33	164.97	1176.02	3.59
	4/16/20 13:20	240.71	27.95	10.44	14.36	169.47	1176.66	3.59
	4/16/20 13:21	240.62	28.12	10.44	14.21	168.91	1174.62	3.59
	4/16/20 13:22	240.95	28.20	10.44	14.12	159.94	1176.07	3.59
	4/16/20 13:23	240.93	27.96	10.45	14.11	172.20	1175.86	3.59
	4/16/20 13:24	240.59	27.99	10.45	14.32	171.78	1175.73	3.59
	4/16/20 13:25	240.76	27.99	10.45	13.99	163.29	1175.08	3.59
	4/16/20 13:26	241.00	28.07	10.45	13.92	163.00	1176.40	3.59
	4/16/20 13:27	240.82	28.05	10.45	13.79	173.81	1175.94	3.59
	4/16/20 13:28	241.12	27.92	10.45	14.51	175.12	1177.21	3.59
	4/16/20 13:29	240.99	28.05	10.45	14.27	174.02	1176.04	3.59

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 12:23 - 4/16 16:49)	240.19	28.00	10.46	14.20	163.87	1175.97	3.56
COUNT = 267							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 13:30	240.88	28.05	10.45	14.39	173.52	1176.06	3.59
4/16/20 13:31	240.96	28.10	10.45	14.35	170.95	1176.56	3.59
4/16/20 13:32	241.22	27.98	10.45	14.12	164.97	1175.75	3.59
4/16/20 13:33	240.16	27.96	10.45	14.07	161.33	1175.81	3.59
4/16/20 13:34	240.94	27.97	10.45	13.86	163.13	1176.11	3.59
4/16/20 13:35	240.77	28.13	10.45	14.44	167.89	1177.22	3.58
4/16/20 13:36	240.72	28.12	10.45	14.31	177.23	1176.93	3.58
4/16/20 13:37	240.38	27.94	10.45	14.07	187.97	1175.15	3.58
4/16/20 13:38	240.55	27.83	10.45	13.95	172.14	1175.83	3.58
4/16/20 13:39	241.05	28.08	10.45	14.10	179.03	1175.49	3.58
4/16/20 13:40	241.15	28.19	10.45	14.20	164.52	1176.71	3.58
4/16/20 13:41	240.81	28.08	10.45	13.86	172.53	1175.84	3.58
4/16/20 13:42	240.56	28.04	10.45	13.98	177.37	1175.10	3.58
4/16/20 13:43	240.88	28.02	10.45	14.18	165.29	1176.29	3.58
4/16/20 13:44	240.69	28.13	10.45	14.13	160.23	1175.48	3.58
4/16/20 13:45	240.43	28.04	10.45	14.16	164.11	1175.91	3.58
4/16/20 13:46	240.62	28.02	10.45	14.15	174.27	1177.12	3.58
4/16/20 13:47	240.35	27.99	10.45	13.98	161.23	1175.38	3.58
4/16/20 13:48	240.36	28.08	10.45	14.10	161.16	1175.82	3.58
4/16/20 13:49	240.00	28.00	10.45	14.06	164.92	1175.27	3.58
4/16/20 13:50	240.65	27.97	10.45	14.07	171.59	1175.92	3.58
4/16/20 13:51	239.98	27.98	10.45	13.99	159.19	1175.41	3.58
4/16/20 13:52	240.75	27.98	10.45	13.95	154.82	1176.08	3.58
4/16/20 13:53	240.37	28.06	10.45	13.88	156.52	1176.26	3.58
4/16/20 13:54	239.81	28.01	10.45	14.05	154.35	1176.19	3.58
4/16/20 13:55	240.23	27.90	10.45	14.21	159.91	1175.95	3.57
4/16/20 13:56	240.62	28.03	10.45	14.10	162.23	1175.93	3.57
4/16/20 13:57	240.52	28.07	10.45	13.74	161.78	1175.58	3.57
4/16/20 13:58	240.93	28.12	10.45	14.03	168.36	1175.94	3.57
4/16/20 13:59	240.75	28.00	10.45	14.26	171.16	1176.20	3.57
4/16/20 14:00	240.79	27.96	10.45	14.33	163.56	1176.01	3.57
4/16/20 14:01	241.05	28.08	10.45	14.16	162.27	1176.22	3.57
4/16/20 14:02	240.67	28.17	10.46	14.25	169.06	1175.80	3.57
4/16/20 14:03	240.50	27.95	10.46	14.16	173.41	1175.88	3.57
4/16/20 14:04	240.56	28.01	10.46	14.17	165.79	1175.82	3.57
4/16/20 14:05	240.71	27.98	10.46	14.31	159.26	1175.91	3.57
4/16/20 14:06	240.89	28.12	10.46	14.27	160.78	1176.24	3.57
4/16/20 14:07	240.68	28.07	10.46	14.19	159.41	1175.94	3.57
4/16/20 14:08	240.56	27.96	10.46	14.46	159.41	1175.86	3.57
4/16/20 14:09	240.90	28.08	10.46	14.22	159.50	1176.64	3.57
4/16/20 14:10	240.37	28.08	10.46	14.34	162.17	1175.62	3.57
4/16/20 14:11	240.45	28.09	10.46	14.41	169.83	1175.71	3.57
4/16/20 14:12	240.58	27.99	10.46	14.21	169.79	1176.15	3.57
4/16/20 14:13	240.86	27.98	10.46	14.52	173.42	1176.26	3.57
4/16/20 14:14	240.73	28.10	10.46	13.95	169.17	1175.33	3.56
4/16/20 14:15	240.92	28.14	10.46	14.29	167.74	1176.75	3.56
4/16/20 14:16	240.84	28.04	10.46	14.15	168.81	1175.77	3.56
4/16/20 14:17	240.83	27.96	10.46	13.93	170.03	1175.80	3.56
4/16/20 14:18	240.91	27.96	10.46	14.27	169.49	1175.38	3.56
4/16/20 14:19	240.69	28.09	10.46	14.37	163.69	1176.03	3.56
4/16/20 14:20	240.37	28.09	10.46	14.01	166.58	1175.79	3.56
4/16/20 14:21	240.85	27.99	10.46	13.92	174.10	1176.40	3.56
4/16/20 14:22	240.59	28.05	10.46	14.18	167.11	1175.63	3.56
4/16/20 14:23	241.09	28.11	10.46	14.10	165.62	1176.20	3.56
4/16/20 14:24	240.35	28.12	10.46	14.12	172.23	1176.49	3.56
4/16/20 14:25	240.68	27.99	10.46	14.39	173.17	1176.52	3.56
4/16/20 14:26	240.09	28.04	10.46	13.98	174.46	1175.22	3.56
4/16/20 14:27	240.59	28.01	10.46	14.60	164.68	1176.22	3.56
4/16/20 14:28	239.93	28.10	10.46	14.53	162.81	1175.91	3.56
4/16/20 14:29	240.08	28.07	10.46	14.76	158.81	1176.28	3.56
4/16/20 14:30	240.43	27.98	10.46	14.26	160.86	1176.21	3.56
4/16/20 14:31	240.12	27.95	10.46	14.46	170.28	1176.04	3.56
4/16/20 14:32	240.08	28.16	10.46	14.10	160.56	1176.00	3.56
4/16/20 14:33	240.62	28.04	10.46	14.61	163.69	1176.25	3.56
4/16/20 14:34	239.79	27.95	10.46	14.01	169.69	1174.93	3.55
4/16/20 14:35	240.42	27.99	10.46	14.24	162.96	1176.03	3.55
4/16/20 14:36	240.28	28.02	10.46	14.52	163.25	1175.70	3.55

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 12:23 - 4/16 16:49)	240.19	28.00	10.46	14.20	163.87	1175.97	3.56
COUNT = 267							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 14:37	240.18	28.06	10.46	14.53	166.15	1175.59	3.55
4/16/20 14:38	240.67	28.00	10.46	14.12	157.24	1176.52	3.55
4/16/20 14:39	239.96	28.02	10.46	14.16	156.65	1175.42	3.55
4/16/20 14:40	240.37	27.99	10.46	14.25	157.29	1175.90	3.55
4/16/20 14:41	240.09	28.05	10.47	14.04	159.17	1176.19	3.55
4/16/20 14:42	239.94	28.07	10.47	14.17	164.58	1174.75	3.55
4/16/20 14:43	240.29	27.91	10.47	13.88	168.24	1175.82	3.55
4/16/20 14:44	240.23	27.99	10.47	14.55	167.11	1176.45	3.55
4/16/20 14:45	240.50	28.01	10.47	14.66	168.25	1176.53	3.55
4/16/20 14:46	240.43	28.08	10.47	14.07	170.64	1176.15	3.55
4/16/20 14:47	240.16	28.04	10.47	14.14	164.07	1175.73	3.55
4/16/20 14:48	240.11	27.95	10.47	14.23	174.75	1176.42	3.55
4/16/20 14:49	240.45	27.99	10.47	14.31	174.71	1176.40	3.55
4/16/20 14:50	240.27	28.13	10.47	14.29	172.37	1176.55	3.55
4/16/20 14:51	239.36	27.97	10.47	14.05	161.32	1174.94	3.55
4/16/20 14:52	239.25	27.88	10.47	14.09	155.33	1174.93	3.55
4/16/20 14:53	239.82	27.89	10.47	14.66	158.90	1176.81	3.55
4/16/20 14:54	239.66	28.03	10.47	14.28	164.82	1177.13	3.54
4/16/20 14:55	239.28	28.00	10.47	13.91	151.05	1176.21	3.54
4/16/20 14:56	239.61	27.93	10.47	14.21	156.80	1176.32	3.54
4/16/20 14:57	240.11	27.95	10.47	13.99	152.70	1175.28	3.54
4/16/20 14:58	240.06	28.00	10.47	14.05	150.30	1176.10	3.54
4/16/20 14:59	239.80	28.09	10.47	14.30	149.78	1176.14	3.54
4/16/20 15:00	240.02	27.97	10.47	14.02	150.95	1176.66	3.54
4/16/20 15:01	239.61	27.89	10.47	14.00	158.69	1175.32	3.54
4/16/20 15:02	239.70	27.94	10.47	14.15	165.09	1174.82	3.54
4/16/20 15:03	240.40	28.04	10.47	14.02	160.26	1176.49	3.54
4/16/20 15:04	240.09	28.07	10.47	14.21	163.84	1176.22	3.54
4/16/20 15:05	239.97	27.96	10.47	14.36	172.96	1175.86	3.54
4/16/20 15:06	239.61	27.93	10.47	14.26	172.67	1175.10	3.54
4/16/20 15:07	239.29	28.03	10.47	14.29	161.79	1175.49	3.54
4/16/20 15:08	239.11	28.03	10.47	14.23	167.23	1175.83	3.54
4/16/20 15:09	239.57	27.92	10.47	14.49	156.43	1176.90	3.54
4/16/20 15:10	239.11	27.88	10.47	14.12	164.06	1175.62	3.54
4/16/20 15:11	238.99	27.98	10.47	14.04	158.08	1175.19	3.54
4/16/20 15:12	239.31	28.02	10.47	14.13	154.89	1175.25	3.54
4/16/20 15:13	239.31	28.04	10.47	14.20	157.71	1175.49	3.53
4/16/20 15:14	239.27	27.90	10.47	14.21	148.47	1175.04	3.53
4/16/20 15:15	239.84	27.83	10.47	14.16	151.49	1176.26	3.53
4/16/20 15:16	239.82	28.03	10.47	14.03	160.97	1175.48	3.53
4/16/20 15:17	239.78	27.99	10.47	14.27	162.34	1175.99	3.53
4/16/20 15:18	239.14	27.92	10.47	14.22	156.26	1175.02	3.53
4/16/20 15:19	239.12	27.86	10.47	14.37	155.11	1175.71	3.53
4/16/20 15:20	239.32	27.95	10.48	14.29	153.61	1176.05	3.53
4/16/20 15:21	239.33	27.97	10.48	14.14	154.77	1175.49	3.53
4/16/20 15:22	239.52	27.93	10.48	14.74	149.37	1176.40	3.53
4/16/20 15:23	239.53	27.92	10.48	14.24	151.42	1176.02	3.53
4/16/20 15:24	239.57	27.88	10.48	14.53	161.55	1176.27	3.53
4/16/20 15:25	240.04	28.08	10.48	14.47	158.97	1175.61	3.53
4/16/20 15:26	239.63	28.00	10.48	14.30	164.71	1176.60	3.53
4/16/20 15:27	239.95	27.86	10.48	14.29	159.76	1176.61	3.53
4/16/20 15:28	239.58	27.92	10.48	14.29	156.58	1176.35	3.53
4/16/20 15:29	239.19	28.09	10.48	14.01	155.83	1174.60	3.53
4/16/20 15:30	239.26	28.00	10.48	13.84	161.27	1175.28	3.53
4/16/20 15:31	238.80	27.88	10.48	14.00	163.13	1174.99	3.53
4/16/20 15:32	239.23	27.84	10.48	14.00	163.12	1175.80	3.53
4/16/20 15:33	239.07	27.90	10.48	14.03	156.31	1175.43	3.52
4/16/20 15:34	239.02	28.03	10.48	14.11	150.54	1175.25	3.52
4/16/20 15:35	238.83	27.99	10.48	14.49	149.54	1175.82	3.52
4/16/20 15:36	239.46	27.87	10.48	14.15	148.83	1176.24	3.52
4/16/20 15:37	239.76	27.92	10.48	14.18	149.39	1176.35	3.52
4/16/20 15:38	239.18	27.96	10.48	14.06	150.36	1175.28	3.52
4/16/20 15:39	239.47	28.05	10.48	14.42	151.20	1176.22	3.52
4/16/20 15:40	239.61	27.87	10.48	14.18	149.24	1175.85	3.52
4/16/20 15:41	239.41	27.96	10.48	13.98	154.81	1176.09	3.52
4/16/20 15:42	239.55	27.90	10.48	14.55	165.26	1176.13	3.53
4/16/20 15:43	239.48	28.05	10.48	14.12	165.41	1176.15	3.53

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 12:23 - 4/16 16:49)	240.19	28.00	10.46	14.20	163.87	1175.97	3.56
COUNT = 267							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 15:44	239.16	27.94	10.48	14.13	155.06	1175.82	3.53
4/16/20 15:45	240.12	27.89	10.48	14.44	154.37	1176.87	3.53
4/16/20 15:46	239.70	27.92	10.48	13.97	163.93	1176.04	3.53
4/16/20 15:47	239.69	28.08	10.48	14.03	160.16	1175.61	3.53
4/16/20 15:48	239.81	27.96	10.48	14.13	154.06	1176.84	3.53
4/16/20 15:49	239.74	27.89	10.48	14.22	162.42	1176.18	3.53
4/16/20 15:50	239.57	27.97	10.48	14.26	163.11	1175.15	3.53
4/16/20 15:51	239.93	28.03	10.48	14.45	164.79	1175.44	3.53
4/16/20 15:52	239.63	27.94	10.48	13.97	164.61	1175.45	3.53
4/16/20 15:53	240.02	27.96	10.48	14.21	159.99	1176.39	3.53
4/16/20 15:54	239.52	27.91	10.48	14.15	154.80	1176.03	3.53
4/16/20 15:55	239.64	27.99	10.48	14.11	166.86	1175.84	3.53
4/16/20 15:56	239.82	28.06	10.48	14.10	158.08	1176.74	3.53
4/16/20 15:57	239.39	27.91	10.48	13.99	154.19	1175.28	3.53
4/16/20 15:58	239.72	27.89	10.48	14.43	154.32	1176.88	3.53
4/16/20 15:59	239.38	27.92	10.49	14.35	161.79	1176.43	3.53
4/16/20 16:00	239.10	28.02	10.49	14.01	151.91	1176.14	3.53
4/16/20 16:01	239.61	27.92	10.49	14.26	151.27	1175.51	3.54
4/16/20 16:02	239.64	27.87	10.49	13.98	159.59	1176.15	3.54
4/16/20 16:03	240.03	27.92	10.49	14.32	161.95	1175.66	3.54
4/16/20 16:04	239.90	28.01	10.49	14.31	161.09	1176.47	3.54
4/16/20 16:05	239.90	28.00	10.49	14.26	152.33	1175.82	3.54
4/16/20 16:06	240.22	27.96	10.49	14.34	163.69	1176.00	3.54
4/16/20 16:07	239.80	27.92	10.49	14.25	164.35	1176.56	3.54
4/16/20 16:08	239.15	28.02	10.49	13.99	165.06	1174.23	3.54
4/16/20 16:09	239.50	28.06	10.49	14.09	165.48	1175.49	3.54
4/16/20 16:10	239.74	27.95	10.49	14.03	161.66	1175.96	3.54
4/16/20 16:11	239.74	27.86	10.49	14.30	153.28	1176.58	3.54
4/16/20 16:12	239.24	27.96	10.49	14.22	153.46	1175.27	3.54
4/16/20 16:13	240.31	28.01	10.49	14.41	154.91	1176.67	3.54
4/16/20 16:14	240.02	27.94	10.49	14.62	166.52	1176.41	3.54
4/16/20 16:15	239.76	27.95	10.49	14.21	161.55	1174.94	3.54
4/16/20 16:16	239.88	27.88	10.49	14.10	167.36	1177.20	3.54
4/16/20 16:17	239.84	28.05	10.49	14.27	160.70	1175.39	3.54
4/16/20 16:18	239.86	28.15	10.49	14.15	167.20	1175.83	3.54
4/16/20 16:19	239.74	27.96	10.49	14.02	166.52	1175.59	3.54
4/16/20 16:20	239.51	27.92	10.49	14.18	162.23	1176.62	3.54
4/16/20 16:21	239.78	27.96	10.49	14.49	167.67	1176.12	3.55
4/16/20 16:22	239.62	28.07	10.49	14.43	165.14	1175.80	3.55
4/16/20 16:23	239.83	28.06	10.49	14.13	162.82	1175.18	3.55
4/16/20 16:24	239.74	27.89	10.49	13.98	160.68	1175.60	3.55
4/16/20 16:25	239.51	27.95	10.49	14.12	154.99	1175.52	3.55
4/16/20 16:26	240.01	28.02	10.49	14.38	154.84	1176.78	3.55
4/16/20 16:27	239.62	28.03	10.49	14.20	154.29	1175.71	3.55
4/16/20 16:28	240.22	27.94	10.49	14.34	160.14	1176.75	3.55
4/16/20 16:29	239.96	27.93	10.49	14.30	166.92	1176.09	3.55
4/16/20 16:30	240.21	28.04	10.49	14.49	159.07	1176.46	3.55
4/16/20 16:31	240.33	28.07	10.49	14.26	158.88	1176.02	3.55
4/16/20 16:32	239.90	28.00	10.49	14.41	170.56	1176.27	3.55
4/16/20 16:33	240.07	27.93	10.49	14.62	163.82	1176.57	3.55
4/16/20 16:34	240.02	27.97	10.49	14.45	165.09	1177.25	3.55
4/16/20 16:35	239.50	28.10	10.49	14.22	163.17	1176.01	3.55
4/16/20 16:36	239.63	28.00	10.49	14.20	158.13	1175.99	3.55
4/16/20 16:37	239.59	27.93	10.49	13.84	157.15	1175.29	3.55
4/16/20 16:38	239.41	27.92	10.50	14.41	156.91	1176.04	3.55
4/16/20 16:39	239.67	28.06	10.50	14.07	160.21	1175.57	3.55
4/16/20 16:40	239.81	28.03	10.50	13.99	157.46	1176.50	3.56
4/16/20 16:41	239.37	27.88	10.50	14.32	152.93	1175.69	3.56
4/16/20 16:42	239.14	27.90	10.50	13.95	150.76	1175.62	3.56
4/16/20 16:43	239.28	27.94	10.50	14.20	151.75	1176.47	3.56
4/16/20 16:44	239.56	28.03	10.50	14.32	159.30	1176.39	3.56
4/16/20 16:45	239.85	28.01	10.50	14.23	158.65	1176.45	3.56
4/16/20 16:46	239.27	27.85	10.50	14.21	152.69	1175.69	3.56
4/16/20 16:47	239.13	27.84	10.50	14.31	149.95	1175.77	3.56
4/16/20 16:48	239.59	28.08	10.50	14.12	149.49	1176.46	3.56
4/16/20 16:49	239.44	27.98	10.50	13.94	152.51	1176.24	3.56

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 4:15 - 4/17 8:34)		244.92	28.45	10.63	14.25	193.21	1182.61	3.71
COUNT = 260								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 4:15	244.34	28.29	10.66	14.29	197.56	1180.91	3.73
	4/17/20 4:16	244.86	28.33	10.66	14.08	190.04	1181.15	3.73
	4/17/20 4:17	244.93	28.39	10.66	14.25	186.02	1181.03	3.73
	4/17/20 4:18	244.83	28.46	10.66	14.20	192.89	1181.24	3.73
	4/17/20 4:19	244.57	28.39	10.66	14.19	188.79	1181.19	3.73
	4/17/20 4:20	244.81	28.33	10.66	14.24	199.49	1181.94	3.73
	4/17/20 4:21	244.76	28.41	10.66	14.25	183.77	1181.44	3.73
	4/17/20 4:22	244.75	28.43	10.66	14.17	190.98	1181.67	3.73
	4/17/20 4:23	244.82	28.40	10.66	14.34	198.85	1181.39	3.73
	4/17/20 4:24	244.77	28.32	10.66	14.41	185.37	1181.84	3.73
	4/17/20 4:25	245.03	28.39	10.66	14.14	189.57	1181.29	3.73
	4/17/20 4:26	244.58	28.51	10.66	14.16	195.36	1181.51	3.73
	4/17/20 4:27	244.25	28.45	10.66	14.08	187.27	1180.82	3.73
	4/17/20 4:28	245.08	28.44	10.66	14.04	202.59	1181.85	3.73
	4/17/20 4:29	244.76	28.37	10.66	14.10	190.58	1181.22	3.73
	4/17/20 4:30	244.31	28.37	10.66	14.01	195.82	1181.41	3.73
	4/17/20 4:31	244.65	28.48	10.66	14.33	199.61	1181.96	3.72
	4/17/20 4:32	244.85	28.40	10.66	14.07	197.82	1182.00	3.72
	4/17/20 4:33	245.02	28.37	10.66	14.03	198.55	1181.54	3.72
	4/17/20 4:34	244.99	28.42	10.66	14.29	204.00	1182.48	3.72
	4/17/20 4:35	244.79	28.45	10.66	14.20	204.91	1182.40	3.72
	4/17/20 4:36	244.67	28.44	10.66	14.08	202.18	1181.55	3.72
	4/17/20 4:37	245.09	28.35	10.66	14.30	201.73	1181.53	3.72
	4/17/20 4:38	244.69	28.35	10.66	14.11	200.67	1181.45	3.72
	4/17/20 4:39	244.57	28.42	10.66	14.12	198.94	1181.32	3.72
	4/17/20 4:40	244.74	28.40	10.66	14.21	197.01	1180.97	3.72
	4/17/20 4:41	244.65	28.39	10.66	14.00	191.63	1181.78	3.72
	4/17/20 4:42	244.56	28.36	10.66	14.03	189.44	1181.68	3.72
	4/17/20 4:43	245.01	28.35	10.66	13.99	178.65	1181.99	3.72
	4/17/20 4:44	245.18	28.42	10.66	14.17	178.55	1181.91	3.72
	4/17/20 4:45	244.77	28.39	10.66	14.19	186.12	1181.94	3.72
	4/17/20 4:46	244.63	28.38	10.66	14.43	191.60	1182.05	3.72
	4/17/20 4:47	244.99	28.35	10.66	14.21	193.05	1181.19	3.72
	4/17/20 4:48	244.97	28.42	10.66	14.15	199.66	1181.93	3.72
	4/17/20 4:49	244.53	28.41	10.66	14.15	200.15	1181.31	3.72
	4/17/20 4:50	244.72	28.34	10.66	14.22	200.23	1182.10	3.72
	4/17/20 4:51	245.21	28.30	10.66	14.45	200.81	1182.73	3.72
	4/17/20 4:52	245.01	28.45	10.66	14.29	201.28	1181.65	3.72
	4/17/20 4:53	244.58	28.57	10.66	14.23	200.95	1181.20	3.72
	4/17/20 4:54	245.09	28.41	10.65	14.51	197.96	1182.36	3.72
	4/17/20 4:55	244.78	28.32	10.65	14.13	184.58	1181.73	3.72
	4/17/20 4:56	244.76	28.44	10.65	14.30	185.89	1181.72	3.72
	4/17/20 4:57	244.89	28.45	10.65	14.21	190.65	1181.79	3.72
	4/17/20 4:58	244.74	28.40	10.65	14.25	198.04	1181.11	3.72
	4/17/20 4:59	244.75	28.35	10.65	14.10	198.18	1181.10	3.72
	4/17/20 5:00	244.82	28.32	10.65	14.04	201.23	1181.48	3.72
	4/17/20 5:01	244.90	28.47	10.65	14.04	199.31	1181.68	3.72
	4/17/20 5:02	244.74	28.46	10.65	14.30	197.42	1180.89	3.72
	4/17/20 5:03	245.03	28.34	10.65	13.86	190.71	1181.76	3.72
	4/17/20 5:04	244.77	28.36	10.65	14.38	189.66	1181.50	3.72
	4/17/20 5:05	245.21	28.41	10.65	14.04	180.60	1182.04	3.72
	4/17/20 5:06	244.77	28.50	10.65	14.44	179.66	1181.35	3.72
	4/17/20 5:07	244.58	28.35	10.65	14.27	194.83	1181.70	3.72
	4/17/20 5:08	245.16	28.31	10.65	14.41	198.60	1183.01	3.72
	4/17/20 5:09	244.20	28.37	10.65	14.39	185.98	1180.74	3.72
	4/17/20 5:10	244.81	28.45	10.65	14.19	188.30	1180.86	3.72
	4/17/20 5:11	244.66	28.41	10.65	14.32	200.79	1181.36	3.72
	4/17/20 5:12	244.64	28.35	10.65	14.20	190.61	1181.25	3.72
	4/17/20 5:13	244.66	28.38	10.65	14.14	190.24	1180.67	3.72
	4/17/20 5:14	244.88	28.52	10.65	14.04	201.23	1181.50	3.72
	4/17/20 5:15	244.99	28.44	10.65	14.35	192.53	1182.51	3.72
	4/17/20 5:16	244.54	28.45	10.65	14.11	201.60	1180.84	3.72
	4/17/20 5:17	244.66	28.44	10.65	14.01	200.18	1181.47	3.72
	4/17/20 5:18	244.66	28.46	10.65	14.42	205.76	1181.52	3.72
	4/17/20 5:19	245.25	28.50	10.65	14.13	199.76	1182.40	3.72
	4/17/20 5:20	244.95	28.43	10.65	14.45	188.21	1182.07	3.72
	4/17/20 5:21	244.70	28.33	10.65	14.17	194.36	1181.38	3.72

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 4:15 - 4/17 8:34)		244.92	28.45	10.63	14.25	193.21	1182.61	3.71
COUNT = 260								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 5:22	244.84	28.48	10.65	14.02	201.37	1180.88	3.72
	4/17/20 5:23	244.96	28.53	10.65	14.24	205.51	1181.20	3.72
	4/17/20 5:24	245.00	28.41	10.65	14.07	201.40	1182.15	3.72
	4/17/20 5:25	244.81	28.40	10.65	14.14	187.31	1182.33	3.72
	4/17/20 5:26	244.95	28.44	10.65	14.39	192.73	1182.57	3.72
	4/17/20 5:27	244.26	28.48	10.65	14.29	201.40	1180.54	3.72
	4/17/20 5:28	244.58	28.47	10.65	14.18	191.17	1181.71	3.72
	4/17/20 5:29	245.07	28.34	10.65	14.45	190.46	1182.32	3.72
	4/17/20 5:30	245.11	28.44	10.65	14.20	199.09	1181.16	3.72
	4/17/20 5:31	244.78	28.46	10.65	14.67	188.74	1182.10	3.72
	4/17/20 5:32	245.32	28.46	10.65	14.27	185.62	1182.30	3.72
	4/17/20 5:33	245.16	28.48	10.65	14.33	181.81	1181.78	3.72
	4/17/20 5:34	244.88	28.39	10.65	14.05	191.42	1181.36	3.72
	4/17/20 5:35	245.23	28.48	10.65	14.23	201.64	1182.57	3.72
	4/17/20 5:36	244.94	28.57	10.65	14.27	196.92	1181.55	3.72
	4/17/20 5:37	245.11	28.55	10.64	14.35	192.62	1182.36	3.72
	4/17/20 5:38	245.15	28.41	10.64	14.42	186.67	1182.05	3.72
	4/17/20 5:39	245.27	28.42	10.64	14.14	200.26	1182.06	3.72
	4/17/20 5:40	244.79	28.45	10.64	14.47	205.97	1181.81	3.72
	4/17/20 5:41	244.79	28.53	10.64	14.25	204.30	1181.92	3.72
	4/17/20 5:42	245.07	28.50	10.64	14.21	198.56	1181.78	3.72
	4/17/20 5:43	245.62	28.46	10.64	14.69	191.08	1182.49	3.72
	4/17/20 5:44	245.30	28.42	10.64	14.54	191.66	1182.23	3.71
	4/17/20 5:45	245.24	28.53	10.64	14.07	205.12	1181.21	3.71
	4/17/20 5:46	245.78	28.43	10.64	14.76	194.95	1183.28	3.71
	4/17/20 5:47	245.16	28.38	10.64	14.49	195.83	1182.20	3.71
	4/17/20 5:48	245.20	28.49	10.64	14.40	204.89	1182.00	3.71
	4/17/20 5:49	244.86	28.41	10.64	14.22	196.45	1180.95	3.71
	4/17/20 5:50	245.24	28.57	10.64	13.95	188.16	1182.04	3.71
	4/17/20 5:51	245.14	28.43	10.64	14.39	198.89	1182.49	3.71
	4/17/20 5:52	245.17	28.46	10.64	14.27	205.38	1182.43	3.71
	4/17/20 5:53	245.23	28.39	10.64	14.36	203.60	1181.72	3.71
	4/17/20 5:54	245.57	28.59	10.64	14.11	196.36	1182.28	3.71
	4/17/20 5:55	245.40	28.49	10.64	14.20	192.38	1181.92	3.71
	4/17/20 5:56	245.38	28.44	10.64	14.29	195.99	1181.76	3.71
	4/17/20 5:57	245.15	28.50	10.64	14.32	202.26	1181.65	3.71
	4/17/20 5:58	245.36	28.58	10.64	14.24	208.96	1181.78	3.71
	4/17/20 5:59	245.59	28.57	10.64	14.15	206.73	1181.87	3.71
	4/17/20 6:00	245.58	28.46	10.64	14.31	209.02	1182.02	3.71
	4/17/20 6:01	245.46	28.44	10.64	14.56	210.04	1182.40	3.71
	4/17/20 6:02	245.41	28.54	10.64	14.78	208.75	1182.67	3.71
	4/17/20 6:03	245.41	28.54	10.64	14.07	207.21	1182.32	3.71
	4/17/20 6:04	245.65	28.46	10.64	14.13	211.77	1182.35	3.71
	4/17/20 6:05	245.62	28.48	10.64	14.32	215.44	1181.98	3.71
	4/17/20 6:06	245.62	28.52	10.64	14.39	214.31	1182.70	3.71
	4/17/20 6:07	245.93	28.54	10.64	14.55	197.26	1182.34	3.71
	4/17/20 6:08	245.56	28.55	10.64	14.49	196.64	1181.85	3.71
	4/17/20 6:09	245.60	28.41	10.64	14.20	191.06	1182.64	3.71
	4/17/20 6:10	245.72	28.52	10.64	14.22	190.69	1182.35	3.71
	4/17/20 6:11	245.74	28.58	10.64	14.38	189.11	1182.50	3.71
	4/17/20 6:12	245.61	28.58	10.64	14.35	199.05	1182.48	3.71
	4/17/20 6:13	245.05	28.52	10.64	14.20	209.88	1182.71	3.71
	4/17/20 6:14	246.38	28.47	10.64	14.47	203.69	1183.67	3.71
	4/17/20 6:15	245.60	28.56	10.64	14.11	197.44	1181.96	3.71
	4/17/20 6:16	245.70	28.66	10.64	14.46	206.17	1183.05	3.71
	4/17/20 6:17	246.21	28.58	10.64	14.31	203.23	1182.07	3.71
	4/17/20 6:18	245.80	28.47	10.64	14.38	216.69	1182.45	3.71
	4/17/20 6:19	245.69	28.54	10.64	14.10	216.03	1182.64	3.71
	4/17/20 6:20	245.99	28.64	10.64	14.46	197.06	1182.75	3.71
	4/17/20 6:21	246.33	28.58	10.63	14.25	196.62	1183.16	3.71
	4/17/20 6:22	245.69	28.54	10.63	14.35	210.86	1182.63	3.71
	4/17/20 6:23	245.81	28.55	10.63	14.17	223.37	1182.13	3.71
	4/17/20 6:24	246.17	28.60	10.63	14.24	219.61	1183.34	3.71
	4/17/20 6:25	245.69	28.64	10.63	14.54	204.91	1183.13	3.71
	4/17/20 6:26	246.40	28.60	10.63	14.45	198.30	1183.00	3.71
	4/17/20 6:27	245.96	28.51	10.63	14.18	206.28	1182.98	3.71
	4/17/20 6:28	245.50	28.51	10.63	14.30	211.47	1182.28	3.71

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 4:15 - 4/17 8:34)		244.92	28.45	10.63	14.25	193.21	1182.61	3.71
COUNT = 260								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 6:29	246.08	28.67	10.63	14.41	214.22	1183.37	3.71
	4/17/20 6:30	246.06	28.59	10.63	14.20	224.57	1182.63	3.71
	4/17/20 6:31	246.37	28.43	10.63	14.30	229.82	1182.80	3.71
	4/17/20 6:32	245.69	28.65	10.63	14.45	225.07	1182.85	3.71
	4/17/20 6:33	246.35	28.60	10.63	14.35	223.84	1183.56	3.71
	4/17/20 6:34	246.13	28.71	10.63	14.45	222.97	1183.72	3.71
	4/17/20 6:35	246.03	28.55	10.63	14.13	226.89	1182.27	3.71
	4/17/20 6:36	245.80	28.51	10.63	14.14	224.27	1181.93	3.71
	4/17/20 6:37	246.33	28.58	10.63	14.27	211.55	1182.98	3.71
	4/17/20 6:38	246.41	28.69	10.63	14.39	193.03	1183.15	3.71
	4/17/20 6:39	245.84	28.63	10.63	14.44	219.34	1182.91	3.71
	4/17/20 6:40	246.48	28.57	10.63	14.19	197.14	1183.00	3.71
	4/17/20 6:41	245.93	28.59	10.63	14.10	203.50	1182.71	3.71
	4/17/20 6:42	245.78	28.66	10.63	14.61	210.49	1183.80	3.71
	4/17/20 6:43	245.95	28.57	10.63	14.41	197.23	1184.13	3.71
	4/17/20 6:44	246.07	28.55	10.63	14.03	210.22	1183.15	3.71
	4/17/20 6:45	245.44	28.52	10.63	14.28	197.52	1182.95	3.71
	4/17/20 6:46	245.64	28.57	10.63	14.18	198.33	1182.49	3.71
	4/17/20 6:47	245.45	28.51	10.63	14.28	209.09	1182.70	3.71
	4/17/20 6:48	245.42	28.47	10.63	14.27	189.61	1183.67	3.71
	4/17/20 6:49	244.90	28.48	10.63	14.24	191.74	1181.99	3.71
	4/17/20 6:50	245.67	28.54	10.63	14.50	197.04	1183.80	3.71
	4/17/20 6:51	245.17	28.57	10.63	14.09	201.42	1183.12	3.71
	4/17/20 6:52	245.42	28.51	10.63	14.40	206.04	1183.92	3.71
	4/17/20 6:53	245.38	28.43	10.63	14.17	196.81	1183.57	3.71
	4/17/20 6:54	245.00	28.56	10.63	14.40	183.87	1184.05	3.71
	4/17/20 6:55	245.45	28.52	10.63	14.32	196.58	1183.33	3.71
	4/17/20 6:56	244.85	28.56	10.63	14.41	205.60	1183.32	3.70
	4/17/20 6:57	245.03	28.44	10.63	14.18	191.78	1182.52	3.70
	4/17/20 6:58	244.85	28.44	10.63	14.27	185.59	1182.34	3.70
	4/17/20 6:59	244.75	28.55	10.63	14.43	189.22	1182.99	3.70
	4/17/20 7:00	245.23	28.57	10.63	14.29	204.76	1183.32	3.70
	4/17/20 7:01	245.11	28.51	10.63	14.37	191.42	1182.84	3.70
	4/17/20 7:02	245.36	28.44	10.63	14.41	178.14	1183.06	3.70
	4/17/20 7:03	245.24	28.55	10.63	14.22	193.66	1182.98	3.70
	4/17/20 7:04	245.20	28.59	10.62	14.14	201.99	1183.24	3.70
	4/17/20 7:05	245.03	28.48	10.62	14.10	202.09	1183.89	3.70
	4/17/20 7:06	245.00	28.44	10.62	14.12	199.31	1183.41	3.70
	4/17/20 7:07	244.97	28.54	10.62	14.13	183.91	1182.99	3.70
	4/17/20 7:08	244.79	28.58	10.62	14.01	179.01	1183.38	3.70
	4/17/20 7:09	244.86	28.46	10.62	14.09	173.81	1182.82	3.70
	4/17/20 7:10	244.49	28.39	10.62	14.10	184.82	1183.15	3.70
	4/17/20 7:11	244.25	28.46	10.62	14.00	185.23	1182.86	3.70
	4/17/20 7:12	244.64	28.53	10.62	14.21	185.73	1182.65	3.70
	4/17/20 7:13	244.72	28.51	10.62	14.11	192.23	1182.54	3.70
	4/17/20 7:14	244.68	28.37	10.62	13.95	192.91	1183.67	3.70
	4/17/20 7:15	244.38	28.42	10.62	14.02	193.79	1183.14	3.70
	4/17/20 7:16	244.77	28.49	10.62	14.04	193.60	1183.46	3.70
	4/17/20 7:17	245.07	28.49	10.62	14.36	191.05	1183.28	3.70
	4/17/20 7:18	244.72	28.37	10.62	14.04	185.52	1183.56	3.70
	4/17/20 7:19	244.47	28.41	10.62	14.41	184.12	1183.08	3.70
	4/17/20 7:20	244.74	28.45	10.62	14.44	175.03	1183.40	3.70
	4/17/20 7:21	244.76	28.49	10.62	14.42	178.04	1183.76	3.70
	4/17/20 7:22	244.87	28.42	10.62	14.31	190.05	1182.78	3.70
	4/17/20 7:23	244.36	28.33	10.62	14.25	179.57	1183.36	3.70
	4/17/20 7:24	244.60	28.43	10.62	14.07	183.04	1183.37	3.70
	4/17/20 7:25	244.85	28.42	10.62	14.30	175.60	1183.37	3.70
	4/17/20 7:26	244.26	28.38	10.62	13.97	174.44	1182.38	3.70
	4/17/20 7:27	243.98	28.39	10.62	14.40	187.69	1182.97	3.70
	4/17/20 7:28	244.78	28.39	10.62	14.23	185.28	1182.43	3.70
	4/17/20 7:29	244.70	28.46	10.62	14.15	173.12	1183.19	3.70
	4/17/20 7:30	244.58	28.48	10.62	13.92	185.85	1183.01	3.70
	4/17/20 7:31	244.47	28.39	10.62	14.09	176.22	1182.79	3.70
	4/17/20 7:32	244.40	28.43	10.62	14.09	185.07	1183.19	3.70
	4/17/20 7:33	244.42	28.43	10.62	14.08	175.55	1183.47	3.70
	4/17/20 7:34	244.14	28.51	10.62	14.02	192.19	1183.78	3.70
	4/17/20 7:35	244.37	28.41	10.62	14.30	180.06	1183.36	3.70

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 4:15 - 4/17 8:34)		244.92	28.45	10.63	14.25	193.21	1182.61	3.71
COUNT = 260								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 7:36	244.59	28.40	10.62	14.02	191.79	1183.54	3.70
	4/17/20 7:37	244.79	28.39	10.62	14.16	178.97	1182.45	3.70
	4/17/20 7:38	244.62	28.46	10.62	14.60	195.41	1184.00	3.70
	4/17/20 7:39	244.84	28.51	10.62	13.95	185.94	1183.56	3.70
	4/17/20 7:40	244.91	28.39	10.62	14.21	184.91	1183.58	3.70
	4/17/20 7:41	244.73	28.43	10.62	14.00	192.12	1183.77	3.70
	4/17/20 7:42	244.70	28.45	10.62	14.32	175.79	1183.78	3.70
	4/17/20 7:43	244.74	28.58	10.62	14.21	185.87	1184.09	3.70
	4/17/20 7:44	244.36	28.39	10.62	14.04	192.23	1183.22	3.70
	4/17/20 7:45	244.32	28.31	10.62	14.18	190.47	1183.34	3.70
	4/17/20 7:46	244.67	28.41	10.62	14.11	181.12	1183.34	3.70
	4/17/20 7:47	244.32	28.46	10.61	14.55	171.40	1184.40	3.70
	4/17/20 7:48	244.61	28.38	10.61	14.00	173.06	1183.33	3.70
	4/17/20 7:49	244.49	28.37	10.61	14.13	190.16	1183.70	3.70
	4/17/20 7:50	244.42	28.40	10.61	14.09	184.96	1183.26	3.70
	4/17/20 7:51	244.54	28.55	10.61	14.18	170.99	1184.04	3.70
	4/17/20 7:52	244.58	28.46	10.61	14.17	187.41	1184.18	3.70
	4/17/20 7:53	244.12	28.29	10.61	14.03	186.05	1183.45	3.70
	4/17/20 7:54	244.56	28.38	10.61	14.64	175.78	1184.51	3.70
	4/17/20 7:55	244.47	28.49	10.61	14.00	190.01	1184.16	3.70
	4/17/20 7:56	244.67	28.48	10.61	14.24	176.94	1184.74	3.70
	4/17/20 7:57	244.62	28.33	10.61	14.34	190.80	1184.24	3.70
	4/17/20 7:58	244.32	28.41	10.61	14.43	179.98	1183.91	3.70
	4/17/20 7:59	244.14	28.41	10.61	14.18	174.53	1183.79	3.70
	4/17/20 8:00	244.31	28.51	10.61	13.93	186.27	1183.60	3.70
	4/17/20 8:01	244.30	28.45	10.61	14.30	180.13	1183.49	3.70
	4/17/20 8:02	244.13	28.37	10.61	14.33	174.43	1183.91	3.70
	4/17/20 8:03	244.05	28.35	10.61	14.15	183.53	1183.47	3.70
	4/17/20 8:04	243.85	28.45	10.61	13.99	174.29	1183.85	3.70
	4/17/20 8:05	244.69	28.44	10.61	14.17	184.59	1183.02	3.70
	4/17/20 8:06	244.14	28.36	10.61	14.13	177.40	1183.65	3.70
	4/17/20 8:07	243.76	28.35	10.61	14.27	183.17	1183.39	3.70
	4/17/20 8:08	244.09	28.40	10.61	14.43	174.42	1183.86	3.70
	4/17/20 8:09	243.93	28.44	10.61	14.32	182.94	1183.42	3.70
	4/17/20 8:10	244.13	28.41	10.61	14.05	175.10	1183.18	3.70
	4/17/20 8:11	243.59	28.29	10.61	14.34	183.41	1184.06	3.70
	4/17/20 8:12	244.50	28.33	10.61	14.58	185.76	1184.07	3.70
	4/17/20 8:13	244.23	28.44	10.61	14.14	176.83	1183.22	3.70
	4/17/20 8:14	244.28	28.40	10.61	14.21	175.68	1184.04	3.70
	4/17/20 8:15	244.58	28.30	10.61	14.43	181.07	1183.80	3.70
	4/17/20 8:16	244.03	28.38	10.61	13.90	187.87	1182.92	3.70
	4/17/20 8:17	244.27	28.54	10.61	14.72	183.08	1184.34	3.70
	4/17/20 8:18	244.19	28.49	10.61	14.37	171.10	1183.55	3.70
	4/17/20 8:19	244.17	28.31	10.61	14.09	174.56	1182.78	3.70
	4/17/20 8:20	243.82	28.36	10.61	14.14	179.23	1183.29	3.70
	4/17/20 8:21	243.64	28.44	10.61	14.57	179.96	1183.54	3.70
	4/17/20 8:22	244.07	28.55	10.61	14.24	181.63	1183.20	3.70
	4/17/20 8:23	243.87	28.40	10.61	14.22	177.91	1183.22	3.70
	4/17/20 8:24	244.02	28.31	10.61	14.46	186.45	1184.70	3.70
	4/17/20 8:25	244.19	28.36	10.61	14.19	185.90	1183.22	3.70
	4/17/20 8:26	244.44	28.48	10.61	14.72	187.55	1184.87	3.70
	4/17/20 8:27	243.86	28.36	10.61	14.40	177.86	1183.73	3.70
	4/17/20 8:28	243.64	28.33	10.61	14.21	174.50	1182.89	3.70
	4/17/20 8:29	244.16	28.42	10.61	14.27	186.16	1182.70	3.70
	4/17/20 8:30	243.71	28.35	10.61	14.07	174.32	1183.63	3.70
	4/17/20 8:31	243.71	28.49	10.60	14.25	174.65	1183.20	3.70
	4/17/20 8:32	243.99	28.32	10.60	14.73	170.35	1183.55	3.70
	4/17/20 8:33	243.85	28.35	10.60	14.35	177.55	1182.83	3.70
	4/17/20 8:34	244.10	28.35	10.60	14.21	185.12	1184.08	3.70

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 9:35 - 4/17 14:03)	241.38	28.20	10.56	14.26	162.37	1181.05	3.70
COUNT = 269							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/17/20 9:35	242.90	28.38	10.59	14.27	158.50	1182.61	3.70
4/17/20 9:36	242.91	28.42	10.59	14.10	167.35	1182.45	3.70
4/17/20 9:37	242.76	28.19	10.59	14.54	170.35	1183.24	3.70
4/17/20 9:38	242.75	28.31	10.59	14.36	176.29	1183.11	3.70
4/17/20 9:39	242.88	28.33	10.59	14.39	162.84	1182.82	3.70
4/17/20 9:40	242.55	28.42	10.59	14.14	175.74	1182.31	3.70
4/17/20 9:41	242.54	28.26	10.59	14.45	165.93	1182.55	3.70
4/17/20 9:42	242.68	28.28	10.59	14.25	172.97	1181.90	3.70
4/17/20 9:43	242.38	28.31	10.59	14.51	179.04	1183.03	3.70
4/17/20 9:44	243.11	28.41	10.59	14.55	175.98	1183.07	3.70
4/17/20 9:45	242.98	28.29	10.59	14.20	170.19	1183.18	3.70
4/17/20 9:46	242.75	28.24	10.59	14.47	163.29	1183.28	3.70
4/17/20 9:47	242.90	28.25	10.59	13.93	173.15	1183.10	3.70
4/17/20 9:48	243.12	28.41	10.59	14.30	166.15	1183.43	3.70
4/17/20 9:49	242.99	28.34	10.59	14.25	166.48	1182.64	3.70
4/17/20 9:50	242.62	28.19	10.59	14.57	165.97	1181.91	3.70
4/17/20 9:51	243.24	28.21	10.59	14.25	163.90	1183.17	3.70
4/17/20 9:52	242.73	28.40	10.59	14.40	175.97	1183.01	3.70
4/17/20 9:53	242.49	28.35	10.59	13.91	169.83	1182.18	3.70
4/17/20 9:54	243.08	28.23	10.59	14.15	173.35	1182.70	3.70
4/17/20 9:55	242.94	28.26	10.59	14.05	168.70	1183.01	3.70
4/17/20 9:56	242.46	28.32	10.59	14.10	166.34	1182.55	3.70
4/17/20 9:57	242.52	28.39	10.58	14.16	171.63	1183.69	3.70
4/17/20 9:58	242.96	28.30	10.58	14.23	163.18	1183.32	3.70
4/17/20 9:59	242.91	28.23	10.58	14.19	175.60	1183.04	3.70
4/17/20 10:00	242.41	28.26	10.58	14.26	168.31	1182.55	3.70
4/17/20 10:01	242.49	28.33	10.58	14.42	175.44	1183.06	3.70
4/17/20 10:02	242.66	28.32	10.58	14.34	179.06	1181.90	3.70
4/17/20 10:03	242.72	28.18	10.58	14.26	180.69	1183.31	3.70
4/17/20 10:04	242.40	28.29	10.58	14.30	179.85	1182.29	3.70
4/17/20 10:05	242.35	28.37	10.58	13.91	177.35	1181.80	3.70
4/17/20 10:06	242.56	28.36	10.58	14.23	178.98	1182.20	3.70
4/17/20 10:07	242.47	28.29	10.58	14.21	170.85	1182.41	3.70
4/17/20 10:08	242.77	28.24	10.58	14.58	176.20	1182.67	3.70
4/17/20 10:09	242.54	28.33	10.58	14.44	170.12	1182.57	3.70
4/17/20 10:10	242.24	28.30	10.58	14.14	164.62	1182.93	3.70
4/17/20 10:11	242.42	28.24	10.58	14.06	157.48	1183.45	3.70
4/17/20 10:12	242.39	28.15	10.58	14.08	163.17	1182.59	3.70
4/17/20 10:13	243.18	28.28	10.58	14.39	169.46	1183.53	3.70
4/17/20 10:14	242.53	28.36	10.58	14.13	175.97	1182.37	3.70
4/17/20 10:15	242.33	28.41	10.58	14.38	167.43	1182.63	3.70
4/17/20 10:16	242.78	28.28	10.58	14.51	164.23	1182.72	3.70
4/17/20 10:17	242.66	28.25	10.58	14.08	169.12	1181.88	3.70
4/17/20 10:18	242.30	28.38	10.58	14.34	173.21	1182.86	3.70
4/17/20 10:19	242.74	28.36	10.58	13.98	167.31	1182.88	3.70
4/17/20 10:20	242.44	28.24	10.58	14.40	171.25	1181.31	3.70
4/17/20 10:21	242.68	28.23	10.58	14.08	164.29	1182.72	3.70
4/17/20 10:22	242.53	28.35	10.58	14.10	169.12	1182.73	3.70
4/17/20 10:23	242.55	28.42	10.58	14.10	174.86	1181.88	3.70
4/17/20 10:24	242.80	28.25	10.58	14.20	162.33	1182.03	3.70
4/17/20 10:25	242.86	28.22	10.58	13.95	167.14	1181.98	3.70
4/17/20 10:26	242.49	28.29	10.58	14.09	179.04	1182.37	3.70
4/17/20 10:27	242.78	28.35	10.58	14.36	171.22	1182.66	3.70
4/17/20 10:28	242.86	28.36	10.58	14.45	165.19	1182.28	3.70
4/17/20 10:29	243.39	28.24	10.58	14.28	171.50	1183.25	3.70
4/17/20 10:30	242.92	28.27	10.58	14.28	177.70	1183.33	3.70
4/17/20 10:31	242.95	28.32	10.58	14.14	171.53	1182.62	3.70
4/17/20 10:32	242.60	28.36	10.58	14.16	165.15	1182.39	3.70
4/17/20 10:33	242.63	28.21	10.58	14.08	169.12	1182.14	3.70
4/17/20 10:34	242.29	28.23	10.58	14.45	173.51	1182.52	3.70
4/17/20 10:35	242.12	28.31	10.58	14.19	172.40	1182.76	3.70
4/17/20 10:36	242.46	28.34	10.58	14.32	171.12	1182.90	3.70
4/17/20 10:37	242.33	28.23	10.58	14.35	163.08	1182.36	3.70
4/17/20 10:38	242.51	28.17	10.58	14.37	163.37	1183.25	3.70
4/17/20 10:39	242.05	28.32	10.58	14.15	163.95	1181.96	3.70
4/17/20 10:40	242.81	28.38	10.57	14.18	168.61	1181.63	3.70
4/17/20 10:41	242.78	28.36	10.57	14.24	162.23	1182.50	3.70

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 9:35 - 4/17 14:03)	241.38	28.20	10.56	14.26	162.37	1181.05	3.70
COUNT = 269							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/17/20 10:42	242.70	28.22	10.57	14.47	166.83	1182.40	3.70
4/17/20 10:43	242.67	28.13	10.57	14.41	171.73	1182.54	3.70
4/17/20 10:44	243.43	28.36	10.57	14.45	178.40	1183.13	3.70
4/17/20 10:45	242.76	28.37	10.57	14.14	165.99	1182.34	3.70
4/17/20 10:46	242.51	28.19	10.57	14.10	178.01	1181.56	3.70
4/17/20 10:47	242.29	28.24	10.57	14.15	173.78	1183.00	3.70
4/17/20 10:48	242.15	28.32	10.57	14.45	169.27	1183.14	3.70
4/17/20 10:49	242.40	28.38	10.57	14.09	177.20	1182.63	3.70
4/17/20 10:50	242.10	28.22	10.57	14.03	161.03	1181.80	3.70
4/17/20 10:51	242.03	28.15	10.57	13.99	160.48	1182.28	3.70
4/17/20 10:52	242.25	28.23	10.57	13.89	167.25	1182.21	3.70
4/17/20 10:53	242.32	28.38	10.57	14.36	169.02	1183.07	3.70
4/17/20 10:54	242.46	28.25	10.57	14.13	165.10	1182.81	3.70
4/17/20 10:55	242.56	28.14	10.57	14.03	161.00	1182.48	3.70
4/17/20 10:56	243.01	28.28	10.57	14.10	172.76	1182.31	3.70
4/17/20 10:57	242.47	28.35	10.57	14.46	164.35	1182.33	3.70
4/17/20 10:58	242.65	28.34	10.57	14.09	171.87	1182.38	3.70
4/17/20 10:59	242.71	28.25	10.57	14.16	176.19	1182.29	3.70
4/17/20 11:00	242.61	28.23	10.57	14.20	177.13	1181.81	3.70
4/17/20 11:01	243.07	28.32	10.57	14.17	172.33	1182.79	3.70
4/17/20 11:02	242.64	28.41	10.57	14.20	165.11	1183.37	3.70
4/17/20 11:03	242.27	28.26	10.57	14.15	177.69	1182.31	3.70
4/17/20 11:04	242.31	28.19	10.57	14.17	168.64	1182.77	3.70
4/17/20 11:05	243.23	28.29	10.57	14.66	166.34	1183.97	3.70
4/17/20 11:06	243.35	28.53	10.57	14.46	161.07	1183.65	3.70
4/17/20 11:07	242.49	28.29	10.57	14.38	174.44	1182.15	3.70
4/17/20 11:08	243.23	28.25	10.57	14.13	164.82	1182.99	3.70
4/17/20 11:09	242.54	28.30	10.57	14.31	165.21	1182.54	3.70
4/17/20 11:10	243.19	28.31	10.57	14.28	165.52	1182.75	3.70
4/17/20 11:11	242.53	28.42	10.57	14.47	164.84	1184.25	3.70
4/17/20 11:12	242.47	28.27	10.57	14.49	169.16	1183.32	3.70
4/17/20 11:13	242.84	28.25	10.57	14.17	166.36	1182.40	3.70
4/17/20 11:14	242.52	28.26	10.57	14.44	169.86	1183.56	3.70
4/17/20 11:15	242.46	28.41	10.57	14.23	166.21	1183.28	3.70
4/17/20 11:16	242.59	28.30	10.57	14.42	172.12	1182.35	3.70
4/17/20 11:17	242.34	28.25	10.57	14.19	161.41	1182.70	3.70
4/17/20 11:18	242.63	28.21	10.57	14.31	174.71	1182.96	3.70
4/17/20 11:19	242.13	28.25	10.57	14.23	159.83	1182.47	3.70
4/17/20 11:20	242.03	28.32	10.57	14.39	160.37	1181.98	3.70
4/17/20 11:21	241.78	28.26	10.57	14.31	171.24	1182.28	3.70
4/17/20 11:22	242.07	28.22	10.57	14.42	158.33	1182.51	3.70
4/17/20 11:23	241.96	28.27	10.57	14.00	169.58	1182.03	3.70
4/17/20 11:24	241.59	28.36	10.56	14.38	194.63	1181.88	3.70
4/17/20 11:25	242.05	28.30	10.56	14.37	199.57	1182.61	3.70
4/17/20 11:26	241.67	28.23	10.56	14.34	201.23	1181.95	3.70
4/17/20 11:27	242.01	28.26	10.56	14.10	193.18	1181.75	3.70
4/17/20 11:28	241.73	28.28	10.56	14.24	172.25	1182.28	3.70
4/17/20 11:29	242.13	28.27	10.56	14.01	179.83	1183.18	3.70
4/17/20 11:30	241.86	28.26	10.56	13.97	162.87	1181.88	3.70
4/17/20 11:31	242.20	28.17	10.56	14.48	172.40	1183.53	3.70
4/17/20 11:32	241.66	28.21	10.56	14.21	157.89	1182.11	3.70
4/17/20 11:33	242.15	28.31	10.56	14.38	171.82	1181.38	3.70
4/17/20 11:34	241.90	28.25	10.56	14.13	160.94	1181.66	3.70
4/17/20 11:35	242.30	28.21	10.56	14.26	166.35	1181.32	3.70
4/17/20 11:36	242.45	28.20	10.56	14.32	167.06	1182.16	3.70
4/17/20 11:37	242.02	28.26	10.56	14.34	160.88	1181.65	3.70
4/17/20 11:38	242.18	28.30	10.56	14.17	162.68	1182.74	3.70
4/17/20 11:39	241.78	28.23	10.56	14.29	171.06	1182.75	3.70
4/17/20 11:40	241.63	28.16	10.56	14.50	160.81	1182.36	3.70
4/17/20 11:41	241.56	28.16	10.56	14.19	166.38	1180.56	3.70
4/17/20 11:42	241.68	28.33	10.56	14.10	155.42	1181.35	3.70
4/17/20 11:43	241.93	28.21	10.56	13.99	168.70	1182.34	3.70
4/17/20 11:44	241.62	28.11	10.56	14.19	155.41	1181.69	3.70
4/17/20 11:45	242.02	28.24	10.56	14.56	163.88	1182.36	3.70
4/17/20 11:46	242.07	28.21	10.56	14.50	158.50	1181.36	3.70
4/17/20 11:47	241.23	28.29	10.56	14.02	155.97	1180.67	3.70
4/17/20 11:48	241.74	28.16	10.56	14.23	157.41	1182.07	3.70

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 9:35 - 4/17 14:03)		241.38	28.20	10.56	14.26	162.37	1181.05	3.70
COUNT = 269								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 11:49	241.46	28.19	10.56	14.45	161.43	1181.44	3.70
	4/17/20 11:50	241.54	28.28	10.56	13.92	169.47	1181.17	3.70
	4/17/20 11:51	241.35	28.24	10.56	14.30	154.69	1181.38	3.70
	4/17/20 11:52	241.30	28.19	10.56	14.24	160.67	1181.23	3.70
	4/17/20 11:53	241.67	28.21	10.56	14.10	162.86	1181.36	3.70
	4/17/20 11:54	241.59	28.19	10.56	14.50	157.91	1181.66	3.70
	4/17/20 11:55	241.79	28.31	10.56	14.29	166.05	1182.02	3.70
	4/17/20 11:56	241.46	28.22	10.56	13.98	153.95	1180.91	3.70
	4/17/20 11:57	241.52	28.16	10.56	14.44	167.57	1181.98	3.70
	4/17/20 11:58	241.27	28.12	10.56	14.65	167.14	1182.26	3.70
	4/17/20 11:59	241.14	28.26	10.56	14.32	156.36	1180.38	3.70
	4/17/20 12:00	241.59	28.28	10.56	14.23	166.83	1180.96	3.70
	4/17/20 12:01	241.00	28.17	10.56	14.11	154.69	1180.78	3.70
	4/17/20 12:02	241.32	28.13	10.56	14.31	166.92	1180.93	3.70
	4/17/20 12:03	241.27	28.21	10.56	14.54	161.16	1181.04	3.70
	4/17/20 12:04	241.49	28.25	10.56	14.11	155.46	1181.12	3.70
	4/17/20 12:05	241.63	28.29	10.56	14.48	157.62	1181.83	3.70
	4/17/20 12:06	242.13	28.18	10.56	14.22	156.55	1181.44	3.70
	4/17/20 12:07	242.05	28.21	10.56	14.29	162.48	1181.21	3.70
	4/17/20 12:08	241.36	28.29	10.56	14.11	164.83	1181.77	3.70
	4/17/20 12:09	241.33	28.27	10.56	14.36	168.74	1180.75	3.70
	4/17/20 12:10	241.12	28.15	10.56	14.54	159.53	1181.59	3.70
	4/17/20 12:11	241.18	28.17	10.56	14.38	164.87	1182.25	3.70
	4/17/20 12:12	241.52	28.20	10.56	14.13	159.32	1182.13	3.70
	4/17/20 12:13	241.35	28.29	10.56	14.15	153.46	1180.75	3.70
	4/17/20 12:14	241.80	28.24	10.56	14.32	155.20	1180.56	3.70
	4/17/20 12:15	241.30	28.17	10.56	13.92	160.77	1180.71	3.70
	4/17/20 12:16	241.17	28.19	10.56	14.56	165.49	1182.10	3.70
	4/17/20 12:17	241.68	28.24	10.56	14.12	165.76	1181.53	3.70
	4/17/20 12:18	241.70	28.24	10.56	13.91	157.41	1181.10	3.70
	4/17/20 12:19	240.76	28.14	10.56	13.90	157.09	1180.87	3.70
	4/17/20 12:20	240.92	28.18	10.56	14.05	156.97	1180.66	3.70
	4/17/20 12:21	241.01	28.20	10.56	14.17	164.55	1180.81	3.70
	4/17/20 12:22	240.68	28.17	10.56	14.36	150.94	1180.55	3.70
	4/17/20 12:23	240.81	28.13	10.56	14.22	160.86	1180.50	3.70
	4/17/20 12:24	240.46	28.11	10.56	14.42	148.74	1179.89	3.70
	4/17/20 12:25	240.94	28.23	10.56	14.30	158.05	1180.96	3.70
	4/17/20 12:26	240.74	28.18	10.56	14.22	154.27	1180.24	3.70
	4/17/20 12:27	240.69	28.18	10.55	14.10	162.85	1179.62	3.70
	4/17/20 12:28	240.51	28.12	10.55	14.21	150.09	1180.02	3.70
	4/17/20 12:29	240.42	28.09	10.55	14.62	152.80	1180.89	3.70
	4/17/20 12:30	240.77	28.19	10.55	14.09	161.74	1180.67	3.70
	4/17/20 12:31	240.54	28.22	10.55	14.27	148.48	1180.58	3.70
	4/17/20 12:32	240.49	28.07	10.55	14.60	159.37	1180.76	3.70
	4/17/20 12:33	240.80	28.12	10.55	14.31	158.19	1181.20	3.70
	4/17/20 12:34	240.66	28.22	10.55	14.21	160.51	1179.89	3.70
	4/17/20 12:35	240.81	28.24	10.55	14.08	148.43	1180.02	3.70
	4/17/20 12:36	240.48	28.14	10.55	14.12	160.27	1180.17	3.70
	4/17/20 12:37	240.42	28.11	10.55	14.40	162.38	1180.71	3.70
	4/17/20 12:38	240.47	28.07	10.55	14.24	158.33	1180.17	3.70
	4/17/20 12:39	240.61	28.16	10.55	14.02	150.71	1179.57	3.70
	4/17/20 12:40	240.39	28.21	10.55	14.24	150.94	1179.62	3.70
	4/17/20 12:41	240.75	28.09	10.55	14.04	156.87	1179.41	3.70
	4/17/20 12:42	240.89	28.10	10.55	14.03	153.78	1179.88	3.70
	4/17/20 12:43	241.20	28.18	10.55	14.14	154.50	1181.54	3.70
	4/17/20 12:44	240.97	28.22	10.55	14.15	151.27	1179.95	3.70
	4/17/20 12:45	240.60	28.06	10.55	14.88	157.20	1180.53	3.70
	4/17/20 12:46	240.43	28.10	10.55	14.17	163.46	1179.49	3.70
	4/17/20 12:47	241.07	28.11	10.55	14.21	162.67	1179.93	3.70
	4/17/20 12:48	240.70	28.14	10.55	14.28	159.54	1179.52	3.70
	4/17/20 12:49	240.20	28.21	10.55	14.44	156.93	1179.79	3.70
	4/17/20 12:50	240.09	28.07	10.55	14.50	152.66	1179.36	3.70
	4/17/20 12:51	239.83	28.02	10.55	14.00	150.37	1180.03	3.70
	4/17/20 12:52	239.93	28.13	10.55	14.12	150.92	1179.19	3.70
	4/17/20 12:53	240.12	28.10	10.55	14.02	146.79	1179.66	3.70
	4/17/20 12:54	239.48	27.99	10.55	14.49	159.18	1178.96	3.70
	4/17/20 12:55	240.08	28.03	10.55	14.09	147.23	1179.16	3.70

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 9:35 - 4/17 14:03)	241.38	28.20	10.56	14.26	162.37	1181.05	3.70
COUNT = 269							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/17/20 12:56	240.20	28.09	10.55	14.16	156.36	1178.87	3.70
4/17/20 12:57	240.29	28.15	10.55	14.56	162.13	1180.20	3.70
4/17/20 12:58	240.41	28.07	10.55	14.39	160.80	1179.49	3.70
4/17/20 12:59	240.88	28.09	10.55	14.44	161.91	1179.95	3.70
4/17/20 13:00	240.49	28.12	10.55	14.31	161.66	1179.14	3.70
4/17/20 13:01	240.02	28.12	10.55	14.36	152.45	1178.47	3.70
4/17/20 13:02	240.07	28.15	10.55	14.66	154.29	1180.40	3.70
4/17/20 13:03	239.77	28.08	10.55	14.22	152.60	1178.95	3.70
4/17/20 13:04	239.70	28.07	10.55	14.17	149.48	1178.77	3.70
4/17/20 13:05	239.67	28.13	10.55	14.36	161.21	1179.15	3.70
4/17/20 13:06	240.14	28.13	10.55	14.30	160.85	1178.59	3.70
4/17/20 13:07	239.60	28.06	10.55	14.36	149.52	1178.85	3.70
4/17/20 13:08	239.99	28.03	10.55	14.09	148.55	1179.05	3.70
4/17/20 13:09	239.56	28.05	10.55	14.26	157.84	1178.89	3.70
4/17/20 13:10	239.61	28.08	10.55	14.32	147.76	1178.63	3.70
4/17/20 13:11	239.40	28.05	10.55	14.40	154.32	1178.99	3.70
4/17/20 13:12	239.14	27.99	10.55	14.28	154.28	1178.65	3.70
4/17/20 13:13	239.32	27.98	10.55	14.49	147.78	1178.75	3.70
4/17/20 13:14	239.48	28.07	10.55	14.05	150.73	1179.15	3.70
4/17/20 13:15	239.57	28.07	10.55	14.55	146.79	1179.09	3.70
4/17/20 13:16	239.44	27.97	10.55	14.12	156.94	1179.34	3.70
4/17/20 13:17	239.44	28.01	10.55	14.15	159.52	1178.54	3.70
4/17/20 13:18	239.58	28.08	10.55	14.05	154.62	1178.44	3.70
4/17/20 13:19	239.73	28.10	10.55	14.51	155.40	1178.79	3.70
4/17/20 13:20	239.09	28.07	10.55	14.33	158.05	1178.20	3.70
4/17/20 13:21	239.96	28.01	10.55	14.24	155.05	1179.47	3.70
4/17/20 13:22	240.20	28.09	10.55	14.47	157.64	1179.64	3.70
4/17/20 13:23	240.04	28.09	10.55	14.26	155.21	1178.28	3.70
4/17/20 13:24	239.34	28.17	10.55	14.52	149.72	1178.39	3.70
4/17/20 13:25	239.67	28.06	10.55	14.62	153.99	1179.49	3.70
4/17/20 13:26	239.48	27.99	10.55	14.33	160.22	1178.71	3.70
4/17/20 13:27	239.53	28.06	10.55	14.26	158.11	1179.40	3.70
4/17/20 13:28	239.56	28.09	10.55	14.59	147.96	1179.27	3.70
4/17/20 13:29	239.40	28.04	10.55	14.47	147.14	1179.38	3.70
4/17/20 13:30	239.32	27.97	10.55	14.08	149.42	1178.03	3.70
4/17/20 13:31	239.79	27.95	10.55	14.16	145.22	1178.37	3.70
4/17/20 13:32	240.22	28.15	10.55	14.36	150.47	1178.97	3.70
4/17/20 13:33	239.94	28.12	10.55	14.34	149.92	1177.64	3.70
4/17/20 13:34	239.78	27.99	10.55	14.18	154.37	1178.88	3.70
4/17/20 13:35	239.04	28.02	10.55	14.26	158.43	1177.29	3.70
4/17/20 13:36	239.13	27.98	10.55	14.04	151.17	1177.84	3.70
4/17/20 13:37	239.61	28.14	10.55	14.13	148.41	1178.28	3.70
4/17/20 13:38	239.58	27.97	10.55	14.24	146.92	1178.84	3.70
4/17/20 13:39	239.42	27.95	10.55	14.32	145.60	1178.14	3.70
4/17/20 13:40	239.23	28.01	10.55	14.38	150.58	1177.69	3.70
4/17/20 13:41	239.26	28.08	10.55	13.99	146.16	1178.31	3.70
4/17/20 13:42	239.87	28.02	10.55	14.18	151.81	1178.23	3.70
4/17/20 13:43	239.53	27.95	10.55	14.10	155.65	1178.32	3.70
4/17/20 13:44	239.36	27.99	10.55	14.18	157.02	1178.57	3.70
4/17/20 13:45	239.24	28.01	10.55	14.50	152.61	1177.72	3.70
4/17/20 13:46	238.90	28.04	10.55	14.12	155.78	1177.78	3.70
4/17/20 13:47	239.38	28.00	10.55	14.34	155.25	1177.94	3.70
4/17/20 13:48	239.42	28.01	10.55	14.07	150.37	1178.44	3.70
4/17/20 13:49	239.67	28.04	10.55	14.31	148.74	1178.31	3.70
4/17/20 13:50	239.39	28.13	10.55	14.02	150.24	1177.29	3.70
4/17/20 13:51	239.28	28.05	10.55	14.48	150.77	1178.03	3.70
4/17/20 13:52	239.39	27.96	10.55	14.15	147.29	1178.30	3.70
4/17/20 13:53	239.33	28.07	10.55	14.11	150.91	1177.60	3.70
4/17/20 13:54	239.05	28.08	10.55	14.11	149.93	1176.95	3.70
4/17/20 13:55	239.41	28.11	10.55	14.38	147.12	1178.20	3.70
4/17/20 13:56	239.57	27.99	10.55	14.17	146.31	1178.18	3.70
4/17/20 13:57	239.64	27.96	10.55	14.19	149.99	1178.17	3.70
4/17/20 13:58	239.65	28.05	10.55	14.31	153.93	1177.31	3.70
4/17/20 13:59	239.09	28.15	10.55	14.24	147.41	1177.13	3.70
4/17/20 14:00	239.57	28.04	10.55	14.40	148.84	1177.42	3.70
4/17/20 14:01	239.53	28.01	10.55	14.54	154.08	1177.40	3.70
4/17/20 14:02	239.99	27.99	10.55	14.36	148.46	1178.35	3.70

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 9:35 - 4/17 14:03)	241.38	28.20	10.56	14.26	162.37	1181.05	3.70
COUNT = 269							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/17/20 14:03	239.69	28.13	10.55	14.38	158.00	1177.54	3.70

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
SAM

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 13:10 - 4/16 15:10)	240.41	28.02	10.46	14.19	165.44	1175.95	3.57
COUNT = 121							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 13:10	240.39	27.96	10.44	14.20	172.70	1175.16	3.60
4/16/20 13:11	240.41	27.95	10.44	14.17	175.11	1175.28	3.60
4/16/20 13:12	240.71	28.07	10.44	14.42	172.64	1176.26	3.60
4/16/20 13:13	240.63	28.05	10.44	14.09	172.30	1175.95	3.60
4/16/20 13:14	240.27	28.01	10.44	14.20	165.51	1175.18	3.60
4/16/20 13:15	240.50	27.96	10.44	14.17	158.85	1175.33	3.59
4/16/20 13:16	240.52	27.99	10.44	14.10	157.07	1176.35	3.59
4/16/20 13:17	240.36	28.09	10.44	14.02	159.40	1176.62	3.59
4/16/20 13:18	240.55	28.10	10.44	14.14	160.64	1175.92	3.59
4/16/20 13:19	240.51	27.93	10.44	14.33	164.97	1176.02	3.59
4/16/20 13:20	240.71	27.95	10.44	14.36	169.47	1176.66	3.59
4/16/20 13:21	240.62	28.12	10.44	14.21	168.91	1174.62	3.59
4/16/20 13:22	240.95	28.20	10.44	14.12	159.94	1176.07	3.59
4/16/20 13:23	240.93	27.96	10.45	14.11	172.20	1175.86	3.59
4/16/20 13:24	240.59	27.99	10.45	14.32	171.78	1175.73	3.59
4/16/20 13:25	240.76	27.99	10.45	13.99	163.29	1175.08	3.59
4/16/20 13:26	241.00	28.07	10.45	13.92	163.00	1176.40	3.59
4/16/20 13:27	240.82	28.05	10.45	13.79	173.81	1175.94	3.59
4/16/20 13:28	241.12	27.92	10.45	14.51	175.12	1177.21	3.59
4/16/20 13:29	240.99	28.05	10.45	14.27	174.02	1176.04	3.59
4/16/20 13:30	240.88	28.05	10.45	14.39	173.52	1176.06	3.59
4/16/20 13:31	240.96	28.10	10.45	14.35	170.95	1176.56	3.59
4/16/20 13:32	241.22	27.98	10.45	14.12	164.97	1175.75	3.59
4/16/20 13:33	240.16	27.96	10.45	14.07	161.33	1175.81	3.59
4/16/20 13:34	240.94	27.97	10.45	13.86	163.13	1176.11	3.59
4/16/20 13:35	240.77	28.13	10.45	14.44	167.89	1177.22	3.58
4/16/20 13:36	240.72	28.12	10.45	14.31	177.23	1176.93	3.58
4/16/20 13:37	240.38	27.94	10.45	14.07	187.97	1175.15	3.58
4/16/20 13:38	240.55	27.83	10.45	13.95	172.14	1175.83	3.58
4/16/20 13:39	241.05	28.08	10.45	14.10	179.03	1175.49	3.58
4/16/20 13:40	241.15	28.19	10.45	14.20	164.52	1176.71	3.58
4/16/20 13:41	240.81	28.08	10.45	13.86	172.53	1175.84	3.58
4/16/20 13:42	240.56	28.04	10.45	13.98	177.37	1175.10	3.58
4/16/20 13:43	240.88	28.02	10.45	14.18	165.29	1176.29	3.58
4/16/20 13:44	240.69	28.13	10.45	14.13	160.23	1175.48	3.58
4/16/20 13:45	240.43	28.04	10.45	14.16	164.11	1175.91	3.58
4/16/20 13:46	240.62	28.02	10.45	14.15	174.27	1177.12	3.58
4/16/20 13:47	240.35	27.99	10.45	13.98	161.23	1175.38	3.58
4/16/20 13:48	240.36	28.08	10.45	14.10	161.16	1175.82	3.58
4/16/20 13:49	240.00	28.00	10.45	14.06	164.92	1175.27	3.58
4/16/20 13:50	240.65	27.97	10.45	14.07	171.59	1175.92	3.58
4/16/20 13:51	239.98	27.98	10.45	13.99	159.19	1175.41	3.58
4/16/20 13:52	240.75	27.98	10.45	13.95	154.82	1176.08	3.58
4/16/20 13:53	240.37	28.06	10.45	13.88	156.52	1176.26	3.58
4/16/20 13:54	239.81	28.01	10.45	14.05	154.35	1176.19	3.58
4/16/20 13:55	240.23	27.90	10.45	14.21	159.91	1175.95	3.57
4/16/20 13:56	240.62	28.03	10.45	14.10	162.23	1175.93	3.57
4/16/20 13:57	240.52	28.07	10.45	13.74	161.78	1175.58	3.57
4/16/20 13:58	240.93	28.12	10.45	14.03	168.36	1175.94	3.57
4/16/20 13:59	240.75	28.00	10.45	14.26	171.16	1176.20	3.57
4/16/20 14:00	240.79	27.96	10.45	14.33	163.56	1176.01	3.57
4/16/20 14:01	241.05	28.08	10.45	14.16	162.27	1176.22	3.57
4/16/20 14:02	240.67	28.17	10.46	14.25	169.06	1175.80	3.57
4/16/20 14:03	240.50	27.95	10.46	14.16	173.41	1175.88	3.57
4/16/20 14:04	240.56	28.01	10.46	14.17	165.79	1175.82	3.57
4/16/20 14:05	240.71	27.98	10.46	14.31	159.26	1175.91	3.57
4/16/20 14:06	240.89	28.12	10.46	14.27	160.78	1176.24	3.57
4/16/20 14:07	240.68	28.07	10.46	14.19	159.41	1175.94	3.57
4/16/20 14:08	240.56	27.96	10.46	14.46	159.41	1175.86	3.57
4/16/20 14:09	240.90	28.08	10.46	14.22	159.50	1176.64	3.57
4/16/20 14:10	240.37	28.08	10.46	14.34	162.17	1175.62	3.57
4/16/20 14:11	240.45	28.09	10.46	14.41	169.83	1175.71	3.57
4/16/20 14:12	240.58	27.99	10.46	14.21	169.79	1176.15	3.57
4/16/20 14:13	240.86	27.98	10.46	14.52	173.42	1176.26	3.57
4/16/20 14:14	240.73	28.10	10.46	13.95	169.17	1175.33	3.56
4/16/20 14:15	240.92	28.14	10.46	14.29	167.74	1176.75	3.56
4/16/20 14:16	240.84	28.04	10.46	14.15	168.81	1175.77	3.56

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/16 13:10 - 4/16 15:10)	240.41	28.02	10.46	14.19	165.44	1175.95	3.57
COUNT = 121							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/16/20 14:17	240.83	27.96	10.46	13.93	170.03	1175.80	3.56
4/16/20 14:18	240.91	27.96	10.46	14.27	169.49	1175.38	3.56
4/16/20 14:19	240.69	28.09	10.46	14.37	163.69	1176.03	3.56
4/16/20 14:20	240.37	28.09	10.46	14.01	166.58	1175.79	3.56
4/16/20 14:21	240.85	27.99	10.46	13.92	174.10	1176.40	3.56
4/16/20 14:22	240.59	28.05	10.46	14.18	167.11	1175.63	3.56
4/16/20 14:23	241.09	28.11	10.46	14.10	165.62	1176.20	3.56
4/16/20 14:24	240.35	28.12	10.46	14.12	172.23	1176.49	3.56
4/16/20 14:25	240.68	27.99	10.46	14.39	173.17	1176.52	3.56
4/16/20 14:26	240.09	28.04	10.46	13.98	174.46	1175.22	3.56
4/16/20 14:27	240.59	28.01	10.46	14.60	164.68	1176.22	3.56
4/16/20 14:28	239.93	28.10	10.46	14.53	162.81	1175.91	3.56
4/16/20 14:29	240.08	28.07	10.46	14.76	158.81	1176.28	3.56
4/16/20 14:30	240.43	27.98	10.46	14.26	160.86	1176.21	3.56
4/16/20 14:31	240.12	27.95	10.46	14.46	170.28	1176.04	3.56
4/16/20 14:32	240.08	28.16	10.46	14.10	160.56	1176.00	3.56
4/16/20 14:33	240.62	28.04	10.46	14.61	163.69	1176.25	3.56
4/16/20 14:34	239.79	27.95	10.46	14.01	169.69	1174.93	3.55
4/16/20 14:35	240.42	27.99	10.46	14.24	162.96	1176.03	3.55
4/16/20 14:36	240.28	28.02	10.46	14.52	163.25	1175.70	3.55
4/16/20 14:37	240.18	28.06	10.46	14.53	166.15	1175.59	3.55
4/16/20 14:38	240.67	28.00	10.46	14.12	157.24	1176.52	3.55
4/16/20 14:39	239.96	28.02	10.46	14.16	156.65	1175.42	3.55
4/16/20 14:40	240.37	27.99	10.46	14.25	157.29	1175.90	3.55
4/16/20 14:41	240.09	28.05	10.47	14.04	159.17	1176.19	3.55
4/16/20 14:42	239.94	28.07	10.47	14.17	164.58	1174.75	3.55
4/16/20 14:43	240.29	27.91	10.47	13.88	168.24	1175.82	3.55
4/16/20 14:44	240.23	27.99	10.47	14.55	167.11	1176.45	3.55
4/16/20 14:45	240.50	28.01	10.47	14.66	168.25	1176.53	3.55
4/16/20 14:46	240.43	28.08	10.47	14.07	170.64	1176.15	3.55
4/16/20 14:47	240.16	28.04	10.47	14.14	164.07	1175.73	3.55
4/16/20 14:48	240.11	27.95	10.47	14.23	174.75	1176.42	3.55
4/16/20 14:49	240.45	27.99	10.47	14.31	174.71	1176.40	3.55
4/16/20 14:50	240.27	28.13	10.47	14.29	172.37	1176.55	3.55
4/16/20 14:51	239.36	27.97	10.47	14.05	161.32	1174.94	3.55
4/16/20 14:52	239.25	27.88	10.47	14.09	155.33	1174.93	3.55
4/16/20 14:53	239.82	27.89	10.47	14.66	158.90	1176.81	3.55
4/16/20 14:54	239.66	28.03	10.47	14.28	164.82	1177.13	3.54
4/16/20 14:55	239.28	28.00	10.47	13.91	151.05	1176.21	3.54
4/16/20 14:56	239.61	27.93	10.47	14.21	156.80	1176.32	3.54
4/16/20 14:57	240.11	27.95	10.47	13.99	152.70	1175.28	3.54
4/16/20 14:58	240.06	28.00	10.47	14.05	150.30	1176.10	3.54
4/16/20 14:59	239.80	28.09	10.47	14.30	149.78	1176.14	3.54
4/16/20 15:00	240.02	27.97	10.47	14.02	150.95	1176.66	3.54
4/16/20 15:01	239.61	27.89	10.47	14.00	158.69	1175.32	3.54
4/16/20 15:02	239.70	27.94	10.47	14.15	165.09	1174.82	3.54
4/16/20 15:03	240.40	28.04	10.47	14.02	160.26	1176.49	3.54
4/16/20 15:04	240.09	28.07	10.47	14.21	163.84	1176.22	3.54
4/16/20 15:05	239.97	27.96	10.47	14.36	172.96	1175.86	3.54
4/16/20 15:06	239.61	27.93	10.47	14.26	172.67	1175.10	3.54
4/16/20 15:07	239.29	28.03	10.47	14.29	161.79	1175.49	3.54
4/16/20 15:08	239.11	28.03	10.47	14.23	167.23	1175.83	3.54
4/16/20 15:09	239.57	27.92	10.47	14.49	156.43	1176.90	3.54
4/16/20 15:10	239.11	27.88	10.47	14.12	164.06	1175.62	3.54

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 3:58 - 4/17 5:58)		244.84	28.41	10.65	14.23	193.59	1181.67	3.72
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 3:58	244.67	28.33	10.66	14.17	188.90	1180.80	3.73
	4/17/20 3:59	244.31	28.38	10.66	14.39	180.02	1181.12	3.73
	4/17/20 4:00	244.42	28.44	10.66	14.58	186.64	1182.39	3.73
	4/17/20 4:01	244.64	28.29	10.66	14.22	193.40	1181.75	3.73
	4/17/20 4:02	244.75	28.32	10.66	14.24	178.26	1181.24	3.73
	4/17/20 4:03	244.28	28.29	10.66	14.23	192.77	1181.15	3.73
	4/17/20 4:04	244.48	28.37	10.66	14.34	188.65	1181.63	3.73
	4/17/20 4:05	244.46	28.37	10.66	14.09	176.28	1181.41	3.73
	4/17/20 4:06	244.31	28.34	10.67	14.18	188.95	1181.10	3.73
	4/17/20 4:07	244.22	28.27	10.67	14.01	184.50	1180.71	3.73
	4/17/20 4:08	244.55	28.30	10.67	14.16	174.41	1181.64	3.73
	4/17/20 4:09	244.24	28.42	10.67	14.06	174.72	1181.13	3.73
	4/17/20 4:10	244.72	28.40	10.67	14.31	182.31	1182.53	3.73
	4/17/20 4:11	244.73	28.29	10.66	14.32	188.89	1181.01	3.73
	4/17/20 4:12	244.41	28.42	10.66	13.96	176.18	1181.39	3.73
	4/17/20 4:13	244.10	28.41	10.66	14.02	189.74	1181.38	3.73
	4/17/20 4:14	244.68	28.38	10.66	14.30	183.09	1182.23	3.73
	4/17/20 4:15	244.34	28.29	10.66	14.29	197.56	1180.91	3.73
	4/17/20 4:16	244.86	28.33	10.66	14.08	190.04	1181.15	3.73
	4/17/20 4:17	244.93	28.39	10.66	14.25	186.02	1181.03	3.73
	4/17/20 4:18	244.83	28.46	10.66	14.20	192.89	1181.24	3.73
	4/17/20 4:19	244.57	28.39	10.66	14.19	188.79	1181.19	3.73
	4/17/20 4:20	244.81	28.33	10.66	14.24	199.49	1181.94	3.73
	4/17/20 4:21	244.76	28.41	10.66	14.25	183.77	1181.44	3.73
	4/17/20 4:22	244.75	28.43	10.66	14.17	190.98	1181.67	3.73
	4/17/20 4:23	244.82	28.40	10.66	14.34	198.85	1181.39	3.73
	4/17/20 4:24	244.77	28.32	10.66	14.41	185.37	1181.84	3.73
	4/17/20 4:25	245.03	28.39	10.66	14.14	189.57	1181.29	3.73
	4/17/20 4:26	244.58	28.51	10.66	14.16	195.36	1181.51	3.73
	4/17/20 4:27	244.25	28.45	10.66	14.08	187.27	1180.82	3.73
	4/17/20 4:28	245.08	28.44	10.66	14.04	202.59	1181.85	3.73
	4/17/20 4:29	244.76	28.37	10.66	14.10	190.58	1181.22	3.73
	4/17/20 4:30	244.31	28.37	10.66	14.01	195.82	1181.41	3.73
	4/17/20 4:31	244.65	28.48	10.66	14.33	199.61	1181.96	3.72
	4/17/20 4:32	244.85	28.40	10.66	14.07	197.82	1182.00	3.72
	4/17/20 4:33	245.02	28.37	10.66	14.03	198.55	1181.54	3.72
	4/17/20 4:34	244.99	28.42	10.66	14.29	204.00	1182.48	3.72
	4/17/20 4:35	244.79	28.45	10.66	14.20	204.91	1182.40	3.72
	4/17/20 4:36	244.67	28.44	10.66	14.08	202.18	1181.55	3.72
	4/17/20 4:37	245.09	28.35	10.66	14.30	201.73	1181.53	3.72
	4/17/20 4:38	244.69	28.35	10.66	14.11	200.67	1181.45	3.72
	4/17/20 4:39	244.57	28.42	10.66	14.12	198.94	1181.32	3.72
	4/17/20 4:40	244.74	28.40	10.66	14.21	197.01	1180.97	3.72
	4/17/20 4:41	244.65	28.39	10.66	14.00	191.63	1181.78	3.72
	4/17/20 4:42	244.56	28.36	10.66	14.03	189.44	1181.68	3.72
	4/17/20 4:43	245.01	28.35	10.66	13.99	178.65	1181.99	3.72
	4/17/20 4:44	245.18	28.42	10.66	14.17	178.55	1181.91	3.72
	4/17/20 4:45	244.77	28.39	10.66	14.19	186.12	1181.94	3.72
	4/17/20 4:46	244.63	28.38	10.66	14.43	191.60	1182.05	3.72
	4/17/20 4:47	244.99	28.35	10.66	14.21	193.05	1181.19	3.72
	4/17/20 4:48	244.97	28.42	10.66	14.15	199.66	1181.93	3.72
	4/17/20 4:49	244.53	28.41	10.66	14.15	200.15	1181.31	3.72
	4/17/20 4:50	244.72	28.34	10.66	14.22	200.23	1182.10	3.72
	4/17/20 4:51	245.21	28.30	10.66	14.45	200.81	1182.73	3.72
	4/17/20 4:52	245.01	28.45	10.66	14.29	201.28	1181.65	3.72
	4/17/20 4:53	244.58	28.57	10.66	14.23	200.95	1181.20	3.72
	4/17/20 4:54	245.09	28.41	10.65	14.51	197.96	1182.36	3.72
	4/17/20 4:55	244.78	28.32	10.65	14.13	184.58	1181.73	3.72
	4/17/20 4:56	244.76	28.44	10.65	14.30	185.89	1181.72	3.72
	4/17/20 4:57	244.89	28.45	10.65	14.21	190.65	1181.79	3.72
	4/17/20 4:58	244.74	28.40	10.65	14.25	198.04	1181.11	3.72
	4/17/20 4:59	244.75	28.35	10.65	14.10	198.18	1181.10	3.72
	4/17/20 5:00	244.82	28.32	10.65	14.04	201.23	1181.48	3.72
	4/17/20 5:01	244.90	28.47	10.65	14.04	199.31	1181.68	3.72
	4/17/20 5:02	244.74	28.46	10.65	14.30	197.42	1180.89	3.72
	4/17/20 5:03	245.03	28.34	10.65	13.86	190.71	1181.76	3.72
	4/17/20 5:04	244.77	28.36	10.65	14.38	189.66	1181.50	3.72

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 3:58 - 4/17 5:58)		244.84	28.41	10.65	14.23	193.59	1181.67	3.72
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 5:05	245.21	28.41	10.65	14.04	180.60	1182.04	3.72
	4/17/20 5:06	244.77	28.50	10.65	14.44	179.66	1181.35	3.72
	4/17/20 5:07	244.58	28.35	10.65	14.27	194.83	1181.70	3.72
	4/17/20 5:08	245.16	28.31	10.65	14.41	198.60	1183.01	3.72
	4/17/20 5:09	244.20	28.37	10.65	14.39	185.98	1180.74	3.72
	4/17/20 5:10	244.81	28.45	10.65	14.19	188.30	1180.86	3.72
	4/17/20 5:11	244.66	28.41	10.65	14.32	200.79	1181.36	3.72
	4/17/20 5:12	244.64	28.35	10.65	14.20	190.61	1181.25	3.72
	4/17/20 5:13	244.66	28.38	10.65	14.14	190.24	1180.67	3.72
	4/17/20 5:14	244.88	28.52	10.65	14.04	201.23	1181.50	3.72
	4/17/20 5:15	244.99	28.44	10.65	14.35	192.53	1182.51	3.72
	4/17/20 5:16	244.54	28.45	10.65	14.11	201.60	1180.84	3.72
	4/17/20 5:17	244.66	28.44	10.65	14.01	200.18	1181.47	3.72
	4/17/20 5:18	244.66	28.46	10.65	14.42	205.76	1181.52	3.72
	4/17/20 5:19	245.25	28.50	10.65	14.13	199.76	1182.40	3.72
	4/17/20 5:20	244.95	28.43	10.65	14.45	188.21	1182.07	3.72
	4/17/20 5:21	244.70	28.33	10.65	14.17	194.36	1181.38	3.72
	4/17/20 5:22	244.84	28.48	10.65	14.02	201.37	1180.88	3.72
	4/17/20 5:23	244.96	28.53	10.65	14.24	205.51	1181.20	3.72
	4/17/20 5:24	245.00	28.41	10.65	14.07	201.40	1182.15	3.72
	4/17/20 5:25	244.81	28.40	10.65	14.14	187.31	1182.33	3.72
	4/17/20 5:26	244.95	28.44	10.65	14.39	192.73	1182.57	3.72
	4/17/20 5:27	244.26	28.48	10.65	14.29	201.40	1180.54	3.72
	4/17/20 5:28	244.58	28.47	10.65	14.18	191.17	1181.71	3.72
	4/17/20 5:29	245.07	28.34	10.65	14.45	190.46	1182.32	3.72
	4/17/20 5:30	245.11	28.44	10.65	14.20	199.09	1181.16	3.72
	4/17/20 5:31	244.78	28.46	10.65	14.67	188.74	1182.10	3.72
	4/17/20 5:32	245.32	28.46	10.65	14.27	185.62	1182.30	3.72
	4/17/20 5:33	245.16	28.48	10.65	14.33	181.81	1181.78	3.72
	4/17/20 5:34	244.88	28.39	10.65	14.05	191.42	1181.36	3.72
	4/17/20 5:35	245.23	28.48	10.65	14.23	201.64	1182.57	3.72
	4/17/20 5:36	244.94	28.57	10.65	14.27	196.92	1181.55	3.72
	4/17/20 5:37	245.11	28.55	10.64	14.35	192.62	1182.36	3.72
	4/17/20 5:38	245.15	28.41	10.64	14.42	186.67	1182.05	3.72
	4/17/20 5:39	245.27	28.42	10.64	14.14	200.26	1182.06	3.72
	4/17/20 5:40	244.79	28.45	10.64	14.47	205.97	1181.81	3.72
	4/17/20 5:41	244.79	28.53	10.64	14.25	204.30	1181.92	3.72
	4/17/20 5:42	245.07	28.50	10.64	14.21	198.56	1181.78	3.72
	4/17/20 5:43	245.62	28.46	10.64	14.69	191.08	1182.49	3.72
	4/17/20 5:44	245.30	28.42	10.64	14.54	191.66	1182.23	3.71
	4/17/20 5:45	245.24	28.53	10.64	14.07	205.12	1181.21	3.71
	4/17/20 5:46	245.78	28.43	10.64	14.76	194.95	1183.28	3.71
	4/17/20 5:47	245.16	28.38	10.64	14.49	195.83	1182.20	3.71
	4/17/20 5:48	245.20	28.49	10.64	14.40	204.89	1182.00	3.71
	4/17/20 5:49	244.86	28.41	10.64	14.22	196.45	1180.95	3.71
	4/17/20 5:50	245.24	28.57	10.64	13.95	188.16	1182.04	3.71
	4/17/20 5:51	245.14	28.43	10.64	14.39	198.89	1182.49	3.71
	4/17/20 5:52	245.17	28.46	10.64	14.27	205.38	1182.43	3.71
	4/17/20 5:53	245.23	28.39	10.64	14.36	203.60	1181.72	3.71
	4/17/20 5:54	245.57	28.59	10.64	14.11	196.36	1182.28	3.71
	4/17/20 5:55	245.40	28.49	10.64	14.20	192.38	1181.92	3.71
	4/17/20 5:56	245.38	28.44	10.64	14.29	195.99	1181.76	3.71
	4/17/20 5:57	245.15	28.50	10.64	14.32	202.26	1181.65	3.71
	4/17/20 5:58	245.36	28.58	10.64	14.24	208.96	1181.78	3.71

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 7:00 - 4/17 9:00)		244.25	28.41	10.61	14.22	181.88	1183.39	3.70
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 7:00	245.23	28.57	10.63	14.29	204.76	1183.32	3.70
	4/17/20 7:01	245.11	28.51	10.63	14.37	191.42	1182.84	3.70
	4/17/20 7:02	245.36	28.44	10.63	14.41	178.14	1183.06	3.70
	4/17/20 7:03	245.24	28.55	10.63	14.22	193.66	1182.98	3.70
	4/17/20 7:04	245.20	28.59	10.62	14.14	201.99	1183.24	3.70
	4/17/20 7:05	245.03	28.48	10.62	14.10	202.09	1183.89	3.70
	4/17/20 7:06	245.00	28.44	10.62	14.12	199.31	1183.41	3.70
	4/17/20 7:07	244.97	28.54	10.62	14.13	183.91	1182.99	3.70
	4/17/20 7:08	244.79	28.58	10.62	14.01	179.01	1183.38	3.70
	4/17/20 7:09	244.86	28.46	10.62	14.09	173.81	1182.82	3.70
	4/17/20 7:10	244.49	28.39	10.62	14.10	184.82	1183.15	3.70
	4/17/20 7:11	244.25	28.46	10.62	14.00	185.23	1182.86	3.70
	4/17/20 7:12	244.64	28.53	10.62	14.21	185.73	1182.65	3.70
	4/17/20 7:13	244.72	28.51	10.62	14.11	192.23	1182.54	3.70
	4/17/20 7:14	244.68	28.37	10.62	13.95	192.91	1183.67	3.70
	4/17/20 7:15	244.38	28.42	10.62	14.02	193.79	1183.14	3.70
	4/17/20 7:16	244.77	28.49	10.62	14.04	193.60	1183.46	3.70
	4/17/20 7:17	245.07	28.49	10.62	14.36	191.05	1183.28	3.70
	4/17/20 7:18	244.72	28.37	10.62	14.04	185.52	1183.56	3.70
	4/17/20 7:19	244.47	28.41	10.62	14.41	184.12	1183.08	3.70
	4/17/20 7:20	244.74	28.45	10.62	14.44	175.03	1183.40	3.70
	4/17/20 7:21	244.76	28.49	10.62	14.42	178.04	1183.76	3.70
	4/17/20 7:22	244.87	28.42	10.62	14.31	190.05	1182.78	3.70
	4/17/20 7:23	244.36	28.33	10.62	14.25	179.57	1183.36	3.70
	4/17/20 7:24	244.60	28.43	10.62	14.07	183.04	1183.37	3.70
	4/17/20 7:25	244.85	28.42	10.62	14.30	175.60	1183.37	3.70
	4/17/20 7:26	244.26	28.38	10.62	13.97	174.44	1182.38	3.70
	4/17/20 7:27	243.98	28.39	10.62	14.40	187.69	1182.97	3.70
	4/17/20 7:28	244.78	28.39	10.62	14.23	185.28	1182.43	3.70
	4/17/20 7:29	244.70	28.46	10.62	14.15	173.12	1183.19	3.70
	4/17/20 7:30	244.58	28.48	10.62	13.92	185.85	1183.01	3.70
	4/17/20 7:31	244.47	28.39	10.62	14.09	176.22	1182.79	3.70
	4/17/20 7:32	244.40	28.43	10.62	14.09	185.07	1183.19	3.70
	4/17/20 7:33	244.42	28.43	10.62	14.08	175.55	1183.47	3.70
	4/17/20 7:34	244.14	28.51	10.62	14.02	192.19	1183.78	3.70
	4/17/20 7:35	244.37	28.41	10.62	14.30	180.06	1183.36	3.70
	4/17/20 7:36	244.59	28.40	10.62	14.02	191.79	1183.54	3.70
	4/17/20 7:37	244.79	28.39	10.62	14.16	178.97	1182.45	3.70
	4/17/20 7:38	244.62	28.46	10.62	14.60	195.41	1184.00	3.70
	4/17/20 7:39	244.84	28.51	10.62	13.95	185.94	1183.56	3.70
	4/17/20 7:40	244.91	28.39	10.62	14.21	184.91	1183.58	3.70
	4/17/20 7:41	244.73	28.43	10.62	14.00	192.12	1183.77	3.70
	4/17/20 7:42	244.70	28.45	10.62	14.32	175.79	1183.78	3.70
	4/17/20 7:43	244.74	28.58	10.62	14.21	185.87	1184.09	3.70
	4/17/20 7:44	244.36	28.39	10.62	14.04	192.23	1183.22	3.70
	4/17/20 7:45	244.32	28.31	10.62	14.18	190.47	1183.34	3.70
	4/17/20 7:46	244.67	28.41	10.62	14.11	181.12	1183.34	3.70
	4/17/20 7:47	244.32	28.46	10.61	14.55	171.40	1184.40	3.70
	4/17/20 7:48	244.61	28.38	10.61	14.00	173.06	1183.33	3.70
	4/17/20 7:49	244.49	28.37	10.61	14.13	190.16	1183.70	3.70
	4/17/20 7:50	244.42	28.40	10.61	14.09	184.96	1183.26	3.70
	4/17/20 7:51	244.54	28.55	10.61	14.18	170.99	1184.04	3.70
	4/17/20 7:52	244.58	28.46	10.61	14.17	187.41	1184.18	3.70
	4/17/20 7:53	244.12	28.29	10.61	14.03	186.05	1183.45	3.70
	4/17/20 7:54	244.56	28.38	10.61	14.64	175.78	1184.51	3.70
	4/17/20 7:55	244.47	28.49	10.61	14.00	190.01	1184.16	3.70
	4/17/20 7:56	244.67	28.48	10.61	14.24	176.94	1184.74	3.70
	4/17/20 7:57	244.62	28.33	10.61	14.34	190.80	1184.24	3.70
	4/17/20 7:58	244.32	28.41	10.61	14.43	179.98	1183.91	3.70
	4/17/20 7:59	244.14	28.41	10.61	14.18	174.53	1183.79	3.70
	4/17/20 8:00	244.31	28.51	10.61	13.93	186.27	1183.60	3.70
	4/17/20 8:01	244.30	28.45	10.61	14.30	180.13	1183.49	3.70
	4/17/20 8:02	244.13	28.37	10.61	14.33	174.43	1183.91	3.70
	4/17/20 8:03	244.05	28.35	10.61	14.15	183.53	1183.47	3.70
	4/17/20 8:04	243.85	28.45	10.61	13.99	174.29	1183.85	3.70
	4/17/20 8:05	244.69	28.44	10.61	14.17	184.59	1183.02	3.70
	4/17/20 8:06	244.14	28.36	10.61	14.13	177.40	1183.65	3.70

Description		CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM		MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 7:00 - 4/17 9:00)		244.25	28.41	10.61	14.22	181.88	1183.39	3.70
COUNT = 121								
Signal Tagname		G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
	4/17/20 8:07	243.76	28.35	10.61	14.27	183.17	1183.39	3.70
	4/17/20 8:08	244.09	28.40	10.61	14.43	174.42	1183.86	3.70
	4/17/20 8:09	243.93	28.44	10.61	14.32	182.94	1183.42	3.70
	4/17/20 8:10	244.13	28.41	10.61	14.05	175.10	1183.18	3.70
	4/17/20 8:11	243.59	28.29	10.61	14.34	183.41	1184.06	3.70
	4/17/20 8:12	244.50	28.33	10.61	14.58	185.76	1184.07	3.70
	4/17/20 8:13	244.23	28.44	10.61	14.14	176.83	1183.22	3.70
	4/17/20 8:14	244.28	28.40	10.61	14.21	175.68	1184.04	3.70
	4/17/20 8:15	244.58	28.30	10.61	14.43	181.07	1183.80	3.70
	4/17/20 8:16	244.03	28.38	10.61	13.90	187.87	1182.92	3.70
	4/17/20 8:17	244.27	28.54	10.61	14.72	183.08	1184.34	3.70
	4/17/20 8:18	244.19	28.49	10.61	14.37	171.10	1183.55	3.70
	4/17/20 8:19	244.17	28.31	10.61	14.09	174.56	1182.78	3.70
	4/17/20 8:20	243.82	28.36	10.61	14.14	179.23	1183.29	3.70
	4/17/20 8:21	243.64	28.44	10.61	14.57	179.96	1183.54	3.70
	4/17/20 8:22	244.07	28.55	10.61	14.24	181.63	1183.20	3.70
	4/17/20 8:23	243.87	28.40	10.61	14.22	177.91	1183.22	3.70
	4/17/20 8:24	244.02	28.31	10.61	14.46	186.45	1184.70	3.70
	4/17/20 8:25	244.19	28.36	10.61	14.19	185.90	1183.22	3.70
	4/17/20 8:26	244.44	28.48	10.61	14.72	187.55	1184.87	3.70
	4/17/20 8:27	243.86	28.36	10.61	14.40	177.86	1183.73	3.70
	4/17/20 8:28	243.64	28.33	10.61	14.21	174.50	1182.89	3.70
	4/17/20 8:29	244.16	28.42	10.61	14.27	186.16	1182.70	3.70
	4/17/20 8:30	243.71	28.35	10.61	14.07	174.32	1183.63	3.70
	4/17/20 8:31	243.71	28.49	10.60	14.25	174.65	1183.20	3.70
	4/17/20 8:32	243.99	28.32	10.60	14.73	170.35	1183.55	3.70
	4/17/20 8:33	243.85	28.35	10.60	14.35	177.55	1182.83	3.70
	4/17/20 8:34	244.10	28.35	10.60	14.21	185.12	1184.08	3.70
	4/17/20 8:35	243.87	28.49	10.60	14.27	174.46	1182.60	3.70
	4/17/20 8:36	243.76	28.33	10.60	13.96	178.14	1183.68	3.70
	4/17/20 8:37	243.93	28.34	10.60	14.27	182.48	1183.42	3.70
	4/17/20 8:38	244.02	28.33	10.60	14.18	180.98	1183.15	3.70
	4/17/20 8:39	243.81	28.35	10.60	14.25	173.21	1183.26	3.70
	4/17/20 8:40	243.51	28.35	10.60	14.26	178.01	1182.69	3.70
	4/17/20 8:41	243.32	28.32	10.60	14.27	168.70	1183.50	3.70
	4/17/20 8:42	243.35	28.31	10.60	14.07	167.05	1182.63	3.70
	4/17/20 8:43	243.82	28.47	10.60	14.17	173.35	1183.23	3.70
	4/17/20 8:44	243.72	28.38	10.60	14.17	183.18	1182.70	3.70
	4/17/20 8:45	243.41	28.31	10.60	14.43	180.03	1183.51	3.70
	4/17/20 8:46	243.66	28.33	10.60	14.21	170.69	1182.31	3.70
	4/17/20 8:47	243.20	28.38	10.60	14.29	178.64	1182.56	3.70
	4/17/20 8:48	243.54	28.36	10.60	14.34	182.08	1182.91	3.70
	4/17/20 8:49	243.26	28.32	10.60	13.99	181.53	1183.85	3.70
	4/17/20 8:50	243.54	28.27	10.60	14.16	183.58	1183.42	3.70
	4/17/20 8:51	243.92	28.38	10.60	14.35	179.82	1183.91	3.70
	4/17/20 8:52	243.70	28.39	10.60	14.24	177.04	1183.22	3.70
	4/17/20 8:53	243.18	28.35	10.60	14.05	171.57	1182.51	3.70
	4/17/20 8:54	243.61	28.27	10.60	14.19	187.01	1182.90	3.70
	4/17/20 8:55	243.55	28.34	10.60	14.23	180.54	1182.87	3.70
	4/17/20 8:56	243.20	28.46	10.60	14.37	166.92	1183.53	3.70
	4/17/20 8:57	243.63	28.40	10.60	14.22	173.13	1183.26	3.70
	4/17/20 8:58	243.38	28.27	10.60	14.29	182.06	1183.39	3.70
	4/17/20 8:59	243.84	28.30	10.60	14.55	180.43	1183.33	3.70
	4/17/20 9:00	243.75	28.43	10.60	14.23	177.54	1183.42	3.70

EMISSION DATA RECORDS

Operating Data Base+DB Load
(provided by Cricket Valley Energy Center LLC)
Opacity

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 10:00 - 4/17 11:00)	242.57	28.29	10.58	14.22	170.06	1182.50	3.70
COUNT = 61							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/17/20 10:00	242.41	28.26	10.58	14.26	168.31	1182.55	3.70
4/17/20 10:01	242.49	28.33	10.58	14.42	175.44	1183.06	3.70
4/17/20 10:02	242.66	28.32	10.58	14.34	179.06	1181.90	3.70
4/17/20 10:03	242.72	28.18	10.58	14.26	180.69	1183.31	3.70
4/17/20 10:04	242.40	28.29	10.58	14.30	179.85	1182.29	3.70
4/17/20 10:05	242.35	28.37	10.58	13.91	177.35	1181.80	3.70
4/17/20 10:06	242.56	28.36	10.58	14.23	178.98	1182.20	3.70
4/17/20 10:07	242.47	28.29	10.58	14.21	170.85	1182.41	3.70
4/17/20 10:08	242.77	28.24	10.58	14.58	176.20	1182.67	3.70
4/17/20 10:09	242.54	28.33	10.58	14.44	170.12	1182.57	3.70
4/17/20 10:10	242.24	28.30	10.58	14.14	164.62	1182.93	3.70
4/17/20 10:11	242.42	28.24	10.58	14.06	157.48	1183.45	3.70
4/17/20 10:12	242.39	28.15	10.58	14.08	163.17	1182.59	3.70
4/17/20 10:13	243.18	28.28	10.58	14.39	169.46	1183.53	3.70
4/17/20 10:14	242.53	28.36	10.58	14.13	175.97	1182.37	3.70
4/17/20 10:15	242.33	28.41	10.58	14.38	167.43	1182.63	3.70
4/17/20 10:16	242.78	28.28	10.58	14.51	164.23	1182.72	3.70
4/17/20 10:17	242.66	28.25	10.58	14.08	169.12	1181.88	3.70
4/17/20 10:18	242.30	28.38	10.58	14.34	173.21	1182.86	3.70
4/17/20 10:19	242.74	28.36	10.58	13.98	167.31	1182.88	3.70
4/17/20 10:20	242.44	28.24	10.58	14.40	171.25	1181.31	3.70
4/17/20 10:21	242.68	28.23	10.58	14.08	164.29	1182.72	3.70
4/17/20 10:22	242.53	28.35	10.58	14.10	169.12	1182.73	3.70
4/17/20 10:23	242.55	28.42	10.58	14.10	174.86	1181.88	3.70
4/17/20 10:24	242.80	28.25	10.58	14.20	162.33	1182.03	3.70
4/17/20 10:25	242.86	28.22	10.58	13.95	167.14	1181.98	3.70
4/17/20 10:26	242.49	28.29	10.58	14.09	179.04	1182.37	3.70
4/17/20 10:27	242.78	28.35	10.58	14.36	171.22	1182.66	3.70
4/17/20 10:28	242.86	28.36	10.58	14.45	165.19	1182.28	3.70
4/17/20 10:29	243.39	28.24	10.58	14.28	171.50	1183.25	3.70
4/17/20 10:30	242.92	28.27	10.58	14.28	177.70	1183.33	3.70
4/17/20 10:31	242.95	28.32	10.58	14.14	171.53	1182.62	3.70
4/17/20 10:32	242.60	28.36	10.58	14.16	165.15	1182.39	3.70
4/17/20 10:33	242.63	28.21	10.58	14.08	169.12	1182.14	3.70
4/17/20 10:34	242.29	28.23	10.58	14.45	173.51	1182.52	3.70
4/17/20 10:35	242.12	28.31	10.58	14.19	172.40	1182.76	3.70
4/17/20 10:36	242.46	28.34	10.58	14.32	171.12	1182.90	3.70
4/17/20 10:37	242.33	28.23	10.58	14.35	163.08	1182.36	3.70
4/17/20 10:38	242.51	28.17	10.58	14.37	163.37	1183.25	3.70
4/17/20 10:39	242.05	28.32	10.58	14.15	163.95	1181.96	3.70
4/17/20 10:40	242.81	28.38	10.57	14.18	168.61	1181.63	3.70
4/17/20 10:41	242.78	28.36	10.57	14.24	162.23	1182.50	3.70
4/17/20 10:42	242.70	28.22	10.57	14.47	166.83	1182.40	3.70
4/17/20 10:43	242.67	28.13	10.57	14.41	171.73	1182.54	3.70
4/17/20 10:44	243.43	28.36	10.57	14.45	178.40	1183.13	3.70
4/17/20 10:45	242.76	28.37	10.57	14.14	165.99	1182.34	3.70
4/17/20 10:46	242.51	28.19	10.57	14.10	178.01	1181.56	3.70
4/17/20 10:47	242.29	28.24	10.57	14.15	173.78	1183.00	3.70
4/17/20 10:48	242.15	28.32	10.57	14.45	169.27	1183.14	3.70
4/17/20 10:49	242.40	28.38	10.57	14.09	177.20	1182.63	3.70
4/17/20 10:50	242.10	28.22	10.57	14.03	161.03	1181.80	3.70
4/17/20 10:51	242.03	28.15	10.57	13.99	160.48	1182.28	3.70
4/17/20 10:52	242.25	28.23	10.57	13.89	167.25	1182.21	3.70
4/17/20 10:53	242.32	28.38	10.57	14.36	169.02	1183.07	3.70
4/17/20 10:54	242.46	28.25	10.57	14.13	165.10	1182.81	3.70
4/17/20 10:55	242.56	28.14	10.57	14.03	161.00	1182.48	3.70
4/17/20 10:56	243.01	28.28	10.57	14.10	172.76	1182.31	3.70
4/17/20 10:57	242.47	28.35	10.57	14.46	164.35	1182.33	3.70
4/17/20 10:58	242.65	28.34	10.57	14.09	171.87	1182.38	3.70
4/17/20 10:59	242.71	28.25	10.57	14.16	176.19	1182.29	3.70
4/17/20 11:00	242.61	28.23	10.57	14.20	177.13	1181.81	3.70

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 11:00 - 4/17 12:00)	242.07	28.26	10.56	14.28	167.28	1182.19	3.70
COUNT = 61							

Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/17/20 11:00	242.61	28.23	10.57	14.20	177.13	1181.81	3.70
4/17/20 11:01	243.07	28.32	10.57	14.17	172.33	1182.79	3.70
4/17/20 11:02	242.64	28.41	10.57	14.20	165.11	1183.37	3.70
4/17/20 11:03	242.27	28.26	10.57	14.15	177.69	1182.31	3.70
4/17/20 11:04	242.31	28.19	10.57	14.17	168.64	1182.77	3.70
4/17/20 11:05	243.23	28.29	10.57	14.66	166.34	1183.97	3.70
4/17/20 11:06	243.35	28.53	10.57	14.46	161.07	1183.65	3.70
4/17/20 11:07	242.49	28.29	10.57	14.38	174.44	1182.15	3.70
4/17/20 11:08	243.23	28.25	10.57	14.13	164.82	1182.99	3.70
4/17/20 11:09	242.54	28.30	10.57	14.31	165.21	1182.54	3.70
4/17/20 11:10	243.19	28.31	10.57	14.28	165.52	1182.75	3.70
4/17/20 11:11	242.53	28.42	10.57	14.47	164.84	1184.25	3.70
4/17/20 11:12	242.47	28.27	10.57	14.49	169.16	1183.32	3.70
4/17/20 11:13	242.84	28.25	10.57	14.17	166.36	1182.40	3.70
4/17/20 11:14	242.52	28.26	10.57	14.44	169.86	1183.56	3.70
4/17/20 11:15	242.46	28.41	10.57	14.23	166.21	1183.28	3.70
4/17/20 11:16	242.59	28.30	10.57	14.42	172.12	1182.35	3.70
4/17/20 11:17	242.34	28.25	10.57	14.19	161.41	1182.70	3.70
4/17/20 11:18	242.63	28.21	10.57	14.31	174.71	1182.96	3.70
4/17/20 11:19	242.13	28.25	10.57	14.23	159.83	1182.47	3.70
4/17/20 11:20	242.03	28.32	10.57	14.39	160.37	1181.98	3.70
4/17/20 11:21	241.78	28.26	10.57	14.31	171.24	1182.28	3.70
4/17/20 11:22	242.07	28.22	10.57	14.42	158.33	1182.51	3.70
4/17/20 11:23	241.96	28.27	10.57	14.00	169.58	1182.03	3.70
4/17/20 11:24	241.59	28.36	10.56	14.38	194.63	1181.88	3.70
4/17/20 11:25	242.05	28.30	10.56	14.37	199.57	1182.61	3.70
4/17/20 11:26	241.67	28.23	10.56	14.34	201.23	1181.95	3.70
4/17/20 11:27	242.01	28.26	10.56	14.10	193.18	1181.75	3.70
4/17/20 11:28	241.73	28.28	10.56	14.24	172.25	1182.28	3.70
4/17/20 11:29	242.13	28.27	10.56	14.01	179.83	1183.18	3.70
4/17/20 11:30	241.86	28.26	10.56	13.97	162.87	1181.88	3.70
4/17/20 11:31	242.20	28.17	10.56	14.48	172.40	1183.53	3.70
4/17/20 11:32	241.66	28.21	10.56	14.21	157.89	1182.11	3.70
4/17/20 11:33	242.15	28.31	10.56	14.38	171.82	1181.38	3.70
4/17/20 11:34	241.90	28.25	10.56	14.13	160.94	1181.66	3.70
4/17/20 11:35	242.30	28.21	10.56	14.26	166.35	1181.32	3.70
4/17/20 11:36	242.45	28.20	10.56	14.32	167.06	1182.16	3.70
4/17/20 11:37	242.02	28.26	10.56	14.34	160.88	1181.65	3.70
4/17/20 11:38	242.18	28.30	10.56	14.17	162.68	1182.74	3.70
4/17/20 11:39	241.78	28.23	10.56	14.29	171.06	1182.75	3.70
4/17/20 11:40	241.63	28.16	10.56	14.50	160.81	1182.36	3.70
4/17/20 11:41	241.56	28.16	10.56	14.19	166.38	1180.56	3.70
4/17/20 11:42	241.68	28.33	10.56	14.10	155.42	1181.35	3.70
4/17/20 11:43	241.93	28.21	10.56	13.99	168.70	1182.34	3.70
4/17/20 11:44	241.62	28.11	10.56	14.19	155.41	1181.69	3.70
4/17/20 11:45	242.02	28.24	10.56	14.56	163.88	1182.36	3.70
4/17/20 11:46	242.07	28.21	10.56	14.50	158.50	1181.36	3.70
4/17/20 11:47	241.23	28.29	10.56	14.02	155.97	1180.67	3.70
4/17/20 11:48	241.74	28.16	10.56	14.23	157.41	1182.07	3.70
4/17/20 11:49	241.46	28.19	10.56	14.45	161.43	1181.44	3.70
4/17/20 11:50	241.54	28.28	10.56	13.92	169.47	1181.17	3.70
4/17/20 11:51	241.35	28.24	10.56	14.30	154.69	1181.38	3.70
4/17/20 11:52	241.30	28.19	10.56	14.24	160.67	1181.23	3.70
4/17/20 11:53	241.67	28.21	10.56	14.10	162.86	1181.36	3.70
4/17/20 11:54	241.59	28.19	10.56	14.50	157.91	1181.66	3.70
4/17/20 11:55	241.79	28.31	10.56	14.29	166.05	1182.02	3.70
4/17/20 11:56	241.46	28.22	10.56	13.98	153.95	1180.91	3.70
4/17/20 11:57	241.52	28.16	10.56	14.44	167.57	1181.98	3.70
4/17/20 11:58	241.27	28.12	10.56	14.65	167.14	1182.26	3.70
4/17/20 11:59	241.14	28.26	10.56	14.32	156.36	1180.38	3.70
4/17/20 12:00	241.59	28.28	10.56	14.23	166.83	1180.96	3.70

Description	CTG3 Gross output	CT3 gas flow	U3 duct burner gas flow	HRSG3 duct inlet pressure	U3 SCR NH3 flow rate	CT3 exhaust gas flow	Aux boiler fuel gas flow
UOM	MW	lbm/s	kpph	inH2O	pph	lbm/s	pph
AVERAGE (4/17 12:00 - 4/17 13:00)	240.84	28.16	10.55	14.25	157.70	1180.44	3.70
COUNT = 61							
Signal Tagname	G3.DWATT	G3.FQG	H3.03JBFT105_ MassFlow	H3.03BAPT001	H3.03BSFIT500	G3.WEXH	BOPC2. 00SBFY061
4/17/20 12:00	241.59	28.28	10.56	14.23	166.83	1180.96	3.70
4/17/20 12:01	241.00	28.17	10.56	14.11	154.69	1180.78	3.70
4/17/20 12:02	241.32	28.13	10.56	14.31	166.92	1180.93	3.70
4/17/20 12:03	241.27	28.21	10.56	14.54	161.16	1181.04	3.70
4/17/20 12:04	241.49	28.25	10.56	14.11	155.46	1181.12	3.70
4/17/20 12:05	241.63	28.29	10.56	14.48	157.62	1181.83	3.70
4/17/20 12:06	242.13	28.18	10.56	14.22	156.55	1181.44	3.70
4/17/20 12:07	242.05	28.21	10.56	14.29	162.48	1181.21	3.70
4/17/20 12:08	241.36	28.29	10.56	14.11	164.83	1181.77	3.70
4/17/20 12:09	241.33	28.27	10.56	14.36	168.74	1180.75	3.70
4/17/20 12:10	241.12	28.15	10.56	14.54	159.53	1181.59	3.70
4/17/20 12:11	241.18	28.17	10.56	14.38	164.87	1182.25	3.70
4/17/20 12:12	241.52	28.20	10.56	14.13	159.32	1182.13	3.70
4/17/20 12:13	241.35	28.29	10.56	14.15	153.46	1180.75	3.70
4/17/20 12:14	241.80	28.24	10.56	14.32	155.20	1180.56	3.70
4/17/20 12:15	241.30	28.17	10.56	13.92	160.77	1180.71	3.70
4/17/20 12:16	241.17	28.19	10.56	14.56	165.49	1182.10	3.70
4/17/20 12:17	241.68	28.24	10.56	14.12	165.76	1181.53	3.70
4/17/20 12:18	241.70	28.24	10.56	13.91	157.41	1181.10	3.70
4/17/20 12:19	240.76	28.14	10.56	13.90	157.09	1180.87	3.70
4/17/20 12:20	240.92	28.18	10.56	14.05	156.97	1180.66	3.70
4/17/20 12:21	241.01	28.20	10.56	14.17	164.55	1180.81	3.70
4/17/20 12:22	240.68	28.17	10.56	14.36	150.94	1180.55	3.70
4/17/20 12:23	240.81	28.13	10.56	14.22	160.86	1180.50	3.70
4/17/20 12:24	240.46	28.11	10.56	14.42	148.74	1179.89	3.70
4/17/20 12:25	240.94	28.23	10.56	14.30	158.05	1180.96	3.70
4/17/20 12:26	240.74	28.18	10.56	14.22	154.27	1180.24	3.70
4/17/20 12:27	240.69	28.18	10.55	14.10	162.85	1179.62	3.70
4/17/20 12:28	240.51	28.12	10.55	14.21	150.09	1180.02	3.70
4/17/20 12:29	240.42	28.09	10.55	14.62	152.80	1180.89	3.70
4/17/20 12:30	240.77	28.19	10.55	14.09	161.74	1180.67	3.70
4/17/20 12:31	240.54	28.22	10.55	14.27	148.48	1180.58	3.70
4/17/20 12:32	240.49	28.07	10.55	14.60	159.37	1180.76	3.70
4/17/20 12:33	240.80	28.12	10.55	14.31	158.19	1181.20	3.70
4/17/20 12:34	240.66	28.22	10.55	14.21	160.51	1179.89	3.70
4/17/20 12:35	240.81	28.24	10.55	14.08	148.43	1180.02	3.70
4/17/20 12:36	240.48	28.14	10.55	14.12	160.27	1180.17	3.70
4/17/20 12:37	240.42	28.11	10.55	14.40	162.38	1180.71	3.70
4/17/20 12:38	240.47	28.07	10.55	14.24	158.33	1180.17	3.70
4/17/20 12:39	240.61	28.16	10.55	14.02	150.71	1179.57	3.70
4/17/20 12:40	240.39	28.21	10.55	14.24	150.94	1179.62	3.70
4/17/20 12:41	240.75	28.09	10.55	14.04	156.87	1179.41	3.70
4/17/20 12:42	240.89	28.10	10.55	14.03	153.78	1179.88	3.70
4/17/20 12:43	241.20	28.18	10.55	14.14	154.50	1181.54	3.70
4/17/20 12:44	240.97	28.22	10.55	14.15	151.27	1179.95	3.70
4/17/20 12:45	240.60	28.06	10.55	14.88	157.20	1180.53	3.70
4/17/20 12:46	240.43	28.10	10.55	14.17	163.46	1179.49	3.70
4/17/20 12:47	241.07	28.11	10.55	14.21	162.67	1179.93	3.70
4/17/20 12:48	240.70	28.14	10.55	14.28	159.54	1179.52	3.70
4/17/20 12:49	240.20	28.21	10.55	14.44	156.93	1179.79	3.70
4/17/20 12:50	240.09	28.07	10.55	14.50	152.66	1179.36	3.70
4/17/20 12:51	239.83	28.02	10.55	14.00	150.37	1180.03	3.70
4/17/20 12:52	239.93	28.13	10.55	14.12	150.92	1179.19	3.70
4/17/20 12:53	240.12	28.10	10.55	14.02	146.79	1179.66	3.70
4/17/20 12:54	239.48	27.99	10.55	14.49	159.18	1178.96	3.70
4/17/20 12:55	240.08	28.03	10.55	14.09	147.23	1179.16	3.70
4/17/20 12:56	240.20	28.09	10.55	14.16	156.36	1178.87	3.70
4/17/20 12:57	240.29	28.15	10.55	14.56	162.13	1180.20	3.70
4/17/20 12:58	240.41	28.07	10.55	14.39	160.80	1179.49	3.70
4/17/20 12:59	240.88	28.09	10.55	14.44	161.91	1179.95	3.70
4/17/20 13:00	240.49	28.12	10.55	14.31	161.66	1179.14	3.70

EMISSION DATA RECORDS

Reference Method Data
Base Load
NOx, CO, VOC, and NH_3

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,014	Btu/SCF fuel
Turbine Fuel Flow	1,651	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,293,723	SCFH

Weather Data

Barometric Pressure	29.99	in. Hg
Relative Humidity	23	%
Ambient Temperature	53	° F
Specific Humidity	0.001939	lb H_2O / lb air

Unit Data

Unit Load	237.6	megawatts
Heat Input	2,327	MMBtu/hr
NH_3 Flow Rate	142	lb/hr
Meas. Stack Moisture	8.8	%
Stack Exhaust Flow (M19)	52,372,088	SCFH

Data from: From PM Run PM U-00003 Base-1

Base Load, Run - 1-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/15/20 12:10:05	6570	12.72	1.88	-0.47	0.00	4.56	0.39
04/15/20 12:10:35	6600	12.73	1.78	-0.49	0.00	4.56	0.34
04/15/20 12:11:05	6630	12.74	1.84	-0.47	0.00	4.56	0.37
04/15/20 12:11:35	6660	12.74	1.85	-0.46	0.00	4.57	0.37
04/15/20 12:12:05	6690	12.75	1.85	-0.46	0.00	4.57	0.36
04/15/20 12:12:35	6720	12.76	1.81	-0.46	0.00	4.57	0.39
04/15/20 12:13:05	6750	12.77	1.79	-0.47	0.00	4.56	0.38
04/15/20 12:13:35	6780	12.76	1.78	-0.46	0.00	4.56	0.36
04/15/20 12:14:05	6810	12.77	1.74	-0.46	0.00	4.56	0.36
04/15/20 12:14:35	6840	12.76	1.75	-0.47	0.00	4.57	0.36
04/15/20 12:15:05	6870	12.76	1.79	-0.46	0.00	4.57	0.37
04/15/20 12:15:35	6900	12.76	1.85	-0.46	0.00	4.57	0.38
04/15/20 12:16:05	6930	12.75	1.86	-0.46	0.01	4.57	0.37
04/15/20 12:16:35	6960	12.75	1.85	-0.47	0.00	4.57	0.38
04/15/20 12:17:05	6990	12.74	1.81	-0.47	0.00	4.57	0.36
04/15/20 12:17:35	7020	12.74	1.83	-0.47	0.00	4.57	0.38
04/15/20 12:18:05	7050	12.76	1.92	-0.44	0.01	4.58	0.36
04/15/20 12:18:35	7080	12.76	1.90	-0.46	0.00	4.57	0.35
04/15/20 12:19:05	7110	12.76	1.87	-0.47	0.00	4.56	0.36
04/15/20 12:19:35	7140	12.76	1.83	-0.47	0.00	4.56	0.38
04/15/20 12:20:05	7170	12.76	1.78	-0.47	0.00	4.56	0.36
04/15/20 12:20:35	7200	12.77	1.78	-0.45	0.01	4.56	0.35
04/15/20 12:21:05	7230	12.77	1.68	-0.49	0.00	4.56	0.35
04/15/20 12:21:35	7260	12.78	1.81	-0.46	0.01	4.56	0.37
04/15/20 12:22:05	7290	12.79	1.79	-0.46	0.00	4.56	0.36
04/15/20 12:22:35	7320	12.79	1.79	-0.47	0.00	4.56	0.33
04/15/20 12:23:05	7350	12.77	1.81	-0.46	0.00	4.57	0.33
04/15/20 12:23:35	7380	12.77	1.79	-0.46	0.00	4.57	0.36
04/15/20 12:24:05	7410	12.77	1.80	-0.46	0.00	4.56	0.38
04/15/20 12:24:35	7440	12.77	1.75	-0.46	0.00	4.56	0.34
04/15/20 12:25:05	7470	12.77	1.76	-0.46	0.01	4.56	0.33
04/15/20 12:25:35	7500	12.77	1.79	-0.46	0.00	4.56	0.30
04/15/20 12:26:05	7530	12.77	1.78	-0.47	0.00	4.56	0.34
04/15/20 12:26:35	7560	12.78	1.74	-0.46	0.01	4.56	0.31
04/15/20 12:27:05	7590	12.77	1.76	-0.47	0.01	4.56	0.32
04/15/20 12:27:35	7620	12.77	1.76	-0.46	0.01	4.56	0.34
04/15/20 12:28:05	7650	12.76	1.79	-0.47	0.00	4.56	0.34
04/15/20 12:28:35	7680	12.76	1.85	-0.47	0.00	4.56	0.30
04/15/20 12:29:05	7710	12.77	1.84	-0.46	0.00	4.57	0.35
04/15/20 12:29:35	7740	12.77	1.81	-0.48	0.00	4.57	0.34
04/15/20 12:30:05	7770	12.77	1.87	-0.46	0.00	4.57	0.33
04/15/20 12:30:35	7800	12.76	1.85	-0.47	0.00	4.57	0.33
04/15/20 12:31:05	7830	12.75	1.92	-0.45	0.01	4.56	0.31
04/15/20 12:31:35	7860	12.76	1.90	-0.46	0.00	4.56	0.33
04/15/20 12:32:05	7890	12.78	1.93	-0.45	0.01	4.57	0.33
04/15/20 12:32:35	7920	12.78	1.84	-0.48	0.00	4.56	0.34
04/15/20 12:33:05	7950	12.75	1.87	-0.45	0.01	4.56	0.30
04/15/20 12:33:35	7980	12.76	1.85	-0.48	0.00	4.56	0.27
04/15/20 12:34:05	8010	12.77	1.80	-0.48	0.00	4.56	0.30
04/15/20 12:34:35	8040	12.78	1.87	-0.46	0.00	4.56	0.32
04/15/20 12:35:05	8070	12.76	1.85	-0.46	0.00	4.56	0.30
04/15/20 12:35:35	8100	12.77	1.85	-0.46	0.00	4.56	0.29
04/15/20 12:36:05	8130	12.76	1.75	-0.48	0.00	4.57	0.33
04/15/20 12:36:35	8160	12.76	1.69	-0.47	0.00	4.56	0.32
04/15/20 12:37:05	8190	12.78	1.63	-0.46	0.00	4.56	0.35
04/15/20 12:37:35	8220	12.78	1.60	-0.46	0.00	4.56	0.30
04/15/20 12:38:05	8250	12.76	1.61	-0.45	0.01	4.56	0.31
04/15/20 12:38:35	8280	12.76	1.54	-0.47	0.00	4.56	0.31
04/15/20 12:39:05	8310	12.77	1.48	-0.47	0.00	4.56	0.34
04/15/20 12:39:35	8340	12.77	1.41	-0.48	0.00	4.56	0.31
04/15/20 12:40:05	8370	12.76	1.34	-0.49	0.00	4.56	0.29
04/15/20 12:40:35	8400	12.76	1.40	-0.47	0.00	4.56	0.29
04/15/20 12:41:05	8430	12.77	1.37	-0.47	0.00	4.57	0.32
04/15/20 12:41:35	8460	12.77	1.46	-0.46	0.00	4.57	0.32
04/15/20 12:42:05	8490	12.77	1.46	-0.46	0.00	4.56	0.28
04/15/20 12:42:35	8520	12.77	1.45	-0.46	0.00	4.56	0.30
04/15/20 12:43:05	8550	12.79	1.44	-0.46	0.00	4.56	0.28
04/15/20 12:43:35	8580	12.78	1.46	-0.46	0.00	4.56	0.27
04/15/20 12:44:05	8610	12.77	1.47	-0.48	0.00	4.56	0.29
04/15/20 12:44:35	8640	12.77	1.51	-0.47	0.00	4.56	0.27
04/15/20 12:45:05	8670	12.77	1.57	-0.47	0.00	4.57	0.29
04/15/20 12:45:35	8700	12.77	1.55	-0.47	0.00	4.56	0.29
04/15/20 12:46:05	8730	12.76	1.66	-0.46	0.01	4.56	0.30
04/15/20 12:46:35	8760	12.76	1.66	-0.46	0.01	4.56	0.30
04/15/20 12:47:05	8790	12.76	1.68	-0.46	0.01	4.56	0.26
04/15/20 12:47:35	8820	12.77	1.67	-0.46	0.00	4.56	0.27
04/15/20 12:48:05	8850	12.77	1.67	-0.46	0.01	4.56	0.25

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,014	Btu/SCF fuel
Turbine Fuel Flow	1,651	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,293,723	SCFH

Weather Data

Barometric Pressure	29.99	in. Hg
Relative Humidity	23	%
Ambient Temperature	53	° F
Specific Humidity	0.001939	lb H_2O / lb air

Unit Data

Unit Load	237.6	megawatts
Heat Input	2,327	MMBtu/hr
NH_3 Flow Rate	142	lb/hr
Meas. Stack Moisture	8.8	%
Stack Exhaust Flow (M19)	52,372,088	SCFH

Data from: From PM Run PM U-00003 Base-1

Base Load, Run - 1-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/15/20 12:48:35	8880	12.77	1.71	-0.46	0.00	4.56	0.26
04/15/20 12:49:05	8910	12.76	1.71	-0.47	0.00	4.56	0.27
04/15/20 12:49:35	8940	12.77	1.73	-0.47	0.00	4.56	0.28
04/15/20 12:50:05	8970	12.75	1.73	-0.46	0.00	4.55	0.33
04/15/20 12:50:35	9000	12.77	1.79	-0.45	0.01	4.56	0.35
04/15/20 12:51:05	9030	12.77	1.84	-0.45	0.01	4.56	0.36
04/15/20 12:51:35	9060	12.77	1.93	-0.47	0.00	4.56	0.35
04/15/20 12:52:05	9090	12.77	1.93	-0.46	0.00	4.56	0.36
04/15/20 12:52:35	9120	12.77	1.96	-0.46	0.00	4.56	0.31
04/15/20 12:53:05	9150	12.78	1.94	-0.46	0.00	4.56	0.32
04/15/20 12:53:35	9180	12.78	1.93	-0.45	0.01	4.56	0.30
04/15/20 12:54:05	9210	12.77	1.93	-0.45	0.01	4.56	0.32
04/15/20 12:54:35	9240	12.77	1.88	-0.47	0.00	4.56	0.33
04/15/20 12:55:05	9270	12.77	1.92	-0.45	0.01	4.56	0.32
04/15/20 12:55:35	9300	12.77	1.86	-0.47	0.00	4.56	0.30
04/15/20 12:56:05	9330	12.76	1.91	-0.46	0.01	4.55	0.33
04/15/20 12:56:35	9360	12.77	1.95	-0.46	0.00	4.56	0.33
04/15/20 12:57:05	9390	12.78	1.98	-0.47	0.00	4.56	0.33
04/15/20 12:57:35	9420	12.77	1.97	-0.47	0.00	4.56	0.35
04/15/20 12:58:05	9450	12.78	1.99	-0.47	0.00	4.56	0.32
04/15/20 12:58:35	9480	12.77	2.00	-0.47	0.00	4.56	0.34
04/15/20 12:59:05	9510	12.77	2.00	-0.47	0.00	4.56	0.30
04/15/20 12:59:35	9540	12.77	1.99	-0.46	0.00	4.56	0.30
04/15/20 13:00:05	9570	12.76	1.95	-0.47	0.00	4.56	0.31
04/15/20 13:00:35	9600	12.76	1.97	-0.46	0.00	4.56	0.31
04/15/20 13:01:05	9630	12.77	1.95	-0.46	0.00	4.56	0.29
04/15/20 13:01:35	9660	12.76	1.92	-0.46	0.00	4.55	0.31
04/15/20 13:02:05	9690	12.77	1.89	-0.46	0.01	4.56	0.29
04/15/20 13:02:35	9720	12.76	1.87	-0.46	0.01	4.56	0.35
04/15/20 13:03:05	9750	12.78	1.84	-0.46	0.00	4.56	0.31
04/15/20 13:03:35	9780	12.78	1.81	-0.46	0.00	4.56	0.30
04/15/20 13:04:05	9810	12.77	1.78	-0.47	0.00	4.55	0.33
04/15/20 13:04:35	9840	12.77	1.85	-0.46	0.00	4.55	0.32
04/15/20 13:05:05	9870	12.79	1.85	-0.46	0.00	4.56	0.34
04/15/20 13:05:35	9900	12.79	1.88	-0.47	0.00	4.55	0.32
04/15/20 13:06:05	9930	12.78	1.81	-0.46	0.00	4.55	0.30
04/15/20 13:06:35	9960	12.79	1.83	-0.45	0.01	4.55	0.30
04/15/20 13:07:05	9990	12.78	1.76	-0.47	0.00	4.55	0.33
04/15/20 13:07:35	10020	12.78	1.80	-0.46	0.00	4.55	0.34
04/15/20 13:08:05	10050	12.78	1.85	-0.46	0.00	4.55	0.32
04/15/20 13:08:35	10080	12.78	1.90	-0.46	0.01	4.55	0.33
04/15/20 13:09:05	10110	12.77	1.88	-0.47	0.00	4.55	0.33
04/15/20 13:09:35	10140	12.77	1.91	-0.47	0.00	4.56	0.30
RAW AVERAGE		**12.77**	**1.78**	**-0.46**	**0.00**	**4.56**	**0.33**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.03	0.06	0.06	-0.01	-0.02	
Bias	**Final Zero**	0.09	0.05	-0.17	0.00	-0.16	
Bias	**Avg. Zero**	0.06	0.06	-0.06	0.00	-0.09	
Bias	**Initial UpScale**	11.90	4.60	5.19	3.02	8.89	
Bias	**Final UpScale**	11.86	4.62	4.88	3.15	8.89	
Bias	**Avg. UpScale**	11.88	4.61	5.04	3.09	8.89	
Upscale Cal Gas		11.98	4.55	5.22	3.03	8.91	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	12.88	1.73	0.00	0.00	4.62	0.36
Concentration (ppm@ 15%O_2)	N/A	1.27	0.00	0.00	N/A	0.26

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,014	Btu/SCF fuel
Turbine Fuel Flow	1,646	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,287,005	SCFH

Weather Data

Barometric Pressure	30.11	in. Hg
Relative Humidity	25	%
Ambient Temperature	54	° F
Specific Humidity	0.002178	lb H_2O / lb air

Unit Data

Unit Load	237.1	megawatts
Heat Input	2,320	MMBtu/hr
NH_3 Flow Rate	135	lb/hr
Meas. Stack Moisture	8.8	%
Stack Exhaust Flow (M19)	52,469,624	SCFH

Data from: From PM Run PM U-00003 Base-1

Base Load, Run - 1-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/15/20 13:23:05	10950	12.72	1.95	-0.47	0.00	4.88	0.30
04/15/20 13:23:35	10980	12.70	1.92	-0.46	0.00	4.88	0.30
04/15/20 13:24:05	11010	12.73	1.90	-0.46	0.00	4.87	0.28
04/15/20 13:24:35	11040	12.75	1.83	-0.47	0.00	4.88	0.32
04/15/20 13:25:05	11070	12.76	1.82	-0.47	0.00	4.89	0.28
04/15/20 13:25:35	11100	12.76	1.84	-0.46	0.01	4.89	0.27
04/15/20 13:26:05	11130	12.76	1.76	-0.48	0.00	4.89	0.30
04/15/20 13:26:35	11160	12.76	1.79	-0.47	0.00	4.89	0.25
04/15/20 13:27:05	11190	12.76	1.89	-0.45	0.01	4.89	0.27
04/15/20 13:27:35	11220	12.76	1.87	-0.46	0.00	4.89	0.31
04/15/20 13:28:05	11250	12.77	1.90	-0.46	0.00	4.89	0.26
04/15/20 13:28:35	11280	12.72	1.89	-0.47	0.00	4.87	0.28
04/15/20 13:29:05	11310	12.75	1.91	-0.46	0.00	4.89	0.26
04/15/20 13:29:35	11340	12.76	1.95	-0.46	0.00	4.89	0.29
04/15/20 13:30:05	11370	12.77	1.94	-0.47	0.00	4.89	0.30
04/15/20 13:30:35	11400	12.77	1.93	-0.47	0.00	4.89	0.28
04/15/20 13:31:05	11430	12.77	1.95	-0.47	0.00	4.89	0.28
04/15/20 13:31:35	11460	12.77	1.98	-0.46	0.00	4.89	0.28
04/15/20 13:32:05	11490	12.76	1.97	-0.47	0.00	4.89	0.28
04/15/20 13:32:35	11520	12.76	2.00	-0.46	0.01	4.89	0.28
04/15/20 13:33:05	11550	12.76	2.00	-0.47	0.00	4.89	0.30
04/15/20 13:33:35	11580	12.76	1.98	-0.47	0.00	4.89	0.27
04/15/20 13:34:05	11610	12.77	2.06	-0.46	0.00	4.89	0.29
04/15/20 13:34:35	11640	12.76	2.05	-0.47	0.00	4.90	0.27
04/15/20 13:35:05	11670	12.77	2.06	-0.47	0.00	4.90	0.28
04/15/20 13:35:35	11700	12.77	2.07	-0.47	0.00	4.90	0.26
04/15/20 13:36:05	11730	12.78	2.05	-0.46	0.00	4.90	0.27
04/15/20 13:36:35	11760	12.77	2.04	-0.47	0.00	4.90	0.27
04/15/20 13:37:05	11790	12.77	2.07	-0.45	0.01	4.89	0.25
04/15/20 13:37:35	11820	12.77	2.00	-0.46	0.00	4.89	0.28
04/15/20 13:38:05	11850	12.76	1.95	-0.47	0.00	4.90	0.28
04/15/20 13:38:35	11880	12.76	1.91	-0.47	0.00	4.90	0.26
04/15/20 13:39:05	11910	12.76	1.89	-0.47	0.00	4.90	0.27
04/15/20 13:39:35	11940	12.78	1.89	-0.46	0.00	4.90	0.23
04/15/20 13:40:05	11970	12.76	1.90	-0.47	0.00	4.89	0.25
04/15/20 13:40:35	12000	12.76	1.88	-0.46	0.00	4.89	0.24
04/15/20 13:41:05	12030	12.76	1.81	-0.48	0.00	4.90	0.27
04/15/20 13:41:35	12060	12.76	1.90	-0.47	0.00	4.90	0.23
04/15/20 13:42:05	12090	12.76	1.95	-0.46	0.00	4.89	0.25
04/15/20 13:42:35	12120	12.76	1.98	-0.47	0.00	4.89	0.26
04/15/20 13:43:05	12150	12.77	2.00	-0.46	0.00	4.90	0.28
04/15/20 13:43:35	12180	12.77	1.94	-0.47	0.00	4.90	0.25
04/15/20 13:44:05	12210	12.77	1.98	-0.47	0.00	4.90	0.25
04/15/20 13:44:35	12240	12.75	1.98	-0.46	0.00	4.89	0.25
04/15/20 13:45:05	12270	12.75	1.94	-0.46	0.00	4.88	0.26
04/15/20 13:45:35	12300	12.77	1.97	-0.47	0.00	4.89	0.24
04/15/20 13:46:05	12330	12.78	1.90	-0.47	0.00	4.89	0.25
04/15/20 13:46:35	12360	12.77	1.82	-0.46	0.00	4.89	0.24
04/15/20 13:47:05	12390	12.76	1.77	-0.47	0.00	4.89	0.25
04/15/20 13:47:35	12420	12.77	1.77	-0.45	0.01	4.90	0.26
04/15/20 13:48:05	12450	12.77	1.78	-0.45	0.01	4.89	0.25
04/15/20 13:48:35	12480	12.76	1.73	-0.47	0.00	4.89	0.23
04/15/20 13:49:05	12510	12.78	1.73	-0.47	0.00	4.89	0.23
04/15/20 13:49:35	12540	12.78	1.78	-0.46	0.01	4.89	0.22
04/15/20 13:50:05	12570	12.77	1.76	-0.46	0.00	4.89	0.25
04/15/20 13:50:35	12600	12.77	1.79	-0.47	0.00	4.89	0.22
04/15/20 13:51:05	12630	12.77	1.73	-0.48	0.00	4.90	0.26
04/15/20 13:51:35	12660	12.77	1.75	-0.48	0.00	4.90	0.25
04/15/20 13:52:05	12690	12.77	1.82	-0.46	0.00	4.89	0.25
04/15/20 13:52:35	12720	12.77	1.78	-0.47	0.00	4.89	0.21
04/15/20 13:53:05	12750	12.78	1.80	-0.47	0.00	4.89	0.22
04/15/20 13:53:35	12780	12.78	1.80	-0.47	0.00	4.89	0.23
04/15/20 13:54:05	12810	12.77	1.88	-0.46	0.01	4.89	0.21
04/15/20 13:54:35	12840	12.77	1.90	-0.46	0.00	4.89	0.24
04/15/20 13:55:05	12870	12.76	1.95	-0.46	0.00	4.89	0.23
04/15/20 13:55:35	12900	12.76	1.99	-0.46	0.00	4.89	0.21
04/15/20 13:56:05	12930	12.76	2.03	-0.46	0.00	4.89	0.25
04/15/20 13:56:35	12960	12.77	2.03	-0.45	0.01	4.89	0.22
04/15/20 13:57:05	12990	12.77	2.02	-0.46	0.01	4.89	0.21
04/15/20 13:57:35	13020	12.77	1.95	-0.48	0.00	4.89	0.23
04/15/20 13:58:05	13050	12.77	2.00	-0.46	0.00	4.89	0.22
04/15/20 13:58:35	13080	12.77	2.02	-0.46	0.00	4.89	0.26
04/15/20 13:59:05	13110	12.78	2.05	-0.47	0.00	4.89	0.27
04/15/20 13:59:35	13140	12.78	2.09	-0.46	0.00	4.89	0.25
04/15/20 14:00:05	13170	12.77	2.02	-0.47	0.00	4.88	0.26
04/15/20 14:00:35	13200	12.77	1.95	-0.46	0.00	4.88	0.24
04/15/20 14:01:05	13230	12.79	1.90	-0.46	0.00	4.89	0.25

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,014	Btu/SCF fuel
Turbine Fuel Flow	1,646	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,287,005	SCFH

Weather Data

Barometric Pressure	30.11	in. Hg
Relative Humidity	25	%
Ambient Temperature	54	°F
Specific Humidity	0.002178	lb H_2O / lb air

Unit Data

Unit Load	237.1	megawatts
Heat Input	2,320	MMBtu/hr
NH_3 Flow Rate	135	lb/hr
Meas. Stack Moisture	8.8	%
Stack Exhaust Flow (M19)	52,469,624	SCFH

Data from: From PM Run PM U-00003 Base-1

Base Load, Run - 1-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/15/20 14:01:35	13260	12.79	1.90	-0.46	0.00	4.89	0.26
04/15/20 14:02:05	13290	12.78	1.86	-0.48	0.00	4.89	0.25
04/15/20 14:02:35	13320	12.78	1.89	-0.46	0.00	4.89	0.26
04/15/20 14:03:05	13350	12.77	1.90	-0.46	0.00	4.89	0.28
04/15/20 14:03:35	13380	12.78	1.93	-0.46	0.00	4.89	0.25
04/15/20 14:04:05	13410	12.77	1.91	-0.47	0.00	4.89	0.25
04/15/20 14:04:35	13440	12.77	1.96	-0.46	0.00	4.89	0.24
04/15/20 14:05:05	13470	12.77	1.96	-0.47	0.00	4.89	0.27
04/15/20 14:05:35	13500	12.78	1.98	-0.45	0.01	4.89	0.28
04/15/20 14:06:05	13530	12.78	1.95	-0.47	0.00	4.89	0.30
04/15/20 14:06:35	13560	12.78	2.01	-0.47	0.00	4.89	0.26
04/15/20 14:07:05	13590	12.77	2.00	-0.47	0.00	4.89	0.28
04/15/20 14:07:35	13620	12.77	1.97	-0.47	0.00	4.89	0.27
04/15/20 14:08:05	13650	12.77	2.03	-0.46	0.01	4.89	0.25
04/15/20 14:08:35	13680	12.77	2.04	-0.47	0.00	4.88	0.27
04/15/20 14:09:05	13710	12.78	2.03	-0.46	0.00	4.89	0.25
04/15/20 14:09:35	13740	12.78	1.98	-0.47	0.00	4.89	0.22
04/15/20 14:10:05	13770	12.79	2.05	-0.46	0.01	4.89	0.25
04/15/20 14:10:35	13800	12.78	2.04	-0.47	0.00	4.89	0.23
04/15/20 14:11:05	13830	12.78	2.04	-0.46	0.00	4.89	0.27
04/15/20 14:11:35	13860	12.78	2.05	-0.47	0.00	4.89	0.24
04/15/20 14:12:05	13890	12.78	2.03	-0.46	0.00	4.89	0.26
04/15/20 14:12:35	13920	12.78	2.06	-0.46	0.00	4.89	0.25
04/15/20 14:13:05	13950	12.77	2.06	-0.47	0.00	4.88	0.25
04/15/20 14:13:35	13980	12.77	2.06	-0.47	0.00	4.89	0.26
04/15/20 14:14:05	14010	12.77	2.09	-0.46	0.00	4.88	0.23
04/15/20 14:14:35	14040	12.77	2.05	-0.46	0.00	4.88	0.27
04/15/20 14:15:05	14070	12.77	2.04	-0.47	0.00	4.88	0.24
04/15/20 14:15:35	14100	12.77	2.04	-0.47	0.00	4.88	0.25
04/15/20 14:16:05	14130	12.79	2.01	-0.47	0.00	4.88	0.26
04/15/20 14:16:35	14160	12.79	2.00	-0.47	0.00	4.88	0.26
04/15/20 14:17:05	14190	12.78	2.06	-0.46	0.00	4.88	0.25
04/15/20 14:17:35	14220	12.79	2.05	-0.46	0.00	4.88	0.24
04/15/20 14:18:05	14250	12.78	2.02	-0.46	0.00	4.88	0.24
04/15/20 14:18:35	14280	12.78	2.03	-0.47	0.00	4.88	0.22
04/15/20 14:19:05	14310	12.78	2.03	-0.45	0.01	4.88	0.25
04/15/20 14:19:35	14340	12.78	2.00	-0.46	0.00	4.88	0.22
04/15/20 14:20:05	14370	12.78	1.98	-0.46	0.00	4.88	0.22
04/15/20 14:20:35	14400	12.78	2.00	-0.47	0.00	4.88	0.27
04/15/20 14:21:05	14430	12.78	2.03	-0.46	0.00	4.88	0.26
04/15/20 14:21:35	14460	12.79	2.05	-0.46	0.00	4.88	0.25
04/15/20 14:22:05	14490	12.79	2.01	-0.47	0.00	4.88	0.24
04/15/20 14:22:35	14520	12.79	2.06	-0.46	0.01	4.88	0.23
RAW AVERAGE		**12.77**	**1.95**	**-0.46**	**0.00**	**4.89**	**0.26**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.09	0.05	-0.17	0.00	-0.16	
Bias	**Final Zero**	0.12	0.29	-0.17	-0.01	0.08	
Bias	**Avg. Zero**	0.11	0.17	-0.17	0.00	-0.04	
Bias	**Initial UpScale**	11.86	4.62	4.88	3.15	8.89	
Bias	**Final UpScale**	11.84	4.66	5.01	2.92	8.98	
Bias	**Avg. UpScale**	11.85	4.64	4.95	3.04	8.94	
Upscale Cal Gas		11.98	4.55	5.22	3.03	8.91	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	12.92	1.81	0.00	0.00	4.89	0.28
Concentration (ppm@ 15%O_2)	N/A	1.34	0.00	0.00	N/A	0.21

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,014	Btu/SCF fuel
Turbine Fuel Flow	1,643	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,282,441	SCFH

Weather Data

Barometric Pressure	30.09	in. Hg
Relative Humidity	29	%
Ambient Temperature	50	°F
Specific Humidity	0.002181	lb H_2O / lb air

Unit Data

Unit Load	237.5	megawatts
Heat Input	2,315	MMBtu/hr
NH_3 Flow Rate	137	lb/hr
Meas. Stack Moisture	8.6	%
Stack Exhaust Flow (M19)	52,110,077	SCFH

Data from: From PM Run PM U-00003 Base-2

Base Load, Run - 1-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/15/20 14:35:05	15270	12.68	2.06	-0.45	0.34	4.85	0.33
04/15/20 14:35:35	15300	12.69	1.98	-0.47	0.21	4.86	0.37
04/15/20 14:36:05	15330	12.70	2.05	-0.44	0.04	4.86	0.38
04/15/20 14:36:35	15360	12.71	1.98	-0.47	0.02	4.86	0.41
04/15/20 14:37:05	15390	12.71	1.99	-0.47	0.00	4.87	0.46
04/15/20 14:37:35	15420	12.71	1.97	-0.46	0.00	4.87	0.47
04/15/20 14:38:05	15450	12.71	1.93	-0.47	0.00	4.87	0.51
04/15/20 14:38:35	15480	12.71	1.93	-0.47	0.00	4.87	0.47
04/15/20 14:39:05	15510	12.71	1.94	-0.46	0.00	4.87	0.48
04/15/20 14:39:35	15540	12.71	1.91	-0.46	0.00	4.87	0.48
04/15/20 14:40:05	15570	12.70	1.93	-0.47	0.00	4.88	0.45
04/15/20 14:40:35	15600	12.71	1.91	-0.47	0.00	4.87	0.49
04/15/20 14:41:05	15630	12.70	1.87	-0.46	0.00	4.87	0.51
04/15/20 14:41:35	15660	12.70	1.85	-0.46	0.00	4.87	0.47
04/15/20 14:42:05	15690	12.70	1.86	-0.46	0.00	4.87	0.49
04/15/20 14:42:35	15720	12.71	1.88	-0.46	0.00	4.88	0.48
04/15/20 14:43:05	15750	12.71	1.89	-0.46	0.00	4.88	0.49
04/15/20 14:43:35	15780	12.70	1.86	-0.47	0.00	4.88	0.46
04/15/20 14:44:05	15810	12.70	1.89	-0.46	0.00	4.88	0.45
04/15/20 14:44:35	15840	12.70	1.88	-0.47	0.00	4.88	0.44
04/15/20 14:45:05	15870	12.71	1.83	-0.46	0.00	4.88	0.44
04/15/20 14:45:35	15900	12.71	1.84	-0.46	0.00	4.88	0.44
04/15/20 14:46:05	15930	12.72	1.81	-0.46	0.00	4.88	0.44
04/15/20 14:46:35	15960	12.72	1.79	-0.47	0.00	4.88	0.45
04/15/20 14:47:05	15990	12.71	1.80	-0.46	0.00	4.88	0.40
04/15/20 14:47:35	16020	12.71	1.80	-0.46	0.00	4.88	0.44
04/15/20 14:48:05	16050	12.71	1.80	-0.47	0.00	4.88	0.40
04/15/20 14:48:35	16080	12.71	1.83	-0.46	0.00	4.88	0.42
04/15/20 14:49:05	16110	12.72	1.85	-0.47	0.00	4.88	0.41
04/15/20 14:49:35	16140	12.72	1.87	-0.47	0.00	4.88	0.41
04/15/20 14:50:05	16170	12.73	1.87	-0.46	0.00	4.88	0.40
04/15/20 14:50:35	16200	12.73	1.84	-0.46	0.00	4.88	0.38
04/15/20 14:51:05	16230	12.71	1.79	-0.47	0.00	4.88	0.38
04/15/20 14:51:35	16260	12.71	1.80	-0.46	0.00	4.88	0.38
04/15/20 14:52:05	16290	12.71	1.81	-0.46	0.01	4.88	0.37
04/15/20 14:52:35	16320	12.71	1.79	-0.47	0.00	4.88	0.35
04/15/20 14:53:05	16350	12.73	1.78	-0.46	0.00	4.88	0.37
04/15/20 14:53:35	16380	12.73	1.85	-0.46	0.00	4.88	0.37
04/15/20 14:54:05	16410	12.72	1.85	-0.47	0.00	4.88	0.36
04/15/20 14:54:35	16440	12.72	1.87	-0.46	0.00	4.88	0.34
04/15/20 14:55:05	16470	12.72	1.92	-0.47	0.00	4.88	0.34
04/15/20 14:55:35	16500	12.72	1.92	-0.46	0.01	4.88	0.35
04/15/20 14:56:05	16530	12.72	1.94	-0.46	0.00	4.88	0.33
04/15/20 14:56:35	16560	12.73	1.95	-0.46	0.00	4.88	0.37
04/15/20 14:57:05	16590	12.73	1.93	-0.47	0.00	4.88	0.34
04/15/20 14:57:35	16620	12.73	1.90	-0.47	0.00	4.88	0.33
04/15/20 14:58:05	16650	12.72	1.90	-0.46	0.00	4.88	0.33
04/15/20 14:58:35	16680	12.72	1.83	-0.46	0.00	4.88	0.33
04/15/20 14:59:05	16710	12.73	1.81	-0.46	0.00	4.88	0.32
04/15/20 14:59:35	16740	12.73	1.85	-0.46	0.00	4.88	0.32
04/15/20 15:00:05	16770	12.72	1.85	-0.46	0.00	4.88	0.31
04/15/20 15:00:35	16800	12.72	1.85	-0.46	0.00	4.88	0.34
04/15/20 15:01:05	16830	12.72	1.84	-0.47	0.00	4.88	0.32
04/15/20 15:01:35	16860	12.71	1.90	-0.46	0.01	4.88	0.30
04/15/20 15:02:05	16890	12.73	1.93	-0.46	0.00	4.88	0.33
04/15/20 15:02:35	16920	12.73	1.94	-0.47	0.00	4.88	0.29
04/15/20 15:03:05	16950	12.72	1.94	-0.47	0.00	4.88	0.29
04/15/20 15:03:35	16980	12.72	1.95	-0.46	0.00	4.88	0.30
04/15/20 15:04:05	17010	12.71	1.97	-0.47	0.00	4.88	0.30
04/15/20 15:04:35	17040	12.71	2.00	-0.45	0.01	4.88	0.29
04/15/20 15:05:05	17070	12.72	1.95	-0.47	0.00	4.88	0.31
04/15/20 15:05:35	17100	12.72	1.95	-0.47	0.00	4.88	0.27
04/15/20 15:06:05	17130	12.71	1.90	-0.46	0.00	4.88	0.30
04/15/20 15:06:35	17160	12.71	1.93	-0.47	0.00	4.88	0.31
04/15/20 15:07:05	17190	12.71	1.91	-0.46	0.01	4.88	0.28
04/15/20 15:07:35	17220	12.71	1.88	-0.45	0.01	4.88	0.32
04/15/20 15:08:05	17250	12.70	1.83	-0.47	0.00	4.88	0.28
04/15/20 15:08:35	17280	12.71	1.81	-0.47	0.00	4.88	0.26
04/15/20 15:09:05	17310	12.72	1.87	-0.45	0.01	4.88	0.27
04/15/20 15:09:35	17340	12.73	1.83	-0.47	0.00	4.88	0.31
04/15/20 15:10:05	17370	12.71	1.85	-0.46	0.00	4.89	0.27
04/15/20 15:10:35	17400	12.71	1.86	-0.46	0.00	4.89	0.28
04/15/20 15:11:05	17430	12.71	1.90	-0.46	0.00	4.88	0.28
04/15/20 15:11:35	17460	12.71	1.90	-0.46	0.00	4.88	0.29
04/15/20 15:12:05	17490	12.71	1.88	-0.47	0.00	4.88	0.27
04/15/20 15:12:35	17520	12.71	1.91	-0.46	0.01	4.88	0.27
04/15/20 15:13:05	17550	12.71	1.91	-0.46	0.00	4.88	0.27

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,638	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,014	Btu/SCF fuel
Turbine Fuel Flow	1,643	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,282,441	SCFH

Weather Data

Barometric Pressure	30.09	in. Hg
Relative Humidity	29	%
Ambient Temperature	50	°F
Specific Humidity	0.002181	lb H_2O / lb air

Unit Data

Unit Load	237.5	megawatts
Heat Input	2,315	MMBtu/hr
NH_3 Flow Rate	137	lb/hr
Meas. Stack Moisture	8.6	%
Stack Exhaust Flow (M19)	52,110,077	SCFH

Data from: From PM Run PM U-00003 Base-2

Base Load, Run - 1-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/15/20 15:13:35	17580	12.71	1.91	-0.46	0.00	4.88	0.24
04/15/20 15:14:05	17610	12.72	1.89	-0.46	0.00	4.89	0.27
04/15/20 15:14:35	17640	12.72	1.87	-0.47	0.00	4.89	0.29
04/15/20 15:15:05	17670	12.72	1.89	-0.47	0.00	4.88	0.28
04/15/20 15:15:35	17700	12.72	1.88	-0.47	0.00	4.88	0.26
04/15/20 15:16:05	17730	12.73	1.92	-0.45	0.01	4.89	0.23
04/15/20 15:16:35	17760	12.73	1.94	-0.45	0.01	4.89	0.28
04/15/20 15:17:05	17790	12.71	1.93	-0.45	0.01	4.88	0.28
04/15/20 15:17:35	17820	12.71	1.90	-0.46	0.00	4.88	0.28
04/15/20 15:18:05	17850	12.71	1.90	-0.46	0.00	4.88	0.24
04/15/20 15:18:35	17880	12.71	1.89	-0.47	0.00	4.88	0.25
04/15/20 15:19:05	17910	12.72	1.89	-0.46	0.00	4.88	0.28
04/15/20 15:19:35	17940	12.72	1.85	-0.47	0.00	4.88	0.27
04/15/20 15:20:05	17970	12.71	1.86	-0.48	0.00	4.88	0.29
04/15/20 15:20:35	18000	12.72	1.94	-0.47	0.00	4.88	0.27
04/15/20 15:21:05	18030	12.72	2.04	-0.46	0.00	4.88	0.26
04/15/20 15:21:35	18060	12.72	2.04	-0.48	0.00	4.88	0.25
04/15/20 15:22:05	18090	12.71	2.09	-0.47	0.01	4.88	0.29
04/15/20 15:22:35	18120	12.71	2.03	-0.47	0.00	4.88	0.24
04/15/20 15:23:05	18150	12.71	2.02	-0.47	0.00	4.88	0.26
04/15/20 15:23:35	18180	12.71	2.09	-0.45	0.01	4.88	0.28
04/15/20 15:24:05	18210	12.72	2.04	-0.47	0.00	4.88	0.26
04/15/20 15:24:35	18240	12.72	2.05	-0.46	0.00	4.88	0.28
04/15/20 15:25:05	18270	12.72	2.06	-0.46	0.00	4.88	0.25
04/15/20 15:25:35	18300	12.72	2.05	-0.46	0.00	4.88	0.26
04/15/20 15:26:05	18330	12.70	2.09	-0.47	0.00	4.88	0.27
04/15/20 15:26:35	18360	12.71	2.08	-0.46	0.00	4.88	0.23
04/15/20 15:27:05	18390	12.71	2.04	-0.46	0.00	4.88	0.31
04/15/20 15:27:35	18420	12.71	2.08	-0.45	0.01	4.88	0.36
04/15/20 15:28:05	18450	12.71	2.00	-0.48	0.00	4.88	0.34
04/15/20 15:28:35	18480	12.72	2.07	-0.47	0.00	4.88	0.36
04/15/20 15:29:05	18510	12.71	2.08	-0.46	0.00	4.87	0.37
04/15/20 15:29:35	18540	12.72	2.06	-0.46	0.00	4.87	0.35
04/15/20 15:30:05	18570	12.72	2.06	-0.46	0.00	4.88	0.33
04/15/20 15:30:35	18600	12.72	2.01	-0.44	0.01	4.88	0.36
04/15/20 15:31:05	18630	12.71	1.81	-0.46	0.01	4.87	0.34
04/15/20 15:31:35	18660	12.71	1.70	-0.46	0.01	4.87	0.33
04/15/20 15:32:05	18690	12.73	1.62	-0.46	0.01	4.88	0.31
04/15/20 15:32:35	18720	12.73	1.55	-0.47	0.00	4.88	0.33
04/15/20 15:33:05	18750	12.71	1.55	-0.46	0.00	4.88	0.36
04/15/20 15:33:35	18780	12.71	1.54	-0.47	0.00	4.87	0.35
04/15/20 15:34:05	18810	12.72	1.56	-0.45	0.01	4.88	0.34
04/15/20 15:34:35	18840	12.72	1.59	-0.45	0.01	4.87	0.36
RAW AVERAGE		**12.71**	**1.90**	**-0.46**	**0.01**	**4.88**	**0.34**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.12	0.29	-0.17	-0.01	0.08	
Bias	**Final Zero**	0.10	0.09	-0.43	0.01	0.09	
Bias	**Avg. Zero**	0.11	0.19	-0.30	0.00	0.09	
Bias	**Initial UpScale**	11.84	4.66	5.01	2.92	8.98	
Bias	**Final UpScale**	11.83	4.56	4.82	2.78	9.08	
Bias	**Avg. UpScale**	11.84	4.61	4.92	2.85	9.03	
Upscale Cal Gas		11.98	4.55	5.22	3.03	8.91	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	12.88	1.76	0.00	0.01	4.78	0.37
Concentration (ppm@ 15%O_2)	N/A	1.29	0.00	0.01	N/A	0.27

Non-Bias Adjusted Averages Include: *

EMISSION DATA RECORDS

Reference Method Data
Base Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#3	
Operator		Rob White	
Date for Preliminary Run	(mm/dd/yy)	04/15/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		U-00003	
Base Run Number		PM U-00003 Base	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	04/15/20	04/15/20	04/16/20	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8638.02	8638.02	8641.42	dscf/MMBtu
Meter Box Number	from ACS	Samp-cp-0033	Samp-cp-0033	Samp-cp-0033	
Meter Calibration Factor	(Y)	0.978	0.978	0.978	
Orifice Meter Coefficient	($\Delta H_@$)	1.846	1.846	1.846	in H_2O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	5266/10	5266/10	5266/10	
Pitot Tube Coefficient	(C_p)	0.7720	0.7720	0.7720	
Nozzle Number	from ACS	4a	4a	4a	must match cyc nozz tab (e.g. 3a, 4b, etc.)
Nozzle Diameter	(D_n)	0.157	0.157	0.157	in
Probe Number	from ACS	SAMP-HP-0138	SAMP-HP-0138	SAMP-HP-0138	
Probe Length		120.0	120.0	120.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039	
Impinger Case Number	from ACS	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	04/15/20
Sampling Location	U-00003 Base	**Stack Type**	Circular
Operator	Rob White	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	4
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

○ Method 1 Trav

◉ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
4	**Ports by**	3	**Across**
12	**Pts Used**	12	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.044	10	18
2	0.146	33 2/8	41 2/8
3	0.296	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Cricket Valley Energy Center			
Sampling Location	U-00003 Base			
Operator	Rob White			
Project #	bec-19-cricketvalley.ny-start#3			
Pitot Leak Check	x	**PreTest**	x	**PostTest**

Preliminary Run Date	04/15/20		
Stack Type	Circular		
Ports Available	4		
Thermocouple ID	SAMP-HP-0138		
Pitot Coefficient	0.8198	**Pitot Identification**	4187

RM 201A or OTM 27 Blckag.	**RM 201A or OTM 27 Pitot Coeff.**
5.39E-04	0.7720

Stack Dimensions			
Area of Stack	(A_s)	283.53	ft²
Diameter of Stack	(D)	228.00	in

Pressures			
Barometric Pressure	(P_b)	29.94	in Hg
Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	29.87	in Hg

Stack Gas Composition			
Composition Data:	**Estimated Composition**		
Carbon Dioxide Concentration	($\%CO_2$)	4.90	%vd
Oxygen Concentration	($\%O_2$)	13.00	%vd
Carbon Monoxide Concentration	(ppmCO)	0.00	ppmvd
Nitrogen Concentration	($\%N_2$)	82.10	%vd
Stack Moisture Content	(B_{ws})	8.00	%
Stack Dry Molecular Weight	(M_d)	29.30	lb/lb-mole
Stack Wet Molecular Weight	(M_w)	28.40	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v_s)	68.88	ft/sec
Avg Stack Dry Std Flow Rate	(Q_{sd})	50,648,445	dscf/hr
Avg Stack Dry Std Flow Rate	(Q_{sd})	844,141	dscf/min
Avg Stack Wet Flow Rate	(Q_{aw})	1,171,822	acf/min
Avg Stack Wet Std Flow Rate	(Q_{sw})	55,052,658	ascf/hr

40 CFR 60, Method 2G, Section 8.11.1 (but applies to all Method 2 type static pressure measurements):
If a Type S probe is used for this measurement, position the probe at or between any traverse point(s) and rotate the probe until a null differential pressure reading is obtained. Disconnect the tubing from one of the pressure ports; read and record the ΔP. For pressure devices with one-directional scales, if a deflection in the positive direction is noted with the negative side disconnected, then the static pressure is positive. Likewise, if a deflection in the positive direction is noted with the positive side disconnected, then the static pressure is negative.

Stack Cross Section Schematic

Velocity Traverse Data

Run Number	PM U-00003 Base-V1				
Run Time	06:45	**Start**	07:10	**End**	

Traverse Point	**Velocity Head** (Δp)	**Null Angle** (N_a)	**Zero Deg Pressure** ($0°_a$)	**Stack Temp** (t_s)	**Local Velocity** ($v_{s(l)}$)	**Adjusted Velocity Pressure**	**Adjusted Velocity Pressure w/BF, if app**
	in H_2O	deg	in H_2O	°F	ft/sec	in H_2O	in H_2O
A-1	1.70	-10	0.25	214	81.45	1.51	1.51
A-2	1.70	-5	0.15	214	81.45	1.51	1.51
A-3	1.30	-5	0.17	212	71.12	1.15	1.15
B-1	1.60	0	0.00	214	79.02	1.42	1.42
B-2	1.50	0	0.00	214	76.51	1.33	1.33
B-3	1.50	-5	0.14	212	76.39	1.33	1.33
C-1	1.60	0	0.00	214	79.02	1.42	1.42
C-2	1.60	-5	0.18	214	79.02	1.42	1.42
C-3	1.40	0	0.00	210	73.69	1.24	1.24
D-1	1.50	0	0.00	214	76.51	1.33	1.33
D-2	1.60	0	0.00	213	78.96	1.42	1.42
D-3	1.60	0	0.00	214	79.02	1.42	1.42
Average	1.55	3		213		1.37	1.37
	1.24	**= Square roots of Δp**					1.17
Standard deviation of null angles =				3.4			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	PM U-00003 Base-4	PM U-00003 Base-5	PM U-00003 Base-6	
Carbon Dioxide Content	4.9	4.9	4.8	4.8				%
Oxygen Content	13.0	12.7	12.8	12.8				%
Stack Moisture Content	8.0	8.8	8.6	7.3				%
Nitrogen plus CO Content	82.1	82.4	82.4	82.4				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H_2O)	Min.	1.15	Max.	1.51

Stack and Equipment Information	Prelim	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	PM U-00003 Base-4	PM U-00003 Base-5	PM U-00003 Base-6	
Barometric Pressure	29.94	29.94	30.11	29.95				in Hg
Stack Static Pressure	-0.92	-0.92	-0.92	-0.92				in H_2O
Absolute Stack Pressure	29.87	29.87	30.04	29.88				in Hg
Average Stack Temp	213	209	192	185				0.00
Average Stack Temp	673	669	652	645				°R
Average Meter Temp	85	80	82	70				0.00
Orifice Meter Coefficient	1.846	1.846	1.846	1.846				in H_2O
Pitot Coefficient	0.772	0.772	0.772	0.772				
Stack Dry Molecular Weight	29.30	29.29	29.28	29.28				lb/lb mole
Stack Wet Molecular Weight	28.40	28.29	28.30	28.46				lb/lb mole
Stack Viscosity	207.77	205.84	202.01	201.57				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.09							
Cunningham Correction Factor, for a 2.5 µm particle		1.08	1.07	1.07				
Prelim Cut Dia., Cyclone I, D_{50LL}, N_{re}<3162	10.21	2.27	2.26	2.27				µm
Middle Zone Dia., Cyclone I, D_{50T}, N_{re}<3162	10.60							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.), N_{re}<3162	0.51							dscfm
Reynolds Number, Cyc I & IV, N_{re}<3162	2656.73	2792.37	2837.93	2841.40				
Dia. of 50% Prob. (D_{50}) Cyc IV (N_{re}<3162)	2.40	2.27	2.27	2.28				µm
Sampling Rate, Cyc IV, N_{re}<3,162	0.51							dscfm
Reynolds Number, Cyc IV, N_{re}<3162	2656.69	2792.37	2837.93	2841.40				
Prelim Cut Dia., Cyclone I, $D_{50LL\geq3162}$	10.62							µm
Middle Zone Dia., Cyclone I, $D_{50T\geq3162}$	10.81							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.)≥3162	0.49							dscfm
Reynolds Number, Cyc I & IV, N_{re}≥3162	2585.93							
Dia. of 50% Prob. (D_{50}) CIV (N_{re}≥3162)	2.30							µm
Sampling Rate, Cyc IV, N_{re}≥3,162	4.93							dscfm
Reynolds Number ≥ 3162	25859.42							
Cyclone Flow Rate	0.51	0.53	0.51	0.50				ft³/min
Recalculated D_{50-1} for C_{IV}		2.27	2.26	2.27				
Recalculated Cunninham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		93.40	92.63	92.75				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.157	0.157	0.157				in

Orifice Head and Nozzle Selection Calculation											
Nozzle No.	2a	2b	3a	3b	4a	4b	5a	5b	6a	6b	7a
Nozzle diameter, D_n, in.	0.088	0.103	0.119	0.130	0.157	0.175	0.197	0.212	0.284	0.331	0.374
Nozzle velocity, v_n, ft/sec	200.06	146.03	109.41	91.67	62.85	50.59	39.92	34.47	19.21	14.14	11.08
R_{min}	0.79	0.78	0.77	0.76	0.73	0.69	0.64	0.59	0.50	0.50	0.50
v_{min}, ft/sec	157.56	113.89	84.10	69.57	45.58	35.06	25.50	20.26	9.60	7.07	5.54
R_{max}	1.21	1.21	1.22	1.23	1.25	1.27	1.30	1.32	1.46	1.50	1.50
v_{max}, ft/sec	241.87	177.34	133.69	112.63	78.54	64.14	51.71	45.40	28.02	21.21	16.61
Δp_{min}, in. H_2O @ $t_{s-50}o_F$	7.76	4.05	2.21	1.51	0.65	0.38	0.20	0.13	0.03	0.02	0.01
Δp_{min}, in. H_2O @ t_s	7.18	3.75	2.05	1.40	0.60	0.36	0.19	0.12	0.03	0.01	0.01
Δp_{max}, in. H_2O @ t_s	16.93	9.10	5.17	3.67	1.79	1.19	0.77	0.60	0.23	0.13	0.08
Δp_{min}, in. H_2O @ $t_{s+50}o_F$	15.76	8.47	4.81	3.42	1.66	1.11	0.72	0.56	0.21	0.12	0.07
ΔH, in. H_2O @ t_s+50°F	0.396										
ΔH, in. H_2O @ t_s	**0.457**										
ΔH, in. H_2O @ t_s-50°F	0.533										

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/15/20		
Sampling Location	U-00003 Base	**Operator**	Rob White		
Project #	bec-19-cricketvalley.ny-start#3	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	PM U-00003 Base-1		**Date**	04/15/20	**Run Start Time**	08:23	**Run Stop Time**	12:46
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:23	4.9	12.7	0.0	82.4	29.29	1.673	140.3	YES

Gas Analysis Data

Run Number	PM U-00003 Base-2		**Date**	04/15/20	**Run Start Time**	13:45	**Run Stop Time**	18:02
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:17	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

Gas Analysis Data

Run Number	PM U-00003 Base-3		**Date**	04/16/20	**Run Start Time**	06:46	**Run Stop Time**	11:15
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:29	4.8	12.8	0.0	82.4	29.28	1.688	143.0	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/15/20
Sampling Location	U-00003 Base	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	04/15/20	500	499.7	-0.3	Pass
Test Day 2	04/16/16	500	499.6	-0.4	Pass

Moisture Content Data									
Run Number		PM U-00003 Base-1		**Date**	04/15/20	**Start Time**	08:23	**Stop Time**	12:46
Meter Box Number		Samp-cp-0033				**Meter Cal Factor**	(Y)	0.978	
Total Meter Volume		(V_m)	96.840	dcf		**Barometric Pressure**	(P_b)	29.94	in Hg
Average Stack Temp		$(t_s)_{avg}$	209	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O
Average Meter Temp		$(t_m)_{avg}$	80	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	540.40	585.00	748.30	951.60				
Initial Value	(V_i),(W_i)	377.50	581.50	747.50	927.80				
Net Value	(V_n),(W_n)	162.9	3.5	0.8	23.8				
Results									
Total Weight		(W_t)	191.00	g		**Water Vol Weighed**	$(V_{wsg(std)})$	9.006	scf
Std Meter Volume		$(V_{m(std)})$	92.757	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	94.46	%
Calc Moisture Content		$(B_{ws(calc)})$	8.85	%		**Final Moisture Content**	(B_{ws})	8.85	%

Moisture Content Data									
Run Number		PM U-00003 Base-2		**Date**	04/15/20	**Start Time**	13:45	**Stop Time**	18:02
Meter Box Number		Samp-cp-0033				**Meter Cal Factor**	(Y)	0.978	
Total Meter Volume		(V_m)	95.730	dcf		**Barometric Pressure**	(P_b)	30.11	in Hg
Average Stack Temp		$(t_s)_{avg}$	192	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O
Average Meter Temp		$(t_m)_{avg}$	82	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.47	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	514.60	585.70	727.80	936.80				
Initial Value	(V_i),(W_i)	362.50	580.70	727.70	909.60				
Net Value	(V_n),(W_n)	152.1	5.0	0.1	27.2				
Results									
Total Weight		(W_t)	184.40	g		**Water Vol Weighed**	$(V_{wsg(std)})$	8.694	scf
Std Meter Volume		$(V_{m(std)})$	91.834	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	65.83	%
Calc Moisture Content		$(B_{ws(calc)})$	8.65	%		**Final Moisture Content**	(B_{ws})	8.65	%

Moisture Content Data									
Run Number		PM U-00003 Base-3		**Date**	04/16/20	**Start Time**	06:46	**Stop Time**	11:15
Meter Box Number		Samp-cp-0033				**Meter Cal Factor**	(Y)	0.978	
Total Meter Volume		(V_m)	93.900	dcf		**Barometric Pressure**	(P_b)	29.95	in Hg
Average Stack Temp		$(t_s)_{avg}$	185	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O
Average Meter Temp		$(t_m)_{avg}$	70	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.46	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	522.80	586.00	649.10	1060.00				
Initial Value	(V_i),(W_i)	378.90	586.00	748.40	952.30				
Net Value	(V_n),(W_n)	143.9	0.0	-99.3	107.7				
Results									
Total Weight		(W_t)	152.30	g		**Water Vol Weighed**	$(V_{wsg(std)})$	7.181	scf
Std Meter Volume		$(V_{m(std)})$	91.769	dscf		**Sat. Moisture Content**	$(B_{ws(svp)})$	56.49	%
Calc Moisture Content		$(B_{ws(calc)})$	7.26	%		**Final Moisture Content**	(B_{ws})	7.26	%

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Date	04/15/20
Operator	Rob White
Run Number	PM U-00003 Base-1

Filter #
19031839
PM U-00003 Base-1-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7720	5266/10
Average Stack Temp	(t_s)	209.1	°F
Average Meter Temp	(t_m)	80.1	
Orifice Meter Coefficient	($\Delta H@$)	1.846	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.19	in H_2O
Stack Moisture Content	(B_{ws})	8.85	%
Stack Dry Molecular Weight	(M_d)	29.29	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.39	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.00	in H_2O	3.6	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.00	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
	Post (+)	0.00	in H_2O	3.8	in H_2O for	15.0	sec [≥15]
	Post (-)	0.00	in H_2O	4.3	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0033		
Meter Cal Factor	(Y)	0.978	
Nozzle Number	4a		
Average Nozzle Diameter	(D_{ns})	0.1570	in
Suggested Nozzle Diameter	(D_n)	0.2111	in
Probe Number	SAMP-HP-0138		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	29.94	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	29.87	in Hg
Absolute Meter Pressure	(P_m)	30.08	in Hg

Nozzle Measurements				
Pre	0.156	0.157	0.158	**PASS**
Post	0.156	0.157	0.158	**PASS**

ID: 4a

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	08:23	**End**	12:46

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	377.5	581.5	747.5	927.8				
Post	540.4	585.0	748.3	951.6				

Wash Volumes				ml
				ml

Identification Nos.		Samp-cp-0033	Samp-cp-0033	Samp-cp-0033			SAMP-HP-0138	SAMP-HP-0138	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0033		Samp-cp-0033					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	258.170	1.50	0.457	0.46	212	248	240	45	55	70	68	68	5.0	1.22	72.08	8.073	92.5	94.284
A-2	21.0	00:21:00	266.410	1.40	0.457	0.46	214	248	245	44	57	71	73	73	5.0	1.18	69.74	15.644	92.9	93.009
A-3	41.3	00:41:15	274.210	1.40	0.457	0.46	216	250	251	47	58	73	78	78	5.0	1.18	69.84	24.125	97.0	96.204
B-1	61.5	01:01:30	283.030	1.50	0.457	0.46	213	254	256	51	60	74	80	80	5.0	1.22	72.13	32.296	96.2	96.008
B-2	82.5	01:22:30	291.560	1.50	0.457	0.46	214	243	234	53	60	74	81	81	5.0	1.22	72.18	40.261	95.2	95.402
B-3	103.5	01:43:30	299.890	1.30	0.457	0.46	212	245	244	55	60	75	82	82	5.0	1.14	67.10	47.238	94.8	94.189
C-1	123.0	02:03:00	307.200	1.40	0.457	0.46	213	248	246	56	61	73	82	82	5.0	1.18	69.68	55.017	95.0	94.192
C-2	143.3	02:23:15	315.350	1.50	0.457	0.46	210	248	245	56	62	75	83	83	5.0	1.22	71.97	63.020	94.5	94.098
C-3	164.3	02:44:15	323.750	1.40	0.457	0.46	204	250	254	58	63	76	84	84	6.0	1.18	69.22	71.084	95.0	94.490
D-1	184.5	03:04:30	332.230	1.40	0.457	0.46	200	247	251	58	65	72	84	84	6.0	1.18	69.01	78.368	94.4	93.869
D-2	204.8	03:24:45	339.890	1.50	0.457	0.46	200	245	252	60	66	74	83	83	6.0	1.22	71.43	86.113	93.9	93.552
D-3	225.8	03:45:45	348.020	1.30	0.457	0.46	201	248	237	61	67	75	83	83	6.0	1.14	66.55	92.773	93.4	92.773
Last Pt	245.3	04:05:15	355.010																	
Final Val	245.3	04:05:15	355.010											**Max Vac**	6.0	**Final Values**		92.773	93.4	
Average Values				1.43		0.46	209	248	246	54	61	74	80	80		1.19	70.08			
													80							

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.157	0.39	8.073	92.5	747.0
0.157	0.39	7.570	93.3	706.2
0.157	0.39	8.481	104.7	887.5
0.157	0.39	8.172	93.7	765.9
0.157	0.39	7.965	91.4	728.3
0.157	0.39	6.977	92.5	645.4
0.157	0.39	7.779	95.8	745.0
0.157	0.39	8.003	91.6	732.9
0.157	0.39	8.064	98.6	795.3
0.157	0.39	7.284	88.8	646.9
0.157	0.39	7.745	88.0	681.4
0.157	0.39	6.659	87.6	583.1
0.157	0.39	92.773		

RM 201A Calculations					
Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**	
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Prelim. Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
21.00	20.91	1.50		1.50	0
20.25	20.20	1.40	20.20	1.40	0
20.25	20.20	1.40	20.20	1.40	0
21.00	20.91	1.50		1.50	0
21.00	20.91	1.50	20.91	1.50	0
19.50	19.46	1.30	19.46	1.30	0
20.25	20.20	1.40		1.40	0
21.00	20.91	1.50	20.91	1.50	0
20.25	20.20	1.40	20.20	1.40	0
20.25	20.20	1.40		1.40	0
21.00	20.91	1.50	20.91	1.50	0
19.50	19.46	1.30	19.46	1.30	0

Notes:

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	205.84	μP
	Cyclone Flow Rate (Q_a)	0.53	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.25	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{re}<3162)	10.21	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.60	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.50	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.27	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}<3162)	0.53	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.08	
	Actual Test Run N_{RE}	2792.37	
	Actual Particle Cut Diameter for CI	10.25	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.27	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.27	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	93.40	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.157	in
	Δp_{min}	0.601	in H_2O
	Δp_{max}	1.785	in H_2O

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Date	04/15/20
Operator	Rob White
Run Number	PM U-00003 Base-2

Filter #
19031840
PM U-00003 Base-2-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7720	5266/10
Average Stack Temp	(t_s)	191.9	°F
Average Meter Temp	(t_m)	82.3	
Orifice Meter Coefficient	($\Delta H@$)	1.846	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.18	in H_2O
Stack Moisture Content	(B_{ws})	8.65	%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.38	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.41	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.000	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.000	in H_2O	4.0	in H_2O for	15.0	sec [≥15]
	Post (+)	0.000	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
	Post (-)	0.000	in H_2O	4.3	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0033		
Meter Cal Factor	(Y)	0.978	
Nozzle Number	4a		
Average Nozzle Diameter	(D_{ns})	0.1570	in
Suggested Nozzle Diameter	(D_n)	0.1492	in
Probe Number	SAMP-HP-0138		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.11	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	30.04	in Hg
Absolute Meter Pressure	(P_m)	30.25	in Hg

Nozzle Measurements			**ID: 4a**	
Pre	0.156	0.157	0.158	**PASS**
Post	0.156	0.157	0.158	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	13:45	**End**	18:02

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	362.5	580.7	727.7	909.6				
Post	514.6	585.7	727.8	936.8				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0033	Samp-cp-0033	Samp-cp-0033			SAMP-HP-0138	SAMP-HP-0138	SAMP-BH-0039	SAMP-SBC-0099	8082	1026	Samp-cp-0033		Samp-cp-0033					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	358.270	1.40	0.457	0.47	191	251	261	56	61	68	75	75	5.0	1.18	68.33	7.682	92.6	92.188
A-2	20.3	00:20:15	366.170	1.50	0.457	0.47	192	250	262	55	63	70	81	81	5.0	1.22	70.78	15.885	92.4	93.579
A-3	41.3	00:41:15	374.700	1.30	0.457	0.47	191	254	255	57	63	72	81	81	5.0	1.14	65.84	22.973	92.3	91.891
B-1	60.8	01:00:45	382.070	1.40	0.457	0.47	190	253	255	58	65	72	83	83	5.0	1.18	68.27	31.634	95.6	94.903
B-2	81.0	01:21:00	391.110	1.50	0.457	0.47	191	255	253	60	66	74	85	85	5.0	1.22	70.73	40.407	96.2	96.264
B-3	102.0	01:42:00	400.300	1.50	0.457	0.47	190	256	255	61	67	75	84	84	5.0	1.22	70.67	48.536	95.4	95.888
C-1	123.0	02:03:00	408.800	1.40	0.457	0.47	196	242	243	62	66	73	83	83	5.0	1.18	68.59	56.718	95.9	96.213
C-2	143.3	02:23:15	417.340	1.30	0.457	0.47	194	244	248	63	64	74	84	84	5.0	1.14	65.99	63.413	95.0	94.681
C-3	162.8	02:42:45	424.340	1.50	0.457	0.47	193	245	250	64	65	75	82	82	5.0	1.22	70.83	71.610	94.6	94.701
D-1	183.8	03:03:45	432.880	1.40	0.457	0.47	194	249	251	65	66	76	83	83	5.0	1.18	68.48	79.074	94.2	94.191
D-2	204.0	03:24:00	440.670	1.30	0.457	0.47	190	243	244	67	70	77	84	84	5.0	1.14	65.79	85.453	93.4	92.909
D-3	223.5	03:43:30	447.340	1.30	0.457	0.47	191	245	256	64	65	73	83	83	5.0	1.14	65.84	91.834	92.6	91.834
Last Pt	243.0	04:03:00	454.000																	
Final Val	243.0	04:03:00	454.000											**Max Vac**	5.0	**Final Values**		91.834	92.6	
Average Values				1.40		0.47	192	249	253	61	65	73	82	82		1.18	68.35			
													82							

Actual	**DP to**	**Point-by-point**	**Point-by-point**	**Point**
Actual Nozzle Diameter (D_{na})	**DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.157	0.41	7.682	92.6	711.2
0.157	0.41	8.203	92.2	756.0
0.157	0.41	7.087	92.0	652.4
0.157	0.41	8.661	104.3	903.4
0.157	0.41	8.773	98.5	864.0
0.157	0.41	8.129	91.2	741.3
0.157	0.41	8.182	99.0	809.9
0.157	0.41	6.695	87.1	583.4
0.157	0.41	8.197	92.2	755.6
0.157	0.41	7.464	90.2	672.9
0.157	0.41	6.379	82.8	528.0
0.157	0.41	6.381	82.9	528.8
0.157	0.41	91.834		

RM 201A Calculations					
Trav. Point	**First Point**	**First Point**	**Subs. Point**	**Velocity**	
Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
20.25	20.20	1.40		1.40	0
21.00	20.91	1.50	20.91	1.50	0
19.50	19.46	1.30	19.46	1.30	0
20.25	20.20	1.40		1.40	0
21.00	20.91	1.50	20.91	1.50	0
21.00	20.91	1.50	20.91	1.50	0
20.25	20.20	1.40		1.40	0
19.50	19.46	1.30	19.46	1.30	0
21.00	20.91	1.50	20.91	1.50	0
20.25	20.20	1.40		1.40	0
19.50	19.46	1.30	19.46	1.30	0
19.50	19.46	1.30	19.46	1.30	0

Stack Gas Viscosity (μs)	202.01	μP
Cyclone Flow Rate (Q_s)	0.51	ft³/min
Dia. of 50% Prob. (D_{50}) CI	10.29	μm
>> Calculated Cunninham, C	1.08	
Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.26	μm
Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
Middle of Zone Dia. (D_{50T}) CI	10.63	μm
Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.49	dscfm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.26	μm
Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.51	dscfm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
Actual Test Run C (2.5 μm)	1.07	
Actual Test Run N_{RE}	2837.93	
Actual Particle Cut Diameter for CI	10.29	μm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.27	μm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<< Recalculated Cunninham, C =	1.08	
Recalculated D_{50-1} for C_{IV} =	2.26	
>> Z (limits 0.99 to 1.01) =	1.00	
Isokinetics (I) (80 to 120%) =	92.63	%
No. Sampling Pts. Outside Δp =	0	
Sample Nozzle Diameter =	0.157	in
Δp_{min}	0.601	in H_2O
Δp_{max}	1.785	in H_2O

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Date	04/16/20
Operator	Rob White
Run Number	PM U-00003 Base-3

Filter #
19031831
PM U-00003 Base-3-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7720	5266/10
Average Stack Temp	(t_s)	184.6	°F
Average Meter Temp	(t_m)	69.5	
Orifice Meter Coefficient	($\Delta H@$)	1.846	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.17	in H_2O
Stack Moisture Content	(B_{ws})	7.26	%
Stack Dry Molecular Weight	(M_d)	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.38	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.41	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec ≥60]
Pitot	**Pre (+)**	0.00	in H_2O	3.7	in H_2O for	15.0	sec ≥15]
PASS	**Pre (-)**	0.00	in H_2O	4.0	in H_2O for	15.0	sec ≥15]
	Post (+)	0.00	in H_2O	3.6	in H_2O for	15.0	sec ≥15]
	Post (-)	0.00	in H_2O	4.2	in H_2O for	15.0	sec ≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0033		
Meter Cal Factor	(Y)	0.978	
Nozzle Number	4a		
Average Nozzle Diameter	(D_{ns})	0.1570	in
Suggested Nozzle Diameter	(D_n)	0.1509	in
Probe Number	SAMP-HP-0138		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	29.95	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	29.88	in Hg
Absolute Meter Pressure	(P_m)	30.09	in Hg

Nozzle Measurements			**ID: 4a**	
Pre	0.156	0.157	0.158	**PASS**
Post	0.156	0.157	0.158	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	06:46	**End**	11:15

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	378.9	586.0	748.4	952.3				
Post	522.8	586.0	649.1	1060.0				

Wash Volumes				ml
				ml

Identification Nos.		Samp-cp-0033	Samp-cp-0033	Samp-cp-0033			SAMP-HP-0138	SAMP-HP-0138	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0033		Samp-cp-0033					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	461.100	1.30	0.457	0.46	184	252	246	40	55	68	54	54	5.0	1.14	65.48	7.843	100.3	96.828
A-2	19.5	00:19:30	468.890	1.40	0.457	0.46	185	255	256	44	56	68	60	60	5.0	1.18	68.01	16.013	98.7	96.985
A-3	39.8	00:39:45	477.100	1.30	0.457	0.46	187	254	257	55	57	69	63	63	5.0	1.14	65.63	23.859	99.3	96.948
B-1	59.3	00:59:15	485.030	1.50	0.457	0.46	184	255	254	56	57	70	64	64	5.0	1.22	70.34	32.728	99.0	98.183
B-2	80.3	01:20:15	494.010	1.50	0.457	0.46	183	256	252	57	58	71	65	65	5.0	1.22	70.28	40.929	97.3	97.319
B-3	101.3	01:41:15	502.330	1.30	0.457	0.46	182	262	265	58	60	71	66	66	5.0	1.14	65.38	47.983	96.2	95.667
C-1	120.8	02:00:45	509.500	1.30	0.457	0.46	186	247	257	55	59	68	68	68	5.0	1.14	65.58	54.794	95.1	94.059
C-2	140.3	02:20:15	516.450	1.40	0.457	0.46	187	254	255	57	62	70	74	74	5.0	1.18	68.11	62.314	94.4	93.471
C-3	160.5	02:40:30	524.210	1.30	0.457	0.46	188	253	256	58	63	72	77	77	5.0	1.14	65.68	69.050	93.7	92.355
D-1	180.0	03:00:00	531.200	1.50	0.457	0.46	184	245	257	61	65	75	80	80	6.0	1.22	70.34	77.119	93.2	92.370
D-2	201.0	03:21:00	539.620	1.40	0.457	0.46	182	250	246	62	66	77	81	81	6.0	1.18	67.85	84.714	92.9	92.180
D-3	221.3	03:41:15	547.560	1.30	0.457	0.46	183	253	247	63	67	77	82	82	6.0	1.14	65.43	91.818	92.7	91.818
Last Pt	240.8	04:00:45	555.000																	
Final Val	240.8	04:00:45	555.000											**Max Vac**	6.0	**Final Values**		91.818	92.7	
Average Values				1.38		0.46	185	253	254	56	60	71	70	70		1.17	67.34			
													70							

Actual Actual Nozzle Diameter (D_{na})	**DP to DP to DH Iso Factor (K)**	**Point-by-point Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.157	0.41	7.843	100.3	786.8
0.157	0.41	8.170	97.1	793.0
0.157	0.41	7.846	100.6	789.4
0.157	0.41	8.868	98.1	869.7
0.157	0.41	8.201	90.6	743.2
0.157	0.41	7.054	90.1	635.5
0.157	0.41	6.812	87.3	594.5
0.157	0.41	7.520	89.5	672.8
0.157	0.41	6.736	86.4	582.2
0.157	0.41	8.069	89.2	720.0
0.157	0.41	7.595	90.0	683.7
0.157	0.41	7.103	90.8	645.0
0.157	0.41	91.818		

RM 201A Calculations					
Trav. Point Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point First Point Dwell Times (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
19.50	19.46	1.30		1.30	0
20.25	20.20	1.40	20.20	1.40	0
19.50	19.46	1.30	19.46	1.30	0
21.00	20.91	1.50		1.50	0
21.00	20.91	1.50	20.91	1.50	0
19.50	19.46	1.30	19.46	1.30	0
19.50	19.46	1.30		1.30	0
20.25	20.20	1.40	20.20	1.40	0
19.50	19.46	1.30	19.46	1.30	0
21.00	20.91	1.50		1.50	0
20.25	20.20	1.40	20.20	1.40	0
19.50	19.46	1.30	19.46	1.30	0

Stack Gas Viscosity (μs)	201.57	μP
Cyclone Flow Rate (Q_s)	0.50	ft³/min
Dia. of 50% Prob. (D_{50}) CI	10.34	μm
>> Calculated Cunninham, C	1.08	
Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.28	μm
Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
Middle of Zone Dia. (D_{50T}) CI	10.64	μm
Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.48	dscfm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.27	μm
Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.50	dscfm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
Actual Test Run C (2.5 μm)	1.07	
Actual Test Run N_{RE}	2841.40	
Actual Particle Cut Diameter for CI	10.34	μm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.28	μm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<< Recalculated Cunninham, C =	1.08	
Recalculated D_{50-1} for C_{IV} =	2.27	
>> Z (limits 0.99 to 1.01) =	1.00	
Isokinetics (I) (80 to 120%) =	92.75	%
No. Sampling Pts. Outside Δp =	0	
Sample Nozzle Diameter =	0.157	in
Δp_{min}	0.601	in H_2O
Δp_{max}	1.785	in H_2O

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#3	
Operator		GT	
Date for Preliminary Run	(mm/dd/yy)	04/15/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	10 L/min	10.6	scf
Run Duration	8a, 2.4.1.3	120	minutes
Unit Number		U-00003	
Base Run Number		SAM U-00003 Base	
Number of Ports Available		4	
Number of Ports Used		1	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	04/15/20	04/16/20	04/16/20	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8638.02	8641.42	8641.42	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0030	samp-cp-0030	samp-cp-0030	
Meter Calibration Factor	(Y)	0.974	0.974	0.974	
Orifice Meter Coefficient	($\Delta H_@$)	1.878	1.878	1.878	in H_2O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-HP-0138	SAMP-HP-0138	SAMP-HP-0138	
Probe Length		72.0	72.0	72.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-bh-0013	samp-bh-0013	samp-bh-0013	
Impinger Case Number	from ACS	samp-bc-0032	samp-bc-0032	samp-bc-0032	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	04/15/20
Sampling Location	U-00003 Base	**Stack Type**	Circular
Operator	GT	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	1
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

◉ Method 1 Trav

○ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
1	**Ports by**	1	**Across**
1	**Pts Used**	1	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
Number	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.275	62 6/8	70 6/8
2			
3			
4			
5			
6			
7			
8			
9			

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/15/20		
Sampling Location	U-00003 Base	**Operator**	GT		
Project #	bec-19-cricketvalley.ny-start#3	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	SAM U-00003 Base-1		**Date**	04/15/20	**Run Start Time**	13:56	**Run Stop Time**	15:56
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.5	12.9	0.0	82.6	29.24	1.778	144.8	YES

Gas Analysis Data

Run Number	SAM U-00003 Base-2		**Date**	04/16/20	**Run Start Time**	06:24	**Run Stop Time**	08:24
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.5	12.9	0.0	82.6	29.24	1.778	144.8	YES

Gas Analysis Data

Run Number	SAM U-00003 Base-3		**Date**	04/16/20	**Run Start Time**	08:57	**Run Stop Time**	10:57
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.5	12.9	0.0	82.6	29.24	1.778	144.8	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/15/20
Sampling Location	U-00003 Base	**Operator**	GT
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	1

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 2	04/16/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		SAM U-00003 Base-1		**Date**	04/15/20	**Start Time**	13:56	**Stop Time**	15:56
Meter Box Number		samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	42.410	dcf		**Barometric Pressure**	(P_b)	29.91	in Hg
Average Stack Temp		$(t_s)_{avg}$	191	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O
Average Meter Temp		$(t_m)_{avg}$	69	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.41	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	761.80	681.30	575.00	946.20				
Initial Value	(V_i),(W_i)	703.90	675.10	574.50	932.80				
Net Value	(V_n),(W_n)	57.9	6.2	0.5	13.4				
Results									
Total Weight		(W_t)	78.00	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.678	scf
Std Meter Volume		($V_{m(std)}$)	41.293	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)	64.98	%
Calc Moisture Content		($B_{ws(calc)}$)	8.18	%		**Final Moisture Content**	(B_{ws})	8.18	%

Moisture Content Data									
Run Number		SAM U-00003 Base-2		**Date**	04/16/20	**Start Time**	06:24	**Stop Time**	08:24
Meter Box Number		samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	42.040	dcf		**Barometric Pressure**	(P_b)	30.04	in Hg
Average Stack Temp		$(t_s)_{avg}$	182	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O
Average Meter Temp		$(t_m)_{avg}$	67	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.41	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	825.20	688.90	575.70	955.10				
Initial Value	(V_i),(W_i)	761.80	681.30	575.00	946.20				
Net Value	(V_n),(W_n)	63.4	7.6	0.7	8.9				
Results									
Total Weight		(W_t)	80.60	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.800	scf
Std Meter Volume		($V_{m(std)}$)	41.266	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)	53.21	%
Calc Moisture Content		($B_{ws(calc)}$)	8.43	%		**Final Moisture Content**	(B_{ws})	8.43	%

Moisture Content Data									
Run Number		SAM U-00003 Base-3		**Date**	04/16/20	**Start Time**	08:57	**Stop Time**	10:57
Meter Box Number		samp-cp-0030				**Meter Cal Factor**	(Y)	0.974	
Total Meter Volume		(V_m)	41.640	dcf		**Barometric Pressure**	(P_b)	30.06	in Hg
Average Stack Temp		$(t_s)_{avg}$	182	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O
Average Meter Temp		$(t_m)_{avg}$	58	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.41	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		H_2O_2	H_2O_2	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	884.50	696.20	576.30	966.20				
Initial Value	(V_i),(W_i)	825.20	688.90	575.70	955.10				
Net Value	(V_n),(W_n)	59.3	7.3	0.6	11.1				
Results									
Total Weight		(W_t)	78.30	g		**Water Vol Weighed**	($V_{wsg(std)}$)	3.692	scf
Std Meter Volume		($V_{m(std)}$)	41.545	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)	53.18	%
Calc Moisture Content		($B_{ws(calc)}$)	8.16	%		**Final Moisture Content**	(B_{ws})	8.16	%

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Date	04/15/20
Operator	GT
Run Number	SAM U-00003 Base-1

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)	191.0	°F
Average Meter Temp	(t_m)	68.5	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})	8.18	%
Stack Dry Molecular Weight	(M_d)	29.24	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-HP-0138		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0013		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	29.91	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	29.84	in Hg
Absolute Meter Pressure	(P_m)	30.05	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	13:56	**End**	15:56

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	703.9	675.1	574.5	932.8				
Post	761.8	681.3	575.0	946.2				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0030	samp-cp-0030	samp-cp-0030			SAMP-HP-0138	SAMP-HP-0138	samp-bh-0013	samp-bc-0032	TCSAM1		samp-cp-0030		samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	829.310	--	0.411	0.41	--	350	510	57	176	--	59	59	2.0			1.725		41.407
A-2	5.0	00:05:00	831.050	--	0.411	0.41	--	350	515	55	185	--	60	60	2.0			3.447		41.368
A-3	10.0	00:10:00	832.790	--	0.411	0.41	--	350	513	56	185	--	61	61	2.0			5.196		41.565
A-4	15.0	00:15:00	834.560	--	0.411	0.41	--	350	516	60	185	--	62	62	2.0			6.911		41.466
A-5	20.0	00:20:00	836.300	--	0.411	0.41	--	350	521	61	183	--	62	62	2.0			8.617		41.359
A-6	25.0	00:25:00	838.030	--	0.411	0.41	--	350	524	63	184	--	63	63	2.0			10.358		41.433
A-7	30.0	00:30:00	839.800	--	0.411	0.41	--	350	527	65	182	--	64	64	2.0			12.077		41.406
A-8	35.0	00:35:00	841.550	--	0.411	0.41	--	350	528	60	158	--	65	65	2.0			13.812		41.436
A-9	40.0	00:40:00	843.320	--	0.411	0.41	--	350	517	55	158	--	65	65	2.0			15.547		41.458
A-10	45.0	00:45:00	845.090	--	0.411	0.41	--	350	520	54	123	--	66	66	2.0			17.288		41.492
A-11	50.0	00:50:00	846.870	--	0.411	0.41	--	350	522	60	114	--	66	66	2.0			19.010		41.477
A-12	55.0	00:55:00	848.630	--	0.411	0.41	--	350	519	62	109	--	67	67	2.0			20.729		41.458
A-13	60.0	01:00:00	850.390	--	0.411	0.41	--	350	516	58	105	--	67	67	2.0			22.448		41.442
A-14	65.0	01:05:00	852.150	--	0.411	0.41	--	350	515	58	105	--	67	67	2.0			24.166		41.428
A-15	70.0	01:10:00	853.910	--	0.411	0.41	--	350	523	56	103	--	68	68	2.0			25.911		41.457
A-16	75.0	01:15:00	855.700	--	0.411	0.41	--	350	521	53	102	--	70	70	2.0			27.620		41.430
A-17	80.0	01:20:00	857.460	--	0.411	0.41	--	350	525	53	103	--	72	72	2.0			29.322		41.396
A-18	85.0	01:25:00	859.220	--	0.411	0.41	--	350	519	53	104	--	73	73	2.0			31.099		41.465
A-19	90.0	01:30:00	861.060	--	0.411	0.41	--	350	524	52	101	--	75	75	2.0			32.782		41.409
A-20	95.0	01:35:00	862.810	--	0.411	0.41	--	350	517	51	101	--	76	76	2.0			34.491		41.389
A-21	100.0	01:40:00	864.590	--	0.411	0.41	--	350	523	54	106	--	78	78	2.0			36.175		41.342
A-22	105.0	01:45:00	866.350	--	0.411	0.41	--	350	513	55	109	--	79	79	2.0			37.874		41.317
A-23	110.0	01:50:00	868.130	--	0.411	0.41	--	350	524	54	106	--	80	80	2.0			39.580		41.301
A-24	115.0	01:55:00	869.920	--	0.411	0.41	--	350	521	53	103	--	80	80	2.0			41.295		41.295
Last Pt	120.0	02:00:00	871.720																	
Final Val	120.0	02:00:00	871.720											**Max Vac**	2.0	**Final Values**		41.295		
Average Values						0.41	191	350	520	57	133		69	69						
													69							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Date	04/16/20
Operator	GT
Run Number	SAM U-00003 Base-2

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)	182.0	°F
Average Meter Temp	(t_m)	66.5	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})	8.43	%
Stack Dry Molecular Weight	(M_d)	29.24	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.34	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-HP-0138		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0013		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.04	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	29.97	in Hg
Absolute Meter Pressure	(P_m)	30.18	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	06:24	**End**	08:24

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	761.8	681.3	575.0	946.2				
Post	825.2	688.9	575.7	955.1				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0030	samp-cp-0030	samp-cp-0030			SAMP-HP-0138	SAMP-HP-0138	samp-bh-0013	samp-bc-0032	TCSAM1		samp-cp-0030		samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	871.950	--	0.411	0.41	--	350	500	39	64	--	75	75	2.0			1.729		41.503
A-2	5.0	00:05:00	873.740	--	0.411	0.41	--	350	502	41	65	--	74	74	2.0			3.413		40.961
A-3	10.0	00:10:00	875.480	--	0.411	0.41	--	350	507	43	84	--	72	72	2.0			5.143		41.142
A-4	15.0	00:15:00	877.260	--	0.411	0.41	--	350	509	44	96	--	71	71	2.0			6.856		41.135
A-5	20.0	00:20:00	879.020	--	0.411	0.41	--	350	533	45	104	--	71	71	2.0			8.559		41.084
A-6	25.0	00:25:00	880.770	--	0.411	0.41	--	350	516	46	107	--	70	70	2.0			10.285		41.141
A-7	30.0	00:30:00	882.540	--	0.411	0.41	--	350	525	46	109	--	69	69	2.0			12.015		41.193
A-8	35.0	00:35:00	884.310	--	0.411	0.41	--	350	528	47	110	--	69	69	2.0			13.744		41.232
A-9	40.0	00:40:00	886.080	--	0.411	0.41	--	350	526	47	110	--	68	68	2.0			15.447		41.193
A-10	45.0	00:45:00	887.820	--	0.411	0.41	--	350	529	49	112	--	67	67	2.0			17.164		41.193
A-11	50.0	00:50:00	889.570	--	0.411	0.41	--	350	523	50	111	--	67	67	2.0			18.880		41.192
A-12	55.0	00:55:00	891.320	--	0.411	0.41	--	350	524	51	112	--	66	66	2.0			20.590		41.179
A-13	60.0	01:00:00	893.060	--	0.411	0.41	--	350	522	51	112	--	65	65	2.0			22.303		41.174
A-14	65.0	01:05:00	894.800	--	0.411	0.41	--	350	523	51	113	--	65	65	2.0			24.016		41.170
A-15	70.0	01:10:00	896.540	--	0.411	0.41	--	350	515	52	112	--	65	65	2.0			25.748		41.197
A-16	75.0	01:15:00	898.300	--	0.411	0.41	--	350	521	51	112	--	64	64	2.0			27.484		41.226
A-17	80.0	01:20:00	900.060	--	0.411	0.41	--	350	523	51	110	--	63	63	2.0			29.224		41.257
A-18	85.0	01:25:00	901.820	--	0.411	0.41	--	350	505	50	110	--	63	63	2.0			30.943		41.258
A-19	90.0	01:30:00	903.560	--	0.411	0.41	--	350	525	51	110	--	63	63	2.0			32.643		41.233
A-20	95.0	01:35:00	905.280	--	0.411	0.41	--	350	530	53	111	--	63	63	2.0			34.363		41.235
A-21	100.0	01:40:00	907.020	--	0.411	0.41	--	350	528	53	112	--	62	62	2.0			36.075		41.229
A-22	105.0	01:45:00	908.750	--	0.411	0.41	--	350	517	54	113	--	62	62	2.0			37.788		41.224
A-23	110.0	01:50:00	910.480	--	0.411	0.41	--	350	508	54	113	--	62	62	2.0			39.511		41.229
A-24	115.0	01:55:00	912.220	--	0.411	0.41	--	350	528	56	113	--	61	61	2.0			41.267		41.267
Last Pt	120.0	02:00:00	913.990																	
Final Val	120.0	02:00:00	913.990											**Max Vac**	2.0	**Final Values**		41.267		
Average Values						0.41	182	350	519	49	105		67	67						
													67							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Date	04/16/20
Operator	GT
Run Number	SAM U-00003 Base-3

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)	182.0	°F
Average Meter Temp	(t_m)	58.4	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})	8.16	%
Stack Dry Molecular Weight	(M_d)	29.24	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.34	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-HP-0138		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0013		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.06	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	29.99	in Hg
Absolute Meter Pressure	(P_m)	30.20	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	08:57	**End**	10:57

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	825.2	688.9	575.7	955.1				
Post	884.5	696.2	576.3	966.2				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0030	samp-cp-0030	samp-cp-0030			SAMP-HP-0138	SAMP-HP-0138	samp-bh-0013	samp-bc-0032	TCSAM1		samp-cp-0030		samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	914.590	--	0.411	0.41	--	350	500	52	62	--	57	57	1.0			1.731		41.536
A-2	5.0	00:05:00	916.320	--	0.411	0.41	--	350	502	51	59	--	57	57	1.0			3.491		41.896
A-3	10.0	00:10:00	918.080	--	0.411	0.41	--	350	505	51	62	--	57	57	1.0			5.232		41.856
A-4	15.0	00:15:00	919.820	--	0.411	0.41	--	350	510	54	68	--	57	57	1.0			6.963		41.776
A-5	20.0	00:20:00	921.550	--	0.411	0.41	--	350	516	55	69	--	57	57	1.0			8.683		41.680
A-6	25.0	00:25:00	923.270	--	0.411	0.41	--	350	521	57	72	--	57	57	1.0			10.424		41.696
A-7	30.0	00:30:00	925.010	--	0.411	0.41	--	350	524	60	77	--	57	57	1.0			12.115		41.536
A-8	35.0	00:35:00	926.700	--	0.411	0.41	--	350	525	59	79	--	58	58	1.0			13.842		41.526
A-9	40.0	00:40:00	928.430	--	0.411	0.41	--	350	508	58	80	--	58	58	1.0			15.569		41.518
A-10	45.0	00:45:00	930.160	--	0.411	0.41	--	350	505	56	81	--	58	58	1.0			17.317		41.560
A-11	50.0	00:50:00	931.910	--	0.411	0.41	--	350	513	54	79	--	58	58	1.0			19.064		41.594
A-12	55.0	00:55:00	933.660	--	0.411	0.41	--	350	517	55	77	--	58	58	1.0			20.791		41.582
A-13	60.0	01:00:00	935.390	--	0.411	0.41	--	350	520	57	77	--	59	59	1.0			22.535		41.603
A-14	65.0	01:05:00	937.140	--	0.411	0.41	--	350	524	55	76	--	59	59	1.0			24.279		41.621
A-15	70.0	01:10:00	938.890	--	0.411	0.41	--	350	521	55	76	--	58	58	1.0			26.006		41.610
A-16	75.0	01:15:00	940.620	--	0.411	0.41	--	350	502	56	78	--	59	59	1.0			27.710		41.566
A-17	80.0	01:20:00	942.330	--	0.411	0.41	--	350	505	58	81	--	59	59	1.0			29.444		41.568
A-18	85.0	01:25:00	944.070	--	0.411	0.41	--	350	517	55	79	--	59	59	1.0			31.158		41.544
A-19	90.0	01:30:00	945.790	--	0.411	0.41	--	350	521	57	81	--	60	60	1.0			32.879		41.531
A-20	95.0	01:35:00	947.520	--	0.411	0.41	--	350	519	59	80	--	59	59	1.0			34.623		41.547
A-21	100.0	01:40:00	949.270	--	0.411	0.41	--	350	525	59	80	--	60	60	1.0			36.354		41.547
A-22	105.0	01:45:00	951.010	--	0.411	0.41	--	350	531	63	79	--	60	60	1.0			38.074		41.535
A-23	110.0	01:50:00	952.740	--	0.411	0.41	--	350	528	60	77	--	60	60	1.0			39.805		41.535
A-24	115.0	01:55:00	954.480	--	0.411	0.41	--	350	524	59	77	--	60	60	1.0			41.545		41.545
Last Pt	120.0	02:00:00	956.230																	
Final Val	120.0	02:00:00	956.230											**Max Vac**	1.0	**Final Values**		41.545		
Average Values						0.41	182	350	516	56	75		58	58						
													58							

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base Load
Opacity

Method Used (Circle One)
Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 6

Continued on Form Number (AHI Project Code)

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Observation Date | Time Zone | Start Time: 6:00 am | End Time: 8:00 am

Process | Unit # 3 | Operating Mode
Control Equipment | Operating Mode

Describe Emissions Pont


Height of Emiss. Pt. Start 145 End 146 | Height of Emiss. Pt. Rel. to Observer Start 148 End 148
Distance to Emiss. Pt. Start 4 End 4 | Direction to Emiss. Pt. (Degrees) Start NW End NW

Vetical Angle to Obs. Pt. Start 12 End 12 | Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 138 End 138

Describe Emissions
Start NA End NA
Emission Color Start NA End NA | Water Droplet Plume Start NA End NA

Describe Plume Background
Start End
Background Color Start Sky Blue End Sky Blue | Sky Conditions Start Clear End Clear
Wind Speed Start 8 End 8 | Wind Direction Start N End N
Ambient Temp. Start End | Wet Bulb Temp. | RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): Sean Fields
Observer's Signature: [signature] Date: 11/15/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 3 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Pont:
Height of Emiss. Pt. Start 137 End 137
Height of Emiss. Pt. Rel. to Observer Start 144 End 144
Distance to Emiss. Pt. Start 8 End 8
Direction to Emiss. Pt. (Degrees) Start NW End NW

Vertical Angle to Obs. Pt. Start 9 End 9
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 142 End 142

Describe Emissions
Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background
Start End
Background Color Start Blue End Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start NW End NW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

Form Number (AHI Project Code) | Page 2 of 4
Continued on Form Number (AHI Project Code)

Observation Date | Time Zone | Start Time 6:30 | End Time 7:00

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 4/15/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 3 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Pont:
Height of Emiss. Pt. Start 141 End 141
Height of Emiss. Pt. Rel. to Observer Start 149 End 149
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start ~ End ~

Vetical Angle to Obs. Pt. Start 11 End 11
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 147 End 142

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Blue End Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start NW End NW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

Form Number (AHI Project Code) Page 3 of 6
Continued on Form Number (AHI Project Code)

Observation Date | Time Zone | Start Time 7:00 am | End Time 7:30 am

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 1/1/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

VISUAL EMISSIONS OBSERVATION FORM

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: AirHygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 3 Operating Mode:
Control Equipment: Operating Mode:


Describe Emissions Pont:
Height of Emiss. Pt. Start 144 End 144
Height of Emiss. Pt. Rel. to Observer Start 157 End 157
Distance to Emiss. Pt. Start 5 End 5
Direction to Emiss. Pt. (Degrees) Start N End N

Vertical Angle to Obs. Pt. Start 11 End 11
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 143 End 143

Describe Emissions
Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background
Start End
Background Color Start Blue End Blue
Sky Conditions Start Clear End clear
Wind Speed Start 10 End 10
Wind Direction Start NW End NW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

Form Number (AHI Project Code) Page 4 of 6
Continued on Form Number (AHI Project Code)

Observation Date | Time Zone | Start Time 7:30 am | End Time 8:00 am

Min. / Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 4/15/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process Unit # 3 Operating Mode
Control Equipment Operating Mode

Describe Emissions Pont


Height of Emiss. Pt. Start 138 End 138
Height of Emiss. Pt. Rel. to Observer Start 146 End 146
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start End

Vetical Angle to Obs. Pt. Start 10 End 10
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 144 End 144

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Blue End Blue
Sky Conditions Start Clear End Clear
Wind Speed Start 9 End 9
Wind Direction Start NW End NW
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude Longitude Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 5 of 6
Continued on Form Number (AHI Project Code)

Observation Date Time Zone Start Time 8:00 am End Time 8:30 am

Min / Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print) SEAN FIELDS
Observer's Signature Date 4/15/20
Organization Air Hygiene International, Inc.
Certified By Comp Assurance Assoc Date 01/03/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 6 of 6

Continued on Form Number (AHI Project Code)

Company Name: Air Hygiene
Facility Name: Crickot Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Observation Date | Time Zone | Start Time: 8:30 | End Time: 9:00

Process | Unit #: 3 | Operating Mode
Control Equipment | Operating Mode

Describe Emissions Pont


Height of Emiss. Pt. Start 147 End 147 | Height of Emiss. Pt. Rel. to Observer Start 153' End 153'
Distance to Emiss. Pt. Start 8' End 8' | Direction to Emiss. Pt. (Degrees) Start NW End NW

Vetical Angle to Obs. Pt. Start 12 End 12 | Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 149' End 149'

Describe Emissions Start NA End NA
Emission Color Start NA End NA | Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Blue End Blue | Sky Conditions Start Clear End Clear
Wind Speed Start 11 End 11 | Wind Direction Start NW End NW
Ambient Temp. Start End | Wet Bulb Temp. | RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Sec. / Min.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 11/15/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

Additional Information

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
NOx, CO, VOC, and NH_3

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,641	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,010	Btu/SCF fuel
Turbine Fuel Flow	1,681	lb/min
Duct Burner Fuel Flow	174	lb/min
Total Fuel Flow	2,578,392	SCFH

Weather Data

Barometric Pressure	29.99	in. Hg
Relative Humidity	54	%
Ambient Temperature	43	°F
Specific Humidity	0.003133	lb H_2O / lb air

Unit Data

Unit Load	240.3	megawatts
Heat Input	2,603	MMBtu/hr
NH_3 Flow Rate	164	lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M19)	52,449,328	SCFH

Data from: From PM Run PM U-00003 Base+DB-1

Base+Db Load, Run - 2-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/16/20 14:04:12	32190	11.78	2.46	0.15	0.00	5.16	1.37
04/16/20 14:04:42	32220	11.78	2.45	0.16	0.00	5.17	1.35
04/16/20 14:05:12	32250	11.79	2.40	0.15	0.00	5.17	1.39
04/16/20 14:05:42	32280	11.80	2.37	0.14	0.00	5.17	1.39
04/16/20 14:06:12	32310	11.79	2.35	0.13	0.00	5.17	1.45
04/16/20 14:06:42	32340	11.80	2.42	0.16	0.01	5.17	1.48
04/16/20 14:07:12	32370	11.80	2.35	0.11	0.00	5.17	1.46
04/16/20 14:07:42	32400	11.80	2.43	0.15	0.01	5.17	1.47
04/16/20 14:08:12	32430	11.80	2.45	0.13	0.00	5.17	1.51
04/16/20 14:08:42	32460	11.80	2.45	0.14	0.00	5.17	1.51
04/16/20 14:09:12	32490	11.79	2.49	0.12	0.00	5.17	1.53
04/16/20 14:09:42	32520	11.79	2.50	0.14	0.01	5.17	1.56
04/16/20 14:10:12	32550	11.79	2.48	0.13	0.00	5.17	1.56
04/16/20 14:10:42	32580	11.79	2.50	0.13	0.00	5.18	1.57
04/16/20 14:11:12	32610	11.79	2.51	0.13	0.00	5.18	1.58
04/16/20 14:11:42	32640	11.80	2.46	0.14	0.00	5.18	1.61
04/16/20 14:12:12	32670	11.81	2.36	0.13	0.00	5.17	1.58
04/16/20 14:12:42	32700	11.81	2.40	0.14	0.00	5.18	1.57
04/16/20 14:13:12	32730	11.80	2.44	0.14	0.00	5.20	1.59
04/16/20 14:13:42	32760	11.81	2.43	0.12	0.00	5.17	1.58
04/16/20 14:14:12	32790	11.81	2.42	0.15	0.00	5.17	1.57
04/16/20 14:14:42	32820	11.81	2.39	0.12	0.00	5.18	1.56
04/16/20 14:15:12	32850	11.79	2.38	0.11	0.00	5.18	1.61
04/16/20 14:15:42	32880	11.79	2.44	0.13	0.01	5.17	1.58
04/16/20 14:16:12	32910	11.80	2.40	0.13	0.00	5.18	1.60
04/16/20 14:16:42	32940	11.79	2.39	0.10	0.00	5.18	1.60
04/16/20 14:17:12	32970	11.80	2.40	0.11	0.00	5.18	1.58
04/16/20 14:17:42	33000	11.79	2.42	0.12	0.00	5.18	1.57
04/16/20 14:18:12	33030	11.80	2.42	0.12	0.00	5.18	1.59
04/16/20 14:18:42	33060	11.81	2.41	0.11	0.00	5.18	1.59
04/16/20 14:19:12	33090	11.79	2.40	0.10	0.00	5.17	1.58
04/16/20 14:19:42	33120	11.80	2.36	0.12	0.00	5.17	1.56
04/16/20 14:20:12	33150	11.80	2.36	0.12	0.00	5.17	1.59
04/16/20 14:20:42	33180	11.80	2.35	0.14	0.00	5.17	1.56
04/16/20 14:21:12	33210	11.80	2.40	0.11	0.00	5.18	1.57
04/16/20 14:21:42	33240	11.80	2.39	0.13	0.00	5.18	1.56
04/16/20 14:22:12	33270	11.80	2.41	0.12	0.00	5.18	1.56
04/16/20 14:22:42	33300	11.80	2.38	0.12	0.00	5.19	1.58
04/16/20 14:23:12	33330	11.80	2.39	0.10	0.00	5.18	1.53
04/16/20 14:23:42	33360	11.79	2.45	0.13	0.01	5.18	1.50
04/16/20 14:24:12	33390	11.81	2.46	0.13	0.01	5.18	1.52
04/16/20 14:24:42	33420	11.81	2.42	0.13	0.01	5.18	1.49
04/16/20 14:25:12	33450	11.80	2.36	0.12	0.00	5.18	1.48
04/16/20 14:25:42	33480	11.80	2.37	0.10	0.00	5.18	1.53
04/16/20 14:26:12	33510	11.80	2.34	0.11	0.00	5.17	1.51
04/16/20 14:26:42	33540	11.80	2.25	0.10	0.00	5.17	1.46
04/16/20 14:27:12	33570	11.80	2.30	0.12	0.00	5.18	1.45
04/16/20 14:27:42	33600	11.80	2.35	0.11	0.00	5.18	1.43
04/16/20 14:28:12	33630	11.81	2.34	0.10	0.00	5.17	1.39
04/16/20 14:28:42	33660	11.81	2.34	0.12	0.00	5.17	1.38
04/16/20 14:29:12	33690	11.81	2.35	0.12	0.00	5.17	1.38
04/16/20 14:29:42	33720	11.81	2.34	0.09	0.00	5.17	1.35
04/16/20 14:30:12	33750	11.81	2.34	0.11	0.00	5.17	1.31
04/16/20 14:30:42	33780	11.82	2.34	0.11	0.00	5.17	1.31
04/16/20 14:31:12	33810	11.82	2.33	0.10	0.00	5.17	1.31
04/16/20 14:31:42	33840	11.82	2.34	0.12	0.00	5.17	1.27
04/16/20 14:32:12	33870	11.83	2.41	0.11	0.00	5.17	1.29
04/16/20 14:32:42	33900	11.83	2.40	0.13	0.00	5.17	1.26
04/16/20 14:33:12	33930	11.83	2.41	0.13	0.00	5.17	1.27
04/16/20 14:33:42	33960	11.83	2.41	0.13	0.00	5.17	1.26
04/16/20 14:34:12	33990	11.81	2.44	0.10	0.00	5.17	1.24
04/16/20 14:34:42	34020	11.82	2.44	0.12	0.00	5.17	1.23
04/16/20 14:35:12	34050	11.82	2.39	0.12	0.01	5.17	1.32
04/16/20 14:35:42	34080	11.83	2.36	0.14	0.00	5.17	1.58
04/16/20 14:36:12	34110	11.82	2.31	0.14	0.00	5.17	1.58
04/16/20 14:36:42	34140	11.83	2.29	0.15	0.00	5.17	1.53
04/16/20 14:37:12	34170	11.82	2.25	0.12	0.00	5.17	1.50
04/16/20 14:37:42	34200	11.81	2.30	0.14	0.01	5.17	1.44
04/16/20 14:38:12	34230	11.82	2.41	0.13	0.00	5.21	1.46
04/16/20 14:38:42	34260	11.83	2.53	0.14	0.00	5.21	1.48
04/16/20 14:39:12	34290	11.82	2.53	0.14	0.00	5.19	1.56
04/16/20 14:39:42	34320	11.82	2.45	0.13	0.00	5.19	1.63
04/16/20 14:40:12	34350	11.82	2.43	0.13	0.00	5.19	1.57
04/16/20 14:40:42	34380	11.81	2.44	0.11	0.00	5.19	1.52
04/16/20 14:41:12	34410	11.83	2.45	0.12	0.01	5.19	1.47
04/16/20 14:41:42	34440	11.83	2.46	0.11	0.01	5.18	1.44
04/16/20 14:42:12	34470	11.83	2.45	0.12	0.00	5.18	1.38

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,641	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,010	Btu/SCF fuel
Turbine Fuel Flow	1,681	lb/min
Duct Burner Fuel Flow	174	lb/min
Total Fuel Flow	2,578,392	SCFH

Weather Data

Barometric Pressure	29.99	in. Hg
Relative Humidity	54	%
Ambient Temperature	43	°F
Specific Humidity	0.003133	lb H_2O / lb air

Unit Data

Unit Load	240.3	megawatts
Heat Input	2,603	MMBtu/hr
NH_3 Flow Rate	164	lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M19)	52,449,328	SCFH

Data from: From PM Run PM U-00003 Base+DB-1

Base+Db Load, Run - 2-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/16/20 14:42:42	34500	11.83	2.44	0.12	0.00	5.18	1.49
04/16/20 14:43:12	34530	11.82	2.46	0.11	0.01	5.18	1.51
04/16/20 14:43:42	34560	11.83	2.45	0.13	0.01	5.18	1.50
04/16/20 14:44:12	34590	11.82	2.44	0.11	0.00	5.18	1.45
04/16/20 14:44:42	34620	11.81	2.44	0.11	0.00	5.18	1.50
04/16/20 14:45:12	34650	11.82	2.42	0.10	0.00	5.18	1.42
04/16/20 14:45:42	34680	11.82	2.55	0.15	0.01	5.19	1.39
04/16/20 14:46:12	34710	11.82	2.56	0.14	0.01	5.19	1.37
04/16/20 14:46:42	34740	11.81	2.55	0.12	0.01	5.19	1.35
04/16/20 14:47:12	34770	11.81	2.64	0.15	0.01	5.19	1.35
04/16/20 14:47:42	34800	11.81	2.64	0.13	0.00	5.19	1.31
04/16/20 14:48:12	34830	11.81	2.54	0.12	0.00	5.19	1.27
04/16/20 14:48:42	34860	11.81	2.48	0.12	0.00	5.18	1.35
04/16/20 14:49:12	34890	11.81	2.48	0.16	0.01	5.18	1.35
04/16/20 14:49:42	34920	11.82	2.40	0.13	0.00	5.18	1.36
04/16/20 14:50:12	34950	11.81	2.33	0.12	0.00	5.18	1.29
04/16/20 14:50:42	34980	11.82	2.37	0.13	0.01	5.18	1.23
04/16/20 14:51:12	35010	11.83	2.39	0.15	0.00	5.18	1.16
04/16/20 14:51:42	35040	11.83	2.45	0.13	0.00	5.18	1.15
04/16/20 14:52:12	35070	11.84	2.41	0.15	0.00	5.18	1.11
04/16/20 14:52:42	35100	11.85	2.40	0.15	0.00	5.17	1.07
04/16/20 14:53:12	35130	11.84	2.40	0.13	0.01	5.18	1.13
04/16/20 14:53:42	35160	11.84	2.36	0.13	0.00	5.18	1.10
04/16/20 14:54:12	35190	11.86	2.36	0.12	0.00	5.18	1.10
04/16/20 14:54:42	35220	11.86	2.33	0.12	0.00	5.17	1.15
04/16/20 14:55:12	35250	11.86	2.34	0.14	0.01	5.17	1.14
04/16/20 14:55:42	35280	11.86	2.36	0.16	0.01	5.17	1.13
04/16/20 14:56:12	35310	11.86	2.44	0.15	0.01	5.16	1.06
04/16/20 14:56:42	35340	11.85	2.43	0.14	0.00	5.17	1.05
04/16/20 14:57:12	35370	11.84	2.44	0.11	0.00	5.16	1.06
04/16/20 14:57:42	35400	11.83	2.52	0.13	0.00	5.17	1.04
04/16/20 14:58:12	35430	11.83	2.57	0.13	0.00	5.17	1.09
04/16/20 14:58:42	35460	11.83	2.57	0.14	0.00	5.17	1.09
04/16/20 14:59:12	35490	11.83	2.57	0.12	0.00	5.17	1.08
04/16/20 14:59:42	35520	11.83	2.54	0.12	0.00	5.17	1.03
04/16/20 15:00:12	35550	11.84	2.59	0.13	0.00	5.18	0.79
04/16/20 15:00:42	35580	11.84	2.52	0.12	0.00	5.17	0.94
04/16/20 15:01:12	35610	11.86	2.54	0.15	0.00	5.17	0.96
04/16/20 15:01:42	35640	11.85	2.58	0.14	0.00	5.16	0.94
04/16/20 15:02:12	35670	11.84	2.55	0.13	0.00	5.16	0.90
04/16/20 15:02:42	35700	11.85	2.51	0.12	0.00	5.16	0.95
04/16/20 15:03:12	35730	11.85	2.51	0.13	0.00	5.17	0.95
04/16/20 15:03:42	35760	11.85	2.48	0.13	0.00	5.17	0.91
RAW AVERAGE		**11.82**	**2.43**	**0.13**	**0.00**	**5.18**	**1.37**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.03	0.06	-0.05	0.01	-0.01	
Bias	**Final Zero**	0.07	0.23	0.05	0.00	0.09	
Bias	**Avg. Zero**	0.05	0.15	0.00	0.00	0.04	
Bias	**Initial UpScale**	11.88	4.53	5.16	3.01	9.02	
Bias	**Final UpScale**	11.84	4.61	5.10	3.11	8.94	
Bias	**Avg. UpScale**	11.86	4.57	5.13	3.06	8.98	
Upscale Cal Gas		11.98	4.55	5.22	3.03	8.91	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.94	2.35	0.13	0.00	5.12	1.52
Concentration (ppm@ 15%O_2)	N/A	1.54	0.08	0.00	N/A	1.00

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,641	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,010	Btu/SCF fuel
Turbine Fuel Flow	1,678	lb/min
Duct Burner Fuel Flow	175	lb/min
Total Fuel Flow	2,573,884	SCFH

Weather Data

Barometric Pressure	30.04	in. Hg
Relative Humidity	55	%
Ambient Temperature	44	° F
Specific Humidity	0.003311	lb H_2O / lb air

Unit Data

Unit Load	239.6	megawatts
Heat Input	2,599	MMBtu/hr
NH_3 Flow Rate	159	lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M19)	52,688,699	SCFH

Data from: From PM Run PM U-00003 Base+DB-1

Base+Db Load, Run - 2-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/16/20 15:23:12	36930	11.84	2.43	0.10	0.00	5.15	2.12
04/16/20 15:23:42	36960	11.84	2.47	0.06	0.00	5.16	1.98
04/16/20 15:24:12	36990	11.84	2.50	0.09	0.00	5.16	1.98
04/16/20 15:24:42	37020	11.83	2.50	0.06	0.00	5.16	2.06
04/16/20 15:25:12	37050	11.83	2.46	0.09	0.01	5.15	2.16
04/16/20 15:25:42	37080	11.82	2.43	0.07	0.00	5.16	2.10
04/16/20 15:26:12	37110	11.84	2.51	0.12	0.00	5.16	2.14
04/16/20 15:26:42	37140	11.84	2.58	0.10	0.01	5.16	2.06
04/16/20 15:27:12	37170	11.83	2.54	0.09	0.01	5.16	1.93
04/16/20 15:27:42	37200	11.84	2.46	0.11	0.00	5.16	2.04
04/16/20 15:28:12	37230	11.85	2.38	0.09	0.00	5.16	2.02
04/16/20 15:28:42	37260	11.85	2.35	0.09	0.01	5.16	1.95
04/16/20 15:29:12	37290	11.85	2.34	0.07	0.01	5.16	1.88
04/16/20 15:29:42	37320	11.85	2.27	0.06	0.02	5.16	1.84
04/16/20 15:30:12	37350	11.84	2.31	0.06	0.00	5.16	1.85
04/16/20 15:30:42	37380	11.84	2.29	0.07	0.00	5.16	1.75
04/16/20 15:31:12	37410	11.84	2.32	0.09	0.00	5.16	1.83
04/16/20 15:31:42	37440	11.85	2.35	0.10	0.00	5.16	1.94
04/16/20 15:32:12	37470	11.86	2.34	0.09	0.00	5.16	1.97
04/16/20 15:32:42	37500	11.86	2.38	0.08	0.00	5.16	2.02
04/16/20 15:33:12	37530	11.85	2.40	0.09	0.00	5.16	1.93
04/16/20 15:33:42	37560	11.85	2.34	0.09	0.00	5.16	2.10
04/16/20 15:34:12	37590	11.85	2.35	0.08	0.00	5.15	2.04
04/16/20 15:34:42	37620	11.85	2.33	0.06	0.00	5.16	2.09
04/16/20 15:35:12	37650	11.86	2.35	0.09	0.01	5.16	2.04
04/16/20 15:35:42	37680	11.86	2.38	0.07	0.00	5.16	1.98
04/16/20 15:36:12	37710	11.85	2.38	0.07	0.00	5.16	2.01
04/16/20 15:36:42	37740	11.86	2.38	0.07	0.00	5.16	2.11
04/16/20 15:37:12	37770	11.86	2.36	0.07	0.00	5.16	2.08
04/16/20 15:37:42	37800	11.86	2.34	0.08	0.00	5.16	2.08
04/16/20 15:38:12	37830	11.86	2.35	0.07	0.00	5.17	1.95
04/16/20 15:38:42	37860	11.86	2.38	0.10	0.01	5.17	2.01
04/16/20 15:39:12	37890	11.86	2.36	0.11	0.01	5.16	2.15
04/16/20 15:39:42	37920	11.86	2.34	0.09	0.00	5.16	1.97
04/16/20 15:40:12	37950	11.85	2.39	0.10	0.01	5.16	2.21
04/16/20 15:40:42	37980	11.85	2.36	0.10	0.00	5.16	2.16
04/16/20 15:41:12	38010	11.85	2.42	0.08	0.00	5.16	2.27
04/16/20 15:41:42	38040	11.85	2.47	0.09	0.00	5.16	2.24
04/16/20 15:42:12	38070	11.85	2.46	0.08	0.00	5.16	2.24
04/16/20 15:42:42	38100	11.85	2.49	0.09	0.00	5.16	2.26
04/16/20 15:43:12	38130	11.84	2.46	0.09	0.01	5.17	2.18
04/16/20 15:43:42	38160	11.84	2.41	0.07	0.00	5.16	2.13
04/16/20 15:44:12	38190	11.85	2.41	0.10	0.00	5.16	1.99
04/16/20 15:44:42	38220	11.84	2.33	0.08	0.00	5.16	1.97
04/16/20 15:45:12	38250	11.84	2.35	0.11	0.00	5.17	2.04
04/16/20 15:45:42	38280	11.85	2.52	0.11	0.01	5.17	1.95
04/16/20 15:46:12	38310	11.84	2.33	0.10	0.00	5.17	2.03
04/16/20 15:46:42	38340	11.84	2.34	0.08	0.00	5.17	2.02
04/16/20 15:47:12	38370	11.84	2.39	0.11	0.00	5.17	2.07
04/16/20 15:47:42	38400	11.83	2.40	0.08	0.00	5.17	1.98
04/16/20 15:48:12	38430	11.84	2.41	0.10	0.00	5.17	1.94
04/16/20 15:48:42	38460	11.85	2.35	0.06	0.00	5.17	2.00
04/16/20 15:49:12	38490	11.85	2.37	0.07	0.00	5.17	1.98
04/16/20 15:49:42	38520	11.86	2.35	0.06	0.00	5.17	1.92
04/16/20 15:50:12	38550	11.85	2.37	0.08	0.00	5.17	1.96
04/16/20 15:50:42	38580	11.84	2.36	0.07	0.00	5.17	2.09
04/16/20 15:51:12	38610	11.85	2.44	0.08	0.01	5.17	1.99
04/16/20 15:51:42	38640	11.85	2.41	0.08	0.00	5.17	2.03
04/16/20 15:52:12	38670	11.84	2.45	0.07	0.01	5.17	2.09
04/16/20 15:52:42	38700	11.85	2.39	0.08	0.00	5.17	2.06
04/16/20 15:53:12	38730	11.85	2.40	0.08	0.00	5.17	2.12
04/16/20 15:53:42	38760	11.84	2.38	0.07	0.00	5.17	2.15
04/16/20 15:54:12	38790	11.84	2.43	0.07	0.01	5.17	2.04
04/16/20 15:54:42	38820	11.84	2.40	0.07	0.00	5.17	2.10
04/16/20 15:55:12	38850	11.84	2.41	0.07	0.01	5.17	1.91
04/16/20 15:55:42	38880	11.85	2.39	0.06	0.00	5.17	2.08
04/16/20 15:56:12	38910	11.85	2.38	0.08	0.00	5.17	1.98
04/16/20 15:56:42	38940	11.85	2.33	0.06	0.00	5.17	1.88
04/16/20 15:57:12	38970	11.84	2.43	0.09	0.01	5.17	1.96
04/16/20 15:57:42	39000	11.85	2.39	0.08	0.01	5.17	1.92
04/16/20 15:58:12	39030	11.86	2.30	0.08	0.00	5.17	1.78
04/16/20 15:58:42	39060	11.86	2.40	0.09	0.00	5.17	1.90
04/16/20 15:59:12	39090	11.84	2.43	0.11	0.01	5.17	1.91
04/16/20 15:59:42	39120	11.84	2.35	0.06	0.00	5.17	1.86
04/16/20 16:00:12	39150	11.85	2.36	0.08	0.00	5.17	1.75
04/16/20 16:00:42	39180	11.85	2.37	0.07	0.00	5.17	1.87
04/16/20 16:01:12	39210	11.85	2.41	0.09	0.01	5.17	1.84

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,641	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,010	Btu/SCF fuel
Turbine Fuel Flow	1,678	lb/min
Duct Burner Fuel Flow	175	lb/min
Total Fuel Flow	2,573,884	SCFH

Weather Data

Barometric Pressure	30.04	in. Hg
Relative Humidity	55	%
Ambient Temperature	44	°F
Specific Humidity	0.003311	lb H_2O / lb air

Unit Data

Unit Load	239.6	megawatts
Heat Input	2,599	MMBtu/hr
NH_3 Flow Rate	159	lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M19)	52,688,699	SCFH

Data from: From PM Run PM U-00003 Base+DB-1

Base+Db Load, Run - 2-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/16/20 16:01:42	39240	11.85	2.40	0.10	0.00	5.17	1.90
04/16/20 16:02:12	39270	11.86	2.39	0.08	0.00	5.17	2.11
04/16/20 16:02:42	39300	11.86	2.37	0.09	0.00	5.17	2.00
04/16/20 16:03:12	39330	11.85	2.45	0.05	0.00	5.17	2.06
04/16/20 16:03:42	39360	11.84	2.47	0.07	0.00	5.17	1.94
04/16/20 16:04:12	39390	11.84	2.49	0.06	0.00	5.17	1.99
04/16/20 16:04:42	39420	11.83	2.47	0.06	0.00	5.17	2.00
04/16/20 16:05:12	39450	11.85	2.46	0.06	0.00	5.18	1.93
04/16/20 16:05:42	39480	11.84	2.43	0.07	0.00	5.18	1.96
04/16/20 16:06:12	39510	11.84	2.43	0.08	0.01	5.18	2.03
04/16/20 16:06:42	39540	11.84	2.46	0.06	0.00	5.17	2.03
04/16/20 16:07:12	39570	11.85	2.51	0.09	0.00	5.17	2.05
04/16/20 16:07:42	39600	11.85	2.49	0.07	0.00	5.17	1.87
04/16/20 16:08:12	39630	11.84	2.46	0.09	0.00	5.18	2.03
04/16/20 16:08:42	39660	11.84	2.46	0.10	0.00	5.18	1.71
04/16/20 16:09:12	39690	11.83	2.45	0.09	0.00	5.18	1.63
04/16/20 16:09:42	39720	11.84	2.45	0.09	0.00	5.18	1.84
04/16/20 16:10:12	39750	11.85	2.38	0.09	0.00	5.17	1.88
04/16/20 16:10:42	39780	11.86	2.39	0.11	0.01	5.18	1.83
04/16/20 16:11:12	39810	11.85	2.36	0.10	0.01	5.18	1.96
04/16/20 16:11:42	39840	11.85	2.32	0.08	0.00	5.18	1.83
04/16/20 16:12:12	39870	11.84	2.36	0.10	0.01	5.19	1.88
04/16/20 16:12:42	39900	11.84	2.43	0.11	0.01	5.18	1.87
04/16/20 16:13:12	39930	11.82	2.42	0.08	0.00	5.18	2.14
04/16/20 16:13:42	39960	11.84	2.46	0.08	0.00	5.19	2.10
04/16/20 16:14:12	39990	11.85	2.56	0.07	0.00	5.19	2.13
04/16/20 16:14:42	40020	11.84	2.58	0.08	0.00	5.19	1.99
04/16/20 16:15:12	40050	11.84	2.56	0.07	0.00	5.18	2.05
04/16/20 16:15:42	40080	11.84	2.52	0.08	0.00	5.19	1.99
04/16/20 16:16:12	40110	11.84	2.50	0.06	0.01	5.19	1.84
04/16/20 16:16:42	40140	11.83	2.42	0.09	0.00	5.19	1.75
04/16/20 16:17:12	40170	11.85	2.38	0.08	0.00	5.19	1.70
04/16/20 16:17:42	40200	11.85	2.32	0.07	0.00	5.19	2.05
04/16/20 16:18:12	40230	11.84	2.44	0.11	0.00	5.20	1.93
04/16/20 16:18:42	40260	11.84	2.48	0.12	0.00	5.20	2.01
04/16/20 16:19:12	40290	11.84	2.53	0.13	0.00	5.20	2.09
04/16/20 16:19:42	40320	11.84	2.54	0.11	0.01	5.20	1.90
04/16/20 16:20:12	40350	11.85	2.51	0.08	0.00	5.20	1.68
04/16/20 16:20:42	40380	11.85	2.53	0.08	0.00	5.20	1.59
04/16/20 16:21:12	40410	11.86	2.48	0.07	0.00	5.20	1.92
04/16/20 16:21:42	40440	11.85	2.42	0.09	0.00	5.19	1.72
04/16/20 16:22:12	40470	11.85	2.39	0.07	0.00	5.19	1.78
04/16/20 16:22:42	40500	11.85	2.42	0.09	0.00	5.20	1.89
RAW AVERAGE		**11.85**	**2.41**	**0.08**	**0.00**	**5.17**	**1.98**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.07	0.23	0.05	0.00	0.09	
Bias	**Final Zero**	0.05	0.22	0.05	0.00	0.10	
Bias	**Avg. Zero**	0.06	0.23	0.05	0.00	0.10	
Bias	**Initial UpScale**	11.84	4.61	5.10	3.11	8.94	
Bias	**Final UpScale**	11.83	4.64	5.14	3.13	8.96	
Bias	**Avg. UpScale**	11.84	4.63	5.12	3.12	8.95	
Upscale Cal Gas		11.98	4.55	5.22	3.03	8.91	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.99	2.26	0.03	0.00	5.11	2.19
Concentration (ppm@ 15%O_2)	N/A	1.50	0.02	0.00	N/A	1.45

Non-Bias Adjusted Averages Include: *

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,641	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,010	Btu/SCF fuel
Turbine Fuel Flow	1,681	lb/min
Duct Burner Fuel Flow	175	lb/min
Total Fuel Flow	2,579,455	SCFH

Weather Data

Barometric Pressure	30.10	in. Hg
Relative Humidity	53	%
Ambient Temperature	46	° F
Specific Humidity	0.003436	lb H_2O / lb air

Unit Data

Unit Load	240.5	megawatts
Heat Input	2,604	MMBtu/hr
NH_3 Flow Rate	164	lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M19)	52,766,594	SCFH

Data from: From PM Run PM U-00003 Base+DB-1

Base+Db Load, Run - 2-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/16/20 17:40:12	45150	11.84	2.27	0.03	0.00	5.18	0.52
04/16/20 17:40:42	45180	11.84	2.29	0.04	0.01	5.18	0.63
04/16/20 17:41:12	45210	11.83	2.25	-0.01	0.00	5.18	0.83
04/16/20 17:41:42	45240	11.84	2.30	0.00	0.00	5.17	0.96
04/16/20 17:42:12	45270	11.83	2.33	0.00	0.00	5.18	1.01
04/16/20 17:42:42	45300	11.83	2.36	0.01	0.00	5.18	0.99
04/16/20 17:43:12	45330	11.83	2.35	0.01	0.00	5.18	0.94
04/16/20 17:43:42	45360	11.83	2.33	-0.01	0.00	5.17	0.89
04/16/20 17:44:12	45390	11.85	2.36	0.00	0.01	5.17	0.87
04/16/20 17:44:42	45420	11.85	2.35	0.00	0.01	5.17	0.86
04/16/20 17:45:12	45450	11.84	2.26	-0.03	0.00	5.17	0.82
04/16/20 17:45:42	45480	11.84	2.29	0.00	0.00	5.18	0.81
04/16/20 17:46:12	45510	11.85	2.28	-0.01	0.00	5.18	0.80
04/16/20 17:46:42	45540	11.85	2.31	0.03	0.01	5.18	0.80
04/16/20 17:47:12	45570	11.84	2.28	0.00	0.00	5.18	0.84
04/16/20 17:47:42	45600	11.83	2.28	0.00	0.00	5.18	0.82
04/16/20 17:48:12	45630	11.83	2.34	0.01	0.00	5.17	0.82
04/16/20 17:48:42	45660	11.83	2.38	-0.01	0.00	5.17	0.77
04/16/20 17:49:12	45690	11.84	2.33	0.01	0.00	5.17	0.76
04/16/20 17:49:42	45720	11.83	2.31	0.00	0.01	5.18	0.78
04/16/20 17:50:12	45750	11.83	2.30	0.01	0.00	5.19	0.77
04/16/20 17:50:42	45780	11.81	2.31	-0.01	0.00	5.19	0.77
04/16/20 17:51:12	45810	11.83	2.27	0.00	0.00	5.18	0.75
04/16/20 17:51:42	45840	11.84	2.26	-0.01	0.00	5.17	0.71
04/16/20 17:52:12	45870	11.84	2.25	-0.02	0.00	5.17	0.77
04/16/20 17:52:42	45900	11.84	2.32	0.00	0.01	5.17	0.82
04/16/20 17:53:12	45930	11.83	2.38	0.00	0.01	5.18	0.91
04/16/20 17:53:42	45960	11.83	2.38	0.01	0.00	5.18	0.93
04/16/20 17:54:12	45990	11.84	2.35	0.00	0.00	5.17	0.86
04/16/20 17:54:42	46020	11.84	2.33	-0.01	0.01	5.17	0.82
04/16/20 17:55:12	46050	11.84	2.29	-0.01	0.00	5.18	0.81
04/16/20 17:55:42	46080	11.84	2.29	-0.01	0.00	5.19	0.81
04/16/20 17:56:12	46110	11.84	2.29	-0.02	0.01	5.19	0.75
04/16/20 17:56:42	46140	11.83	2.28	0.00	0.00	5.19	0.76
04/16/20 17:57:12	46170	11.84	2.31	-0.04	0.00	5.19	0.78
04/16/20 17:57:42	46200	11.83	2.39	0.00	0.00	5.19	0.85
04/16/20 17:58:12	46230	11.84	2.49	-0.01	0.01	5.19	0.87
04/16/20 17:58:42	46260	11.85	2.46	-0.02	0.00	5.19	0.83
04/16/20 17:59:12	46290	11.84	2.41	0.01	0.00	5.19	0.82
04/16/20 17:59:42	46320	11.84	2.37	-0.03	0.00	5.20	0.82
04/16/20 18:00:12	46350	11.84	2.35	0.02	0.00	5.19	0.81
04/16/20 18:00:42	46380	11.84	2.37	0.00	0.00	5.19	0.81
04/16/20 18:01:12	46410	11.84	2.34	-0.02	0.00	5.19	0.77
04/16/20 18:01:42	46440	11.84	2.34	-0.03	0.00	5.20	0.74
04/16/20 18:02:12	46470	11.84	2.36	-0.01	0.00	5.20	0.71
04/16/20 18:02:42	46500	11.84	2.33	-0.02	0.00	5.20	0.68
04/16/20 18:03:12	46530	11.84	2.36	-0.01	0.00	5.20	0.67
04/16/20 18:03:42	46560	11.85	2.34	-0.01	0.00	5.19	0.64
04/16/20 18:04:12	46590	11.84	2.29	-0.03	0.00	5.19	0.65
04/16/20 18:04:42	46620	11.84	2.30	0.01	0.01	5.18	0.63
04/16/20 18:05:12	46650	11.84	2.28	0.02	0.01	5.18	0.64
04/16/20 18:05:42	46680	11.84	2.23	0.00	0.00	5.18	0.64
04/16/20 18:06:12	46710	11.83	2.29	0.01	0.01	5.18	0.63
04/16/20 18:06:42	46740	11.83	2.23	-0.01	0.00	5.19	0.64
04/16/20 18:07:12	46770	11.84	2.22	-0.01	0.00	5.19	0.66
04/16/20 18:07:42	46800	11.84	2.20	0.02	0.00	5.19	0.67
04/16/20 18:08:12	46830	11.83	2.22	0.00	0.00	5.19	0.66
04/16/20 18:08:42	46860	11.83	2.26	0.02	0.01	5.20	0.65
04/16/20 18:09:12	46890	11.84	2.28	0.02	0.01	5.20	0.73
04/16/20 18:09:42	46920	11.83	2.34	0.01	0.00	5.20	0.75
04/16/20 18:10:12	46950	11.83	2.37	0.00	0.00	5.20	0.86
04/16/20 18:10:42	46980	11.84	2.38	0.01	0.00	5.21	0.91
04/16/20 18:11:12	47010	11.83	2.43	0.02	0.00	5.20	0.88
04/16/20 18:11:42	47040	11.83	2.29	0.01	0.00	5.20	0.87
04/16/20 18:12:12	47070	11.83	2.31	0.04	0.00	5.20	0.84
04/16/20 18:12:42	47100	11.83	2.31	0.01	0.00	5.21	0.82
04/16/20 18:13:12	47130	11.85	2.29	0.01	0.00	5.19	0.83
04/16/20 18:13:42	47160	11.85	2.24	0.00	0.00	5.19	0.82
04/16/20 18:14:12	47190	11.84	2.31	0.01	0.00	5.19	0.79
04/16/20 18:14:42	47220	11.83	2.25	0.01	0.00	5.20	0.80
04/16/20 18:15:12	47250	11.84	2.23	0.00	0.00	5.20	0.80
04/16/20 18:15:42	47280	11.84	2.23	0.01	0.00	5.20	0.79
04/16/20 18:16:12	47310	11.83	2.27	0.01	0.00	5.20	0.83
04/16/20 18:16:42	47340	11.82	2.26	0.01	0.00	5.21	0.81
04/16/20 18:17:12	47370	11.83	2.29	0.01	0.00	5.20	0.77
04/16/20 18:17:42	47400	11.83	2.24	-0.01	0.00	5.20	0.77
04/16/20 18:18:12	47430	11.84	2.32	0.00	0.01	5.20	0.80

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,641	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,010	Btu/SCF fuel
Turbine Fuel Flow	1,681	lb/min
Duct Burner Fuel Flow	175	lb/min
Total Fuel Flow	2,579,455	SCFH

Weather Data

Barometric Pressure	30.10	in. Hg
Relative Humidity	53	%
Ambient Temperature	46	°F
Specific Humidity	0.003436	lb H_2O / lb air

Unit Data

Unit Load	240.5	megawatts
Heat Input	2,604	MMBtu/hr
NH_3 Flow Rate	164	lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M19)	52,766,594	SCFH

Data from: From PM Run PM U-00003 Base+DB-1

Base+Db Load, Run - 2-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	VOC (as C1) (ppmvw)	CO_2 (%)	NH_3 (ppmvw)
04/16/20 18:18:42	47460	11.84	2.37	0.02	0.00	5.21	0.81
04/16/20 18:19:12	47490	11.83	2.37	0.02	0.01	5.21	0.82
04/16/20 18:19:42	47520	11.83	2.35	0.01	0.00	5.21	0.83
04/16/20 18:20:12	47550	11.84	2.33	-0.01	0.00	5.22	0.86
04/16/20 18:20:42	47580	11.84	2.38	0.04	0.01	5.21	0.94
04/16/20 18:21:12	47610	11.83	2.35	0.02	0.01	5.20	0.99
04/16/20 18:21:42	47640	11.84	2.41	0.04	0.01	5.20	0.99
04/16/20 18:22:12	47670	11.82	2.40	0.01	0.01	5.19	0.98
04/16/20 18:22:42	47700	11.82	2.33	0.00	0.00	5.19	0.99
04/16/20 18:23:12	47730	11.84	2.31	0.01	0.00	5.19	0.92
04/16/20 18:23:42	47760	11.84	2.29	0.02	0.00	5.19	0.95
04/16/20 18:24:12	47790	11.84	2.25	0.03	0.00	5.19	0.90
04/16/20 18:24:42	47820	11.83	2.23	0.03	0.00	5.19	0.91
04/16/20 18:25:12	47850	11.84	2.21	0.04	0.00	5.19	0.90
04/16/20 18:25:42	47880	11.84	2.23	0.02	0.00	5.19	0.86
04/16/20 18:26:12	47910	11.83	2.26	0.02	0.01	5.19	0.89
04/16/20 18:26:42	47940	11.83	2.26	0.03	0.00	5.20	0.88
04/16/20 18:27:12	47970	11.83	2.27	0.03	0.01	5.20	0.89
04/16/20 18:27:42	48000	11.84	2.26	0.00	0.00	5.20	0.89
04/16/20 18:28:12	48030	11.84	2.32	0.02	0.00	5.20	0.86
04/16/20 18:28:42	48060	11.83	2.31	0.03	0.01	5.20	0.91
04/16/20 18:29:12	48090	11.85	2.27	0.02	0.00	5.19	0.87
04/16/20 18:29:42	48120	11.84	2.26	0.04	0.01	5.20	0.93
04/16/20 18:30:12	48150	11.83	2.20	0.03	0.00	5.20	0.95
04/16/20 18:30:42	48180	11.83	2.26	0.04	0.00	5.20	1.01
04/16/20 18:31:12	48210	11.83	2.36	0.03	0.00	5.19	0.96
04/16/20 18:31:42	48240	11.82	2.35	0.04	0.00	5.19	1.01
04/16/20 18:32:12	48270	11.84	2.38	0.03	0.00	5.20	0.96
04/16/20 18:32:42	48300	11.84	2.36	0.04	0.00	5.20	0.94
04/16/20 18:33:12	48330	11.83	2.31	0.00	0.00	5.20	0.97
04/16/20 18:33:42	48360	11.83	2.35	0.04	0.01	5.20	0.94
04/16/20 18:34:12	48390	11.83	2.30	0.02	0.00	5.20	0.92
04/16/20 18:34:42	48420	11.84	2.33	0.04	0.01	5.20	0.93
04/16/20 18:35:12	48450	11.83	2.32	0.03	0.01	5.20	0.94
04/16/20 18:35:42	48480	11.82	2.37	0.01	0.00	5.20	0.95
04/16/20 18:36:12	48510	11.82	2.33	0.05	0.01	5.20	0.96
04/16/20 18:36:42	48540	11.82	2.37	0.04	0.01	5.20	0.91
04/16/20 18:37:12	48570	11.84	2.31	0.03	0.00	5.20	0.93
04/16/20 18:37:42	48600	11.84	2.30	0.03	0.01	5.20	0.93
04/16/20 18:38:12	48630	11.82	2.25	0.01	0.00	5.19	0.91
04/16/20 18:38:42	48660	11.82	2.32	0.04	0.00	5.19	0.88
04/16/20 18:39:12	48690	11.83	2.31	0.00	0.00	5.19	0.92
04/16/20 18:39:42	48720	11.83	2.30	0.02	0.00	5.19	0.93
RAW AVERAGE		**11.84**	**2.31**	**0.01**	**0.00**	**5.19**	**0.83**

		O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
	Serial Number:	inst-02-0024	inst-nx-0031	inst-co-0029	inst-th-0013	inst-c2-0016	inst-ir-0004
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)	
Bias	**Initial Zero**	0.05	0.22	0.05	0.00	0.10	
Bias	**Final Zero**	0.08	0.15	-0.04	0.00	0.11	
Bias	**Avg. Zero**	0.07	0.19	0.01	0.00	0.11	
	Initial UpScale	11.83	4.64	5.14	3.13	8.96	
	Final UpScale	11.83	4.64	5.25	3.16	8.90	
	Avg. UpScale	11.83	4.64	5.20	3.15	8.93	
Upscale Cal Gas		11.98	4.55	5.22	3.03	8.91	

EMISSIONS DATA	O_2	NOx	CO	VOC (as C1)	CO_2	NH_3
Corrected Raw Average (ppm/% dry basis)	11.99	2.17	0.00	0.00	5.13	0.92
Concentration (ppm@ 15%O_2)	N/A	1.44	0.00	0.00	N/A	0.61

Non-Bias Adjusted Averages Include: *

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
PM_{10}

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#3	
Operator		Rob White	
Date for Preliminary Run	(mm/dd/yy)	04/16/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	indust. spec.	50	scf
Run Duration	chk Subpart	240	minutes
Unit Number		U-00003	
Base Run Number		PM U-00003 Base+DB	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	04/16/20	04/17/20	04/17/20	
Load		Base+DB	Base+DB	Base+DB	% or w/DB
Fuel F-Factor		8641.42	8663.09	8663.09	dscf/MMBtu
Meter Box Number	from ACS	Samp-cp-0033	Samp-cp-0033	Samp-cp-0033	
Meter Calibration Factor	(Y)	0.978	0.978	0.978	
Orifice Meter Coefficient	($\Delta H_@$)	1.846	1.846	1.846	in H_2O
Non-Console Manometer Used		No	No	No	
Pitot Identification	from ACS	5266/10	5266/10	5266/10	
Pitot Tube Coefficient	(C_p)	0.7720	0.7720	0.7720	
Nozzle Number	from ACS	4a	4a	4a	must match cyc nozz tab (e.g. 3a, 4b, etc.)
Nozzle Diameter	(D_n)	0.157	0.157	0.157	in
Probe Number	from ACS	SAMP-HP-0138	SAMP-HP-0138	SAMP-HP-0138	
Probe Length		120.0	120.0	120.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039	
Impinger Case Number	from ACS	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	04/16/20
Sampling Location	U-00003 Base+DB	**Stack Type**	Circular
Operator	Rob White	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	4
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

○ Method 1 Trav

◉ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
4	**Ports by**	3	**Across**
12	**Pts Used**	12	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.044	10	18
2	0.146	33 2/8	41 2/8
3	0.296	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Cricket Valley Energy Center			
Sampling Location	U-00003 Base+DB			
Operator	Rob White			
Project #	bec-19-cricketvalley.ny-start#3			
Pitot Leak Check	x	**PreTest**	x	**PostTest**

Preliminary Run Date	04/16/20		
Stack Type	Circular		
Ports Available	4		
Thermocouple ID	SAMP-HP-0138		
Pitot Coefficient	0.8198	**Pitot Identification**	4187

RM 201A or OTM 27 Blckag.	**RM 201A or OTM 27 Pitot Coeff.**
5.39E-04	0.7720

Stack Dimensions			
Area of Stack	(A_s)	283.53	ft²
Diameter of Stack	(D)	228.00	in

Pressures			
Barometric Pressure	(P_b)	29.99	in Hg
Static Pressure	(P_{static})	-0.96	in H_2O
Absolute Stack Pressure	(P_s)	29.92	in Hg

Stack Gas Composition			
Composition Data:	**Estimated Composition**		
Carbon Dioxide Concentration	($\%CO_2$)	5.76	%vd
Oxygen Concentration	($\%O_2$)	12.78	%vd
Carbon Monoxide Concentration	(ppmCO)	0.00	ppmvd
Nitrogen Concentration	($\%N_2$)	81.46	%vd
Stack Moisture Content	(B_{ws})	8.00	%
Stack Dry Molecular Weight	(M_d)	29.43	lb/lb-mole
Stack Wet Molecular Weight	(M_w)	28.52	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v_s)	66.24	ft/sec
Avg Stack Dry Std Flow Rate	(Q_{sd})	51,309,129	dscf/hr
Avg Stack Dry Std Flow Rate	(Q_{sd})	855,152	dscf/min
Avg Stack Wet Flow Rate	(Q_{aw})	1,126,852	acf/min
Avg Stack Wet Std Flow Rate	(Q_{sw})	55,770,793	ascf/hr

40 CFR 60, Method 2G, Section 8.11.1 (but applies to all Method 2 type static pressure measurements):
If a Type S probe is used for this measurement, position the probe at or between any traverse point(s) and rotate the probe until a null differential pressure reading is obtained. Disconnect the tubing from one of the pressure ports; read and record the ΔP. For pressure devices with one-directional scales, if a deflection in the positive direction is noted with the negative side disconnected, then the static pressure is positive. Likewise, if a deflection in the positive direction is noted with the positive side disconnected, then the static pressure is negative.

Stack Cross Section Schematic

Velocity Traverse Data

Run Number	PM U-00003 Base+DB-V1				
Run Time	12:09	**Start**	12:21	**End**	

Traverse Point	**Velocity Head** (Δp)	**Null Angle** (N_a)	**Zero Deg Pressure** ($0°_a$)	**Stack Temp** (t_s)	**Local Velocity** ($v_{s(l)}$)	**Adjusted Velocity Pressure**	**Adjusted Velocity Pressure w/BF, if app**
	in H_2O	deg	in H_2O	°F	ft/sec	in H_2O	in H_2O
A-1	1.70	0	0.00	181	79.20	1.51	1.51
A-2	1.60	-5	0.15	181	76.84	1.42	1.42
A-3	1.40	-5	0.17	180	71.82	1.24	1.24
B-1	1.40	0	0.00	181	71.88	1.24	1.24
B-2	1.50	0	0.00	180	74.34	1.33	1.33
B-3	1.60	0	0.00	181	76.84	1.42	1.42
C-1	1.70	-5	0.08	180	79.14	1.51	1.51
C-2	1.30	-5	0.18	180	69.21	1.15	1.15
C-3	1.40	0	0.00	180	71.82	1.24	1.24
D-1	1.50	0	0.00	179	74.28	1.33	1.33
D-2	1.50	-5	0.16	178	74.22	1.33	1.33
D-3	1.60	-5	0.13	180	76.78	1.42	1.42
Average	1.52	3		180		1.34	1.34
	1.23	**= Square roots of Δp**					1.16
Standard deviation of null angles =				2.6			

METHOD 201A and OTM 27 - DETERMINATION OF NOZZLE SIZE AND POST RUN QUALITY CONTROL

Gas Analysis	Prelim	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	PM U-00003 Base+DB-4	PM U-00003 Base+DB-5	PM U-00003 Base+DB-6	
Carbon Dioxide Content	5.8	5.1	5.1	5.1				%
Oxygen Content	12.8	11.8	11.8	11.8				%
Stack Moisture Content	8.0	9.5	9.9	10.0				%
Nitrogen plus CO Content	81.5	83.1	83.1	83.1				%

Corrected Velocity Head, $\Delta p_{2.5}$ (in H_2O)	Min.	1.15	Max.	1.51

Stack and Equipment Information	Prelim	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	PM U-00003 Base+DB-4	PM U-00003 Base+DB-5	PM U-00003 Base+DB-6	
Barometric Pressure	29.99	30.05	30.21	30.22				in Hg
Stack Static Pressure	-0.96	-0.96	-0.96	-0.96				in H_2O
Absolute Stack Pressure	29.92	29.98	30.14	30.15				in Hg
Average Stack Temp	180	182	177	178				0.00
Average Stack Temp	640	642	637	638				°R
Average Meter Temp	85	80	70	75				0.00
Orifice Meter Coefficient	1.846	1.846	1.846	1.846				in H_2O
Pitot Coefficient	0.772	0.772	0.772	0.772				
Stack Dry Molecular Weight	29.43	29.29	29.29	29.29				lb/lb mole
Stack Wet Molecular Weight	28.52	28.22	28.18	28.16				lb/lb mole
Stack Viscosity	199.79	198.41	196.82	196.86				µP
Cunningham Correction Factor, for a 2.25 µm particle	1.08							
Cunningham Correction Factor, for a 2.5 µm particle		1.07	1.07	1.07				
Prelim Cut Dia., Cyclone I, D_{50LL}, N_{re}<3162	10.30	2.28	2.27	2.25				µm
Middle Zone Dia., Cyclone I, D_{50T}, N_{re}<3162	10.65							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.), N_{re}<3162	0.48							dscfm
Reynolds Number, Cyc I & IV, N_{re}<3162	2746.16	2831.81	2862.75	2877.55				
Dia. of 50% Prob. (D_{50}) Cyc IV (N_{re}<3162)	2.38	2.29	2.28	2.26				µm
Sampling Rate, Cyc IV, N_{re}<3,162	0.48							dscfm
Reynolds Number, Cyc IV, N_{re}<3162	2746.12	2831.81	2862.75	2877.55				
Prelim Cut Dia., Cyclone I, $D_{50LL\geq3162}$	10.63							µm
Middle Zone Dia., Cyclone I, $D_{50T\geq3162}$	10.81							µm
Sampling Rate (PM_{10} & $PM_{2.5}$ Cyc.)≥3162	0.47							dscfm
Reynolds Number, Cyc I & IV, N_{re}≥3162	2688.56							
Dia. of 50% Prob. (D_{50}) CIV (N_{re}≥3162)	2.29							µm
Sampling Rate, Cyc IV, N_{re}≥3,162	4.66							dscfm
Reynolds Number ≥ 3162	26885.76							
Cyclone Flow Rate	0.48	0.49	0.49	0.49				ft³/min
Recalculated D_{50-1} for C_{IV}		2.28	2.27	2.25				
Recalculated Cunninham		1.08	1.08	1.08				
Z		1.00	1.00	1.00				
Isokinetics		91.09	90.33	90.47				%
No. Sampling Pts. Outside Δp		0	0	0				
Sample Nozzle Diameter		0.157	0.157	0.157				in

Orifice Head and Nozzle Selection Calculation											
Nozzle No.	2a	2b	3a	3b	4a	4b	5a	5b	6a	6b	7a
Nozzle diameter, D_n, in.	0.088	0.103	0.119	0.130	0.157	0.175	0.197	0.212	0.284	0.331	0.374
Nozzle velocity, v_n, ft/sec	187.98	137.21	102.80	86.14	59.06	47.53	37.51	32.39	18.05	13.29	10.41
R_{min}	0.79	0.78	0.77	0.76	0.72	0.69	0.63	0.58	0.50	0.50	0.50
v_{min}, ft/sec	147.98	106.95	78.94	65.28	42.72	32.81	23.79	18.82	9.02	6.64	5.20
R_{max}	1.21	1.21	1.22	1.23	1.25	1.27	1.30	1.32	1.46	1.50	1.50
v_{max}, ft/sec	227.30	166.67	125.67	105.88	73.86	60.34	48.66	42.74	26.42	19.93	15.61
Δp_{min}, in. H_2O @ $t_{s-50}{}^oF$	7.27	3.80	2.07	1.41	0.61	0.36	0.19	0.12	0.03	0.01	0.01
Δp_{min}, in. H_2O @ t_s	6.70	3.50	1.91	1.30	0.56	0.33	0.17	0.11	0.02	0.01	0.01
Δp_{max}, in. H_2O @ t_s	15.82	8.50	4.83	3.43	1.67	1.11	0.72	0.56	0.21	0.12	0.07
Δp_{min}, in. H_2O @ $t_{s+50}{}^oF$	14.67	7.89	4.48	3.18	1.55	1.03	0.67	0.52	0.20	0.11	0.07
ΔH, in. H_2O @ t_s+50°F	0.386										
ΔH, in. H_2O @ t_s	**0.449**										
ΔH, in. H_2O @ t_s-50°F	0.528										

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/16/20		
Sampling Location	U-00003 Base+DB	**Operator**	Rob White		
Project #	bec-19-cricketvalley.ny-start#3	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	PM U-00003 Base+DB-1		**Date**	04/16/20	**Run Start Time**	12:23	**Run Stop Time**	16:49
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:26	5.1	11.8	0.0	83.1	29.29	1.772	116.7	YES

Gas Analysis Data

Run Number	PM U-00003 Base+DB-2		**Date**	04/17/20	**Run Start Time**	04:15	**Run Stop Time**	08:34
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:19	5.1	11.8	0.0	83.1	29.29	1.768	116.8	YES

Gas Analysis Data

Run Number	PM U-00003 Base+DB-3		**Date**	04/17/20	**Run Start Time**	09:35	**Run Stop Time**	14:03
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
04:28	5.1	11.8	0.0	83.1	29.29	1.773	116.9	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/16/20
Sampling Location	U-00003 Base+DB	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	4

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 1	04/16/20	500	499.6	-0.4	Pass
Test Day 2	04/17/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number		PM U-00003 Base+DB-1		**Date**	04/16/20	**Start Time**	12:23	**Stop Time**	16:49
Meter Box Number		Samp-cp-0033				**Meter Cal Factor**	(Y)	0.978	
Total Meter Volume	(V_m)	93.650	dcf			**Barometric Pressure**	(P_b)	30.05	in Hg
Average Stack Temp	$(t_s)_{avg}$	182	°F			**Stack Static Pressure**	(P_{static})	-0.96	in H_2O
Average Meter Temp	$(t_m)_{avg}$	80	°F			**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.45	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	529.70	587.00	728.50	884.60				
Initial Value	(V_i),(W_i)	363.90	586.90	722.80	856.00				
Net Value	(V_n),(W_n)	165.8	0.1	5.7	28.6				
Results									
Total Weight	(W_t)	200.20	g			**Water Vol Weighed**	$(V_{wsg(std)})$	9.439	scf
Std Meter Volume	$(V_{m(std)})$	89.987	dscf			**Sat. Moisture Content**	$(B_{ws(svp)})$	53.59	%
Calc Moisture Content	$(B_{ws(calc)})$	9.49	%			**Final Moisture Content**	(B_{ws})	9.49	%

Moisture Content Data									
Run Number		PM U-00003 Base+DB-2		**Date**	04/17/20	**Start Time**	04:15	**Stop Time**	08:34
Meter Box Number		Samp-cp-0033				**Meter Cal Factor**	(Y)	0.978	
Total Meter Volume	(V_m)	91.890	dcf			**Barometric Pressure**	(P_b)	30.21	in Hg
Average Stack Temp	$(t_s)_{avg}$	177	°F			**Stack Static Pressure**	(P_{static})	-0.96	in H_2O
Average Meter Temp	$(t_m)_{avg}$	70	°F			**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.45	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	564.80	578.80	650.00	988.00				
Initial Value	(V_i),(W_i)	379.70	578.80	649.10	963.40				
Net Value	(V_n),(W_n)	185.1	0.0	0.9	24.6				
Results									
Total Weight	(W_t)	210.60	g			**Water Vol Weighed**	$(V_{wsg(std)})$	9.930	scf
Std Meter Volume	$(V_{m(std)})$	90.539	dscf			**Sat. Moisture Content**	$(B_{ws(svp)})$	47.52	%
Calc Moisture Content	$(B_{ws(calc)})$	9.88	%			**Final Moisture Content**	(B_{ws})	9.88	%

Moisture Content Data									
Run Number		PM U-00003 Base+DB-3		**Date**	04/17/20	**Start Time**	09:35	**Stop Time**	14:03
Meter Box Number		Samp-cp-0033				**Meter Cal Factor**	(Y)	0.978	
Total Meter Volume	(V_m)	93.400	dcf			**Barometric Pressure**	(P_b)	30.22	in Hg
Average Stack Temp	$(t_s)_{avg}$	178	°F			**Stack Static Pressure**	(P_{static})	-0.96	in H_2O
Average Meter Temp	$(t_m)_{avg}$	75	°F			**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.45	in H_2O
		Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**
		(g)	(g)	(g)	(g)				
Contents		Dry	Dry	DI Water	Sil Gel				
Final Value	(V_f),(W_f)	544.30	586.70	729.00	901.30				
Initial Value	(V_i),(W_i)	363.80	584.40	722.80	875.40				
Net Value	(V_n),(W_n)	180.5	2.3	6.2	25.9				
Results									
Total Weight	(W_t)	214.90	g			**Water Vol Weighed**	$(V_{wsg(std)})$	10.133	scf
Std Meter Volume	$(V_{m(std)})$	91.239	dscf			**Sat. Moisture Content**	$(B_{ws(svp)})$	48.13	%
Calc Moisture Content	$(B_{ws(calc)})$	10.00	%			**Final Moisture Content**	(B_{ws})	10.00	%

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Date	04/16/20
Operator	Rob White
Run Number	PM U-00003 Base+DB-1

Filter #
19031829
PM U-00003 Base+DB-1-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7720	5266/10
Average Stack Temp	(t_s)	182.3	°F
Average Meter Temp	(t_m)	80.3	
Orifice Meter Coefficient	($\Delta H@$)	1.846	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.18	in H_2O
Stack Moisture Content	(B_{ws})	9.49	%
Stack Dry Molecular Weight	(M_d)	29.29	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.40	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec (≥60)
Pitot	**Pre (+)**	0.00	in H_2O	3.6	in H_2O for	15.0	sec (≥15)
PASS	**Pre (-)**	0.00	in H_2O	4.0	in H_2O for	15.0	sec (≥15)
	Post (+)	0.00	in H_2O	3.9	in H_2O for	15.0	sec (≥15)
	Post (-)	0.00	in H_2O	4.3	in H_2O for	15.0	sec (≥15)

Sampling Equipment			
Meter Box Number	Samp-cp-0033		
Meter Cal Factor	(Y)	0.978	
Nozzle Number	4a		
Average Nozzle Diameter	(D_{na})	0.1570	in
Suggested Nozzle Diameter	(D_n)	0.2098	in
Probe Number	SAMP-HP-0138		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.05	in Hg
Stack Static Pressure	(P_{static})	-0.96	in H_2O
Absolute Stack Pressure	(P_s)	29.98	in Hg
Absolute Meter Pressure	(P_m)	30.19	in Hg

Nozzle Measurements			**ID: 4a**	
Pre	0.156	0.157	0.158	**PASS**
Post	0.156	0.157	0.158	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	12:23	**End**	16:49

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	363.9	586.9	722.8	856.0				
Post	529.7	587.0	728.5	884.6				

Wash Volumes				ml
				ml

Identification Nos.		Samp-cp-0033	Samp-cp-0033	Samp-cp-0033			SAMP-HP-0138	SAMP-HP-0138	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0033		Samp-cp-0033					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH ($\Delta H_@$)**	**Actual Orifice ΔH ($\Delta H_@$)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	558.350	1.30	0.449	0.45	181	254	255	55	56	68	75	75	6.0	1.14	65.50	7.754	99.5	95.993
A-2	19.8	00:19:45	566.340	1.40	0.449	0.45	181	252	256	57	60	69	78	78	6.0	1.18	67.97	15.571	96.3	94.586
A-3	40.3	00:40:15	574.440	1.30	0.449	0.45	183	255	253	60	62	72	81	81	6.0	1.14	65.60	23.575	98.6	96.068
B-1	60.0	01:00:00	582.780	1.50	0.449	0.45	182	243	245	61	63	74	82	82	6.0	1.22	70.41	31.765	96.6	95.589
B-2	81.3	01:21:15	591.330	1.40	0.449	0.45	180	242	244	62	65	75	83	83	6.0	1.18	67.92	39.950	96.8	95.998
B-3	101.8	01:41:45	599.890	1.30	0.449	0.45	181	245	246	63	66	76	85	85	6.0	1.14	65.50	47.457	96.7	95.500
C-1	121.5	02:01:30	607.770	1.50	0.449	0.45	183	246	257	64	67	77	84	84	6.0	1.22	70.47	55.837	96.2	95.636
C-2	142.8	02:22:45	616.550	1.40	0.449	0.45	182	247	254	60	62	73	80	80	6.0	1.18	68.02	62.788	94.7	94.038
C-3	163.3	02:43:15	623.780	1.30	0.449	0.45	183	245	255	62	63	73	81	81	6.0	1.14	65.60	69.074	93.5	92.288
D-1	183.0	03:03:00	630.330	1.50	0.449	0.45	185	245	254	63	65	74	79	79	6.0	1.22	70.58	76.684	92.6	91.795
D-2	204.3	03:24:15	638.230	1.30	0.449	0.45	183	254	255	64	66	76	78	78	6.0	1.14	65.60	82.928	91.7	90.517
D-3	224.0	03:44:00	644.700	1.40	0.449	0.45	184	255	256	66	68	78	78	78	6.0	1.18	68.13	89.973	91.1	89.973
Last Pt	244.5	04:04:30	652.000																	
Final Val	244.5	04:04:30	652.000											**Max Vac**	6.0	**Final Values**		89.973	91.1	
Average Values				1.38		0.45	182	249	253	61	64	74	80	80		1.18	67.61			
													80							

Actual Actual Nozzle Diameter (D_{na})	**DP to DP to DH Iso Factor (K)**	**Point-by-point Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.157	0.40	7.754	99.5	771.8
0.157	0.40	7.817	93.2	728.2
0.157	0.40	8.004	102.9	823.6
0.157	0.40	8.190	91.0	745.6
0.157	0.40	8.185	97.5	797.7
0.157	0.40	7.507	96.4	723.4
0.157	0.40	8.380	93.2	781.1
0.157	0.40	6.951	82.9	576.3
0.157	0.40	6.286	80.8	508.0
0.157	0.40	7.610	84.8	645.2
0.157	0.40	6.244	80.3	501.2
0.157	0.40	7.045	84.2	592.8
0.157	0.40	89.973		

RM 201A Calculations

Trav. Point Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point First Point Dwell Times Prelim. Trav. (t_1)**	**First Point First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
19.75	19.68	1.30		1.30	0
20.50	20.42	1.40	20.42	1.40	0
19.75	19.68	1.30	19.68	1.30	0
21.25	21.14	1.50		1.50	0
20.50	20.42	1.40	20.42	1.40	0
19.75	19.68	1.30	19.68	1.30	0
21.25	21.14	1.50		1.50	0
20.50	20.42	1.40	20.42	1.40	0
19.75	19.68	1.30	19.68	1.30	0
21.25	21.14	1.50		1.50	0
19.75	19.68	1.30	19.68	1.30	0
20.50	20.42	1.40	20.42	1.40	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	198.41	μP
	Cyclone Flow Rate (Q_a)	0.49	ft³/min
	Dia. of 50% Prob. (D_{50}) CI	10.36	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{re}<3162)	10.28	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.64	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.48	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.28	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}<3162)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2831.81	
	Actual Particle Cut Diameter for CI	10.36	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}<3162)	2.29	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.28	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	91.09	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.157	in
	Δp_{min}	0.559	in H_2O
	Δp_{max}	1.670	in H_2O

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Date	04/17/20
Operator	Rob White
Run Number	PM U-00003 Base+DB-2

Filter #
19031826
PM U-00003 Base+DB-2-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7720	5266/10
Average Stack Temp	(t_s)	177.2	°F
Average Meter Temp	(t_m)	69.8	
Orifice Meter Coefficient	($\Delta H@$)	1.846	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.18	in H_2O
Stack Moisture Content	(B_{ws})	9.88	%
Stack Dry Molecular Weight	(M_d)	29.29	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.37	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.40	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft^3/min@	15.0	in Hg for	60.0	sec ≥60]
PASS	**Post**	0.000	ft^3/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**	0.000	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
PASS	**Pre (-)**	0.000	in H_2O	4.0	in H_2O for	15.0	sec [≥15]
	Post (+)	0.000	in H_2O	3.7	in H_2O for	15.0	sec [≥15]
	Post (-)	0.000	in H_2O	4.3	in H_2O for	15.0	sec [≥15]

Sampling Equipment			
Meter Box Number	Samp-cp-0033		
Meter Cal Factor	(Y)	0.978	
Nozzle Number	4a		
Average Nozzle Diameter	(D_{ns})	0.1570	in
Suggested Nozzle Diameter	(D_n)	0.1480	in
Probe Number	SAMP-HP-0138		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.21	in Hg
Stack Static Pressure	(P_{static})	-0.96	in H_2O
Absolute Stack Pressure	(P_s)	30.14	in Hg
Absolute Meter Pressure	(P_m)	30.35	in Hg

Nozzle Measurements			**ID: 4a**	
Pre	0.156	0.157	0.158	**PASS**
Post	0.156	0.157	0.158	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	04:15	**End**	08:34

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	379.7	578.8	649.1	963.4				
Post	564.8	578.8	650.0	988.0				

Wash Volumes				ml
				ml

Identification Nos.		Samp-cp-0033	Samp-cp-0033	Samp-cp-0033			SAMP-HP-0138	SAMP-HP-0138	SAMP-BH-0039	SAMP-SBC-0099	8082	1026	Samp-cp-0033		Samp-cp-0033					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft^3	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	657.110	1.30	0.449	0.45	178	251	257	38	40	78	47	47	5.0	1.14	65.22	7.670	98.3	95.533
A-2	19.8	00:19:45	664.560	1.50	0.449	0.45	177	265	258	40	49	76	62	62	5.0	1.22	70.00	16.129	95.9	96.775
A-3	41.0	00:41:00	673.020	1.40	0.449	0.45	177	251	263	43	50	77	64	64	5.0	1.18	67.63	23.959	95.0	95.834
B-1	61.5	01:01:30	680.880	1.30	0.449	0.45	178	253	266	45	51	77	64	64	5.0	1.14	65.22	31.937	96.8	96.697
B-2	81.3	01:21:15	688.890	1.50	0.449	0.45	176	254	254	48	54	78	70	70	6.0	1.22	69.95	40.890	97.3	98.135
B-3	102.5	01:42:30	697.980	1.40	0.449	0.45	175	255	257	49	56	78	74	74	6.0	1.18	67.52	47.849	95.2	95.698
C-1	123.0	02:03:00	705.100	1.50	0.449	0.45	178	247	253	52	57	78	77	77	6.0	1.22	70.06	55.848	94.3	95.242
C-2	144.3	02:24:15	713.330	1.30	0.449	0.45	177	251	253	54	58	78	78	78	6.0	1.14	65.17	62.514	93.3	93.770
C-3	164.0	02:44:00	720.200	1.40	0.449	0.45	178	256	254	55	58	77	76	76	6.0	1.18	67.68	69.301	92.1	92.401
D-1	184.5	03:04:30	727.170	1.50	0.449	0.45	176	249	247	52	61	76	75	75	6.0	1.22	69.95	76.726	91.1	91.735
D-2	205.8	03:25:45	734.780	1.40	0.449	0.45	177	250	250	54	62	78	76	76	6.0	1.18	67.63	83.533	90.3	90.824
D-3	226.3	03:46:15	741.770	1.30	0.449	0.45	179	256	246	53	62	77	74	74	6.0	1.14	65.27	90.599	90.3	90.599
Last Pt	246.0	04:06:00	749.000																	
Final Val	246.0	04:06:00	749.000											**Max Vac**	6.0	**Final Values**		90.599	90.3	
Average Values				1.40		0.45	177	253	255	49	55	77	70	70		1.18	67.61			
													70							

Actual Actual Nozzle Diameter (D_{na})	**DP to DP to DH Iso Factor (K)**	**Point-by-point Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.157	0.40	7.670	98.3	754.1
0.157	0.40	8.459	93.7	793.0
0.157	0.40	7.829	93.1	728.9
0.157	0.40	7.979	102.3	816.0
0.157	0.40	8.952	99.1	887.4
0.157	0.40	6.959	82.6	575.0
0.157	0.40	8.000	88.7	709.7
0.157	0.40	6.665	85.4	569.0
0.157	0.40	6.787	80.8	548.2
0.157	0.40	7.425	82.2	610.4
0.157	0.40	6.807	80.9	550.9
0.157	0.40	7.067	90.7	640.7
0.157	0.40	90.599		

RM 201A Calculations						
Trav. Point Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point First Point Dwell Times Prelim. Trav. (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
19.75	19.68	1.30		1.30	0
21.25	21.14	1.50	21.14	1.50	0
20.50	20.42	1.40	20.42	1.40	0
19.75	19.68	1.30		1.30	0
21.25	21.14	1.50	21.14	1.50	0
20.50	20.42	1.40	20.42	1.40	0
21.25	21.14	1.50		1.50	0
19.75	19.68	1.30	19.68	1.30	0
20.50	20.42	1.40	20.42	1.40	0
21.25	21.14	1.50		1.50	0
20.50	20.42	1.40	20.42	1.40	0
19.75	19.68	1.30	19.68	1.30	0

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

	Stack Gas Viscosity (μs)	196.82	μP
	Cyclone Flow Rate (Q_s)	0.49	ft^3/min
	Dia. of 50% Prob. (D_{50}) CI	10.34	μm
>>	Calculated Cunninham, C	1.08	
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.30	μm
	Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
	Middle of Zone Dia. (D_{50T}) CI	10.65	μm
	Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.47	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.27	μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.49	dscfm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
	Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
	Actual Test Run C (2.5 μm)	1.07	
	Actual Test Run N_{RE}	2862.75	
	Actual Particle Cut Diameter for CI	10.34	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.28	μm
	Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<<	Recalculated Cunninham, C =	1.08	
	Recalculated D_{50-1} for C_{IV} =	2.27	
>>	Z (limits 0.99 to 1.01) =	1.00	
	Isokinetics (I) (80 to 120%) =	90.33	%
	No. Sampling Pts. Outside Δp =	0	
	Sample Nozzle Diameter =	0.157	in
	Δp_{min}	0.559	in H_2O
	Δp_{max}	1.670	in H_2O

Notes:

METHOD 201A (FRONT) AND 202 (BACK) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Date	04/17/20
Operator	Rob White
Run Number	PM U-00003 Base+DB-3

Filter #
18081503
PM U-00003 Base+DB-3-CPM

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)	0.7720	5266/10
Average Stack Temp	(t_s)	177.8	°F
Average Meter Temp	(t_m)	74.5	
Orifice Meter Coefficient	($\Delta H@$)	1.846	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)	1.19	in H_2O
Stack Moisture Content	(B_{ws})	10.00	%
Stack Dry Molecular Weight	(M_d)	29.29	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.37	acfm
ΔP to ΔH Isokinetic Factor	(K)	0.40	

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft^3/min@	15.0	in Hg for	60.0	sec (≥60)
PASS	**Post**	0.000	ft^3/min@	15.0	in Hg for	60.0	sec (≥60)
Pitot	**Pre (+)**	0.00	in H_2O	3.7	in H_2O for	15.0	sec (≥15)
PASS	**Pre (-)**	0.00	in H_2O	4.0	in H_2O for	15.0	sec (≥15)
	Post (+)	0.00	in H_2O	3.6	in H_2O for	15.0	sec (≥15)
	Post (-)	0.00	in H_2O	4.2	in H_2O for	15.0	sec (≥15)

Sampling Equipment			
Meter Box Number	Samp-cp-0033		
Meter Cal Factor	(Y)	0.978	
Nozzle Number	4a		
Average Nozzle Diameter	(D_{ns})	0.1570	in
Suggested Nozzle Diameter	(D_n)	0.1473	in
Probe Number	SAMP-HP-0138		in
Probe Length	120		in
Liner Material	glass		
Sample Case / Oven Number	SAMP-BH-0039		
Impinger Case Number	SAMP-SBC-0099		

Pressures			
Barometric Pressure	(P_b)	30.22	in Hg
Stack Static Pressure	(P_{static})	-0.96	in H_2O
Absolute Stack Pressure	(P_s)	30.15	in Hg
Absolute Meter Pressure	(P_m)	30.36	in Hg

Nozzle Measurements			**ID: 4a**	
Pre	0.156	0.157	0.158	**PASS**
Post	0.156	0.157	0.158	**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	09:35	**End**	14:03

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	363.8	584.4	722.8	875.4				
Post	544.3	586.7	729.0	901.3				

Wash Volumes					
					ml
					ml

Identification Nos.		Samp-cp-0033	Samp-cp-0033	Samp-cp-0033			SAMP-HP-0138	SAMP-HP-0138	SAMP-BH-0039	SAMP-SBC-0099	1048	1018	Samp-cp-0033		Samp-cp-0033					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_a)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (248±25°F)**	**Filter Temp (248±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤85°F)**	**CPM Filter Temp (76.5±8.5°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft^3	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	756.100	1.30	0.449	0.45	175	249	257	55	54	78	65	65	5.0	1.14	65.07	7.966	102.0	99.528
A-2	19.8	00:19:45	764.110	1.50	0.449	0.45	178	254	243	56	60	78	65	65	6.0	1.22	70.07	16.589	98.7	99.837
A-3	41.0	00:41:00	772.780	1.40	0.449	0.45	176	243	245	57	63	77	66	66	6.0	1.18	67.58	24.768	98.2	99.375
B-1	61.5	01:01:30	781.020	1.40	0.449	0.45	177	246	243	59	64	78	70	70	6.0	1.18	67.64	32.610	97.1	98.129
B-2	82.0	01:22:00	788.980	1.50	0.449	0.45	179	254	255	60	63	79	73	73	6.0	1.22	70.12	41.123	96.5	98.277
B-3	103.3	01:43:15	797.670	1.30	0.449	0.45	180	254	242	61	65	77	77	77	6.0	1.14	65.33	47.501	94.6	95.292
C-1	123.0	02:03:00	804.230	1.50	0.449	0.45	179	254	247	64	67	78	78	78	6.0	1.22	70.12	55.673	94.0	95.233
C-2	144.3	02:24:15	812.650	1.40	0.449	0.45	177	257	243	61	63	77	78	78	6.0	1.18	67.64	63.243	93.5	94.721
C-3	164.8	02:44:45	820.450	1.50	0.449	0.45	179	253	245	63	65	78	80	80	6.0	1.22	70.12	70.534	92.3	93.571
D-1	186.0	03:06:00	827.990	1.30	0.449	0.45	178	254	254	62	66	77	80	80	7.0	1.14	65.23	77.089	91.6	92.451
D-2	205.8	03:25:45	834.770	1.50	0.449	0.45	177	251	257	63	67	78	81	81	7.0	1.22	70.01	84.858	91.1	92.241
D-3	227.0	03:47:00	842.820	1.30	0.449	0.45	178	253	256	64	68	78	81	81	7.0	1.14	65.23	91.305	90.5	91.305
Last Pt	246.8	04:06:45	849.500																	
Final Val	246.8	04:06:45	849.500											**Max Vac**	7.0	**Final Values**		91.305	90.5	
Average Values				1.41		0.45	178	252	249	60	64	78	75	75		1.19	67.85			
													75							

Actual Nozzle Diameter (D_{na})	**DP to Actual DP to DH Iso Factor (K)**	**Point-by-point Meter Volume (V_m)$_{std}$**	**Point-by-point Percent IsoKinetic (I)**	**Point Weighted Average Isokinetics**
in		dscf	%	(V_m)$_{std}$ x (I)
0.157	0.40	7.966	102.0	812.2
0.157	0.40	8.623	95.7	825.3
0.157	0.40	8.179	97.3	795.5
0.157	0.40	7.842	93.3	731.8
0.157	0.40	8.513	94.6	805.0
0.157	0.40	6.378	82.0	522.7
0.157	0.40	8.172	90.8	741.8
0.157	0.40	7.570	90.1	681.9
0.157	0.40	7.291	81.0	590.4
0.157	0.40	6.556	84.1	551.3
0.157	0.40	7.769	86.2	669.5
0.157	0.40	6.447	82.7	533.2
0.157	0.40	91.305		

RM 201A Calculations

Trav. Point Estimated Dwell Times (t_1), (t_n)	**First Point Dwell Times (t_1)**	**First Point Vel. Head Current Trav. (Δp_{RM2})**	**Subs. Point Dwell Times Current Trav. (t_n)**	**Velocity Velocity Head Current Trav. (Δp_{201A})**	**Violations**
min	min	in H_2O	min	in H_2O	
19.75	19.68	1.30		1.30	0
21.25	21.14	1.50	21.14	1.50	0
20.50	20.42	1.40	20.42	1.40	0
20.50	20.42	1.40		1.40	0
21.25	21.14	1.50	21.14	1.50	0
19.75	19.68	1.30	19.68	1.30	0
21.25	21.14	1.50		1.50	0
20.50	20.42	1.40	20.42	1.40	0
21.25	21.14	1.50	21.14	1.50	0
19.75	19.68	1.30		1.30	0
21.25	21.14	1.50	21.14	1.50	0
19.75	19.68	1.30	19.68	1.30	0

Stack Gas Viscosity (μs)	196.86	μP
Cyclone Flow Rate (Q_s)	0.49	ft^3/min
Dia. of 50% Prob. (D_{50}) CI	10.30	μm
>> Calculated Cunninham, C	1.08	
Lower Limit Dia. (D_{50LL}) CI (N_{Re}<3162)	10.30	μm
Lower Limit Dia. (D_{50LL}) CI (N_{Re}≥3162)		μm
Middle of Zone Dia. (D_{50T}) CI	10.65	μm
Sampling Rate (PM_{10} and $PM_{2.5}$ Cyc.)	0.47	dscfm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.25	μm
Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}<3162)	0.49	dscfm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
Sampling Rate ($PM_{2.5}$ Cyc., N_{Re}≥3162)		dscfm
Actual Test Run C (2.5 μm)	1.07	
Actual Test Run N_{RE}	2877.55	
Actual Particle Cut Diameter for CI	10.30	μm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}<3162)	2.26	μm
Dia. of 50% Prob. (D_{50}) C_{IV} (N_{Re}≥3162)		μm
<< Recalculated Cunninham, C =	1.08	
Recalculated D_{50-1} for C_{IV} =	2.25	
>> Z (limits 0.99 to 1.01) =	1.00	
Isokinetics (I) (80 to 120%) =	90.47	%
No. Sampling Pts. Outside Δp =	0	
Sample Nozzle Diameter =	0.157	in
Δp_{min}	0.559	in H_2O
Δp_{max}	1.670	in H_2O

Z must be between 0.99 and 1.01, but the initial calculation is based on assumptions of the Cunniham Correction Factor and the Reynolds Number. In cases where your Z value is not between the limits and is producing an error, you need to run a second iteration based on the re-calculated numbers. To do this, copy the value in "Recalculated Cunninham, C =" [BH189] and do a "paste special value only" into "Calculated Cunninham, C =" [BH174]. This sets the initially calculated C equal to the C determined during this test run. At this point the program may recognize the second iteration and your error may go away. If it doesn't it is probably because it is having difficulties deciding between the Reynolds number at the threshold.

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
SAM

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE

Source Information	
Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Fuel Type	Gas, Natural

Test Information			
Project #		bec-19-cricketvalley.ny-start#3	
Operator		GT	
Date for Preliminary Run	(mm/dd/yy)	04/16/20	
Standard Temperature		68	°F
Standard Pressure		29.92	in Hg
Required Sample Vol.	10 L/min	10.6	scf
Run Duration	8a, 2.4.1.3	120	minutes
Unit Number		U-00003	
Base Run Number		SAM U-00003 Base+DB	
Number of Ports Available		4	
Number of Ports Used		1	
Port Inside Diameter		6.00	in
Stack Shape		Circular	

Test Equipment Information					
Run		**1**	**2**	**3**	
Test Date	(mm/dd/yy)	04/16/20	04/17/20	04/17/20	
Load		Base	Base	Base	% or w/DB
Fuel F-Factor		8641.42	8663.09	8663.09	dscf/MMBtu
Meter Box Number	from ACS	samp-cp-0030	samp-cp-0030	samp-cp-0030	
Meter Calibration Factor	(Y)	0.974	0.974	0.974	
Orifice Meter Coefficient	($\Delta H_@$)	1.878	1.878	1.878	in H_2O
Non-Console Manometer Used		No	No	No	
Probe Number	from ACS	SAMP-HP-0138	SAMP-HP-0138	SAMP-HP-0138	
Probe Length		72.0	72.0	72.0	in
(SS, Glass ….) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	samp-bh-0013	samp-bh-0013	samp-bh-0013	
Impinger Case Number	from ACS	samp-bc-0032	samp-bc-0032	samp-bc-0032	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	1600 W Tacoma Street
City, State Zip	Broken Arrow, Oklahoma 74012
Project Manager	Rob White
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131


Created with Isocalc-AHI v20190830

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Cricket Valley Energy Center	**Date**	04/16/20
Sampling Location	U-00003 Base+DB	**Stack Type**	Circular
Operator	GT	**Ports Available**	4
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	1
Stack Size	Large (>24 inch diameter)	**Port ID (inches)**	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in
Distance to Near Wall of Stack	(L_{nw})	8.00	in
Diameter of Stack	(D)	228.00	in
Area of Stack	(A_s)	283.53	ft²

Distance from Port to Disturbances			
Distance Upstream	(A)	200.40	in
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		**Minimum Number of[1] Traverse Points**	
Down Stream	**Up Stream**	**Particulate Points**	**Velocity Points**
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

◉ Method 1 Trav

○ 12 Point PM Trav (M201a ONLY)

○ Velocity

Number of Traverse Points Used			
1	**Ports by**	1	**Across**
1	**Pts Used**	1	**Required**

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point) Number of Traverse Points Across the Stack								
Number	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	**Fraction of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
		in	in
1	0.275	62 6/8	70 6/8
2			
3			
4			
5			
6			
7			
8			
9			

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/16/20		
Sampling Location	U-00003 Base+DB	**Operator**	GT		
Project #	bec-19-cricketvalley.ny-start#3	**# of Ports Used**	1 (gas probe)		
Fuel Type	Gas, Natural	**Min. Fuel Factor**	1.600	**Max. Fuel Factor**	1.836

Gas Analysis Data

Run Number	SAM U-00003 Base+DB-1		**Date**	04/16/20	**Run Start Time**	13:10	**Run Stop Time**	15:10
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.5	12.9	0.0	82.6	29.24	1.778	144.8	YES

Gas Analysis Data

Run Number	SAM U-00003 Base+DB-2		**Date**	04/17/20	**Run Start Time**	03:58	**Run Stop Time**	05:58
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.5	12.9	0.0	82.6	29.24	1.778	144.8	YES

Gas Analysis Data

Run Number	SAM U-00003 Base+DB-3		**Date**	04/17/20	**Run Start Time**	07:00	**Run Stop Time**	09:00
Sample Analysis Time	**CO_2 Conc.**	**O_2 Conc.**	**CO Conc.**	**N_2 Conc.**	**Dry Molecular Weight**	**Calculated Fuel Factor**	**Excess Air**	**Fuel Factor in Range**
	($\%CO_2$)	($\%O_2$)	(ppmCO)	($\%N_2$)	(M_d)	$(F_o)_{avg}$	$(\%EA)_{avg}$	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
02:00	4.5	12.9	0.0	82.6	29.24	1.778	144.8	YES

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Cricket Valley Energy Center	**Preliminary Run Date**	04/16/20
Sampling Location	U-00003 Base+DB	**Operator**	GT
Project #	bec-19-cricketvalley.ny-start#3	**Ports Used**	1

Scale Daily Calibration					
Scale Number	SAMP-SC-0028	**Standard**	**Result**	**Difference**	**Pass/Fail**
Date		(g)	(g)	(g)	(± 0.5 g)
Test Day 2	04/16/20	500	499.7	-0.3	Pass

Moisture Content Data									
Run Number	SAM U-00003 Base+DB-1		**Date**	04/16/20	**Start Time**	13:10	**Stop Time**	15:10	
Meter Box Number	samp-cp-0030				**Meter Cal Factor**	(Y)	0.974		
Total Meter Volume	(V_m)	41.730	dcf		**Barometric Pressure**	(P_b)	30.07	in Hg	
Average Stack Temp	$(t_s)_{avg}$	182	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O	
Average Meter Temp	$(t_m)_{avg}$	63	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.41	in H_2O	
	Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**	
	(g)	(g)	(g)	(g)					
Contents	H_2O_2	H_2O_2	DI Water	Sil Gel					
Final Value (V_f),(W_f)	768.60	695.20	575.90	928.50					
Initial Value (V_i),(W_i)	699.70	688.10	575.40	913.90					
Net Value (V_n),(W_n)	68.9	7.1	0.5	14.6					
Results									
Total Weight	(W_t)	91.10	g		**Water Vol Weighed**	($V_{wsg(std)}$)	4.295	scf	
Std Meter Volume	($V_{m(std)}$)	41.297	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)	53.16	%	
Calc Moisture Content	($B_{ws(calc)}$)	9.42	%		**Final Moisture Content**	(B_{ws})	9.42	%	

Moisture Content Data									
Run Number	SAM U-00003 Base+DB-2		**Date**	04/17/20	**Start Time**	03:58	**Stop Time**	05:58	
Meter Box Number	samp-cp-0030				**Meter Cal Factor**	(Y)	0.974		
Total Meter Volume	(V_m)	41.780	dcf		**Barometric Pressure**	(P_b)	30.22	in Hg	
Average Stack Temp	$(t_s)_{avg}$	182	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O	
Average Meter Temp	$(t_m)_{avg}$	83	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.41	in H_2O	
	Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**	
	(g)	(g)	(g)	(g)					
Contents	H_2O_2	H_2O_2	DI Water	Sil Gel					
Final Value (V_f),(W_f)	774.70	690.40	575.60	938.60					
Initial Value (V_i),(W_i)	697.40	687.50	575.60	928.50					
Net Value (V_n),(W_n)	77.3	2.9	0.0	10.1					
Results									
Total Weight	(W_t)	90.30	g		**Water Vol Weighed**	($V_{wsg(std)}$)	4.258	scf	
Std Meter Volume	($V_{m(std)}$)	40.040	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)	52.90	%	
Calc Moisture Content	($B_{ws(calc)}$)	9.61	%		**Final Moisture Content**	(B_{ws})	9.61	%	

Moisture Content Data									
Run Number	SAM U-00003 Base+DB-3		**Date**	04/17/20	**Start Time**	07:00	**Stop Time**	09:00	
Meter Box Number	samp-cp-0030				**Meter Cal Factor**	(Y)	0.974		
Total Meter Volume	(V_m)	41.790	dcf		**Barometric Pressure**	(P_b)	30.27	in Hg	
Average Stack Temp	$(t_s)_{avg}$	182	°F		**Stack Static Pressure**	(P_{static})	-0.92	in H_2O	
Average Meter Temp	$(t_m)_{avg}$	82	°F		**Avg Orifice Pressure**	$(\Delta H)_{avg}$	0.41	in H_2O	
	Impinger 1	**Impinger 2**	**Impinger 3**	**Impinger 4**	**Impinger 5**	**Impinger 6**	**Impinger 7**	**Impinger 8**	
	(g)	(g)	(g)	(g)					
Contents	H_2O_2	H_2O_2	DI Water	Sil Gel					
Final Value (V_f),(W_f)	853.70	691.20	575.60	929.60					
Initial Value (V_i),(W_i)	774.70	690.40	575.60	921.80					
Net Value (V_n),(W_n)	79.0	0.8	0.0	7.8					
Results									
Total Weight	(W_t)	87.60	g		**Water Vol Weighed**	($V_{wsg(std)}$)	4.130	scf	
Std Meter Volume	($V_{m(std)}$)	40.144	dscf		**Sat. Moisture Content**	($B_{ws(svp)}$)	52.81	%	
Calc Moisture Content	($B_{ws(calc)}$)	9.33	%		**Final Moisture Content**	(B_{ws})	9.33	%	

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Date	04/16/20
Operator	GT
Run Number	SAM U-00003 Base+DB-1

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)	182.0	°F
Average Meter Temp	(t_m)	62.8	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})	9.42	%
Stack Dry Molecular Weight	(M_d)	29.24	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.75	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-HP-0138		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0013		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.07	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	30.00	in Hg
Absolute Meter Pressure	(P_m)	30.21	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	13:10	**End**	15:10

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	699.7	688.1	575.4	913.9				
Post	768.6	695.2	575.9	928.5				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0030	samp-cp-0030	samp-cp-0030			SAMP-HP-0138	SAMP-HP-0138	samp-bh-0013	samp-bc-0032	TCSAM1		samp-cp-0030		samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	961.540	--	0.411	0.41	--	350	501	61	65	--	58	58	1.0			1.708		40.990
A-2	5.0	00:05:00	963.250	--	0.411	0.41	--	350	504	61	70	--	58	58	1.0			3.426		41.110
A-3	10.0	00:10:00	964.970	--	0.411	0.41	--	350	510	59	82	--	59	59	1.0			5.180		41.442
A-4	15.0	00:15:00	966.730	--	0.411	0.41	--	350	517	56	80	--	59	59	1.0			6.885		41.309
A-5	20.0	00:20:00	968.440	--	0.411	0.41	--	350	520	58	74	--	60	60	1.0			8.452		40.569
A-6	25.0	00:25:00	970.015	--	0.411	0.41	--	350	522	60	77	--	60	60	1.0			10.327		41.310
A-7	30.0	00:30:00	971.900	--	0.411	0.41	--	350	519	60	76	--	61	61	1.0			12.035		41.264
A-8	35.0	00:35:00	973.620	--	0.411	0.41	--	350	525	62	79	--	62	62	1.0			13.760		41.280
A-9	40.0	00:40:00	975.360	--	0.411	0.41	--	350	530	60	77	--	62	62	1.0			15.455		41.213
A-10	45.0	00:45:00	977.070	--	0.411	0.41	--	350	528	55	72	--	62	62	1.0			17.160		41.183
A-11	50.0	00:50:00	978.790	--	0.411	0.41	--	350	527	59	74	--	63	63	1.0			18.891		41.216
A-12	55.0	00:55:00	980.540	--	0.411	0.41	--	350	524	59	75	--	63	63	1.0			20.632		41.263
A-13	60.0	01:00:00	982.300	--	0.411	0.41	--	350	526	60	76	--	64	64	1.0			22.360		41.279
A-14	65.0	01:05:00	984.050	--	0.411	0.41	--	350	520	59	76	--	64	64	1.0			24.078		41.276
A-15	70.0	01:10:00	985.790	--	0.411	0.41	--	350	518	57	77	--	64	64	1.0			25.805		41.289
A-16	75.0	01:15:00	987.540	--	0.411	0.41	--	350	522	62	79	--	64	64	1.0			27.533		41.300
A-17	80.0	01:20:00	989.290	--	0.411	0.41	--	350	522	59	77	--	65	65	1.0			29.268		41.319
A-18	85.0	01:25:00	991.050	--	0.411	0.41	--	350	523	60	76	--	65	65	1.0			30.982		41.310
A-19	90.0	01:30:00	992.790	--	0.411	0.41	--	350	524	63	77	--	65	65	1.0			32.707		41.314
A-20	95.0	01:35:00	994.540	--	0.411	0.41	--	350	521	62	77	--	65	65	1.0			34.412		41.294
A-21	100.0	01:40:00	996.270	--	0.411	0.41	--	350	519	60	77	--	65	65	1.0			36.196		41.366
A-22	105.0	01:45:00	998.080	--	0.411	0.41	--	350	517	53	68	--	66	66	1.0			37.877		41.321
A-23	110.0	01:50:00	999.790	--	0.411	0.41	--	350	523	60	71	--	66	66	1.0			39.579		41.300
A-24	115.0	01:55:00	1001.520	--	0.411	0.41	--	350	528	64	76	--	67	67	1.0			41.297		41.297
Last Pt	120.0	02:00:00	1003.270																	
Final Val	120.0	02:00:00	1003.270											**Max Vac**	1.0	**Final Values**		41.297		
Average Values						0.41	182	350	520	60	75		63	63						
													63							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Date	04/17/20
Operator	GT
Run Number	SAM U-00003 Base+DB-2

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)	182.0	°F
Average Meter Temp	(t_m)	82.5	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})	9.61	%
Stack Dry Molecular Weight	(M_d)	29.24	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.34	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-HP-0138		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0013		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.22	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	30.15	in Hg
Absolute Meter Pressure	(P_m)	30.36	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	03:58	**End**	05:58

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	697.4	687.5	575.6	928.5				
Post	774.7	690.4	575.6	938.6				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0030	samp-cp-0030	samp-cp-0030			SAMP-HP-0138	SAMP-HP-0138	samp-bh-0013	samp-bc-0032	TCSAM1		samp-cp-0030		samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	11.320	--	0.411	0.41	--	350	501	40	44	--	78	78	3.0			1.691		40.591
A-2	5.0	00:05:00	13.070	--	0.411	0.41	--	350	505	39	56	--	78	78	3.0			3.363		40.359
A-3	10.0	00:10:00	14.800	--	0.411	0.41	--	350	512	41	67	--	78	78	3.0			5.045		40.359
A-4	15.0	00:15:00	16.540	--	0.411	0.41	--	350	518	45	76	--	79	79	3.0			6.743		40.456
A-5	20.0	00:20:00	18.300	--	0.411	0.41	--	350	521	47	85	--	79	79	3.0			8.460		40.607
A-6	25.0	00:25:00	20.080	--	0.411	0.41	--	350	524	49	90	--	80	80	3.0			10.154		40.617
A-7	30.0	00:30:00	21.840	--	0.411	0.41	--	350	528	47	91	--	81	81	3.0			11.846		40.614
A-8	35.0	00:35:00	23.600	--	0.411	0.41	--	350	530	50	93	--	81	81	3.0			13.547		40.641
A-9	40.0	00:40:00	25.370	--	0.411	0.41	--	350	527	48	92	--	82	82	3.0			15.283		40.756
A-10	45.0	00:45:00	27.180	--	0.411	0.41	--	350	526	43	86	--	82	82	3.0			17.020		40.847
A-11	50.0	00:50:00	28.990	--	0.411	0.41	--	350	521	40	83	--	83	83	3.0			18.762		40.936
A-12	55.0	00:55:00	30.810	--	0.411	0.41	--	350	522	39	81	--	83	83	3.0			20.496		40.991
A-13	60.0	01:00:00	32.620	--	0.411	0.41	--	350	519	39	81	--	83	83	3.0			22.229		41.038
A-14	65.0	01:05:00	34.430	--	0.411	0.41	--	350	524	43	84	--	84	84	3.0			23.940		41.039
A-15	70.0	01:10:00	36.220	--	0.411	0.41	--	350	529	45	86	--	84	84	3.0			25.650		41.041
A-16	75.0	01:15:00	38.010	--	0.411	0.41	--	350	525	46	87	--	84	84	3.0			27.352		41.028
A-17	80.0	01:20:00	39.790	--	0.411	0.41	--	350	518	49	89	--	85	85	3.0			29.050		41.012
A-18	85.0	01:25:00	41.570	--	0.411	0.41	--	350	523	52	93	--	85	85	3.0			30.748		40.997
A-19	90.0	01:30:00	43.350	--	0.411	0.41	--	350	527	55	95	--	85	85	3.0			32.465		41.009
A-20	95.0	01:35:00	45.150	--	0.411	0.41	--	350	530	57	97	--	85	85	3.0			34.183		41.019
A-21	100.0	01:40:00	46.950	--	0.411	0.41	--	350	528	58	99	--	85	85	3.0			35.881		41.007
A-22	105.0	01:45:00	48.730	--	0.411	0.41	--	350	525	58	99	--	85	85	3.0			37.608		41.026
A-23	110.0	01:50:00	50.540	--	0.411	0.41	--	350	526	58	101	--	86	86	3.0			39.322		41.031
A-24	115.0	01:55:00	52.340	--	0.411	0.41	--	350	525	57	103	--	86	86	3.0			40.045		40.045
Last Pt	120.0	02:00:00	53.100																	
Final Val	120.0	02:00:00	53.100											**Max Vac**	3.0	**Final Values**		40.045		
Average Values						0.41	182	350	522	48	86		83	83						
													83							

Notes:

METHOD 8A (CONTROLLED CONDENSATE) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Date	04/17/20
Operator	GT
Run Number	SAM U-00003 Base+DB-3

Filter #
R0001

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient / ID	(C_p)		
Average Stack Temp	(t_s)	182.0	°F
Average Meter Temp	(t_m)	82.2	
Orifice Meter Coefficient	($\Delta H@$)	1.878	in H_2O
Square Root ΔP	($\Delta p^{1/2}_{avg}$)		in H_2O
Stack Moisture Content	(B_{ws})	9.33	%
Stack Dry Molecular Weight	(M_d)	29.24	lb/lb-mole
Estimated Orifice Flow Rate	(Q_m)	0.33	acfm
ΔP to ΔH Isokinetic Factor	(K)		

Leak Checks		*[change]*		*[level]*		*[time]*	
Train	**Pre**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
PASS	**Post**	0.000	ft³/min@	15.0	in Hg for	60.0	sec [≥60]
Pitot	**Pre (+)**		in H_2O		in H_2O for		sec [≥15]
	Pre (-)		in H_2O		in H_2O for		sec [≥15]
	Post (+)		in H_2O		in H_2O for		sec [≥15]
	Post (-)		in H_2O		in H_2O for		sec [≥15]

Sampling Equipment			
Meter Box Number	samp-cp-0030		
Meter Cal Factor	(Y)	0.974	
Nozzle Number	NA		
Average Nozzle Diameter	(D_{na})		in
Suggested Nozzle Diameter	(D_{ni})		in
Probe Number	SAMP-HP-0138		in
Probe Length	72		in
Liner Material	glass		
Sample Case / Oven Number	samp-bh-0013		
Impinger Case Number	samp-bc-0032		

Pressures			
Barometric Pressure	(P_b)	30.27	in Hg
Stack Static Pressure	(P_{static})	-0.92	in H_2O
Absolute Stack Pressure	(P_s)	30.20	in Hg
Absolute Meter Pressure	(P_m)	30.41	in Hg

Nozzle Measurements			**ID: NA**
Pre			**PASS**
Post			**PASS**

Barometer ID
SAMP-WE-0014
Scale ID
SAMP-SC-0028

Run Time			
Start	07:00	**End**	09:00

Weights	**Imp 1**	**Imp 2**	**Imp 3**	**Imp 4**	**Imp 5**	**Imp 6**	**Imp 7**	**Imp 8**
Pre	774.7	690.4	575.6	921.8				
Post	853.7	691.2	575.6	929.6				

Wash Volumes					
					ml
					ml

Identification Nos.		samp-cp-0030	samp-cp-0030	samp-cp-0030			SAMP-HP-0138	SAMP-HP-0138	samp-bh-0013	samp-bc-0032	TCSAM1		samp-cp-0030		samp-cp-0030					
Traverse Point #	**Sampling Time (Θ)**	**Timer Time**	**Dry Gas Meter Reading (V_m)**	**Velocity Head (Δp)**	**Desired Orifice ΔH (ΔH_d)**	**Actual Orifice ΔH (ΔH_a)**	**Stack Temp (t_s)**	**Probe Temp (375±25°F)**	**Filter Temp (525±25°F)**	**Impinger Exit Temp (≤68°F)**	**Cond. Temp (≤185°F)**	**CPM Filter Temp (--±--°F)**	**Meter Inlet Temp (t_{mi})**	**Meter Outlet Temp (t_{mo})**	**Pump Vacuum**	**Square Root ΔP ($\Delta p^{1/2}$)**	**Local Stack Velocity (v_s)$_l$**	**Cumul. Meter Volume (V_m)$_{std}$**	**Cumul. Percent IsoKinetic (I)**	**Est-Run Meter Volume (V_m)$_{std}$**
	min	hh:mm:ss	ft³	in H_2O	in H_2O	in H_2O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H_2O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	61.770	--	0.411	0.41	--	350	502	45	54	--	80	80	3.0			1.697		40.739
A-2	5.0	00:05:00	63.530	--	0.411	0.41	--	350	506	42	59	--	80	80	3.0			3.395		40.739
A-3	10.0	00:10:00	65.290	--	0.411	0.41	--	350	511	39	66	--	80	80	3.0			5.102		40.816
A-4	15.0	00:15:00	67.060	--	0.411	0.41	--	350	515	38	68	--	80	80	3.0			6.790		40.739
A-5	20.0	00:20:00	68.810	--	0.411	0.41	--	350	519	37	69	--	80	80	3.0			8.516		40.877
A-6	25.0	00:25:00	70.600	--	0.411	0.41	--	350	522	37	70	--	81	81	3.0			10.220		40.880
A-7	30.0	00:30:00	72.370	--	0.411	0.41	--	350	524	38	71	.	81	81	3.0			11.924		40.882
A-8	35.0	00:35:00	74.140	--	0.411	0.41	--	350	526	38	71	--	81	81	3.0			13.618		40.855
A-9	40.0	00:40:00	75.900	--	0.411	0.41	--	350	525	38	74	--	82	82	3.0			15.329		40.877
A-10	45.0	00:45:00	77.680	--	0.411	0.41	--	350	527	37	73	--	82	82	3.0			17.049		40.917
A-11	50.0	00:50:00	79.470	--	0.411	0.41	--	350	530	36	72	--	82	82	3.0			18.740		40.887
A-12	55.0	00:55:00	81.230	--	0.411	0.41	--	350	529	37	72	--	82	82	3.0			20.460		40.920
A-13	60.0	01:00:00	83.020	--	0.411	0.41	--	350	526	38	73	--	83	83	3.0			22.167		40.924
A-14	65.0	01:05:00	84.800	--	0.411	0.41	--	350	530	39	74	--	83	83	3.0			23.874		40.928
A-15	70.0	01:10:00	86.580	--	0.411	0.41	--	350	532	40	76	--	83	83	3.0			25.610		40.977
A-16	75.0	01:15:00	88.390	--	0.411	0.41	--	350	527	40	76	--	83	83	3.0			27.346		41.020
A-17	80.0	01:20:00	90.200	--	0.411	0.41	--	350	524	41	77	--	83	83	3.0			29.073		41.044
A-18	85.0	01:25:00	92.000	--	0.411	0.41	--	350	525	41	78	--	83	83	3.0			30.790		41.053
A-19	90.0	01:30:00	93.790	--	0.411	0.41	--	350	521	41	76	--	83	83	3.0			32.516		41.073
A-20	95.0	01:35:00	95.590	--	0.411	0.41	--	350	519	42	76	--	84	84	3.0			34.230		41.076
A-21	100.0	01:40:00	97.380	--	0.411	0.41	--	350	526	41	75	--	84	84	3.0			35.953		41.089
A-22	105.0	01:45:00	99.180	--	0.411	0.41	--	350	529	42	75	--	84	84	3.0			37.676		41.101
A-23	110.0	01:50:00	100.980	--	0.411	0.41	--	350	524	42	75	--	84	84	3.0			39.380		41.093
A-24	115.0	01:55:00	102.760	--	0.411	0.41	--	350	528	42	75	--	84	84	3.0			40.146		40.146
Last Pt	120.0	02:00:00	103.560																	
Final Val	120.0	02:00:00	103.560											**Max Vac**	3.0	**Final Values**		40.146		
Average Values						0.41	182	350	523	40	72		82	82						
													82							

Notes:

EMISSION DATA RECORDS

Reference Method Data
Base+DB Load
Opacity

Method Used (Circle One)
Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 1 of 6

Continued on Form Number (AHI Project Code)

Company Name: A-C Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Observation Date | Time Zone | Start Time: 10:00 am | End Time: 10:30

Process | Unit # 3 | Operating Mode
Control Equipment | Operating Mode: Duct B

Describe Emissions Pont


Height of Emiss. Pt. Start 141 End 141 | Height of Emiss. Pt. Rel. to Observer Start 137 End 137
Distance to Emiss. Pt. Start 7 End 7 | Direction to Emiss. Pt. (Degrees) Start 5 End 5

Vetical Angle to Obs. Pt. Start 13 End 13 | Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 142 End 142

Describe Emissions Start NA End NA
Emission Color Start NA End NA | Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Blue End Blue | Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 12 End 12 | Wind Direction Start S End S
Ambient Temp. Start End | Wet Bulb Temp. | RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 4/10/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

Additional Information

Method Used (Circle One)
Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 2 of 6

Continued on Form Number (AHI Project Code)

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process Unit # 3 Operating Mode
Control Equipment Operating Mode DB

Describe Emissions Pont


Height of Emiss. Pt. Start 140 End 146
Height of Emiss. Pt. Rel. to Observer Start End
Distance to Emiss. Pt. Start 8 End 8
Direction to Emiss. Pt. (Degrees) Start 5 End 5

Vetical Angle to Obs. Pt. Start 12 End 12
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 143 End 143

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Blue End Blue
Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 11 End 11
Wind Direction Start S End S
Ambient Temp. Start End
Wet Bulb Temp.
RH Percent

Source Layout Sketch



Latitude Longitude Declination

Observation Date	Time Zone	Start Time	End Time
		10:30	11:00

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 4/1/2020
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

Additional Information

Method Used (Circle One)
Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 3 of 6

Continued on Form Number (AHI Project Code)

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Observation Date | Time Zone | Start Time: 11:00 | End Time: 11:30

Process | Unit #: 3 | Operating Mode
Control Equipment | Operating Mode: DB

Describe Emissions Pont


Height of Emiss. Pt. Start 140 End 140
Height of Emiss. Pt. Rel. to Observer Start 150 End 150
Distance to Emiss. Pt. Start 6 End 6
Direction to Emiss. Pt. (Degrees) Start 5 End 5

Vetical Angle to Obs. Pt. Start 14 End 14
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 144 End 144

Describe Emissions
Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background
Start End
Background Color Start Blue End Blue
Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 11 End 11
Wind Direction Start S End S
Ambient Temp. Start End
Wet Bulb Temp. RH Percent

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 4/17/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 4 of 6

Continued on Form Number (AHI Project Code)

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process Unit # 3 Operating Mode
Control Equipment Operating Mode DB

Describe Emissions Pont


Height of Emiss. Pt. Start 142 End 142
Height of Emiss. Pt. Rel. to Observer Start 148 End 148
Distance to Emiss. Pt. Start 7 End 7
Direction to Emiss. Pt. (Degrees) Start S End S

Vetical Angle to Obs. Pt. Start 10 End 10
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 141 End 141

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Blue End Blue
Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 9 End 9
Wind Direction Start S End S
Ambient Temp. Start End
Wet Bulb Temp.
RH Percent

Source Layout Sketch



Latitude Longitude Declination

Min \ Sec	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observation Date Time Zone Start Time 11:30 End Time 12:00pm

Observer's Name (Print) SEAN FIELDS
Observer's Signature Date 4/10/20
Organization Air Hygiene International, Inc.
Certified By Comp Assurance Assoc Date 01/03/2020

Additional Information

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: AIC Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process Unit # 3 Operating Mode
Control Equipment Operating Mode DB

Describe Emissions Pont


Height of Emiss. Pt. Start 137 End 137
Height of Emiss. Pt. Rel. to Observer Start 140 End 140
Distance to Emiss. Pt. Start 5 End 5
Direction to Emiss. Pt. (Degrees) Start 5 End 5

Vetical Angle to Obs. Pt. Start 12 End 12
Direction to Obs. Pt. (Degrees) Start End
Distance and Direction to Observation Point from Emission Point Start 146 End 146

Describe Emissions Start NA End NA
Emission Color Start NA End NA
Water Droplet Plume Start NA End NA

Describe Plume Background Start End
Background Color Start Blue End Blue
Sky Conditions Start Cloudy End Cloudy
Wind Speed Start 5 End 5
Wind Direction Start 5 End 5
Ambient Temp. Start End
Wet Bulb Temp.
RH Percent

Source Layout Sketch



Latitude Longitude Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 5 of 6
Continued on Form Number (AHI Project Code)
Observation Date Time Zone Start Time 12:00 PM End Time 12:30

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print) SEAN FIELDS
Observer's Signature Date 1/3/20
Organization Air Hygiene International, Inc.
Certified By Comp Assurance Assoc Date 01/03/2020

Method Used (Circle One)
Method 9 203A 203B Other: _____

Company Name: Air Hygiene
Facility Name: Cricket Valley Energy Plant
Street Address: 1600 W Tacoma St
City: Broken Arrow State: OK Zip: 74012

Process: Unit # 3 Operating Mode:
Control Equipment: Operating Mode: DB

Describe Emissions Pont

Height of Emiss. Pt.		Height of Emiss. Pt. Rel. to Observer	
Start 139	End 139	Start 145	End 145
Distance to Emiss. Pt.		Direction to Emiss. Pt. (Degrees)	
Start 8	End 8	Start 5	End 5

Vetical Angle to Obs. Pt.		Direction to Obs. Pt. (Degrees)	
Start 142	End 142	Start	End
Distance and Direction to Observation Point from Emission Point			
Start 149		End 149	


Describe Emissions
Start NA End NA

Emission Color		Water Droplet Plume	
Start NA	End NA	Start NA	End NA

Describe Plume Background
Start End

Background Color		Sky Conditions	
Start Blue	End Blue	Start cloudy	End Cloudy
Wind Speed		Wind Direction	
Start 12	End 12	Start 5	End 5
Ambient Temp.		Wet Bulb Temp.	RH Percent
Start	End		

Source Layout Sketch



Latitude | Longitude | Declination

Additional Information

VISUAL EMISSIONS OBSERVATION FORM

Form Number (AHI Project Code) Page 6 of 6
Continued on Form Number (AHI Project Code)

Observation Date	Time Zone	Start Time	End Time
		12:50 pm	1:00

Min. \ Sec.	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Observer's Name (Print): SEAN FIELDS
Observer's Signature: [signature] Date: 11/12/20
Organization: Air Hygiene International, Inc.
Certified By: Comp Assurance Assoc Date: 01/03/2020

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

CERTIFICATE OF ANALYSIS
(Zero Ambient Nitrogen)

Cylinder Number:	EB0058639	**Certification Date:**	02/25/2020
Product ID Number:	121026	**Expiration Date:**	02/23/2028
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0058639.20200225-0	**Lot Number:**	EB0058639.20200225
Customer PO. NO.:		**Tracking Number:**	074332593
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
PGVP Vendor ID # G12020
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

Anthony Cyr
Assistant Operations Manager

Version 02-B, Revised on 2015-05-27

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC722643	**Certification Date**:	11/26/2018
Product ID Number:	124605	**Expiration Date:**	11/24/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC722643.20181121-0	**Lot Number:**	CC722643.20181121
Customer PO. NO.:		**Tracking Number:**	098499928
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**18.9 %**	±0.10 %	NDIR	11/26/2018
Oxygen	**20.9 %**	±0.11 %	MPA	11/26/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0005996	EB0005996.20170209	05/09/2026	GMIS	N2	O2	20 %	0.077	071001
EB0032246	EB0032246.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0097768	EB0097768.20171018	02/06/2026	GMIS	N2	CO2	24.8 %	0.398	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	11/06/2018
CO2	NDIR	Thermo	410i	1162980025	11/26/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12020

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC716390	**Certification Date**:	02/25/2020
Product ID Number:	124606	**Expiration Date:**	02/23/2028
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC716390.20200220-0	**Lot Number:**	CC716390.20200220
Customer PO. NO.:		**Tracking Number:**	098496532
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.91 %**	±0.03 %	NDIR	02/25/2020
Oxygen	**11.98 %**	±0.07 %	MPA	02/24/2020
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0007908	EB0007908.20190327	06/18/2027	GMIS	N2	CO2	9.5 %	0.191	C1579010.02
EB0080793	EB0080793.20180118	07/21/2026	GMIS	N2	O2	11.97 %	0.507	071001
EB0087693	EB0087693.20180504	07/21/2026	GMIS	N2	O2	24 %	0.497	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	02/11/2020
CO2	NDIR	Thermo	410i	1162980025	02/25/2020

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0040961	**Certification Date**:	10/31/2019
Product ID Number:	124737	**Expiration Date:**	10/30/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0040961.20191017-0	**Lot Number:**	EB0040961.20191017
Customer PO. NO.:		**Tracking Number:**	065159907
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**9.1 PPM**	±0.12 PPM	FTIR	10/30/2019
Nitric Oxide	**8.8 PPM**	±0.10 PPM	Chemiluminescence	10/23/2019, 10/31/2019
Total Oxides of Nitrogen	8.9 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM005307	ALM0053007.20181025	10/09/2022	GMIS	N2	NO	34.2 PPM	1.062	1684B
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002
EB0089797	EB0089797.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.085	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	10/18/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/30/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC727541	**Certification Date**:	09/04/2019
Product ID Number:	125564	**Expiration Date:**	09/03/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC727541.20190821-0	**Lot Number:**	CC727541.20190821
Customer PO. NO.:		**Tracking Number:**	098853162
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**5.22 PPM**	±0.07 PPM	FTIR	08/27/2019
Nitric Oxide	**4.51 PPM**	±0.06 PPM	Chemiluminescence	08/27/2019, 09/04/2019
Total Oxides of Nitrogen	4.55 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM047128	ALM047128.20171116	11/08/2022	GMIS	N2	NO	9.7 PPM	1.06	12100115
CC238352	CC238352.20180209	07/18/2022	GMIS	N2	NO	5.68 PPM	1.131	12100115
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	08/09/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	08/26/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0075711	**Certification Date:**	05/09/2019
Product ID Number:	126123	**Expiration Date:**	05/07/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0075711.20190429-0	**Lot Number:**	EB0075711.20190429
Customer PO. NO.:		**Tracking Number:**	084269029
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**8.78 PPM**	±0.07 PPM	FTIR	05/09/2019
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	05/09/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12020

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0078043	**Certification Date:**	02/25/2020
Product ID Number:	124609	**Expiration Date:**	02/23/2028
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0078043.20200220-0	**Lot Number:**	EB0078043.20200220
Customer PO. NO.:		**Tracking Number:**	084268978
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**5.19 PPM**	±0.03 PPM	FTIR	02/25/2020
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0058163	EB0058163.201411231g	03/17/2023	GMIS	N2	CH4	30.38 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	02/25/2020

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0065886	**Certification Date**:	09/27/2018
Product ID Number:	125892	**Expiration Date:**	09/25/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0065886.20180918-0	**Lot Number:**	EB0065886.20180918
Customer PO. NO.:		**Tracking Number:**	083031632
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Methane	**3.03 PPM**	±0.02 PPM	FTIR	09/27/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0042063	EB0042063.20171231	03/17/2023	GMIS	N2	CH4	30.37 PPM	0.277	2751

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
CH4	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/27/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12020

PJLA Calibration and Testing
Accreditation #62754

CERTIFIED GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0093359	**Certification Date:**	03/26/2020
Product ID Number:	125123	**Expiration Date:**	03/26/2021
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0093359.20200325-0	**Lot Number:**	EB0093359.20200325
Customer PO. NO.:		**Tracking Number:**	095486048
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Ammonia	**48.9 PPM**	± 2% NIST	FTIR
Sulfur Hexafluoride	**9.74 PPM**	± 2% NIST	FTIR
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
SA18481	70086910005	04/12/2020	PS	N2	NH3	21.1 PPM	1.2	73248226
EB0079029	EB0079029	06/27/2020	PS	N2	SF6	10.1 PPM	5	191064

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NH3	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	
SF6	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-G, Revised on 2017-07-02

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0098845	**Certification Date**:	05/03/2019
Product ID Number:	124731	**Expiration Date:**	05/02/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0098845.20190416-0	**Lot Number:**	EB0098845.20190416
Customer PO. NO.:		**Tracking Number:**	095689140
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	**48.7 PPM**	±0.6 PPM	FTIR	04/26/2019, 05/03/2019

Air Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003640	EB0003640.20190102	03/20/2022	GMIS	AIR	NO2	87.8 PPM	1.061	C1579010.01
EB0096848	EB0096848.20190102	03/21/2022	GMIS	AIR	NO2	61.1 PPM	1.072	C1579010.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/26/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the "hands of the test" on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the "hands of the test" on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3 A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

Data Provided by Client

Data provided by the Client is clearly identified in the report. Air Hygiene accepts data provided by the Client as accurate.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO_2 to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO_2 in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS
QUALITY ASSURANCE DATA

Date: April 15-17, 2020
Company: Cricket Valley Energy Center LLC
Location: Dover Plains, New York
Techs: RW / AM / SF / JJ / MJ / GT

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
April 15-17, 2020	1	0

bec-19-cricketvalley.ny-start#3-U-00003-rpt

Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This laboratory also meets the A2LA *R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (*refer to joint ISO-ILAC-IAF Communiqué dated April 2017*).

Presented this 18th day of December 2019

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2021

For the tests to which this accreditation applies, please refer to the laboratory's Envrionmental Scope of Accreditation.

STAC STACK TESTING ACCREDITATION COUNCIL

A2LA American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 18th day of December 2019.

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2021

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY

Qualified Source Testing Individual

LET IT BE KNOWN THAT

ROBERT C. WHITE, Jr.

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 25TH DAY OF OCTOBER 2019 AND EFFECTIVE UNTIL OCTOBER 24TH, 2024

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Tina Sanderson, QSTI/QSTO Review Board

J. Wade Bice, QSTI/QSTO Review Board

Karen D. Kajiya-Mills , QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board

CERTIFICATE NO. 2015-898

Compliance Assurance Associates Inc.

Helping Industry Comply with Environmental Regulations

This is to acknowledge that

Sean Fields

BRO200103-17227

Certificate verification is available at www.Compliance.Assurance.com/certs.php using the last name and 17227

successfully participated in Visible Emissions Evaluation field training and certification and pursuant to US EPA 40 CFR 60 Appendix A, Reference Method 9, as amended, is certified to evaluate Visible Emissions for a period of six (6) months from the date of this certification.



Anthony Ferro - Field Manager	Broken Arrow, OK	01/03/2020
	Location	Date

Compliance Assurance Associates, Inc. 682 Orvil Smith Rd, Harvest, AL, 35749. 901-381-9960. compliance-assurance.com

QUALITY ASSURANCE AND QUALITY CONTROL DATA


Daily Reference Method Analyzer Calibration Data

Calibration Date: April 15, 2020 **Location: Cricket Valley Energy Center - Unit U-00003**

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 8.90

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.01	0.11	0.01	YES (%)
4.55	4.85	3.37	0.30	YES (abs)
8.90	8.82	-0.90	0.08	YES (%)
Linearity = 1.008				




CO Span (ppm) = 9.10

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.11	-1.18	0.11	YES (%)
5.22	5.16	-0.66	0.06	YES (%)
9.10	9.11	0.11	0.01	YES (%)
Linearity = 0.988				



O_2 Span (%) = 20.90


SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.03	0.14	0.03	YES (%)
11.98	11.96	-0.10	0.02	YES (%)
20.90	20.93	0.14	0.03	YES (%)
Linearity = 1.000				



VOC (as C1) Range (ppm) = 10.5


THERMO 51 series (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass (±2,5%)[1]
0.00	0.00	0.00	N/A	YES
3.03	2.96	-1.40	3.00	YES
5.19	4.97	-3.33	5.14	YES
8.78	8.70	-0.76	N/A	YES
Linearity = 0.997				

[1]-zero/high based on 2% of span, low/mid based on 5% of concentration



CO_2 Span (%) = 18.90

SERVOMEX 1440 (CO_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.00	0.00	0.00	YES (%)
8.91	9.25	1.80	0.34	YES (%)
18.90	18.41	-2.59	0.49	YES (abs)
Linearity = 1.027				




Calibration Date: April 16, 2020 **Location: Cricket Valley Energy Center - Unit U-00003**

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 8.90

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.02	0.22	0.02	YES (%)
4.55	4.69	1.57	0.14	YES (%)
8.90	8.83	-0.79	0.07	YES (%)
Linearity = 1.009				




CO Span (ppm) = 9.10

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.01	0.13	0.01	YES (%)
5.22	5.10	-1.32	0.12	YES (%)
9.10	9.05	-0.55	0.05	YES (%)
Linearity = 1.008				



O_2 Span (%) = 20.90


SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.00	0.00	0.00	YES (%)
11.98	11.97	-0.05	0.01	YES (%)
20.90	21.10	0.96	0.20	YES (%)
Linearity = 0.991				



VOC (as C1) Range (ppm) = 10.5


THERMO 51 series (THC/VOC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass (±2,5%)[1]
0.00	0.01	0.05	N/A	YES
3.03	3.01	0.14	3.01	YES
5.19	4.96	-3.56	5.14	YES
8.78	8.70	-0.76	N/A	YES
Linearity = 1.004				

[1]-zero/high based on 2% of span,low/mid based on 5% of concentration



CO_2 Span (%) = 18.90

SERVOMEX 1440 (CO_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	-0.02	-0.09	0.02	YES (%)
8.91	9.32	2.17	0.41	YES (abs)
18.90	18.93	0.16	0.03	YES (%)
Linearity = 0.998				



NOx Converter Efficiency

Date: April 15, 2020

Analyzer: inst-nx-0031

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**48.70**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**2.19**
	Analyzer Reading, NOx Channel, ppmvd	**49.10**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**46.91**
	Converter Efficiency, %	**96.32**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{46.91 \text{ ppmvd}}{48.70 \text{ ppmvd}}$ x 100 = 96.32%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
04/15/20 10:01:00	0	45.97	3.13
04/15/20 10:01:10	10	46.40	3.03
04/15/20 10:01:20	20	46.97	3.00
04/15/20 10:01:30	30	47.34	2.85
04/15/20 10:01:40	40	47.72	2.76
04/15/20 10:01:50	50	48.13	2.71
04/15/20 10:02:00	60	48.35	2.56
04/15/20 10:02:10	70	48.57	2.46
04/15/20 10:02:20	80	48.76	2.44
04/15/20 10:02:30	90	48.94	2.36
04/15/20 10:02:40	100	49.04	2.29
04/15/20 10:02:50	110	49.10	2.24
04/15/20 10:03:00	***120***	***49.10***	***2.19***
04/15/20 10:03:10	130	49.23	2.22
04/15/20 10:03:20	140	49.34	2.18
04/15/20 10:03:30	150	49.43	2.12
04/15/20 10:03:40	160	49.48	2.10
04/15/20 10:03:50	170	48.49	2.07

NOx Converter Efficiency

Date: April 16, 2020

Analyzer: inst-nx-0031

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**48.70**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**1.70**
	Analyzer Reading, NOx Channel, ppmvd	**46.19**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**44.49**
	Converter Efficiency, %	**91.36**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{44.49 \text{ ppmvd}}{48.70 \text{ ppmvd}}$ x 100 = 91.36%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
04/16/20 05:20:02	740	44.92	1.76
04/16/20 05:20:12	750	45.17	1.74
04/16/20 05:20:22	760	45.17	1.73
04/16/20 05:20:32	770	45.21	1.76
04/16/20 05:20:42	780	45.13	1.69
04/16/20 05:20:52	790	45.16	1.71
04/16/20 05:21:02	800	45.98	1.68
04/16/20 05:21:12	810	46.20	1.71
04/16/20 05:21:22	820	46.21	1.67
04/16/20 05:21:32	830	46.20	1.69
04/16/20 05:21:42	***840***	***46.19***	***1.70***
04/16/20 05:21:52	850	46.08	1.60
04/16/20 05:22:02	860	46.06	1.63
04/16/20 05:22:12	870	46.11	1.65
04/16/20 05:22:22	880	46.14	1.67
04/16/20 05:22:32	890	45.25	1.66
04/16/20 05:22:42	900	44.01	1.71
04/16/20 05:22:52	910	43.35	1.71
04/16/20 05:23:02	920	42.90	2.17

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
04/15/20	9:11:40	20200415CAL&SPIKE_0425.LAB	9.1282
04/15/20	9:11:50	20200415CAL&SPIKE_0426.LAB	9.1524
04/15/20	9:12:01	20200415CAL&SPIKE_0427.LAB	9.1538
04/15/20	9:12:11	20200415CAL&SPIKE_0428.LAB	9.1495
04/15/20	9:12:21	20200415CAL&SPIKE_0429.LAB	9.1561

PRE TEST AVERAGE **9.15**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
04/15/20	13:25:09	20200415RUN#3_0001.LAB	9.1662
04/15/20	13:25:39	20200415RUN#3_0002.LAB	9.2259
04/15/20	13:26:09	20200415RUN#3_0003.LAB	9.2390
04/15/20	13:26:39	20200415RUN#3_0004.LAB	9.2362
04/15/20	13:27:09	20200415RUN#3_0005.LAB	9.2510

POST TEST AVERAGE **9.22**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.91

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.15	2.67	PASS
Post Test	9.22	3.52	PASS

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
04/15/20	8:28:17	20200415CAL&SPIKE_0173.LAB	47.7009
04/15/20	8:28:27	20200415CAL&SPIKE_0174.LAB	47.5497
04/15/20	8:28:37	20200415CAL&SPIKE_0175.LAB	47.5848
04/15/20	8:28:48	20200415CAL&SPIKE_0176.LAB	47.5393
04/15/20	8:28:58	20200415CAL&SPIKE_0177.LAB	47.5565

PRE TEST AVERAGE **47.59**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
04/16/20	4:59:05	20200415SPIKE_0872.LAB	47.9093
04/16/20	4:59:15	20200415SPIKE_0873.LAB	47.9443
04/16/20	4:59:26	20200415SPIKE_0874.LAB	47.9725
04/16/20	4:59:36	20200415SPIKE_0875.LAB	48.0365
04/16/20	4:59:47	20200415SPIKE_0876.LAB	48.0709

POST TEST AVERAGE **47.99**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 48.90

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	47.59	-2.69	PASS
Post Test	47.99	-1.87	PASS

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd
04/15/20	8:27:46	20200415CAL&SPIKE_0170.LAB	47.4839
04/15/20	8:27:56	20200415CAL&SPIKE_0171.LAB	47.4808
04/15/20	8:28:06	20200415CAL&SPIKE_0172.LAB	47.5834
04/15/20	8:28:17	20200415CAL&SPIKE_0173.LAB	47.7009
04/15/20	8:28:27	20200415CAL&SPIKE_0174.LAB	47.5497
04/15/20	8:28:37	20200415CAL&SPIKE_0175.LAB	47.5848
04/15/20	8:28:48	20200415CAL&SPIKE_0176.LAB	47.5393
04/15/20	8:28:58	20200415CAL&SPIKE_0177.LAB	47.5565
RAW AVERAGE			**47.560**

Calibration Gas #2

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	SF_6 ppmvd
04/15/20	8:19:09	20200415CAL&SPIKE_0120.LAB	10.2301
04/15/20	8:19:19	20200415CAL&SPIKE_0121.LAB	10.2182
04/15/20	8:19:30	20200415CAL&SPIKE_0122.LAB	10.2299
04/15/20	8:19:40	20200415CAL&SPIKE_0123.LAB	10.2233
04/15/20	8:19:50	20200415CAL&SPIKE_0124.LAB	10.2322
04/15/20	8:20:01	20200415CAL&SPIKE_0125.LAB	10.2258
04/15/20	8:20:11	20200415CAL&SPIKE_0126.LAB	10.2182
04/15/20	8:20:22	20200415CAL&SPIKE_0127.LAB	10.2138
RAW AVERAGE			**10.224**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/15/20	15:10:50	20200415RUN#3_0212.LAB	4.5235	4.3240	0.2707	0.0006
04/15/20	15:11:20	20200415RUN#3_0213.LAB	4.5245	4.3205	0.2504	0.0012
04/15/20	15:11:50	20200415RUN#3_0214.LAB	4.5271	4.2876	0.2727	0.0003
04/15/20	15:12:20	20200415RUN#3_0215.LAB	4.5442	4.2094	0.2554	-0.0025
04/15/20	15:12:50	20200415RUN#3_0216.LAB	4.5324	4.1599	0.2369	-0.0011
04/15/20	15:13:20	20200415RUN#3_0217.LAB	4.5443	4.1716	0.2545	-0.0027
04/15/20	15:13:50	20200415RUN#3_0218.LAB	4.5385	4.1663	0.2405	-0.0019
04/15/20	15:14:20	20200415RUN#3_0219.LAB	4.5389	4.1462	0.2546	-0.0018
RAW AVERAGE			**4.534**	**4.223**	**0.254**	**-0.001**

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/15/20	15:32:04	20200415SPIKE_0097.LAB	4.1273	2.7738	1.0243	3.6900
04/15/20	15:32:14	20200415SPIKE_0098.LAB	4.1247	2.7299	1.0063	3.5985
04/15/20	15:32:25	20200415SPIKE_0099.LAB	4.1403	2.6976	1.0001	3.6008
04/15/20	15:32:35	20200415SPIKE_0100.LAB	4.1236	3.0493	0.9957	3.7726
04/15/20	15:32:45	20200415SPIKE_0101.LAB	4.0903	3.3813	0.9940	3.7888
04/15/20	15:32:56	20200415SPIKE_0102.LAB	4.0742	3.8885	0.9923	3.9360
04/15/20	15:33:06	20200415SPIKE_0103.LAB	4.0400	4.5620	0.9872	4.0751
04/15/20	15:33:16	20200415SPIKE_0104.LAB	4.0694	5.3042	0.8312	4.1363
RAW AVERAGE			**4.099**	**3.548**	**0.979**	**3.825**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/15/20	15:42:03	20200415SPIKE_0155.LAB	4.3191	8.0914	0.7755	0.0018
04/15/20	15:42:14	20200415SPIKE_0156.LAB	4.3088	8.1076	0.7703	0.0009
04/15/20	15:42:24	20200415SPIKE_0157.LAB	4.3275	8.0690	0.7358	0.0005
04/15/20	15:42:34	20200415SPIKE_0158.LAB	4.3137	8.0129	0.7437	0.0015
04/15/20	15:42:44	20200415SPIKE_0159.LAB	4.2955	8.2107	0.7785	-0.0003
04/15/20	15:42:55	20200415SPIKE_0160.LAB	4.3033	8.2988	0.7468	0.0008
04/15/20	15:43:05	20200415SPIKE_0161.LAB	4.3109	8.0401	0.7380	0.0013
04/15/20	15:43:15	20200415SPIKE_0162.LAB	4.2880	7.9006	0.7045	0.0152
RAW AVERAGE			**4.308**	**8.091**	**0.749**	**0.003**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/15/20	16:00:28	20200415SPIKE_0262.LAB	3.9367	6.3520	0.9931	3.9958
04/15/20	16:00:39	20200415SPIKE_0263.LAB	3.9243	6.5516	0.9940	4.0464
04/15/20	16:00:49	20200415SPIKE_0264.LAB	3.9636	6.6642	0.9069	4.0010
04/15/20	16:01:00	20200415SPIKE_0265.LAB	3.9579	6.6672	0.8997	3.8731
04/15/20	16:01:10	20200415SPIKE_0266.LAB	3.9595	6.6572	0.9026	3.8705
04/15/20	16:01:20	20200415SPIKE_0267.LAB	3.9675	6.6527	0.9022	3.8132
04/15/20	16:01:30	20200415SPIKE_0268.LAB	3.9486	6.6679	0.8947	3.7853
04/15/20	16:01:41	20200415SPIKE_0269.LAB	3.9551	6.6432	0.8995	3.7947
RAW AVERAGE			**3.952**	**6.607**	**0.924**	**3.897**

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/15/20	16:15:48	20200415SPIKE_0351.LAB	4.2048	9.5861	0.6437	0.0001
04/15/20	16:15:58	20200415SPIKE_0352.LAB	4.2055	9.5252	0.5934	-0.0020
04/15/20	16:16:08	20200415SPIKE_0353.LAB	4.1947	9.6407	0.5687	0.0006
04/15/20	16:16:19	20200415SPIKE_0354.LAB	4.1980	9.6435	0.6502	-0.0018
04/15/20	16:16:29	20200415SPIKE_0355.LAB	4.1718	10.1725	0.6049	-0.0020
04/15/20	16:16:40	20200415SPIKE_0356.LAB	4.1652	10.3723	0.6192	-0.0005
04/15/20	16:16:50	20200415SPIKE_0357.LAB	4.1219	10.5080	0.6269	0.0196
04/15/20	16:17:00	20200415SPIKE_0358.LAB	3.8276	10.0626	0.5873	0.7175
RAW AVERAGE			**4.136**	**9.939**	**0.612**	**0.091**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/15/20	16:27:51	20200415SPIKE_0421.LAB	3.9636	6.4576	0.9279	4.1122
04/15/20	16:28:01	20200415SPIKE_0422.LAB	3.9680	6.4509	0.9109	3.9723
04/15/20	16:28:11	20200415SPIKE_0423.LAB	3.9732	6.4388	0.9065	3.9004
04/15/20	16:28:22	20200415SPIKE_0424.LAB	3.9767	6.4072	0.9043	3.8530
04/15/20	16:28:32	20200415SPIKE_0425.LAB	3.9871	6.4201	0.9029	3.8507
04/15/20	16:28:42	20200415SPIKE_0426.LAB	3.9850	6.3950	0.9000	3.8180
04/15/20	16:28:53	20200415SPIKE_0427.LAB	3.9818	6.3714	0.9006	3.8110
04/15/20	16:29:03	20200415SPIKE_0428.LAB	3.9921	6.2970	0.8988	3.7491
RAW AVERAGE			**3.978**	**6.405**	**0.907**	**3.883**

Cricket Valley Energy Center LLC
April 15, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	47.56	47.56	47.56
Concentration of SF_6 Cylinder	ppmvd	10.22	10.22	10.22

Spike A

Stack CO_2 Concentration	%vd	4.534	4.308	4.136
Stack H_2O Concentration	%	4.223	8.091	9.939
Stack NH_3 Concentration	ppmvw	0.254	0.749	0.612
Stack SF_6 Concentration	ppmvw	-0.001	0.003	0.091
Stack + Spike CO_2 Concentration	%vd	4.099	3.952	3.978
Stack + Spike H_2O Concentration	%	3.548	6.607	6.405
Stack + Spike NH_3 Concentration	ppmvw	3.825	3.897	3.883
Stack + Spike SF_6 Concentration	ppmvw	0.979	0.924	0.907
Dilution Ratio		0.099	0.097	0.095
Ideal NH_3 Spike Yield	ppmvd	4.960	5.339	5.120
Percent Recovery NH_3	%	78.92%	74.67%	78.44%

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
04/16/20	4:38:26	20200415SPIKE_0752.LAB	8.7633
04/16/20	4:38:36	20200415SPIKE_0753.LAB	9.1456
04/16/20	4:38:46	20200415SPIKE_0754.LAB	9.1752
04/16/20	4:38:56	20200415SPIKE_0755.LAB	9.2008
04/16/20	4:39:07	20200415SPIKE_0756.LAB	9.2479

PRE TEST AVERAGE **9.11**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
04/16/20	17:44:46	20200416RUN#3_0494.LAB	9.2052
04/16/20	17:45:16	20200416RUN#3_0495.LAB	9.1884
04/16/20	17:45:47	20200416RUN#3_0496.LAB	9.1816
04/16/20	17:46:17	20200416RUN#3_0497.LAB	9.1695
04/16/20	17:46:47	20200416RUN#3_0498.LAB	9.1873

POST TEST AVERAGE **9.19**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.91

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.11	2.21	PASS
Post Test	9.19	3.10	PASS

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
04/16/20	4:59:05	20200415SPIKE_0872.LAB	47.9093
04/16/20	4:59:15	20200415SPIKE_0873.LAB	47.9443
04/16/20	4:59:26	20200415SPIKE_0874.LAB	47.9725
04/16/20	4:59:36	20200415SPIKE_0875.LAB	48.0365
04/16/20	4:59:47	20200415SPIKE_0876.LAB	48.0709

PRE TEST AVERAGE **47.99**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
04/16/20	17:50:17	20200416RUN#3_0505.LAB	47.6024
04/16/20	17:50:47	20200416RUN#3_0506.LAB	47.8209
04/16/20	17:51:17	20200416RUN#3_0507.LAB	47.8932
04/16/20	17:51:47	20200416RUN#3_0508.LAB	48.0216
04/16/20	17:52:17	20200416RUN#3_0509.LAB	48.2362

POST TEST AVERAGE **47.91**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 48.90

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	47.99	-1.87	PASS
Post Test	47.91	-2.01	PASS

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd
04/16/20	4:58:24	20200415SPIKE_0868.LAB	47.6362
04/16/20	4:58:34	20200415SPIKE_0869.LAB	47.6883
04/16/20	4:58:44	20200415SPIKE_0870.LAB	47.7292
04/16/20	4:58:55	20200415SPIKE_0871.LAB	47.7872
04/16/20	4:59:05	20200415SPIKE_0872.LAB	47.9093
04/16/20	4:59:15	20200415SPIKE_0873.LAB	47.9443
04/16/20	4:59:26	20200415SPIKE_0874.LAB	47.9725
04/16/20	4:59:36	20200415SPIKE_0875.LAB	48.0365
RAW AVERAGE			**47.838**

Calibration Gas #2

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	SF_6 ppmvd
04/16/20	4:58:34	20200415SPIKE_0869.LAB	10.2488
04/16/20	4:58:44	20200415SPIKE_0870.LAB	10.2581
04/16/20	4:58:55	20200415SPIKE_0871.LAB	10.2375
04/16/20	4:59:05	20200415SPIKE_0872.LAB	10.2589
04/16/20	4:59:15	20200415SPIKE_0873.LAB	10.2581
04/16/20	4:59:26	20200415SPIKE_0874.LAB	10.2443
04/16/20	4:59:36	20200415SPIKE_0875.LAB	10.2557
04/16/20	4:59:47	20200415SPIKE_0876.LAB	10.2474
RAW AVERAGE			**10.251**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/16/20	5:55:52	20200416SPIKE_0183.LAB	4.7820	0.9422	0.1539	-0.0006
04/16/20	5:56:02	20200416SPIKE_0184.LAB	4.7556	0.9441	0.1680	-0.0021
04/16/20	5:56:13	20200416SPIKE_0185.LAB	4.7573	0.9424	0.2106	-0.0016
04/16/20	5:56:23	20200416SPIKE_0186.LAB	4.7691	0.9450	0.1387	-0.0002
04/16/20	5:56:33	20200416SPIKE_0187.LAB	4.7673	0.9492	0.1356	0.0012
04/16/20	5:56:43	20200416SPIKE_0188.LAB	4.7649	0.9480	0.1676	-0.0014
04/16/20	5:56:54	20200416SPIKE_0189.LAB	4.7552	0.9437	0.1702	-0.0044
04/16/20	5:57:04	20200416SPIKE_0190.LAB	4.7519	0.9436	0.2152	-0.0018
RAW AVERAGE			**4.763**	**0.945**	**0.170**	**-0.001**

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/16/20	6:05:19	20200416SPIKE_0238.LAB	4.3272	0.8523	0.9308	3.2745
04/16/20	6:05:30	20200416SPIKE_0239.LAB	4.3224	0.8554	0.9274	3.2823
04/16/20	6:05:40	20200416SPIKE_0240.LAB	4.3358	0.8569	0.9236	3.2639
04/16/20	6:05:51	20200416SPIKE_0241.LAB	4.3290	0.8541	0.9263	3.2988
04/16/20	6:06:01	20200416SPIKE_0242.LAB	4.3215	0.8583	0.9239	3.2724
04/16/20	6:06:11	20200416SPIKE_0243.LAB	4.3205	0.8593	0.9244	3.2850
04/16/20	6:06:21	20200416SPIKE_0244.LAB	4.3231	0.8592	0.9228	3.3060
04/16/20	6:06:32	20200416SPIKE_0245.LAB	4.3262	0.8620	0.9201	3.3256
RAW AVERAGE			**4.326**	**0.857**	**0.925**	**3.289**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/16/20	6:18:35	20200416SPIKE_0315.LAB	4.7402	1.2027	0.3876	-0.0014
04/16/20	6:18:45	20200416SPIKE_0316.LAB	4.7501	1.2185	0.4118	0.0024
04/16/20	6:18:56	20200416SPIKE_0317.LAB	4.7780	1.2307	0.3194	-0.0040
04/16/20	6:19:06	20200416SPIKE_0318.LAB	4.7621	1.2559	0.3657	-0.0027
04/16/20	6:19:16	20200416SPIKE_0319.LAB	4.7542	1.2867	0.3318	-0.0030
04/16/20	6:19:27	20200416SPIKE_0320.LAB	4.7446	1.3154	0.3318	-0.0055
04/16/20	6:19:37	20200416SPIKE_0321.LAB	4.7576	1.3445	0.3577	-0.0025
04/16/20	6:19:47	20200416SPIKE_0322.LAB	4.7355	1.3503	0.3459	0.0008
RAW AVERAGE			**4.753**	**1.276**	**0.356**	**-0.002**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/16/20	6:28:03	20200416SPIKE_0370.LAB	4.2839	1.4085	0.9171	3.5395
04/16/20	6:28:13	20200416SPIKE_0371.LAB	4.2992	1.4100	0.9269	3.6219
04/16/20	6:28:24	20200416SPIKE_0372.LAB	4.2960	1.4165	0.9206	3.5542
04/16/20	6:28:34	20200416SPIKE_0373.LAB	4.3049	1.4070	0.9240	3.6200
04/16/20	6:28:44	20200416SPIKE_0374.LAB	4.3075	1.4139	0.9208	3.5396
04/16/20	6:28:54	20200416SPIKE_0375.LAB	4.2952	1.4044	0.9231	3.6026
04/16/20	6:29:05	20200416SPIKE_0376.LAB	4.2841	1.4168	0.9219	3.5841
04/16/20	6:29:15	20200416SPIKE_0377.LAB	4.2916	1.4089	0.9214	3.5879
RAW AVERAGE			**4.295**	**1.411**	**0.922**	**3.581**

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/16/20	6:48:32	20200416SPIKE_0489.LAB	4.4207	6.9832	0.4635	0.0059
04/16/20	6:48:42	20200416SPIKE_0490.LAB	4.4083	7.1622	0.4619	0.0020
04/16/20	6:48:52	20200416SPIKE_0491.LAB	4.4096	7.1675	0.4503	0.0040
04/16/20	6:49:03	20200416SPIKE_0492.LAB	4.3961	7.0997	0.4230	0.0019
04/16/20	6:49:13	20200416SPIKE_0493.LAB	4.3857	7.6501	0.4309	0.0013
04/16/20	6:49:23	20200416SPIKE_0494.LAB	4.3981	7.5485	0.4648	0.0037
04/16/20	6:49:33	20200416SPIKE_0495.LAB	4.4089	7.2687	0.4359	0.0017
04/16/20	6:49:44	20200416SPIKE_0496.LAB	4.4034	7.0484	0.4228	0.0054
RAW AVERAGE			**4.404**	**7.241**	**0.444**	**0.003**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vd	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/16/20	6:58:10	20200416SPIKE_0545.LAB	4.1186	5.1727	0.9222	3.6885
04/16/20	6:58:20	20200416SPIKE_0546.LAB	4.0940	5.3279	0.9223	3.7172
04/16/20	6:58:30	20200416SPIKE_0547.LAB	4.0959	5.3622	0.9196	3.7382
04/16/20	6:58:41	20200416SPIKE_0548.LAB	4.0900	5.3540	0.9187	3.6908
04/16/20	6:58:51	20200416SPIKE_0549.LAB	4.0841	5.4307	0.9183	3.7077
04/16/20	6:59:01	20200416SPIKE_0550.LAB	4.0798	5.4271	0.9160	3.6657
04/16/20	6:59:12	20200416SPIKE_0551.LAB	4.0952	5.3989	0.9160	3.7498
04/16/20	6:59:22	20200416SPIKE_0552.LAB	4.0655	5.4220	0.9479	3.7334
RAW AVERAGE			**4.090**	**5.362**	**0.923**	**3.711**

Cricket Valley Energy Center LLC
April 16, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	47.84	47.84	47.84
Concentration of SF_6 Cylinder	ppmvd	10.25	10.25	10.25

Spike A

Stack CO_2 Concentration	%vd	4.763	4.753	4.404
Stack H_2O Concentration	%	0.945	1.276	7.241
Stack NH_3 Concentration	ppmvw	0.170	0.356	0.444
Stack SF_6 Concentration	ppmvw	-0.001	-0.002	0.003
Stack + Spike CO_2 Concentration	%vd	4.326	4.295	4.090
Stack + Spike H_2O Concentration	%	0.857	1.411	5.362
Stack + Spike NH_3 Concentration	ppmvw	3.289	3.581	3.711
Stack + Spike SF_6 Concentration	ppmvw	0.925	0.922	0.923
Dilution Ratio		0.091	0.091	0.095
Ideal NH_3 Spike Yield	ppmvd	4.509	4.692	4.983
Percent Recovery NH_3	%	72.61%	75.72%	76.68%

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	0.00	0.06
Final Zero	0.11	0.15
Avg. Zero	0.06	0.11
Initial UpScale	11.91	4.56
Final UpScale	11.86	4.40
Avg. UpScale	11.89	4.48
Sys Resp (Zero)	0.03	0.01
Sys Resp (Upscale)	11.96	4.85
Upscale Cal Gas	11.98	4.55
Initial Zero Bias	-0.14%	0.56%
Final Zero Bias	0.38%	1.57%
Zero Drift	0.53%	1.01%
Initial Upscale Bias	-0.24%	-3.26%
Final Upscale Bias	-0.48%	-5.06%
Upscale Drift	0.24%	1.80%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.05
Alternative Specification Abs Diff **Final Zero**	0.08	0.14
Alternative Specification Abs Diff **Initial Upscale**	0.05	0.29
Alternative Specification Abs Diff **Final Upscale**	0.10	0.45
Calibration Span	20.90	8.90
3% of Cal. Span (drift)	0.63	0.27
5% of Cal. Span (bias)	1.05	0.45

Response Time (min)	2.2	2.5
Sys. Response (min)	2.5	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
04/15/20 10:07:00		**12.37**			2.16		x
04/15/20 10:07:10		**12.38**			2.17		
04/15/20 10:07:20		**12.36**			2.17		
04/15/20 10:07:30		**11.79**			2.11		
04/15/20 10:07:40		6.29			1.84		
04/15/20 10:07:50		3.57			1.59		
04/15/20 10:08:00		3.27			1.18		
04/15/20 10:08:10		3.27			0.81		
04/15/20 10:08:20		3.29			0.73		
04/15/20 10:08:30		3.29			0.69		
04/15/20 10:08:40		1.67			0.69		
04/15/20 10:08:50		**0.31**			0.69		
04/15/20 10:09:00		0.66			**0.28**		
04/15/20 10:09:10	x	**0.50**			1.88		
04/15/20 10:09:20		**0.46**			3.96		
04/15/20 10:09:30		**0.45**			**4.45**	x	
04/15/20 10:09:40		**0.44**			**4.54**		
04/15/20 10:09:50		**0.43**			**4.57**		
04/15/20 10:10:00		**0.42**			**4.57**		
04/15/20 10:10:10		**0.41**			**4.61**		
04/15/20 10:10:20		**0.40**			**4.60**		
04/15/20 10:10:30		**0.40**			**4.57**		
04/15/20 10:10:40		**0.39**			**4.57**		
04/15/20 10:10:50		**0.39**			**4.57**		
04/15/20 10:11:00		**0.38**			**4.63**		
04/15/20 10:11:10		**0.38**			**4.57**		
04/15/20 10:11:20		**0.38**			**4.59**		
04/15/20 10:11:30		**0.37**			**4.57**		
04/15/20 10:11:40		**0.37**			**4.54**		
04/15/20 10:11:50		**0.37**			**4.55**		
04/15/20 10:12:00		**0.38**			**4.59**		
04/15/20 10:12:10		**0.37**			**4.65**		
04/15/20 10:12:20		**0.38**			**4.59**		x
04/15/20 10:12:30		**0.46**			**4.60**		
04/15/20 10:12:40		7.23			**4.61**		
04/15/20 10:12:50		11.26			4.24		
04/15/20 10:13:00		**11.81**	x		3.90		
04/15/20 10:13:10		**11.89**			2.41		
04/15/20 10:13:20		**11.91**		x	**0.34**		
04/15/20 10:13:30		**11.93**			**0.19**		
04/15/20 10:13:40		**11.94**			**0.08**		
04/15/20 10:13:50		**11.94**			**0.12**		
04/15/20 10:14:00		**11.96**			**0.08**		
04/15/20 10:14:10		**11.96**			**0.08**		
04/15/20 10:14:20		**11.96**			**0.09**		
04/15/20 10:14:30		**11.97**			**0.07**		
04/15/20 10:14:40		**11.98**			**0.06**		

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	0.03	0.06
Final Zero	0.09	0.11
Avg. Zero	0.06	0.09
Initial UpScale	11.88	4.53
Final UpScale	11.81	4.55
Avg. UpScale	11.85	4.54
Sys Resp (Zero)	0.00	0.02
Sys Resp (Upscale)	11.97	4.69
Upscale Cal Gas	11.98	4.55
Initial Zero Bias	0.14%	0.45%
Final Zero Bias	0.43%	1.01%
Zero Drift	0.29%	0.56%
Initial Upscale Bias	-0.43%	-1.80%
Final Upscale Bias	-0.77%	-1.57%
Upscale Drift	0.33%	0.22%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.04
Alternative Specification Abs Diff **Final Zero**	0.09	0.09
Alternative Specification Abs Diff **Initial Upscale**	0.09	0.16
Alternative Specification Abs Diff **Final Upscale**	0.16	0.14
Calibration Span	20.90	8.90
3% of Cal. Span (drift)	0.63	0.27
5% of Cal. Span (bias)	1.05	0.45

Response Time (min)	2.2	2.5
Sys. Response (min)	2.5	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
04/15/20 10:07:00		**12.37**			2.16		x
04/15/20 10:07:10		**12.38**			2.17		
04/15/20 10:07:20		**12.36**			2.17		
04/15/20 10:07:30		**11.79**			2.11		
04/15/20 10:07:40		6.29			1.84		
04/15/20 10:07:50		3.57			1.59		
04/15/20 10:08:00		3.27			1.18		
04/15/20 10:08:10		3.27			0.81		
04/15/20 10:08:20		3.29			0.73		
04/15/20 10:08:30		3.29			0.69		
04/15/20 10:08:40		1.67			0.69		
04/15/20 10:08:50		**0.31**			0.69		
04/15/20 10:09:00		0.66			**0.28**		
04/15/20 10:09:10	x	**0.50**			1.88		
04/15/20 10:09:20		**0.46**			3.96		
04/15/20 10:09:30		**0.45**			**4.45**	x	
04/15/20 10:09:40		**0.44**			**4.54**		
04/15/20 10:09:50		**0.43**			**4.57**		
04/15/20 10:10:00		**0.42**			**4.57**		
04/15/20 10:10:10		**0.41**			**4.61**		
04/15/20 10:10:20		**0.40**			**4.60**		
04/15/20 10:10:30		**0.40**			**4.57**		
04/15/20 10:10:40		**0.39**			**4.57**		
04/15/20 10:10:50		**0.39**			**4.57**		
04/15/20 10:11:00		**0.38**			**4.63**		
04/15/20 10:11:10		**0.38**			**4.57**		
04/15/20 10:11:20		**0.38**			**4.59**		
04/15/20 10:11:30		**0.37**			**4.57**		
04/15/20 10:11:40		**0.37**			**4.54**		
04/15/20 10:11:50		**0.37**			**4.55**		
04/15/20 10:12:00		**0.38**			**4.59**		
04/15/20 10:12:10		**0.37**			**4.65**		
04/15/20 10:12:20		**0.38**			**4.59**		x
04/15/20 10:12:30		**0.46**			**4.60**		
04/15/20 10:12:40		7.23			**4.61**		
04/15/20 10:12:50		11.26			4.24		
04/15/20 10:13:00		**11.81**	x		3.90		
04/15/20 10:13:10		**11.89**			2.41		
04/15/20 10:13:20		**11.91**		x	**0.34**		
04/15/20 10:13:30		**11.93**			**0.19**		
04/15/20 10:13:40		**11.94**			**0.08**		
04/15/20 10:13:50		**11.94**			**0.12**		
04/15/20 10:14:00		**11.96**			**0.08**		
04/15/20 10:14:10		**11.96**			**0.08**		
04/15/20 10:14:20		**11.96**			**0.09**		
04/15/20 10:14:30		**11.97**			**0.07**		
04/15/20 10:14:40		**11.98**			**0.06**		

DRIFT AND BIAS CHECK					
Base Load, Run - 1-1	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.77	1.78	-0.46	0.00	4.56
Corrected Average	12.88	1.73	0.00	0.00	4.62
Initial Zero	0.03	0.06	0.06	-0.01	-0.02
Final Zero	0.09	0.05	-0.17	0.00	-0.16
Avg. Zero	0.06	0.06	-0.06	0.00	-0.09
Initial UpScale	11.90	4.60	5.19	3.02	8.89
Final UpScale	11.86	4.62	4.88	3.15	8.89
Avg. UpScale	11.88	4.61	5.04	3.09	8.89
Sys Resp (Zero)	0.03	0.01	-0.11	0.00	0.00
Sys Resp (Upscale)	11.96	4.85	5.16	2.96	9.25
Upscale Cal Gas	11.98	4.55	5.22	3.03	8.91
Initial Zero Bias	0.00%	0.56%	1.84%	-0.08%	-0.11%
Final Zero Bias	0.29%	0.45%	-0.69%	0.00%	-0.85%
Zero Drift	0.29%	0.11%	2.53%	0.08%	0.74%
Initial Upscale Bias	-0.29%	-2.81%	0.33%	0.57%	-1.90%
Final Upscale Bias	-0.48%	-2.58%	-3.08%	1.81%	-1.90%
Upscale Drift	0.19%	0.22%	3.41%	1.24%	0.00%
Alternative Specification Abs Diff **Initial Zero**	0.00	0.05	0.17	--	0.02
Alternative Specification Abs Diff **Final Zero**	0.06	0.04	0.06	--	0.16
Alternative Specification Abs Diff **Initial Upscale**	0.06	0.25	0.03	--	0.36
Alternative Specification Abs Diff **Final Upscale**	0.10	0.23	0.28	--	0.36
Calibration Span	20.90	8.90	9.10	10.50	18.90
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base Load, Run - 1-2	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.77	1.95	-0.46	0.00	4.89
Corrected Average	12.92	1.81	0.00	0.00	4.89
Initial Zero	0.09	0.05	-0.17	0.00	-0.16
Final Zero	0.12	0.29	-0.17	-0.01	0.08
Avg. Zero	0.11	0.17	-0.17	0.00	-0.04
Initial UpScale	11.86	4.62	4.88	3.15	8.89
Final UpScale	11.84	4.66	5.01	2.92	8.98
Avg. UpScale	11.85	4.64	4.95	3.04	8.94
Sys Resp (Zero)	0.03	0.01	-0.11	0.00	0.00
Sys Resp (Upscale)	11.96	4.85	5.16	2.96	9.25
Upscale Cal Gas	11.98	4.55	5.22	3.03	8.91
Initial Zero Bias	0.29%	0.45%	-0.69%	0.00%	-0.85%
Final Zero Bias	0.43%	3.15%	-0.69%	-0.07%	0.42%
Zero Drift	0.14%	2.70%	0.00%	0.07%	1.27%
Initial Upscale Bias	-0.48%	-2.58%	-3.08%	1.81%	-1.90%
Final Upscale Bias	-0.57%	-2.13%	-1.65%	-0.38%	-1.43%
Upscale Drift	0.10%	0.45%	1.43%	2.19%	0.48%
Alternative Specification Abs Diff **Initial Zero**	0.06	0.04	0.06	--	0.16
Alternative Specification Abs Diff **Final Zero**	0.09	0.28	0.06	--	0.08
Alternative Specification Abs Diff **Initial Upscale**	0.10	0.23	0.28	--	0.36
Alternative Specification Abs Diff **Final Upscale**	0.12	0.19	0.15	--	0.27
Calibration Span	20.90	8.90	9.10	10.50	18.90
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base Load, Run - 1-3	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	12.71	1.90	-0.46	0.01	4.88
Corrected Average	12.88	1.76	0.00	0.01	4.78
Initial Zero	0.12	0.29	-0.17	-0.01	0.08
Final Zero	0.10	0.09	-0.43	0.01	0.09
Avg. Zero	0.11	0.19	-0.30	0.00	0.09
Initial UpScale	11.84	4.66	5.01	2.92	8.98
Final UpScale	11.83	4.56	4.82	2.78	9.08
Avg. UpScale	11.84	4.61	4.92	2.85	9.03
Sys Resp (Zero)	0.03	0.01	-0.11	0.00	0.00
Sys Resp (Upscale)	11.96	4.85	5.16	2.96	9.25
Upscale Cal Gas	11.98	4.55	5.22	3.03	8.91
Initial Zero Bias	0.43%	3.15%	-0.69%	-0.07%	0.42%
Final Zero Bias	0.33%	0.90%	-3.55%	0.10%	0.48%
Zero Drift	0.10%	2.25%	2.86%	0.16%	0.05%
Initial Upscale Bias	-0.57%	-2.13%	-1.65%	-0.38%	-1.43%
Final Upscale Bias	-0.62%	-3.26%	-3.74%	-1.71%	-0.90%
Upscale Drift	0.05%	1.12%	2.09%	1.33%	0.53%
Alternative Specification Abs Diff **Initial Zero**	0.09	0.28	0.06	--	0.08
Alternative Specification Abs Diff **Final Zero**	0.07	0.08	0.32	--	0.09
Alternative Specification Abs Diff **Initial Upscale**	0.12	0.19	0.15	--	0.27
Alternative Specification Abs Diff **Final Upscale**	0.13	0.29	0.34	--	0.17
Calibration Span	20.90	8.90	9.10	10.50	18.90
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-1	**O_2**	**NOx**	**CO**	**VOC (as C1)**	**CO_2**
Raw Average	11.82	2.43	0.13	0.00	5.18
Corrected Average	11.94	2.35	0.13	0.00	5.12
Initial Zero	0.03	0.06	-0.05	0.01	-0.01
Final Zero	0.07	0.23	0.05	0.00	0.09
Avg. Zero	0.05	0.15	0.00	0.00	0.04
Initial UpScale	11.88	4.53	5.16	3.01	9.02
Final UpScale	11.84	4.61	5.10	3.11	8.94
Avg. UpScale	11.86	4.57	5.13	3.06	8.98
Sys Resp (Zero)	0.00	0.02	0.01	0.01	-0.02
Sys Resp (Upscale)	11.97	4.69	5.10	3.01	9.32
Upscale Cal Gas	11.98	4.55	5.22	3.03	8.91
Initial Zero Bias	0.14%	0.45%	-0.68%	0.00%	0.04%
Final Zero Bias	0.33%	2.36%	0.42%	-0.05%	0.57%
Zero Drift	0.19%	1.91%	1.10%	0.05%	0.53%
Initial Upscale Bias	-0.43%	-1.80%	0.66%	0.00%	-1.59%
Final Upscale Bias	-0.62%	-0.90%	0.00%	0.95%	-2.01%
Upscale Drift	0.19%	0.90%	0.66%	0.95%	0.42%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.04	0.06	--	0.01
Alternative Specification Abs Diff **Final Zero**	0.07	0.21	0.04	--	0.11
Alternative Specification Abs Diff **Initial Upscale**	0.09	0.16	0.06	--	0.30
Alternative Specification Abs Diff **Final Upscale**	0.13	0.08	0.00	--	0.38
Calibration Span	20.90	8.90	9.10	10.50	18.90
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-2	O_2	NOx	CO	VOC (as C1)	CO_2
Raw Average	11.85	2.41	0.08	0.00	5.17
Corrected Average	11.99	2.26	0.03	0.00	5.11
Initial Zero	0.07	0.23	0.05	0.00	0.09
Final Zero	0.05	0.22	0.05	0.00	0.10
Avg. Zero	0.06	0.23	0.05	0.00	0.10
Initial UpScale	11.84	4.61	5.10	3.11	8.94
Final UpScale	11.83	4.64	5.14	3.13	8.96
Avg. UpScale	11.84	4.63	5.12	3.12	8.95
Sys Resp (Zero)	0.00	0.02	0.01	0.01	-0.02
Sys Resp (Upscale)	11.97	4.69	5.10	3.01	9.32
Upscale Cal Gas	11.98	4.55	5.22	3.03	8.91
Initial Zero Bias	0.33%	2.36%	0.42%	-0.05%	0.57%
Final Zero Bias	0.24%	2.25%	0.42%	-0.01%	0.62%
Zero Drift	0.10%	0.11%	0.00%	0.04%	0.05%
Initial Upscale Bias	-0.62%	-0.90%	0.00%	0.95%	-2.01%
Final Upscale Bias	-0.67%	-0.56%	0.44%	1.14%	-1.90%
Upscale Drift	0.05%	0.34%	0.44%	0.19%	0.11%
Alternative Specification Abs Diff: Initial Zero	0.07	0.21	0.04	--	0.11
Alternative Specification Abs Diff: Final Zero	0.05	0.20	0.04	--	0.12
Alternative Specification Abs Diff: Initial Upscale	0.13	0.08	0.00	--	0.38
Alternative Specification Abs Diff: Final Upscale	0.14	0.05	0.04	--	0.36
Calibration Span	20.90	8.90	9.10	10.50	18.90
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

DRIFT AND BIAS CHECK					
Base+Db Load, Run - 2-3	O_2	NOx	CO	VOC (as C1)	CO_2
Raw Average	11.84	2.31	0.01	0.00	5.19
Corrected Average	11.99	2.17	0.00	0.00	5.13
Initial Zero	0.05	0.22	0.05	0.00	0.10
Final Zero	0.08	0.15	-0.04	0.00	0.11
Avg. Zero	0.07	0.19	0.01	0.00	0.11
Initial UpScale	11.83	4.64	5.14	3.13	8.96
Final UpScale	11.83	4.64	5.25	3.16	8.90
Avg. UpScale	11.83	4.64	5.20	3.15	8.93
Sys Resp (Zero)	0.00	0.02	0.01	0.01	-0.02
Sys Resp (Upscale)	11.97	4.69	5.10	3.01	9.32
Upscale Cal Gas	11.98	4.55	5.22	3.03	8.91
Initial Zero Bias	0.24%	2.25%	0.42%	-0.01%	0.62%
Final Zero Bias	0.38%	1.46%	-0.57%	-0.02%	0.67%
Zero Drift	0.14%	0.79%	0.99%	0.01%	0.05%
Initial Upscale Bias	-0.67%	-0.56%	0.44%	1.14%	-1.90%
Final Upscale Bias	-0.67%	-0.56%	1.65%	1.43%	-2.22%
Upscale Drift	0.00%	0.00%	1.21%	0.29%	0.32%
Alternative Specification Abs Diff: Initial Zero	0.05	0.20	0.04	--	0.12
Alternative Specification Abs Diff: Final Zero	0.08	0.13	0.05	--	0.13
Alternative Specification Abs Diff: Initial Upscale	0.14	0.05	0.04	--	0.36
Alternative Specification Abs Diff: Final Upscale	0.14	0.05	0.15	--	0.42
Calibration Span	20.90	8.90	9.10	10.50	18.90
3% of Cal. Span (drift)	0.63	0.27	0.27	0.32	0.57
5% of Cal. Span (bias)	1.05	0.45	0.46	0.53	0.95

SINGLE LOAD TEST - FIELD DATA SHEET

AIR HYGIENE

Company:	Bechtel		
Location:	Cricket Valley, New York		
Date:	4/15/2020	**Project Code:**	bec-19-cricketvalley.ny-start#3
Unit Make and Model:			
Unit Number:			
Serial Number:			
Data Recorded By:			
Tested With AHI Unit(s):	**Truck(s):** 163	**Trailer(s):**	215
LDEQ Warmup/Cal Req:	**On (Day/Time):**	**Cal (Day/Time):**	

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0058639	EB0058639	EB0058639
	Mid	CC716390	CC727541	CC727541
	High	CC722643	EB040961	EB040961

Stack Dia. = _____
Measured By: _____
Measured With: _____

CYLINDER SERIAL NUMBERS		THC	CO_2	SO_2
	Low	EB0065886	EB0058639	N/a
	Mid	EB0078043	CC716390	N/a
	High	EB0075711	CC722643	N/a

RUN INFORMATION	**Load**		
	_____% #1	_____% #2	_____% #3
Time Start (hh:mm:ss)	12:10:05	13:23:05	14:35:05
Time Stop (hh:mm:ss)	13:09:35	14:22:35	15:34:35
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)			
Ambient Temperature (°F)			
Relative Humidity (%)			
Fuel Flow (lb/min)			
Fuel Flow (SCF/hr)=(lb/min)*21.7			
Specific Humidity (gr/lb)			
Spec. Hum. (lb H_2O/lb air)=(gr/lb)/7000			
PCD (psi)			
PCD (mm Hg)=(psi+14.24)*51.71493			
NOx Water Injection (gpm)			

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	2.24
NOx Reading (ppm)	49.1
Cylinder Num	EB0098845

REPORT INFORMATION		
	INSTRUMENT	**SERIAL #**
O_2	Sevromex 1440	Inst-O2-0033
NOx	Thermo 42c	Inst-Nx-0049
CO	Thermo 48c	Inst-Co-0030
THC	Thermo 51i	Inst-Th-0013
CO_2	Sevromex 1440	Inst-C2-0015
SO_2	N/a	N/a

RESPONSE TIME		
	TIME (hh:mm)	**RESP (min)**
1st Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
2nd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
3rd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		

CALIBRATION	O_2		NOx		CO		THC		CO_2		SO_2	
	Conc.	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**
Zero Gas	0	0.03	0	0.01	0	-0.107	0	0	0	-0.08	N/a	N/a
Low Gas	N/a	N/a	N/a	N/a	N/a	N/a	3.03	2.96	N/a	N/a	N/a	N/a
Mid Gas	11.98	11.96	4.55	4.85	5.22	5.16	5.19	4.97	8.91	9.25	N/a	N/a
High Gas	20.9	20.93	8.9	8.82	9.1	9.11	8.78	8.7	18.9	18.46	N/a	N/a

5	O_2		NOx		CO		THC		CO_2		SO_2	
	Zero	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**
Initial Run #1	0.03	11.91	0.06	4.6	0.06	5.19	-0.008	3.02	-0.2	8.98	N/a	N/a
Run #1 / Run #2	0.09	11.86	0.05	4.62	-0.17	4.86	0	3.15	-0.16	8.89	N/a	N/a
Run #2 / Run #3	0.12	11.84	0.29	4.66	-0.17	5.01	-0.007	2.92	0.08	8.98	N/a	N/a
Run #3 / Final	0.1	11.83	0.09	4.56	-0.43	4.82	0.01	2.78	0.09	9.08	N/a	N/a
Bias Gas Actual Conc.		11.98		4.55		5.22		3.03		8.91		N/a

Signature _____

SINGLE LOAD TEST - FIELD DATA SHEET

AIR HYGIENE

Company:	Bechtel		
Location:	Cricket Valley, New York		
Date:	4/16/2020	**Project Code:**	bec-19-cricketvalley.ny-start#3
Unit Make and Model:			
Unit Number:			
Serial Number:			
Data Recorded By:			
Tested With AHI Unit(s):	**Truck(s):** 163	**Trailer(s):**	215
LDEQ Warmup/Cal Req:	**On (Day/Time):**	**Cal (Day/Time):**	

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0058639	EB0058639	EB0058639
	Mid	CC716390	CC727541	CC727541
	High	CC722643	EB040961	EB040961

Stack Dia. = _____
Measured By: _____
Measured With: _____

CYLINDER SERIAL NUMBERS		THC	CO_2	SO_2
	Low	EB0065886	EB0058639	N/a
	Mid	EB0078043	CC716390	N/a
	High	EB0075711	CC722643	N/a

RUN INFORMATION	**Load**		
	_____% #1	_____% #2	_____% #3
Time Start (hh:mm:ss)	14:04:12	15:23:12	16:40:12
Time Stop (hh:mm:ss)	15:03:42	16:03:42	17:39:42
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)			
Ambient Temperature (°F)			
Relative Humidity (%)			
Fuel Flow (lb/min)			
Fuel Flow (SCF/hr)=(lb/min)*21.7			
Specific Humidity (gr/lb)			
Spec. Hum. (lb H_2O/lb air)=(gr/lb)/7000			
PCD (psi)			
PCD (mm Hg)=(psi+14.24)*51.71493			
NOx Water Injection (gpm)			

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	1.71
NOx Reading (ppm)	46.19
Cylinder Num	EB0098845

REPORT INFORMATION		
	INSTRUMENT	**SERIAL #**
O_2	Sevromex 1440	Inst-O2-0024
NOx	Thermo 42c	Inst-Nx-0031
CO	Thermo 48c	Inst-Co-0029
THC	Thermo 51i	Inst-Th-0013
CO_2	Sevromex 1440	Inst-C2-0016
SO_2	N/a	N/a

RESPONSE TIME		
	TIME (hh:mm)	**RESP (min)**
1st Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
2nd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		
3rd Gas Inject		
1st Inst. @ 95%		
2nd Inst. @ 95%		
3rd Inst. @ 95%		

CALIBRATION	O_2		NOx		CO		THC		CO_2		SO_2	
	Conc.	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**	**Conc.**	**Actual**
Zero Gas	0	-0.002	0	0.02	0	0.012	0	0.005	0	-0.017	N/a	N/a
Low Gas	N/a	N/a	N/a	N/a	N/a	N/a	3.03	3.01	N/a	N/a	N/a	N/a
Mid Gas	11.98	11.97	4.55	4.69	5.22	5.1	5.19	4.96	8.91	9.32	N/a	N/a
High Gas	20.9	21.1	8.9	8.83	9.1	9.05	8.78	8.7	18.9	18.93	N/a	N/a

BIAS	O_2		NOx		CO		THC		CO_2		SO_2	
	Zero	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**	**Zero**	**Mid**
Initial Run #1	0.03	11.88	0.06	4.53	-0.05	5.16	0.005	3.01	-0.01	9.02	N/a	N/a
Run #1 / Run #2	0.07	11.84	0.23	4.61	0.05	5.1	0	3.11	0.09	8.94	N/a	N/a
Run #2 / Run #3	0.05	11.83	0.22	4.64	0.05	5.14	0.004	3.13	0.1	8.96	N/a	N/a
Run #3 / Final	0.08	11.83	0.15	4.64	-0.04	5.25	-0.003	3.16	0.11	8.9	N/a	N/a
Bias Gas Actual Conc.		11.98		4.55		5.22		5.19		8.91		N/a

Signature _____

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data Summary Base Load PM_{10}

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	04/15/20
Sampling Location	U-00003 Base	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#3		

Run History Data				
Run Number	PM U-00003 Base-1	PM U-00003 Base-2	PM U-00003 Base-3	
Run Start Time	08:23	13:45	06:46	(hh:mm)
Run Stop Time	12:46	18:02	11:15	(hh:mm)
Train Prepared By	RW	RW	RW	
Train Recovered By	RW	RW	RW	
Recovery Date	04/15/20	04/15/20	04/16/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	04/18/20	04/18/20	04/18/20	(mm/dd/yy)
Relinquished Time	07:12	12:30	12:30	(hh:mm)

Equipment Identification Numbers			
Impinger Case	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039
Sample Box	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099
PM Filter	19031839	19031840	19031831
CPM Filter	PM U-00003 Base-1-CPM	PM U-00003 Base-2-CPM	PM U-00003 Base-3-CPM

Sample Blank Taken	☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	1873.7	1828.1	1757.9	g
Initial Weight	(W_i)	1706.5	1670.9	1713.3	g
Net Weight	(W_n)	167.2	157.2	44.6	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	951.6	936.8	1060.0	g
Initial Weight	(W_i)	927.8	909.6	952.3	g
Net Weight	(W_n)	23.8	27.2	107.7	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	191.0	184.4	152.3	g
Total Volume	(V_{lc})	191.3	184.7	152.6	ml

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base-1		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations

Blank Type	Weight	Volume	Concentration	Mass	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL, (1) negative results observed

Gravimetric Concentrations			**Run**		1	**Start Time**	08:23
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*(1)	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			17.5	78	0.0000	17.5000	
Cyclone Wash 2.5<PM<10			1.0	75	0.0000	1.0000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.6	61	0.0000	1.6000	
Inorganic Impinger Contents			3.3	461	1.4762	1.8238	
Organic Impinger Contents			2.4	364	0.5238	1.8762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base-2		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL

Gravimetric Concentrations			**Run**		2	**Start Time**	13:45
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.5000	--	--	0.5000	
Filter Beaker				--	--		
Nozzle Wash PM>10			9.3	72	0.0000	9.3000	
Cyclone Wash 2.5<PM<10			1.3	66	0.0000	1.3000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.4	61	0.0000	1.4000	
Inorganic Impinger Contents			2.2	361	1.4762	0.7238	
Organic Impinger Contents			1.9	303	0.5238	1.3762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base-3		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations

Blank Type	Weight	Volume	Concentration	Mass	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL, (1) negative results observed

Gravimetric Concentrations			**Run**		3	**Start Time**	06:46
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*(1)	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			14.1	60	0.0000	14.1000	
Cyclone Wash 2.5<PM<10			1.0	66	0.0000	1.0000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.2	36	0.0000	1.2000	
Inorganic Impinger Contents			2.2	381	1.4762	0.7238	
Organic Impinger Contents			1.5	334	0.5238	0.9762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base-FB		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Gravimetric Concentrations					
Sample Portion	**Final**	**Tare**	**Gain**		**Actual Gain**
	(g)	(g)	(mg)		(mg)
Inorganic Impinger Contents	0.0031	0.0000	1.4762	max 2 mg total blank adjustment, proportioned	3.1000
Organic Impinger Contents	0.0011	0.0000	0.5238		1.1000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data Summary Base+DB Load PM_{10}

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	04/16/20
Sampling Location	U-00003 Base+DB	**Operator**	Rob White
Project #	bec-19-cricketvalley.ny-start#3		

Run History Data				
Run Number	PM U-00003 Base+DB-1	PM U-00003 Base+DB-2	PM U-00003 Base+DB-3	
Run Start Time	12:23	04:15	09:35	(hh:mm)
Run Stop Time	16:49	08:34	14:03	(hh:mm)
Train Prepared By	RW	RW	RW	
Train Recovered By	RW	RW	RW	
Recovery Date	04/16/20	04/17/20	04/17/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	04/18/20	04/18/20	04/18/20	(mm/dd/yy)
Relinquished Time	12:30	12:30	12:30	(hh:mm)

Equipment Identification Numbers			
Impinger Case	SAMP-BH-0039	SAMP-BH-0039	SAMP-BH-0039
Sample Box	SAMP-SBC-0099	SAMP-SBC-0099	SAMP-SBC-0099
PM Filter	19031829	19031826	18081503
CPM Filter	PM U-00003 Base+DB-1-CPM	PM U-00003 Base+DB-2-CPM	PM U-00003 Base+DB-3-CPM

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	1845.2	1793.6	1860.0	g
Initial Weight	(W_i)	1673.6	1607.6	1671.0	g
Net Weight	(W_n)	171.6	186.0	189.0	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	884.6	988.0	901.3	g
Initial Weight	(W_i)	856.0	963.4	875.4	g
Net Weight	(W_n)	28.6	24.6	25.9	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	200.2	210.6	214.9	g
Total Volume	(V_{lc})	200.6	211.0	215.3	ml

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base+DB-1		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

Gravimetric Concentrations			**Run**		1	**Start Time**	12:23
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.5000	--	--	0.5000	
Filter Beaker				--	--		
Nozzle Wash PM>10			8.3	70	0.0000	8.3000	
Cyclone Wash 2.5<PM<10			1.1	60	0.0000	1.1000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.5	73	0.0000	1.5000	
Inorganic Impinger Contents			2.1	381	1.4762	0.6238	
Organic Impinger Contents		*	1.0	288	0.5238	0.4762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base+DB-2		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

Gravimetric Concentrations			**Run**		2	**Start Time**	04:15
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter			0.7000	--	--	0.7000	
Filter Beaker				--	--		
Nozzle Wash PM>10			10.9	76	0.0000	10.9000	
Cyclone Wash 2.5<PM<10			1.0	76	0.0000	1.0000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.3	62	0.0000	1.3000	
Inorganic Impinger Contents			3.7	381	1.4762	2.2238	
Organic Impinger Contents			1.1	319	0.5238	0.5762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base+DB-3		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Filter	BV Labs		
Nozzle Wash PM>10	BV Labs		
Cyclone Wash 2.5<PM<10	BV Labs		
Cyclone Exit to Front Half of Filter Wash (<2.5)	BV Labs		
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Blank and Titration Concentrations					
Blank Type	**Weight**	**Volume**	**Concentration**	**Mass**	
	(g)	(ml)	(mg/ml)	(mg)	
Acetone Blank Weight of Solids	0.0000	201	0.000000	--	below RDL
DI Water Blank Weight of Solids	0.0000	197	0.000000	--	below RDL
Hexane Blank Weight of Solids	0.0000	228	0.000000	--	below RDL

* Reported at RDL

Gravimetric Concentrations			**Run**		3	**Start Time**	09:35
Sample Portion	**Final**	**Tare**	**Gain**	**Volume**	**Blank Adjustment**	**Adjusted Gain**	
	(g)	(g)	(mg)	(ml)	(mg)	(mg)	
Filter		*	0.3000	--	--	0.3000	
Filter Beaker				--	--		
Nozzle Wash PM>10			1.4	61	0.0000	1.4000	
Cyclone Wash 2.5<PM<10			3.5	69	0.0000	3.5000	
Cyclone Exit to Front Half of Filter Wash (<2.5)			1.2	70	0.0000	1.2000	
Inorganic Impinger Contents			2.1	331	1.4762	0.6238	
Organic Impinger Contents			1.4	288	0.5238	0.8762	

SAMPLE ANALYTICAL DATA SHEET

Plant Name	Cricket Valley Energy Center
Sampling Location	U-00003 Base+DB
Project #	bec-19-cricketvalley.ny-start#3

Analytical Data		**Run**	PM U-00003 Base+DB-FB		
Sample Leakage Evident	NO	**Estimated Leak Volume**		0.00	(mg)

Sample Type	Sample Number	Date	Time
Inorganic Impinger Contents	BV Labs		
Organic Impinger Contents	BV Labs		

Gravimetric Concentrations					
Sample Portion	**Final**	**Tare**	**Gain**		**Actual Gain**
	(g)	(g)	(mg)		(mg)
Inorganic Impinger Contents	0.0031	0.0000	1.4762	max 2 mg total blank adjustment, proportioned	3.1000
Organic Impinger Contents	0.0011	0.0000	0.5238		1.1000

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Field Collection Data QA SAM

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	04/15/20
Sampling Location	U-00003 Base	**Operator**	GT
Project #	bec-19-cricketvalley.ny-start#3		

Run History Data				
Run Number	SAM U-00003 Base-1	SAM U-00003 Base-2	SAM U-00003 Base-3	
Run Start Time	13:56	06:24	08:57	(hh:mm)
Run Stop Time	15:56	08:24	10:57	(hh:mm)
Train Prepared By	AM	AM	AM	
Train Recovered By	AM	AM	AM	
Recovery Date	03/09/20	03/09/20	03/09/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	03/12/20	03/12/20	03/12/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	samp-bh-0013	samp-bh-0013	samp-bh-0013
Sample Box	samp-bc-0032	samp-bc-0032	samp-bc-0032
Filter	R0001	R0001	R0001

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	2018.1	2089.8	2157.0	g
Initial Weight	(W_i)	1953.5	2018.1	2089.8	g
Net Weight	(W_n)	64.6	71.7	67.2	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	946.2	955.1	966.2	g
Initial Weight	(W_i)	932.8	946.2	955.1	g
Net Weight	(W_n)	13.4	8.9	11.1	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	78.0	80.6	78.3	g
Total Volume	(V_{lc})	78.1	80.7	78.4	ml

SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Cricket Valley Energy Center	**Date**	04/16/20
Sampling Location	U-00003 Base+DB	**Operator**	GT
Project #	bec-19-cricketvalley.ny-start#3		

Run History Data				
Run Number	SAM U-00003 Base+DB-1	SAM U-00003 Base+DB-2	SAM U-00003 Base+DB-3	
Run Start Time	13:10	03:58	07:00	(hh:mm)
Run Stop Time	15:10	05:58	09:00	(hh:mm)
Train Prepared By	AM	AM	AM	
Train Recovered By	AM	AM	AM	
Recovery Date	03/09/20	03/09/20	03/09/20	(mm/dd/yy)
Relinquished By	RW	RW	RW	
Received By	Courier	Courier	Courier	
Relinquished Date	03/12/20	03/12/20	03/12/20	(mm/dd/yy)
Relinquished Time	14:20	14:20	14:20	(hh:mm)

Equipment Identification Numbers			
Impinger Case	samp-bh-0013	samp-bh-0013	samp-bh-0013
Sample Box	samp-bc-0032	samp-bc-0032	samp-bc-0032
Filter	R0001	R0001	R0001

Sample Blank Taken ☑ YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
Final Weight	(W_f)	2039.7	2040.7	2120.5	g
Initial Weight	(W_i)	1963.2	1960.5	2040.7	g
Net Weight	(W_n)	76.5	80.2	79.8	g
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W_f)	928.5	938.6	929.6	g
Initial Weight	(W_i)	913.9	928.5	921.8	g
Net Weight	(W_n)	14.6	10.1	7.8	g
Comments					
Total Water Collected					
Total Weight	(W_{lc})	91.1	90.3	87.6	g
Total Volume	(V_{lc})	91.3	90.5	87.8	ml

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data PM_{10} and SAM
BV Labs

Your Project #: BEC-19-CRICKETVALLEY.NY-START

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/04/27
Report #: R6156688
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C097773
Received: 2020/04/18, 19:45

Sample Matrix: Stack Sampling Train
Samples Received: 18

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Extractable Condensables (M202)	6	2020/04/21	2020/04/24	BRL SOP-00118	EPA 202 m
Non Extractable Condensibles (M202)	6	2020/04/21	2020/04/22	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
>10um Particulates in Rinse	6	2020/04/22	2020/04/24	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	6	2020/04/22	2020/04/24	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	6	N/A	2020/04/22	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	6	2020/04/22	2020/04/24	BRL SOP-00109	EPA M201A
H2SO4 Acid Mist in IPA Impinger (M8mod)	6	2020/04/24	2020/04/24	BRL SOP-00105	EPA 8 m
Sulphuric Acid Mist by Titration (M8A)	6	2020/04/27	2020/04/27	BRL SOP-00116	EPA CFR PTM 8 m
Final Volume of Acetone Probe Rinse	6	N/A	2020/04/22	BRL SOP-00109	
Final Volume of Impinger	6	N/A	2020/04/24		
Weight of Solvent from Impingers	6	N/A	2020/04/21		
Weight of Water from Impingers	6	N/A	2020/04/21		

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.
Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.
This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

Your Project #: BEC-19-CRICKETVALLEY.NY-START

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/04/27
Report #: R6156688
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C097773
Received: 2020/04/18, 19:45

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.
* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key

AUTHORIZED REPORT
RAPPORT AUTORISÉ

Bureau Veritas Laboratories
27 Apr 2020 17:21:33

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: Clayton.Johnson@bvlabs.com
Phone# (905)817-5769

==========

This report has been generated and distributed using a secure automated process.
BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

BV Labs ID		MMC518	MMC519	MMC520		
Sampling Date		2020/04/16	2020/04/17	2020/04/17		
	UNITS	M201A- U3 BASE W/DB- R1	M201A- U3 BASE W/DB- R2	M201A- U3 BASE W/DB- R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	8.3	10.9	1.4	0.5	6692255
< 2.5 Particulate Weight in Acetone Rinse	mg	1.5	1.3	1.2	0.5	6692239
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.1	1.0	3.5	0.5	6692253
< 2.5 Particulate Weight on Filter	mg	0.50	0.70	<0.30	0.30	6692295
Acetone Rinse Volume (10)	ml	70	76	61	1	6692260
Acetone Rinse Volume (2.5 - 10)	ml	60	76	69	1	6692260
Acetone Rinse Volume (2.5)	ml	73	62	70	1	6692260

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC521	MMC522	MMC523		
Sampling Date		2020/04/15	2020/04/15	2020/04/15		
	UNITS	M201A- U3 BASE-R1	M201A- U3 BASE-R2	M201A- U3 BASE-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	17.5	9.3	14.1	0.5	6692255
< 2.5 Particulate Weight in Acetone Rinse	mg	1.6	1.4	1.2	0.5	6692239
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.0	1.3	1.0	0.5	6692253
< 2.5 Particulate Weight on Filter	mg	<0.30 (1)	0.50	<0.30 (1)	0.30	6692295
Acetone Rinse Volume (10)	ml	78	72	60	1	6692260
Acetone Rinse Volume (2.5 - 10)	ml	75	66	66	1	6692260
Acetone Rinse Volume (2.5)	ml	61	61	36	1	6692260

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative result observed

LFT Loose filter material in the petri dish
DE Edges of the filter are frayed

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

BV Labs ID		MMC512	MMC513	MMC514		
Sampling Date		2020/04/16	2020/04/17	2020/04/17		
	UNITS	M202- U3 BASE W/DB-R1	M202- U3 BASE W/DB-R2	M202- U3 BASE W/DB-R3	RDL	QC Batch
Weight	g	380	380	330	0.1	6690925
Weight of Solvent	g	190	210	190	0.1	6690922
Miscellaneous Parameters						
Inorganic Condensibles	mg	2.1	3.7	2.1	0.5	6690928
Organic Condensibles	mg	<1.0	1.1	1.4	1.0	6690921

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC515	MMC516	MMC517		
Sampling Date		2020/04/15	2020/04/15	2020/04/15		
	UNITS	M202- U3 BASE-R1	M202- U3 BASE-R2	M202- U3 BASE-R3	RDL	QC Batch
Weight	g	460	360	380	0.1	6690925
Weight of Solvent	g	240	200	220	0.1	6690922
Miscellaneous Parameters						
Inorganic Condensibles	mg	3.3	2.2	2.2	0.5	6690928
Organic Condensibles	mg	2.4	1.9	1.5	1.0	6690921

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

BV Labs ID		MMC524		MMC525	MMC525		
Sampling Date		2020/04/16		2020/04/17	2020/04/17		
	UNITS	M8A- U3 BASE W/DB-R1	RDL	M8A- U3 BASE W/DB-R2	M8A- U3 BASE W/DB-R2 Lab-Dup	RDL	QC Batch
Impinger Volume	ml	166	1	103	N/A	1	6696057
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.017	0.017	0.060	0.058	0.011	6696051

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

BV Labs ID		MMC526		MMC527	MMC528		
Sampling Date		2020/04/17		2020/04/15	2020/04/16		
	UNITS	M8A- U3 BASE W/DB-R3	RDL	M8A- U3 BASE- R1 -CW	M8A- U3 BASE- R2 -CW	RDL	QC Batch
Impinger Volume	ml	108	1	125	132	1	6696057
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	0.017	0.011	0.047	0.094	0.013	6696051

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC529		
Sampling Date		2020/04/16		
	UNITS	M8A- U3 BASE- R3 -CW	RDL	QC Batch
Impinger Volume	ml	183	1	6696057
Miscellaneous Parameters				
Sulphuric Acid Mist	mg	<0.019	0.019	6696051

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

INDUSTRIAL HYGIENE (STACK SAMPLING TRAIN)

BV Labs ID		MMC524		MMC525	MMC525		
Sampling Date		2020/04/16		2020/04/17	2020/04/17		
	UNITS	M8A- U3 BASE W/DB-R1	RDL	M8A- U3 BASE W/DB-R2	M8A- U3 BASE W/DB-R2 Lab-Dup	RDL	QC Batch
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.66	0.66	<0.41	<0.41	0.41	6698432

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate

BV Labs ID		MMC526		MMC527		MMC528		
Sampling Date		2020/04/17		2020/04/15		2020/04/16		
	UNITS	M8A- U3 BASE W/DB-R3	RDL	M8A- U3 BASE- R1 -CW	RDL	M8A- U3 BASE- R2 -CW	RDL	QC Batch
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	<0.43	0.43	<0.5	0.5	<0.53	0.53	6698432

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC529		
Sampling Date		2020/04/16		
	UNITS	M8A- U3 BASE- R3 -CW	RDL	QC Batch
Miscellaneous Parameters				
Sulphuric Acid Mist	mg	<0.73	0.73	6698432

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MMC512 **Collected:** 2020/04/16
Sample ID: M202- U3 BASE W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC513 **Collected:** 2020/04/17
Sample ID: M202- U3 BASE W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC514 **Collected:** 2020/04/17
Sample ID: M202- U3 BASE W/DB- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC515 **Collected:** 2020/04/15
Sample ID: M202- U3 BASE- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC516 **Collected:** 2020/04/15
Sample ID: M202- U3 BASE- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MMC517 **Collected:** 2020/04/15
Sample ID: M202- U3 BASE- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC518 **Collected:** 2020/04/16
Sample ID: M201A- U3 BASE W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC519 **Collected:** 2020/04/17
Sample ID: M201A- U3 BASE W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC520 **Collected:** 2020/04/17
Sample ID: M201A- U3 BASE W/DB- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC521 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MMC521 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC522 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC523 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC524 **Collected:** 2020/04/16
Sample ID: M8A- U3 BASE W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC525 **Collected:** 2020/04/17
Sample ID: M8A- U3 BASE W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MMC525 Dup
Sample ID: M8A- U3 BASE W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/04/17
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota

BV Labs ID: MMC526
Sample ID: M8A- U3 BASE W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/04/17
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC527
Sample ID: M8A- U3 BASE- R1 -CW
Matrix: Stack Sampling Train

Collected: 2020/04/15
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC528
Sample ID: M8A- U3 BASE- R2 -CW
Matrix: Stack Sampling Train

Collected: 2020/04/16
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC529
Sample ID: M8A- U3 BASE- R3 -CW
Matrix: Stack Sampling Train

Collected: 2020/04/16
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

GENERAL COMMENTS

Sample MMC512 [M202- U3 BASE W/DB- R1] : ORGANIC EXTRACTION :Light oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC513 [M202- U3 BASE W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC514 [M202- U3 BASE W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC515 [M202- U3 BASE- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC516 [M202- U3 BASE- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC517 [M202- U3 BASE- R3] : ORGANIC EXTRACTION : Visual oily extract residue found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Results relate only to the items tested.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

BV Labs Job #: C097773
Report Date: 2020/04/27

Air Hygiene International Inc
Client Project #: BEC-19-CRICKETVALLEY.NY-START
Sampler Initials: RW

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
6690921	MOR	Spiked Blank	Organic Condensibles	2020/04/24		99	%	70 - 130
6690921	MOR	Method Blank	Organic Condensibles	2020/04/24	<1.0		mg	
6690928	MOR	Method Blank	Inorganic Condensibles	2020/04/24	<0.5		mg	
6692239	MOR	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2020/04/24	<0.5		mg	
6692253	MOR	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2020/04/24	<0.5		mg	
6692255	MOR	Method Blank	> 10 Particulate Weight in Acetone Rinse	2020/04/24	<0.5		mg	
6696051	LLE	Matrix Spike(MMC525)	Sulphuric Acid Mist	2020/04/24		93	%	80 - 120
6696051	LLE	Spiked Blank	Sulphuric Acid Mist	2020/04/24		98	%	90 - 110
6696051	LLE	Method Blank	Sulphuric Acid Mist	2020/04/24	<0.01		mg	
6696051	LLE	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/04/24	3.4		%	20
6698432	RSU	Matrix Spike(MMC525)	Sulphuric Acid Mist	2020/04/27		98	%	80 - 120
6698432	RSU	Spiked Blank	Sulphuric Acid Mist	2020/04/27		98	%	90 - 110
6698432	RSU	Method Blank	Sulphuric Acid Mist	2020/04/27	<0.2		mg	
6698432	RSU	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/04/27	NC		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.


Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).


Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Ann-Marie Stern, Team Lead, Inorganic



Brenda Moore, Team Lead, Inorganic



Frank Mo, B.Sc., Inorganic Lab. Manager

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3	Laboratory Analysis Requested:
Person Taking Samples:	Rob White	Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	--	--
PM U-00003 Base w/DB-1-F	Unit PM U-00003 Base w/DB - Run 1 - Filter	04/16/20	N/A	X			
PM U-00003 Base w/DB-1-C2	Unit PM U-00003 Base w/DB - Run 1 - Nozzle Wash PM>10	04/16/20		X			
PM U-00003 Base w/DB-1-C3	Unit PM U-00003 Base w/DB - Run 1 - Cyclone Wash 2.5<PM<10	04/16/20		X			
PM U-00003 Base w/DB-1-C4	Unit PM U-00003 Base w/DB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/16/20	N/A	X			
PM U-00003 Base w/DB-1-C5	Unit PM U-00003 Base w/DB - Run 1 - Inorganic Impinger Contents	04/16/20			X		
PM U-00003 Base w/DB-1-C6	Unit PM U-00003 Base w/DB - Run 1 - Organic Impinger Contents	04/16/20			X		
PM U-00003 Base w/DB-1-CPM	Unit PM U-00003 Base w/DB - Run 1 - CPM Filter	04/16/20	N/A		X		
PM U-00003 Base w/DB-2-F	Unit PM U-00003 Base w/DB - Run 2 - Filter	04/17/20	N/A	X			
PM U-00003 Base w/DB-2-C2	Unit PM U-00003 Base w/DB - Run 2 - Nozzle Wash PM>10	04/17/20		X			
PM U-00003 Base w/DB-2-C3	Unit PM U-00003 Base w/DB - Run 2 - Cyclone Wash 2.5<PM<10	04/17/20		X			
PM U-00003 Base w/DB-2-C4	Unit PM U-00003 Base w/DB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/17/20	N/A	X			
PM U-00003 Base w/DB-2-C5	Unit PM U-00003 Base w/DB - Run 2 - Inorganic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-2-C6	Unit PM U-00003 Base w/DB - Run 2 - Organic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-2-CPM	Unit PM U-00003 Base w/DB - Run 2 - CPM Filter	04/17/20	N/A		X		
PM U-00003 Base w/DB-3-F	Unit PM U-00003 Base w/DB - Run 3 - Filter	04/17/20	N/A	X			
PM U-00003 Base w/DB-3-C2	Unit PM U-00003 Base w/DB - Run 3 - Nozzle Wash PM>10	04/17/20		X			
PM U-00003 Base w/DB-3-C3	Unit PM U-00003 Base w/DB - Run 3 - Cyclone Wash 2.5<PM<10	04/17/20		X			
PM U-00003 Base w/DB-3-C4	Unit PM U-00003 Base w/DB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/17/20	N/A	X			
PM U-00003 Base w/DB-3-C5	Unit PM U-00003 Base w/DB - Run 3 - Inorganic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-3-C6	Unit PM U-00003 Base w/DB - Run 3 - Organic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-3-CPM	Unit PM U-00003 Base w/DB - Run 3 - CPM Filter	04/17/20	N/A		X		

Signature 4/18 12:00 Signature Date Time

Signature DAVID CHAN 2020/04/18 19:45 Signature Date Time

Signature Date Time

Signature Date Time

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3
Person Taking Samples:	Rob White

Sample Number	Location	Date	Volume	Laboratory Analysis Requested: Gravimetric Analysis Method RM 201A	RM 202	--	--
PM U-00003 Base-1-F	Unit PM U-00003 Base - Run 1 - Filter	04/15/20	N/A	X			
PM U-00003 Base-1-C2	Unit PM U-00003 Base - Run 1 - Nozzle Wash PM>10	04/15/20		X			
PM U-00003 Base-1-C3	Unit PM U-00003 Base - Run 1 - Cyclone Wash 2.5<PM<10	04/15/20		X			
PM U-00003 Base-1-C4	Unit PM U-00003 Base - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/15/20	N/A	X			
PM U-00003 Base-1-C5	Unit PM U-00003 Base - Run 1 - Inorganic Impinger Contents	04/15/20			X		
PM U-00003 Base-1-C6	Unit PM U-00003 Base - Run 1 - Organic Impinger Contents	04/15/20			X		
PM U-00003 Base-1-CPM	Unit PM U-00003 Base - Run 1 - CPM Filter	04/15/20	N/A		X		
PM U-00003 Base-2-F	Unit PM U-00003 Base - Run 2 - Filter	04/15/20	N/A	X			
PM U-00003 Base-2-C2	Unit PM U-00003 Base - Run 2 - Nozzle Wash PM>10	04/15/20		X			
PM U-00003 Base-2-C3	Unit PM U-00003 Base - Run 2 - Cyclone Wash 2.5<PM<10	04/15/20		X			
PM U-00003 Base-2-C4	Unit PM U-00003 Base - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/15/20	N/A	X			
PM U-00003 Base-2-C5	Unit PM U-00003 Base - Run 2 - Inorganic Impinger Contents	04/15/20			X		
PM U-00003 Base-2-C6	Unit PM U-00003 Base - Run 2 - Organic Impinger Contents	04/15/20			X		
PM U-00003 Base-2-CPM	Unit PM U-00003 Base - Run 2 - CPM Filter	04/15/20	N/A		X		
PM U-00003 Base-3-F	Unit PM U-00003 Base - Run 3 - Filter	04/15/20	N/A	X			
PM U-00003 Base-3-C2	Unit PM U-00003 Base - Run 3 - Nozzle Wash PM>10	04/15/20		X			
PM U-00003 Base-3-C3	Unit PM U-00003 Base - Run 3 - Cyclone Wash 2.5<PM<10	04/15/20		X			
PM U-00003 Base-3-C4	Unit PM U-00003 Base - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/15/20	N/A	X			
PM U-00003 Base-3-C5	Unit PM U-00003 Base - Run 3 - Inorganic Impinger Contents	04/15/20			X		
PM U-00003 Base-3-C6	Unit PM U-00003 Base - Run 3 - Organic Impinger Contents	04/15/20			X		
PM U-00003 Base-3-CPM	Unit PM U-00003 Base - Run 3 - CPM Filter	04/15/20	N/A		X		

RW 4/18 9:00
Signature Date Time

DAVID CHAN 2020/04/18 19:45
Signature Date Time

Signature Date Time

Signature Date Time

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White

Phone: (918) 307-8865

Email:

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3			Laboratory Analysis Requested:			
Person Taking Samples:	GT			Titration			
Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
SAM U-00003 Base-1-CW	Unit SAM U-00003 Base - Run 1 - Condenser Wash w/1773	04/16/20			IC		
SAM U-00003 Base-2-CW	Unit SAM U-00003 Base - Run 2 - Condenser Wash	04/17/20			IC		
SAM U-00003 Base-3-CW	Unit SAM U-00003 Base - Run 3 - Condenser Wash	04/17/20			IC		

Signature 4/18/20 Date 12:00 Time

Signature Date Time

Signature DAVID CHAN 2020/04/18 Date 19:45 Time

Signature Date Time

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White

Phone: (918) 307-8865

Email:

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3			Laboratory Analysis Requested:			
Person Taking Samples:	GT			Titration			
Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
SAM U-00003 Base-1-CW	Unit SAM U-00003 Base - Run 1 - Condenser Wash	04/15/20			TC		
SAM U-00003 Base-2-CW	Unit SAM U-00003 Base - Run 2 - Condenser Wash	04/16/20			TC		
SAM U-00003 Base-3-CW	Unit SAM U-00003 Base - Run 3 - Condenser Wash	04/16/20			TC		

RGM 4/18 0:00
Signature Date Time

DAVID CHAN 2020/04/18 19:45
Signature Date Time

Signature Date Time

Signature Date Time

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Laboratory Data PM_{10} and SAM Blanks
BV Labs [U-00001 Report]

Your Project #: BEC-19-CRICKETVALLEY.NY-START1

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/03
Report #: R6096087
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C048069
Received: 2020/02/21, 17:15

Sample Matrix: Stack Sampling Train
Samples Received: 23

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Extractable Condensables (M202)	9	2020/02/27	2020/02/26	BRL SOP-00118	EPA 202 m
Non Extractable Condensibles (M202)	8	2020/02/27	2020/02/27	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
>10um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	7	N/A	2020/02/26	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	7	2020/02/27	2020/02/28	BRL SOP-00109	EPA M201A
Sulphuric Acid Mist by Titration (M8A)	7	2020/03/02	2020/03/02	BRL SOP-00116	EPA CFR PTM 8 m
Final Volume of Acetone Probe Rinse	7	N/A	2020/02/26	BRL SOP-00109	
Final Volume of Impinger	7	N/A	2020/03/02		
Weight of Solvent from Impingers	9	N/A	2020/02/26		
Weight of Water from Impingers	8	N/A	2020/02/26		

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.
Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.
This Certificate shall not be reproduced except in full, without the written approval of the laboratory.
Reference Method suffix “m” indicates test methods incorporate validated modifications from specific reference methods to improve performance.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Your Project #: BEC-19-CRICKETVALLEY.NY-START1

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/03/03
Report #: R6096087
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C048069
Received: 2020/02/21, 17:15

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key



Bureau Veritas Laboratories
03 Mar 2020 16:17:38

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: Clayton.Johnson@bvlabs.com
Phone# (905)817-5769

==========

This report has been generated and distributed using a secure automated process.
BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

BV Labs ID		MBP551	MBP552	MBP553	MBP554		
Sampling Date			2020/02/18	2020/02/18	2020/02/18		
	UNITS	M201A- BLANK	M201A- W/DB-R1	M201A- W/DB-R2	M201A- W/DB-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	1.2	1.1	13.9	1.2	0.5	6608986
< 2.5 Particulate Weight in Acetone Rinse	mg	1.9	1.7	1.7	1.4	0.5	6608981
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.7	0.9	1.4	1.8	0.5	6608984
< 2.5 Particulate Weight on Filter	mg	<0.30	<0.30 (1)	<0.30	<0.30 (2)	0.30	6607770
Acetone Rinse Volume (10)	ml	110	140	110	120	1	6608983
Acetone Rinse Volume (2.5 - 10)	ml	91	120	99	130	1	6608983
Acetone Rinse Volume (2.5)	ml	100	120	120	130	1	6608983

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative weight observed

LFT Loose filter material in the petri dish
DE Edges of the filter are frayed
(2) Negative weight observed

BV Labs ID		MBP556	MBP557	MBP558		
Sampling Date		2020/02/17	2020/02/17	2020/02/17		
	UNITS	M201A- W/ODB-R1	M201A- W/ODB-R2	M201A- W/ODB-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	16.2	14.5	14.0	0.5	6608986
< 2.5 Particulate Weight in Acetone Rinse	mg	1.7	2.7	1.7	0.5	6608981
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.3	1.7	1.5	0.5	6608984
< 2.5 Particulate Weight on Filter	mg	<0.30 (1)	<0.30 (2)	<0.30 (3)	0.30	6607770
Acetone Rinse Volume (10)	ml	100	110	97	1	6608983
Acetone Rinse Volume (2.5 - 10)	ml	130	130	85	1	6608983
Acetone Rinse Volume (2.5)	ml	130	130	63	1	6608983

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative weight observed

WET Filters was received wet
(2) Negative weight observed
(3) Negtive results observed

WET Filters were received wet
LFT Loose filter material in the petri dish
DE Edges of the filter are frayed

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

BV Labs ID		MBP535	MBP536	MBP537	MBP538		
Sampling Date							
	UNITS	M8A/M202- DI WATER BLANK	M202- HEXANE BLANK	M202- ACETONE BLANK	M202- FB	RDL	QC Batch
Weight	g	200	N/A	N/A	440	0.1	6608740
Weight of Solvent	g	N/A	130	150	320	0.1	6608738
Miscellaneous Parameters							
Inorganic Condensibles	mg	<0.5	N/A	N/A	3.1	0.5	6608739
Organic Condensibles	mg	N/A	<1.0	<1.0	1.1	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
N/A = Not Applicable

BV Labs ID		MBP539	MBP540	MBP541	MBP543	MBP544		
Sampling Date		2020/02/18	2020/02/18	2020/02/18	2020/02/17	2020/02/17		
	UNITS	M202- W/DB-R1	M202- W/DB-R2	M202- W/DB-R3	M202- W/ODB-R1	M202- W/ODB-R2	RDL	QC Batch
Weight	g	370	470	390	500	440	0.1	6608740
Weight of Solvent	g	220	280	210	150	230	0.1	6608738
Miscellaneous Parameters								
Inorganic Condensibles	mg	4.6	3.7	3.8	4.6	4.2	0.5	6608739
Organic Condensibles	mg	1.3	1.2	<1.0	1.6	2.4	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MBP545		
Sampling Date		2020/02/17		
	UNITS	M202- W/ODB-R3	RDL	QC Batch
Weight	g	440	0.1	6608740
Weight of Solvent	g	230	0.1	6608738
Miscellaneous Parameters				
Inorganic Condensibles	mg	3.6	0.5	6608739
Organic Condensibles	mg	<1.0	1.0	6608735

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

BV Labs ID		MBP535		MBP785	MBP785		
Sampling Date				2020/02/17	2020/02/17		
	UNITS	M8A/M202- DI WATER BLANK	RDL	M8A- W/DB- R1-CW	M8A- W/DB- R1-CW Lab-Dup	RDL	QC Batch
Impinger Volume	ml	196	1	232	N/A	1	6613884
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.78	0.78	<0.93	<0.93	0.93	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

BV Labs ID		MBP801		MBP802		MBP805		
Sampling Date		2020/02/17		2020/02/17		2020/02/18		
	UNITS	M8A- W/DB- R2-CW	RDL	M8A- W/DB- R3-CW	RDL	M8A- W/ODB- R1-CW	RDL	QC Batch
Impinger Volume	ml	194	1	254	1	191	1	6613884
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	<0.78	0.78	<1	1	<0.76	0.76	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MBP806		MBP807		
Sampling Date		2020/02/18		2020/02/18		
	UNITS	M8A- W/ODB- R2-CW	RDL	M8A- W/ODB- R3-CW	RDL	QC Batch
Impinger Volume	ml	197	1	232	1	6613884
Miscellaneous Parameters						
Sulphuric Acid Mist	mg	<0.79	0.79	<0.93	0.93	6613883

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP535 **Collected:**
Sample ID: M8A/M202- DI WATER BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP536 **Collected:**
Sample ID: M202- HEXANE BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP537 **Collected:**
Sample ID: M202- ACETONE BLANK **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP538 **Collected:**
Sample ID: M202- FB **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP539 **Collected:** 2020/02/18
Sample ID: M202- W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP540 **Collected:** 2020/02/18
Sample ID: M202- W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP540
Sample ID: M202- W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP541
Sample ID: M202- W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP543
Sample ID: M202- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP544
Sample ID: M202- W/ODB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP545
Sample ID: M202- W/ODB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6608735	2020/02/27	2020/02/26	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6608739	2020/02/27	2020/02/27	Muhammad M Rahman
Weight of Solvent from Impingers		6608738	N/A	2020/02/26	Muhammad M Rahman
Weight of Water from Impingers		6608740	N/A	2020/02/26	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP551
Sample ID: M201A- BLANK
Matrix: Stack Sampling Train

Collected:
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP552
Sample ID: M201A- W/DB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP553
Sample ID: M201A- W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP554
Sample ID: M201A- W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP556
Sample ID: M201A- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP556
Sample ID: M201A- W/ODB- R1
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP557
Sample ID: M201A- W/ODB- R2
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP558
Sample ID: M201A- W/ODB- R3
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6608986	2020/02/27	2020/02/28	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6608984	2020/02/27	2020/02/28	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6607770	N/A	2020/02/26	Brenda Moore
<2.5um Particulates in Rinse	BAL	6608981	2020/02/27	2020/02/28	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6608983	N/A	2020/02/26	Muhammad M Rahman

BV Labs ID: MBP785
Sample ID: M8A- W/DB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP785 Dup
Sample ID: M8A- W/DB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota

BV Labs ID: MBP801
Sample ID: M8A- W/DB- R2- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MBP802
Sample ID: M8A- W/DB- R3- CW
Matrix: Stack Sampling Train

Collected: 2020/02/17
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP805
Sample ID: M8A- W/ODB- R1- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP806
Sample ID: M8A- W/ODB- R2- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

BV Labs ID: MBP807
Sample ID: M8A- W/ODB- R3- CW
Matrix: Stack Sampling Train

Collected: 2020/02/18
Shipped:
Received: 2020/02/21

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Sulphuric Acid Mist by Titration (M8A)	MT	6613883	2020/03/02	2020/03/02	Rupinder Sihota
Final Volume of Impinger		6613884	N/A	2020/03/02	Rupinder Sihota

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

GENERAL COMMENTS

Sample MBP535 [M8A/M202- DI WATER BLANK] : INORGANIC EXTRACTION: No residue noted in Teflon dish.

Sample MBP536 [M202- HEXANE BLANK] : ORGANIC EXTRACTION: No residue noted in vial.

Sample MBP537 [M202- ACETONE BLANK] : ORGANIC EXTRACTION: No residue noted in vial.

Sample MBP538 [M202- FB] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP539 [M202- W/DB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP540 [M202- W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP541 [M202- W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP543 [M202- W/ODB- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP544 [M202- W/ODB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MBP545 [M202- W/ODB- R3] : ORGANIC EXTRACTION : Light oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Results relate only to the items tested.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
6608735	MOR	Spiked Blank	Organic Condensibles	2020/02/28		98	%	70 - 130
6608735	MOR	Method Blank	Organic Condensibles	2020/02/26	<1.0		mg	
6608739	MOR	Method Blank	Inorganic Condensibles	2020/03/02	<0.5		mg	
6608981	MOR	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6608984	MOR	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6608986	MOR	Method Blank	> 10 Particulate Weight in Acetone Rinse	2020/02/28	<0.5		mg	
6613883	RSU	Matrix Spike(MBP785)	Sulphuric Acid Mist	2020/03/02		97	%	80 - 120
6613883	RSU	Spiked Blank	Sulphuric Acid Mist	2020/03/02		99	%	90 - 110
6613883	RSU	Method Blank	Sulphuric Acid Mist	2020/03/02	<0.2		mg	
6613883	RSU	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/03/02	NC		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

Brenda Moore

Brenda Moore, Team Lead, Inorganic

Frank Mo, B.Sc., Inorganic Lab. Manager

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports.
For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

5048089

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number: bec-19-cricketvalley.ny-start#1
Person Taking Samples: Aaron Blum
Laboratory Analysis Requested:
Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	–	–
CTG-0001_W/DB-1-F	Unit CTG-0001_W/DB - Run 1 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-1-C2	Unit CTG-0001_W/DB - Run 1 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-1-C3	Unit CTG-0001_W/DB - Run 1 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-1-C4	Unit CTG-0001_W/DB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-1-C5	Unit CTG-0001_W/DB - Run 1 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-1-C6	Unit CTG-0001_W/DB - Run 1 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-1-CPM	Unit CTG-0001_W/DB - Run 1 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-2-F	Unit CTG-0001_W/DB - Run 2 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-2-C2	Unit CTG-0001_W/DB - Run 2 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-2-C3	Unit CTG-0001_W/DB - Run 2 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-2-C4	Unit CTG-0001_W/DB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-2-C5	Unit CTG-0001_W/DB - Run 2 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-2-C6	Unit CTG-0001_W/DB - Run 2 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-2-CPM	Unit CTG-0001_W/DB - Run 2 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-3-F	Unit CTG-0001_W/DB - Run 3 - Filter	02/18/20	N/A	X			
CTG-0001_W/DB-3-C2	Unit CTG-0001_W/DB - Run 3 - Nozzle Wash PM>10	02/18/20		X			
CTG-0001_W/DB-3-C3	Unit CTG-0001_W/DB - Run 3 - Cyclone Wash 2.5<PM<10	02/18/20		X			
CTG-0001_W/DB-3-C4	Unit CTG-0001_W/DB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/18/20	N/A	X			
CTG-0001_W/DB-3-C5	Unit CTG-0001_W/DB - Run 3 - Inorganic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-3-C6	Unit CTG-0001_W/DB - Run 3 - Organic Impinger Contents	02/18/20			X		
CTG-0001_W/DB-3-CPM	Unit CTG-0001_W/DB - Run 3 - CPM Filter	02/18/20	N/A		X		
CTG-0001_W/DB-FB-C3	Unit CTG-0001_W/DB - Run FB - Cyclone Wash 2.5<PM<10	FB		X			
CTG-0001_W/DB-FB-C4	Unit CTG-0001_W/DB - Run FB - Cyclone Exit to Front Half of Filter Wash (<2.5)	FB	N/A	X			
CTG-0001_W/DB-FB-C5	Unit CTG-0001_W/DB - Run FB - Inorganic Impinger Contents	FB			X		
CTG-0001_W/DB-B1-Acetone	Unit CTG-0001_W/DB - Blank - Acetone		200		X		
CTG-0001_W/DB-B2-DI Water	Unit CTG-0001_W/DB - Blank - DI Water		200	X			
CTG-0001_W/DB-B3-Hexane	Unit CTG-0001_W/DB - Blank - Hexane		200		X		

Signature / Date / Time

Signature / Date / Time

ODILE NTANWEMEZI
Signature / Date: 2020/02/21 Time: 17:15

ODILE NTANWEMEZI
Signature / Date: 2020/02/25 Time: 13:40

C048-069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:
Person Taking Samples:	Aaron Blum	Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	–	–
CTG-0001_W/ODB-1-F	Unit CTG-0001_W/ODB - Run 1 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-1-C2	Unit CTG-0001_W/ODB - Run 1 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-1-C3	Unit CTG-0001_W/ODB - Run 1 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-1-C4	Unit CTG-0001_W/ODB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-1-C5	Unit CTG-0001_W/ODB - Run 1 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-1-C6	Unit CTG-0001_W/ODB - Run 1 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-1-CPM	Unit CTG-0001_W/ODB - Run 1 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-2-F	Unit CTG-0001_W/ODB - Run 2 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-2-C2	Unit CTG-0001_W/ODB - Run 2 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-2-C3	Unit CTG-0001_W/ODB - Run 2 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-2-C4	Unit CTG-0001_W/ODB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-2-C5	Unit CTG-0001_W/ODB - Run 2 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-2-C6	Unit CTG-0001_W/ODB - Run 2 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-2-CPM	Unit CTG-0001_W/ODB - Run 2 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-3-F	Unit CTG-0001_W/ODB - Run 3 - Filter	02/17/20	N/A	X			
CTG-0001_W/ODB-3-C2	Unit CTG-0001_W/ODB - Run 3 - Nozzle Wash PM>10	02/17/20		X			
CTG-0001_W/ODB-3-C3	Unit CTG-0001_W/ODB - Run 3 - Cyclone Wash 2.5<PM<10	02/17/20		X			
CTG-0001_W/ODB-3-C4	Unit CTG-0001_W/ODB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	02/17/20	N/A	X			
CTG-0001_W/ODB-3-C5	Unit CTG-0001_W/ODB - Run 3 - Inorganic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-3-C6	Unit CTG-0001_W/ODB - Run 3 - Organic Impinger Contents	02/17/20			X		
CTG-0001_W/ODB-3-CPM	Unit CTG-0001_W/ODB - Run 3 - CPM Filter	02/17/20	N/A		X		
CTG-0001_W/ODB-FB-C3	Unit CTG-0001_W/ODB - Run FB - Cyclone Wash 2.5<PM<10	FB		X			
CTG-0001_W/ODB-FB-C4	Unit CTG-0001_W/ODB - Run FB - Cyclone Exit to Front Half of Filter Wash (<2.5)	FB	N/A	X			
CTG-0001_W/ODB-FB-C5	Unit CTG-0001_W/ODB - Run FB - Inorganic Impinger Contents	FB			X		
CTG-0001_W/ODB-B1-Acetone	Unit CTG-0001_W/ODB - Blank - Acetone		200		X		
CTG-0001_W/ODB-B2-DI Water	Unit CTG-0001_W/ODB - Blank - DI Water		200	X			
CTG-0001_W/ODB-B3-Hexane	Unit CTG-0001_W/ODB - Blank - Hexane		200		X		

Signature	Date	Time	Signature	Date	Time
[signature]	2/20/20	1400	FIDELE NTAMWEMEZI [signature]	2020/02/21	17 15
			FIDELE NTAMWEMEZI [signature]	2020/02/25	13 40

C048069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)
Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:
Person Taking Samples:	Atlas Melchert	Titration

Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
CT-0001W/DB-1-CW	Unit CT-0001W/DB - Run 1 - Condenser Wash	02/17/20					
CT-0001W/DB-2-CW	Unit CT-0001W/DB - Run 2 - Condenser Wash	02/17/20					
CT-0001W/DB-3-CW	Unit CT-0001W/DB - Run 3 - Condenser Wash	02/17/20					
CT-0001W/DB-B2-DI Water	Unit CT-0001W/DB - Blank - DI Water		100				
CT-0001W/DB-B3-H_2O_2	Unit CT-0001W/DB - Blank - H_2O_2		100				

Signature	Date	Time	Signature	Date	Time
[signature]	2/20/20	1420	FIDELE NTAMWEMEZI [signature]	2020/02/21	17:15
			FIDELE NTAMWEMEZI [signature]	2020/02/25	13:40

bec-19-cricketvally.ny-start#1-M8a-wDB

SD&L

C048069

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number: bec-19-cricketvalley.ny-start#1

Person Taking Samples:

Laboratory Analysis Requested: Titration

Sample Number	Location	Date	Volume	Analysis Method: Cont Cond	--	--	--
CT-0001w/oDB-1-CW	Unit CT-0001w/oDB - Run 1 - Condenser Wash	02/18/20					
CT-0001w/oDB-2-CW	Unit CT-0001w/oDB - Run 2 - Condenser Wash	02/18/20					
CT-0001w/oDB-3-CW	Unit CT-0001w/oDB - Run 3 - Condenser Wash	02/18/20					
CT-0001w/oDB-B2-DI Water	Unit CT-0001w/oDB - Blank - DI Water		100				
CT-0001w/oDB-B3-H_2O_2	Unit CT-0001w/oDB - Blank - H_2O_2		100				

	Signature	Date	Time
	[signature]	2/20/20	1900

	Signature	Date	Time
	FIDELE NTAMWEMEZI [signature]	2020/02/21	17:15
	FIDELE NTAMWEMEZI [signature]	2020/02/25	13:40

bec-19-cricketvalley.ny-start#1-woDB-M8A

SD&L

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Supplemental Laboratory Data
BV Labs

Specific data from the lab regarding the filter weights reported at the RDL and noted as “negative weight observed”.

Comparison of actual Lab Reported Filter Loss to the gains in the sample train sections just prior to and just after the filter. The total gains in each of these sections always accounts for the filter loss. Air Hygiene concluded that the frayed filter edges either ended up in the section prior to the filter and/or the section just downstream of the filter.

Data Summary

Run	Filter	Gain in Cyclone End to Front Half of Filter Wash (<2.5) (mg)	Gain in Inorganic Impinger Content (mg)	Sum of Gains (mg)	Lab Reported Filter Loss (mg)
Base – Run 1	19031839	1.6	3.3	4.9	-1.2
Base – Run 3	19031831	1.2	2.2	3.4	-3.1

Prepared for: Air Hygiene International

Project: BEC-19-CRICKETVALLEY.NY-START

Analytical Data Package

Analysis: Method 8A / Method 201A / Method 202

BV Job #: C097773

Bureau Veritas Laboratories
6740 Campobello Rd.
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.bvlabs.com

I hereby certify that to the best of my knowledge all analytical data presented in this report:

- Has been checked for completeness.
- Is accurate, legible and error free.
- Has been conducted in accordance with approved SOP's and that all deviations are clearly listed in the Case Narrative.
- This report has been generated in .pdf format.

Review Performed By:

2020.05.15 11:36:08 -04'00'

Bureau Veritas Laboratories
6740 Campobello Rd.
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.bvlabs.com

Glossary of Terms

- ***MDL*** represents the Minimum Detection Limit below which the laboratory cannot confirm the presence of the analyte to the 95% confidence level.
- ***RDL*** represents the Reportable Detection Limit and is usually set at a value equivalent to the lowest calibration standard
- ***Acceptance Criteria*** are values used by the laboratory to determine that a process is in control.
- ***Accuracy*** is the degree of agreement of a measured value with the true or expected value.
- ***Calibration Standards*** are a set of solutions containing the analytes of interest at a specified concentration.
- ***Calibration Verification Standard*** consists of a calibration standard solution of intermediate concentration (mid-point initial calibration level) used to access whether the initial calibration is still valid
- ***Certified Reference Material*** is a stable homogenous material that is certified by repetitive analysis from a supplier who is certified to generate said materials.
- ***Internal Standard*** a deuterated or ^{13}C-labelled analyte that is added to a sample extract prior to instrumental analysis to compensate for injection variablity.
- ***Isomer*** is a member of a group of compounds that differ from each other only in the locations of a specific number of common substituent atoms or groups of atoms on the parent compound.
- ***Method Blank*** is a laboratory control sample using reagents that are known to be free of contamination.
- ***Precision*** is the degree of agreement between the data generated from repetitive measurements under specific conditions.
- ***Quality Assurance*** is a system of activities whose purpose is to provide the producer or user of a product with the assurance that the product meets a defined standard of quality.
- ***Quality Control*** is the overall system of activities whose purpose is to control the quality of a product so that it meets the needs of the end user.
- ***RSD*** is the relative standard deviation.
- ***Blank Spike*** is a laboratory control sample that has been fortified with native analytes of interest.
- ***Window Defining Mixture*** is a solution containing only the earliest and latest eluting congeners within each homologous group of target analytes on a specified GC column.
- ***RPD*** or Relative Percent Difference. A measure used to compare duplicate sample analysis.
- ***EMPC/NDR –*** Peak detected does not meet ratio criteria and has resulted in a higher detection limit.



1.0 Project Narrative

Bureau Veritas Laboratories
6740 Campobello Rd
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.bvlabs.com

PROJECT NARRATIVE

Bureau Veritas Laboratories
Client Project #: BEC-19-CRICKETVALLEY.NY-START

Client: Air Hygiene International Inc
Client Project: BEC-19-CRICKETVALLEY.NY-START

I. SAMPLE RECEIPT/ANALYSIS

a) Sample Listing

BV Labs ID	Client Sample ID	Date Sampled	Date Received	Date Prepped	Date Run	Initial Calibration
<2.5um Particulates in Rinse						
MMC518	M201A- U3 BASE W/DB- R1	2020/04/16	2020/04/18	2020/04/22	2020/04/24	N/A
MMC519	M201A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/22	2020/04/24	N/A
MMC520	M201A- U3 BASE W/DB- R3	2020/04/17	2020/04/18	2020/04/22	2020/04/24	N/A
MMC521	M201A- U3 BASE- R1	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
MMC522	M201A- U3 BASE- R2	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
MMC523	M201A- U3 BASE- R3	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
>10um Particulates in Rinse						
MMC518	M201A- U3 BASE W/DB- R1	2020/04/16	2020/04/18	2020/04/22	2020/04/24	N/A
MMC519	M201A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/22	2020/04/24	N/A
MMC520	M201A- U3 BASE W/DB- R3	2020/04/17	2020/04/18	2020/04/22	2020/04/24	N/A
MMC521	M201A- U3 BASE- R1	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
MMC522	M201A- U3 BASE- R2	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
MMC523	M201A- U3 BASE- R3	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
2.5 um Particulates on Filter						
MMC518	M201A- U3 BASE W/DB- R1	2020/04/16	2020/04/18	N/A	2020/04/22	N/A
MMC519	M201A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	N/A	2020/04/22	N/A
MMC520	M201A- U3 BASE W/DB- R3	2020/04/17	2020/04/18	N/A	2020/04/22	N/A
MMC521	M201A- U3 BASE- R1	2020/04/15	2020/04/18	N/A	2020/04/22	N/A
MMC522	M201A- U3 BASE- R2	2020/04/15	2020/04/18	N/A	2020/04/22	N/A
MMC523	M201A- U3 BASE- R3	2020/04/15	2020/04/18	N/A	2020/04/22	N/A
2.5-10um Particulates in Rinse						
MMC518	M201A- U3 BASE W/DB- R1	2020/04/16	2020/04/18	2020/04/22	2020/04/24	N/A
MMC519	M201A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/22	2020/04/24	N/A
MMC520	M201A- U3 BASE W/DB- R3	2020/04/17	2020/04/18	2020/04/22	2020/04/24	N/A
MMC521	M201A- U3 BASE- R1	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
MMC522	M201A- U3 BASE- R2	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
MMC523	M201A- U3 BASE- R3	2020/04/15	2020/04/18	2020/04/22	2020/04/24	N/A
Extractable Condensables (M202)						
MMC512	M202- U3 BASE W/DB- R1	2020/04/16	2020/04/18	2020/04/21	2020/04/24	N/A
MMC513	M202- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/21	2020/04/24	N/A
MMC514	M202- U3 BASE W/DB- R3	2020/04/17	2020/04/18	2020/04/21	2020/04/24	N/A
MMC515	M202- U3 BASE- R1	2020/04/15	2020/04/18	2020/04/21	2020/04/24	N/A
MMC516	M202- U3 BASE- R2	2020/04/15	2020/04/18	2020/04/21	2020/04/24	N/A
MMC517	M202- U3 BASE- R3	2020/04/15	2020/04/18	2020/04/21	2020/04/24	N/A
Non Extractable Condensibles (M202)						
MMC512	M202- U3 BASE W/DB- R1	2020/04/16	2020/04/18	2020/04/21	2020/04/22	N/A
MMC513	M202- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/21	2020/04/22	N/A
MMC514	M202- U3 BASE W/DB- R3	2020/04/17	2020/04/18	2020/04/21	2020/04/22	N/A
MMC515	M202- U3 BASE- R1	2020/04/15	2020/04/18	2020/04/21	2020/04/22	N/A
MMC516	M202- U3 BASE- R2	2020/04/15	2020/04/18	2020/04/21	2020/04/22	N/A
MMC517	M202- U3 BASE- R3	2020/04/15	2020/04/18	2020/04/21	2020/04/22	N/A

BV Labs ID	Client Sample ID	Date Sampled	Date Received	Date Prepped	Date Run	Initial Calibration
H2SO4 Acid Mist in IPA Impinger (M8mod)						
MMC524	M8A- U3 BASE W/DB- R1	2020/04/16	2020/04/18	2020/04/24	2020/04/24	2020/04/24
MMC525	M8A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/24	2020/04/24	2020/04/24
MMC525 Dup	M8A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/24	2020/04/24	2020/04/24
MMC526	M8A- U3 BASE W/DB- R3	2020/04/17	2020/04/18	2020/04/24	2020/04/24	2020/04/24
MMC527	M8A- U3 BASE- R1 -CW	2020/04/15	2020/04/18	2020/04/24	2020/04/24	2020/04/24
MMC528	M8A- U3 BASE- R2 -CW	2020/04/16	2020/04/18	2020/04/24	2020/04/24	2020/04/24
MMC529	M8A- U3 BASE- R3 -CW	2020/04/16	2020/04/18	2020/04/24	2020/04/24	2020/04/24
Sulphuric Acid Mist by Titration (M8A)						
MMC524	M8A- U3 BASE W/DB- R1	2020/04/16	2020/04/18	2020/04/27	2020/04/27	2020/04/27
MMC525	M8A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/27	2020/04/27	2020/04/27
MMC525 Dup	M8A- U3 BASE W/DB- R2	2020/04/17	2020/04/18	2020/04/27	2020/04/27	2020/04/27
MMC526	M8A- U3 BASE W/DB- R3	2020/04/17	2020/04/18	2020/04/27	2020/04/27	2020/04/27
MMC527	M8A- U3 BASE- R1 -CW	2020/04/15	2020/04/18	2020/04/27	2020/04/27	2020/04/27
MMC528	M8A- U3 BASE- R2 -CW	2020/04/16	2020/04/18	2020/04/27	2020/04/27	2020/04/27
MMC529	M8A- U3 BASE- R3 -CW	2020/04/16	2020/04/18	2020/04/27	2020/04/27	2020/04/27

Run Date is defined as the date of injection of the last calibration standard (12 hours or less) prior to the samples analyzed within that run sequence. Therefore the time of calibration injection that defines the run date is always within 12 hours of the time of sample injection.

b) Shipping Problems: none encountered

c) Documentation Problems: none encountered

II. SAMPLE PREP:

No problems encountered

III. SAMPLE ANALYSIS:

See also comments within the appropriate Certificate of Analysis

a) Hold Times: all within recommended hold times

b) Instrument Calibration: all within control limits

c) Quality Control: All applicable QC meets control criteria, except where otherwise noted.

d) All analytes requiring manual intergration(s) are noted on the sample chromatograms

I certify that this data package is in compliance with the terms and conditions of the contract, both technically and for other than the conditions detailed above.

In addition, I certify, that to the best of my knowledge and belief, the data as reported are true and accurate. Release of the data contained in this data package has been authorized by the cognizant laboratory official or his/her designee, as verified by this signature.



Clayton Johnson, Customer Experience Team Lead

2020/05/14
Date

2.0 Summary Report

Bureau Veritas Laboratories
6740 Campobello Rd
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.bvlabs.com

Your Project #: BEC-19-CRICKETVALLEY.NY-START

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/04/27
Report #: R6156688
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C097773
Received: 2020/04/18, 19:45

Sample Matrix: Stack Sampling Train
Samples Received: 18

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Extractable Condensables (M202)	6	2020/04/21	2020/04/24	BRL SOP-00118	EPA 202 m
Non Extractable Condensibles (M202)	6	2020/04/21	2020/04/22	BRL SOP-00118 / BRL SOP-00109	EPA 202 m
>10um Particulates in Rinse	6	2020/04/22	2020/04/24	BRL SOP-00109	EPA M201A
2.5-10um Particulates in Rinse	6	2020/04/22	2020/04/24	BRL SOP-00109	EPA M201A
2.5 um Particulates on Filter	6	N/A	2020/04/22	BRL SOP-00109	EPA M201A
<2.5um Particulates in Rinse	6	2020/04/22	2020/04/24	BRL SOP-00109	EPA M201A
H2SO4 Acid Mist in IPA Impinger (M8mod)	6	2020/04/24	2020/04/24	BRL SOP-00105	EPA 8 m
Sulphuric Acid Mist by Titration (M8A)	6	2020/04/27	2020/04/27	BRL SOP-00116	EPA CFR PTM 8 m
Final Volume of Acetone Probe Rinse	6	N/A	2020/04/22	BRL SOP-00109	
Final Volume of Impinger	6	N/A	2020/04/24		
Weight of Solvent from Impingers	6	N/A	2020/04/21		
Weight of Water from Impingers	6	N/A	2020/04/21		

Remarks:

Bureau Veritas Laboratories are accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by BV Labs are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in BV Labs profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and BV Labs in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

BV Labs liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. BV Labs has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by BV Labs, unless otherwise agreed in writing. BV Labs is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.
Results relate to samples tested. When sampling is not conducted by BV Labs, results relate to the supplied samples tested.
This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Your Project #: BEC-19-CRICKETVALLEY.NY-START

Attention: Data Reports

Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Report Date: 2020/04/27
Report #: R6156688
Version: 1 - Final

CERTIFICATE OF ANALYSIS

BV LABS JOB #: C097773
Received: 2020/04/18, 19:45

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.
* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Clayton Johnson, Project Manager - Air Toxics, Source Evaluation
Email: Clayton.Johnson@bvlabs.com
Phone# (905)817-5769
==========
This report has been generated and distributed using a secure automated process.
BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

EPA M201A - PARTICULATES (STACK SAMPLING TRAIN)

BV Labs ID		MMC518	MMC519	MMC520		
Sampling Date		2020/04/16	2020/04/17	2020/04/17		
	UNITS	M201A- U3 BASE W/DB- R1	M201A- U3 BASE W/DB- R2	M201A- U3 BASE W/DB- R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	8.3	10.9	1.4	0.5	6692255
< 2.5 Particulate Weight in Acetone Rinse	mg	1.5	1.3	1.2	0.5	6692239
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.1	1.0	3.5	0.5	6692253
< 2.5 Particulate Weight on Filter	mg	0.50	0.70	<0.30	0.30	6692295
Acetone Rinse Volume (10)	ml	70	76	61	1	6692260
Acetone Rinse Volume (2.5 - 10)	ml	60	76	69	1	6692260
Acetone Rinse Volume (2.5)	ml	73	62	70	1	6692260

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC521	MMC522	MMC523		
Sampling Date		2020/04/15	2020/04/15	2020/04/15		
	UNITS	M201A- U3 BASE-R1	M201A- U3 BASE-R2	M201A- U3 BASE-R3	RDL	QC Batch
> 10 Particulate Weight in Acetone Rinse	mg	17.5	9.3	14.1	0.5	6692255
< 2.5 Particulate Weight in Acetone Rinse	mg	1.6	1.4	1.2	0.5	6692239
2.5 - 10 Particulate Weight in Acetone Rinse	mg	1.0	1.3	1.0	0.5	6692253
< 2.5 Particulate Weight on Filter	mg	<0.30 (1)	0.50	<0.30 (1)	0.30	6692295
Acetone Rinse Volume (10)	ml	78	72	60	1	6692260
Acetone Rinse Volume (2.5 - 10)	ml	75	66	66	1	6692260
Acetone Rinse Volume (2.5)	ml	61	61	36	1	6692260

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
(1) Negative result observed

LFT Loose filter material in the petri dish
DE Edges of the filter are frayed

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

EPA M202 CONDENSIBLE PM (STACK SAMPLING TRAIN)

BV Labs ID		MMC512	MMC513	MMC514		
Sampling Date		2020/04/16	2020/04/17	2020/04/17		
	UNITS	M202- U3 BASE W/DB-R1	M202- U3 BASE W/DB-R2	M202- U3 BASE W/DB-R3	RDL	QC Batch
Weight	g	380	380	330	0.1	6690925
Weight of Solvent	g	190	210	190	0.1	6690922
Miscellaneous Parameters						
Inorganic Condensibles	mg	2.1	3.7	2.1	0.5	6690928
Organic Condensibles	mg	<1.0	1.1	1.4	1.0	6690921

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC515	MMC516	MMC517		
Sampling Date		2020/04/15	2020/04/15	2020/04/15		
	UNITS	M202- U3 BASE-R1	M202- U3 BASE-R2	M202- U3 BASE-R3	RDL	QC Batch
Weight	g	460	360	380	0.1	6690925
Weight of Solvent	g	240	200	220	0.1	6690922
Miscellaneous Parameters						
Inorganic Condensibles	mg	3.3	2.2	2.2	0.5	6690928
Organic Condensibles	mg	2.4	1.9	1.5	1.0	6690921

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

BV Labs Job #: C097773
Report Date: 2020/04/27

Air Hygiene International Inc
Client Project #: BEC-19-CRICKETVALLEY.NY-START
Sampler Initials: RW

RESULTS OF ANALYSES OF STACK SAMPLING TRAIN

BV Labs ID		MMC524		MMC525	MMC525		
Sampling Date		2020/04/16		2020/04/17	2020/04/17		
	UNITS	M8A- U3 BASE W/DB-R1	RDL	M8A- U3 BASE W/DB-R2	M8A- U3 BASE W/DB-R2 Lab-Dup	RDL	QC Batch
Impinger Volume	ml	166	1	103	N/A	1	6696057
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.017	0.017	0.060	0.058	0.011	6696051

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate
N/A = Not Applicable

BV Labs ID		MMC526		MMC527	MMC528		
Sampling Date		2020/04/17		2020/04/15	2020/04/16		
	UNITS	M8A- U3 BASE W/DB-R3	RDL	M8A- U3 BASE- R1 -CW	M8A- U3 BASE- R2 -CW	RDL	QC Batch
Impinger Volume	ml	108	1	125	132	1	6696057
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	0.017	0.011	0.047	0.094	0.013	6696051

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC529		
Sampling Date		2020/04/16		
	UNITS	M8A- U3 BASE- R3 -CW	RDL	QC Batch
Impinger Volume	ml	183	1	6696057
Miscellaneous Parameters				
Sulphuric Acid Mist	mg	<0.019	0.019	6696051

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

INDUSTRIAL HYGIENE (STACK SAMPLING TRAIN)

BV Labs ID		MMC524		MMC525	MMC525		
Sampling Date		2020/04/16		2020/04/17	2020/04/17		
	UNITS	M8A- U3 BASE W/DB-R1	RDL	M8A- U3 BASE W/DB-R2	M8A- U3 BASE W/DB-R2 Lab-Dup	RDL	QC Batch
Miscellaneous Parameters							
Sulphuric Acid Mist	mg	<0.66	0.66	<0.41	<0.41	0.41	6698432

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch
Lab-Dup = Laboratory Initiated Duplicate

BV Labs ID		MMC526		MMC527		MMC528		
Sampling Date		2020/04/17		2020/04/15		2020/04/16		
	UNITS	M8A- U3 BASE W/DB-R3	RDL	M8A- U3 BASE- R1 -CW	RDL	M8A- U3 BASE- R2 -CW	RDL	QC Batch
Miscellaneous Parameters								
Sulphuric Acid Mist	mg	<0.43	0.43	<0.5	0.5	<0.53	0.53	6698432

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

BV Labs ID		MMC529		
Sampling Date		2020/04/16		
	UNITS	M8A- U3 BASE- R3 -CW	RDL	QC Batch
Miscellaneous Parameters				
Sulphuric Acid Mist	mg	<0.73	0.73	6698432

RDL = Reportable Detection Limit
QC Batch = Quality Control Batch

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

TEST SUMMARY

BV Labs ID: MMC512 **Collected:** 2020/04/16
Sample ID: M202- U3 BASE W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC513 **Collected:** 2020/04/17
Sample ID: M202- U3 BASE W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC514 **Collected:** 2020/04/17
Sample ID: M202- U3 BASE W/DB- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC515 **Collected:** 2020/04/15
Sample ID: M202- U3 BASE- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC516 **Collected:** 2020/04/15
Sample ID: M202- U3 BASE- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

TEST SUMMARY

BV Labs ID: MMC517 **Collected:** 2020/04/15
Sample ID: M202- U3 BASE- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
Extractable Condensables (M202)	BAL	6690921	2020/04/21	2020/04/24	Muhammad M Rahman
Non Extractable Condensibles (M202)	BAL	6690928	2020/04/21	2020/04/22	Muhammad M Rahman
Weight of Solvent from Impingers		6690922	N/A	2020/04/21	Muhammad M Rahman
Weight of Water from Impingers		6690925	N/A	2020/04/21	Muhammad M Rahman

BV Labs ID: MMC518 **Collected:** 2020/04/16
Sample ID: M201A- U3 BASE W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC519 **Collected:** 2020/04/17
Sample ID: M201A- U3 BASE W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC520 **Collected:** 2020/04/17
Sample ID: M201A- U3 BASE W/DB- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC521 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore

TEST SUMMARY

BV Labs ID: MMC521 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC522 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC523 **Collected:** 2020/04/15
Sample ID: M201A- U3 BASE- R3 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
>10um Particulates in Rinse	BAL	6692255	2020/04/22	2020/04/24	Muhammad M Rahman
2.5-10um Particulates in Rinse	BAL	6692253	2020/04/22	2020/04/24	Muhammad M Rahman
2.5 um Particulates on Filter	BAL	6692295	N/A	2020/04/22	Brenda Moore
<2.5um Particulates in Rinse	BAL	6692239	2020/04/22	2020/04/24	Muhammad M Rahman
Final Volume of Acetone Probe Rinse		6692260	N/A	2020/04/22	Muhammad M Rahman

BV Labs ID: MMC524 **Collected:** 2020/04/16
Sample ID: M8A- U3 BASE W/DB- R1 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC525 **Collected:** 2020/04/17
Sample ID: M8A- U3 BASE W/DB- R2 **Shipped:**
Matrix: Stack Sampling Train **Received:** 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

TEST SUMMARY

BV Labs ID: MMC525 Dup
Sample ID: M8A- U3 BASE W/DB- R2
Matrix: Stack Sampling Train

Collected: 2020/04/17
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota

BV Labs ID: MMC526
Sample ID: M8A- U3 BASE W/DB- R3
Matrix: Stack Sampling Train

Collected: 2020/04/17
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC527
Sample ID: M8A- U3 BASE- R1 -CW
Matrix: Stack Sampling Train

Collected: 2020/04/15
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC528
Sample ID: M8A- U3 BASE- R2 -CW
Matrix: Stack Sampling Train

Collected: 2020/04/16
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

BV Labs ID: MMC529
Sample ID: M8A- U3 BASE- R3 -CW
Matrix: Stack Sampling Train

Collected: 2020/04/16
Shipped:
Received: 2020/04/18

Test Description	Instrumentation	Batch	Extracted	Date Analyzed	Analyst
H2SO4 Acid Mist in IPA Impinger (M8mod)	IC/SPEC	6696051	2020/04/24	2020/04/24	Lang Le
Sulphuric Acid Mist by Titration (M8A)	MT	6698432	2020/04/27	2020/04/27	Rupinder Sihota
Final Volume of Impinger		6696057	N/A	2020/04/24	Frank Mo

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.

GENERAL COMMENTS

Sample MMC512 [M202- U3 BASE W/DB- R1] : ORGANIC EXTRACTION :Light oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC513 [M202- U3 BASE W/DB- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC514 [M202- U3 BASE W/DB- R3] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC515 [M202- U3 BASE- R1] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC516 [M202- U3 BASE- R2] : ORGANIC EXTRACTION : Oily material found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Sample MMC517 [M202- U3 BASE- R3] : ORGANIC EXTRACTION : Visual oily extract residue found in vial.
INORGANIC EXTRACTION : Whitish residue found in Teflon dish.

Results relate only to the items tested.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

BV Labs Job #: C097773
Report Date: 2020/04/27

Air Hygiene International Inc
Client Project #: BEC-19-CRICKETVALLEY.NY-START
Sampler Initials: RW

QUALITY ASSURANCE REPORT

QA/QC Batch	Init	QC Type	Parameter	Date Analyzed	Value	% Recovery	UNITS	QC Limits
6690921	MOR	Spiked Blank	Organic Condensibles	2020/04/24		99	%	70 - 130
6690921	MOR	Method Blank	Organic Condensibles	2020/04/24	<1.0		mg	
6690928	MOR	Method Blank	Inorganic Condensibles	2020/04/24	<0.5		mg	
6692239	MOR	Method Blank	< 2.5 Particulate Weight in Acetone Rinse	2020/04/24	<0.5		mg	
6692253	MOR	Method Blank	2.5 - 10 Particulate Weight in Acetone Rinse	2020/04/24	<0.5		mg	
6692255	MOR	Method Blank	> 10 Particulate Weight in Acetone Rinse	2020/04/24	<0.5		mg	
6696051	LLE	Matrix Spike(MMC525)	Sulphuric Acid Mist	2020/04/24		93	%	80 - 120
6696051	LLE	Spiked Blank	Sulphuric Acid Mist	2020/04/24		98	%	90 - 110
6696051	LLE	Method Blank	Sulphuric Acid Mist	2020/04/24	<0.01		mg	
6696051	LLE	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/04/24	3.4		%	20
6698432	RSU	Matrix Spike(MMC525)	Sulphuric Acid Mist	2020/04/27		98	%	80 - 120
6698432	RSU	Spiked Blank	Sulphuric Acid Mist	2020/04/27		98	%	90 - 110
6698432	RSU	Method Blank	Sulphuric Acid Mist	2020/04/27	<0.2		mg	
6698432	RSU	RPD - Sample/Sample Dup	Sulphuric Acid Mist	2020/04/27	NC		%	20

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.


Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

NC (Duplicate RPD): The duplicate RPD was not calculated. The concentration in the sample and/or duplicate was too low to permit a reliable RPD calculation (absolute difference <= 2x RDL).


Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Ann-Marie Stern, Team Lead, Inorganic



Brenda Moore, Team Lead, Inorganic



Frank Mo, B.Sc., Inorganic Lab. Manager

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Bureau Veritas Laboratories 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvlabs.com



3.0 Sample Custody

Bureau Veritas Laboratories
6740 Campobello Rd
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.bvlabs.com

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3	Laboratory Analysis Requested:
Person Taking Samples:	Rob White	Gravimetric

Sample Number	Location	Date	Volume	Analysis Method			
				RM 201A	RM 202	–	–
PM U-00003 Base w/DB-1-F	Unit PM U-00003 Base w/DB - Run 1 - Filter	04/16/20	N/A	X			
PM U-00003 Base w/DB-1-C2	Unit PM U-00003 Base w/DB - Run 1 - Nozzle Wash PM>10	04/16/20		X			
PM U-00003 Base w/DB-1-C3	Unit PM U-00003 Base w/DB - Run 1 - Cyclone Wash 2.5<PM<10	04/16/20		X			
PM U-00003 Base w/DB-1-C4	Unit PM U-00003 Base w/DB - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/16/20	N/A	X			
PM U-00003 Base w/DB-1-C5	Unit PM U-00003 Base w/DB - Run 1 - Inorganic Impinger Contents	04/16/20			X		
PM U-00003 Base w/DB-1-C6	Unit PM U-00003 Base w/DB - Run 1 - Organic Impinger Contents	04/16/20			X		
PM U-00003 Base w/DB-1-CPM	Unit PM U-00003 Base w/DB - Run 1 - CPM Filter	04/16/20	N/A		X		
PM U-00003 Base w/DB-2-F	Unit PM U-00003 Base w/DB - Run 2 - Filter	04/17/20	N/A	X			
PM U-00003 Base w/DB-2-C2	Unit PM U-00003 Base w/DB - Run 2 - Nozzle Wash PM>10	04/17/20		X			
PM U-00003 Base w/DB-2-C3	Unit PM U-00003 Base w/DB - Run 2 - Cyclone Wash 2.5<PM<10	04/17/20		X			
PM U-00003 Base w/DB-2-C4	Unit PM U-00003 Base w/DB - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/17/20	N/A	X			
PM U-00003 Base w/DB-2-C5	Unit PM U-00003 Base w/DB - Run 2 - Inorganic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-2-C6	Unit PM U-00003 Base w/DB - Run 2 - Organic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-2-CPM	Unit PM U-00003 Base w/DB - Run 2 - CPM Filter	04/17/20	N/A		X		
PM U-00003 Base w/DB-3-F	Unit PM U-00003 Base w/DB - Run 3 - Filter	04/17/20	N/A	X			
PM U-00003 Base w/DB-3-C2	Unit PM U-00003 Base w/DB - Run 3 - Nozzle Wash PM>10	04/17/20		X			
PM U-00003 Base w/DB-3-C3	Unit PM U-00003 Base w/DB - Run 3 - Cyclone Wash 2.5<PM<10	04/17/20		X			
PM U-00003 Base w/DB-3-C4	Unit PM U-00003 Base w/DB - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/17/20	N/A	X			
PM U-00003 Base w/DB-3-C5	Unit PM U-00003 Base w/DB - Run 3 - Inorganic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-3-C6	Unit PM U-00003 Base w/DB - Run 3 - Organic Impinger Contents	04/17/20			X		
PM U-00003 Base w/DB-3-CPM	Unit PM U-00003 Base w/DB - Run 3 - CPM Filter	04/17/20	N/A		X		

Signature 4/18 12:00 Date Time

Signature Date Time

DAVID CHAN 2020/04/18 19:45
Signature Date Time

Signature Date Time

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email: rwhite@airhygiene.com

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3
Person Taking Samples:	Rob White

Sample Number	Location	Date	Volume	Laboratory Analysis Requested: Gravimetric Analysis Method RM 201A	RM 202	–	–
PM U-00003 Base-1-F	Unit PM U-00003 Base - Run 1 - Filter	04/15/20	N/A	X			
PM U-00003 Base-1-C2	Unit PM U-00003 Base - Run 1 - Nozzle Wash PM>10	04/15/20		X			
PM U-00003 Base-1-C3	Unit PM U-00003 Base - Run 1 - Cyclone Wash 2.5<PM<10	04/15/20		X			
PM U-00003 Base-1-C4	Unit PM U-00003 Base - Run 1 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/15/20	N/A	X			
PM U-00003 Base-1-C5	Unit PM U-00003 Base - Run 1 - Inorganic Impinger Contents	04/15/20			X		
PM U-00003 Base-1-C6	Unit PM U-00003 Base - Run 1 - Organic Impinger Contents	04/15/20			X		
PM U-00003 Base-1-CPM	Unit PM U-00003 Base - Run 1 - CPM Filter	04/15/20	N/A		X		
PM U-00003 Base-2-F	Unit PM U-00003 Base - Run 2 - Filter	04/15/20	N/A	X			
PM U-00003 Base-2-C2	Unit PM U-00003 Base - Run 2 - Nozzle Wash PM>10	04/15/20		X			
PM U-00003 Base-2-C3	Unit PM U-00003 Base - Run 2 - Cyclone Wash 2.5<PM<10	04/15/20		X			
PM U-00003 Base-2-C4	Unit PM U-00003 Base - Run 2 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/15/20	N/A	X			
PM U-00003 Base-2-C5	Unit PM U-00003 Base - Run 2 - Inorganic Impinger Contents	04/15/20			X		
PM U-00003 Base-2-C6	Unit PM U-00003 Base - Run 2 - Organic Impinger Contents	04/15/20			X		
PM U-00003 Base-2-CPM	Unit PM U-00003 Base - Run 2 - CPM Filter	04/15/20	N/A		X		
PM U-00003 Base-3-F	Unit PM U-00003 Base - Run 3 - Filter	04/15/20	N/A	X			
PM U-00003 Base-3-C2	Unit PM U-00003 Base - Run 3 - Nozzle Wash PM>10	04/15/20		X			
PM U-00003 Base-3-C3	Unit PM U-00003 Base - Run 3 - Cyclone Wash 2.5<PM<10	04/15/20		X			
PM U-00003 Base-3-C4	Unit PM U-00003 Base - Run 3 - Cyclone Exit to Front Half of Filter Wash (<2.5)	04/15/20	N/A	X			
PM U-00003 Base-3-C5	Unit PM U-00003 Base - Run 3 - Inorganic Impinger Contents	04/15/20			X		
PM U-00003 Base-3-C6	Unit PM U-00003 Base - Run 3 - Organic Impinger Contents	04/15/20			X		
PM U-00003 Base-3-CPM	Unit PM U-00003 Base - Run 3 - CPM Filter	04/15/20	N/A		X		

Signature	Date	Time	Signature	Date	Time
[signature]	4/18	21:00			
[signature] DAVID CHAN	2020/04/18	19:45			

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email:

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3			Laboratory Analysis Requested:			
Person Taking Samples:	GT			Titration			
Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	--	--	--
SAM U-00003 Base-1-CW	Unit SAM U-00003 Base - Run 1 - Condenser Wash	04/16/20			IC		
SAM U-00003 Base-2-CW	Unit SAM U-00003 Base - Run 2 - Condenser Wash	04/17/20			IC		
SAM U-00003 Base-3-CW	Unit SAM U-00003 Base - Run 3 - Condenser Wash	04/17/20			IC		

Signature Date Time

4/15/20 12:00

Signature Date Time

DAVID CHAN 2020/04/18 19:45

Signature Date Time

Signature Date Time

Signature Date Time

Signature Date Time

C097773

Requested Standard Analysis - 5-10 business days after receipt at lab

SAMPLE DESCRIPTION AND LABELING RECORD

Contact Information (deliver results to)

Name: Rob White
Phone: (918) 307-8865
Email:

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

Project Number:	bec-19-cricketvalley.ny-start#3	Laboratory Analysis Requested:
Person Taking Samples:	GT	Titration

Sample Number	Location	Date	Volume	Analysis Method			
				Cont Cond	–	–	–
SAM U-00003 Base-1-CW	Unit SAM U-00003 Base - Run 1 - Condenser Wash	04/15/20			IC		
SAM U-00003 Base-2-CW	Unit SAM U-00003 Base - Run 2 - Condenser Wash	04/16/20			IC		
SAM U-00003 Base-3-CW	Unit SAM U-00003 Base - Run 3 - Condenser Wash	04/16/20			IC		

TGM 4/18 11:00
Signature Date Time

DAVID CHAN 2020/04/18 19:45
Signature Date Time

Signature Date Time

Signature Date Time

4.0 Sample Chromatograms

Bureau Veritas Laboratories
6740 Campobello Rd
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.bvlabs.com

Method 201A – Determination of PM_{10} Emissions

Bureau Veritas Laboratories
6740 Campobello Rd.
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.BVLabs.com

Inorganic Analysis Action / Comment Form

Client ID	Air Hygiene
Maxxam Job #	C097773
Maxxam Sample ID's (start)	MMC518-01R

Analytical Worksheet(s)			
	Filters	6692295	
	Solvent Rinse	6692239	
	Solvent Volumes	6692260	

Analysis	Particulates
Analyst ID	Bmoore/ MOR

Actions:	*Impacted Sample ID's
Bottle discrepancies	No
Filters damaged	Yes
Solvent rinse anomalies	No
Water impinger anomalies	N/A
Filter blank submitted	No
Solvent blank submitted	No
Water blank submitted	N/A
Other	

Comments

See data sheets for any anomalies of samples

Filter
Particulate Weight Log

Job #	C097773	Metals	No	supplier	Pall	N/A		
Client	Air Hygiene	Filter Blank Submitted	No	p/n	61631	N/A		
Analysis	Particulate Weight on Filter	Date of Dessication	2020/04/21	lot #	T83173	N/A	Type	
Balance ID	220-BALANAL4	Time of Dessication	9:50 AM				M5	
Condition	Dickson THDX S/N 6213019							

DE Edges of filter frayed
LPC Loose particulate material in filter container
FT Filter torn
FCL Filter contains liquid after dessication
LFT Loose filter material

Increment 1

Analyst	B Moore	B Moore	B Moore					
Weighing Date		2020/04/22	2020/04/23					
Weighing Time		12:05 PM	10:55 AM					
Temperature (°C)		22	22					
Humidity (%)		36	37					

Worksheet #	#	Maxxam #	Filter Condition	Filter ID #	Pre Weight gm	Weight #1 gm	Weight #2 gm	Weight #3 gm	Weight #4 gm	Weight #5 gm	Weight #6 gm	Weight #7 gm	Final Weight gm	Particulate mg	RDL mg
6692295	1	MMC518-01R	NORMAL	19031829	0.11620	0.1166	0.1167						0.1167	0.5	0.3
6692295	2	MMC519-01R	NORMAL	19031826	0.11425	0.1148	0.1149						0.1149	0.7	0.3
6692295	3	MMC520-01R	NORMAL	18081503	0.11430	0.1145	0.1145						0.1145	0.2	0.3
6692295	4	MMC521-01R	DE*LFT	19031839	0.11365	0.1117	0.1117						0.1117	-1.2	0.3
6692295	5	MMC522-01R	NORMAL	19031840	0.11410	0.1146	0.1146						0.1146	0.5	0.3
6692295	6	MMC523-01R	DE*LFT	19031831	0.11285	0.1098	0.1098						0.1098	-3.1	0.3
	7														
	8														
	9														
	10														
				zero	0.0000	0.0000	0.0000								
				0.3000 gm	0.3000	0.3000	0.3000								
	11														
	12														
	13														
	14														
	15														
	16														
	17														
	18														
	19														
	20														
				zero											
				0.3000 gm											
	21														
	22														
	23														
	24														
	25														
	26														
	27														
	28														
	29														
	30														
				zero											
				0.3000 gm											
	31														
	32														
	33														
	34														
	35														
	36														
	37														
	38														
	39														
	40														
				zero											
				0.3000 gm											

Filters are placed in a dessicator for 24 hours minimum prior to beginning weighing cycle.
Filters are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity of≥50 %.
Verification Weight 5mg S/N 1000144533
Verification Weight 100mg S/N 29785
Verification Weight 300mg S/N 1000112492

Solvent
Particulate Weight Log

Job #	C097773
Client	Air Hygiene
Analysis	Particulate Weight in Acetone Rinse
Test Code	PARTACE-TR (as per M5)
Balance ID	NONT BALAN7
Condition	Dickson THDX S/N 6003123

Metals	No
Reagent Blank Submitted	No
Date of Dessication	2020/04/22
Time of Dessication	4:30PM

Solvent	Acetone
Lab Supplier	Caledon
lot #	104974

Analyst	MOR	MOR	MOR					
Weighing Date	2020/04/22	2020/04/24	2020/04/24					
Weighing Time	12:19PM	9:17 AM	3:32 PM					
Temperature (°C)	22	22	22					
Humidity (%)	37	34	39					

reagent blank correction
N/A

Worksheet #	#	Maxxam #	Bottle Full gm	Bottle Empty gm	Solvent Volume mL	Vial ID	Pre Weight gm	Weight #1 gm	Weight #2 gm	Weight #3 gm	Weight #4 gm	Weight #5 gm	Weight #6 gm	Weight #7 gm	Final Weight gm	Particulate mg	RDL mg
6692239	1	Blank	253.0	174.1	99.9	Q63	25.2314	25.2317	25.2317						25.2317	0.3	0.5
6692239	2	N/A															
6692239	3	MMC518-02R	90.7	33.2	72.8	Q64	25.4680	25.4693	25.4695						25.4695	1.5	0.5
6692239	4	MMC519-02R	82.2	33.6	61.5	Q65	25.2278	25.2289	25.2291						25.2291	1.3	0.5
6692239	5	MMC520-02R	89.1	33.7	70.1	Q66	25.4742	25.4752	25.4754						25.4754	1.2	0.5
6692239	6	MMC521-02R	81.5	33.0	61.4	Q67	25.2434	25.2447	25.2450						25.2450	1.6	0.5
6692239	7	MMC522-02R	81.5	33.0	61.4	Q68	24.9073	24.9085	24.9087						24.9087	1.4	0.5
6692239	8	MMC523-02R	61.6	32.8	36.5	Q69	25.5154	25.5164	25.5166						25.5166	1.2	0.5
	9																
	10																
	11																
		zero	0.0	0.0		zero	0.0000	0.0000	0.0000								
		100.0 gm	100.0	100.0		0.3000 gm	0.2998	0.2998	0.2998								
	12																
	13																
	14																
	15																
	16																
	17																
	18																
	19																
	20																
	21																
		zero				zero											
		100.0 gm				0.3000 gm											
	22	Blank															
	23																
	24																
	25																
	26																
	27																
	28																
	29																
	30																
	31																
	32																
		zero				zero											
		100.0 gm				0.3000 gm											
	33																
	34																
	35																
	36																
	37																
	38																
	39																
	40																
	41																
	42																
		zero				zero											
		100.0 gm				0.3000 gm											

Unusual residue appearance is noted in the appropriate cell.
Vials are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity ~~of~~ 50%. The residue appearance is noted.
Verification Weight 300mg S/N 1000112492

Solvent
Particulate Weight Log

Job #	C097773
Client	Air Hygiene
Analysis	Particulate Weight in Acetone Rinse
Test Code	PARTACE-TR (as per M5)
Balance ID	NONT BALAN7
Condition	Dickson THDX S/N 6003123

Metals	No
Reagent Blank Submitted	No
Date of Dessication	2020/04/22
Time of Dessication	4:30PM

Solvent	Acetone
Lab Supplier	Caledon
lot #	104974

Analyst	MOR	MOR	MOR						
Weighing Date	2020/04/22	2020/04/24	2020/04/24						
Weighing Time	12:25PM	9:24 AM	3:37 PM						
Temperature (°C)	22	22	22						
Humidity (%)	37	34	39						

reagent blank correction
N/A

Worksheet #	#	Maxxam #	Bottle Full gm	Bottle Empty gm	Solvent Volume mL	Vial ID	Pre Weight gm	Weight #1 gm	Weight #2 gm	Weight #3 gm	Weight #4 gm	Weight #5 gm	Weight #6 gm	Weight #7 gm	Final Weight gm	Particulate mg	RDL mg
6692253	1	Blank	253.0	174.1	99.9	Q63	25.2314	25.2317	25.2317						25.2317	0.3	0.5
6692253	2	N/A															
6692253	3	MMC518-03R	80.6	33.6	59.5	Q70	25.0749	25.0759	25.0760						25.0760	1.1	0.5
6692253	4	MMC519-03R	93.4	33.5	75.8	Q71	25.7636	25.7645	25.7646						25.7646	1.0	0.5
6692253	5	MMC520-03R	88.9	34.6	68.7	Q72	25.5457	25.5491	25.5492						25.5492	3.5	0.5
6692253	6	MMC521-03R	92.0	32.9	74.8	R1	25.1516	25.1525	25.1526						25.1526	1.0	0.5
6692253	7	MMC522-03R	85.3	33.4	65.7	R2	25.5149	25.5161	25.5162						25.5162	1.3	0.5
6692253	8	MMC523-03R	84.7	32.9	65.6	R3	25.6126	25.6136	25.6136						25.6136	1.0	0.5
	9																
	10																
	11																
		zero	0.0	0.0		zero	0.0000	0.0000	0.0000								
		100.0 gm	100.0	100.0		0.3000 gm	0.2998	0.2998	0.2998								
	12																
	13																
	14																
	15																
	16																
	17																
	18																
	19																
	20																
	21																
		zero				zero											
		100.0 gm				0.3000 gm											
	22	Blank															
	23																
	24																
	25																
	26																
	27																
	28																
	29																
	30																
	31																
	32																
		zero				zero											
		100.0 gm				0.3000 gm											
	33																
	34																
	35																
	36																
	37																
	38																
	39																
	40																
	41																
	42																
		zero				zero											
		100.0 gm				0.3000 gm											

Unusual residue appearance is noted in the appropriate cell.
Vials are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity ~~or~~ 50%. The residue appearance is noted.
Verification Weight 300mg S/N 1000112492

Solvent
Particulate Weight Log

Job #	C097773
Client	Air Hygiene
Analysis	Particulate Weight in Acetone Rinse
Test Code	PARTACE-TR (as per M5)
Balance ID	NONT BALAN7
Condition	Dickson THDX S/N 6003123

Metals	No
Reagent Blank Submitted	No
Date of Dessication	2020/04/22
Time of Dessication	4:30PM

Solvent	Acetone
Lab Supplier	Caledon
lot #	104974

Analyst	MOR	MOR	MOR					
Weighing Date	2020/04/22	2020/04/24	2020/04/24					
Weighing Time	12:31PM	9:28 AM	3:41 PM					
Temperature (°C)	22	22	22					
Humidity (%)	37	34	39					

reagent blank correction
N/A

Worksheet #	#	Maxxam #	Bottle Full gm	Bottle Empty gm	Solvent Volume mL	Vial ID	Pre Weight gm	Weight #1 gm	Weight #2 gm	Weight #3 gm	Weight #4 gm	Weight #5 gm	Weight #6 gm	Weight #7 gm	Final Weight gm	Particulate mg	RDL mg
6692255	1	Blank	253.0	174.1	99.9	Q63	25.2314	25.2317	25.2317						25.2317	0.3	0.5
6692255	2	N/A															
6692255	3	MMC518-04R	88.5	33.4	69.7	R4	25.3876	25.3958	25.3959						25.3959	8.3	0.5
6692255	4	MMC519-04R	93.7	33.7	75.9	R5	25.0149	25.0257	25.0258						25.0258	10.9	0.5
6692255	5	MMC520-04R	82.1	33.7	61.3	R6	25.6094	25.6108	25.6108						25.6108	1.4	0.5
6692255	6	MMC521-04R	94.8	33.3	77.8	R7	25.3433	25.3608	25.3608						25.3608	17.5	0.5
6692255	7	MMC522-04R	89.8	33.1	71.8	R8	25.6114	25.6207	25.6207						25.6207	9.3	0.5
6692255	8	MMC523-04R	80.7	33.0	60.4	R9	25.4866	25.5008	25.5007						25.5007	14.1	0.5
	9																
	10																
	11																
		zero	0.0	0.0		zero	0.0000	0.0000	0.0000								
		100.0 gm	100.0	100.0		0.3000 gm	0.2998	0.2998	0.2998								
	12																
	13																
	14																
	15																
	16																
	17																
	18																
	19																
	20																
	21																
		zero				zero											
		100.0 gm				0.3000 gm											
	22	Blank															
	23																
	24																
	25																
	26																
	27																
	28																
	29																
	30																
	31																
	32																
		zero				zero											
		100.0 gm				0.3000 gm											
	33																
	34																
	35																
	36																
	37																
	38																
	39																
	40																
	41																
	42																
		zero				zero											
		100.0 gm				0.3000 gm											

Unusual residue appearance is noted in the appropriate cell.

Vials are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity ~~of~~ 50%. The residue appearance is noted.

Verification Weight 300mg S/N 1000112492

Method 202 – Determination of Condensible Particulate Emissions from Stationary Sources

Bureau Veritas Laboratories
6740 Campobello Rd.
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.BVLabs.com

METHOD-202 ANALYSIS ACTION/COMMENT FORM

Client ID	Air Hygiene
Maxxam Job #	C097773

Analytical Worksheet(s) - solvent	**6690921**
Analytical Worksheet(s) - water	**6690928**

Analysis	**Method 202**
Analyst ID - solvent	M Rahman
Analyst ID - water	M Rahman

ACTIONS		*COMMENTS
Bottle discrepancies	No	No discrepancies were noted regarding bottles used for samples.
Solvent rinse anomalies	No	No anomalies were noted in this submission.
Water impinger anomalies	No	No anomalies were noted in this submission.
Solvent blank submitted	No	Not Applicable
Water blank submitted	No	Not Applicable
Filter anomalies	No	No anomalies were noted in this submission.
Other	No	Not Applicable

** Please note any action or anomalies impacting this set of samples*

GENERAL COMMENTS:

Non-Extractable CPM (Method-202)

Job #	C097773
Client	Air Hygiene
Analysis	Non-Extractable Condensibles
Balance ID	NONT BALAN7
Condition	Fisher S/N 191863398

Water Blank Submitted	No	
Date of Dessication	2020/04/23	
Time of Dessication	8:40AM	
Date/Time of Transfer	2020/04/22	9:40 AM

NH_4OH Supplier	Not Applicable
p/n	Not Applicable
lot #	Not Applicable
Normailty	Not Applicable

Analyst	MOR	MOR	MOR					
Weighing Date	2020/04/22	2020/04/24	2020/04/24					
Weighing Time	9:25 AM	8:57 AM	3:25 PM					
Temperature (°C)	22.0	21.9	21.6					
Humidity (%)	0	0	0					

Worksheet #	#	Maxxam #	Residue Appearance	Water Weight Before g	Water Weight After g	Water Weight g	Neutralization Required	Volume of 0.1 N NH_4OH used ml	Pre Weight g	1st Weight after 24hrs desiccation g	2nd Weight after 6hrs of 1st wt. g	3rd Weight after 24hrs desiccation g (Not Applicable)	4th Weight after 6hrs of 3rd wt. g	5th Weight after 6hrs of 4th wt. g	6th Weight after 6hrs of 5th wt. g	Final Weight g	Non Extractable Condensibles mg	RDL mg
6690928	1	Blank				200 ml	No	0	2.3927	2.3929	2.3928					2.3928	0.1	0.5
		Spike				200 ml												
		Spike:D1				200 ml												
6690928	2	MMC512-01R	Whitish	472.8	90.2	383	No	0	2.3150	2.3171	2.3171					2.3171	2.1	0.5
6690928	3	MMC513-01R	Whitish	465.4	89.7	376	No	0	2.3272	2.3310	2.3309					2.3309	3.7	0.5
6690928	4	MMC514-01R	Whitish	416.7	89.8	327	No	0	2.2505	2.2527	2.2526					2.2526	2.1	0.5
6690928	5	MMC515-01R	Whitish	548.0	88.6	459	No	0	2.2931	2.2963	2.2964					2.2964	3.3	0.5
6690928	6	MMC516-01R	Whitish	449.7	89.6	360	No	0	2.3088	2.3109	2.3110					2.3110	2.2	0.5
6690928	7	MMC517-01R	Whitish	469.0	89.1	380	No	0	2.2602	2.2623	2.2624					2.2624	2.2	0.5
	8																	
	9																	
	10																	
	11																	
			zero	0.0	0.0			zero	0.0000	0.0000	0.0000							
			100.0 gm	100.0	100.0			0.3000	0.2998	0.2998	0.2998							
	12																	
	13																	
	14																	
	15																	
	16																	
	17																	
	18																	
	19																	
	20																	
	21																	
			zero					zero										
			100.0 gm					0.3000										

NOTE: Vials are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity of 50 %.

Appearance of residue is noted in the Residue column (Oily residues, color of residues etc.)

COMMENTS: Verification weight 100g S/N 29785

Verification weight 0.3g S/N 4392-1

Digital Hygrometer S/N 192590073

Extractable CPM (Method-202)

Job #	C097773
Client	Air Hygiene
Analysis	Condensibles
Balance ID	NONT BALAN7
Condition	Fisher S/N 191863398

Solvent Blank Submitted	No	
Date of Dessication	2020/04/22	
Time of Dessication	1:37 PM	
Date/Time of Extraction	2020/04/21	2:15PM

Solvent	Hexane	Acetone
Lab Supplier	Fisher	Caledon
lot #	193856	103774

Spike ID	MOGC202# 23	Vial #	V-1	
Solvent Spike	Acetone			
Date Prepared	2020/01/08			
Date Expired	2020/07/08			

Spike Mean	94.88			
Std. Deviation	3.25			
Spike Range	Min:	85.1	Max:	104.6

Analyst	MOR	MOR	MOR					
Weighing Date	2020/04/22	2020/04/24	2020/04/24					
Weighing Time	9:50 AM	8:52 AM	3:16 PM					
Temperature (°C)	22.0	21.9	21.6					
Humidity (%)	0	0	0					

Worksheet #	#	Maxxam #	Residue Appearance	Solvent Weight Before g	Solvent Weight After g	Solvent Weight g	Pre Weight g	Weight #1 g	Weight #2 g	Weight #3 g	Weight #4 g	Weight #5 g	Weight #6 g	Weight #7 g	Final Weight g	Residue mg	RDL mg
6690921	1	Blank				200 ml	12.1405	12.1405	12.1405						12.1405	0.0	1.0
6690921	2	Spike				200 ml	12.1726	12.2121	12.2121						12.2121	98.8 %	1.0
6690921	3	Spike:D1				200 ml	N/A	N/A	N/A							##### ##	1.0
6690921	4	MMC512-02R	Light oily	469.1	279.3	190	12.1429	12.1432	12.1433						12.1433	0.4	1.0
6690921	5	MMC513-02R	Oily	485.4	277.8	208	12.0783	12.0791	12.0794						12.0794	1.1	1.0
6690921	6	MMC514-02R	Oily	471.3	277.9	193	12.0754	12.0765	12.0768						12.0768	1.4	1.0
6690921	7	MMC515-02R	Oily	513.8	278.0	236	12.1115	12.1137	12.1139						12.1139	2.4	1.0
6690921	8	MMC516-02R	Oily	477.0	277.8	199	12.3403	12.3420	12.3422						12.3422	1.9	1.0
6690921	9	MMC517-02R	Oily	498.5	276.9	222	12.3423	12.3437	12.3438						12.3438	1.5	1.0
	10																
	11																
	12																
	13																
			zero	0.0	0.0	zero	0.0000	0.0000	0.0000								
			100.0 gm	100.0	100.0	0.3000	0.2998	0.2998	0.2998								
	14																
	15																
	16																
	17																
	18																
	19																
	20																
	21																
	22																
	23																
			zero			zero											
			100.0 gm			0.3000											

NOTE: Vials are not to be exposed to lab atmosphere for > 2 minutes at a relative humidity of 50 %

Appearance of residue is noted in the Residue column (Oily residues, color of residues etc.)

COMMENTS: Verification weight 100g S/N 29785

Verification weight 0.3g S/N 4392-1

Digital Hygrometer S/N 192590073

Method 8A – Sulfuric Acid Mist by Titration

Bureau Veritas Laboratories
6740 Campobello Rd.
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.BVLabs.com

Inorganic Analysis Action / Comment Form

* Please note any action or anomalies impacting this set of samples

Client ID: Air Hygiene International Inc

Maxxam Job #: GC097773

Autosampler Index

Analysis	Worksheet	Run Date	Run #	Start Lab ID	End Lab ID	START	END	Analyst ID
Sulfuric Acid Mist	6696051	2020/04/24	1	MMC524	MMC529	16	23	LLE

Actions: *Impacted Sample ID's

Bottle discrepancies NO

Interferences observed NO

Reintegrations performed YES

Dilutions performed NO

Field / Trip blanks missing NA

Other

Explanation/comments:

Re-integrated due to poor automated baseline construction .

Inorganic Analysis Action / Comment Form

Client ID :	Air Hygiene	**Maxxam Job # :**	C097773
Analysis :		**Analyst :**	R. Sihota

	Start	End
Maxxam Sample ID's :	MMC524-01R	MMC529-01R

Analytical Worksheet(s) :	6698432
	6696057

Actions	*Impacted Sample ID's
Re-analysis needed (alternate technique)	No
Bottle discrepancies	No
Interferences observed	No
Dilutions needed	No
Internal calculations modified	No
Field / Trip blanks missing	No
Other	No

NOTE : * Please note any action or anomalies impacting this set of samples.

Comments :

Sulphuric Acid Mist


Run Date	2020/04/27
Calibration Date	2020/04/27
Analyst	R. Sihota
Test Code	SAMT8A-IP
Component	Sulphuric Acid Mist
RDL (H_2SO_4)	0.20

Normality H_2SO_4	0.0100	Up-to-date normality for H_2SO_4 taken from the bottle
Normality $Ba(ClO_4)_2.3H_2O$	0.0095	
Correlation	0.99996	
Slope	1.052	
Intercept	0.0617	

	Prep Date	Exp Date
0.01N $Ba(ClO_4)_2.3H_2O$:	2020/02/28	2020/08/28
Thorin Indicator :	2019/05/28	2020/05/28

Standard Number	H_2SO_4 Volume (mL)	Titrant Volume (mL)	H_2SO_4 (mg)	%
1	0.00	0.050	RSE	**16.6%**
2	0.06	0.110	0.05	-23%
3	3.00	3.230	3.01	0%
4	6.00	6.430	6.06	1%
5	9.00	9.490	8.97	0%
ICV (IPA)	6.00	6.260	5.90	98.3

	Lot Number/ID
H_2SO_4 Calibration :	4002D76
H_2SO_4 Reference :	4804K72
2-Propanol :	186011
Pipet # 1 :	IAWVE-8
Pipet # 2 :	IAWVE-12
Pipet # 3 :	IAWVE-16
Burette ID #	Buret#1 (Standard)



EPA 8 & 8A H_2SO_4 TITRATIONS (ISOPROPANOL SOLUTIONS)
(Samples are diluted to 250 ml with 80 % IPA before titration for method 8)
(20 mL aliquots are diluted with 80 mL IPA before titration for method 8A)
(Titrations are performed in duplicate - 100 mls aliquots - if sufficient sample exists)
Titrations must be repeated (if sufficient sample) if the absolute titration volume difference is > 0.20 mL

Job #	Worksheet #	Maxxam Sample ID	Sample Volume (mL)	Titration Volume (mL)	Barium Volume # 1 (mL)	Barium Volume # 2 (mL)	Barium Average Volume (mL)	Titrant Δ (mL)	H_2SO_4 (mg)	RDL (mg)	Spike or Dups (%)	Pass/Fail
C097773	6698432	Blank	50	20.000	0.060		0.060		-0.002	0.20		Blank Pass
	6698432	Spike	50	20.000	3.160		3.160		3.610	0.20	97.8	Spike Pass
	6698432	MMC524-01R	166	20.000	0.100	0.080	0.090	0.020	0.109	0.66		Pass
	6698432	MMC525-01R	103	20.000	0.060		0.055	0.010	-0.016	0.41		Pass
	6698432	MMC525-01R:D1	103	20.000	0.050				-0.028	0.41	18.2	**Dup Fail**
	6698432	MATSPK	103	20.000	3.220				7.581	0.41	98.0	MATSPK Pass
	6698432	MMC526-01R	108	20.000	0.080	0.070	0.075	0.010	0.033	0.43		Pass
	6698432	MMC527-01R	125	20.000	0.050	0.080	0.065	0.030	0.010	0.50		Pass
	6698432	MMC528-01R	132	20.000	0.060	0.060	0.060	0.000	-0.005	0.53		Pass
	6698432	MMC529-01R	183	20.000	0.080	0.070	0.075	0.010	0.057	0.73		Pass
Audit #1												
Audit #2												
		Titrant Check			3.230							Titrant Pass

		Blank										
		Spike										
Audit #1												
Audit #2												
		Titrant Check										

Volume Adjustment- Sulfuric Acid Mist

Run Date : 2020/04/27 | Analyst : R. Sihota | Method : M-8A | Component : Volume

Job #	Worksheet #	Maxxam Sample #	Sample Type Enter Blank	Charged Impinger Volume (mL)	Volume of sample received (mL)	Measured Bottle Contents (mL)	Volume Removed at Source (mL)	Volume Adjusted Theoretical (mL)	Final Volume to 50 mL with RODI
C097773	6696057	MMC524-01R			166.000	166.0	0	166	NA
	6696057	MMC525-01R			103.000	103.0	0	103	NA
	6696057	MMC526-01R			108.000	108.0	0	108	NA
	6696057	MMC527-01R			125.000	125.0	0	125	NA
	6696057	MMC528-01R			132.000	132.0	0	132	NA
	6696057	MMC529-01R			183.000	183.0	0	183	NA

Method 8A – Sulfuric Acid Mist by IC

Bureau Veritas Laboratories
6740 Campobello Rd.
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.BVLabs.com

WS# : 6696051

Page #: 1/1

RUSH

Report Name : Worksheet - (Liquids and Solids)

Assignment Date : Friday, April 24, 2020

Assigned to : Lang Le

Test Code : SAMIC-TR

Test Description : Sulphuric Acid Mist - IC

Instrument Id: NONT-ICEC2

Job Number	Sample Number	D	Sample ID	F	% Moisture	Wt or Vol	Final Vol	DF or AF	# Cont	Expiry Date	Test DeadLine	Criteria	Extract Date
	MTRX SPK		MSO3% MMC525-*										2020/04/24
	SPIKE		MSO3%										2020/04/24
	BLANK												2020/04/24
C097773*	MMC524-01R		M8A- U3 BASE W/*				166.0	1X	1	2020/05/14	2020/04/27 17:00		2020/04/24
C097773*	MMC525-01R	0	M8A- U3 BASE W/*				103		1	2020/05/15	2020/04/27 17:00		2020/04/24
C097773*	MMC525-01R	1	M8A- U3 BASE W/*				108		1	2020/05/15	2020/04/27 17:00		2020/04/24
C097773*	MMC526-01R		M8A- U3 BASE W/*				125		1	2020/05/13	2020/04/27 17:00		2020/04/24
C097773*	MMC527-01R		M8A- U3 BASE- R*				132		1	2020/05/14	2020/04/27 17:00		2020/04/24
C097773*	MMC528-01R		M8A- U3 BASE- R*				183	1X	1	2020/05/14	2020/04/27 17:00		2020/04/24
C097773*	MMC529-01R		M8A- U3 BASE- R*										

Remarks: FV = weighed LE APR 2 4 2020

Samples extracted by: Lang Le

Instrumentation performed by: Lang Le Date: APR 2 4 2020

Calculations performed by: Lang Le Date: 2020/04/24

Validated by: Date: APR 2 4 2020 LE

Job No.	Rep / Client Name / Remarks	Contact	Client Tier	National
GC097773	CJO Air Hygiene International Inc	Data Reports	Tier 3 (Enviro.)	

M8 titration requested therefore SAMTIT-TR added previous job C067891 M201A/ M202/M8A by IC (client confirmed to proceed with IC for this project). Field blank samples not received updgraded to rush by Sean Barnes 2020/04/21 cjo
Project #: BEC-19-CRICKETVALLEY.NY-START

Job	Sample	Lab Comments
	MTRX SPK	
	SPIKE	
	BLANK	
C097773	MMC524-01R	
C097773	MMC525-01R	
C097773	MMC525-01R:DUP	
C097773	MMC526-01R	
C097773	MMC527-01R	
C097773	MMC528-01R	
C097773	MMC529-01R	

WorkSheet 6696051 Instrument Sequences

1.	 6696051:MTRX SPK	MTRX SPK
2.	 6696051:SPIKE	SPIKE
3.	 6696051:BLANK	BLANK
4.	 6696051:MMC524-01	M8A- U3 BASE W/DB- R1
5.	 6696051:MMC525-01	M8A- U3 BASE W/DB- R2
6.	 6696051:MMC525-01:D1	M8A- U3 BASE W/DB- R2 :D1
7.	 6696051:MMC526-01	M8A- U3 BASE W/DB- R3
8.	 6696051:MMC527-01	M8A- U3 BASE- R1 -CW
9.	 6696051:MMC528-01	M8A- U3 BASE- R2 -CW
10.	 6696051:MMC529-01	M8A- U3 BASE- R3 -CW

Internal Data Validation Checklist

Analysis: Anions Run Date: 20200424

Worksheet # (s): 669051, 669057

	Primary review by the analyst - 100 % analysis review	yes	no	n/a
1	Sample analyses meet hold time criteria	✓		
2	Analysis set-up meets method criteria	✓		
3	Tuning and correct calibration used - criteria meets method criteria	✓		
4	SQC/Control Charts updated, analysis in statistical/method control	✓		
5	Internal area counts checked (if applicable)			✓
6	LCS, SRM are within acceptance criteria	✓		
7	Surrogate Recovery(s) is within acceptance criteria			✓
8	Method Blank meets acceptance criteria	✓		
9	Matrix Spike recovery(s) meets acceptance criteria	✓		
10	Duplicate precision meets acceptance criteria	✓		
11	QC is documented on the run logs			✓
12	Runs checked for carryover	✓		
13	Prep log / worksheet(s) are present, signed / dated by a prep / instrument analysts	✓		
14	Initial weights, splits, impringer volumes (where applicable) are documented	✓		
15	Standards and reagents traceable to Certificates of Analysis	✓		
16	Samples above calibration range diluted and reanalyzed			✓
17	Dilution factors (where justified) have been checked for correctness and entered			✓
18	Dilution results compared to original results - Comparison sound			✓
19	Analytical observations/anomalies documented in LIMS			✓
20	Random calculation checked and in correct units	✓		
21	If corrective actions were applied they are documented, initialed & dated			✓
22	Manual integration – before & after data with a reason included, initialed & dated	✓		
24	Transferred data is validated in LIMS for correctness	✓		
25	Data package assembled (where required)			✓

Reviewed by: Ling Li Date: 20200424

Comments:

	Secondary Supervisor/Qualified Data Review Staff	yes	no	n/a
1	Primary Review completed and correct	✓		
2	Repeats documented and referenced			✓
3	Method and sample deviations noted, anomalies described (if applicable)			✓
4	Data and QC validated in LIMS	✓		
5	Random calculation checked	✓		
6	Dilution factors/results have been checked and and compared to original results			✓
7	Worksheet(s) and sample prep sheets (FCDs) signed and dated	✓		
8	Data Package (if required) checked for completeness APR 24 2020			✓

Reviewed by: Date:

Comments:

Note: Primary and Secondary Internal Data Review Check must be performed by a different person

Report Name: Entry

Job #: C097773

Client: Air Hygiene International Inc
1600 West Tacoma Street
Broken Arrow, OK
USA 74012

Inv Attn: Accounts Payable

Task Order:
Line Item:

Report: same

Attention: Data Reports
Phone: (918)994 - 4163
Fax: () -
EMAIL: sbarnes@airhygiene.com ...

Project Coordinator: CJO

Printed: 2020/04/20 Version 3
Reception Date: 2020/04/18
Reception Time: 19:45
Login Date: 2020/04/20
REQUIRED DATE: 2020/05/04, 18:00
Quote Number: B90673
COC:
P.O. Number:
Project Number: BEC-19-CRICKETVALLEY.NY-START
Site Location:
Site #:
Client Number: 23832
Rpt Address #:
Q.C Samples: No

BV Labs Number	Client Sample ID/Report ID/Sample Info	Cont's	Store Code	Recd. OK	Sampling Date	Matrix	Test Codes
MMC512-01R	M202- U3 BASE W/DB- R1 M202- U3 BASE W/DB- R1	1-IMP	N/A	Yes	2020/04/16	TR	COND202-TR, WWATER-TR, SHIPPINGPU
MMC512-02R	M202- U3 BASE W/DB- R1 M202- U3 BASE W/DB- R1	1-IR	N/A	Yes	2020/04/16	TR	CON202E-TR, WSOLV-TR
MMC512-03R	M202- U3 BASE W/DB- R1 M202- U3 BASE W/DB- R1	1-FILT	N/A	Yes	2020/04/16	TR	FILPREP-TR
MMC513-01R	M202- U3 BASE W/DB- R2 M202- U3 BASE W/DB- R2	1-IMP	N/A	Yes	2020/04/17	TR	COND202-TR, WWATER-TR
MMC513-02R	M202- U3 BASE W/DB- R2 M202- U3 BASE W/DB- R2	1-IR	N/A	Yes	2020/04/17	TR	CON202E-TR, WSOLV-TR
MMC513-03R	M202- U3 BASE W/DB- R2 M202- U3 BASE W/DB- R2	1-FILT	N/A	Yes	2020/04/17	TR	FILPREP-TR
MMC514-01R	M202- U3 BASE W/DB- R3 M202- U3 BASE W/DB- R3	1-IMP	N/A	Yes	2020/04/17	TR	COND202-TR, WWATER-TR
MMC514-02R	M202- U3 BASE W/DB- R3 M202- U3 BASE W/DB- R3	1-IR	N/A	Yes	2020/04/17	TR	CON202E-TR, WSOLV-TR
MMC514-03R	M202- U3 BASE W/DB- R3 M202- U3 BASE W/DB- R3	1-FILT	N/A	Yes	2020/04/17	TR	FILPREP-TR
MMC515-01R	M202- U3 BASE- R1 M202- U3 BASE- R1	1-IMP	N/A	Yes	2020/04/15	TR	COND202-TR, WWATER-TR
MMC515-02R	M202- U3 BASE- R1 M202- U3 BASE- R1	1-IR	N/A	Yes	2020/04/15	TR	CON202E-TR, WSOLV-TR
MMC515-03R	M202- U3 BASE- R1 M202- U3 BASE- R1	1-FILT	N/A	Yes	2020/04/15	TR	FILPREP-TR
MMC516-01R	M202- U3 BASE- R2 M202- U3 BASE- R2	1-IMP	N/A	Yes	2020/04/15	TR	COND202-TR, WWATER-TR
MMC516-02R	M202- U3 BASE- R2 M202- U3 BASE- R2	1-IR	N/A	Yes	2020/04/15	TR	CON202E-TR, WSOLV-TR
MMC516-03R	M202- U3 BASE- R2 M202- U3 BASE- R2	1-FILT	N/A	Yes	2020/04/15	TR	FILPREP-TR
MMC517-01R	M202- U3 BASE- R3 M202- U3 BASE- R3	1-IMP	N/A	Yes	2020/04/15	TR	COND202-TR, WWATER-TR
MMC517-02R	M202- U3 BASE- R3 M202- U3 BASE- R3	1-IR	N/A	Yes	2020/04/15	TR	CON202E-TR, WSOLV-TR
MMC517-03R	M202- U3 BASE- R3 M202- U3 BASE- R3	1-FILT	N/A	Yes	2020/04/15	TR	FILPREP-TR
MMC518-01R	M201A- U3 BASE W/DB- R1 M201A- U3 BASE W/DB- R1	1-FILT	N/A	Yes	2020/04/16	TR	P2.5FIL-TR
MMC518-02R	M201A- U3 BASE W/DB- R1 M201A- U3 BASE W/DB- R1	1-PRA	N/A	Yes	2020/04/16	TR	P2.5-TR, *VOLACE-TR

BV Labs Number	Client Sample ID/Report ID/Sample Info	Cont's	Store Code	Recd. OK	Sampling Date	Matrix	Test Codes
MMC518-03R	M201A- U3 BASE W/DB- R1 M201A- U3 BASE W/DB- R1	1-PRA2	N/A	Yes	2020/04/16	TR	P2.5-10-TR
MMC518-04R	M201A- U3 BASE W/DB- R1 M201A- U3 BASE W/DB- R1	1-PRA3	N/A	Yes	2020/04/16	TR	P10-TR
MMC519-01R	M201A- U3 BASE W/DB- R2 M201A- U3 BASE W/DB- R2	1-FILT	N/A	Yes	2020/04/17	TR	P2.5FIL-TR
MMC519-02R	M201A- U3 BASE W/DB- R2 M201A- U3 BASE W/DB- R2	1-PRA	N/A	Yes	2020/04/17	TR	P2.5-TR, *VOLACE-TR
MMC519-03R	M201A- U3 BASE W/DB- R2 M201A- U3 BASE W/DB- R2	1-PRA2	N/A	Yes	2020/04/17	TR	P2.5-10-TR
MMC519-04R	M201A- U3 BASE W/DB- R2 M201A- U3 BASE W/DB- R2	1-PRA3	N/A	Yes	2020/04/17	TR	P10-TR
MMC520-01R	M201A- U3 BASE W/DB- R3 M201A- U3 BASE W/DB- R3	1-FILT	N/A	Yes	2020/04/17	TR	P2.5FIL-TR
MMC520-02R	M201A- U3 BASE W/DB- R3 M201A- U3 BASE W/DB- R3	1-PRA	N/A	Yes	2020/04/17	TR	P2.5-TR, *VOLACE-TR
MMC520-03R	M201A- U3 BASE W/DB- R3 M201A- U3 BASE W/DB- R3	1-PRA2	N/A	Yes	2020/04/17	TR	P2.5-10-TR
MMC520-04R	M201A- U3 BASE W/DB- R3 M201A- U3 BASE W/DB- R3	1-PRA3	N/A	Yes	2020/04/17	TR	P10-TR
MMC521-01R	M201A- U3 BASE- R1 M201A- U3 BASE- R1	1-FILT	N/A	Yes	2020/04/15	TR	P2.5FIL-TR
MMC521-02R	M201A- U3 BASE- R1 M201A- U3 BASE- R1	1-PRA	N/A	Yes	2020/04/15	TR	P2.5-TR, *VOLACE-TR
MMC521-03R	M201A- U3 BASE- R1 M201A- U3 BASE- R1	1-PRA2	N/A	Yes	2020/04/15	TR	P2.5-10-TR
MMC521-04R	M201A- U3 BASE- R1 M201A- U3 BASE- R1	1-PRA3	N/A	Yes	2020/04/15	TR	P10-TR
MMC522-01R	M201A- U3 BASE- R2 M201A- U3 BASE- R2	1-FILT	N/A	Yes	2020/04/15	TR	P2.5FIL-TR
MMC522-02R	M201A- U3 BASE- R2 M201A- U3 BASE- R2	1-PRA	N/A	Yes	2020/04/15	TR	P2.5-TR, *VOLACE-TR
MMC522-03R	M201A- U3 BASE- R2 M201A- U3 BASE- R2	1-PRA2	N/A	Yes	2020/04/15	TR	P2.5-10-TR
MMC522-04R	M201A- U3 BASE- R2 M201A- U3 BASE- R2	1-PRA3	N/A	Yes	2020/04/15	TR	P10-TR
MMC523-01R	M201A- U3 BASE- R3 M201A- U3 BASE- R3	1-FILT	N/A	Yes	2020/04/15	TR	P2.5FIL-TR
MMC523-02R	M201A- U3 BASE- R3 M201A- U3 BASE- R3	1-PRA	N/A	Yes	2020/04/15	TR	P2.5-TR, *VOLACE-TR
MMC523-03R	M201A- U3 BASE- R3 M201A- U3 BASE- R3	1-PRA2	N/A	Yes	2020/04/15	TR	P2.5-10-TR
MMC523-04R	M201A- U3 BASE- R3 M201A- U3 BASE- R3	1-PRA3	N/A	Yes	2020/04/15	TR	P10-TR
MMC524-01R	M8A- U3 BASE W/DB- R1 M8A- U3 BASE W/DB- R1	1-WI	N/A	Yes	2020/04/16	TR	SAMIC-TR, SAMT8A-IP, VOLUME-TR
MMC525-01R	M8A- U3 BASE W/DB- R2 M8A- U3 BASE W/DB- R2	1-WI	N/A	Yes	2020/04/17	TR	SAMIC-TR, SAMT8A-IP, VOLUME-TR
MMC526-01R	M8A- U3 BASE W/DB- R3 M8A- U3 BASE W/DB- R3	1-WI	N/A	Yes	2020/04/17	TR	SAMIC-TR, SAMT8A-IP, VOLUME-TR
MMC527-01R	M8A- U3 BASE- R1 -CW M8A- U3 BASE- R1 -CW	1-WI	N/A	Yes	2020/04/15	TR	SAMIC-TR, SAMT8A-IP, VOLUME-TR
MMC528-01R	M8A- U3 BASE- R2 -CW M8A- U3 BASE- R2 -CW	1-WI	N/A	Yes	2020/04/16	TR	SAMIC-TR, SAMT8A-IP, VOLUME-TR
MMC529-01R	M8A- U3 BASE- R3 -CW M8A- U3 BASE- R3 -CW	1-WI	N/A	Yes	2020/04/16	TR	SAMIC-TR, SAMT8A-IP, VOLUME-TR

Remarks: M8 titration requested therefore SAMTIT-TR added previous job C067891

BV Labs Number	Client Sample ID/Report ID/Sample Info	Cont's	Store Code	Recd. OK	Sampling Date	Matrix	Test Codes
	M201A/ M202/M8A by IC (client confirmed to proceed with IC for this project). Field blank samples not received						

Entered by: DKN
Date: 2020/04/20
Time: 15:59

Approved by:
Date:
Time:

Date of Sample Disposal:
Disposal by:

Worksheet Number: **6696051**

H2SO4 Acid Mist in IPA Impinger (M8mod) - Stack Sampling Train

mg

Parameter Name	Units	MTRX SPK	DL	SPIKE	DL	BLANK	DL
Sulphuric Acid Mist	mg	92.8	0.011	98.4	0.01	0	0.01

Parameter Name	C097773 MMC524	DL	C097773 MMC525	DL	C097773 MMC525 Dup1	DL	C097773 MMC526
Sulphuric Acid Mist	0.014	0.017	0.06	0.011	0.058	0.011	0.017

Parameter Name	DL	C097773 MMC527	DL	C097773 MMC528	DL	C097773 MMC529	DL
Sulphuric Acid Mist	0.011	0.047	0.013	0.094	0.013	0	0.019

Parameter Name	RDL	MDL	IDL				
Sulphuric Acid Mist	0.01	0.01	0				


Sulphuric Acid Mist

RUN DATE	2020/04/24
ANALYST	L Le
INSTRUMENT	DX-120
TESTCODE	SAMIC-TR
COMPONENT	Sulphuric Acid Mist
Spike (mg/L)	12.0
Units factor	0.001021

Standard / Reagent	Prepared	Traceability
Stock Calibration Standard	NA	#VALUE!
Stock Reference Standard	NA	#VALUE!
Intermediate Mixed Cal. Standard (IS)	2020/03/27	good
Intermediate Mixed Ref. Standard (IR)	2020/04/15	good
Working Calibration Standards	2020/04/16	good
Working Reference Standards	2020/04/15	good
Eluent Stock Solution	2020/04/02	good
Working Eluent Solution	2020/04/23	good
Regenerant Solution	NA	#VALUE!

Std ID	Actual Amount ppm	Area Counts
1	0.10	0.0056
2	2.40	0.1548
3	12.0	0.8078
4	24.0	1.6795
5	36.0	2.6191

Method Criteria	Limits	Expected	Results
2nd Order Correlation	-	≥0.990	0.99955
ICV (ppm)	± 0.90	18.0	17.781
QCS ICMIX6 (ppm)	± 0.75	15.0	15.015
Blank (ppm)	-	< 0.10	
Blank Spike (ppm)	± 1.20	12.0	
Duplicates (±%)	20	-	
Matrix Spike (%)	80 - 120	100	
CCB (ppm)	-	< 0.10	
CCV (ppm)	± 1.20	12.0	



Job #	Worksheet #	Maxxam ID	Volume (mL)	Sulphate reading (mg/L)	Dilution at IC	H2SO4 (mg)	RDL (mg)	Spike or Dups (%)	Pass Fail
C097773	6696051	Blank	100	0.0000		0.000	0.010		Blank pass
	6696051	Spike	100	11.8114		1.206	0.010	98.4	BSPK pass
	6696051	MMC524-01R	166	0.0811	1.0	0.014	0.017		
	6696051	MMC525-01R	103	0.5718	1.0	0.060	0.011		
	6696051	MMC525-01R DI		0.5481		0.058	0.011	4.2	Dup pass
	6696051	MATSPK		11.6922		1.230	0.011	92.8	MSPK pass
	6696051	MMC526-01R	108	0.1535	1.0	0.017	0.011		
	6696051	MMC527-01R	125	0.3669	1.0	0.047	0.013		
	6696051	MMC528-01R	132	0.6950	1.0	0.094	0.013		
	6696051	MMC529-01R	183	0.0000	1.0	0.000	0.019		
		CCB		0.0000					ccb pass
		CCV		12.0860					ccv pass
		CCB							
		CCV							
		Blank							
		Spike							
		CCB							
		CCV							
		CCB							
		CCV							

$MMC528 = 0.6950 \frac{mg}{L} \times 132 ml \times 0.001021$

$= 0.09367 mg\ H_2SO_4$

APR 2 4 2020

Worksheet Number: **6696057**

Final Volume of Impinger - Stack Sampling Train

ml


Parameter Name	Units	C097773 MMC524	DL	C097773 MMC525	DL	C097773 MMC526	DL
Volume	ml	166	1	103	1	108	1

Parameter Name	C097773 MMC527	DL	C097773 MMC528	DL	C097773 MMC529	DL	RDL
Volume	125	1	132	1	183	1	1

Parameter Name	MDL	IDL					
Volume	1	0					


Sample Name:	**Mblank**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 10:53**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
		TOTAL:		0.00	0.00	0.00



Sample Name:	**CALIB STD1**	*Inj. Vol.:*	**25.0**
Sample Type:	**standard**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 11:04**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.06	F	BMB	0.008	0.069	0.1177
3	1.55	Cl	MB*	0.009	0.112	0.0493
4	1.83	NO2	BMB	0.009	0.115	0.0547
5	2.67	Br	BMB	0.003	0.035	0.1010
6	3.03	NO3	BMB	0.010	0.088	0.0540
7	4.98	PO4	BMB	0.026	0.114	0.5140
8	6.60	SO4	BMB*	0.006	0.023	0.1030
		TOTAL:		0.07	0.56	0.99




APR 2 4 2020

M3 LK APR 2 4 2020


Sample Name:	**CALIB STD1**	*Inj. Vol.:*	**25.0**
Sample Type:	**standard**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 11:04**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.06	F	BMB	0.008	0.069	0.1177
3	1.55	Cl	bMB	0.004	0.070	0.0552
4	1.83	NO2	BMB	0.009	0.115	0.0547
5	2.67	Br	BMB	0.003	0.035	0.1010
6	3.03	NO3	BMB	0.010	0.088	0.0540
7	4.98	PO4	BMB	0.026	0.114	0.5313
8	6.60	SO4	BMB	0.004	0.020	0.1388
		TOTAL:		0.06	0.51	1.05



Sample Name:	**CALIB STD2**	*Inj. Vol.:*	**25.0**
Sample Type:	**standard**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 11:15**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.06	F	BMB	0.032	0.300	0.3786
3	1.55	Cl	MB*	0.056	0.855	0.6041
4	1.83	NO2	BMB	0.056	0.695	0.2983
5	2.67	Br	BMB	0.043	0.433	1.1953
6	3.02	NO3	BMB	0.083	0.711	0.3934
7	4.97	PO4	BMB*	0.073	0.307	1.1882
8	6.59	SO4	BMB*	0.155	0.549	2.3911
		TOTAL:		0.50	3.85	6.45




APR 2 4 2020

M3/SP

APR 2 4 2020


Sample Name:	**CALIB STD2**	*Inj. Vol.:*	**25.0**
Sample Type:	**standard**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 11:15**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.06	F	BMB	0.032	0.300	0.3786
2	1.55	Cl	BMB	0.051	0.828	0.5927
3	1.83	NO2	BMB	0.056	0.695	0.2983
4	2.67	Br	BMB	0.043	0.433	1.1953
5	3.02	NO3	BMB	0.083	0.711	0.3934
6	4.97	PO4	BMB	0.071	0.305	1.1673
7	6.59	SO4	BMB	0.148	0.545	2.3430
		TOTAL:		0.48	3.82	6.37




Sample Name:	**CALIB STD3**	*Inj. Vol.:*	**25.0**
Sample Type:	**standard**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 11:26**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	bMb	0.189	1.783	2.0034
3	1.55	Cl	bMB	0.274	4.396	2.9924
4	1.83	NO2	BMB	0.294	3.644	1.4912
5	2.67	Br	BMb	0.224	2.302	6.0086
6	3.01	NO3	bMB	0.445	3.822	2.0047
7	4.95	PO4	BMB	0.433	1.900	5.9921
8	6.57	SO4	BMB	0.808	2.966	12.0128
		TOTAL:		2.67	20.81	32.51




Sample Name:	**CALIB STD4**	*Inj. Vol.:*	**25.0**
Sample Type:	**standard**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 11:37**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	bMB	0.400	3.884	4.0008
3	1.55	Cl	bMB	0.576	9.433	6.0059
4	1.83	NO2	BMB	0.614	7.694	3.0085
5	2.67	Br	BMb	0.462	4.868	11.9931
6	2.99	NO3	bMB	0.929	7.985	3.9972
7	4.92	PO4	BMB	0.935	4.227	12.0084
8	6.54	SO4	BMB	1.679	6.284	23.9902
		TOTAL:		5.60	44.38	65.00




Sample Name:	**CALIB STD5**	*Inj. Vol.:*	**25.0**
Sample Type:	**standard**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 11:48**	*Run Time:*	**8.53**


No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	bMb	0.629	6.151	5.9994
3	1.56	Cl	bMb	0.908	14.874	8.9983
4	1.84	NO2	bMB	0.949	11.836	4.4973
5	2.66	Br	BMb	0.717	7.702	18.0021
6	2.98	NO3	bMB	1.458	12.459	6.0007
7	4.90	PO4	BMB	1.491	6.802	17.9974
8	6.52	SO4	BMB	2.619	9.878	36.0028
		TOTAL:		8.77	69.70	97.50





Calibration Batch Report


Sequence:	ANIONS0424	Inj. Vol.:	25.0
Program:	AS4A	Operator:	MISS-I-04-2402
Inj. Date/Time:	04/24/20 11:48	Run Time:	8.53
















Sequence:	**ANIONS0424**	*Inj. Vol.:*	**25.0**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**############**	*Run Time:*	**8.53**



No.	Ret.Time min	Peak Name	Cal.Type	Points	Offset (C0)	Slope (C1)	Curve (C2)	Corr.Coeff. %
2	1.06	F	QOff	5	-0.003	0.091	0.002	99.936
3	1.56	Cl	QOff	5	0.004	0.085	0.002	99.915
4	1.84	NO2	QOff	5	-0.001	0.192	0.004	99.969
5	2.66	Br	QOff	5	0.000	0.036	0.000	99.967
6	2.98	NO3	QOff	5	-0.001	0.212	0.005	99.942
7	4.90	PO4	QOff	5	-0.010	0.069	0.001	99.901
8	6.52	SO4	QOff	5	-0.001	0.065	0.000	99.955
AVERAGE:					-0.0017	0.1070	0.0021	99.9404


Sample Name:	**ICB**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 12:10**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
		TOTAL:		0.00	0.00	0.00




Sample Name:	**ICV-20-10(IR-20-05)**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 12:20**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	bMB	0.288	2.825	2.9639
3	1.56	Cl	BMB	0.427	6.989	4.5605
4	1.84	NO2	BMB	0.465	5.814	2.3136
5	2.67	Br	BMb	0.337	3.514	8.8957
6	3.00	NO3	bMB	0.666	5.758	2.9377
7	4.94	PO4	BMB	0.682	3.056	9.0622
8	6.56	SO4	BMB	1.219	4.559	17.7813
		TOTAL:		4.09	32.52	48.51



Sample Name:	**QCSICMIX6-20-04**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 12:31**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	BMb*	0.186	1.836	1.9703
4	1.56	Cl	MB*	0.500	8.203	5.2702
5	1.84	NO2	BMB	0.512	6.445	2.5321
6	2.67	Br	BMb*	0.387	4.029	10.1503
7	3.01	NO3	bMB	0.558	4.854	2.4853
8	4.96	PO4	BMB	0.349	1.549	4.9074
9	6.57	SO4	BMB	1.020	3.790	15.0148
		TOTAL:		3.51	30.71	42.33




APR 2 4 2020

APR 2 4 2020


Sample Name:	**QCSICMIX6-20-04**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 12:31**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	BMB	0.186	1.836	1.9703
3	1.56	Cl	bMB	0.508	8.203	5.3506
4	1.84	NO2	BMB	0.512	6.445	2.5321
5	2.67	Br	BMB	0.387	4.029	10.1503
6	3.01	NO3	bMB	0.558	4.854	2.4853
7	4.96	PO4	BMB	0.349	1.549	4.9074
8	6.57	SO4	BMB	1.020	3.790	15.0148
		TOTAL:		3.52	30.71	42.41




Sample Name:	**6696051:BLANK**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 13:26**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
		TOTAL:		0.00	0.00	0.00




Sample Name:	**6696051:SPIKE**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 13:37**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	BMB	0.202	1.855	2.1251
3	1.55	Cl	BMB	0.278	4.393	3.0330
4	1.83	NO2	BMB	0.297	3.664	1.5044
5	2.67	Br	BMb	0.220	2.256	5.9057
6	3.00	NO3	bMB	0.436	3.743	1.9688
7	4.94	PO4	BMB	0.434	1.918	6.0087
8	6.56	SO4	BMB	0.794	2.936	11.8114
		TOTAL:		2.66	20.76	32.36



Sample Name:	**6696051:MMC524-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 13:48**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.55	Cl	BMB	0.002	0.037	-0.0252
2	6.60	SO4	BMB*	0.004	0.017	0.0811
		TOTAL:		0.01	0.05	0.06




APR 24 2020

M3 APR 24 2020


Sample Name:	**6696051:MMC524-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 13:48**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.55	Cl	BMB	0.002	0.037	-0.0252
2	6.60	SO4	BMB	0.004	0.016	0.0711
		TOTAL:		0.01	0.05	0.05



Sample Name:	**6696051:MMC525-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 13:59**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.55	Cl	BMB	0.004	0.073	0.0012
2	6.59	SO4	BMB*	0.036	0.126	0.5718
		TOTAL:		0.04	0.20	0.57




APR 2 4 2020

MB UF APR 2 4 2020


Sample Name:	**6696051:MMC525-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 13:59**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.55	Cl	BMB	0.004	0.073	0.0012
2	6.59	SO4	BMB	0.030	0.120	0.4855
		TOTAL:		0.03	0.19	0.49



Sample Name:	**6696051:MMC525-01:D1**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:10**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.54	Cl	BMB	0.004	0.069	-0.0022
2	6.59	SO4	BMB*	0.034	0.125	0.5481
		TOTAL:		0.04	0.19	0.55




MB APR 24 2020

APR 24 2020


Sample Name:	**6696051:MMC525-01:D1**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:10**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.54	Cl	BMB	0.004	0.069	-0.0022
2	6.59	SO4	BMB	0.030	0.120	0.4842
		TOTAL:		0.03	0.19	0.48




Sample Name:	**6696051:MTRX SPK**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:20**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	bMb	0.189	1.758	1.9952
3	1.55	Cl	bMB	0.263	4.176	2.8782
4	1.83	NO2	BMB	0.280	3.457	1.4222
5	2.67	Br	BMb	0.206	2.114	5.5602
6	3.01	NO3	bMB	0.410	3.515	1.8549
7	4.95	PO4	BMB	0.404	1.801	5.6283
8	6.56	SO4	BMB	0.785	2.892	11.6922
		TOTAL:		2.54	19.71	31.03



Sample Name:	**6696051:MMC526-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:31**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	6.60	SO4	BMB*	0.009	0.031	0.1535
		TOTAL:		0.01	0.03	0.15




M3
LE APR 2 4 2020

APR 2 4 2020


Sample Name:	**6696051:MMC526-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:31**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	6.60	SO4	BMB	0.007	0.029	0.1292
		TOTAL:		0.01	0.03	0.13



Sample Name:	**6696051:MMC527-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:42**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.55	Cl	BMB	0.006	0.093	0.0149
2	1.83	NO2	BMB	0.004	0.054	0.0301
3	6.59	SO4	BMB*	0.023	0.084	0.3669
		TOTAL:		0.03	0.23	0.41




M3 APR 24 2020

APR 24 2020


Sample Name:	**6696051:MMC527-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:42**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.55	Cl	BMB	0.006	0.093	0.0149
2	1.83	NO2	BMB	0.004	0.054	0.0301
3	6.59	SO4	BMB	0.021	0.082	0.3395
		TOTAL:		0.03	0.23	0.38




Sample Name:	**6696051:MMC528-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 14:53**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.07	F	BMB	0.005	0.042	0.0856
2	1.56	Cl	BMB	0.006	0.100	0.0218
3	1.84	NO2	BMB	0.006	0.077	0.0403
4	6.59	SO4	BMB	0.044	0.162	0.6950
		TOTAL:		0.06	0.38	0.84




Sample Name:	**6696051:MMC529-01**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 15:04**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
1	1.55	Cl	BMB	0.002	0.041	-0.0230
		TOTAL:		0.00	0.04	-0.02




Sample Name:	**CCB**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 15:15**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
		TOTAL:		0.00	0.00	0.00



Sample Name:	**CCV**	*Inj. Vol.:*	**25.0**
Sample Type:	**unknown**	*Dilution Factor:*	**1.0000**
Program:	**AS4A**	*Operator:*	**n.a.**
Inj. Date/Time:	**2020/04/24 15:26**	*Run Time:*	**8.50**

No.	Time min	Peak Name	Type	Area µS*min	Height µS	Amount ppm
2	1.06	F	bMB	0.197	1.887	2.0767
3	1.56	Cl	BMB	0.276	4.411	3.0132
4	1.84	NO2	BMB	0.296	3.640	1.5012
5	2.70	Br	BMB	0.226	2.299	6.0619
6	3.04	NO3	BMB	0.448	3.811	2.0205
7	4.95	PO4	BMB	0.441	1.963	6.0929
8	6.57	SO4	BMB	0.813	2.999	12.0860
		TOTAL:		2.70	21.01	32.85



This is the last page of the report and is intentionally left blank

Bureau Veritas Laboratories
6740 Campobello Rd.
Mississauga, Ontario, Canada
L5N 2L8
1-800-668-0639
www.bvlabs.com

QUALITY ASSURANCE AND QUALITY CONTROL DATA

Audit Sample Data
(not required for this scope of work)

APPENDIX E

FUEL ANALYSIS RECORDS

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: April 15, 2020
Project #: bec-19-cricketvalley.ny-start#3

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	96.1040	16.0430	15.42	92.69	994.85	956.09	895.75	860.86
Ethane	C_2H_6	3.1230	30.0700	0.94	5.65	1,743.15	54.44	1,594.41	49.79
Propane	C_3H_8	0.1380	44.0970	0.06	0.37	2,478.35	3.42	2,280.17	3.15
iso-Butane	iC_4H_{10}	0.0040	58.1230	0.00	0.01	3,203.11	0.13	2,955.38	0.12
n-Butane	nC_4H_{10}	0.0060	58.1230	0.00	0.02	3,213.35	0.19	2,965.62	0.18
Iso-Pentane	iC_5H_{12}	0.0010	72.1500	0.00	0.00	3,940.87	0.04	3,643.50	0.04
n-Pentane	nC_5H_{12}	0.0010	72.1500	0.00	0.00	3,948.75	0.04	3,648.32	0.04
Hexanes	C_6H_{14}	0.0000	86.1770	0.00	0.00	4,684.54	0.00	4,337.82	0.00
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.2480	44.0100	0.11	0.66	0.00	0.00	0.00	0.00
Nitrogen	N_2	0.3550	28.0134	0.10	0.60	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.0000	31.9988	0.00	0.00	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0200	2.0159	0.00	0.00	319.34	0.06	269.82	0.05
Totals		**100.000**		**16.63**	**100.00**	**dry**	**1,014.41**	**dry**	**914.22**
						wet[2,5]	**991.02**	**wet[2,5]**	**893.14**

Characteristics of Fuel Gas		
Molecular Weight of gas =	16.634	lb/lb-mole
Btu per lb. of gas[4] =	23,492.652	gross (HHV)
Btu per lb. of gas[4] =	21,172.377	net (LHV)
Density of fuel gas[2] =	0.0432	lb/cu. ft
Wt % VOC in fuel gas =	0.41	%
Specific Gravity[1] =	0.5743	

Component	Wt%
carbon	74.42
oxygen	0.48
hydrogen	24.51
nitrogen	0.60
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,638.02
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: April 15, 2020
Project #: bec-19-cricketvalley.ny-start#3

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	89.168	16.0430	14.31	81.81	994.85	887.09	895.75	798.73
Ethane	C_2H_6	3.164	30.0700	0.95	5.44	1,743.15	55.16	1,594.41	50.45
Propane	C_3H_8	0.114	44.0970	0.05	0.29	2,478.35	2.83	2,280.17	2.60
iso-Butane	iC_4H_{10}	0.006	58.1230	0.00	0.02	3,203.11	0.18	2,955.38	0.17
n-Butane	nC_4H_{10}	0.006	58.1230	0.00	0.02	3,213.35	0.18	2,965.62	0.17
Iso-Pentane	iC_5H_{12}	0.003	72.1500	0.00	0.01	3,940.87	0.12	3,643.50	0.11
n-Pentane	nC_5H_{12}	0.003	72.1500	0.00	0.01	3,948.75	0.12	3,648.32	0.11
Hexanes	C_6H_{14}	0.000	86.1770	0.00	0.00	4,684.54	0.00	4,337.82	0.00
Heptanes	C_7H_{16}	0.000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.354	44.0100	0.16	0.89	0.00	0.00	0.00	0.00
Nitrogen*	N_2	**7.182**	28.0134	2.01	11.51	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.000	31.9988	0.00	0.00	0.00	0.00	0.00	0.00
Helium	He	0.000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
Totals		**100.000**		**17.49**	**100.00**	**dry**	**945.68**	**dry**	**852.34**
						wet[2,5]	**923.87**	**wet[2,5]**	**832.69**

* Note: nitrogen content indicates atmospheric contamination or leak in sampling system. Subsequent sample substituted for calculations

Characteristics of Fuel Gas		
Molecular Weight of gas =	17.486	lb/lb-mole
Btu per lb. of gas[4] =	20,834.278	gross (HHV)
Btu per lb. of gas[4] =	18,777.981	net (LHV)
Density of fuel gas[2] =	0.0454	lb/cu. ft
Wt % VOC in fuel gas =	0.35	%
Specific Gravity[1] =	0.6037	

Component	Wt%
carbon	66.13
oxygen	0.65
hydrogen	21.72
nitrogen	11.51
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,713.75
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: April 16, 2020
Project #: bec-19-cricketvalley.ny-start#3

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	93.6582	16.0430	15.03	88.32	994.85	931.75	895.75	838.95
Ethane	C_2H_6	4.2566	30.0700	1.28	7.52	1,743.15	74.20	1,594.41	67.87
Propane	C_3H_8	0.1339	44.0970	0.06	0.35	2,478.35	3.32	2,280.17	3.05
iso-Butane	iC_4H_{10}	0.0051	58.1230	0.00	0.02	3,203.11	0.16	2,955.38	0.15
n-Butane	nC_4H_{10}	0.0051	58.1230	0.00	0.02	3,213.35	0.16	2,965.62	0.15
Iso-Pentane	iC_5H_{12}	0.0010	72.1500	0.00	0.00	3,940.87	0.04	3,643.50	0.04
n-Pentane	nC_5H_{12}	0.0010	72.1500	0.00	0.00	3,948.75	0.04	3,648.32	0.04
Hexanes	C_6H_{14}	0.0000	86.1770	0.00	0.00	4,684.54	0.00	4,337.82	0.00
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.5510	44.0100	0.24	1.43	0.00	0.00	0.00	0.00
Nitrogen	N_2	1.1224	28.0134	0.31	1.85	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.2596	31.9988	0.08	0.49	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0061	2.0159	0.00	0.00	319.34	0.02	269.82	0.02
Totals		**100.000**		**17.01**	**100.00**	**dry**	**1,009.70**	**dry**	**910.26**
						wet[2,5]	**986.42**	**wet[2,5]**	**889.27**

Characteristics of Fuel Gas		
Molecular Weight of gas =	17.012	lb/lb-mole
Btu per lb. of gas[4] =	22,864.088	gross (HHV)
Btu per lb. of gas[4] =	20,612.385	net (LHV)
Density of fuel gas[2] =	0.0442	lb/cu. ft
Wt % VOC in fuel gas =	0.39	%
Specific Gravity[1] =	0.5874	

Component	Wt%
carbon	72.84
oxygen	1.52
hydrogen	23.78
nitrogen	1.85
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,641.42
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

Client: Cricket Valley Energy Center LLC
Location: Cricket Valley Energy Center
Date: April 17, 2020
Project #: bec-19-cricketvalley.ny-start#3

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular[1] Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net[1,3] Heating Value (Btu/ft^3)	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH_4	92.7470	16.0430	14.88	86.77	994.85	922.69	895.75	830.79
Ethane	C_2H_6	4.2076	30.0700	1.27	7.38	1,743.15	73.34	1,594.41	67.09
Propane	C_3H_8	0.2594	44.0970	0.11	0.67	2,478.35	6.43	2,280.17	5.91
iso-Butane	iC_4H_{10}	0.0206	58.1230	0.01	0.07	3,203.11	0.66	2,955.38	0.61
n-Butane	nC_4H_{10}	0.0244	58.1230	0.01	0.08	3,213.35	0.78	2,965.62	0.72
Iso-Pentane	iC_5H_{12}	0.0013	72.1500	0.00	0.01	3,940.87	0.05	3,643.50	0.05
n-Pentane	nC_5H_{12}	0.0013	72.1500	0.00	0.01	3,948.75	0.05	3,648.32	0.05
Hexanes	C_6H_{14}	0.0000	86.1770	0.00	0.00	4,684.54	0.00	4,337.82	0.00
Heptanes	C_7H_{16}	0.0000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C_8H_{18}	0.0000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO_2	0.5882	44.0100	0.26	1.51	0.00	0.00	0.00	0.00
Nitrogen	N_2	2.1477	28.0134	0.60	3.51	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H_2S	0.0000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O_2	0.0000	31.9988	0.00	0.00	0.00	0.00	0.00	0.00
Helium	He	0.0000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H_2	0.0025	2.0159	0.00	0.00	319.34	0.01	269.82	0.01
Totals		**100.000**		**17.15**	**100.00**	**dry**	**1,004.02**	**dry**	**905.22**
						wet[2,5]	**980.87**	**wet[2,5]**	**884.35**

Characteristics of Fuel Gas		
Molecular Weight of gas =	17.148	lb/lb-mole
Btu per lb. of gas[4] =	22,555.765	gross (HHV)
Btu per lb. of gas[4] =	20,336.257	net (LHV)
Density of fuel gas[2] =	0.0445	lb/cu. ft
Wt % VOC in fuel gas =	0.83	%
Specific Gravity[1] =	0.5921	

Component	Wt%
carbon	71.95
oxygen	1.10
hydrogen	23.44
nitrogen	3.51
helium	0.00
sulfur	0.00
Total	**100.00**

F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,663.09
(Based on EPA RM-19) at 68 deg F and 14.696 psia

F-Factor Calculation:

F-Factor = 1,000,000*((3.64*%H)+(1.53*%C)+(0.57*%S)+(0.14*%N)-(0.46*%O))/GCV

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

References:

[1] ASTM D 3588

[2] Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg

[3] Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III

[4] Introduction to Fluid Mechanics, 3rd ed. - William S. Janna

[5] GPA Reference Bulletin 181-86, revised 1986, reprinted 1995

CLIENT:	McHale & Associates, Inc	**REQUESTED BY:**	Mr. Wilson Davis
CLIENT PROJECT:	Bechtel Cricket Valley	**PURCHASE ORDER NO:**	PENDING
LABORATORY NO:	92357-001	**REPORT DATE:**	April 22, 2020
SAMPLE:	4819 U3-Unfired 1 A (4819) 2020-04-15 13:55		

Composition of Natural Gas by Gas Chromatography. ASTM D 1945.a

	Results. Mol %
Hydrogen	0.020
Oxygen	0.000
Nitrogen	0.355
Carbon Dioxide	0.248
Methane	96.104
Ethane	3.123
Propane	0.138
iso-Butane	0.004
n-Butane	0.006
iso-Pentane	0.001
n-Pentane	0.001
Hexanes Plus	0.000
TOTAL	**100.000**

Calorific Value and Specific Gravity. Calculated at 14.696 psia and 60°F. ASTM D 3588.e

	Results
Specific Gravity at 60ºF (air=1)	0.5743
NET (Dry basis), BTU/scf	928.2
Gross (Dry basis), BTU/scf	1,030
NET (Dry basis), BTU/lb	21,177
Gross (Dry basis), BTU/lb	23,496

Respectfully submitted
For Texas OilTech Laboratories, L.P.



Roland Gore
Associate Laboratory Director

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-001 Page 1 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R1-NoDuct Natural Gas Sample 2020-04-15		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography, ASTM D 1945.a*

	Results, Mol %
Hydrogen	0.0000
Oxygen	0.0000
Nitrogen	7.1817
Carbon Dioxide	0.3541
Methane	89.1684
Ethane	3.1642
Propane	0.1142
iso-Butane	0.0057
n-Butane	0.0057
iso-Pentane	0.0030
n-Pentane	0.0030
Hexanes Plus	0.0000
TOTAL	**100.0000**

*Data has been air corrected.

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 60°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	865.3
Gross (Dry basis), BTU/scf	960.0
NET (Dry basis), BTU/lb	18,782
Gross (Dry basis), BTU/lb	20,837

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 68°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	852.2
Gross (Dry basis), BTU/scf	945.4
NET (Dry basis), BTU/lb	18,782
Gross (Dry basis), BTU/lb	20,837

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-001 Page 2 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R1-NoDuct Natural Gas Sample 2020-04-15		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	1.0
Carbonyl Sulfide	0.1
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	<0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.1
Methyl Mercaptan	<0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.1
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	0.5
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-001 Page 3 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R1-NoDuct Natural Gas Sample 2020-04-15		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504 Continued...

	Results, ppm/Wt
1-Octanethiol	<0.1
2-Ethyl Thiophene	<0.1

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	1.5×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	1.5×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	1.5
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	1.5
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.04
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.04

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-002 Page 1 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R1-Duct Natural Gas Sample 2020-04-16		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography, ASTM D 1945.a

	Results, Mol %
Hydrogen	0.0061
Oxygen	0.2596
Nitrogen	1.1224
Carbon Dioxide	0.5510
Methane	93.6582
Ethane	4.2566
Propane	0.1339
iso-Butane	0.0051
n-Butane	0.0051
iso-Pentane	0.0010
n-Pentane	0.0010
Hexanes Plus	0.0000
TOTAL	100.0000

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 60°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	924.1
Gross (Dry basis), BTU/scf	1,026
NET (Dry basis), BTU/lb	20,617
Gross (Dry basis), BTU/lb	22,867

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 68°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	910.1
Gross (Dry basis), BTU/scf	1,010
NET (Dry basis), BTU/lb	20,617
Gross (Dry basis), BTU/lb	22,867

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-002 Page 2 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R1-Duct Natural Gas Sample 2020-04-16		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	1.4
Carbonyl Sulfide	0.3
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.5
Methyl Mercaptan	0.1
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.2
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	1.8
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-002 Page 3 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R1-Duct Natural Gas Sample 2020-04-16		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC. ASTM D 5504 Continued....

	Results, ppm/Wt
1-Octanethiol	<0.1
2-Ethyl Thiophene	<0.1

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	3.7×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	3.6×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	3.7
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	3.6
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.11
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.11

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-003 Page 1 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R2&3- Duct_R3 noduct Natural Gas Sample 2020-04-17		

TEST **RESULT**

Composition of Natural Gas by Gas Chromatography, ASTM D 1945.a*

	Results, Mol %
Hydrogen	0.0025
Oxygen	0.0000
Nitrogen	2.1477
Carbon Dioxide	0.5882
Methane	92.7470
Ethane	4.2076
Propane	0.2594
iso-Butane	0.0206
n-Butane	0.0244
iso-Pentane	0.0013
n-Pentane	0.0013
Hexanes Plus	0.0000
TOTAL	**100.0000**

*Data has been air corrected.

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 60°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	919.0
Gross (Dry basis), BTU/scf	1,019
NET (Dry basis), BTU/lb	20,341
Gross (Dry basis), BTU/lb	22,559

Calorific Value and Specific Gravity, Calculated at 14.696 psia and 68°F, ASTM D 3588.e

	Results
NET (Dry basis), BTU/scf	905.1
Gross (Dry basis), BTU/scf	991.7
NET (Dry basis), BTU/lb	20,341
Gross (Dry basis), BTU/lb	22,559

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985
Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-003 Page 2 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R2&3- Duct_R3 noduct Natural Gas Sample 2020-04-17		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC, ASTM D 5504

	Results, ppm/Wt
Hydrogen Sulfide	0.6
Carbonyl Sulfide	0.4
2-Methyl Thiophene	<0.1
2-Pentyl Mercaptan	<0.1
3-Methyl Thiophene	<0.1
Benzothiophene	<0.1
Carbon Disulfide	<0.1
Diethylsulfide	<0.1
Dimethylsulfide	<0.1
Ethyl Mercaptan	0.1
Ethylmethylsulfide	<0.1
Isobutyl Mercaptan	<0.1
Isopropyl Mercaptan	0.5
Methyl Mercaptan	0.2
Methyl-t-butyl Sulfide	<0.1
n-Butyl Mercaptan	<0.1
Propyl Mercaptan	0.2
Tert-butyl disulfide	<0.1
Tert-Butyl mercaptan	1.7
Tetra-Hydro Thiophene	<0.1
Thiophene	<0.1
Thiophenol	<0.1
Dibenzothiophene	<0.1
1,2-Ethanedithiol	<0.1
Propyl Sulfide	<0.1
1-Hexanethiol	<0.1
1,5-Pentanedithiol	<0.1
Bromothiophene	<0.1
Propyl Disulfide	<0.1
1-Heptanethiol	<0.1
2-Methyl Benzothiophene	<0.1
Phenyl Sulfide	<0.1
1-Nonanethiol	<0.1
2-Butyl Thiophene	<0.1
3-Butyl Thiophene	<0.1

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005
These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Certificate of Analysis

SINCE 1985

Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

CLIENT:	Air Hygiene International	**REQUESTED BY:**	Dr. Sean Barnes
CLIENT PROJECT:	bec-19-cricketvalley.ny-start#1	**PURCHASE ORDER NO:**	190827LAB
LABORATORY NO:	92376-003 Page 3 of 3	**REPORT DATE:**	April 30, 2020
SAMPLE:	Cricket Valley-R2&3- Duct_R3 noduct Natural Gas Sample 2020-04-17		

TEST **RESULT**

Sulfur Compounds in Natural Gas and Gaseous Fuels by GC. ASTM D 5504 Continued...

	Results, ppm/Wt
1-Octanethiol	<0.1
2-Ethyl Thiophene	<0.1

Parameter	***Results***
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, wt%	1.1×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, wt%	1.1×10^{-4}
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 60ºF, ppmw	1.1
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, @ 68ºF, ppmw	1.1
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 60ºF	0.03
Sulfur Total Volatile, in Gaseous Hydrocarbons and LPG, ASTM D 6667, grains/100 scf @ 68ºF	0.03

Respectfully submitted
For Texas OilTech Laboratories, L.P.

Roland Gore
Associate Laboratory Director

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

SINCE 1985
Quality Controlled Through Analysis

10630 FALLSTONE RD. HOUSTON, TEXAS 77099
P.O. BOX 741905, HOUSTON, TEXAS 77274

TEL: (281) 495-2400
FAX: (281) 495-2410

Conversion Factors (Gas Analysis) to adjust BTU/ft^3 and Sulfur content @60ºF and 68ºF

NET (Dry Basis) BTU/scf @60ºF, factor= 1

NET (Dry Basis) BTU/scf @68ºF, factor= 0.984839

Gross (Dry Basis) BTU/scf @60ºF, factor = 1

Gross (Dry Basis) BTU/scf @68ºF, factor = 0.984839

NET (Dry Basis) BTU/lb @60ºF, factor = 1

NET (Dry Basis) BTU/lb @68ºF, factor = 1

GROSS (Dry Basis) BTU/lb @60ºF, factor= 1

GROSS (Dry Basis) BTU/lb @68ºF, factor= 1

Sulfur Total Volatile, ASTM D 6667 @60ºF, wt% or ppmwt, factor= 1

Sulfur Total Volatile, ASTM D 6667 @68ºF, wt% or ppmwt, factor= 0.984839

Sulfur Total Volatile, ASTM D 6667 @60ºF, grains/100scf = ppmwt @60ºF x 0.0300

Sulfur Total Volatile, ASTM D 6667 @68ºF, grains/100scf = ppmwt @60ºF x 0.0295

Conversion Factors (Liquid Fuel Analysis)

Liquid Fuel BTU/lb @60ºF= Liquid fuel BTU/lb @68ºF

Cert. No.: 0005085, 17025
Quality Management System Certified to ISO 9001:2008, and ISO 17025:2005

These analyses, opinions or interpretations are based on material supplied by the client to whom, and for whose exclusive and confidential use this report is made. Results related only to the items tested. Texas OilTech Laboratories, L.P. and its officers assume no responsibility and make no warranty for proper operations of any petroleum, oil, gas or any other material in connection with which this report is used or relied on. This report may not be reproduced, except in full without prior written approval by Texas OilTech Laboratories, L.P.

Air Hygiene International, Inc.
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
(888) 461-8778
www.airhygiene.com

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Project Number:	bec-19-cricketvalley.ny-start#1	Laboratory Analysis Requested:	
Person Taking Samples:	Swanson B., R. White	Fuel Component and Sulfur Analysis	

Sample Number	Location	Date	Volume	Analysis Method(s) [and target(s)]						
				GPA2261/ASTM 1945 [component analysis]	GPA 2172 Calculation @ 60 F & 68 F [HHV]	ASTM 5504 [speciated sulfur content]				
UNIT3_41520_FUELGAS A	Cricket Valley-R1-NoDuct Natural Gas Sample [primary]	04/15/20	10L	X	X	X				
UNIT3_41520_FUELGAS B	Cricket Valley-R1-NoDuct Natural Gas Sample [backup]	04/15/20	10L	as necessary	as necessary	as necessary				
UNIT3_41620_FUELGAS A	Cricket Valley-R1-Duct Natural Gas Sample [primary]	04/16/20	10L	X	X	X				
UNIT3_41620_FUELGAS B	Cricket Valley-R1-Duct Natural Gas Sample [backup]	04/16/20	10L	as necessary	as necessary	as necessary				
UNIT3_41720_FUELGAS A	Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample [primary]	04/17/20	10L	X	X	X				
UNIT2_41720_FUELGAS B	Cricket Valley-R2&3-Duct_R3 noduct Natural Gas Sample [backup]	04/17/20	10L	as necessary	as necessary	as necessary				

Relinquished by: (Signature)	Date: 4/20/20	Time: 12:00	Received by: (Signature) G. Morrow	Date: 4.21.20	Time: 11:28
Relinquished by: (Signature)	Date:	Time:	Received by: (Signature)	Date:	Time:

Please return cooler

APPENDIX F

STRATIFICATION TEST DATA

STRATIFICATION TEST DATA

Stratification Test Data Base Load

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric 7F.05
Location	Dover Plains, New York

Test Information	
Date	04/15/20
Project #	bec-19-cricketvalley.ny-start#3
Unit Number	U-00003
Load	Base
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)** ☐ Part 60	☑ Part 75	


Created with Traverse-AHI v20200108

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	04/15/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#3
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2


Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
				12 points	


[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	04/15/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#3
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	10:33:05	**Run End**	11:39:05

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	8.00	10:33:05	10:41:05	12.34	0.13%	2.13	0.86%
D-2	5.00	10:41:05	10:46:05	12.34	0.09%	1.95	**7.54%**
D-1	5.00	10:46:05	10:51:05	12.36	0.07%	2.08	1.37%
C-3	6.00	10:51:05	10:57:05	12.34	0.09%	2.12	0.53%
C-2	5.00	10:57:05	11:02:05	12.35	0.01%	2.07	1.85%
C-1	5.00	11:02:05	11:07:05	12.34	0.09%	2.08	1.37%
B-3	6.00	11:07:05	11:13:05	12.37	**0.15%**	2.06	2.32%
B-2	5.00	11:13:05	11:18:05	12.34	0.09%	2.24	6.22%
B-1	5.00	11:18:05	11:23:05	12.36	0.07%	2.18	3.37%
A-3	6.00	11:23:05	11:29:05	12.36	0.07%	2.13	1.00%
A-2	5.00	11:29:05	11:34:05	12.36	0.07%	2.23	5.74%
A-1	5.00	11:34:05	11:39:05	12.36	0.07%	2.04	3.27%
Average				12.35		2.11	

			O_2		NOx		
			Criteria	**Results**	**Criteria**	**Results**	**AND criteria**
RATA Part 75	Non-Stratified %	≤	5%	Non (%)	5%	Non (Δ)	Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.
	Non-Stratified Δ	≤	0.3		3		
	Minimally-Stratified %	≤	10%		10%		
	Minimally-Stratified Δ	≤	0.5		5		
	Stratified	>	10%		10%		
	Outcome		1 point		1 point		
	Location		any point		any point		
	Maximum Concentration		12.37		2.24		
	Upscale Δ = Max Concentration - Average		0.02	Non	0.13	Non	
	Upscale % Difference		0.15%	Non	6.22%	Mini	
	Minimum Concentration		12.34		1.95		
	Downscale Δ = Average - Min Concentration		0.02	Non	0.16	Non	
	Downscale % Difference		0.13%	Non	7.54%	Mini	
	First Point on List Closest to Average		C-1		C-2		
Port Averages with Maximum Concentration Indicator	**Port A Average**		12.36	<max	2.13		
	Port B Average		12.36		2.16	<max	
	Port C Average		12.34		2.09		
	Port D Average		12.35		2.05		
	Port E Average						
	Port F Average						
	Port G Average						

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	04/15/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#3
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	10:33:05	**Run End**	11:39:05

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	7.54 % for NOx
Maximum Pollutant Conc. Diff.	0.16 ppm for NOx
Maximum Diluent Conc. Diff.	0.02 % for O_2
Stratification Conclusions	
Comparison	all diluents/pollutants
Stack Diameter	D > 93.6 in.


Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type
- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

☐ Use 6.5.6.3(a) points?

☐ 6.5.6(b)(2) alt. points could apply



STRATIFICATION TEST DATA

Stratification Test Data Base+DB Load

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric 7F.05
Location	Dover Plains, New York

Test Information	
Date	04/16/20
Project #	bec-19-cricketvalley.ny-start#3
Unit Number	U-00003
Load	Base+DB
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)** ☐ Part 60	☑ Part 75	

Created with Traverse-AHI v20200108


bec-19-cricketvalley.ny-start#3-U-00003-StratBaseDB

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	04/16/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#3
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2


Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Comp Stratification Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
				12 points	


[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	04/16/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#3
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	12:29:12	**Run End**	13:35:12

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	8.00	12:29:12	12:37:12	11.81	0.05%	2.47	1.89%
D-2	5.00	12:37:12	12:42:12	11.81	0.05%	2.32	**4.30%**
D-1	5.00	12:42:12	12:47:12	11.81	0.05%	2.46	1.48%
C-3	6.00	12:47:12	12:53:12	11.80	0.04%	2.47	1.89%
C-2	5.00	12:53:12	12:58:12	11.81	0.05%	2.48	2.30%
C-1	5.00	12:58:12	13:03:12	11.81	0.05%	2.37	2.23%
B-3	6.00	13:03:12	13:09:12	11.81	0.05%	2.45	1.07%
B-2	5.00	13:09:12	13:14:12	11.79	**0.12%**	2.45	1.07%
B-1	5.00	13:14:12	13:19:12	11.80	0.04%	2.45	1.07%
A-3	6.00	13:19:12	13:25:12	11.81	0.05%	2.38	1.82%
A-2	5.00	13:25:12	13:30:12	11.79	**0.12%**	2.34	3.47%
A-1	5.00	13:30:12	13:35:12	11.80	0.04%	2.45	1.07%
Average				11.80		2.42	

			O_2		NOx		
			Criteria	**Results**	**Criteria**	**Results**	**AND criteria**
RATA Part 75	Non-Stratified %	≤	5%	Non (%)	5%	Non (%)	Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.
	Non-Stratified Δ	≤	0.3		3		
	Minimally-Stratified %	≤	10%		10%		
	Minimally-Stratified Δ	≤	0.5		5		
	Stratified	>	10%		10%		
	Outcome		1 point		1 point		
	Location		any point		any point		
	Maximum Concentration		11.81		2.48		
	Upscale Δ = Max Concentration - Average		0.01	Non	0.06	Non	
	Upscale % Difference		0.05%	Non	2.30%	Non	
	Minimum Concentration		11.79		2.32		
	Downscale Δ = Average - Min Concentration		0.01	Non	0.10	Non	
	Downscale % Difference		0.12%	Non	4.30%	Non	
	First Point on List Closest to Average		C-2		B-2		
Port Averages with Maximum Concentration Indicator	**Port A Average**		11.80		2.39		
	Port B Average		11.80		2.45	<max	
	Port C Average		11.81		2.44		
	Port D Average		11.81	<max	2.42		
	Port E Average						
	Port F Average						
	Port G Average						

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	04/16/20
Plant Name	Cricket Valley Energy Center	**Project #**	bec-19-cricketvalley.ny-start#3
Equipment	General Electric 7F.05	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	12:29:12	**Run End**	13:35:12

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	4.30 % for NOx
Maximum Pollutant Conc. Diff.	0.10 ppm for NOx
Maximum Diluent Conc. Diff.	0.01 % for O_2
Stratification Conclusions	
Comparison	all diluents/pollutants
Stack Diameter	D > 93.6 in.


Under Part 75 criteria all measured pollutants and diluents demonstrate a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type
- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

☐ Use 6.5.6.3(a) points?

☐ 6.5.6(b)(2) alt. points could apply



APPENDIX G

EQUIPMENT CALIBRATION RECORDS

APEX SOURCE TESTING EQUIPMENT INSTRUMENTS

Apex Instruments, Inc.
204 Technology Park Lane
Fuquay-Varina, NC 27526

S-TYPE PITOT TUBE CALIBRATION SHEET

Reference USEPA Reference Method 2 (40CFR60, App. A, Meth. 2)

PITOT SERIAL#	4187	CALIBRATION DATE:	10-Jan-13
PITOT TYPE:	S-Type	BAROMETRIC PRESSURE:	29.74 in Hg
STD. PITOT TYPE:	Ellipsoidal	STATIC PRESSURE	1.4 in H_20
Cp(std):	0.990	BLOCKAGE %:	N/A
PROBE SERIAL#	NICK	CORRECTION FACTOR:	1.00

	SIDE "A" CALIBRATION			
RUN NO.	Δ Pstd in H_2O	Δ Ps in H_2O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.560	0.820	0.818	-0.001
2	0.560	0.815	0.821	0.002
3	0.560	0.820	0.818	-0.001
		"A" AVERAGE	0.819	0.0014 (must be ≤ 0.01)

	SIDE "B" CALIBRATION			
RUN NO.	Δ Pstd in H_2O	Δ Ps in H_2O	Cp(s)	DEVIATION Cp(s) - avg.Cp(s)
1	0.560	0.815	0.821	0.000
2	0.560	0.815	0.821	0.000
3	0.560	0.815	0.821	0.000
		"B" AVERAGE	0.821	0.0000 (must be ≤ 0.01)

ACCEPTANCE CRITERIA

AVERAGE -0.0017 AVG. Cp (A) - AVG. Cp (B) must be ≤ 0.01

If the Average and both Deviation Averages "A" & "B" are ≤ 0.01, then the OVERALL AVERAGE below may be used.
*** If NOT, use the "A" Average OR "B" Average.**

OVERALL AVERAGE 0.8198



I certify that the above pitot tube was tested in accordance with the US EPA Method 2 standards.
See the Code of Federal Regulations, Title 40, Part 60, Appendix A, Method 2, Item 4.

Print Name: Nick Allen

Signature:

Date 1.11.13

Wind Tunnel Pitot Calibration

S-type Pitot ID:	**A5266**	Date:	**2-Mar-15**
Standard Pitot ID:	**001**	Personnel:	**KMR MF**
Cp(std):	**0.99**	Cp(actual):	**0.772**
Part Number:		P_{bar}(in Hg):	**29.71**
Test Velocity (fps):	**50**	T(°F):	**55**
Wind Tunnel Location:	**Calera, AL**	Tunnel Size:	**20" x 40"**
Customer:	**Air Hygiene**		

A-SIDE

ΔP_{std} (in. H_2O)	ΔP_s (in. H_2O)	Cp(s)	Deviation*
0.5594	**0.9193**	**0.772**	0.002
0.5595	**0.9195**	**0.772**	-0.001
0.5602	**0.9203**	**0.772**	0.000
	AVERAGE	**0.772**	0.001
		Std deviation	0.002

NOTES:

1. **Pitot calibrated with an Environmental Supply Co. PM10 cyclone.**
2. **C_p is only valid when used with PM10 cyclone.**
3. **C_p is only valid with 1" spacing from PM10 cyclone.**

$$Cp(s) = Cp(std)\sqrt{\frac{\Delta P(std)}{\Delta P(s)}}$$

*Deviation = {Cp(s) - *AVG* Cp(s)} {must be <0.010}

Standard deviation of the deviations must be less than 0.02 for both sides.

Pitot tube S/N A5266 was calibrated in accordance with the CFR 40, Part 60 Appendix A, Method 2, Section 10.

Signature

3/2/15
Date

METERING SYSTEM DRY GAS METER CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1706009

Date: 07/03/19
Barometric Pressure: 29.10 (in. Hg)
Theoretical Critical Vacuum: 13.73 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume Initial (ft³)	Volume Final (ft³)	Volume Total (ft³)	Initial Temperature Inlet (°F)	Initial Temperature Outlet (°F)
0.32	17.00	443.350	448.680	5.330	71.0	71.0
0.63	12.00	448.680	454.070	5.390	73.0	73.0
1.10	10.00	454.070	460.140	6.070	74.0	74.0
1.90	10.00	460.140	468.070	7.930	76.0	76.0
3.50	10.00	468.070	479.010	10.940	77.0	77.0

Final Temperature Inlet (°F)	Final Temperature Outlet (°F)	Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature Initial (°F)	Ambient Temperature Final (°F)	Ambient Temperature Average (°F)
73.0	73.0	40	0.2341	16.0	71.3	72.0	71.7
74.0	74.0	48	0.3350	16.0	72.0	72.5	72.3
76.0	76.0	55	0.4531	16.0	72.5	72.7	72.6
77.0	77.0	63	0.5888	16.0	72.7	72.8	72.8
80.0	80.0	73	0.8077	16.0	72.8	73.0	72.9

RESULTS

DRY GAS METER VOLUME CORRECTED Vm(std) (ft³)	DRY GAS METER VOLUME CORRECTED Vm(std) (liters)	ORIFICE VOLUME CORRECTED Vcr(std) (ft³)	ORIFICE VOLUME CORRECTED Vcr(std) (liters)	ORIFICE VOLUME NOMINAL Vcr (ft³)
5.147	145.76	5.023	142.2	5.202
5.194	147.11	5.071	143.6	5.258
5.840	165.40	5.713	161.8	5.928
7.624	215.91	7.423	210.2	7.704
10.521	297.95	10.182	288.3	10.570

DRY GAS METER CALIBRATION FACTOR Y Variation (number)	DRY GAS METER CALIBRATION FACTOR Y Value (number)	ORIFICE CALIBRATION FACTOR ΔH@ Value (in. H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Value (mm H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Variation (in. H2O)
0.001	0.976	1.990	50.56	0.113
0.002	0.976	1.910	48.52	0.033
0.004	0.978	1.819	46.21	-0.058
-0.001	0.974	1.856	47.15	-0.021
-0.007	0.968	1.811	46.00	-0.067
AVERAGE:	**0.974**	**1.878**	47.69	**PASSED**

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter,acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H_20 that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)^3*(deg R)^0.5/((in.Hg)*(min)).

SIGNATURE: Craig McCarty

DATE: 07/03/19 07/03/19

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0030

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1706009

Date: 07/03/19
Barometric Pressure: 29.28 (in. Hg)
Temperature (ASTM cal): 75.40 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	603.00	0.50	1206.00	0.50
Probe	101.00	0.50	603.00	0.50	1206.00	0.50
Filter	101.00	0.50	603.00	0.50	1206.00	0.50
Dryer	101.00	0.50	603.00	0.50	1206.00	0.50
Aux.	101.00	0.50	603.00	0.50	1206.00	0.50

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	75.40 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	74.0	1.40	yes
DGM Out	74.0	1.40	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 07/03/19 07/03/19

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
Appendix A, Method 5
10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration

Air Hygiene Assett ID(s): **Probe:** samp-hp-0086 **Hotbox:** samp-bh-0012 **Gooseneck:** samp-ad-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0030 Calibration 7-3-19 (.xls]Original (5 point)

Barometric Pressure: 29.10

Thermo-couples		Temps (°F)	Signature		Date	
Stack	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Probe	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Filter	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Cond.	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
CPM	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				
Exit	Ref	73.10	Craig McCarty		07/03/19	07/03/19
	Read	73.00				
	±°F	0.10				

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	120.00	120.00	120.00	minutes
Actual Meter Volume	V_m	42.41	42.04	41.64	dcf
Meter Temperature	T_m	528.54	526.54	518.38	°R
Meter Pressure at 0.75 cfm	ΔH@	1.878	1.878	1.878	in. H_2O
Barometric Pressure	P_{bar}	29.91	30.04	30.06	in. Hg
Average Meter Pressure	ΔH_{avg}	0.41	0.41	0.41	in. H_2O
Dry Molecular Weight	M_d	29.24	29.24	29.24	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.64	0.64	0.64	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9881	0.9928	0.9942	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9917
Y_i	0.9740
%Diff	1.82%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{120.00}{42.41} \times \sqrt{\frac{0.0319 \times 528.54}{1.878 \times \left(29.91 + \frac{0.41}{13.6}\right)}} \times \frac{29}{29.24} \times 0.6403 = 0.9881$$

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}}\frac{29}{M_d}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	120.00	120.00	120.00	minutes
Actual Meter Volume	V_m	41.73	41.78	41.79	dcf
Meter Temperature	T_m	522.79	542.54	542.17	°R
Meter Pressure at 0.75 cfm	ΔH@	1.878	1.878	1.878	in. H_2O
Barometric Pressure	P_{bar}	30.07	30.22	30.27	in. Hg
Average Meter Pressure	ΔH_{avg}	0.41	0.41	0.41	in. H_2O
Dry Molecular Weight	M_d	29.24	29.24	29.24	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.64	0.64	0.64	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9961	1.0110	1.0096	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	1.0055
Y_i	0.9740
%Diff	3.24%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{120.00}{41.73} \times \sqrt{\frac{0.0319 \times 522.79}{1.878 \times \left(30.07 + \frac{0.41}{13.6}\right)}} \times \frac{29}{29.24} \times 0.6403 = 0.9961$$

METERING SYSTEM DRY GAS METER CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0033

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0033 Calibration 12-10-19.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1804003

Date: 12/10/19
Barometric Pressure: 29.49 (in. Hg)
Theoretical Critical Vacuum: 13.91 (in. Hg)

DRY GAS METER READINGS

ΔH (in. H2O)	Time (min)	Volume Initial (ft³)	Volume Final (ft³)	Volume Total (ft³)	Initial Temperature Inlet (°F)	Initial Temperature Outlet (°F)
0.32	17.00	112.400	117.790	5.390	71.0	71.0
0.66	12.00	117.790	123.330	5.540	74.0	74.0
1.10	10.00	123.330	129.400	6.070	76.0	76.0
2.00	10.00	129.400	137.480	8.080	77.0	77.0
3.60	10.00	137.480	148.430	10.950	79.0	79.0

Final Temperature Inlet (°F)	Final Temperature Outlet (°F)	Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature Initial (°F)	Ambient Temperature Final (°F)	Ambient Temperature Average (°F)
73.0	73.0	140	0.2395	16.0	71.3	71.8	71.6
76.0	76.0	148	0.3446	16.0	71.8	71.6	71.7
77.0	77.0	155	0.4561	16.0	71.6	71.6	71.6
79.0	79.0	163	0.5897	16.0	71.6	71.9	71.8
82.0	82.0	173	0.8096	16.0	71.9	72.1	72.0

RESULTS

DRY GAS METER VOLUME CORRECTED Vm(std) (ft³)	DRY GAS METER VOLUME CORRECTED Vm(std) (liters)	ORIFICE VOLUME CORRECTED Vcr(std) (ft³)	ORIFICE VOLUME CORRECTED Vcr(std) (liters)	ORIFICE VOLUME NOMINAL Vcr (ft³)
5.275	149.38	5.208	147.5	5.321
5.396	152.80	5.289	149.8	5.405
5.902	167.14	5.834	165.2	5.961
7.852	222.36	7.541	213.6	7.709
10.633	301.14	10.351	293.1	10.586

DRY GAS METER CALIBRATION FACTOR Y Variation (number)	DRY GAS METER CALIBRATION FACTOR Y Value (number)	ORIFICE CALIBRATION FACTOR ΔH@ Value (in. H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Value (mm H2O)	ORIFICE CALIBRATION FACTOR ΔH@ Variation (in. H2O)
0.009	0.987	1.876	47.66	0.030
0.002	0.980	1.859	47.23	0.013
0.010	0.988	1.764	44.80	-0.083
-0.017	0.960	1.913	48.60	0.067
-0.005	0.973	1.820	46.22	-0.027
AVERAGE:	**0.978**	**1.846**	46.90	**PASSED**

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter,acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H_20 that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)^3*(deg R)^0.5/((in.Hg)*(min)).

SIGNATURE: Craig McCarty _____ DATE: 12/10/19 12/10/19

METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration
Air Hygiene Assett ID: samp-cp-0033

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0033 Calibration 12-10-19.xls]Original (5 point)

Make: apex
Model #: 522
Serial #: 1804003

Date: 12/10/19
Barometric Pressure: 29.49 (in. Hg)
Temperature (ASTM cal): 69.50 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	101.00	0.50	601.00	0.17	1201.00	0.08
Probe	101.00	0.50	601.00	0.17	1201.00	0.08
Filter	101.00	0.50	601.00	0.17	1201.00	0.08
Dryer	101.00	0.50	601.00	0.17	1201.00	0.08
Aux.	101.00	0.50	601.00	0.17	1201.00	0.08

Note: Calibrated against an ALTEK Thermocouple Source Series 22, ID: samp-tc-0003
Direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	69.50 (°F)		Responded to heating/cooling with the anticipated outcome?
	Reading	(±°F)	
DGM In	69.0	0.50	yes
DGM Out	69.0	0.50	yes

Note: Calibrated against Reference Thermometer ID: a070717

SIGNATURE: Craig McCarty DATE: 12/10/19 12/10/19

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60
Appendix A, Method 5
10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET
EPA Reference Method
Metering System Pre-Test Calibration

Air Hygiene Assett ID(s): **Probe:** samp-hp-0086 **Hotbox:** samp-bh-0012 **Gooseneck:** samp-ad-0046

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.1\Current\[SAMP-CP-0033 Calibration 12-10-19.xls]Original (5 point)

Barometric Pressure: 29.63

Thermo-couples		Temps (°F)	Signature		Date	
Stack	Ref	69.50	Craig McCarty		12/10/19	12/10/19
	Read	70.00				
	±°F	0.50				
Probe	Ref	69.50	Craig McCarty		12/10/19	12/10/19
	Read	70.00				
	±°F	0.50				
Filter	Ref	69.50	Craig McCarty		12/10/19	12/10/19
	Read	69.00				
	±°F	0.50				
Cond.	Ref	69.50	Craig McCarty		12/10/19	12/10/19
	Read	70.00				
	±°F	0.50				
CPM	Ref	69.50	Craig McCarty		12/10/19	12/10/19
	Read	70.00				
	±°F	0.50				
Exit	Ref	69.50	Craig McCarty		12/10/19	12/10/19
	Read	70.00				
	±°F	0.50				

Note: Calibrated against Reference Thermometer ID: a070717

Thermocouple	Responded to heating/cooling with the anticipated outcome?
Stack	yes
Probe	yes
Filter	yes
Cond.	yes
CPM	yes
Exit	yes

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

Check the continuity of the thermocouple by subjecting it to a change in the temperature (e.g.., removing it from the stack or touching an ice cube). This step will also check for loose connections and reversed connections (noted by a wrong change in the temperature).

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}\frac{29}{M_d}}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	245.25	243.00	240.75	minutes
Actual Meter Volume	V_m	96.84	95.73	93.9	dcf
Meter Temperature	T_m	540.08	542.33	529.50	°R
Meter Pressure at 0.75 cfm	ΔH@	1.846	1.846	1.846	in. H_2O
Barometric Pressure	P_{bar}	29.94	30.11	29.95	in. Hg
Average Meter Pressure	ΔH_{avg}	0.46	0.47	0.46	in. H_2O
Dry Molecular Weight	M_d	29.29	29.28	29.28	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.68	0.69	0.68	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9537	0.9657	0.9557	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9584
Y_i	0.9780
%Diff	2.01%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{245.25}{96.84} \times \sqrt{\frac{0.0319 \times 540.08}{1.846 \times \left(29.94 + \frac{0.46}{13.6}\right)} \times \frac{29}{29.29}} \times 0.6782 = 0.9537$$

Alternative Post-Test Metering System Calibration

RM 5, Section 16.3.1.3

$$\gamma_{qa} = \frac{\theta}{V_m}\sqrt{\frac{0.0319T_m}{\Delta H@\left(P_{bar} + \frac{\Delta H_{avg}}{13.6}\right)}\frac{29}{M_d}}\left(\sqrt{\Delta H}\right)_{avg}$$

Parameters	Variable	Run 1	Run 2	Run 3	Units
Run Time	Θ	244.50	246.00	246.75	minutes
Actual Meter Volume	V_m	93.65	91.89	93.4	dcf
Meter Temperature	T_m	540.33	529.75	534.50	°R
Meter Pressure at 0.75 cfm	ΔH@	1.846	1.846	1.846	in. H_2O
Barometric Pressure	P_{bar}	30.05	30.21	30.22	in. Hg
Average Meter Pressure	ΔH_{avg}	0.45	0.45	0.45	in. H_2O
Dry Molecular Weight	M_d	29.29	29.29	29.29	lb/lb-mol
Average √Meter Pressure	$(\Delta H)^{1/2}_{avg}$	0.67	0.67	0.67	$(\text{in. } H_2O)^{1/2}$
Run Specific Gamma	Y_{aq}	0.9708	0.9831	0.9743	

Constants:

0.0319 = (29.92/528) $(0.75)^2$(in. Hg/°R) cfm^2

29 = Dry molecular weight of air, lb/lb-mole

13.6 = conversion from inches of water to inches of mercury

$Y_{aq\ (avg)}$	0.9761
Y_i	0.9780
%Diff	0.20%
Criteria	%Diff <5%
Result	**PASS**

Example Calculation (Run 1)

$$Y_{aq} = \frac{244.50}{93.65} \times \sqrt{\frac{0.0319 \times 540.33}{1.846 \times \left(30.05 + \frac{0.45}{13.6}\right)} \times \frac{29}{29.29}} \times 0.6708 = 0.9708$$

Field Balance Weight Verfication
Annual 500g Field Balance Stock Weight vs. 500g ISO 17025 Traceable Weight
Air Hygiene Asset ID: samp-sc-0028

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\Field Balance Weights\2020\[samp-sc-0028-Extra.xlsm]Balance
Make: Ohaus
Model #: Scout Pro SP2001-US
Serial #: B228113219
Field Weight #: sc-0028
Trailer #: Extra

ISO 17025 Weight ID LABS-WT-0005
ISO S/N 1000128090
ISO Cal Due 7/29/2020

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.90	0.10

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.50	0.50

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

ISO 17025 Certfified Weight (g)	Field Balance Weight (g)	± g
500.00	499.80	0.20

must be <0.5

Sean Barnes _____ 01/09/20

(signature) *(date)*

Note: Calibrated against ISO 17025 Certified weight LABS-WT-0005

EPA Method 4 - Section 10.3, EPA Method 5 - Section 10.7, EPA Method 202 - Section 10.3: Field Balance Calibration Check. Check the calibration of the balance used to weigh impingers with a weight that is at least 500g or within 50g of a loaded impinger. The weight must be ASTM E617-13 "Standard Specification for Laboratory Weights and Precision Mass Standards" Class 6 (or better). Daily before used, the field balance must meausure within ±0.5g of the certified mass. If the daily balance calibration check fails, perform corrective measures and repeat the check before using balance.

ISO 17025 Certified 500g Weight is certified annually. Certified weight is used to verify Class 6 or better weight that accompanies each field balance on the balance it will be used. Acceptance critieria is certified weight must be within ±0.5g of Class 6 or better weight.

WEATHER STATION CALIBRATION SHEET
Temperature, Barometric Pressure, and Relative Humidity Periodic Calibration
Air Hygiene Asset ID: samp-we-0014

Filename: \\AHI-FILESVR\public\Shared\QAQC\Calibrations\Weather Stations\2020\[SAMP-WE-0014_224.xlsm]112013
Make: Kestrel
Model #: 4000
Serial #: 671144
ISO 17025 Weather Station ID SAMP-WE-0033
ISO 17025 S/N A026334
ISO 17025 Cal Due 7/23/2020

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.10	69.70	0.40	29.11	29.13	0.02	15:08
Sean Barnes		Sean Barnes			01/27/20	
(signature)					*(date)*	

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.50	70.40	0.10	29.11	29.12	0.01	15:26
Sean Barnes		Sean Barnes			01/27/20	
(signature)					*(date)*	

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.80	70.40	0.40	29.11	29.12	0.01	15:41
Sean Barnes		Sean Barnes			01/27/20	
(signature)					*(date)*	

ASTM Temp (deg F) (±1.5°)	Thermo. (deg F)	± deg F	ASTM Barometer (in. Hg) (±0.1 in Hg)	Barometric (in. Hg)	± in. Hg	Time
70.60	69.00	1.60	29.10	29.12	0.02	16:00
Sean Barnes		Sean Barnes			01/27/20	
(signature)					*(date)*	

Note: Verified against ISO 17025 Traceable Barometer and Thermometer (SAMP-WE-0033).

this page intentionally left blank
end of report

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CRICKET VALLEY ENERGY CENTER
DUTCHESS COUNTY, NEW YORK

ORIS CODE: 57185
UNIT U-00001 (U001)

PART 75 INITIAL CEMS AND FUEL FLOWMETERS CERTIFICATION TEST REPORTS

AND

PART 60 INITIAL CEMS CERTIFICATION TEST REPORTS

PREPARED FOR: GENERAL ELECTRIC

PREPARED BY: CUSTOM INSTRUMENTATION SERVICES, CORP. (CiSCO)

Date: March 12, 2020

Revision: 0

COPY NO:

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX: (303) 790-7292

TABLE OF CONTENTS

1. INTRODUCTION **3**

2. CEMS CERTIFICATION **6**

2.1 RELATIVE ACCURACY TEST AUDIT 6
2.2 BIAS CHECK 7
2.3 7-DAY CALIBRATION ERROR/DRIFT & ONLINE/OFFLINE DEMONSTRATION TESTS 7
2.4 LINEARITY CHECK 7
2.5 CYCLE TIME & RESPONSE TIME TESTS 8

3. DAHS VERIFIFICATION **8**

4. FUEL FLOWMETER CERTIFICATION TESTS DOCUMENTATION **8**

5. DISCUSSION OF RESULTS **8**

APPENDIX 1 Emissions Collection and Monitoring Plan System (ECMPS) Printout

APPENDIX 2 7-Day Error Drift Tests & Online/Offline Demonstration Test Documentation

APPENDIX 3 Linearity Check Documentation

APPENDIX 4 Cycle Time & Response Time Test Documentation

APPENDIX 5 DAHS Verification Documentation

APPENDIX 6 Relative Accuracy Test Audit Report

APPENDIX 7 Fuel Flowmeter Accuracy Test/Primary Element Visual Inspection Documentation

APPENDIX 8 Gas Cylinder Certification Sheets

1. INTRODUCTION

Cricket Valley Energy Center is a facility located in Dover Plains, New York. The facility consists of three natural gas-fired combined cycle electric generating units identified as U-00001 (U001), U-00002 (U002), and U-00003 (U003) . In addition to the air emitting equipment, the Facility will include three steam turbine generators (STGs), an air cooled condenser (ACC) and associated auxiliary equipment and systems. This certification report pertains to the U-00001 which consists of a General Electric (GE) Model 7FA.05 combustion turbine generators (CTGs) operating in combined-cycle mode with supplemental firing of the heat recovery steam generators (HRSGs) which has a nominal generating capacity of 333 MW. The maximum potential when incorporated with the steam turbine generator megawatts as per 40 CFR 75 is 383 MW. Natural gas will be the sole fuel fired in the CTGs and duct burners. Each combined cycle generating unit consisting of the CTG, HRSG and STG will be exhausted through its own stack. In addition, to oxidation catalyst being used to control CO emission, both dry-low NO_X burners (DLNB) and Selective Catalytic Reduction (SCR) are used for NO_X control on each unit. Exhaust gases from the turbines are discharged into the atmosphere through a stack approximately 282.5 feet above grade. A dedicated CEMS will monitor NO_X, CO, NH_3(NO_X) and O_2 emissions and gas fuel flow from each of the three units. This report focuses on the U-00001 CEMS.

Custom Instrumentation Services Corporation of Englewood, Colorado built the Continuous Emission Monitoring System. Data from the CEMS is recorded and stored on a Data Acquisition and Handling System (DAHS).

The CEMS on the U-00001 unit was designed to meet the monitoring and reporting requirements of New York State Department of Environmental Conservation (NYSDEC) Permit No. 3-1326-00275/00009 and the regulatory requirements of 40 CFR 60 (NO_X, NH_3, CO and O_2 analyzers) and 40 CFR 75 (NO_x and O_2 analyzers). This report presents the results of the initial certification tests performed on the NO_x, NO_X/NH_3, CO and O_2 analyzers. The testing was performed in accordance with the requirements of 40 CFR 60, Appendix B, Performance Specification 2, 3; 4a and 40 CFR 75, Appendix A.

In addition, this report provides documentation of the DAHS missing data substitution and formula verification as well as fuel flow meter transmitter accuracy tests and orifice plate primary element visual inspections performed as required by 40 CFR 75 for the initial certification.

Field certification testing on Unit U-00001 occurred between December 30, 2019 and February 6, 2020. The tests conducted under 40 CFR 75 on the NO_x and O_2 CEMS included Relative Accuracy Test Audit (RATA), Bias Check, 7-Day Calibration Error Test, Linearity Check and Cycle Time Test. The tests conducted under 40 CFR 60 on NO_X, NH_3/NO_X, CO and O_2 CEMS included RATA, 7-Day Calibration Drift Test and CO Response Time Test. A summary of the tests performed on each analyzer is provided in Table 1.

Printouts of the tests results and revised monitoring plans for the 40 CFR 75 NO_x and O_2 CEMS from EPA's Emissions Collection and Monitoring Plan System (ECMPS) Software are provided in Appendix 1.

Air Hygiene, International(AHI) of Broken Arrow, Oklahoma conducted the RATAs on the NO_x, NH_3/NO_X, CO and O_2 CEMS. On February 6, 2020 ten (10) 21-minute runs were completed on the unit. The results of the RATAs are summarized in Table 1. As shown, the Relative Accuracy calculations on the analyzers were within the EPA and NYSDEC specifications for all parameters. A detailed description of the RATAs conducted are provided in Section 2.1 and the AHI test reports in Appendix 6.

A bias check evaluation was made on the NO_x lb/mmBtu relative accuracy results as required in 40 CFR 75. The bias adjustment factor for the NO_x monitoring systems (NO_x lb/mmBtu) is provided in Table 1. The bias test results are discussed in Section 2.2. Supporting data is provided in the relative accuracy tables in the AHI RA report in Appendix 6.

The 40 CFR 60 7-day Calibration Drift and 40 CFR 75 7-Day Calibration Error tests for U-00001 CEMS occurred during seven consecutive unit operating days from December 30, 2019 through February 8, 2020. The results of these tests are summarized in Table 1. As shown, the analyzers operated well within the applicable specifications. An explanation of the calibration drift and calibration error tests is provided in Section 2.3 and supporting documentation is provided in Appendix 2 of this report.

Although not required for the initial certification, Online/Offline Calibration Error Demonstration tests were performed on the 40 CFR 75 NO_x and O_2 analyzers on January 24, 2020 to allow the use of offline calibrations to validate the Part 75 data during subsequent normal operation. Information on the Online/Offline calibration error demonstration tests is also provided in Section 2.3 and Appendix 2 of this report.

The U-00001 Linearity Checks were performed on the 40 CFR 75 NO_x and O_2 analyzers on February 4, 2020. The NO_x and O_2 Cycle Time Tests and the CO Response Time tests were performed February 4, 2020. The results of these tests are summarized in Table 1. As shown, the analyzers operated well within EPA specifications for all parameters. An explanation of the linearity check is provided in Section 2.4. Explanations of the cycle time and response time tests are provided in Section 2.5. Audit reports for the linearity checks and supporting documents for the cycle time/response time tests are provided in Appendices 3 and 4, respectively.

The DAHS missing data substitution verification and formula verification tests took place November 2, 2019. The DAHS passed all the tests required by EPA. The DAHS tests are described in Section 3 and supporting documents are provided in Appendix 5. Please note that although not required by 40 CFR 60, DAHS formula verifications are also provided for the CO analyzers.

In summary, based on the results of the initial certification tests performed on the CEMS installed on the U-00001 stacks at the Cricket Valley Energy Center, the CEMSs met the

requirements in 40 CFR 60, Appendix B Performance Specification 2, 3, 4a and 40 CFR 75, Appendix A and are therefore certified to provide accurate and reliable data under these regulations and under the NYSDEC air permit. These CEMS will continue to be calibrated, maintained, and operated following the requirements of 40 CFR 60, Appendix F and 40 CFR 75, Appendix B.

TABLE 1.
SUMMARY OF CEMS CERTIFICATION TESTS RESULTS

	RESULTS	STANDARD	PASS / FAIL
	RELATIVE ACCURACY		
NO_x ppm @ 15% O_2	9.22% RA RM	20% RA RM or 10% ARA	PASS
NO_x lb/hr	9.60% RA RM	20% RA RM or 10% ARA	PASS
NO_x lb/mmBtu	0.000 lb/mmBtu MD	7.5% RA RM or 0.015 lb/mmBtu MD[1]	PASS
CO ppm @ 15% O_2	0.7 ppm MD	10% RA RM or 5% ARA or ±5 ppm MD[2]	PASS
CO lb/hr	0.7 ppm MD	10% RA RM or 5% ARA or ±5 ppm MD[2]	PASS
NH_3 ppm @ 15% O_2	9.70% RA RM	20% RA RM or 10% ARA	PASS
NH_3 lb/hr	10.36% RA RM	20% RA RM or 10% ARA	PASS
O_2 %	0.48% O_2	20% RA RM or 1% O_2 MD	PASS
	BIAS TEST		
Adjustment Factor	1.000	NA	PASS
	24-HOUR ZERO DRIFT[3]		
NO_x low	0.2% of span	2.5 % of span	PASS
NO_x high	0.1% of span	2.5 % of span	PASS
CO low	3.90% of span	5 % of span	PASS
CO high	0.05% of span	5 % of span	PASS
$NH_3/(NO_x)$	1.56% of span	2.5 % of span	PASS
O_2 %	0.02% O_2	0.5% O_2	PASS
	24-HOUR SPAN DRIFT[3]		
NO_x low	1.0% of span	2.5 % of span	PASS
NO_x high	0.2% of span	2.5 % of span	PASS
CO low	2.60% of span	5 % of span	PASS
CO high	1.80% of span	5 % of span	PASS
$NH_3/(NO_x)$	1.06% of span	2.5 % of span	PASS
‘O_2 %	0.03% O_2	0.5% O_2	PASS
	LINEARITY[3]		
NO_x high ppm	1.7% LE	5% LE	PASS
O_2 %	0.4% LE	5% LE	PASS
	CYCLE TIME/CO RESPONSE TIME TEST(S)[iii]		
NO_x lb/mmBtu	3 Minutes	15 Minutes	PASS
CO low	140 Avg. Seconds	240 Avg. Seconds	PASS
	DAHS VERIFICATION		
DAHS Computer	Verified	Verify	PASS
ANALYZER SERIAL NUMBERS			
NO_x		1012	
O_2		128	
CO		518	
NH_3/NO_X		1047	

WHERE: [1] RATA RESULTS REQUIRED FOR ANNUAL RATA FREQUENCY FOR 40 CFR 75

[2] MD =|d| +|2.5% CC|

[3] DRIFT, LINEARITY CTT/RTT RESULTS ARE THE HIGHEST ENCOUNTERED DURING ALL TESTS

2. CEMS CERTIFICATION TESTS

Field tests were performed for the initial CEMS certification in accordance with the requirements of 40 CFR 60, Appendix B and 40 CFR Part 75, Appendix A. The results for all tests were determined from the data collected by the DAHS. The computer printouts for each field test are included in the Appendices.

2.1 RELATIVE ACCURACY TEST AUDIT

Relative accuracy testing was performed on February 6, 2020 by AHI a source testing company that meets the EPA Air Emissions Testing Body (AETB) requirements. Each test run was a minimum of 21 minutes in duration and consisted of sampling for NO_x, NH_3 (NO_X), CO and O_2. The times during which the tests were performed and additional information on stratification test, NO_x converter efficiency check and reference method calibrations are provided in the AHI report in Appendix 6.

The reference methods used by AHI are outlined below:

CONSTITUENT	METHOD
O_2	EPA METHOD 3A
NO_x	EPA METHOD 7E
$NH_3(NO_x)$	EPA METHOD 7E
CO	EPA METHOD 10

As shown in the Relative Accuracy tables in the AHI reports in Appendix 6, relative accuracy is reported as an error and is the sum of the absolute mean value of the differences between the reference method tests and the instrument readings, plus the 95 percent confidence interval of the differences, expressed as a percentage of the mean reference method value or the emission standard. As an alternative, 40 CFR 75 allows low NO_x emitters (less than 0.20 lb/mmBtu) to express relative accuracy as the difference between the average reference method value and the average CEMS value. Performance Specification 4a in 40 CFR 60, Appendix B also allows for CO relative accuracy results to be expressed as a mean difference between the reference method average value and CEMS average value.

The analyzer response was determined from the average of readings taken every minute for the duration of the time the relative accuracy tests were performed. The 1-Minute Data Reports from the CEMS are included in the AHI report.

The NO_x, $NH_3(NO_X)$, CO and O_2. analyzers passed the relative accuracy requirements (as stated in 40 CRF 60, Appendix B 2,3, 4a). In addition, the NO_x diluent systems (NO_x and O_2 analyzers combined) passed the relative accuracy requirements as stated in 40 CRF 75, Appendix A and based on the RATA results, these systems qualify for annual RATA frequency under 40 CFR 75.

2.2 BIAS CHECK

The relative accuracy result for the NO_x diluent systems reported in lb/mmBtu was checked for low bias by determining if the mean difference between the test team's values and the CEMS values was greater than the absolute value of the confidence coefficient. U-00001 NO_x diluent systems exhibited bias. Therefore, the bias adjustment factor (BAF) for the unit was 1.000. In general, the BAF is determined after each RATA test.

2.3 7 DAY CALIBRATION ERROR/DRIFT TEST & ONLINE/OFFLINE DEMONSTRATION TESTS

In general, the U-00001 7-day calibration error/drift tests required by 40 CFR 60 and 40 CFR 75 on the NO_x, NH_3 (NO_X), CO and O_2. analyzers occurred between December 30, 2019 and January 27, 2020. All tests occurred on seven consecutive unit-operating days when the unit was combusting fuel. The NO_x and O_2 calibration gases used for the zero and span calibration error tests meet the requirements of the EPA 40 CFR 75, Appendix A, Protocol Gas Verification Program (PGVP). The certificates of analysis for the cylinders used to meet the requirements of both 40 CFR 60 and 40 CFR 75 drift/calibration error requirements are included in Appendix 8 of this report.

Although not required for the initial certification, this report includes the results of the Online/Offline Calibration Error Demonstration tests that were performed on January 24, 2020. 40 CFR 75 Appendix B §2.1.1.2 allows the use of offline calibrations for the purpose of validating online data if both offline and online calibrations are performed within 26-clock hours and meets the performance specification criteria of 40 CFR 75 Append A, §3.1.

The data from calibrations occurring over seven days and the offline determination occurring within 26-clock hours are summarized in Appendix 2 of this report. As shown, the calibration error/drift for all analyzers were well within EPA requirements as stated in 40 CFR 60, Appendix B and 40 CFR 75, Appendix A. The calibration summary reports are provided in Appendix 2.

2.4 LINEARITY CHECKS

The U-00001 NO_x and O_2 linearity checks were performed on February 4, 2020. To perform the linearity check, the high ranges of the NO_x analyzers and the O_2 analyzers were challenged three times with each of three levels of calibration gas (low, mid and high). The mean difference between the analyzer response and the calibration gas value, as a percentage of the calibration gas value, must be within 5%. Results are also acceptable if the difference between the mean response and the calibration gas value is within 0.5% O_2 or 5 ppm NO_x. The results were well within the requirements of 40 CFR 75, Appendix A.

A summary of the linearity check results are provided in Appendix 3 and the certificates of analysis for the calibration gases used during the checks are provided in Appendix 8. The calibration gases used for the linearity checks met the US EPA PGVP requirements of 40 CFR 75, Appendix A.

2.5 CYCLE TIME & RESPONSE TIME TESTS

The U-00001 cycle time tests were performed on February 4, 2020. To perform the test, the NO_x and O_2 analyzers were challenged with a zero gas and a high level (80 to 100% of span) calibration gas. Both the upscale and down scale response times were determined. As stated in 40 CFR 75, Appendix A, the response time to reach 95% of the gas value must be less than 15 minutes.

40 CFR 75, Appendix A, Section 6.4 specifies that on and after January 1, 2009, the cycle time for each component analyzer of a NO_x diluent system must be recorded separately. It also specifies that for monitors with dual ranges, the test results for each range must be reported separately. Cycle time test results are acceptable for monitoring system certification if none of the cycle times exceed 15 minutes. The down scale and upscale cycle times for the NO_x low range, NO_x high range and O_2 analyzers met this specification.

The U-00001 CO response time tests were performed on February 4, 2020 to meet the requirements of 40 CFR 60. To perform this test, the low range of the CO analyzer was challenged with a zero gas and a high level (50 to 100% of range) calibration gas. Both the upscale and down scale response time averages were determined. As stated in 40 CFR 60, Appendix B, Performance Specification 4A the response time to reach 95% of the gas value must be less than 240 seconds. For the upscale and downscale readings the longer of the two response times is the response time for the analyzer. The response time for the low range of the CO analyzers met this requirement. The gas cylinders used to perform the CO response time tests are provided in Appendix 8.

Audit reports that show the analyzers response in ten second increments are located in Appendix 4. The gas cylinders used to perform the NO_X/O_2 cycle time tests meet the US EPA PGVP requirements of 40 CFR 75, Appendix A and are provided in Appendix 8.

3. DAHS VERIFICATION

A letter from the 40 CFR 75 software vendor (CiSCO CEMS) stating that each of the missing data routines and calculations performed by the DAHS was verified is included in Appendix 5. A formula verification is also included. All variables included in the calculations (bias adjustment factor, fuel inputs) were used. The formula verification spreadsheet and associated printouts are also included in Appendix 5.

4. FUEL FLOWMETER CERTIFICATION TESTS DOCUMENTATION

Documents demonstrating that the fuel flowmeters installed in each combustion turbine and duct burner meet the 2% upper range accuracy specified in 40 CFR 75 Appendix D are provided in Appendix 7. This includes Certificate of Compliance document which references ASME NFC 9M:2006 calibration which demonstrates compliance with 40 CFR 75 Appendix D Section 2.1.5.1 certification criteria.

5. DISCUSSION OF RESULTS

The CEMS and DAHS on the U-00001 combustion turbine generators at the Cricket Valley Energy Center successfully met all the requirements of the EPA as outlined in 40 CFR 60 and 40 CFR 75. An electronic QA certification file in the format specified by EPA Clean Air Markets Division for 40 CFR 75 has been prepared for each unit and will be submitted via ECMPS within 45 days of test completion.

APPENDIX 1

EMISSIONS MONITORING AND MONITORING PLAN SYSTEM PRINTOUTS

ECMPS Client Tool

Version 1.* 2019 Q3

QA/Cert Events Printout Report

March 10, 2020 05:56 PM

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL):	57185
State:	NY
County:	Dutchess County

QA Certification Events Details

Unit/Stack Identifier	Event Code	Event Date/Hour	System ID / Type	Component ID / Type	Required Tests	Conditional Data Begin Date/Hour	Last Test Completed Date/Hour	Submitted?
U001	125	12/30/2019 05	N10/NOX	110/NOX	4		02/04/2020 17	Not Yet Submitted
				120/O2	4		02/04/2020 17	Not Yet Submitted

Event Codes: 125 - Initial Certification of Gas Monitoring System

Required Test Codes: 4 - Normal Load RATA, 7-day Calibration Error Test, Linearity Check, Cycle Time Test, DAHS Verification

ECMPS Client Tool

Version 1.* 2019 Q3

QA/Cert Test Detail Report

March 12, 2020 04:29 PM

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL): 57185
State: NY
County: Dutchess County

Unit/Stack/Pipe ID: U001

7-Day Calibration

Component ID: 110
Test Number: 7DCAL-NOX_H-
Span Scale Level: High
Component Type: NOX
Reason for Test: INITIAL
Span Value: 200.000
Test Completion: 01/08/2020 06:05
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
01/01/2020 06	ZERO	0.000	0	-0.100	0.10		0.10	
01/01/2020 06	HIGH	179.200	89.6	179.600	0.20		0.20	
01/02/2020 06	ZERO	0.000	0	-0.100	0.10		0.10	
01/02/2020 06	HIGH	179.200	89.6	178.900	0.20		0.20	
01/06/2020 18	ZERO	0.000	0	-0.100	0.10		0.10	
01/06/2020 18	HIGH	179.200	89.6	179.300	0.10		0.10	
01/07/2020 06	ZERO	0.000	0	-0.100	0.10		0.10	
01/07/2020 06	HIGH	179.200	89.6	179.300	0.10		0.10	
01/08/2020 06	ZERO	0.000	0	-0.100	0.10		0.10	
01/08/2020 06	HIGH	179.200	89.6	178.800	0.20		0.20	
12/30/2019 06	ZERO	0.000	0	-0.100	0.10		0.10	
12/30/2019 06	HIGH	179.200	89.6	179.100	0.10		0.10	
12/31/2019 06	ZERO	0.000	0	-0.100	0.10		0.10	
12/31/2019 06	HIGH	179.200	89.6	179.300	0.10		0.10	

Additional Information:
No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A &3.1)

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

March 12, 2020 04:29 PM

Unit/Stack/Pipe ID: U001

7-Day Calibration

Component ID:	120	**Component Type:**	O2	**Test Completion:**	01/08/2020 06:05
Test Number:	7DCAL-O2-Q12020	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	25.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
01/01/2020 06	ZERO	0.000	0	0.020	0.00		0.00	
01/01/2020 06	HIGH	22.210	88.8	22.220	0.00		0.00	
01/02/2020 06	ZERO	0.000	0	0.010	0.00		0.00	
01/02/2020 06	HIGH	22.210	88.8	22.210	0.00		0.00	
01/06/2020 18	ZERO	0.000	0	0.020	0.00		0.00	
01/06/2020 18	HIGH	22.210	88.8	22.230	0.00		0.00	
01/07/2020 06	ZERO	0.000	0	0.010	0.00		0.00	
01/07/2020 06	HIGH	22.210	88.8	22.220	0.00		0.00	
01/08/2020 06	ZERO	0.000	0	0.010	0.00		0.00	
01/08/2020 06	HIGH	22.210	88.8	22.210	0.00		0.00	
12/30/2019 06	ZERO	0.000	0	0.010	0.00		0.00	
12/30/2019 06	HIGH	22.190	88.8	22.210	0.00		0.00	
12/31/2019 06	ZERO	0.000	0	0.020	0.00		0.00	
12/31/2019 06	HIGH	22.210	88.8	22.240	0.00		0.00	

Additional Information:
No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A &3.1)

Unit/Stack/Pipe ID: U001
Cycle Time Test

Component ID:	110	**Component Type:**	NOX	**Test Completion:**	02/04/2020 13:29
Test Number:	CTT-110L-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	Low	**Span Value:**	10.000	**EPA Calculated Result:**	PASSED
Total Cycle Time:	2	**Calculated Total Cycle Time:**	2		
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/02/04	13:22	13:23	ZERO	0.000	2.277	-0.127	1	1
2020/02/04	13:27	13:29	HIGH	8.930	2.270	8.850	2	2

Additional Information:
No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U001
Cycle Time Test

Component ID:	110	**Component Type:**	NOX	**Test Completion:**	02/04/2020 13:41
Test Number:	CTT-110H-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	200.000	**EPA Calculated Result:**	PASSED
Total Cycle Time:	2	**Calculated Total Cycle Time:**	2		
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/02/04	13:33	13:34	ZERO	0.000	2.334	-0.019	1	1
2020/02/04	13:39	13:41	HIGH	176.800	2.334	177.091	2	2

Additional Information:
No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U001

Cycle Time Test

Component ID: 120
Test Number: CTT-120-2020Q1
Span Scale Level: High
Total Cycle Time: 2
Component Type: O2
Reason for Test: INITIAL
Span Value: 25.000
Calculated Total Cycle Time: 2
Test Completion: 02/04/2020 13:54
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/02/04	13:47	13:49	ZERO	0.000	12.766	0.016	2	2
2020/02/04	13:52	13:54	HIGH	22.140	12.740	22.114	2	2

Additional Information:
No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U001

Fuel Flowmeter Accuracy Test

Component ID: 170
Test Number: FFAT-170-2020Q1
Component Type: GFFM
Test Completion: 03/14/2018 10:00
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Accuracy Test Method	High Level Accuracy	Mid Level Accuracy	Low Level Accuracy	Reinstallation Date/Hour
ASME	0.0	0.0	0.0	02/21/2020 00

Additional Information:
No comment.

Unit/Stack/Pipe ID: U001

Linearity Check

Facility Name: Cricket Valley Energy Center

QA/Cert Test Detail Report

March 12, 2020 04:29 PM

Facility ID (ORISPL): 57185

Component ID:	110	**Component Type:**	NOX	**Test Completion:**	02/04/2020 15:39
Test Number:	110-LIN-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	200.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
Grace period Tested?				**Submission Date/Time:**	

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,NO,NOX,BALN	B22019	SG9160199BAL	6/22/2027
Mid	CO,NO,NOX,BALN	G12019	CC719253	9/24/2026
Low	CO,NO,NOX,BALN	G12019	CC712750	6/27/2022

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	176.800	176.800	109.400	109.400	49.400	49.400
Mass CEM Value	180.605	180.605	110.633	110.633	48.567	48.567
Alt. Perf. Indicator						
Results	2.2	2.2	1.1	1.1	1.7	1.7

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
02/04/2020 15:35	MID	110.700	109.400	54.7%
02/04/2020 15:10	MID	110.600	109.400	54.7%
02/04/2020 15:23	MID	110.600	109.400	54.7%
02/04/2020 15:31	LOW	48.700	49.400	24.7%
02/04/2020 15:06	LOW	48.400	49.400	24.7%
02/04/2020 15:19	LOW	48.600	49.400	24.7%
02/04/2020 15:39	HIGH	182.217	176.800	88.4%
02/04/2020 15:14	HIGH	182.397	176.800	88.4%
02/04/2020 15:27	HIGH	177.200	176.800	88.4%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: U001

Linearity Check

Component ID:	120	**Component Type:**	O2	**Test Completion:**	02/04/2020 16:47
Test Number:	120-LIN-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	25.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
Grace period Tested?				**Submission Date/Time:**	

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
Low	CO2,O2,BALN	L12013	EB0049417	8/13/2021
High	O2,BALN	A12019	ALM010779	5/9/2027
Mid	O2,BALN	G12015	EB0053431	6/13/2023

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	22.150	22.150	13.460	13.460	6.030	6.030
Mass CEM Value	22.120	22.120	13.523	13.523	6.013	6.013
Alt. Perf. Indicator						
Results	0.1	0.1	0.5	0.5	0.3	0.3

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
02/04/2020 16:47	HIGH	22.130	22.150	88.6%
02/04/2020 16:32	HIGH	22.110	22.150	88.6%
02/04/2020 16:17	HIGH	22.120	22.150	88.6%
02/04/2020 16:27	MID	13.510	13.460	53.8%
02/04/2020 16:42	MID	13.530	13.460	53.8%
02/04/2020 16:12	MID	13.530	13.460	53.8%
02/04/2020 16:37	LOW	6.010	6.030	24.1%
02/04/2020 16:07	LOW	6.010	6.030	24.1%
02/04/2020 16:22	LOW	6.020	6.030	24.1%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: U001

On-Line/Off-Line Calibration

Component ID: 120
Test Number: ON_OFF-120-
Span Scale Level: High
Component Type: O2
Reason for Test: INITIAL
Span Value:
Test Completion: 01/24/2020 19
Reported Test Results: PASSED
EPA Calculated Result:
Evaluation Status: Not Evaluated
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	01/24/2020 19	ZERO	0.000		-0.010	0.00			
Online	01/24/2020 19	HIGH	22.150		22.160	0.00			
Offline	01/24/2020 00	ZERO	0.000		0.010	0.00			
Offline	01/24/2020 00	HIGH	22.150		22.180	0.00			

Additional Information:

No comment.

Unit/Stack/Pipe ID: U001

On-Line/Off-Line Calibration

Component ID: 110
Test Number: ON_OFF-110L-
Span Scale Level: Low
Component Type: NOX
Reason for Test: INITIAL
Span Value:
Test Completion: 01/24/2020 19
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	01/24/2020 19	ZERO	0.000		0.240	2.40		2.40	
Online	01/24/2020 19	HIGH	8.900		8.920	0.20		0	
Offline	01/24/2020 00	ZERO	0.000		0.010	0.10		0.10	
Offline	01/24/2020 00	HIGH	8.900		8.760	1.40		1.40	

Additional Information:

No comment.

Unit/Stack/Pipe ID: U001

On-Line/Off-Line Calibration

Component ID: 110
Test Number: ON_OFF-110H-
Span Scale Level: High
Component Type: NOX
Reason for Test: INITIAL
Span Value:
Test Completion: 01/24/2020 19
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	01/24/2020 19	ZERO	0.000		0.200	0.10		0.10	
Online	01/24/2020 19	HIGH	176.800		175.200	0.80		0	
Offline	01/24/2020 00	ZERO	0.000		0.000	0.00		0.00	
Offline	01/24/2020 00	HIGH	179.200		178.700	0.30		0.30	

Additional Information:

No comment.

Unit/Stack/Pipe ID: U001
Relative Accuracy Test

System ID:	N10	**System Parameter:**	NOX	**Test Completion:**	02/06/2020 17:06
Test Number:	N10-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSAPS
# of Op. Levels:	1	**Grace Period Test?**		**EPA Calculated Result:**	PASSAPS
Evaluation Status:	No Errors			**Reported BAF:**	1.000
Submission Status:	Not Submitted			**EPA Calculated BAF:**	1.000
Submission Date:				**RATA Frequency:**	4QTRS

Air Emissions Testing Data

QI Name:	BLUM, AARON M	**AETB Name:**	AIR HYGIENE INTERNATIONAL
Exam Date:	1/31/2019	**AETB Phone Number:**	888-461-8778
Provider Name:	SOURCE EVALUATION SOCIETY (SES)	**AETB Email:**	info@airhygiene.com
Provider Email:	QSTIPROGRAM@GMAIL.COM		

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	BALN,CO,NO,NOX	G12019	EB0040961	10/30/2022
Mid	BALN,CO,NO,NOX	G12019	EB0101718	5/30/2022
High	BALN,CO2,O2	G12019	EB0080940	6/25/2027
Mid	BALN,CO2,O2	G12019	EB0069916	11/9/2026
Low	ZERO			

Operating Level: High
Reference Method Used: 7E,3A: NOX RM 7E and CO2/O2 RM 3A

Summary Statistics:

	Reported	Recalculated		Reported	Recalculated
Mean of Monitoring System	0.00643	0.00643	**Relative Accuracy**	9.34	9.34
Mean of Reference Method Values	0.00664	0.00664	**Bias Adjustment Factor**	1.000	1.000
Mean of Difference	0.00021	0.00021	**APS Indicator**	Y	Y
Standard Deviation of Difference	0.00053	0.00053	**T-Value**	2.306	2.306
Confidence Coefficient	0.00041	0.00041	**Gross Unit Load or Velocity**	373	373

Run Data:

Run	Start Date	End Date	Run Status	Monitoring System Value	Reference Method Value	Gross Load or Velocity
1	02/06/2020 11:36	02/06/2020 11:56	RUNUSED	0.00630	0.00720	373
2	02/06/2020 12:10	02/06/2020 12:30	RUNUSED	0.00670	0.00620	373
3	02/06/2020 12:42	02/06/2020 13:02	RUNUSED	0.00630	0.00650	373
4	02/06/2020 13:20	02/06/2020 13:40	RUNUSED	0.00630	0.00650	373
5	02/06/2020 13:55	02/06/2020 14:15	RUNUSED	0.00640	0.00660	373
6	02/06/2020 14:27	02/06/2020 14:47	RUNUSED	0.00670	0.00610	373
7	02/06/2020 15:01	02/06/2020 15:21	RUNUSED	0.00630	0.00730	373
8	02/06/2020 15:36	02/06/2020 15:56	RUNUSED	0.00660	0.00680	373
9	02/06/2020 16:08	02/06/2020 16:28	RUNUSED	0.00630	0.00660	373
10	02/06/2020 16:46	02/06/2020 17:06	NOTUSED	0.00540	0.00760	373

Additional Information:

No comment.

*Performance Spec: RA <= 10% or Mean Difference <= +/- 2.0fps:
Reduced Frequency Spec: RA <= 7.5% or Mean Difference +/- 1.5 fps (Appendix A &3.3.4)

Unit/Stack/Pipe ID: U001

Transmitter Transducer Test

Component ID: 175
Test Number: FFTTT-175-2020Q1
Component Type: GFFM
Reason for Test: INITIAL
Test Completion: 02/23/2018 08:22
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

High Level Accuracy	High Level Accuracy Specification	Mid Level Accuracy	Mid Level Accuracy Specification	Low Level Accuracy	Low Level Accuracy Specification
0.0	SUM	0.0	SUM	0.0	SUM

Additional Information:

No comment.

Unit/Stack/Pipe ID: U001

DAHS Verification

System ID:		**System Type:**		**Test Completion:**	11/02/2019 18:00
Component ID:	D01	**Component Type:**	DAHS	**Reported Test Results:**	PASSED
Test Number:	DAHS_2020Q1	**Reason for Test:**	INITIAL	**Grace Period Test?**	
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted

Test Description:

Additional Information:

DAHS VERIFICATION

Unit/Stack/Pipe ID: U001

Primary Element Inspection

System ID:		**System Type:**		**Test Completion:**	10/19/2019 00:00
Component ID:	175	**Component Type:**	GFFM	**Reported Test Results:**	PASSED
Test Number:	175-PEI-2020Q1	**Reason for Test:**	INITIAL	**Grace Period Test?**	
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted

Test Description:

Additional Information:

ORIFICE PLATE INSPECTION

APPENDIX 2

7-DAY ERROR/DRIFT TESTS
&
ONLINE/OFFLINE DEMONSTRATION TESTS
DOCUMENTATION

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 60-NOx ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
12/30/2019 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.10	-0.10	5.00	On-Line
12/31/2019 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.30	0.10	5.00	On-Line
1/1/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.60	0.40	5.00	On-Line
1/2/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	178.90	-0.30	5.00	On-Line
1/3/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	178.90	-0.30	5.00	Off-Line
1/4/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.10	-0.10	5.00	Off-Line
1/4/2020 14:21	200	0.00	-0.10	-0.10	5.00	179.20	179.10	-0.10	5.00	Off-Line
1/5/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.50	0.30	5.00	Off-Line
1/6/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.70	0.50	5.00	Off-Line
1/6/2020 15:34	200	0.00	-0.10	-0.10	5.00	179.20	179.70	0.50	5.00	Off-Line
1/6/2020 15:59	200	0.00	0.00	0.00	5.00	179.20	179.50	0.30	5.00	Off-Line
1/6/2020 18:36	200	0.00	-0.10	-0.10	5.00	179.20	179.30	0.10	5.00	On-Line
1/7/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.30	0.10	5.00	On-Line
1/8/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	178.80	-0.40	5.00	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 60-NOx ppm/L

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
12/30/2019 06:05	10	0.00	-0.02	-0.02	0.25	9.04	8.94	-0.10	0.25	On-Line
12/31/2019 06:05	10	0.00	-0.02	-0.02	0.25	9.04	8.94	-0.10	0.25	On-Line
12/31/2019 08:58	10	0.00	-0.01	-0.01	0.25	9.01	9.10	0.10	0.25	On-Line
1/1/2020 06:05	10	0.00	0.00	0.00	0.25	9.01	9.04	0.04	0.25	On-Line
1/2/2020 06:05	10	0.00	0.00	0.00	0.25	9.01	9.03	0.03	0.25	On-Line
1/3/2020 06:05	10	0.00	-0.01	-0.01	0.25	9.01	9.01	0.01	0.25	Off-Line
1/4/2020 06:05	10	0.00	0.01	0.01	0.25	9.01	9.02	0.02	0.25	Off-Line
1/4/2020 14:21	10	0.00	-0.11	-0.11	0.25	9.01	8.68	**-0.33**	0.25	Off-Line
1/5/2020 06:05	10	0.00	-0.15	-0.15	0.25	9.05	8.67	**-0.38**	0.25	Off-Line
1/6/2020 06:05	10	0.00	-0.14	-0.14	0.25	9.05	8.68	**-0.37**	0.25	Off-Line
1/6/2020 15:34	10	0.00	0.00	0.00	0.25	9.00	9.01	0.01	0.25	Off-Line
1/6/2020 15:59	10	0.00	0.14	0.14	0.25	9.00	9.02	0.02	0.25	Off-Line
1/6/2020 18:36	10	0.00	0.01	0.01	0.25	9.00	9.00	0.00	0.25	On-Line
1/7/2020 06:05	10	0.00	-0.01	-0.01	0.25	9.00	8.98	-0.02	0.25	On-Line
1/8/2020 06:05	10	0.00	-0.01	-0.01	0.25	9.00	8.96	-0.04	0.25	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 75-NOx ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
12/30/2019 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.10	-0.10	5.00	On-Line
12/31/2019 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.30	0.10	5.00	On-Line
1/1/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.60	0.40	5.00	On-Line
1/2/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	178.90	-0.30	5.00	On-Line
1/3/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	178.90	-0.30	5.00	Off-Line
1/4/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.10	-0.10	5.00	Off-Line
1/4/2020 14:21	200	0.00	-0.10	-0.10	5.00	179.20	179.10	-0.10	5.00	Off-Line
1/5/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.50	0.30	5.00	Off-Line
1/6/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.70	0.50	5.00	Off-Line
1/6/2020 15:34	200	0.00	-0.10	-0.10	5.00	179.20	179.70	0.50	5.00	Off-Line
1/6/2020 15:59	200	0.00	0.00	0.00	5.00	179.20	179.50	0.30	5.00	Off-Line
1/6/2020 18:36	200	0.00	-0.10	-0.10	5.00	179.20	179.30	0.10	5.00	On-Line
1/7/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	179.30	0.10	5.00	On-Line
1/8/2020 06:05	200	0.00	-0.10	-0.10	5.00	179.20	178.80	-0.40	5.00	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 CO ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/7/2020 06:05	2050	0.00	-1.00	-1.00	102.50	1728.00	1726.00	-2.00	102.50	On-Line
1/8/2020 06:05	2050	0.00	-1.00	-1.00	102.50	1728.00	1738.00	10.00	102.50	On-Line
1/9/2020 06:05	2050	0.00	-1.00	-1.00	102.50	1728.00	1719.00	-9.00	102.50	Off-Line
1/10/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1728.00	1719.00	-9.00	102.50	Off-Line
1/11/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1728.00	1726.00	-2.00	102.50	Off-Line
1/12/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1728.00	1736.00	8.00	102.50	Off-Line
1/13/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1728.00	1725.00	-3.00	102.50	Off-Line
1/14/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1728.00	1724.00	-4.00	102.50	Off-Line
1/15/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1728.00	171.00	**-1557.00**	102.50	Off-Line
1/15/2020 20:46	2050	0.00	-1.00	-1.00	102.50	1731.00	1731.00	0.00	102.50	Off-Line
1/15/2020 22:39	2050	0.00	-1.00	-1.00	102.50	1731.00	1730.00	-1.00	102.50	Off-Line
1/16/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1731.00	1732.00	1.00	102.50	Off-Line
1/17/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1731.00	1737.00	6.00	102.50	Off-Line
1/18/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1731.00	1725.00	-6.00	102.50	Off-Line
1/19/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1731.00	1741.00	10.00	102.50	Off-Line
1/20/2020 00:01	2050	0.00	0.00	0.00	102.50	1731.00	1744.00	13.00	102.50	Off-Line
1/21/2020 00:01	2050	0.00	0.00	0.00	102.50	1731.00	1736.00	5.00	102.50	Off-Line
1/22/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1731.00	1736.00	5.00	102.50	Off-Line
1/22/2020 16:29	2050	0.00	-1.00	-1.00	102.50	1731.00	1737.00	6.00	102.50	On-Line
1/23/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1731.00	1735.00	4.00	102.50	Off-Line
1/24/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1731.00	1733.00	2.00	102.50	Off-Line
1/24/2020 14:35	2050	0.00	-1.00	-1.00	102.50	1709.00	1732.00	23.00	102.50	Off-Line
1/24/2020 19:51	2050	0.00	-1.00	-1.00	102.50	1709.00	1732.00	23.00	102.50	On-Line
1/25/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1709.00	1732.00	23.00	102.50	Off-Line
1/25/2020 01:49	2050	0.00	-1.00	-1.00	102.50	1709.00	1735.00	26.00	102.50	On-Line
1/25/2020 10:09	2050	0.00	-1.00	-1.00	102.50	1709.00	1736.00	27.00	102.50	On-Line
1/26/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1709.00	1746.00	37.00	102.50	On-Line
1/27/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1709.00	1746.00	37.00	102.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 CO ppm/L

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/7/2020 06:05	10	0.00	-0.39	-0.39	0.50	7.06	7.14	0.08	0.50	On-Line
1/8/2020 06:05	10	0.00	-0.26	-0.26	0.50	7.06	7.32	0.26	0.50	On-Line
1/9/2020 06:05	10	0.00	-0.28	-0.28	0.50	7.06	7.27	0.21	0.50	Off-Line
1/10/2020 00:01	10	0.00	-0.24	-0.24	0.50	7.06	7.36	0.30	0.50	Off-Line
1/10/2020 06:34	10	0.00	-0.10	-0.10	0.50	7.06	7.22	0.16	0.50	Off-Line
1/11/2020 00:01	10	0.00	0.00	0.00	0.50	7.06	7.17	0.11	0.50	Off-Line
1/12/2020 00:01	10	0.00	-0.05	-0.05	0.50	7.06	7.14	0.08	0.50	Off-Line
1/13/2020 00:01	10	0.00	0.13	0.13	0.50	7.06	7.24	0.18	0.50	Off-Line
1/14/2020 00:01	10	0.00	0.09	0.09	0.50	7.06	7.17	0.11	0.50	Off-Line
1/15/2020 00:01	10	0.00	-0.01	-0.01	0.50	7.06	3.81	**-3.25**	0.50	Off-Line
1/15/2020 20:46	10	0.00	-0.03	-0.03	0.50	7.04	6.34	**-0.70**	0.50	Off-Line
1/15/2020 22:39	10	0.00	-0.04	-0.04	0.50	7.04	6.32	**-0.72**	0.50	Off-Line
1/16/2020 00:01	10	0.00	0.01	0.01	0.50	7.04	6.30	**-0.74**	0.50	Off-Line
1/17/2020 00:01	10	0.00	-0.03	-0.03	0.50	7.04	6.32	**-0.72**	0.50	Off-Line
1/18/2020 00:01	10	0.00	-0.06	-0.06	0.50	7.04	6.26	**-0.78**	0.50	Off-Line
1/19/2020 00:01	10	0.00	0.00	0.00	0.50	7.04	6.36	**-0.68**	0.50	Off-Line
1/20/2020 00:01	10	0.00	-0.10	-0.10	0.50	7.04	6.27	**-0.77**	0.50	Off-Line
1/21/2020 00:01	10	0.00	-0.11	-0.11	0.50	7.04	6.27	**-0.77**	0.50	Off-Line
1/21/2020 08:58	10	0.00	0.01	0.01	0.50	7.04	7.05	0.01	0.50	Off-Line
1/22/2020 00:01	10	0.00	0.08	0.08	0.50	7.04	7.14	0.10	0.50	Off-Line
1/22/2020 16:29	10	0.00	0.22	0.22	0.50	7.04	7.20	0.16	0.50	On-Line
1/23/2020 00:01	10	0.00	0.11	0.11	0.50	7.07	7.14	0.07	0.50	Off-Line
1/24/2020 00:01	10	0.00	0.04	0.04	0.50	7.07	7.11	0.04	0.50	Off-Line
1/24/2020 19:51	10	0.00	0.18	0.18	0.50	7.07	7.13	0.06	0.50	On-Line
1/25/2020 00:01	10	0.00	0.06	0.06	0.50	7.07	7.08	0.01	0.50	Off-Line
1/25/2020 01:49	10	0.00	0.09	0.09	0.50	7.07	7.09	0.02	0.50	On-Line
1/25/2020 10:09	10	0.00	0.09	0.09	0.50	7.07	7.16	0.09	0.50	On-Line
1/26/2020 00:01	10	0.00	0.07	0.07	0.50	7.07	7.17	0.10	0.50	On-Line
1/27/2020 00:01	10	0.00	0.14	0.14	0.50	7.07	7.24	0.17	0.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 NH3/NOx ppm

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
12/30/2019 06:05	16	0.00	-0.23	-0.23	0.48	9.04	8.87	-0.17	0.48	On-Line
12/31/2019 06:05	16	0.00	-0.20	-0.20	0.48	9.04	8.92	-0.12	0.48	On-Line
12/31/2019 08:58	16	0.00	-0.07	-0.07	0.48	9.01	9.15	0.15	0.48	On-Line
1/1/2020 06:05	16	0.00	-0.05	-0.05	0.48	9.01	8.98	-0.03	0.48	On-Line
1/2/2020 06:05	16	0.00	-0.02	-0.02	0.48	9.01	8.99	-0.02	0.48	On-Line
1/3/2020 06:05	16	0.00	-0.08	-0.08	0.48	9.01	9.01	0.01	0.48	Off-Line
1/4/2020 06:05	16	0.00	-0.08	-0.08	0.48	9.01	8.97	-0.04	0.48	Off-Line
1/4/2020 14:21	16	0.00	-0.15	-0.15	0.48	9.01	8.49	**-0.52**	0.48	Off-Line
1/5/2020 06:05	16	0.00	-0.18	-0.18	0.48	9.01	8.47	**-0.54**	0.48	Off-Line
1/6/2020 06:05	16	0.00	-0.17	-0.17	0.48	9.01	8.47	**-0.54**	0.48	Off-Line
1/6/2020 15:59	16	0.00	0.23	0.23	0.48	9.00	9.05	0.05	0.48	Off-Line
1/6/2020 18:36	16	0.00	0.25	0.25	0.48	9.00	9.05	0.05	0.48	On-Line
1/7/2020 06:05	16	0.00	0.04	0.04	0.48	9.00	9.00	0.00	0.48	On-Line
1/8/2020 06:05	16	0.00	0.05	0.05	0.48	9.00	9.00	0.00	0.48	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 60-O2 %

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
12/30/2019 06:05	25	0.00	0.01	0.01	0.50	22.19	22.21	0.02	0.50	On-Line
12/31/2019 06:05	25	0.00	0.02	0.02	0.50	22.21	22.24	0.03	0.50	On-Line
1/1/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.22	0.01	0.50	On-Line
1/2/2020 06:05	25	0.00	0.01	0.01	0.50	22.21	22.21	0.00	0.50	On-Line
1/3/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.21	0.00	0.50	Off-Line
1/4/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.21	0.00	0.50	Off-Line
1/4/2020 14:21	25	0.00	0.02	0.02	0.50	22.21	22.22	0.01	0.50	Off-Line
1/5/2020 06:05	25	0.00	0.03	0.03	0.50	22.21	22.23	0.02	0.50	Off-Line
1/6/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.23	0.02	0.50	Off-Line
1/6/2020 15:59	25	0.00	0.01	0.01	0.50	22.21	22.22	0.01	0.50	Off-Line
1/6/2020 18:36	25	0.00	0.02	0.02	0.50	22.21	22.23	0.02	0.50	On-Line
1/7/2020 06:05	25	0.00	0.01	0.01	0.50	22.21	22.22	0.01	0.50	On-Line
1/8/2020 06:05	25	0.00	0.01	0.01	0.50	22.21	22.21	0.00	0.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 1 75-O2 %

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
12/30/2019 06:05	25	0.00	0.01	0.01	0.50	22.19	22.21	0.02	0.50	On-Line
12/31/2019 06:05	25	0.00	0.02	0.02	0.50	22.21	22.24	0.03	0.50	On-Line
1/1/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.22	0.01	0.50	On-Line
1/2/2020 06:05	25	0.00	0.01	0.01	0.50	22.21	22.21	0.00	0.50	On-Line
1/3/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.21	0.00	0.50	Off-Line
1/4/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.21	0.00	0.50	Off-Line
1/4/2020 14:21	25	0.00	0.02	0.02	0.50	22.21	22.22	0.01	0.50	Off-Line
1/5/2020 06:05	25	0.00	0.03	0.03	0.50	22.21	22.23	0.02	0.50	Off-Line
1/6/2020 06:05	25	0.00	0.02	0.02	0.50	22.21	22.23	0.02	0.50	Off-Line
1/6/2020 15:59	25	0.00	0.01	0.01	0.50	22.21	22.22	0.01	0.50	Off-Line
1/6/2020 18:36	25	0.00	0.02	0.02	0.50	22.21	22.23	0.02	0.50	On-Line
1/7/2020 06:05	25	0.00	0.01	0.01	0.50	22.21	22.22	0.01	0.50	On-Line
1/8/2020 06:05	25	0.00	0.01	0.01	0.50	22.21	22.21	0.00	0.50	On-Line

The 7-Day Drift Test has been passed.

Turbine 1 Calibration Checks

Cricket Valley Energy Center
Cal Checks for 1/24/2020

Date/Time	Parameter	Analyzer Scale	Test Level	Reference Value	Measured Value	Actual Drift	Allowable Drift	Instrument Span	Results
			Cylinder ID	*Expiration Date*		*EPA Vendor ID*	*EPA Gas Type Codes*		
1/24/2020 12:01 AM	75-NOx ppm	High	Zero	0.0 ppm	0.0 ppm	0 ppm	±10 ppm	200 ppm	Unit offline; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
1/24/2020 12:01 AM	75-NOx ppm	High	Span	179.2 ppm	178.7 ppm	-0.5 ppm	±10 ppm	200 ppm	Unit offline; Passed
			ALM-032192	*6/24/2027*		*B22019*	*CO,NO,NOX,BALN*		
1/24/2020 12:01 AM	75-NOx ppm	Low	Zero	0.00 ppm	0.01 ppm	0.01 ppm	±0.5 ppm	10 ppm	Unit offline; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
1/24/2020 12:01 AM	75-NOx ppm	Low	Span	8.90 ppm	8.76 ppm	-0.14 ppm	±0.5 ppm	10 ppm	Unit offline; Passed
			CC342258	*6/24/2022*		*B22019*	*NO,NOX,BALN*		
1/24/2020 12:01 AM	75-O2 %	Single	Zero	0.00%	0.01%	0.01%	±1%	25%	Unit offline; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
1/24/2020 12:01 AM	75-O2 %	Single	Span	22.15%	22.18%	0.03%	±1%	25%	Unit offline; Passed
			ALM010779	*3/4/2027*		*B72018*	*CO2,O2,BALN*		
1/24/2020 2:35 PM	75-NOx ppm	High	Zero	0.0 ppm	0.0 ppm	0 ppm	±10 ppm	200 ppm	Unit offline; Passed; Manual
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
1/24/2020 2:35 PM	75-NOx ppm	High	Span	176.8 ppm	176.2 ppm	-0.6 ppm	±10 ppm	200 ppm	Unit offline; Passed; Manual
			ALM034669	*7/22/2027*		*B22019*	*CO,NO,NOX,BALN*		
1/24/2020 7:51 PM	75-NOx ppm	High	Zero	0.0 ppm	0.2 ppm	0.2 ppm	±10 ppm	200 ppm	Unit online; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
1/24/2020 7:51 PM	75-NOx ppm	High	Span	176.8 ppm	175.2 ppm	-1.6 ppm	±10 ppm	200 ppm	Unit online; Passed
			ALM034669	*7/22/2027*		*B22019*	*CO,NO,NOX,BALN*		
1/24/2020 7:51 PM	75-NOx ppm	Low	Zero	0.00 ppm	0.24 ppm	0.24 ppm	±0.5 ppm	10 ppm	Unit online; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
1/24/2020 7:51 PM	75-NOx ppm	Low	Span	8.90 ppm	8.92 ppm	0.02 ppm	±0.5 ppm	10 ppm	Unit online; Passed
			CC342258	*6/24/2022*		*B22019*	*NO,NOX,BALN*		
1/24/2020 7:51 PM	75-O2 %	Single	Zero	0.00%	-0.01%	-0.01%	±1%	25%	Unit online; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		

Date/Time	Parameter	Analyzer Scale	Test Level	Reference Value	Measured Value	Actual Drift	Allowable Drift	Instrument Span	Results
			Cylinder ID		*Expiration Date*	*EPA Vendor ID*	*EPA Gas Type Codes*		
1/24/2020 7:51 PM	75-O2 %	Single	Span	22.15%	22.16%	0.01%	±1%	25%	Unit online; Passed
			ALM010779		*3/4/2027*	*B72018*	*CO2,O2,BALN*		

APPENDIX 3

LINEARITY CHECK DOCUMENTATION

Turbine 1 O2 Linearity

Cricket Valley Energy Center

Test Information

Test Date: **2/4/2020**
Test Reason: Initial Certification
Grace Period: No
Aborted: No
Unit online during QA test

Analyzer and Monitor Information

Range: Single Scale
Instrument Span: 25 %O2
Component ID: 120
Manufacturer: TELEDYNE
Model: T802
Serial Number: 128

Run Number	Time	Reference Gas	CEMS Response		Cylinder Information
Low Gas					
1	4:07 PM	6.03	6.01		
2	4:22 PM	6.03	6.02		Allowable Reference Values:
3	4:37 PM	6.03	6.01		5-7.5 %O2 (20-30% of span)
	Mean (%O2)	6.03	6.01		Cylinder ID: EB0049417
	Difference of means (|R-A|) (%O2)	0.0	*Limit 0.5*	*Passed*	Expiration Date: 8/13/2021
					EPA Vendor ID: L12013
	Linearity Error (%)	0.3	*Limit 5.0*	*Passed*	Cylinder contains: CO2,O2,BALN
Mid Gas					
1	4:12 PM	13.46	13.51		
2	4:27 PM	13.46	13.51		Allowable Reference Values:
3	4:42 PM	13.46	13.53		12.5-15 %O2 (50-60% of span)
	Mean (%O2)	13.46	13.52		Cylinder ID: EB0053431
	Difference of means (|R-A|) (%O2)	0.1	*Limit 0.5*	*Passed*	Expiration Date: 6/13/2023
					EPA Vendor ID: G12015
	Linearity Error (%)	0.4	*Limit 5.0*	*Passed*	Cylinder contains: O2,BALN
High Gas					
1	4:17 PM	22.15	22.12		
2	4:32 PM	22.15	22.11		Allowable Reference Values:
3	4:47 PM	22.15	22.13		20-25 %O2 (80-100% of span)
	Mean (%O2)	22.15	22.12		Cylinder ID: ALM010779
	Difference of means (|R-A|) (%O2)	0.0	*Limit 0.5*	*Passed*	Expiration Date: 5/9/2027
					EPA Vendor ID: A12019
	Linearity Error (%)	0.1	*Limit 5.0*	*Passed*	Cylinder contains: O2,BALN

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

Turbine 1 NOx/H Linearity

Cricket Valley Energy Center

Test Information

Test Date: **2/4/2020**
Test Reason: Initial Certification
Grace Period: No
Aborted: No
Unit online during QA test

Analyzer and Monitor Information

Range: High
Instrument Span: 200 ppm
Component ID: 110
Manufacturer: TELEDYNE
Model: T200M
Serial Number: 1012

Run Number	Time	Reference Gas	CEMS Response		Cylinder Information
Low Gas					
1	3:06 PM	49.4	48.4		
2	3:19 PM	49.4	48.6		Allowable Reference Values: 40-60 ppm (20-30% of span)
3	3:31 PM	49.4	48.7		
	Mean (ppm)	49.4	48.6		Cylinder ID: CC712750
	Difference of means (|R-A|) (ppm)	0.8	*Limit 5*	*Passed*	Expiration Date: 6/27/2022
	Linearity Error (%)	1.7	*Limit 5.0*	*Passed*	EPA Vendor ID: G12019
					Cylinder contains: CO,NO,BALN
Mid Gas					
1	3:10 PM	109.4	110.6		
2	3:23 PM	109.4	110.6		Allowable Reference Values: 100-120 ppm (50-60% of span)
3	3:35 PM	109.4	110.7		
	Mean (ppm)	109.4	110.6		Cylinder ID: CC719253
	Difference of means (|R-A|) (ppm)	1.2	*Limit 5*	*Passed*	Expiration Date: 9/24/2026
	Linearity Error (%)	1.1	*Limit 5.0*	*Passed*	EPA Vendor ID: G12019
					Cylinder contains: CO,NO,BALN
High Gas					
1	3:14 PM	176.8	176.9		Allowable Reference Values: 160-200 ppm (80-100% of span)
2	3:27 PM	176.8	177.2		
3	3:39 PM	176.8	177.0		Cylinder ID: ALM034669
	Mean (ppm)	176.8	177.0		Expiration Date: 6/22/2027
	Difference of means (|R-A|) (ppm)	0.2	*Limit 5*	*Passed*	EPA Vendor ID: B22019
	Linearity Error (%)	0.1	*Limit 5.0*	*Passed*	Cylinder contains: CO,NO,NOX,BALN

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

APPENDIX 4

CYCLE TIME & RESPONSE TIME TESTS DOCUMENTATION

I/O Audit Data

Cricket Valley Energy Center

Data for 2/4/2020 1:18:50 PM thru 2/4/2020 1:57:40 PM

Timestamp	(Turbine 1) NOx Value	(Turbine 1) NH3/NOx Value	(Turbine 1) O2 Value	(Turbine 1) GT Megawatts Value
1:18:53 PM	2.278	3.807	12.739	--
1:19:03 PM	2.275	3.807	12.748	--
1:19:13 PM	2.275	3.802	12.739	--
1:19:23 PM	2.276	3.799	12.739	--
1:19:33 PM	2.278	3.795	12.739	231.082
1:19:43 PM	2.278	3.790	12.739	--
1:19:53 PM	2.278	3.789	12.743	--
1:20:03 PM	2.281	3.785	12.739	--
1:20:13 PM	2.284	--	12.739	--
1:20:23 PM	2.284	3.782	12.739	--
1:20:33 PM	2.283	3.781	12.739	--
1:20:43 PM	2.284	3.780	12.738	--
1:20:53 PM	2.286	3.775	12.739	--
1:21:03 PM	2.284	3.776	12.739	--
1:21:13 PM	2.283	--	12.739	--
1:21:23 PM	2.280	--	12.740	--
1:21:33 PM	2.280	3.771	12.737	--
1:21:43 PM	2.281	3.772	12.740	--
1:21:53 PM	2.281	3.771	12.739	--
1:22:03 PM	2.277	3.767	12.732	--
1:22:13 PM	2.277	3.768	12.732	--
1:22:23 PM	2.086	3.767	11.682	--
1:22:33 PM	2.434	3.771	2.323	--
1:22:43 PM	1.238	3.771	0.591	--
1:22:53 PM	-0.029	2.936	0.221	--
1:23:03 PM	-0.097	3.019	0.132	--
1:23:14 PM	-0.111	1.131	0.084	--
1:23:24 PM	--	--	--	231.433
1:23:34 PM	--	-0.090	--	231.222
1:23:48 PM	-0.127	-0.110	0.038	231.296
1:23:58 PM	-0.128	-0.113	0.030	--
1:24:08 PM	-0.127	-0.113	0.031	231.266
1:24:18 PM	-0.127	--	0.024	--
1:24:29 PM	-0.128	-0.119	0.023	231.049
1:24:39 PM	-0.128	-0.118	0.025	231.402
1:24:49 PM	-0.128	-0.117	0.022	231.283
1:24:59 PM	-0.128	-0.117	0.018	231.343
1:25:09 PM	-0.127	--	0.023	231.093
1:25:19 PM	0.460	-0.118	1.323	230.901
1:25:29 PM	1.867	-0.118	10.284	231.274
1:25:39 PM	2.217	-0.121	12.129	--
1:25:49 PM	2.252	0.519	12.542	--
1:25:59 PM	2.259	3.079	12.650	231.045
1:26:09 PM	2.263	3.517	12.684	230.844
1:26:19 PM	2.266	3.613	12.696	231.113

Timestamp	(Turbine 1) NOx Value	(Turbine 1) NH3/NOx Value	(Turbine 1) O2 Value	(Turbine 1) GT Megawatts Value
1:26:29 PM	2.269	3.670	12.704	231.289
1:26:39 PM	2.269	3.670	12.703	230.881
1:26:49 PM	2.269	3.732	12.712	230.591
1:26:59 PM	2.270	3.772	12.711	--
1:27:09 PM	2.269	3.773	12.719	--
1:27:19 PM	2.269	3.777	12.717	231.161
1:27:29 PM	2.269	3.777	12.717	231.275
1:27:39 PM	2.270	3.778	12.717	230.992
1:27:49 PM	2.269	3.776	12.717	231.217
1:27:59 PM	1.392	3.777	6.839	231.458
1:28:09 PM	5.756	3.781	1.274	--
1:28:19 PM	8.686	3.627	0.390	231.078
1:28:29 PM	8.763	2.327	0.165	231.261
1:28:39 PM	8.813	7.441	0.099	231.051
1:28:49 PM	8.837	7.440	0.070	231.196
1:28:59 PM	8.845	8.761	0.059	231.431
1:29:09 PM	8.850	8.885	0.044	231.375
1:29:19 PM	8.845	8.899	0.039	231.012
1:29:29 PM	8.848	8.888	0.030	230.954
1:29:39 PM	8.848	8.898	0.031	230.929
1:29:49 PM	8.847	8.906	0.024	231.084
1:29:59 PM	8.850	8.902	0.030	231.223
1:30:09 PM	8.850	8.902	0.025	231.445
1:30:19 PM	8.851	8.903	0.030	--
1:30:29 PM	8.853	8.901	0.019	230.557
1:30:39 PM	8.853	8.902	0.018	231.192
1:30:49 PM	8.853	8.901	0.018	231.182
1:30:59 PM	7.838	8.903	1.168	231.295
1:31:09 PM	4.932	8.903	10.223	230.840
1:31:19 PM	3.106	8.902	12.122	231.112
1:31:29 PM	2.318	7.821	12.541	--
1:31:39 PM	2.299	4.755	12.650	231.200
1:31:49 PM	2.302	3.729	12.675	231.250
1:31:59 PM	2.286	3.653	12.698	230.861
1:32:09 PM	2.274	3.690	12.696	230.882
1:32:19 PM	2.266	3.751	12.706	230.925
1:32:29 PM	2.266	3.780	12.710	230.890
1:32:39 PM	2.267	3.786	12.712	231.369
1:32:49 PM	2.327	3.781	12.717	231.046
1:32:59 PM	2.315	3.781	12.717	231.703
1:33:09 PM	2.321	3.785	12.725	231.108
1:33:19 PM	2.327	3.785	12.725	230.869
1:33:29 PM	2.334	3.785	12.725	--
1:33:39 PM	2.327	3.786	12.724	231.420
1:33:49 PM	2.959	3.789	12.718	231.432
1:33:59 PM	6.444	3.794	4.214	231.039
1:34:09 PM	3.591	3.798	0.913	230.545
1:34:19 PM	0.144	4.496	0.289	--
1:34:29 PM	0.044	7.000	0.139	--

Timestamp	(Turbine 1) NOx Value	(Turbine 1) NH3/NOx Value	(Turbine 1) O2 Value	(Turbine 1) GT Megawatts Value
1:34:39 PM	0.006	2.084	0.078	--
1:34:49 PM	-0.019	0.149	0.060	230.817
1:34:59 PM	-0.006	-0.058	0.045	231.556
1:35:09 PM	-0.025	-0.089	0.037	231.256
1:35:19 PM	0.013	-0.091	0.032	231.453
1:35:29 PM	-0.006	-0.104	0.030	231.049
1:35:39 PM	-0.006	-0.114	0.026	--
1:35:49 PM	-0.120	-0.114	0.023	231.262
1:35:59 PM	-0.122	-0.114	0.018	231.608
1:36:09 PM	-0.121	-0.113	0.016	230.637
1:36:19 PM	-0.121	-0.112	0.018	230.930
1:36:29 PM	-0.123	-0.115	0.016	230.830
1:36:39 PM	-0.124	-0.114	0.019	--
1:36:49 PM	-0.123	-0.114	0.018	230.868
1:36:59 PM	1.283	-0.117	7.033	231.090
1:37:09 PM	2.164	-0.118	11.465	231.031
1:37:19 PM	2.255	-0.108	12.402	231.021
1:37:29 PM	2.266	0.653	12.617	231.313
1:37:39 PM	2.261	1.877	12.675	--
1:37:49 PM	2.264	3.617	12.691	231.182
1:37:59 PM	2.279	3.675	12.703	231.186
1:38:09 PM	2.280	3.730	12.711	231.038
1:38:19 PM	2.280	3.760	12.711	230.900
1:38:29 PM	2.315	3.785	12.717	230.913
1:38:39 PM	2.340	3.790	12.725	230.902
1:38:49 PM	2.321	3.790	12.725	230.963
1:38:59 PM	2.340	3.791	12.726	--
1:39:09 PM	2.309	3.793	12.725	--
1:39:19 PM	2.334	3.795	12.727	230.920
1:39:29 PM	1.789	3.794	10.990	--
1:39:39 PM	66.041	3.795	2.146	230.859
1:39:49 PM	161.863	3.795	0.544	230.831
1:39:59 PM	161.875	2.683	0.221	--
1:40:09 PM	175.020	16.400	0.125	--
1:40:19 PM	176.052	16.400	0.079	231.203
1:40:29 PM	176.484	16.400	0.059	230.969
1:40:39 PM	176.790	16.400	0.052	230.973
1:40:49 PM	176.853	16.400	0.046	231.154
1:40:59 PM	176.959	16.400	0.038	231.000
1:41:09 PM	176.972	16.400	0.039	231.394
1:41:19 PM	176.972	16.400	0.032	231.104
1:41:29 PM	176.947	16.400	0.039	230.942
1:41:39 PM	177.022	16.400	0.027	231.039
1:41:49 PM	177.003	16.400	0.025	231.103
1:41:59 PM	177.091	16.400	0.026	230.943
1:42:09 PM	177.078	8.146	0.024	--
1:42:19 PM	177.066	5.865	0.026	230.855
1:42:29 PM	116.624	4.813	2.984	231.273
1:42:39 PM	21.346	2.886	10.674	--

Timestamp	(Turbine 1) NOx Value	(Turbine 1) NH3/NOx Value	(Turbine 1) O2 Value	(Turbine 1) GT Megawatts Value
1:42:49 PM	4.813	1.941	12.255	231.319
1:42:59 PM	3.469	14.835	12.585	231.024
1:43:09 PM	3.027	10.053	12.675	--
1:43:19 PM	2.847	4.595	12.704	230.917
1:43:29 PM	2.743	4.048	12.717	231.203
1:43:39 PM	2.670	3.960	12.725	231.132
1:43:49 PM	2.614	3.998	12.731	230.767
1:43:59 PM	2.587	3.995	12.732	230.403
1:44:09 PM	2.584	3.990	12.739	231.225
1:44:19 PM	2.584	3.978	12.731	231.061
1:44:29 PM	2.578	3.972	12.732	230.698
1:44:39 PM	2.568	3.972	12.739	231.233
1:44:49 PM	2.558	3.972	12.746	230.900
1:44:59 PM	2.546	3.973	12.746	230.915
1:45:09 PM	2.533	3.973	12.747	--
1:45:19 PM	2.521	3.972	12.746	230.951
1:45:29 PM	2.508	3.972	12.746	230.975
1:45:39 PM	2.492	3.972	12.746	230.889
1:45:49 PM	2.477	3.967	12.759	--
1:45:59 PM	2.462	3.970	12.753	231.322
1:46:09 PM	2.447	3.969	12.751	230.591
1:46:19 PM	2.435	3.968	12.760	--
1:46:29 PM	2.427	3.963	12.751	230.758
1:46:39 PM	2.418	3.964	12.761	231.152
1:46:49 PM	2.402	3.965	12.766	230.748
1:46:59 PM	2.394	3.960	12.761	231.213
1:47:09 PM	2.387	3.959	12.766	--
1:47:19 PM	2.381	3.955	12.768	230.855
1:47:29 PM	10.250	3.955	12.697	--
1:47:39 PM	10.250	3.956	3.495	231.415
1:47:49 PM	10.250	3.951	0.766	--
1:47:59 PM	2.241	14.517	0.268	230.572
1:48:09 PM	0.789	16.400	0.139	--
1:48:19 PM	0.302	15.593	0.084	230.368
1:48:29 PM	0.160	15.592	0.065	230.535
1:48:39 PM	0.116	2.262	0.044	230.872
1:48:49 PM	0.052	0.189	0.038	230.687
1:48:59 PM	0.003	0.093	0.038	231.071
1:49:09 PM	-0.024	0.037	0.030	--
1:49:19 PM	-0.028	0.015	0.023	230.715
1:49:29 PM	-0.027	-0.001	0.027	231.032
1:49:39 PM	-0.030	-0.019	0.019	230.439
1:49:49 PM	-0.032	-0.019	0.016	--
1:49:59 PM	-0.038	-0.024	0.017	230.757
1:50:09 PM	-0.038	-0.025	0.023	230.382
1:50:19 PM	1.410	-0.027	7.501	--
1:50:29 PM	2.219	-0.028	11.587	230.950
1:50:39 PM	2.308	-0.027	12.444	--
1:50:49 PM	2.315	1.860	12.651	230.626

Timestamp	(Turbine 1) NOx Value	(Turbine 1) NH3/NOx Value	(Turbine 1) O2 Value	(Turbine 1) GT Megawatts Value
1:50:59 PM	2.315	3.569	12.699	231.137
1:51:09 PM	2.318	3.750	12.717	--
1:51:19 PM	2.305	3.799	12.732	230.552
1:51:29 PM	2.305	3.846	12.732	--
1:51:39 PM	2.305	3.868	12.744	230.866
1:51:49 PM	2.305	3.871	12.740	230.493
1:51:59 PM	2.301	3.885	12.746	230.740
1:52:09 PM	2.301	3.882	12.746	230.373
1:52:19 PM	2.305	3.882	12.746	--
1:52:29 PM	2.305	3.880	12.740	230.509
1:52:39 PM	2.301	3.876	12.753	230.509
1:52:49 PM	2.301	3.876	12.752	230.509
1:52:59 PM	1.735	3.877	6.683	230.693
1:53:09 PM	1.256	3.872	11.825	230.832
1:53:19 PM	0.242	3.869	19.946	230.678
1:53:29 PM	-0.095	1.937	21.531	--
1:53:39 PM	-0.028	1.729	21.924	230.585
1:53:49 PM	-0.022	0.071	22.031	--
1:53:59 PM	-0.024	-0.061	22.074	--
1:54:09 PM	-0.026	-0.006	22.092	230.678
1:54:19 PM	-0.027	-0.006	22.100	230.749
1:54:29 PM	-0.027	-0.007	22.106	230.640
1:54:39 PM	-0.027	-0.015	22.107	231.049
1:54:49 PM	-0.028	-0.015	22.114	230.725
1:54:59 PM	-0.029	-0.014	22.113	230.288
1:55:09 PM	-0.029	-0.016	22.120	230.653
1:55:19 PM	-0.029	-0.015	22.113	230.432
1:55:29 PM	-0.030	-0.020	22.119	231.122
1:55:39 PM	0.105	-0.019	22.079	--
1:55:49 PM	1.758	-0.018	15.532	230.483
1:55:59 PM	2.241	-0.018	13.388	230.606
1:56:09 PM	2.293	-0.015	12.966	230.521
1:56:19 PM	2.306	2.342	12.850	--
1:56:29 PM	2.320	3.578	12.822	230.924
1:56:39 PM	2.310	3.652	12.802	--
1:56:49 PM	2.315	3.708	12.794	230.552
1:56:59 PM	2.315	3.781	12.789	230.674
1:57:09 PM	2.313	3.793	12.800	--
1:57:19 PM	2.312	3.815	12.789	--
1:57:29 PM	2.313	3.821	12.793	--
1:57:39 PM	2.313	3.821	12.788	230.965
Average	15.181	4.158	8.603	230.974
Minimum	-0.128	-0.121	0.016	230.288
Maximum	177.091	16.400	22.120	231.703

I/O Audit Data

Cricket Valley Energy Center

Data for 2/4/2020 2:16:30 PM thru 2/4/2020 2:36:00 PM

Timestamp	(Turbine 1) CO Value	
2:16:33 PM	0.232	
2:16:43 PM	0.235	
2:16:53 PM	0.235	
2:17:03 PM	0.230	
2:17:13 PM	0.221	
2:17:23 PM	0.217	
2:17:33 PM	0.209	
2:17:43 PM	0.201	
2:17:53 PM	0.187	
2:18:03 PM	0.185	
2:18:13 PM	0.187	
2:18:23 PM	0.179	
2:18:33 PM	0.190	
2:18:44 PM	0.003	
2:18:58 PM	-0.010	
2:19:09 PM	-0.001	
2:19:19 PM	0.009	
2:19:29 PM	0.022	
2:19:39 PM	0.033	
2:19:49 PM	0.066	
2:19:59 PM	0.069	
2:20:09 PM	0.087	
2:20:19 PM	0.099	
2:20:29 PM	0.066	
2:20:39 PM	0.058	
2:20:49 PM	0.057	
2:20:59 PM	0.037	Up-1
2:21:09 PM	0.375	
2:21:19 PM	1.302	
2:21:29 PM	2.676	
2:21:39 PM	4.297	
2:21:49 PM	5.610	
2:21:59 PM	6.397	
2:22:09 PM	6.774	
2:22:19 PM	6.929	
2:22:29 PM	6.979	
2:22:39 PM	7.014	
2:22:49 PM	7.021	
2:22:59 PM	7.022	
2:23:09 PM	7.029	
2:23:19 PM	7.043	
2:23:29 PM	7.046	
2:23:39 PM	6.824	
2:23:49 PM	5.849	
2:23:59 PM	4.341	Down-1
2:24:09 PM	2.644	

Timestamp	(Turbine 1) CO Value	
2:24:19 PM	1.151	
2:24:29 PM	0.313	
2:24:39 PM	0.030	
2:24:49 PM	-0.026	
2:24:59 PM	0.001	
2:25:09 PM	0.044	
2:25:19 PM	0.074	
2:25:29 PM	0.103	
2:25:39 PM	0.106	
2:25:49 PM	0.111	
2:25:59 PM	0.111	
2:26:09 PM	0.367	
2:26:19 PM	1.213	Up-2
2:26:29 PM	2.474	
2:26:39 PM	4.046	
2:26:49 PM	5.430	
2:26:59 PM	6.308	
2:27:09 PM	6.740	
2:27:19 PM	6.900	
2:27:29 PM	6.973	
2:27:39 PM	6.986	
2:27:49 PM	6.989	
2:27:59 PM	7.014	
2:28:09 PM	7.021	
2:28:19 PM	7.033	
2:28:29 PM	7.041	
2:28:39 PM	7.046	
2:28:49 PM	6.895	
2:28:59 PM	6.080	
2:29:09 PM	4.603	Down-2
2:29:19 PM	2.941	
2:29:29 PM	1.337	
2:29:39 PM	0.370	
2:29:49 PM	0.017	
2:29:59 PM	-0.036	
2:30:09 PM	-0.042	
2:30:19 PM	-0.017	
2:30:29 PM	-0.007	
2:30:39 PM	0.012	
2:30:49 PM	0.028	
2:30:59 PM	0.031	
2:31:09 PM	0.033	
2:31:19 PM	0.125	
2:31:29 PM	0.766	
2:31:39 PM	1.928	Up-3
2:31:49 PM	3.449	
2:31:59 PM	4.994	
2:32:09 PM	6.078	
2:32:19 PM	6.656	
2:32:29 PM	6.899	

Timestamp	(Turbine 1) CO Value	
2:32:39 PM	7.000	
2:32:49 PM	7.032	
2:32:59 PM	7.046	
2:33:09 PM	7.032	
2:33:19 PM	7.022	
2:33:29 PM	7.019	
2:33:39 PM	7.019	
2:33:49 PM	7.034	
2:33:59 PM	7.051	
2:34:09 PM	6.931	
2:34:19 PM	6.234	Down-3
2:34:29 PM	4.877	
2:34:39 PM	3.227	
2:34:49 PM	1.599	
2:34:59 PM	0.523	
2:35:09 PM	0.128	
2:35:19 PM	0.035	
2:35:29 PM	0.033	
2:35:39 PM	0.052	
2:35:49 PM	0.049	
2:35:59 PM	0.055	
Average	2.891	
Minimum	-0.042	
Maximum	7.051	

APPENDIX 5

DAHS VERIFICATION DOCUMENTATION

CUSTOM INSTRUMENTATION SERVICES CORPORATION

Data Acquisition and Handling System (DAHS) Verification Documentation

CeDAR and Breez75X ECMPS Reporting Software

Developed by:
Custom Instrumentation Services Corporation

EPA Regulations

- 40CFR75 Acid Rain
- 40CFR97 CSAPR NOx and SO_2

This letter serves as notice that the required 40 CFR 75 DAHS (missing data and formula) verification have been conducted and passed.

The attached formula verification document which includes CeDAR printouts demonstrates that the DAHS accurately calculates regulated parameters using raw data. In addition, verification tests have been conducted and passed for all missing data substitution routines for ECMPS reporting according to all applicable regulations and specifications in 40 CFR 75 Appendix D and Subpart D. The attached checklist, as adapted from Section 15 of the Acid Rain Program Policy Manual (revised) for 40CFR75, provides the regulatory description of the data substitution criteria.
These verification tests were conducted using numerous data sets at varying loads and operating conditions as well as various missing data periods as described in each set of tests. The tests were conducted using data sets with known outcomes and criteria and were verified against those outcomes. All missing data substitution procedures have been verified to be accurate and correct. Detailed data sets and documentation and test documentation are provided below

Walt Bastron
President

SO_2 Missing Data Verification Checklist [1]

Initial SO_2 Data Substitution: 75.31

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard SO_2 Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous SO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

1 The SO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

O_2 Missing Data Verification Checklist

Initial O_2 Data Substitution: 75.31

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(b) 75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.36(b) 75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard O2 Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 10th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 10th percentile of the lookback period.	75.36(d) 75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 5th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 5th percentile of the lookback period.	75.36(d) 75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the minimum value in the lookback period.	75.36(d) 75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.36(d) 75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.36(d) 75.33(a)

Miscellaneous SO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)

For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(c)(4)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous NOx Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

Appendix D Fuel Flow Rate Missing Data Verification Checklist

Single Fuel Hours, Load Based: Appendix D

Description	Regulation
Non-QA data is substituted with the average of the lookback period at the corresponding load range when only the same fuel was combusted.	App. D 2.4.2.2.1
Non-QA data is substituted with the average of the lookback period at the next higher available load range when only the same fuel was combusted if no data in the corresponding load range exists.	App. D 2.4.2.2.1
Non-QA data is substituted with the a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when only the same fuel was combusted exists.	App. D 2.4.2.2.1
Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3

Co-Fired Fuel Hours, Load Based: Appendix D

Description	Regulation
Non-QA data is substituted with the maximum in the lookback period at the corresponding load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Non-QA data is substituted with the maximum in the lookback period at the next higher available load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Non-QA data is substituted with a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when the same fuel is co-fired with another fuel exists.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3

Note: If Maximum Heat Rate is exceeded, manual adjustment of Fuel Flows is allowed so that reported Heat Rate equals the maximum. (App. D 2.4.2.3.4)

Fuel Specific NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Fuel Specific NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)

For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(3) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a fuel specific MPC.	75.33(c)(4) 75.33(c)(8)(iii)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(5) 75.33(c)(8)(i) 75.33(c)(8)(ii)
If no data in the corresponding or higher load ranges exists in the lookback period, the fuel specific MPC is used.	75.33(c)(6) 75.33(c)(8)(iii)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.33(c)(8)

Miscellaneous Fuel Specific NO_X Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

Season Specific NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(1) 75.74(c)(7)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(2) 75.74(c)(7)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges. Historical data is separated into season specific pools.	75.31(c)(3) 75.74(c)(7)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Season Specific NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(i) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(A) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(B) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(i) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(A) 75.34(a)(2) 75.74(c)(7)

For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(B) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(3) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with an MPC.	75.33(c)(4) 75.74(c)(7)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into season specific pools.	75.33(c)(5) 75.34(a)(2) 75.74(c)(7)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6) 75.34(a)(2) 75.74(c)(7)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.34(a)(2) 75.74(c)(7)

Miscellaneous Season Specific NO_X Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

CO_2 Missing Data Verification Checklist 2

Initial CO_2 Data Substitution: 75.35(b) [75.31]

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard CO_2 Data Substitution: 75.35(d) [75.33]

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous CO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

2 The CO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

Missing Data Verification Checklist [3]

Initial Stack Flow Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard Stack Flow Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)

For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(c)(4)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous Stack Flow Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

3 The stack flow missing data verification mentioned here does not apply to Cricket Valley Energy Center

TECHNICAL DOCUMENT - DATA SUBSTITUTION - 1 [4]

SO2 Missing Data Verification Checklist [5]

Initial SO2 Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)	DS1 1/1/99
	Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)	DS2 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Standard SO2 Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)	DS1 3/3/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)	DS1 6/14/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)	DS1 6/30/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.33(b)(4)	DS1 7/31/99
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)	DS3 3/31/02

Miscellaneous SO2 Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

O2 Missing Data Verification Checklist

Initial O2 Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(b) 75.31(b)(1)	DS1 1/1/99
	Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.36(b) 75.31(b)(2)	DS2 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Standard O2 Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 10th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(ii)(A)	DS1 3/3/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 10th percentile of the lookback period.	75.36(d) 75.33(b)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 5th percentile of the	75.36(d) 75.33(b)(2)(ii)(A)	DS1 6/14/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.		
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 5th percentile of the lookback period.	75.36(d) 75.33(b)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the minimum value in the lookback period.	75.36(d) 75.33(b)(3)	DS1 6/30/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.36(d) 75.33(b)(4)	DS1 7/31/99
	Substitution routines have a maximum lookback period of 26280 hours.	75.36(d) 75.33(a)	DS3 3/31/02

Miscellaneous SO2 Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

NOx Missing Data Verification Checklist

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)	DS1 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

4 The dates and data sets for in-house testing of formulas, monitor code logic and general software testing is historical, but is consistent with the operations required by the most recent regulatory requirements.

5 The stack SO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Standard NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)	DS2 1/3/00
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.33(c)(4)	DS1 8/3/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)	DS2 1/3/00
	If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)	DS2 1/3/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Miscellaneous NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

Appendix D Fuel Flow Rate Missing Data Verification Checklist

Single Fuel Hours, Load Based: Appendix D

P/F	Description	Regulation	Test
	Non-QA data is substituted with the average of the lookback period at the corresponding load range when only the same fuel was combusted.	App. D 2.4.2.2.1	DS1 1/24/99
	Non-QA data is substituted with the average of the lookback period at the next higher available load range when only the same fuel was combusted if no data in the corresponding load range exists.	App. D 2.4.2.2.1	DS2 1/2/00
	Non-QA data is substituted with the a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when only the same fuel was combusted exists.	App. D 2.4.2.2.1	DS2 1/1/99
	Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3	DS3 6/30/03

Co-Fired Fuel Hours, Load Based: Appendix D

P/F	Description	Regulation	Test
	Non-QA data is substituted with the maximum in the lookback period at the corresponding load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS1 1/1/99
	Non-QA data is substituted with the maximum in the lookback period at the next higher available load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS2 1/3/00
	Non-QA data is substituted with a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when the same fuel is co-fired with another fuel exists.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS1 1/1/99
	Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3	DS3 6/30/03

Note: If Maximum Heat Rate is exceeded, manual adjustment of Fuel Flows is allowed so that reported Heat Rate equals the maximum. (App. D 2.4.2.3.4)

Fuel Specific NOx Missing Data Verification Checklist

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)	DS1 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Fuel Specific NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 5/31/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/16/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(3) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a fuel specific MPC.	75.33(c)(4) 75.33(c)(8)(iii)	DS1 7/31/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(5) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 7/31/99
	If no data in the corresponding or higher load ranges exists in the lookback period, the fuel specific MPC is used.	75.33(c)(6) 75.33(c)(8)(iii)	DS1 1/30/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.33(c)(8)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Miscellaneous Fuel Specific NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

Season Specific NOx Missing Data Verification Checklist

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(1) 75.74(c)(7)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(2) 75.74(c)(7)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges. Historical data is separated into season specific pools.	75.31(c)(3) 75.74(c)(7)	DS1 1/31/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Season Specific NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(i) 75.34(a)(2) 75.74(c)(7)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(A) 75.34(a)(2) 75.74(c)(7)	DS1 5/31/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(B) 75.34(a)(2) 75.74(c)(7)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(i) 75.34(a)(2) 75.74(c)(7)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(A) 75.34(a)(2) 75.74(c)(7)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(B) 75.34(a)(2) 75.74(c)(7)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(3) 75.34(a)(2) 75.74(c)(7)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with an MPC.	75.33(c)(4) 75.74(c)(7)	DS1 7/31/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into season specific pools.	75.33(c)(5) 75.34(a)(2) 75.74(c)(7)	DS1 7/31/99
	If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6) 75.34(a)(2) 75.74(c)(7)	DS1 1/30/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.34(a)(2) 75.74(c)(7)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Miscellaneous Season Specific NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Cricket Valley All Settings

Cricket Valley Energy Center

Group	Setting	Value	Last changed
Facility- Fuel Constants			
	Nat Gas GCV Btu/scf	1050	1/25/2019 5:19 PM
	Fd Factor Gas dscf/mmBtu	8710	1/25/2019 5:19 PM
	Fc Factor Gas dscf/mmBtu	1040	1/25/2019 5:19 PM
	Gas Density lb/scf	0.042	1/25/2019 5:19 PM
Turbine 1 40CFR75 Settings			
	75-NOx ppm Scale Max	200	1/25/2019 5:24 PM
	75-NOx ppm Scale Exceedance Default	400	1/25/2019 5:24 PM
	75-NOx Bias Factor	1	1/25/2019 5:24 PM
Turbine 1 Emission Factor Settings[6]			
	PM10/PM2.5 lb/mmBtu	0.0005	12/24/2019 4:56 PM
	VOC lb/mmBtu	0.0002	12/24/2019 4:56 PM
	H2SO4 lb/mmBtu	0.0001	12/24/2019 4:56 PM

6 Emission factors found here are only sample settings used to confirm that software is calculating correctly.

Formula Verification Examples

Unit Name:	**CRICKET VALLEY ENERGY CENTER**	**Oris Code:**	**57185**
Date/ Time:	**11/02/2019 HOUR 1800**	**Unit /Stack #**	**U001**

Formula **19-1**
Parameter **NOx lb/mmBtu for gas**

Fd dscf/mmbtu	K units lb/dscf-ppm Nox	NOx ppmv	O2 dry %	**NOx lb/mmBtu**	BAF	**Bias adj. NOx lb/mmBtu**
8710	1.194E-07	16.33	12.89	**0.0443**	1.000	**0.0443**

Formula **F-20**
Parameter **Heat Input - gas**

CT Total NG hscf/hr	CT Op Time hr	DB Total NG hscf/hr	DB Op Time hr	**Total NG hscf**
22885.7	1	278.0	1.00	**23163.7**

NG GCV Btu/hscf	mmBtu/Btu	CT Heat input mmBtu	DB Heat input mmBtu	**Total Heat input mmBtu**
105000	1.00E-06	2403	29.2	**2432.2**

Formula **F-24A**
Parameter **NOx lb/hr** **gas**

NOx lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NOx lb/hr**	BAF	**Bias adj. NOx lb/hr**
0.044	2403.0	29.2	**107.8**	1.000	**107.8**

Formula **G-4**
Parameter **CO2 ton/hr** **gas**

Fc scf/mmbtu	CT HI gas mmBtu/hr	DB HI gas mmBtu/hr	M Wt CO2 g/g-mole	Conversion 1/385 scf CO2/lbmole	Convers lb/ton	**CO2 Ton/hr**
1040	2403.0	29.2	44	2.60E-03	2000	**144.5**

Formula **D-5**
Parameter **SO2 lb/hr** **gas**

CT HI gas mmBtu/hr	DB HI gas mmBtu/hr	SO2 EF lb/mmBtu	**SO2 lb/hr**
2403.0	29.2	0.0006	**1.46**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 1- Daily 40CFR75 Emissions & Operations Report

November 2, 2019

Hour	O2 %	NOx ppm	NOx lb/mmBtu	Bias Factor	Bias Adj NOx lb/mmBtu	NOx lbs	SO2 lbs	CO2 tons	Gas Flow hscf/hr	Nat Gas GCV Btu/hscf	Heat Input mmBtu/hr	Turbine On-Time	Total Megawatts	Bin Load Range
00	12.98	13.81	0.0379	1.000	0.0379	91.8	1.45	143.9	23057.1	105000	2421.0	1.00	237.2	10
01	12.98	13.55	0.0372	1.000	0.0372	90.1	1.45	143.9	23057.1	105000	2421.0	1.00	237.2	10
02	12.99	13.20	0.0363	1.000	0.0363	87.9	1.45	143.9	23057.1	105000	2421.0	1.00	237.4	10
03	12.99	12.98	0.0357	1.000	0.0357	86.4	1.45	143.9	23057.1	105000	2421.0	1.00	237.5	10
04	12.98	12.80	0.0351	1.000	0.0351	85.0	1.45	143.9	23057.1	105000	2421.0	1.00	237.5	10
05	12.99	12.63	0.0347	1.000	0.0347	52.9	0.91	90.7	23057.1	105000	2421.0	0.63	237.6	10
06	**DCal**	**DCal**	**DCal**	1.000	**DCal**	**DCal**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
07	15.61	16.58	0.0681	1.000	0.0681	26.6	0.24	23.2	9771.4	105000	1026.0	0.38	58.2	3
08	13.33	12.09	0.0347	1.000	0.0347	64.6	1.12	110.7	17745.7	105000	1863.3	1.00	165.6	9
09	13.28	12.99	0.0371	1.000	0.0371	24.3	0.39	39.0	17828.6	105000	1872.0	0.35	168.6	9
10	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
11	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
12	14.30	13.39	0.0441	1.000	0.0441	41.6	0.56	56.0	14485.7	105000	1521.0	0.62	123.4	7
13	12.98	15.77	0.0433	1.000	0.0433	104.0	1.44	142.8	22885.7	105000	2403.0	1.00	234.4	10
14	13.01	15.03	0.0414	1.000	0.0414	97.7	1.41	140.3	22725.2	105000	2386.2	1.00	229.6	10
15	14.27	21.95	0.0720	1.000	0.0720	127.8	1.06	105.5	17156.7	105000	1801.5	1.00	156.5	8
16	16.27	42.40	0.1990	1.000	0.1990	155.8	0.47	46.5	7457.1	105000	783.0	1.00	32.7	2
17	12.94	20.77	0.0567	1.000	0.0567	135.5	1.44	142.1	22813.6	105000	2395.4	1.00	230.1	10
18	12.89	16.33	0.0443	1.000	0.0443	107.8	1.46	144.5	23163.7	105000	2432.2	1.00	234.8	10
19	13.22	13.37	0.0378	1.000	0.0378	24.8	0.39	39.0	18022.6	105000	1892.4	0.35	167.4	9
20	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
21	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
22	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
23	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**

CeDAR 1-Hour Data

Cricket Valley Energy Center

Data for 11/2/2019 12 AM thru 11/2/2019 11 PM

Timestamp	(Turbine 1) CT Nat Gas Flow hscf/hr 1-Hr	(Turbine 1) DB Nat Gas Flow hscf/hr 1-Hr	(Turbine 1) 75-Total Gas Flow hscf/hr 1-Hr
11/2/19 12 AM	23057.1	0.2 <13>	23057.1
11/2/19 1 AM	23057.1	0.2 <13>	23057.1
11/2/19 2 AM	23057.1	0.2 <13>	23057.1
11/2/19 3 AM	23057.1	0.4 <13>	23057.1
11/2/19 4 AM	23057.1	0.2 <13>	23057.1
11/2/19 5 AM	23057.1	0.2 <13>	23057.1
11/2/19 6 AM	0.0 <13>	0.2 <13>	0.2 <13>
11/2/19 7 AM	9771.4	0.2 <13>	9771.4
11/2/19 8 AM	17742.9	2.8	17745.7
11/2/19 9 AM	17828.6	0.2 <13>	17828.6
11/2/19 10 AM	0.0 <13>	0.1 <13>	0.1 <13>
11/2/19 11 AM	0.0 <13>	0.1 <13>	0.1 <13>
11/2/19 12 PM	14485.7	0.1 <13>	14485.7
11/2/19 1 PM	22885.7	0.1 <13>	22885.7
11/2/19 2 PM	22457.1	268.1	22725.2
11/2/19 3 PM	16885.7	271.0	17156.7
11/2/19 4 PM	7457.1	0.3 <13>	7457.1
11/2/19 5 PM	22542.9	270.7	22813.6
11/2/19 6 PM	22885.7	278.0	23163.7
11/2/19 7 PM	17742.9	279.7	18022.6
11/2/19 8 PM	0.0 <13>	0.4 <13>	0.4 <13>
11/2/19 9 PM	0.0 <13>	0.4 <13>	0.4 <13>
11/2/19 10 PM	0.0 <13>	0.4 <13>	0.4 <13>
11/2/19 11 PM	0.0 <13>	0.5 <13>	0.5 <13>
Average (all)	13792.9	57.3	13850.0
Total (all)	--	--	332400.7
Minimum (all)	0.0	0.1	0.1
Maximum (all)	23057.1	279.7	23163.7
Average (valid values only)	19472.3	228.4	19552.9
Total (valid values only)	--	--	332398.6
Count (valid values only)	17	6	17

<13> = Down

Formula Verification Examples

Unit Name: **CRICKET VALLEY ENERGY CENTER** **Oris Code:** **57185**
Date/ Time: **11/02/2019 HOUR 1800** **Unit /Stack #** **U001**

Formula **19-1**
Parameter **NOx lb/mmBtu for gas**

Fd dscf/mmbtu	K units lb/dscf-ppm Nox	NOx ppmv	O2 dry %	**NOx lb/mmBtu**
8710	1.194E-07	16.33	12.89	**0.0443**

Formula **F-20**
Parameter **Heat Input - gas**

CT Total NG hscf/hr	CT Op Time hr	DB Total NG hscf/hr	DB Op Time hr	Total PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**Total Heat input mmBtu**
22885.7	1	278.0	1.00	23163.7	105000	1.00E-06	**2432.2**

CT Total PNG hscf/hr	CT Op Time hr	Total CT PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**CT Heat input mmBtu**
22885.7	1	22886	105000	1.00E-06	**2403.0**

DB Total PNG hscf/hr	DB Op Time hr	Total DB PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**DB Heat input mmBtu**
278.0	1	278	105000	1.00E-06	**29.2**

Parameter **NOx ppm@15% O2**

NOx ppm	O2 dry %	**NOx ppm corr**
16.33	12.89	**12.03**

Parameter **NOx lb/hr** **gas**

NOx lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NOx lb/hr**
0.0443	2403.0	29.2	**107.74**

Parameter **CO ppm@15% O2**

Formula **19-1**
Parameter **CO lb/mmBtu for gas**

Fc scf CO2/mmbtu	K (lb-mol /dscf-ppmvd)	CO MW lb/lb-mol	CO ppmv	O2 dry %	**CO lb/mmBtu**
8710	2.59E-09	28	0.82	12.89	**0.0014**

CO ppm	O2 dry %	**CO ppm corr**
0.82	12.89	**0.60**

Parameter **CO lb/hr** **gas**

CO lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**CO lb/hr**
0.0014	2403.0	29.2	**3.40**

Formula **19-1**
Parameter **NH3 lb/mmBtu for gas**

Fc scf CO2/mmbtu	K ppmvd)	NH3 MW lb/lb-mol	NH3 ppmv	O2 dry %	**NH3 lb/mmBtu**
8710	2.59E-09	17.03	0.05	12.89	**0.0001**

NH3 ppm	O2 dry %	**NH3 ppm corr**
0.05	12.89	**0.04**

Parameter **CO lb/hr** **gas**

NH3 lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NH3 lb/hr**
0.0001	2403.0	29.2	**0.24**

Parameter **PM10/PM2.5 lb/hr** **gas**

CT HI gas mmBtu/hr	CT PM10/PM2.5 EF lb/mmBtu	**CT PM10/PM2.5 lb/hr**	DB HI gas mmBtu/hr	DB PM10/PM2.5 EF lb/mmBtu	**DB PM10/PM2.5 lb/hr**	**Total PM10/PM2.5 lb/hr**
2403.0	0.0005	**1.20**	29.2	0.0005	**0.01**	**1.21**

Parameter **VOC lb/hr** **gas**

CT HI gas mmBtu/hr	VOC EF lb/mmBtu	**CT VOC lb/hr**	DB HI gas mmBtu/hr	VOC EF lb/mmBtu	**DB VOC lb/hr**	**Total VOC lb/hr**
2403.0	0.0002	**0.48**	29.2	0.0002	**0.01**	**0.49**

Parameter **H2SO4 lb/hr** **gas**

CT HI gas mmBtu/hr	H2SO4 EF lb/mmBtu	**CT H2SO4 lb/hr**	DB HI gas mmBtu/hr	H2SO4 EF lb/mmBtu	**DB H2SO4 lb/hr**	**Total H2SO4 lb/hr**
2403.0	0.0001	**0.24**	29.2	0.0001	**0.00**	**0.24**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 1- Daily Emissions Report

November 2, 2019

Hourly Emission Limits

Normal Ops NOx ppm @15% O2 - 2 | Normal Ops CO ppm @15% O2 - 2 | NH3 Slip ppm @15% O2 - 5

30-Day Rolling Emission Limits

NOx ppm @15% O2 - <Null>

Hour	O2 %	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lbs	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lbs	NH3 Slip ppm	NH3 Slip ppm @15% O2	NH3 Slip lb/mmBtu	NH3 Slip lbs	Process Status
00	12.98	13.81	10.29	0.0379	91.76	0.73	0.54	0.0012	2.91	0.20	0.15	0.0002	0.48	Hot SU
01	12.98	13.55	10.09	0.0372	90.06	0.70	0.52	0.0012	2.91	0.24	0.18	0.0002	0.48	Hot SU
02	12.99	13.20	9.85	0.0363	87.88	0.69	0.51	0.0012	2.91	0.12	0.09	0.0001	0.24	Hot SU
03	12.99	12.98	9.68	0.0357	86.43	0.67	0.50	0.0011	2.66	0.11	0.08	0.0001	0.24	Hot SU
04	12.98	12.80	9.54	0.0351	84.98	0.69	0.51	0.0012	2.91	0.16	0.12	0.0002	0.48	Hot SU
05	12.99	12.63	9.42	0.0347	52.93	0.68	0.51	0.0011	1.68	0.16	0.12	0.0002	0.30	Hot SU
06	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	Down
07	15.61	16.58	18.49	0.0681	26.55	275.48	307.25	0.6875	268.04	0.99	1.10	0.0015	0.59	Hot SU
08	13.33	12.09	9.42	0.0347	64.65	6.14	4.79	0.0107	19.93	0.59	0.46	0.0006	1.12	Hot SU
09	13.28	12.99	10.06	0.0371	24.31	52.45	40.61	0.0909	59.56	0.51	0.39	0.0005	0.33	Hot SU
10	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
11	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
12	14.30	13.39	11.97	0.0441	41.59	143.31	128.11	0.2867	270.36	0.24	0.21	0.0003	0.29	Hot SU
13	12.98	15.77	11.75	0.0433	104.05	0.53	0.39	0.0009	2.16	0.03	0.02	0.0000	0.00	Hot SU
14	13.01	15.03	11.24	0.0414	97.76	0.56	0.42	0.0009	2.12	0.03	0.02	0.0000	0.00	Hot SU
15	14.27	21.95	19.53	0.0720	127.76	73.62	65.51	0.1466	260.13	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
16	16.27	42.40	54.03	0.1990	155.82	485.83	619.09	1.3852	1084.61	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
17	12.94	20.77	15.39	0.0567	135.53	1.45	1.07	0.0024	5.74	0.00	0.00	0.0000	0.00	Hot SU
18	12.89	16.33	12.03	0.0443	107.74	0.82	0.60	0.0014	3.40	0.05	0.04	0.0001	0.24	Hot SU
19	13.22	13.37	10.27	0.0378	24.84	44.08	33.86	0.0758	49.81	0.61	0.47	0.0006	0.39	Hot SU
20	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
21	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
22	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
23	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
Average	13.53	16.45	14.30	0.0527	82.63	64.03	70.87	0.1586	120.11	0.27	0.23	0.0003	0.35	
Total					1404.64				2041.84				5.18	
30-Day			**NSD**											

Cricket Valley Energy Center

Dover Plains, NY

Turbine 1- Daily Mass Emissions Report

November 2, 2019

Hour	NOx lbs	CO lbs	PM10/PM2.5 lbs	NH3 Slip lbs	VOC lbs	H2SO4 lbs	Turbine On-Time
00	91.76	2.91	1.21	0.48	0.48	0.24	1.00
01	90.06	2.91	1.21	0.48	0.48	0.24	1.00
02	87.88	2.91	1.21	0.24	0.48	0.24	1.00
03	86.43	2.66	1.21	0.24	0.48	0.24	1.00
04	84.98	2.91	1.21	0.48	0.48	0.24	1.00
05	52.93	1.68	0.76	0.30	0.30	0.15	0.63
06	**DCal**	**DCal**	**Down**	**DCal**	**Down**	**Down**	0.00
07	26.55	268.04	0.19	0.59	0.08	0.04	0.38
08	64.65	19.93	0.93	1.12	0.37	0.19	1.00
09	24.31	59.56	0.33	0.33	0.13	0.07	0.35
10	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
11	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
12	41.59	270.36	0.47	0.29	0.19	0.09	0.62
13	104.05	2.16	1.20	0.00	0.48	0.24	1.00
14	97.76	2.12	1.18	0.00	0.47	0.24	1.00
15	127.76	260.13	0.89	**OOR**	0.35	0.18	1.00
16	155.82	1084.61	0.39	**OOR**	0.16	0.08	1.00
17	135.53	5.74	1.19	0.00	0.48	0.24	1.00
18	107.74	3.40	1.21	0.24	0.49	0.24	1.00
19	24.84	49.81	0.33	0.39	0.13	0.07	0.35
20	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
21	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
22	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
23	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
Average	82.63	120.11	0.89	0.35	0.35	0.18	
Total	1404.64	2041.84	15.12	5.18	6.03	3.03	14.33

Cricket Valley Energy Center

Dover Plains, NY

Turbine 1- Daily Operations & EMS Inlet Emissions Report

November 2, 2019

Hour	SCR NOx ppm	SCR O2 %	CO Cat CO ppm	CT Nat Gas Flow klb	CT Heat Input mmBtu	DB Nat Gas Flow kscf	DB Heat Input mmBtu	Total Heat Input mmBtu	GT Megawatt Hours	ST Megawatt Hours	Process Status
00	14.09	12.97	0.55	96.8	2421.0	**Down**	**Down**	2421.0	237.2	**Down**	Hot SU
01	13.85	12.97	0.59	96.8	2421.0	**Down**	**Down**	2421.0	237.2	**Down**	Hot SU
02	13.57	12.97	0.56	96.8	2421.0	**Down**	**Down**	2421.0	237.4	**Down**	Hot SU
03	13.45	12.97	0.52	96.8	2421.0	**Down**	**Down**	2421.0	237.5	**Down**	Hot SU
04	13.29	12.97	0.54	96.8	2421.0	**Down**	**Down**	2421.0	237.5	**Down**	Hot SU
05	13.07	12.97	0.53	61.0	1525.2	**Down**	**Down**	1525.2	149.7	**Down**	Hot SU
06	**Down**	**Down**	**DCal**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
07	26.94	15.12	222.01	15.6	389.9	**Down**	**Down**	389.9	22.1	**Down**	Hot SU
08	12.70	13.31	6.11	74.5	1863.0	0.0	0.0	1863.0	165.6	**Down**	Hot SU
09	16.38	13.51	100.23	26.2	655.2	**Down**	**Down**	655.2	59.0	**Down**	Hot SU
10	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
11	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
12	17.54	14.10	109.28	37.7	943.0	**Down**	**Down**	943.0	76.5	**Down**	Hot SU
13	16.34	12.95	0.50	96.1	2403.0	**Down**	**Down**	2403.0	234.4	**Down**	Hot SU
14	14.95	12.99	0.53	94.3	2358.0	3.2	3.4	2361.4	229.6	**Down**	Hot SU
15	31.67	14.36	77.60	70.9	1773.0	1.4	1.4	1774.4	156.5	**Down**	Hot SU
16	61.05	16.22	487.63	31.3	783.0	**Down**	**Down**	783.0	32.7	**Down**	Hot SU
17	15.09	12.94	0.90	94.7	2367.0	22.2	23.3	2390.3	230.1	**Down**	Hot SU
18	14.78	12.93	0.61	96.1	2403.0	27.8	29.2	2432.2	234.8	**Down**	Hot SU
19	15.93	13.50	104.08	26.1	652.1	4.8	5.0	657.1	58.6	**Down**	Hot SU
20	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
21	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
22	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
23	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
Average	19.10	13.51	65.46	71.1	1777.7	9.9	10.4	1781.3	166.8	**Down**	
Total				1208.5	30220.4	59.4	62.3	30282.7	2836.4	**Down**	

Formula Verification Examples

Unit Name:	**144.5CRICKET VALLEY ENERGY CENTER**	**Oris Code:**	**57185**
Date/ Time:	**11/02/2019 HOUR 1800**	**Unit /Stack #**	**U001**

Formula **Conversion**
Parameter **CO2 metric tons-PNG**

CO2 (Eq. G-4) tons	conversion factor tons/metric ton	**CO2 metric tons**	GWP Factor	**CO2e (CO2) metric tons**
144.5	1.1023	**131.09**	1	**131.09**

Formula **C-10**
Parameter **CH4 metric tons-PNG**

Total CT HI mmBtu	Total DB HI mmBtu	CH4 EF kgCH4/mmBtu	Conversion metric ton/kg	**CH4 metric tons**	GWP Factor	**CO2e (CH4) metric tons**
2403.0	29.2	0.001	0.001	**0.00243**	25	**0.06075**

Formula **C-10**
Parameter **N2O metric tons-PNG**

Total CT HI mmBtu	Total DB HI mmBtu	N2O EF kgN2O/mmBtu	Conversion metric ton/kg	**N2O metric tons**	GWP Factor	**CO2e (N2O) metric tons**
2403.0	29.2	0.0001	0.001	**0.00024**	298	**0.07152**

Parameter **CO2e metric tons-PNG**

CO2e (CO2) metric tons	CO2e (CH4) metric tons	CO2e(N2O) metric tons	**CO2e (total) metric tons**
131.1	0.06075	0.07152	**131.22227**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 1- Daily GHG Emissions Report

November 2, 2019

Hour	Nat Gas GCV Btu/scf	Heat Input mmBtu	CO2 tons	CO2 Metric Tons	N2O Metric Tons	CH4 Metric Tons	N2O (CO2e) Metric Tons	CH4 (CO2e) Metric Tons	Total CO2e Metric Tons	Turbine On-Time
00	1050.0	2421.0	143.9	130.55	0.00024	0.00242	0.07152	0.06050	130.68202	1.00
01	1050.0	2421.0	143.9	130.55	0.00024	0.00242	0.07152	0.06050	130.68202	1.00
02	1050.0	2421.0	143.9	130.55	0.00024	0.00242	0.07152	0.06050	130.68202	1.00
03	1050.0	2421.0	143.9	130.55	0.00024	0.00242	0.07152	0.06050	130.68202	1.00
04	1050.0	2421.0	143.9	130.55	0.00024	0.00242	0.07152	0.06050	130.68202	1.00
05	1050.0	1525.2	90.7	82.28	0.00015	0.00153	0.04470	0.03825	82.36295	0.63
06	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
07	1050.0	389.9	23.2	21.05	0.00004	0.00039	0.01192	0.00975	21.07167	0.38
08	1050.0	1863.0	110.7	100.43	0.00019	0.00186	0.05662	0.04650	100.53312	1.00
09	1050.0	655.2	39.0	35.38	0.00007	0.00066	0.02086	0.01650	35.41736	0.35
10	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
11	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
12	1050.0	943.0	56.0	50.80	0.00009	0.00094	0.02682	0.02350	50.85032	0.62
13	1050.0	2403.0	142.8	129.55	0.00024	0.00240	0.07152	0.06000	129.68152	1.00
14	1050.0	2361.4	140.3	127.28	0.00024	0.00236	0.07152	0.05900	127.41052	1.00
15	1050.0	1774.4	105.5	95.71	0.00018	0.00177	0.05364	0.04425	95.80789	1.00
16	1050.0	783.0	46.5	42.18	0.00008	0.00078	0.02384	0.01950	42.22334	1.00
17	1050.0	2390.3	142.1	128.91	0.00024	0.00239	0.07152	0.05975	129.04127	1.00
18	1050.0	2432.2	144.5	131.09	0.00024	0.00243	0.07152	0.06075	131.22227	1.00
19	1050.0	657.1	39.0	35.38	0.00007	0.00066	0.02086	0.01650	35.41736	0.35
20	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
21	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
22	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
23	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
Average Total	1050.0	30282.7	1799.8	1632.79	0.00303	0.03027	0.90294	0.75675	1634.44969	14.33

APPENDIX 6

RELATIVE ACCURACY TEST AUDIT REPORT

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00001 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 6, 2020

Report Date: March 11, 2020



Corporate Headquarters
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012

AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices
Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00001 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 6, 2020

Prepared and Reviewed by:

Logan K. Tsotsoros

Logan Tsotsoros
AHU Support Staff

Gavin Dolsky

Gavin Dolsky, QI
Staff Engineer – Report Manager

I, Aaron Blum

Aaron Blum, QSTI
Sr. Test Manager
certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

Table of Contents

1.0 INTRODUCTION *1*

1.1 TEST PURPOSE AND OBJECTIVES **1**

1.2 SUMMARY OF TEST PROGRAM **2**

1.2.1 Participating Organizations 2
1.2.2 Industry 2
1.2.3 Air Permit and Federal Requirements 2
1.2.4 Plant Location 2
1.2.5 Equipment Tested 2
1.2.6 Emission Points 2
1.2.7 Emission Parameters Measured 2
1.2.8 Date of Emission Test 2
1.2.9 Federal Certifications 3

1.3 KEY PERSONNEL **3**

2.0 SUMMARY OF TEST RESULTS *3*

3.0 SOURCE OPERATION *5*

3.1 PROCESS DESCRIPTION **5**

3.2 SAMPLING LOCATION **5**

4.0 SAMPLING AND ANALYTICAL PROCEDURES *6*

4.1 TEST METHODS **6**

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS **6**

APPENDICES

Appendix A Test Results and Calculations

Appendix B CEMS and Reference Method Data

Appendix C Calibration Gas Certifications

Appendix D Quality Assurance and Quality Control Data

Appendix E Stratification Test Data

Relative Accuracy Test Audit
General Electric, 7F.05, Unit #U-00001 CEMS
Cricket Valley Energy Center LLC
Cricket Valley Energy Center
Dover Plains, New York
February 6, 2020

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Relative Accuracy Test Audit (RATA) for nitrogen oxides (NOx), carbon monoxide (CO), ammonia (NH_3), and oxygen (O_2) from the exhaust of the General Electric, 7F.05, Unit #U-00001 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on February 6, 2020.

The accumulated data from the RATA provides the figures for evaluating the acceptability of the operation of the on-site continuous emission monitoring system (CEMS) for the monitoring of NOx, CO, NH_3, and O_2 from the General Electric, 7F.05, Unit #U-00001 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to perform the initial certification RATA on the CEMS that serves the General Electric, 7F.05, Unit #U-00001 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. Reference method (RM) testing followed the Code of Federal Regulations (CFR), Title 40 (40 CFR), Part 60 (40 CFR 60), Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320. RM values are compared with the on-site CEMS to document performance as required in the 40 CFR 60, Appendix B, Performance Specifications (PS) and 40 CFR 75 Appendix A and B. All relative accuracies were established on-site and were governed by the following sets of rules:

In accordance with 40 CFR 60, Appendix B, PS 2, Section 13.2, the NOx and NH_3 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent when average emissions during the test are greater than 50 percent of the emission standard or alternative relative accuracy (ARA) does not exceed 10.0 percent when the average emissions during the test are less than 50 percent of the emission standard. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

In accordance with 40 CFR 75, Appendix A, Section 3.3.2(a) and (b), the NOx RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and reference method (RM) values does not exceed 0.020 lb/MMBtu. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (f), and Appendix B, Figure 2, the NOx RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and RM values does not exceed 0.015 lb/MMBtu. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 3, Section 13.2, the O_2 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent or if the average difference between the CEMS and reference method (RM) values does not exceed plus or minus 1.0 percent of the measured value.

In accordance with 40 CFR 60, Appendix B, PS 4 and 4A, Sections 13.2 of each, the CO relative accuracy (RA) test results are acceptable if the RA does not exceed 10.0 percent, if the average difference between the CEMS and reference method (RM) values plus the 2.5 percent confidence coefficient (2.5%CC) does not exceed 5.0 parts per million (ppm), or if the alternative relative accuracy (ARA) does not exceed 5.0 percent. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations
- New York State Department of Environmental Conservation (NYSDEC)
- Cricket Valley Energy Center LLC
- Custom Instrumentation Services Corporation (CiSCO)
- Bechtel
- Air Hygiene

1.2.2 Industry
- Electric Utility / Electric Services

1.2.3 Air Permit and Federal Requirements
- Permit Number: 3-1326-00275/00009
- DEC ID: 3132600275
- 40 CFR 60, Appendix B, Performance Specifications (PS)
- 40 CFR 75, Appendix A and B

1.2.4 Plant Location
- Cricket Valley Energy Center in Dover Plains, New York
  - GPS Coordinates [Latitude 41.67616, Longitude -73.576914]
  - 2241 Route NY 22, Dover Plains, New York 12522
  - Federal Registry System / Facility Registry Service (FRS) No. – 110043333372
  - Source Classification Code (SCC) – 20100209

1.2.5 Equipment Tested
- General Electric, 7F.05, Unit #U-00001
  - NOx Analyzer (TAPI T200M, Serial No. 1012)
  - NH_3 Analyzer (TAPI T200M, Serial No. 1047)
  - CO Analyzer (TAPI T300M, Serial No. 518)
  - O_2 Analyzer (TAPI T803, Serial No. 128)

1.2.6 Emission Points
- Exhaust from the General Electric, 7F.05, Unit #U-00001
- For all gases, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00001, determined after conducting a stratification test

1.2.7 Emission Parameters Measured
- NOx
- CO
- NH_3
- O_2

1.2.8 Date of Emission Test
- February 6, 2020

1.2.9 Federal Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Cricket Valley Energy Center LLC:	Marc Duquette (mduquette@cricketvalley.com)	617-320-5219
Bechtel:	Ron Swanson (reswanson@bechtel.com)	571-262-0198
CiSCO:	Reginald Williams (rwilliams@ciscocems.com)	720-419-0177
Air Hygiene:	Aaron Blum (ablum@airhygiene.com)	918-307-8865
Air Hygiene:	Swanson Bierman	918-307-8865
Air Hygiene:	Matt Jones	918-307-8865
Air Hygiene:	Rob White	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00001 located at the Cricket Valley Energy Center on February 6, 2020 are summarized in the following table and relate only to the items tested.

TABLE 2.1
SUMMARY OF GENERAL ELECTRIC, 7F.05, UNIT #U-00001 RATA RESULTS

Pollutant	Units	Criteria			Results	Passed / Test Frequency
		CFR	Specification / Section	Standard		
NOx	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 9.22%	YES / ANNUAL
NOx	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 9.60%	YES / ANNUAL
NOx	lb/MMBtu	Part 75	Appendix A, Section 3.3.2(a),(b) Appendix B, Section 2.3.1.2(a),(f), Figure 2	RA ≤ 10%, or if lb/MMBtu ≤ 0.200, d ≤ ±0.020 lb/MMBtu Annual Incentive RA ≤ 7.5%, or if lb/MMBtu ≤ 0.2, d ≤ ±0.015 lb/MMBtu	RA = 9.34% RM = 0.01 lb/MMBtu d = 0.000 lb/MMBtu BAF=1.000	YES / ANNUAL
O_2	%vd	Part 60	Appendix B, Performance Specification 3, Section 13.2	RA ≤ 20%, or d ≤ ±1.0%	RA = 0.48% d = 0.0 %	YES / ANNUAL
CO	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	RA = 137.85% |d|+2.5%CC = 0.7 ppm	YES / ANNUAL
CO	lb/hr	Part 60	Appendix B, Performance Specification 4, 4A Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 lb/hr, or ARA ≤ 5%	RA = 137.82% |d|+2.5%CC = 0.7 ppm (|d|+2.5%CC = 4.3 lb/hr)	YES / ANNUAL
NH_3	ppmvd@15%O_2	Assumed Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 9.70%	YES / ANNUAL
NH_3	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 10.36%	YES / ANNUAL
Load	MW	Part 60	Appendix B, Performance Specifications	> 50% max load	372.8	WITHIN TOLERANCE
Load	MW	Part 75	Appendix A and B	normal load range	372.8	WITHIN TOLERANCE

Notes: RA = relative accuracy, ARA = alternative relative accuracy, RM = reference method value, d = difference between RM and CEMS value, CC = confidence coefficient, v = velocity, BAF = bias adjustment factor

The RATA passed for all pollutants (NOx, CO, NH_3, and O_2) in all units (ppm@15%O_2, lb/hr, lb/MMBtu, and %) under all 40 CFR 60 and 40 CFR 75 criteria.

Specifically, NOx in units of ppm@15%O_2 and lb/hr, passed 40 CFR 60 criteria with an RA less than 20 percent. NOx in units of lb/MMBtu passed the 40 CFR 75 alternative annual incentive criteria with an emissions rate of less than 0.200 lb/MMBtu and a difference between the RM and CEMS analyzers of less than 0.015 lb/MMBtu. Also the Bias Adjustment Factor test resulted in an adjustment factor equal to 1.0 (no adjustment required). O_2 in units of % passed the 40 CFR 60 criteria with an RA less than 20 percent. CO in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 alternative criteria with a concentration difference between the RM and CEMS analyzers plus the confidence coefficient of less than 5 ppm and 5 lb/hr respectively. NH_3 in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 criteria with an RA less than 20 percent.

Unit load was within the 40 CFR 60 required criteria of greater than 50 percent of the maximum load and also fell within the normal load criteria as defined by the plants Quality Control and Monitoring Plan which defined the upper and lower boundary on the unit and the normal and secondary normal load ranges.

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

Cricket Valley Energy Center LLC (CVEC) owns and operates the Cricket Valley Energy Center located at 2241 ST RTE 22 in Dover Plains, New York. Located on the Cricket Valley Energy Center are three General Electric (GE) 7F.05 Combustion Turbine Generators (CTGs), designated as U-00001, U-00002, and U-0003, and each unit is equipped with one heat recovery steam generator (HRSG) with supplemental duct firing. Each unit is rated at 381 megawatts (MW). The nominal MW per unit as per the NYSDEC Permit ID 3-1326-00275/00009 is identified as 333 MW.

A single, dedicated dry extraction based continuous emissions monitoring system (CEMS) is installed on each the unit. The CEMS configurations include nitrogen oxide (NOx) analyzers, ammonia (NH_3) analyzers, carbon monoxide (CO) analyzers, diluent gas oxygen (O_2) analyzers, and data acquisition and handling systems (DAHS).

3.2 SAMPLING LOCATION

The CTG stack is vertical, circular, and measures 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 265.8 ft above grade level with an exit elevation of approximately 282.5 ft above grade level. The test ports are located approximately 70.8 ft (850 inches) downstream and approximately 16.7 ft (200.4 inches) upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by Cricket Valley Energy Center LLC. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test. During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the General Electric, 7F.05, Unit #U-00001 at the Cricket Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on February 6, 2020.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Oxygen	EPA Method 3A	Paramagnetic Cell
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor
Ammonia and Moisture	EPA Method 320	Fourier Transform Infrared

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory / portable analyzer via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer,

interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations. Spectral data was analyzed by the MKS MG2000 software.

Ten test runs of approximately 21 minutes each were conducted on the General Electric, 7F.05, Unit #U-00001 for NOx, CO, NH_3, and O_2.

The stack gas analysis for O_2 concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O_2 analyzer uses a paramagnetic cell detector.

EPA Method 7E was used to determine concentrations of NOx. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO_2 in nitrogen certified gas cylinder was used to verify at least a 90 percent NO_2 conversion on the day of the test.


CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

An MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer, or equivalent, was used for NH_3 and H_2O analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm^{-1}. The system employed a silicon carbide infrared source at 1200ºC, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191ºC. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 4.0 liters per minute, the sample gas in the cell is refreshed approximately four times each minute. Interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations.

TABLE 4.2
ANALYTICAL INSTRUMENTATION

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NOx	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO_2 to NO. Chemiluminescence of reaction of NO with O_3. Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
NH_3 and H_2O	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
O_2	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

COPYRIGHT © 2011 AIR HYGIENE INTERNATIONAL, INC.




PROBE

HEATED PROBE FILTER

LEGEND

- Heated Teflon Tubing (pre-conditioned sample)
- Unheated Teflon Tubing (conditioned sample)
- Diluted Calibration Gas
- Calibration Gas
- Electronic Input/Output



HEATED PROBE FILTER

PROBE

STACK EXHAUST

PROCESS INLET OR 2ND STACK

dual line heated sample umbilical

TEST TRAILER EXTERIOR

TEST TRAILER INTERIOR


DATA RECORDER



COMPUTER




GAS CONDITIONER



dual line heated sample umbilical

MOBILE SECONDARY ANALYZERS

MANIFOLD





GAS DILUTER

THC, VOC



O_2, CO_2, NOx, CO, SO_2



HOT/WET ANALYZERS

COLD/DRY ANALYZERS




COLD/DRY ANALYZERS HOT/WET



O_2, CO_2, NOx, CO, SO_2

FLOW CONTROL MANIFOLD





FTIR


THC, VOC



CONDITIONER

VENT

CALIBRATION/ BIAS GAS BOTTLES



VENT

FIXED PRIMARY ANALYZERS

Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.

AIR HYGIENE

Figure 4.1
EMISSIONS TESTING LAB

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1:
EMISSIONS TESTING SCHEDULE

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
U-00001	Base Load	Stratification Test	1	02/05/20	14:35:00	16:30:00	DAHS
U-00001	Base Load	Gas RATA	1	02/06/20	11:36:10	11:56:40	DAHS
U-00001	Base Load	Gas RATA	2	02/06/20	12:10:10	12:30:40	DAHS
U-00001	Base Load	Gas RATA	3	02/06/20	12:42:10	13:02:40	DAHS
U-00001	Base Load	Gas RATA	4	02/06/20	13:20:10	13:40:40	DAHS
U-00001	Base Load	Gas RATA	5	02/06/20	13:55:10	14:15:40	DAHS
U-00001	Base Load	Gas RATA	6	02/06/20	14:27:10	14:47:40	DAHS
U-00001	Base Load	Gas RATA	7	02/06/20	15:01:10	15:21:40	DAHS
U-00001	Base Load	Gas RATA	8	02/06/20	15:36:10	15:56:40	DAHS
U-00001	Base Load	Gas RATA	9	02/06/20	16:08:10	16:28:40	DAHS
U-00001	Base Load	Gas RATA	10	02/06/20	16:46:10	17:06:40	DAHS

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
O_2 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(%vd)	(%vd)	(diff)	($diff^2$)
1	11:36 - 11:56	YES	373.4	11.86	11.99	-0.13	0.02
2	12:10 - 12:30	NO	373.2	11.68	12.00		
3	12:42 - 13:02	YES	373.3	11.97	11.99	-0.02	0.00
4	13:20 - 13:40	YES	372.6	12.02	12.00	0.02	0.00
5	13:55 - 14:15	YES	372.8	12.02	11.98	0.04	0.00
6	14:27 - 14:47	YES	372.7	12.04	11.99	0.05	0.00
7	15:01 - 15:21	YES	372.7	12.06	11.99	0.07	0.00
8	15:36 - 15:56	YES	372.8	12.07	12.00	0.07	0.01
9	16:08 - 16:28	YES	372.6	12.02	12.00	0.02	0.00
10	16:46 - 17:06	YES	372.2	11.97	12.01	-0.04	0.00
11		NO					
12		NO					
	Total		**3355.1**	**108.03**	**107.95**	**0.085**	**0.032**
	Average		**372.8**	**12.00**	**11.99**	**0.009**	

Number of Runs	9
Standard Deviation	0.06
T-value	2.306
Confidence Coefficient	0.05

Average Difference =	**0.0**
Relative Accuracy =	**0.5%**

Part 60, Appendix B, Performance Specification 3,
13.2 CEMS Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent of the mean value of the reference method (RM) data. The results are also acceptable if the absolute value of the difference between the mean RM value and the mean CEMS value is less than or equal to 1.0 percent O2 (or CO2).

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:36 - 11:56	YES	373.4	1.96	1.70	0.26	0.07
2	12:10 - 12:30	YES	373.2	1.68	1.82	-0.14	0.02
3	12:42 - 13:02	YES	373.3	1.77	1.71	0.06	0.00
4	13:20 - 13:40	YES	372.6	1.75	1.70	0.05	0.00
5	13:55 - 14:15	YES	372.8	1.78	1.75	0.03	0.00
6	14:27 - 14:47	YES	372.7	1.64	1.81	-0.17	0.03
7	15:01 - 15:21	YES	372.7	1.97	1.72	0.25	0.06
8	15:36 - 15:56	YES	372.8	1.86	1.79	0.07	0.00
9	16:08 - 16:28	YES	372.6	1.78	1.70	0.08	0.01
10	16:46 - 17:06	NO	372.2	2.06	1.47		
11		NO					
12		NO					
	Total		**3356.1**	**16.19**	**15.70**	**0.49**	**0.19**
	Average		**372.9**	**1.80**	**1.74**	**0.05**	

Number of Runs	9
Standard Deviation	0.14
T-value	2.306
Confidence Coefficient	0.11

Relative Accuracy = 9.2%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:36 - 11:56	YES	373.4	0.01	0.00	0.01	0.00
2	12:10 - 12:30	YES	373.2	0.28	0.00	0.28	0.08
3	12:42 - 13:02	YES	373.3	0.34	0.00	0.34	0.11
4	13:20 - 13:40	YES	372.6	0.51	0.00	0.51	0.26
5	13:55 - 14:15	YES	372.8	0.62	0.00	0.62	0.39
6	14:27 - 14:47	YES	372.7	0.67	0.00	0.67	0.45
7	15:01 - 15:21	YES	372.7	0.79	0.00	0.79	0.62
8	15:36 - 15:56	YES	372.8	0.67	0.00	0.67	0.45
9	16:08 - 16:28	YES	372.6	0.67	0.00	0.67	0.46
10	16:46 - 17:06	NO	372.2	1.51	0.00		
11		NO					
12		NO					
	Total		**3356.1**	**4.56**	**0.00**	**4.56**	**2.81**
	Average		**372.9**	**0.51**	**0.00**	**0.51**	

Number of Runs	9
Standard Deviation	0.25
T-value	2.306
Confidence Coefficient	0.19

Relative Accuracy =	**137.8%**
|d (difference in ppm)| + CC =	**0.7**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:36 - 11:56	YES	373.4	1.44	1.46	-0.02	0.00
2	12:10 - 12:30	YES	373.2	1.47	1.30	0.17	0.03
3	12:42 - 13:02	YES	373.3	1.56	1.44	0.12	0.01
4	13:20 - 13:40	YES	372.6	1.53	1.47	0.06	0.00
5	13:55 - 14:15	YES	372.8	1.56	1.45	0.11	0.01
6	14:27 - 14:47	YES	372.7	1.40	1.26	0.14	0.02
7	15:01 - 15:21	YES	372.7	1.41	1.38	0.03	0.00
8	15:36 - 15:56	YES	372.8	1.47	1.29	0.18	0.03
9	16:08 - 16:28	YES	372.6	1.44	1.44	0.00	0.00
10	16:46 - 17:06	NO	372.2	1.72	1.81		
11		NO					
12		NO					
	Total		**3356.1**	**13.27**	**12.49**	**0.78**	**0.11**
	Average		**372.9**	**1.47**	**1.39**	**0.09**	

Number of Runs	9
Standard Deviation	0.07
T-value	2.306
Confidence Coefficient	0.06

Relative Accuracy = 9.7%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:36 - 11:56	YES	373.4	19.70	17.00	2.70	7.27
2	12:10 - 12:30	YES	373.2	16.88	18.18	-1.30	1.70
3	12:42 - 13:02	YES	373.3	17.72	17.09	0.63	0.40
4	13:20 - 13:40	YES	372.6	17.55	16.95	0.60	0.36
5	13:55 - 14:15	YES	372.8	17.84	17.41	0.43	0.19
6	14:27 - 14:47	YES	372.7	16.47	18.04	-1.57	2.48
7	15:01 - 15:21	YES	372.7	19.70	17.15	2.55	6.51
8	15:36 - 15:56	YES	372.8	18.61	17.85	0.76	0.57
9	16:08 - 16:28	YES	372.6	17.80	16.98	0.82	0.67
10	16:46 - 17:06	NO	372.2	20.59	14.60		
11		NO					
12		NO					
	Total		**3356.1**	**162.26**	**156.65**	**5.61**	**20.13**
	Average		**372.9**	**18.03**	**17.41**	**0.62**	

Number of Runs	9
Standard Deviation	1.44
T-value	2.306
Confidence Coefficient	1.11

Relative Accuracy = 9.6%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:36 - 11:56	YES	373.4	0.07	0.00	0.07	0.01
2	12:10 - 12:30	YES	373.2	1.72	0.00	1.72	2.97
3	12:42 - 13:02	YES	373.3	2.05	0.00	2.05	4.19
4	13:20 - 13:40	YES	372.6	3.10	0.00	3.10	9.60
5	13:55 - 14:15	YES	372.8	3.78	0.00	3.78	14.32
6	14:27 - 14:47	YES	372.7	4.08	0.00	4.08	16.63
7	15:01 - 15:21	YES	372.7	4.80	0.00	4.80	23.02
8	15:36 - 15:56	YES	372.8	4.11	0.00	4.11	16.86
9	16:08 - 16:28	YES	372.6	4.11	0.00	4.11	16.89
10	16:46 - 17:06	NO	372.2	9.16	0.00		
11		NO					
12		NO					
	Total		**3356.1**	**27.82**	**0.00**	**27.82**	**104.49**
	Average		**372.9**	**3.09**	**0.00**	**3.09**	

Number of Runs	9
Standard Deviation	1.52
T-value	2.306
Confidence Coefficient	1.17

Relative Accuracy =	**137.8%**
|d (difference in lb/hr)| + CC =	**4.3**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:36 - 11:56	YES	373.4	5.34	5.42	-0.08	0.01
2	12:10 - 12:30	YES	373.2	5.46	4.80	0.66	0.43
3	12:42 - 13:02	YES	373.3	5.78	5.35	0.43	0.19
4	13:20 - 13:40	YES	372.6	5.68	5.41	0.27	0.07
5	13:55 - 14:15	YES	372.8	5.78	5.35	0.43	0.19
6	14:27 - 14:47	YES	372.7	5.17	4.62	0.55	0.31
7	15:01 - 15:21	YES	372.7	5.22	5.06	0.16	0.02
8	15:36 - 15:56	YES	372.8	5.45	4.73	0.72	0.51
9	16:08 - 16:28	YES	372.6	5.33	5.41	-0.08	0.01
10	16:46 - 17:06	NO	372.2	6.35	6.62		
11		NO					
12		NO					
	Total		**3356.1**	**49.20**	**46.15**	**3.05**	**1.73**
	Average		**372.9**	**5.47**	**5.13**	**0.34**	

Number of Runs	9
Standard Deviation	0.30
T-value	2.306
Confidence Coefficient	0.23

Relative Accuracy = 10.4%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/MMBtu)	(lb/MMBtu)	(diff)	($diff^2$)
1	11:36 - 11:56	YES	373.4	0.0072	0.0063	0.0009	0.0000
2	12:10 - 12:30	YES	373.2	0.0062	0.0067	-0.0005	0.0000
3	12:42 - 13:02	YES	373.3	0.0065	0.0063	0.0002	0.0000
4	13:20 - 13:40	YES	372.6	0.0065	0.0063	0.0002	0.0000
5	13:55 - 14:15	YES	372.8	0.0066	0.0064	0.0002	0.0000
6	14:27 - 14:47	YES	372.7	0.0061	0.0067	-0.0006	0.0000
7	15:01 - 15:21	YES	372.7	0.0073	0.0063	0.0010	0.0000
8	15:36 - 15:56	YES	372.8	0.0068	0.0066	0.0002	0.0000
9	16:08 - 16:28	YES	372.6	0.0066	0.0063	0.0003	0.0000
10	16:46 - 17:06	NO	372.2	0.0076	0.0054		
11		NO					
12		NO					
	Total		**3356.1**	**0.0598**	**0.0579**	**0.0019**	**0.0000**
	Average		**372.9**	**0.0066**	**0.0064**	**0.0002**	

Number of Runs	9
Standard Deviation	0.0005
T-value	2.306
Confidence Coefficient	0.0004

Relative Accuracy = 9.34%

If the mean difference is less than or equal to the absolute value of the confidence coefficient, then the Bias Test passes and the bias adjustment factor is not applicable.

Mean Difference =	0.0002
Confidence Coefficient =	0.0004

BAF = 1 + (abs. value mean difference/avg. CEMS reading)

Average CEMS Reading =	0.0064
BAF =	**1.000**

Part 75, Appendix A,
3.3.2 Relative Accuracy for NOX-Diluent Continuous Emission Monitoring Systems
(a) The relative accuracy for NOX-diluent continuous emission monitoring systems shall not exceed 10.0 percent.
(b) For affected units where the average of the reference method measurements of NOX emission rate (this means lb/MMBtu) during the relative accuracy test audit is less than or equal to 0.200 lb/mmBtu, the difference between the mean value of the continuous emission monitoring system measurements and the reference method mean value shall not exceed ±0.020 lb/mmBtu, wherever the relative accuracy specification of 10.0 percent is not achieved.

7.6.5 Bias Adjustment
(b) For single-load RATAs of SO2 pollutant concentration monitors, NOX concentration monitoring systems, and NOX-diluent monitoring systems and for the single-load flow RATAs required or allowed under section 6.5.2 of this appendix and sections 2.3.1.3(b) and 2.3.1.3(c) of Appendix B to this part, the appropriate BAF is determined directly from the RATA results at normal load, using Equation A-12. Notwithstanding, when a NOX concentration CEMS or an SO2 CEMS or a NOX-diluent CEMS installed on a low-emitting affected unit (i.e., average SO2 or NOX concentration during the RATA ≦ 250 ppm or average NOX emission rate ≦ 0.200 lb/mmBtu) meets the normal 10.0 percent relative accuracy specification (as calculated using Equation A-10) or the alternate relative accuracy specification in section 3.3 of this appendix for low-emitters, but fails the bias test, the BAF may either be determined using Equation A-12, or a default BAF of 1.111 may be used.

Part 75, Appendix B,
2.3.1.2 Reduced RATA Frequencies. Relative accuracy test audits of primary and redundant backup SO2 pollutant concentration monitors, CO2 pollutant concentration monitors (including O2 monitors used to determine CO2 emissions), CO2 or O2 diluent monitors used to determine heat input, moisture monitoring systems, NOX concentration monitoring systems, flow monitors, NOX-diluent monitoring systems or SO2-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:
(a) The relative accuracy during the audit of an SO2 or CO2 pollutant concentration monitor (including an O2 pollutant monitor used to measure CO2 using the procedures in appendix F to this part), or of a CO2 or O2 diluent monitor used to determine heat input, or of a NOX concentration monitoring system, or of a NOX-diluent monitoring system, or of an SO2-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(f) For units with low NOX emission rates (average NOX emission rate measured by the reference method during the RATA ≤ 0.200 lb/mmBtu), when a NOX-diluent continuous emission monitoring system fails to achieve a relative accuracy ≤ 7.5 percent, but the monitoring system mean value from the RATA, calculated using Equation A-7 in appendix A to this part, is within ± 0.015 lb/mmBtu of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO2 or NOX(3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO2-diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NOX-diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO2 or O2	7.5% < RA ≤ 10.0% or ± 1.0% CO2/O2(2)	RA ≤ 7.5% or ± 0.7% CO2/O2(2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H2O(2)	RA ≤ 7.5% or ± 1.0% H2O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO2 monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.
(2) The difference between monitor and reference method mean values applies to moisture monitors, CO2, and O2 monitors, low emitters, or low flow, only.
(3) A NOX concentration monitoring system used to determine NOX mass emissions under § 75.71.

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO_2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH_3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO_2 (lb/lb-mole) =	44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO_2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH_3 =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO_2 =	0.0000001142434

NOTE: units are lb/ppm*ft^3

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right)$$

2. Correction to % O_2, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}} \right)$$

3. Correction to % O_2 and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_O - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O_2 based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp \cdot hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} or \frac{E_{lb/hr} \times 453.6}{hp}$$

RATA SHEET CALCULATIONS

d = Reference Method Data - CEMS Data

S_d = Standard Deviation

CC = Confident Coefficient

n = number of runs

$t_{0.025}$ = 2.5 percent confidence coefficient T-values

RA = relative accuracy

ARA = alternative relative accuracy

BAF = Bias adjustment factor

n	t	n	t	n	t
2	12.706	7	2.447	12	2.201
3	4.303	8	2.365	13	2.179
4	3.182	9	2.306	14	2.160
5	2.776	10	2.262	15	2.145
6	2.571	11	2.228	16	2.131

1. Difference

$$d = \sum_{i=1}^{n} d_i$$

2. Standard Deviation

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \left[\frac{\left(\sum_{i=1}^{n} d_i \right)^2}{n} \right]}{n-1}}$$

3. Confident Coefficient

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$

4. Relative Accuracy

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$

5. Alternative Relative Accuracy

$$ARA = \frac{|d_{AVG}| + |CC|}{AS} \times 100$$

5. Bias Adjustment Factor

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right)$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO_2 to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H_2O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
$\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
$\%_{CO2d}$,$\%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g.,24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO_2 rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O_2.
E_{jo},E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft^3 = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
$\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
$\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = $2x10^4$ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p,L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
$\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
$M_{\%}$ = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)[1]
NCM = net Btu per SCF (constant based on compound)
$\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
$\%_{O2d}$, $\%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO2 emissions, percent.
$\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
$\%_{Sf}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
$\%S_p$, $\%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
$t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2}=CO_2 Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RHsp (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp}(lb/lb) = \left[\left(\frac{gr}{lb}\right) \times \frac{lb}{7000\ gr}\right]$$

RH_{sp}= 26.63 gr / lb x 1 lb / 7000 gr = 0.003805 lb H_2O / lb Air

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

ACE = (4.90 ppm - 4.99 ppm) / 8.90 ppm x 100 = -1.01 %

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS}\right) \times 100$$ Eq. 7E-2

SB = (4.82 ppm - 4.90 ppm) / 8.90 ppm x 100 = -0.90 %

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = \left|SB_{final} - SB_t\right|$$ Eq. 7E-4

D = | -1.01 % - -0.90 % | = 0.11 %

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs – Cdir| is ≤ 0.5 ppmv or if |Cs – Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = \left|C_S - C_{Dir}\right|$$ Eq. Section 13.2 and 13.3

SB / D_{Alt} = | 4.82 ppm - 4.90 ppm | = 0.08 ppm

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$ Eq. 7E-5b

C_{Gas} = (2.90 ppm - 0.01 ppm) (4.99 ppm / (4.82 ppm - 0.01 ppm)) = 3.01 ppm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Stack Exhaust Flow (Q_S) - RM19

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000}\right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}}\right)$$

Note: Equation presented in EPA Emission Measurement Center (EMC), Frequently Asked Questions (FAQ) for Method 19

$$Q_S = \frac{8{,}710.00\ SCF}{MMBtu} \times \frac{2{,}593{,}600.00\ SCF}{hr} \times \frac{1{,}050.00\ Btu}{SCF} \times \frac{MMBtu}{10^6\ Btu} \times \left[\frac{20.90\%}{20.9\% - 11.9\ \%}\right] = 54{,}863{,}375.38\ SCFH$$

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_W = C_D \times (1 - B_{WS})$$

$$C_D = \frac{C_W}{1 - B_{WS}}$$ Eq. 7E-10 $C_D = \frac{2.80\ ppmvw}{1 - 0.07} = 3.01\ ppmvd$ or inversely, $C_W = 3.01\ ppmvd \times \left[1 - 0.07\right] = 2.80\ ppmvw$

Diluent-Corrected Pollutant Concentration, O_2 Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O_2 Concentration. Calculate the O_2 corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$ Eq. 20-4 $C_{adj} = 3.01\ ppm \times \left[\frac{20.9\% - 15.00\ \%}{20.9\% - 11.86\ \%}\right] = 1.96\ ppm@15\%O_2$

Emissions Rate (lb/hr)

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$ $E_{lb/hr} = \frac{3.01\ ppmvd}{10^6\ ppm/part} \times \frac{54{,}863{,}375\ DSCFH \times 46.01\ lb/lb\text{-}mol}{385.23\ SCF/lb\text{-}mol} = \frac{19.70\ lb}{hr}$

Emissions Rate (lb/MMBtu)

RM 19, (02-27-14), 12.2 Emission Rates of PM, SO_2, and NOx. Select from the following sections the applicable procedure to compute the PM, SO_2, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for NOx gas Run 1, if applicable)

Oxygen Based

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O_2 ($\%O_2d$) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$ Eq. 19-1

$$E_{lb/MMBtu} = \frac{3.01\ ppm \times 8{,}710.00\ SCF/MMBtu \times 0.0000001194\ lb/ppm*ft^3 \times 20.9\%}{20.9\% - 11.86\ \%} = \frac{0.007\ lb}{MMBtu}$$

Conversion Constant

Convc for NOx

$$Conv_c(lb/ppm \cdot ft^3) = \frac{\frac{MW}{G}}{10^6}$$

$$Conv_c = \frac{\frac{46.01\ lb}{lb\text{•}mole} \times \frac{lb\text{•}mole}{385.23\ SCF}}{10^6} = \frac{0.0000001194\ lb}{ppm\text{-}ft^3}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RATA RESULTS)

Difference (d)

40 CFR 75, App A, (12-17-09), 7.3.1 Arithmetic Mean. Calculate the arithmetic mean of the differences, d , of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$d = \sum_{i=1}^{n} d_i$$ Eq. A-7

d = 0.007 lb/MMBtu - 0.006 lb/MMBtu = 0.000 lb/MMBtu

Standard Deviation

40 CFR 75, App A, (12-17-09), 7.3.2 Standard Deviation. Calculate the standard deviation, Sd, of a data set as follows:
(calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \frac{\left[\left(\sum_{i=1}^{n} d_i\right)^2\right]}{n}}{n-1}}$$ Eq. A-8

$$S_d = \sqrt{\frac{0.000 \text{ lb/MMBtu}^2 - \frac{\left[0.003 \text{ lb/MMBtu}\right]^2}{9}}{9 - 1}} = 0.001 \text{ lb/MMBtu}$$

Confidence Coefficient

40 CFR 75, App A, (12-17-09), 7.3.3 Confidence Coefficient. Calculate the confidence coefficient (one-tailed), cc, of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$ Eq. A-9

CC = 2.306 x $\frac{0.001 \text{ lb/MMBtu}}{\sqrt{9}}$ = 0.001 lb/MMBtu

T-Values	n	2	3	4	5	6	7	8	9
	$t_{0.025}$	12.706	4.303	3.182	2.776	2.571	2.447	2.365	2.306

2.5 percent confidence coefficients

Relative Accuracy

40 CFR 75, App A, (12-17-09), 7.3.4 Relative Accuracy. Calculate the relative accuracy of a data set using the following equation. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$ Eq. A-10

RA = $\frac{|0.000 \text{ lb/MMBtu}| + |0.001 \text{ lb/MMBtu}|}{0.007 \text{ lb/MMBtu}}$ x 100 = 14.99 %

Bias Adjustment Factor (BAF)

40 CFR 75, App A, (12-17-09), 7.6.5 Bias Adjustment. (a) If the monitor or monitoring system fails to meet the bias test requirement, adjust the value obtained from the monitor using the following equation: (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}}\right)$$ Eq. A-12

d_{AVG}= 0.000 < |CC| = 0.001 ⇨ BAF = 1 + $\frac{|\quad| \text{ lb/MMBtu}}{\text{lb/MMBtu}}$ = 1.000 lb/MMBtu

Note: BAF only applies if the mean difference (d) is greater than the absolute value of the confidence coefficient.

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B

CEMS AND REFERENCE METHOD DATA

Cricket Valley Energy Center LLC

Air Permit Number:	3-1326-00275/00009
Plant Name or Location:	Cricket Valley Energy Center
Date:	February 6, 2020
Project Number:	cis-19-cricketvalley.ny-start#1
Manufacturer & Equipment:	General Electric
Model:	7F.05
Unit Number:	U-00001
Test Load:	Base Load
Tester(s) / Test Unit(s):	RW/220

		RUN									
	UNITS	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**10**
Start Time	hh:mm:ss	11:36:10	12:10:10	12:42:10	13:20:10	13:55:10	14:27:10	15:01:10	15:36:10	16:08:10	16:46:10
End Time	hh:mm:ss	11:56:40	12:30:40	13:02:40	13:40:40	14:15:40	14:47:40	15:21:40	15:56:40	16:28:40	17:06:40
Bar. Pressure	in. Hg	29.67	29.65	29.67	29.58	29.57	29.54	29.54	29.53	29.51	29.53
Amb. Temp.	°F	33	34	35	37	38	38	35	36	36	35
Rel. Humidity	%	96	92	90	84	80	79	87	86	87	88
Spec. Humidity	lb water / lb air	0.003805	0.003798	0.003864	0.003916	0.003881	0.003836	0.003751	0.003860	0.003908	0.003796
Turbine Fuel Flow	SCFH	2,593,600	2,591,200	2,592,160	2,589,920	2,588,170	2,587,280	2,587,680	2,587,770	2,587,110	2,582,950
Duct Burner Fuel Flow	SCFH	0	0	0	0	0	0	0	0	0	0
Total Fuel Flow	SCFH	2,593,600	2,591,200	2,592,160	2,589,920	2,588,170	2,587,280	2,587,680	2,587,770	2,587,110	2,582,950
Power Output	megawatts	373.4	373.2	373.3	372.6	372.8	372.7	372.7	372.8	372.6	372.2
O_2 CEMS Data	%vd	11.99	12.00	11.99	12.00	11.98	11.99	11.99	12.00	12.00	12.01
NOx CEMS Data	ppmvd@15%O_2	1.70	1.82	1.71	1.70	1.75	1.81	1.72	1.79	1.70	1.47
	lb/hr	17.00	18.18	17.09	16.95	17.41	18.04	17.15	17.85	16.98	14.60
	lb/MMBtu	0.0063	0.0067	0.0063	0.0063	0.0064	0.0067	0.0063	0.0066	0.0063	0.0054
CO CEMS Data	ppmvd@15%O_2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	lb/hr	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NH_3 CEMS Data	ppmvd@15%O_2	1.46	1.30	1.44	1.47	1.45	1.26	1.38	1.29	1.44	1.81
	lb/hr	5.42	4.80	5.35	5.41	5.35	4.62	5.06	4.73	5.41	6.62
NH_3 RM Data	ppmvd@15%O_2	1.44	1.47	1.56	1.53	1.56	1.40	1.41	1.47	1.44	1.72
	lb/hr	5.34	5.46	5.78	5.68	5.78	5.17	5.22	5.45	5.33	6.35

Created with Comp&RATA&Eng-AHI v20190529

CEMS AND REFERENCE METHOD DATA

CEMS Data
(provided by Cricket Valley Energy Center LLC)

Relative Accuracy Test Data
CEMS Results (NOx)
General Electric, 7F.05, Unit #U-00001

Parameter:	Oxides of Nitrogen
Date of Test:	February 6, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Chemiluminescence
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1012

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:36 - 11:56	373.4		1.70	17.00	0.0063
2	12:10 - 12:30	373.2		1.82	18.18	0.0067
3	12:42 - 13:02	373.3		1.71	17.09	0.0063
4	13:20 - 13:40	372.6		1.70	16.95	0.0063
5	13:55 - 14:15	372.8		1.75	17.41	0.0064
6	14:27 - 14:47	372.7		1.81	18.04	0.0067
7	15:01 - 15:21	372.7		1.72	17.15	0.0063
8	15:36 - 15:56	372.8		1.79	17.85	0.0066
9	16:08 - 16:28	372.6		1.70	16.98	0.0063
10	16:46 - 17:06	372.2		1.47	14.60	0.0054
11						
12						

Relative Accuracy Test Data
CEMS Results (CO)
General Electric, 7F.05, Unit #U-00001

Parameter:	Carbon Monoxide
Date of Test:	February 6, 2020
Reference Method:	EPA Method 10
CEMS Analyzer Type:	Infrared Absorption
Manufacturer:	TAPI
Model #:	T300M
Serial #:	518

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:36 - 11:56	373.4		0.00	0.00	
2	12:10 - 12:30	373.2		0.00	0.00	
3	12:42 - 13:02	373.3		0.00	0.00	
4	13:20 - 13:40	372.6		0.00	0.00	
5	13:55 - 14:15	372.8		0.00	0.00	
6	14:27 - 14:47	372.7		0.00	0.00	
7	15:01 - 15:21	372.7		0.00	0.00	
8	15:36 - 15:56	372.8		0.00	0.00	
9	16:08 - 16:28	372.6		0.00	0.00	
10	16:46 - 17:06	372.2		0.00	0.00	
11						
12						

Relative Accuracy Test Data
CEMS Results (NH_3)
General Electric, 7F.05, Unit #U-00001

Parameter:	Ammonia
Date of Test:	February 6, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Dual NOx w/ NH3 conversion
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1047

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:36 - 11:56	373.4		1.46	5.42	
2	12:10 - 12:30	373.2		1.30	4.80	
3	12:42 - 13:02	373.3		1.44	5.35	
4	13:20 - 13:40	372.6		1.47	5.41	
5	13:55 - 14:15	372.8		1.45	5.35	
6	14:27 - 14:47	372.7		1.26	4.62	
7	15:01 - 15:21	372.7		1.38	5.06	
8	15:36 - 15:56	372.8		1.29	4.73	
9	16:08 - 16:28	372.6		1.44	5.41	
10	16:46 - 17:06	372.2		1.81	6.62	
11						
12						

Relative Accuracy Test Data
CEMS Results (O_2)
General Electric, 7F.05, Unit #U-00001

Parameter:	Oxygen
Date of Test:	February 6, 2020
Reference Method:	EPA Method 3A
CEMS Analyzer Type:	Paramagnetic Cell
Manufacturer:	TAPI
Model #:	T803
Serial #:	128

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	11:36 - 11:56	373.4	11.99
2	12:10 - 12:30	373.2	12.00
3	12:42 - 13:02	373.3	11.99
4	13:20 - 13:40	372.6	12.00
5	13:55 - 14:15	372.8	11.98
6	14:27 - 14:47	372.7	11.99
7	15:01 - 15:21	372.7	11.99
8	15:36 - 15:56	372.8	12.00
9	16:08 - 16:28	372.6	12.00
10	16:46 - 17:06	372.2	12.01
11			
12			

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 11:36 AM thru 2/6/2020 11:56 AM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 11:36	2.60	1.72	0.0063	17.05	0.00	0.00	0.00	1.45	5.41
2/6 11:37	2.58	1.71	0.0063	17.15	0.00	0.00	0.00	1.45	5.44
2/6 11:38	2.57	1.70	0.0063	17.03	0.00	0.00	0.00	1.45	5.41
2/6 11:39	2.58	1.71	0.0063	17.09	0.00	0.00	0.00	1.45	5.43
2/6 11:40	2.58	1.71	0.0063	17.10	0.00	0.00	0.00	1.46	5.43
2/6 11:41	2.57	1.70	0.0063	17.06	0.00	0.00	0.00	1.47	5.42
2/6 11:42	2.56	1.69	0.0062	16.84	0.00	0.00	0.00	1.46	5.44
2/6 11:43	2.56	1.69	0.0062	16.90	0.00	0.00	0.00	1.45	5.45
2/6 11:44	2.57	1.70	0.0063	17.10	0.00	0.00	0.00	1.45	5.43
2/6 11:45	2.58	1.71	0.0063	17.09	0.00	0.00	0.00	1.45	5.43
2/6 11:46	2.58	1.71	0.0063	17.03	0.00	0.00	0.00	1.45	5.41
2/6 11:47	2.58	1.71	0.0063	17.09	0.00	0.00	0.00	1.47	5.43
2/6 11:48	2.56	1.70	0.0063	17.08	0.00	0.00	0.00	1.47	5.43
2/6 11:49	2.53	1.68	0.0062	16.76	0.00	0.00	0.00	1.47	5.41
2/6 11:50	2.52	1.67	0.0062	16.78	0.00	0.00	0.00	1.47	5.41
2/6 11:51	2.54	1.68	0.0062	16.86	0.00	0.00	0.00	1.47	5.44
2/6 11:52	2.56	1.69	0.0062	16.85	0.00	0.00	0.00	1.46	5.44
2/6 11:53	2.58	1.71	0.0063	17.00	0.00	0.00	0.00	1.46	5.40
2/6 11:54	2.59	1.71	0.0063	17.05	0.00	0.00	0.00	1.46	5.41
2/6 11:55	2.59	1.72	0.0063	17.04	0.00	0.00	0.00	1.47	5.41
2/6 11:56	2.59	1.72	0.0063	17.03	0.00	0.00	0.00	1.47	5.41
Average (all)	2.57	1.70	0.0063	17.00	0.00	0.00	0.00	1.46	5.42
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.52	1.67	0.0062	16.76	0.00	0.00	0.00	1.45	5.40
Maximum (all)	2.60	1.72	0.0063	17.15	0.00	0.00	0.00	1.47	5.45
Average (valid values only)	2.57	1.70	0.0063	17.00	0.00	0.00	0.00	1.46	5.42
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 11:36 AM thru 2/6/2020 11:56 AM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 11:36	11.97	27.4	4017.2	25896.0	233.5	140.5	374.0
2/6 11:37	11.98	27.6	3987.5	26049.6	233.4	140.3	373.7
2/6 11:38	11.99	27.4	3970.8	25868.2	233.5	140.1	373.6
2/6 11:39	12.00	27.5	3962.6	25949.0	233.5	140.0	373.5
2/6 11:40	12.00	27.5	3987.9	25964.1	233.4	140.0	373.4
2/6 11:41	12.00	27.4	4063.0	25923.5	233.5	139.9	373.4
2/6 11:42	11.98	27.5	4050.6	26001.8	233.4	140.0	373.4
2/6 11:43	11.98	27.6	4028.2	26074.0	233.5	140.0	373.5
2/6 11:44	11.99	27.5	4006.0	25975.0	233.4	140.1	373.5
2/6 11:45	12.00	27.5	3984.5	25962.1	233.2	139.8	373.0
2/6 11:46	12.00	27.4	3969.8	25867.6	233.2	139.4	372.6
2/6 11:47	12.01	27.5	3968.2	25952.3	233.2	139.8	373.0
2/6 11:48	12.01	27.5	3959.6	25947.2	233.5	139.8	373.3
2/6 11:49	12.01	27.4	3956.3	25859.5	233.3	139.8	373.1
2/6 11:50	12.01	27.4	4001.8	25886.8	233.3	139.7	373.0
2/6 11:51	12.00	27.5	4087.0	26023.6	233.1	139.8	372.9
2/6 11:52	11.98	27.5	4062.8	26009.1	233.3	140.1	373.4
2/6 11:53	11.98	27.3	4030.6	25818.4	233.1	140.3	373.4
2/6 11:54	11.98	27.4	4015.4	25894.9	233.3	140.5	373.8
2/6 11:55	11.99	27.4	3994.3	25882.3	233.4	140.3	373.7
2/6 11:56	12.00	27.4	3964.0	25864.1	233.1	140.1	373.2
Average (all)	11.99	27.5	4003.2	25936.6	233.3	140.0	373.4
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.97	27.3	3956.3	25818.4	233.1	139.4	372.6
Maximum (all)	12.01	27.6	4087.0	26074.0	233.5	140.5	374.0
Average (valid values only)	11.99	27.5	4003.2	25936.6	233.3	140.0	373.4
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 12:10 PM thru 2/6/2020 12:30 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 12:10	2.75	1.83	0.0067	18.14	0.00	0.00	0.00	1.41	5.15
2/6 12:11	2.87	1.91	0.0070	18.92	0.00	0.00	0.00	1.40	5.13
2/6 12:12	2.93	1.94	0.0072	19.60	0.00	0.00	0.00	1.38	5.17
2/6 12:13	2.95	1.95	0.0072	19.56	0.00	0.00	0.00	1.34	4.89
2/6 12:14	2.93	1.93	0.0071	19.28	0.00	0.00	0.00	1.30	4.89
2/6 12:15	2.90	1.91	0.0070	19.05	0.00	0.00	0.00	1.27	4.63
2/6 12:16	2.87	1.89	0.0070	18.97	0.00	0.00	0.00	1.24	4.60
2/6 12:17	2.82	1.86	0.0069	18.62	0.00	0.00	0.00	1.23	4.59
2/6 12:18	2.79	1.85	0.0068	18.40	0.00	0.00	0.00	1.23	4.60
2/6 12:19	2.76	1.83	0.0067	18.11	0.00	0.00	0.00	1.23	4.59
2/6 12:20	2.72	1.81	0.0067	18.16	0.00	0.00	0.00	1.25	4.61
2/6 12:21	2.69	1.78	0.0066	17.89	0.00	0.00	0.00	1.25	4.61
2/6 12:22	2.68	1.78	0.0066	17.77	0.00	0.00	0.00	1.25	4.58
2/6 12:23	2.66	1.77	0.0065	17.61	0.00	0.00	0.00	1.27	4.61
2/6 12:24	2.63	1.75	0.0064	17.28	0.00	0.00	0.00	1.30	4.86
2/6 12:25	2.62	1.74	0.0064	17.28	0.00	0.00	0.00	1.30	4.86
2/6 12:26	2.63	1.75	0.0064	17.31	0.00	0.00	0.00	1.31	4.87
2/6 12:27	2.64	1.75	0.0065	17.60	0.00	0.00	0.00	1.32	4.88
2/6 12:28	2.64	1.75	0.0064	17.38	0.00	0.00	0.00	1.33	4.88
2/6 12:29	2.64	1.75	0.0064	17.32	0.00	0.00	0.00	1.34	4.87
2/6 12:30	2.65	1.76	0.0065	17.58	0.00	0.00	0.00	1.35	4.87
Average (all)	2.75	1.82	0.0067	18.18	0.00	0.00	0.00	1.30	4.80
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.62	1.74	0.0064	17.28	0.00	0.00	0.00	1.23	4.58
Maximum (all)	2.95	1.95	0.0072	19.60	0.00	0.00	0.00	1.41	5.17
Average (valid values only)	2.75	1.82	0.0067	18.18	0.00	0.00	0.00	1.30	4.80
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 12:10 PM thru 2/6/2020 12:30 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 12:10	12.01	27.5	3903.4	25913.4	233.4	139.8	373.2
2/6 12:11	12.02	27.4	3971.7	25868.7	233.4	139.8	373.2
2/6 12:12	12.00	27.5	4113.4	26039.4	233.4	139.8	373.2
2/6 12:13	11.97	27.4	4189.3	25999.3	233.2	140.0	373.2
2/6 12:14	11.95	27.4	4166.8	25985.8	233.4	140.4	373.8
2/6 12:15	11.95	27.5	4122.3	26044.8	233.2	140.8	374.0
2/6 12:16	11.96	27.4	4080.4	25933.9	233.2	140.3	373.5
2/6 12:17	11.97	27.3	4039.6	25823.8	232.9	140.8	373.7
2/6 12:18	11.99	27.4	4007.9	25890.4	233.0	140.6	373.6
2/6 12:19	12.00	27.4	3976.2	25871.4	233.0	140.4	373.4
2/6 12:20	12.01	27.5	3955.5	25944.7	233.0	140.2	373.2
2/6 12:21	12.00	27.5	3945.2	25938.5	233.3	140.1	373.4
2/6 12:22	12.01	27.3	3936.6	25762.0	233.1	140.0	373.1
2/6 12:23	12.01	27.5	3921.5	25924.3	233.1	139.9	373.0
2/6 12:24	12.02	27.4	3914.6	25834.5	233.2	139.9	373.1
2/6 12:25	12.02	27.4	3912.0	25832.9	233.1	139.7	372.8
2/6 12:26	12.02	27.4	3990.8	25880.2	233.1	139.3	372.4
2/6 12:27	12.01	27.4	4042.6	25911.3	232.9	139.7	372.6
2/6 12:28	11.99	27.5	4026.0	25987.0	232.8	139.9	372.7
2/6 12:29	11.99	27.4	4013.7	25893.9	232.9	140.0	372.9
2/6 12:30	12.00	27.4	3988.8	25879.0	232.9	140.2	373.1
Average (all)	12.00	27.4	4010.4	25912.4	233.1	140.1	373.2
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.95	27.3	3903.4	25762.0	232.8	139.3	372.4
Maximum (all)	12.02	27.5	4189.3	26044.8	233.4	140.8	374.0
Average (valid values only)	12.00	27.4	4010.4	25912.4	233.1	140.1	373.2
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 12:42 PM thru 2/6/2020 1:02 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 12:42	2.59	1.72	0.0063	17.08	0.00	0.00	0.00	1.42	5.15
2/6 12:43	2.58	1.71	0.0063	17.13	0.00	0.00	0.00	1.43	5.17
2/6 12:44	2.58	1.71	0.0063	17.02	0.00	0.00	0.00	1.44	5.41
2/6 12:45	2.58	1.71	0.0063	16.97	0.00	0.00	0.00	1.44	5.38
2/6 12:46	2.58	1.71	0.0063	17.02	0.00	0.00	0.00	1.44	5.40
2/6 12:47	2.57	1.71	0.0063	17.06	0.00	0.00	0.00	1.44	5.42
2/6 12:48	2.58	1.71	0.0063	17.11	0.00	0.00	0.00	1.44	5.43
2/6 12:49	2.59	1.71	0.0063	17.17	0.00	0.00	0.00	1.42	5.18
2/6 12:50	2.62	1.73	0.0064	17.37	0.00	0.00	0.00	1.42	5.15
2/6 12:51	2.64	1.74	0.0064	17.36	0.00	0.00	0.00	1.43	5.15
2/6 12:52	2.65	1.75	0.0065	17.61	0.00	0.00	0.00	1.44	5.42
2/6 12:53	2.63	1.74	0.0064	17.34	0.00	0.00	0.00	1.44	5.42
2/6 12:54	2.60	1.72	0.0063	17.00	0.00	0.00	0.00	1.45	5.39
2/6 12:55	2.56	1.70	0.0062	16.83	0.00	0.00	0.00	1.46	5.43
2/6 12:56	2.54	1.68	0.0062	16.77	0.00	0.00	0.00	1.45	5.41
2/6 12:57	2.54	1.68	0.0062	16.77	0.00	0.00	0.00	1.45	5.41
2/6 12:58	2.56	1.70	0.0063	17.09	0.00	0.00	0.00	1.46	5.43
2/6 12:59	2.56	1.70	0.0063	16.98	0.00	0.00	0.00	1.47	5.39
2/6 13:00	2.57	1.71	0.0063	17.06	0.00	0.00	0.00	1.47	5.42
2/6 13:01	2.58	1.71	0.0063	17.14	0.00	0.00	0.00	1.46	5.44
2/6 13:02	2.58	1.71	0.0063	17.07	0.00	0.00	0.00	1.46	5.42
Average (all)	2.58	1.71	0.0063	17.09	0.00	0.00	0.00	1.44	5.35
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.54	1.68	0.0062	16.77	0.00	0.00	0.00	1.42	5.15
Maximum (all)	2.65	1.75	0.0065	17.61	0.00	0.00	0.00	1.47	5.44
Average (valid values only)	2.58	1.71	0.0063	17.09	0.00	0.00	0.00	1.44	5.35
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 12:42 PM thru 2/6/2020 1:02 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 12:42	12.01	27.5	3956.7	25945.4	233.1	139.9	373.0
2/6 12:43	12.01	27.6	3959.4	26032.7	233.0	140.0	373.0
2/6 12:44	12.01	27.4	3960.6	25862.1	233.1	140.0	373.1
2/6 12:45	12.01	27.3	3945.2	25767.1	233.2	140.0	373.2
2/6 12:46	12.01	27.4	3946.0	25853.3	233.0	139.8	372.8
2/6 12:47	12.01	27.4	4052.0	25916.9	233.0	139.7	372.7
2/6 12:48	11.99	27.4	4166.3	25985.5	233.2	140.0	373.2
2/6 12:49	11.96	27.5	4166.3	26071.2	233.0	139.9	372.9
2/6 12:50	11.96	27.4	4135.6	25967.1	232.9	140.7	373.6
2/6 12:51	11.96	27.4	4104.8	25948.6	233.2	141.0	374.2
2/6 12:52	11.97	27.4	4074.4	25930.3	233.1	141.0	374.1
2/6 12:53	11.98	27.4	4051.3	25916.5	233.0	140.8	373.8
2/6 12:54	11.98	27.3	4018.9	25811.3	233.0	140.6	373.6
2/6 12:55	11.99	27.5	4000.1	25971.5	233.0	140.6	373.6
2/6 12:56	11.99	27.4	3993.8	25882.0	232.8	140.5	373.3
2/6 12:57	12.00	27.4	3983.9	25876.0	233.1	140.5	373.6
2/6 12:58	12.00	27.5	3970.8	25953.9	233.0	140.3	373.3
2/6 12:59	12.01	27.3	3965.2	25779.1	233.1	140.1	373.2
2/6 13:00	12.01	27.4	4049.9	25915.6	233.0	140.0	373.0
2/6 13:01	11.99	27.5	4097.6	26030.0	233.1	140.0	373.1
2/6 13:02	11.98	27.4	4086.9	25937.8	233.0	140.3	373.3
Average (all)	11.99	27.4	4032.7	25921.6	233.0	140.3	373.3
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.96	27.3	3945.2	25767.1	232.8	139.7	372.7
Maximum (all)	12.01	27.6	4166.3	26071.2	233.2	141.0	374.2
Average (valid values only)	11.99	27.4	4032.7	25921.6	233.0	140.3	373.3
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 1:20 PM thru 2/6/2020 1:40 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 13:20	2.56	1.70	0.0063	17.04	0.00	0.00	0.00	1.47	5.41
2/6 13:21	2.56	1.70	0.0063	17.09	0.00	0.00	0.00	1.47	5.43
2/6 13:22	2.56	1.69	0.0062	16.82	0.00	0.00	0.00	1.46	5.43
2/6 13:23	2.57	1.70	0.0063	17.07	0.00	0.00	0.00	1.46	5.42
2/6 13:24	2.57	1.70	0.0063	17.12	0.00	0.00	0.00	1.46	5.44
2/6 13:25	2.58	1.71	0.0063	17.06	0.00	0.00	0.00	1.47	5.42
2/6 13:26	2.58	1.71	0.0063	17.05	0.00	0.00	0.00	1.47	5.42
2/6 13:27	2.58	1.71	0.0063	17.11	0.00	0.00	0.00	1.47	5.43
2/6 13:28	2.58	1.71	0.0063	17.10	0.00	0.00	0.00	1.47	5.43
2/6 13:29	2.58	1.71	0.0063	17.04	0.00	0.00	0.00	1.48	5.41
2/6 13:30	2.58	1.71	0.0063	17.09	0.00	0.00	0.00	1.48	5.43
2/6 13:31	2.56	1.70	0.0063	17.03	0.00	0.00	0.00	1.48	5.41
2/6 13:32	2.54	1.68	0.0062	16.70	0.00	0.00	0.00	1.48	5.39
2/6 13:33	2.53	1.68	0.0062	16.75	0.00	0.00	0.00	1.48	5.40
2/6 13:34	2.52	1.67	0.0062	16.79	0.00	0.00	0.00	1.48	5.42
2/6 13:35	2.54	1.69	0.0062	16.74	0.00	0.00	0.00	1.48	5.40
2/6 13:36	2.55	1.69	0.0062	16.68	0.00	0.00	0.00	1.48	5.38
2/6 13:37	2.56	1.70	0.0063	16.99	0.00	0.00	0.00	1.49	5.39
2/6 13:38	2.55	1.69	0.0062	16.75	0.00	0.00	0.00	1.49	5.40
2/6 13:39	2.56	1.69	0.0062	16.81	0.00	0.00	0.00	1.48	5.42
2/6 13:40	2.58	1.70	0.0063	17.07	0.00	0.00	0.00	1.47	5.42
Average (all)	2.56	1.70	0.0063	16.95	0.00	0.00	0.00	1.47	5.41
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.52	1.67	0.0062	16.68	0.00	0.00	0.00	1.46	5.38
Maximum (all)	2.58	1.71	0.0063	17.12	0.00	0.00	0.00	1.49	5.44
Average (valid values only)	2.56	1.70	0.0063	16.95	0.00	0.00	0.00	1.47	5.41
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 1:20 PM thru 2/6/2020 1:40 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 13:20	12.01	27.4	4010.2	25891.8	232.8	139.8	372.6
2/6 13:21	12.00	27.4	4122.8	25959.4	232.6	139.8	372.4
2/6 13:22	11.98	27.4	4109.4	25951.3	233.0	139.6	372.6
2/6 13:23	11.97	27.4	4082.8	25935.4	232.8	140.2	373.0
2/6 13:24	11.98	27.5	4061.1	26008.1	232.7	140.4	373.1
2/6 13:25	11.98	27.4	4044.2	25912.2	232.8	140.4	373.2
2/6 13:26	11.99	27.4	4034.1	25906.2	232.7	140.3	373.0
2/6 13:27	11.99	27.5	4023.5	25985.5	232.8	140.3	373.1
2/6 13:28	11.99	27.5	4009.7	25977.2	232.8	140.3	373.1
2/6 13:29	12.00	27.4	3995.3	25882.9	232.8	140.3	373.1
2/6 13:30	12.00	27.5	3981.2	25960.1	232.7	140.1	372.8
2/6 13:31	12.00	27.4	3970.9	25868.2	232.7	139.9	372.6
2/6 13:32	12.00	27.3	3958.6	25775.2	232.8	139.8	372.6
2/6 13:33	12.01	27.4	3931.8	25844.8	232.7	139.7	372.4
2/6 13:34	12.01	27.5	3913.7	25919.6	232.6	139.6	372.2
2/6 13:35	12.02	27.4	3904.6	25828.5	232.8	139.4	372.2
2/6 13:36	12.02	27.3	3904.8	25742.9	232.9	139.3	372.2
2/6 13:37	12.02	27.3	3994.7	25796.8	232.7	139.3	372.0
2/6 13:38	12.00	27.3	4099.2	25859.5	232.6	139.5	372.1
2/6 13:39	11.98	27.4	4098.1	25944.6	232.7	139.8	372.5
2/6 13:40	11.97	27.4	4079.9	25933.6	232.6	140.1	372.7
Average (all)	12.00	27.4	4015.7	25899.2	232.7	139.9	372.6
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.97	27.3	3904.6	25742.9	232.6	139.3	372.0
Maximum (all)	12.02	27.5	4122.8	26008.1	233.0	140.4	373.2
Average (valid values only)	12.00	27.4	4015.7	25899.2	232.7	139.9	372.6
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 1:55 PM thru 2/6/2020 2:15 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 13:55	2.53	1.68	0.0062	16.76	0.00	0.00	0.00	1.47	5.41
2/6 13:56	2.54	1.68	0.0062	16.69	0.00	0.00	0.00	1.48	5.38
2/6 13:57	2.56	1.69	0.0062	16.84	0.00	0.00	0.00	1.48	5.43
2/6 13:58	2.58	1.70	0.0063	17.10	0.00	0.00	0.00	1.46	5.43
2/6 13:59	2.60	1.72	0.0063	17.03	0.00	0.00	0.00	1.47	5.41
2/6 14:00	2.61	1.72	0.0064	17.34	0.00	0.00	0.00	1.47	5.42
2/6 14:01	2.61	1.72	0.0064	17.33	0.00	0.00	0.00	1.47	5.42
2/6 14:02	2.60	1.72	0.0063	16.99	0.00	0.00	0.00	1.47	5.39
2/6 14:03	2.58	1.71	0.0063	17.03	0.00	0.00	0.00	1.47	5.41
2/6 14:04	2.56	1.70	0.0063	17.02	0.00	0.00	0.00	1.47	5.41
2/6 14:05	2.54	1.69	0.0062	16.75	0.00	0.00	0.00	1.48	5.40
2/6 14:06	2.53	1.68	0.0062	16.76	0.00	0.00	0.00	1.47	5.41
2/6 14:07	2.52	1.67	0.0062	16.75	0.00	0.00	0.00	1.48	5.40
2/6 14:08	2.54	1.68	0.0062	16.82	0.00	0.00	0.00	1.47	5.43
2/6 14:09	2.56	1.69	0.0062	16.81	0.00	0.00	0.00	1.47	5.42
2/6 14:10	2.62	1.73	0.0064	17.28	0.00	0.00	0.00	1.45	5.40
2/6 14:11	2.71	1.79	0.0066	17.88	0.00	0.00	0.00	1.42	5.14
2/6 14:12	2.84	1.88	0.0069	18.67	0.00	0.00	0.00	1.40	5.14
2/6 14:13	2.92	1.93	0.0071	19.21	0.00	0.00	0.00	1.40	5.14
2/6 14:14	2.94	1.95	0.0072	19.47	0.00	0.00	0.00	1.38	5.14
2/6 14:15	2.90	1.92	0.0071	19.13	0.00	0.00	0.00	1.36	5.12
Average (all)	2.64	1.75	0.0064	17.41	0.00	0.00	0.00	1.45	5.35
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.52	1.67	0.0062	16.69	0.00	0.00	0.00	1.36	5.12
Maximum (all)	2.94	1.95	0.0072	19.47	0.00	0.00	0.00	1.48	5.43
Average (valid values only)	2.64	1.75	0.0064	17.41	0.00	0.00	0.00	1.45	5.35
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 1:55 PM thru 2/6/2020 2:15 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 13:55	12.01	27.4	3953.1	25857.6	232.8	139.6	372.4
2/6 13:56	12.00	27.2	4072.9	25758.0	232.6	139.6	372.2
2/6 13:57	11.98	27.4	4173.2	25989.6	232.7	139.8	372.5
2/6 13:58	11.95	27.4	4155.3	25978.9	232.5	140.2	372.7
2/6 13:59	11.96	27.3	4112.3	25867.4	232.6	140.6	373.2
2/6 14:00	11.97	27.4	4073.7	25929.9	232.5	140.5	373.0
2/6 14:01	11.97	27.4	4039.2	25909.2	232.7	140.4	373.1
2/6 14:02	11.98	27.3	4007.0	25804.2	232.7	140.3	373.0
2/6 14:03	11.99	27.4	3980.2	25873.8	232.6	140.2	372.8
2/6 14:04	12.00	27.4	3952.7	25857.3	232.6	140.1	372.7
2/6 14:05	12.01	27.4	3941.6	25850.7	232.7	139.9	372.6
2/6 14:06	12.01	27.4	3969.0	25867.1	232.7	139.8	372.5
2/6 14:07	12.00	27.3	4093.9	25856.3	232.7	139.8	372.5
2/6 14:08	11.97	27.4	4114.8	25954.6	232.7	140.0	372.7
2/6 14:09	11.96	27.4	4090.7	25940.1	232.7	140.3	373.0
2/6 14:10	11.97	27.3	4067.6	25840.6	232.8	140.5	373.3
2/6 14:11	11.98	27.4	4049.7	25915.5	232.7	140.4	373.1
2/6 14:12	11.98	27.4	4026.6	25901.7	232.7	140.3	373.0
2/6 14:13	11.98	27.4	4008.9	25891.0	232.8	140.2	373.0
2/6 14:14	11.99	27.4	3992.4	25881.1	232.6	140.2	372.8
2/6 14:15	11.99	27.3	3983.5	25790.1	232.5	140.2	372.7
Average (all)	11.98	27.4	4040.9	25881.7	232.7	140.1	372.8
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.95	27.2	3941.6	25758.0	232.5	139.6	372.2
Maximum (all)	12.01	27.4	4173.2	25989.6	232.8	140.6	373.3
Average (valid values only)	11.98	27.4	4040.9	25881.7	232.7	140.1	372.8
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 2:27 PM thru 2/6/2020 2:47 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 14:27	2.75	1.82	0.0067	18.11	0.00	0.00	0.00	1.15	4.33
2/6 14:28	2.73	1.81	0.0067	18.11	0.00	0.00	0.00	1.17	4.33
2/6 14:29	2.71	1.80	0.0066	17.78	0.00	0.00	0.00	1.19	4.31
2/6 14:30	2.68	1.78	0.0066	17.85	0.00	0.00	0.00	1.20	4.33
2/6 14:31	2.66	1.76	0.0065	17.57	0.00	0.00	0.00	1.21	4.32
2/6 14:32	2.66	1.76	0.0065	17.65	0.00	0.00	0.00	1.23	4.61
2/6 14:33	2.67	1.76	0.0065	17.58	0.00	0.00	0.00	1.23	4.60
2/6 14:34	2.68	1.77	0.0065	17.57	0.00	0.00	0.00	1.26	4.60
2/6 14:35	2.68	1.77	0.0065	17.62	0.00	0.00	0.00	1.28	4.61
2/6 14:36	2.67	1.77	0.0065	17.48	0.00	0.00	0.00	1.28	4.57
2/6 14:37	2.66	1.76	0.0065	17.52	0.00	0.00	0.00	1.30	4.85
2/6 14:38	2.64	1.75	0.0064	17.29	0.00	0.00	0.00	1.31	4.87
2/6 14:39	2.62	1.74	0.0064	17.40	0.00	0.00	0.00	1.32	4.89
2/6 14:40	2.62	1.74	0.0064	17.22	0.00	0.00	0.00	1.33	4.84
2/6 14:41	2.68	1.78	0.0066	17.76	0.00	0.00	0.00	1.31	4.84
2/6 14:42	2.78	1.84	0.0068	18.37	0.00	0.00	0.00	1.30	4.87
2/6 14:43	2.87	1.90	0.0070	18.95	0.00	0.00	0.00	1.30	4.88
2/6 14:44	2.92	1.93	0.0071	19.23	0.00	0.00	0.00	1.28	4.60
2/6 14:45	2.94	1.94	0.0072	19.57	0.00	0.00	0.00	1.26	4.62
2/6 14:46	2.91	1.92	0.0071	19.23	0.00	0.00	0.00	1.24	4.60
2/6 14:47	2.86	1.89	0.0070	18.94	0.00	0.00	0.00	1.22	4.60
Average (all)	2.73	1.81	0.0067	18.04	0.00	0.00	0.00	1.26	4.62
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.62	1.74	0.0064	17.22	0.00	0.00	0.00	1.15	4.31
Maximum (all)	2.94	1.94	0.0072	19.57	0.00	0.00	0.00	1.33	4.89
Average (valid values only)	2.73	1.81	0.0067	18.04	0.00	0.00	0.00	1.26	4.62
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 2:27 PM thru 2/6/2020 2:47 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 14:27	12.00	27.4	3981.9	25874.8	232.6	140.1	372.7
2/6 14:28	12.00	27.4	3970.9	25868.2	232.7	139.9	372.6
2/6 14:29	12.01	27.3	3959.6	25775.8	232.6	140.0	372.6
2/6 14:30	12.01	27.4	3993.8	25882.0	232.6	139.9	372.5
2/6 14:31	12.00	27.3	4123.8	25874.3	232.6	140.2	372.8
2/6 14:32	11.97	27.4	4160.5	25982.0	232.4	140.3	372.7
2/6 14:33	11.96	27.3	4145.6	25887.4	232.6	140.7	373.3
2/6 14:34	11.96	27.3	4120.9	25872.5	232.7	140.8	373.5
2/6 14:35	11.97	27.4	4085.6	25937.1	232.7	140.7	373.4
2/6 14:36	11.98	27.2	4035.6	25735.7	232.5	140.7	373.2
2/6 14:37	11.99	27.3	3987.6	25792.6	232.5	140.4	372.9
2/6 14:38	12.00	27.4	3943.6	25851.9	232.6	140.2	372.8
2/6 14:39	12.01	27.6	3927.9	26013.8	232.6	140.0	372.6
2/6 14:40	12.01	27.3	3911.5	25746.9	232.4	139.7	372.1
2/6 14:41	12.02	27.3	3905.3	25743.2	232.6	139.5	372.1
2/6 14:42	12.01	27.4	3944.0	25852.1	232.5	139.4	371.9
2/6 14:43	12.01	27.4	4040.5	25910.0	232.5	139.5	372.0
2/6 14:44	11.99	27.4	4049.0	25915.1	232.6	139.7	372.3
2/6 14:45	11.98	27.5	4063.2	26009.3	232.7	140.0	372.7
2/6 14:46	11.98	27.4	4041.4	25910.5	232.5	140.3	372.8
2/6 14:47	11.99	27.4	4014.0	25894.1	232.4	140.3	372.7
Average (all)	11.99	27.4	4019.3	25872.8	232.6	140.1	372.7
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.96	27.2	3905.3	25735.7	232.4	139.4	371.9
Maximum (all)	12.02	27.6	4160.5	26013.8	232.7	140.8	373.5
Average (valid values only)	11.99	27.4	4019.3	25872.8	232.6	140.1	372.7
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 3:01 PM thru 2/6/2020 3:21 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 15:01	2.63	1.75	0.0064	17.30	0.00	0.00	0.00	1.32	4.87
2/6 15:02	2.61	1.73	0.0064	17.24	0.00	0.00	0.00	1.33	4.85
2/6 15:03	2.60	1.73	0.0064	17.29	0.00	0.00	0.00	1.33	4.86
2/6 15:04	2.60	1.72	0.0063	17.10	0.00	0.00	0.00	1.33	4.89
2/6 15:05	2.64	1.74	0.0064	17.37	0.00	0.00	0.00	1.33	4.89
2/6 15:06	2.66	1.76	0.0065	17.62	0.00	0.00	0.00	1.35	4.88
2/6 15:07	2.65	1.75	0.0065	17.60	0.00	0.00	0.00	1.37	5.14
2/6 15:08	2.62	1.73	0.0064	17.20	0.00	0.00	0.00	1.38	5.11
2/6 15:09	2.60	1.72	0.0063	17.03	0.00	0.00	0.00	1.37	5.13
2/6 15:10	2.60	1.72	0.0063	17.02	0.00	0.00	0.00	1.38	5.13
2/6 15:11	2.58	1.71	0.0063	17.02	0.00	0.00	0.00	1.39	5.13
2/6 15:12	2.56	1.70	0.0063	17.03	0.00	0.00	0.00	1.40	5.13
2/6 15:13	2.56	1.70	0.0063	17.03	0.00	0.00	0.00	1.41	5.14
2/6 15:14	2.56	1.69	0.0062	16.79	0.00	0.00	0.00	1.41	5.15
2/6 15:15	2.58	1.70	0.0063	17.10	0.00	0.00	0.00	1.41	5.16
2/6 15:16	2.60	1.72	0.0063	17.09	0.00	0.00	0.00	1.40	5.15
2/6 15:17	2.61	1.72	0.0064	17.40	0.00	0.00	0.00	1.41	5.17
2/6 15:18	2.61	1.73	0.0064	17.33	0.00	0.00	0.00	1.41	5.14
2/6 15:19	2.59	1.72	0.0063	16.93	0.00	0.00	0.00	1.42	5.11
2/6 15:20	2.57	1.70	0.0063	17.03	0.00	0.00	0.00	1.43	5.13
2/6 15:21	2.55	1.69	0.0062	16.65	0.00	0.00	0.00	1.43	5.10
Average (all)	2.60	1.72	0.0063	17.15	0.00	0.00	0.00	1.38	5.06
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.55	1.69	0.0062	16.65	0.00	0.00	0.00	1.32	4.85
Maximum (all)	2.66	1.76	0.0065	17.62	0.00	0.00	0.00	1.43	5.17
Average (valid values only)	2.60	1.72	0.0063	17.15	0.00	0.00	0.00	1.38	5.06
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 3:01 PM thru 2/6/2020 3:21 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 15:01	12.01	27.4	3960.3	25861.9	232.5	139.7	372.2
2/6 15:02	12.01	27.3	3968.9	25781.3	232.3	139.8	372.1
2/6 15:03	12.01	27.3	4087.0	25852.2	232.5	139.7	372.2
2/6 15:04	11.98	27.4	4157.4	25980.1	232.4	139.9	372.3
2/6 15:05	11.96	27.4	4133.4	25965.7	232.5	140.3	372.8
2/6 15:06	11.96	27.4	4094.7	25942.5	232.6	140.6	373.2
2/6 15:07	11.97	27.4	4056.7	25919.7	232.3	140.5	372.8
2/6 15:08	11.98	27.2	4016.8	25724.4	232.4	140.4	372.8
2/6 15:09	11.99	27.4	3983.9	25876.0	232.7	140.2	372.9
2/6 15:10	12.00	27.4	3954.4	25858.3	232.5	140.1	372.6
2/6 15:11	12.01	27.4	3945.9	25853.2	232.6	139.9	372.5
2/6 15:12	12.01	27.4	3973.5	25869.8	232.6	139.9	372.5
2/6 15:13	12.01	27.3	4112.3	25867.4	232.4	139.8	372.2
2/6 15:14	11.98	27.3	4183.7	25910.2	232.6	140.1	372.7
2/6 15:15	11.96	27.4	4155.2	25978.8	232.5	140.5	373.0
2/6 15:16	11.96	27.4	4119.8	25957.6	232.5	140.7	373.2
2/6 15:17	11.97	27.5	4079.6	26019.2	232.5	140.7	373.2
2/6 15:18	11.98	27.4	4047.0	25913.9	232.5	140.6	373.1
2/6 15:19	11.99	27.2	4008.1	25719.2	232.4	140.6	373.0
2/6 15:20	12.00	27.4	3976.1	25871.4	232.5	140.4	372.9
2/6 15:21	12.00	27.2	3960.0	25690.3	232.4	140.3	372.7
Average (all)	11.99	27.4	4046.4	25876.8	232.5	140.2	372.7
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.96	27.2	3945.9	25690.3	232.3	139.7	372.1
Maximum (all)	12.01	27.5	4183.7	26019.2	232.7	140.7	373.2
Average (valid values only)	11.99	27.4	4046.4	25876.8	232.5	140.2	372.7
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 3:36 PM thru 2/6/2020 3:56 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 15:36	2.93	1.94	0.0072	19.45	0.00	0.00	0.00	1.35	4.87
2/6 15:37	2.87	1.90	0.0070	18.91	0.00	0.00	0.00	1.33	4.86
2/6 15:38	2.81	1.86	0.0069	18.70	0.00	0.00	0.00	1.29	4.61
2/6 15:39	2.77	1.84	0.0068	18.45	0.00	0.00	0.00	1.26	4.62
2/6 15:40	2.73	1.81	0.0067	18.15	0.00	0.00	0.00	1.25	4.60
2/6 15:41	2.72	1.80	0.0066	17.82	0.00	0.00	0.00	1.23	4.59
2/6 15:42	2.72	1.80	0.0066	17.87	0.00	0.00	0.00	1.22	4.60
2/6 15:43	2.73	1.81	0.0067	18.12	0.00	0.00	0.00	1.22	4.60
2/6 15:44	2.72	1.80	0.0066	17.86	0.00	0.00	0.00	1.23	4.60
2/6 15:45	2.72	1.80	0.0066	17.87	0.00	0.00	0.00	1.24	4.60
2/6 15:46	2.70	1.79	0.0066	17.91	0.00	0.00	0.00	1.26	4.61
2/6 15:47	2.67	1.76	0.0065	17.64	0.00	0.00	0.00	1.28	4.61
2/6 15:48	2.66	1.76	0.0065	17.56	0.00	0.00	0.00	1.28	4.60
2/6 15:49	2.65	1.75	0.0065	17.61	0.00	0.00	0.00	1.29	4.88
2/6 15:50	2.65	1.75	0.0065	17.59	0.00	0.00	0.00	1.30	4.87
2/6 15:51	2.64	1.75	0.0064	17.25	0.00	0.00	0.00	1.32	4.85
2/6 15:52	2.64	1.75	0.0065	17.55	0.00	0.00	0.00	1.32	4.86
2/6 15:53	2.63	1.75	0.0064	17.28	0.00	0.00	0.00	1.34	4.86
2/6 15:54	2.61	1.73	0.0064	17.21	0.00	0.00	0.00	1.34	4.84
2/6 15:55	2.59	1.72	0.0063	16.99	0.00	0.00	0.00	1.35	4.86
2/6 15:56	2.59	1.72	0.0063	17.02	0.00	0.00	0.00	1.35	4.87
Average (all)	2.70	1.79	0.0066	17.85	0.00	0.00	0.00	1.29	4.73
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.59	1.72	0.0063	16.99	0.00	0.00	0.00	1.22	4.59
Maximum (all)	2.93	1.94	0.0072	19.45	0.00	0.00	0.00	1.35	4.88
Average (valid values only)	2.70	1.79	0.0066	17.85	0.00	0.00	0.00	1.29	4.73
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 3:36 PM thru 2/6/2020 3:56 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 15:36	12.00	27.4	3948.0	25854.5	232.7	140.0	372.7
2/6 15:37	12.01	27.4	3932.2	25845.0	232.7	139.9	372.6
2/6 15:38	12.01	27.5	3922.5	25924.9	232.6	139.8	372.4
2/6 15:39	12.01	27.5	3994.7	25968.2	232.6	139.8	372.4
2/6 15:40	12.00	27.4	4073.5	25929.8	232.6	139.8	372.4
2/6 15:41	11.97	27.3	4058.4	25835.0	232.7	140.1	372.8
2/6 15:42	11.98	27.4	4032.5	25905.2	232.5	140.3	372.8
2/6 15:43	11.98	27.4	4008.6	25890.9	232.7	140.4	373.1
2/6 15:44	11.99	27.4	4002.7	25887.3	232.7	140.2	372.9
2/6 15:45	11.99	27.4	4024.9	25900.6	232.6	140.2	372.8
2/6 15:46	11.99	27.4	4139.3	25969.3	232.5	140.3	372.8
2/6 15:47	11.97	27.4	4144.2	25972.2	232.7	140.5	373.2
2/6 15:48	11.96	27.3	4103.5	25862.1	232.5	140.8	373.3
2/6 15:49	11.98	27.4	4063.3	25923.7	232.5	141.0	373.5
2/6 15:50	11.98	27.4	4019.4	25897.3	232.6	141.0	373.6
2/6 15:51	11.99	27.3	3977.6	25786.6	232.7	140.6	373.3
2/6 15:52	12.01	27.4	3936.8	25847.8	232.6	140.3	372.9
2/6 15:53	12.02	27.4	3906.2	25829.4	232.7	140.1	372.8
2/6 15:54	12.02	27.3	3885.2	25731.1	232.4	139.8	372.2
2/6 15:55	12.02	27.4	3882.6	25815.3	232.6	139.7	372.3
2/6 15:56	12.03	27.4	3948.0	25854.5	232.7	139.7	372.4
Average (all)	12.00	27.4	4000.2	25877.7	232.6	140.2	372.8
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.96	27.3	3882.6	25731.1	232.4	139.7	372.2
Maximum (all)	12.03	27.5	4144.2	25972.2	232.7	141.0	373.6
Average (valid values only)	12.00	27.4	4000.2	25877.7	232.6	140.2	372.8
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 4:08 PM thru 2/6/2020 4:28 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 16:08	2.54	1.69	0.0062	16.73	0.00	0.00	0.00	1.43	5.12
2/6 16:09	2.54	1.69	0.0062	16.73	0.00	0.00	0.00	1.43	5.12
2/6 16:10	2.54	1.69	0.0062	16.73	0.00	0.00	0.00	1.42	5.12
2/6 16:11	2.54	1.69	0.0062	16.78	0.00	0.00	0.00	1.42	5.14
2/6 16:12	2.56	1.70	0.0063	17.05	0.00	0.00	0.00	1.42	5.14
2/6 16:13	2.61	1.72	0.0064	17.41	0.00	0.00	0.00	1.40	5.16
2/6 16:14	2.65	1.74	0.0064	17.34	0.00	0.00	0.00	1.40	5.15
2/6 16:15	2.67	1.76	0.0065	17.58	0.00	0.00	0.00	1.42	5.14
2/6 16:16	2.66	1.76	0.0065	17.57	0.00	0.00	0.00	1.43	5.14
2/6 16:17	2.64	1.74	0.0064	17.34	0.00	0.00	0.00	1.42	5.14
2/6 16:18	2.62	1.73	0.0064	17.32	0.00	0.00	0.00	1.42	5.14
2/6 16:19	2.59	1.72	0.0063	17.03	0.00	0.00	0.00	1.43	5.13
2/6 16:20	2.56	1.70	0.0063	17.02	0.00	0.00	0.00	1.43	5.13
2/6 16:21	2.55	1.69	0.0062	16.75	0.00	0.00	0.00	1.43	5.13
2/6 16:22	2.55	1.69	0.0062	16.74	0.00	0.00	0.00	1.43	5.13
2/6 16:23	2.55	1.69	0.0062	16.68	0.00	0.00	0.00	1.44	5.38
2/6 16:24	2.53	1.68	0.0062	16.72	0.00	0.00	0.00	1.45	5.39
2/6 16:25	2.51	1.66	0.0061	16.46	0.00	0.00	0.00	1.45	5.39
2/6 16:26	2.52	1.67	0.0062	16.78	0.00	0.00	0.00	1.44	5.41
2/6 16:27	2.54	1.68	0.0062	16.83	0.00	0.00	0.00	1.43	5.16
2/6 16:28	2.58	1.71	0.0063	17.04	0.00	0.00	0.00	1.44	5.41
Average (all)	2.57	1.70	0.0063	16.98	0.00	0.00	0.00	1.43	5.20
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.51	1.66	0.0061	16.46	0.00	0.00	0.00	1.40	5.12
Maximum (all)	2.67	1.76	0.0065	17.58	0.00	0.00	0.00	1.45	5.41
Average (valid values only)	2.57	1.70	0.0063	16.98	0.00	0.00	0.00	1.43	5.20
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 4:08 PM thru 2/6/2020 4:28 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 16:08	12.02	27.4	3888.3	25818.7	232.6	139.8	372.4
2/6 16:09	12.03	27.4	3874.2	25810.2	232.5	139.6	372.1
2/6 16:10	12.03	27.4	3882.1	25815.0	232.5	139.5	372.0
2/6 16:11	12.03	27.4	4009.0	25891.1	232.4	139.4	371.8
2/6 16:12	12.00	27.3	4151.0	25890.6	232.4	139.6	372.0
2/6 16:13	11.97	27.4	4232.4	26025.1	232.6	140.1	372.7
2/6 16:14	11.94	27.3	4202.8	25921.7	232.5	140.7	373.2
2/6 16:15	11.95	27.3	4154.5	25892.7	232.6	141.1	373.7
2/6 16:16	11.96	27.3	4111.4	25866.8	232.5	141.0	373.5
2/6 16:17	11.97	27.4	4064.4	25924.3	232.7	140.9	373.6
2/6 16:18	11.98	27.4	4022.6	25899.3	232.5	140.7	373.2
2/6 16:19	11.99	27.4	3978.3	25872.7	232.6	140.4	373.0
2/6 16:20	12.00	27.4	3953.3	25857.7	232.6	140.4	373.0
2/6 16:21	12.01	27.4	3930.5	25844.0	232.4	140.3	372.7
2/6 16:22	12.01	27.4	3917.5	25836.2	232.4	140.1	372.5
2/6 16:23	12.02	27.3	3921.6	25753.0	232.3	139.9	372.2
2/6 16:24	12.02	27.3	4001.1	25800.7	232.5	139.7	372.2
2/6 16:25	12.00	27.3	4018.2	25810.9	232.6	139.7	372.3
2/6 16:26	12.00	27.4	4013.6	25893.9	232.6	139.8	372.4
2/6 16:27	11.99	27.5	4011.9	25978.5	232.7	140.0	372.7
2/6 16:28	11.99	27.4	4006.3	25889.5	232.5	139.9	372.4
Average (all)	12.00	27.4	4016.4	25871.1	232.5	140.1	372.6
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.94	27.3	3874.2	25753.0	232.3	139.4	371.8
Maximum (all)	12.03	27.5	4232.4	26025.1	232.7	141.1	373.7
Average (valid values only)	12.00	27.4	4016.4	25871.1	232.5	140.1	372.6
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 4:46 PM thru 2/6/2020 5:06 PM

Timestamp	(Turbine 1) 75-NOx ppm 1-Min	(Turbine 1) NOx ppm @15% O2 1-Min	(Turbine 1) 75-NOx lb/mmBtu 1-Min	(Turbine 1) NOx lb/hr 1-Min	(Turbine 1) CO ppm Crnt-Hr	(Turbine 1) CO ppm @15% O2 1-Min	(Turbine 1) CO lb/hr 1-Min	(Turbine 1) NH3 Slip ppm @15% O2 1-Min	(Turbine 1) NH3 Slip lb/hr 1-Min
2/6 16:46	2.39	1.58	0.0058	15.68	0.00	0.00	0.00	1.50	5.41
2/6 16:47	2.32	1.54	0.0057	15.42	0.00	0.00	0.00	1.50	5.41
2/6 16:48	2.28	1.51	0.0056	15.14	0.00	0.00	0.00	1.52	5.67
2/6 16:49	2.26	1.50	0.0055	14.87	0.00	0.00	0.00	1.58	5.67
2/6 16:50	2.25	1.49	0.0055	14.92	0.00	0.00	0.00	1.64	5.97
2/6 16:51	2.25	1.49	0.0055	14.81	0.00	0.00	0.00	1.69	6.19
2/6 16:52	2.25	1.49	0.0055	14.86	0.00	0.00	0.00	1.74	6.48
2/6 16:53	2.23	1.48	0.0055	14.86	0.00	0.00	0.00	1.78	6.48
2/6 16:54	2.21	1.47	0.0054	14.53	0.00	0.00	0.00	1.81	6.73
2/6 16:55	2.20	1.46	0.0054	14.53	0.00	0.00	0.00	1.82	6.73
2/6 16:56	2.19	1.46	0.0054	14.61	0.00	0.00	0.00	1.84	6.77
2/6 16:57	2.18	1.45	0.0053	14.30	0.00	0.00	0.00	1.86	6.74
2/6 16:58	2.17	1.44	0.0053	14.30	0.00	0.00	0.00	1.89	7.02
2/6 16:59	2.17	1.44	0.0053	14.29	0.00	0.00	0.00	1.93	7.01
2/6 17:00	2.18	1.45	0.0053	14.34	0.00	0.00	0.00	1.95	7.03
2/6 17:01	2.18	1.45	0.0053	14.28	0.00	0.00	0.00	1.96	7.27
2/6 17:02	2.18	1.45	0.0053	14.28	0.00	0.00	0.00	1.98	7.27
2/6 17:03	2.16	1.43	0.0053	14.27	0.00	0.00	0.00	1.99	7.27
2/6 17:04	2.15	1.43	0.0053	14.27	0.00	0.00	0.00	2.00	7.27
2/6 17:05	2.13	1.41	0.0052	14.00	0.00	0.00	0.00	2.01	7.27
2/6 17:06	2.14	1.42	0.0052	14.09	0.00	0.00	0.00	2.01	7.31
Average (all)	2.21	1.47	0.0054	14.60	0.00	0.00	0.00	1.81	6.62
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.13	1.41	0.0052	14.00	0.00	0.00	0.00	1.50	5.41
Maximum (all)	2.39	1.58	0.0058	15.68	0.00	0.00	0.00	2.01	7.31
Average (valid values only)	2.21	1.47	0.0054	14.60	0.00	0.00	0.00	1.81	6.62
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/6/2020 4:46 PM thru 2/6/2020 5:06 PM

Timestamp	(Turbine 1) 75-O2 % 1-Min	(Turbine 1) CT Nat Gas Flow lb/sec 1-Min	(Turbine 1) DB Nat Gas Flow scf/min 1-Min	(Turbine 1) Total Gas Flow hscf/hr 1-Min	(Turbine 1) GT Megawatts 1-Min	(Turbine 1) ST Megawatts 1-Min	(Turbine 1) Total Megawatts 1-Min
2/6 16:46	11.99	27.4	3999.4	25885.3	232.4	140.3	372.7
2/6 16:47	12.00	27.4	3988.2	25878.6	232.3	140.1	372.4
2/6 16:48	12.00	27.4	3985.0	25876.7	232.5	140.1	372.6
2/6 16:49	12.01	27.4	3980.0	25873.7	232.5	140.1	372.6
2/6 16:50	12.00	27.5	3961.7	25948.4	232.2	140.1	372.3
2/6 16:51	12.01	27.3	3949.3	25769.6	232.5	140.0	372.5
2/6 16:52	12.01	27.4	3938.6	25848.9	232.5	140.1	372.6
2/6 16:53	12.01	27.4	3929.7	25843.5	232.3	139.9	372.2
2/6 16:54	12.02	27.3	3924.6	25754.8	232.4	139.6	372.0
2/6 16:55	12.02	27.3	3930.4	25758.2	232.2	139.5	371.7
2/6 16:56	12.02	27.4	4022.6	25899.3	232.3	139.4	371.7
2/6 16:57	12.00	27.3	4036.4	25821.8	232.4	139.6	372.0
2/6 16:58	11.99	27.3	4022.2	25813.3	232.4	139.8	372.2
2/6 16:59	12.00	27.3	3996.2	25797.7	232.3	140.1	372.4
2/6 17:00	12.00	27.4	3988.9	25879.0	232.6	140.1	372.7
2/6 17:01	12.00	27.3	3972.5	25783.5	232.5	139.9	372.4
2/6 17:02	12.00	27.3	3961.2	25776.7	232.5	139.8	372.3
2/6 17:03	12.01	27.3	3941.6	25765.0	232.4	139.6	372.0
2/6 17:04	12.01	27.3	3934.0	25760.4	232.3	139.3	371.6
2/6 17:05	12.01	27.3	3930.0	25758.0	232.4	139.6	372.0
2/6 17:06	12.01	27.5	3926.8	25927.5	232.6	139.5	372.1
Average (all)	12.01	27.4	3967.6	25829.5	232.4	139.8	372.2
Total (all)	--	--	--	--	--	--	--
Minimum (all)	11.99	27.3	3924.6	25754.8	232.2	139.3	371.6
Maximum (all)	12.02	27.5	4036.4	25948.4	232.6	140.3	372.7
Average (valid values only)	12.01	27.4	3967.6	25829.5	232.4	139.8	372.2
Total (valid values only)	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21

CEMS AND REFERENCE METHOD DATA

Reference Method Data

Relative Accuracy Test Data
Reference Method Results (NOx)
General Electric, 7F.05, Unit #U-00001

Parameter:	Oxides of Nitrogen
Date of Test:	February 6, 2020
Reference Method:	EPA Method 7E
RM Analyzer Type:	Chemiluminescence
Manufacturer:	THERMO 42 series
Model #:	
Serial #:	INST-NX-0020

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:36 - 11:56	373.4		1.96	19.70	0.0072
2	12:10 - 12:30	373.2		1.68	16.88	0.0062
3	12:42 - 13:02	373.3		1.77	17.72	0.0065
4	13:20 - 13:40	372.6		1.75	17.55	0.0065
5	13:55 - 14:15	372.8		1.78	17.84	0.0066
6	14:27 - 14:47	372.7		1.64	16.47	0.0061
7	15:01 - 15:21	372.7		1.97	19.70	0.0073
8	15:36 - 15:56	372.8		1.86	18.61	0.0068
9	16:08 - 16:28	372.6		1.78	17.80	0.0066
10	16:46 - 17:06	372.2		2.06	20.59	0.0076
11						
12						

Relative Accuracy Test Data
Reference Method Results (CO)
General Electric, 7F.05, Unit #U-00001

Parameter:	Carbon Monoxide
Date of Test:	February 6, 2020
Reference Method:	EPA Method 10
RM Analyzer Type:	Infrared Absorption
Manufacturer:	
Model #:	THERMO 48 series
Serial #:	INST-CO-0045

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:36 - 11:56	373.4		0.01	0.07	
2	12:10 - 12:30	373.2		0.28	1.72	
3	12:42 - 13:02	373.3		0.34	2.05	
4	13:20 - 13:40	372.6		0.51	3.10	
5	13:55 - 14:15	372.8		0.62	3.78	
6	14:27 - 14:47	372.7		0.67	4.08	
7	15:01 - 15:21	372.7		0.79	4.80	
8	15:36 - 15:56	372.8		0.67	4.11	
9	16:08 - 16:28	372.6		0.67	4.11	
10	16:46 - 17:06	372.2		1.51	9.16	
11						
12						

Relative Accuracy Test Data
Reference Method Results (NH_3)
General Electric, 7F.05, Unit #U-00001

Parameter:	Ammonia
Date of Test:	February 6, 2020
Reference Method:	EPA Method 027
RM Analyzer Type:	Fourier Transform infared
Manufacturer:	MKS
Model #:	2030
Serial #:	INST-IR-0004

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:36 - 11:56	373.4		1.44	5.34	
2	12:10 - 12:30	373.2		1.47	5.46	
3	12:42 - 13:02	373.3		1.56	5.78	
4	13:20 - 13:40	372.6		1.53	5.68	
5	13:55 - 14:15	372.8		1.56	5.78	
6	14:27 - 14:47	372.7		1.40	5.17	
7	15:01 - 15:21	372.7		1.41	5.22	
8	15:36 - 15:56	372.8		1.47	5.45	
9	16:08 - 16:28	372.6		1.44	5.33	
10	16:46 - 17:06	372.2		1.72	6.35	
11						
12						

Relative Accuracy Test Data
Reference Method Results (O_2)
General Electric, 7F.05, Unit #U-00001

Parameter:	Oxygen
Date of Test:	February 6, 2020
Reference Method:	EPA Method 3A
RM Analyzer Type:	Paramagnetic Cell
Manufacturer:	SERVOMEX 1440
Model #:	
Serial #:	INST-O2-OO14

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	11:36 - 11:56	373.4	11.86
2	12:10 - 12:30	373.2	11.68
3	12:42 - 13:02	373.3	11.97
4	13:20 - 13:40	372.6	12.02
5	13:55 - 14:15	372.8	12.02
6	14:27 - 14:47	372.7	12.04
7	15:01 - 15:21	372.7	12.06
8	15:36 - 15:56	372.8	12.07
9	16:08 - 16:28	372.6	12.02
10	16:46 - 17:06	372.2	11.97
11			
12			

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,593,600	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,593,600	SCFH

Weather Data

Barometric Pressure	29.67	in. Hg
Relative Humidity	96	%
Ambient Temperature	33	°F
Specific Humidity	0.003805	lb H_2O / lb air

Unit Data

Unit Load	373.4	megawatts
Stack Exhaust Flow (M19)	54,863,375	SCFH

Base Load Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 11:36:10	22670	11.13	2.73	0.00	2.01	3.07
02/06/20 11:36:40	22700	11.12	2.71	0.03	1.99	3.22
02/06/20 11:37:10	22730	11.11	2.69	0.00	2.12	3.38
02/06/20 11:37:40	22760	11.11	2.69	0.00	2.01	3.50
02/06/20 11:38:10	22790	11.10	2.72	0.01	2.05	3.86
02/06/20 11:38:40	22820	11.09	2.72	0.00	2.10	4.18
02/06/20 11:39:10	22850	11.15	2.75	0.00	2.18	4.55
02/06/20 11:39:40	22880	12.11	2.72	0.01	2.19	4.71
02/06/20 11:40:10	22910	12.14	2.84	0.00	2.14	4.93
02/06/20 11:40:40	22940	12.15	2.86	0.00	2.11	5.12
02/06/20 11:41:10	22970	12.14	2.87	0.00	2.24	5.69
02/06/20 11:41:40	23000	12.14	2.88	0.02	2.13	5.63
02/06/20 11:42:10	23030	12.13	2.88	0.02	2.24	5.62
02/06/20 11:42:40	23060	12.16	2.87	0.01	2.29	6.02
02/06/20 11:43:10	23090	12.13	2.85	0.09	2.18	6.08
02/06/20 11:43:40	23120	12.11	2.88	0.17	2.26	6.49
02/06/20 11:44:10	23150	12.10	2.91	0.15	2.19	6.46
02/06/20 11:44:40	23180	12.09	2.93	0.18	2.05	7.18
02/06/20 11:45:10	23210	12.09	2.97	0.17	1.92	7.98
02/06/20 11:45:40	23240	12.09	2.98	0.19	1.87	7.81
02/06/20 11:46:10	23270	12.10	2.98	0.08	2.04	7.44
02/06/20 11:46:40	23300	12.09	2.98	0.05	2.26	7.23
02/06/20 11:47:10	23330	12.09	2.99	0.01	2.07	7.85
02/06/20 11:47:40	23360	12.10	3.01	0.00	1.66	8.08
02/06/20 11:48:10	23390	12.11	3.03	0.00	1.84	8.27
02/06/20 11:48:40	23420	12.12	3.03	0.00	1.79	8.23
02/06/20 11:49:10	23450	12.12	2.97	0.00	1.84	7.91
02/06/20 11:49:40	23480	12.13	2.96	0.00	1.90	8.12
02/06/20 11:50:10	23510	12.13	2.96	0.00	1.91	7.98
02/06/20 11:50:40	23540	12.15	2.92	0.00	1.88	7.85
02/06/20 11:51:10	23570	12.15	2.94	0.00	1.94	8.14
02/06/20 11:51:40	23600	12.16	2.99	0.01	1.85	7.93
02/06/20 11:52:10	23630	12.14	2.91	0.02	1.99	7.96
02/06/20 11:52:40	23660	12.13	2.86	0.01	2.04	8.01
02/06/20 11:53:10	23690	12.15	2.89	0.00	1.93	8.70
02/06/20 11:53:40	23720	12.15	2.92	0.00	2.07	10.00
02/06/20 11:54:10	23750	12.14	2.96	0.03	2.30	9.14
02/06/20 11:54:40	23780	12.14	3.02	0.00	2.18	8.52
02/06/20 11:55:10	23810	12.15	3.05	0.03	2.20	8.43
02/06/20 11:55:40	23840	12.15	3.01	0.00	2.32	8.40
02/06/20 11:56:10	23870	12.15	3.00	0.02	1.99	8.45
02/06/20 11:56:40	23900	12.15	3.03	0.06	1.89	8.48
RAW AVERAGE		**11.96**	**2.90**	**0.03**	**2.05**	**6.82**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	0.04	-0.13	0.03	
	Final Zero	0.12	0.14	0.00	
	Avg. Zero	0.08	0.01	0.02	
	Initial UpScale	12.05	4.82	5.02	
	Final UpScale	12.06	4.81	4.97	
	Avg. UpScale	12.06	4.82	5.00	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	11.86	3.01	0.02	2.20
Concentration (ppm@ 15%O_2)	N/A	1.96	0.01	1.44
Emission Rate (lb/hr)	N/A	19.70	0.07	5.34
Emission Rate (lb/MMBtu)	N/A	0.0072	0.000	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,591,200	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,591,200	SCFH

Weather Data

Barometric Pressure	29.65	in. Hg
Relative Humidity	92	%
Ambient Temperature	34	°F
Specific Humidity	0.003798	lb H_2O / lb air

Unit Data

Unit Load	373.2	megawatts
Stack Exhaust Flow (M19)	53,713,011	SCFH

Base Load Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 12:10:10	24710	11.68	2.57	0.27	2.05	3.45
02/06/20 12:10:40	24740	11.69	2.67	0.25	2.08	3.63
02/06/20 12:11:10	24770	11.70	2.72	0.26	2.11	3.83
02/06/20 12:11:40	24800	11.69	2.71	0.28	2.09	4.04
02/06/20 12:12:10	24830	11.67	2.60	0.27	2.22	4.88
02/06/20 12:12:40	24860	11.67	2.58	0.21	2.11	5.35
02/06/20 12:13:10	24890	11.68	2.60	0.19	2.15	5.07
02/06/20 12:13:40	24920	11.68	2.61	0.10	2.20	4.91
02/06/20 12:14:10	24950	11.69	2.61	0.22	2.28	4.87
02/06/20 12:14:40	24980	11.69	2.61	0.26	2.29	4.99
02/06/20 12:15:10	25010	11.69	2.63	0.32	2.24	5.11
02/06/20 12:15:40	25040	11.70	2.60	0.26	2.21	5.85
02/06/20 12:16:10	25070	11.71	2.59	0.24	2.34	5.77
02/06/20 12:16:40	25100	11.72	2.55	0.26	2.23	5.81
02/06/20 12:17:10	25130	11.72	2.53	0.23	2.34	5.98
02/06/20 12:17:40	25160	11.72	2.51	0.24	2.39	6.01
02/06/20 12:18:10	25190	11.72	2.50	0.26	2.28	6.46
02/06/20 12:18:40	25220	11.72	2.50	0.43	2.36	6.35
02/06/20 12:19:10	25250	11.71	2.51	0.52	2.29	6.29
02/06/20 12:19:40	25280	11.70	2.53	0.65	2.15	6.16
02/06/20 12:20:10	25310	11.68	2.54	0.60	2.02	6.09
02/06/20 12:20:40	25340	11.67	2.54	0.78	1.97	6.04
02/06/20 12:21:10	25370	11.66	2.55	0.83	2.14	6.07
02/06/20 12:21:40	25400	11.67	2.59	0.90	2.36	6.46
02/06/20 12:22:10	25430	11.69	2.59	1.09	2.17	7.48
02/06/20 12:22:40	25460	11.69	2.60	1.09	1.76	7.48
02/06/20 12:23:10	25490	11.70	2.56	0.93	1.94	6.86
02/06/20 12:23:40	25520	11.70	2.58	0.72	1.89	6.96
02/06/20 12:24:10	25550	11.69	2.57	0.59	1.94	7.70
02/06/20 12:24:40	25580	11.67	2.53	0.57	2.00	7.65
02/06/20 12:25:10	25610	11.79	2.54	0.31	2.01	7.68
02/06/20 12:25:40	25640	11.66	2.55	0.21	1.98	7.24
02/06/20 12:26:10	25670	11.68	2.38	0.19	2.04	7.15
02/06/20 12:26:40	25700	11.68	2.40	0.10	1.95	6.91
02/06/20 12:27:10	25730	11.69	2.41	0.22	2.09	7.19
02/06/20 12:27:40	25760	11.69	2.41	0.26	2.14	6.87
02/06/20 12:28:10	25790	11.69	2.42	0.32	2.03	7.19
02/06/20 12:28:40	25820	11.66	2.46	0.26	2.17	7.12
02/06/20 12:29:10	25850	11.69	2.46	0.24	2.40	8.06
02/06/20 12:29:40	25880	11.69	2.47	0.26	2.28	9.10
02/06/20 12:30:10	25910	11.68	2.43	0.23	2.30	8.68
02/06/20 12:30:40	25940	11.68	2.45	0.24	2.42	9.50
RAW AVERAGE		**11.69**	**2.54**	**0.43**	**2.15**	**6.34**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	(ppmvd)	(ppmvd)	
Bias	**Initial Zero**	0.12	0.14	0.00	
Bias	**Final Zero**	0.09	-0.09	0.00	
Bias	**Avg. Zero**	0.11	0.03	0.00	
Bias	**Initial UpScale**	12.06	4.81	4.97	
Bias	**Final UpScale**	11.88	4.79	4.85	
Bias	**Avg. UpScale**	11.97	4.80	4.91	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	11.68	2.63	0.44	2.30
Concentration (ppm@ 15%O_2)	N/A	1.68	0.28	1.47
Emission Rate (lb/hr)	N/A	16.88	1.72	5.46
Emission Rate (lb/MMBtu)	N/A	0.0062	0.001	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,592,160	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,592,160	SCFH

Weather Data

Barometric Pressure	29.67	in. Hg
Relative Humidity	90	%
Ambient Temperature	35	°F
Specific Humidity	0.003864	lb H_2O / lb air

Unit Data

Unit Load	373.3	megawatts
Stack Exhaust Flow (M19)	55,506,291	SCFH

Base Load Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 12:42:10	26630	11.86	2.51	0.13	2.00	7.81
02/06/20 12:42:40	26660	11.87	2.48	0.18	2.03	7.83
02/06/20 12:43:10	26690	11.87	2.48	0.20	2.11	7.76
02/06/20 12:43:40	26720	11.88	2.48	0.17	2.07	7.88
02/06/20 12:44:10	26750	11.89	2.49	0.22	2.20	8.14
02/06/20 12:44:40	26780	11.90	2.50	0.17	2.37	8.22
02/06/20 12:45:10	26810	11.90	2.52	0.24	2.17	8.76
02/06/20 12:45:40	26840	11.89	2.51	0.27	2.20	9.22
02/06/20 12:46:10	26870	11.87	2.48	0.29	2.08	9.44
02/06/20 12:46:40	26900	11.86	2.48	0.33	2.13	10.49
02/06/20 12:47:10	26930	11.86	2.51	0.36	2.08	10.00
02/06/20 12:47:40	26960	11.87	2.54	0.38	2.28	9.66
02/06/20 12:48:10	26990	11.87	2.54	0.39	2.27	9.19
02/06/20 12:48:40	27020	11.87	2.54	0.38	2.19	9.07
02/06/20 12:49:10	27050	11.88	2.56	0.35	2.25	9.20
02/06/20 12:49:40	27080	11.88	2.55	0.35	2.23	9.29
02/06/20 12:50:10	27110	11.87	2.57	0.24	2.30	9.76
02/06/20 12:50:40	27140	11.88	2.57	0.26	2.26	9.87
02/06/20 12:51:10	27170	11.89	2.54	0.38	2.15	9.43
02/06/20 12:51:40	27200	11.89	2.54	0.58	2.12	9.21
02/06/20 12:52:10	27230	11.89	2.51	0.56	2.13	8.91
02/06/20 12:52:40	27260	11.89	2.52	0.65	2.09	9.03
02/06/20 12:53:10	27290	11.89	2.54	0.75	2.04	8.86
02/06/20 12:53:40	27320	11.89	2.54	0.94	1.98	8.89
02/06/20 12:54:10	27350	11.89	2.53	0.85	1.91	8.96
02/06/20 12:54:40	27380	11.89	2.55	0.84	1.84	9.20
02/06/20 12:55:10	27410	11.89	2.57	0.92	2.09	8.92
02/06/20 12:55:40	27440	11.88	2.55	0.90	2.00	9.93
02/06/20 12:56:10	27470	11.87	2.53	0.76	2.25	10.77
02/06/20 12:56:40	27500	11.85	2.55	0.69	2.14	9.50
02/06/20 12:57:10	27530	11.86	2.57	0.62	2.13	9.84
02/06/20 12:57:40	27560	11.86	2.57	0.53	2.32	9.36
02/06/20 12:58:10	27590	11.87	2.57	0.49	2.33	9.20
02/06/20 12:58:40	27620	11.87	2.56	0.50	2.29	8.73
02/06/20 12:59:10	27650	11.88	2.57	0.42	2.27	8.77
02/06/20 12:59:40	27680	11.88	2.53	0.45	2.25	8.61
02/06/20 13:00:10	27710	11.88	2.53	0.63	2.19	8.41
02/06/20 13:00:40	27740	11.88	2.51	0.63	2.32	8.35
02/06/20 13:01:10	27770	11.89	2.48	0.62	2.20	8.36
02/06/20 13:01:40	27800	11.89	2.51	0.62	1.88	8.54
02/06/20 13:02:10	27830	11.89	2.51	0.57	1.89	8.62
02/06/20 13:02:40	27860	11.89	2.51	0.56	2.00	8.50
RAW AVERAGE		**11.88**	**2.53**	**0.48**	**2.14**	**9.01**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	(ppmvd)	(ppmvd)	
Bias	**Initial Zero**	0.09	-0.09	0.00	
Bias	**Final Zero**	0.07	-0.13	0.00	
Bias	**Avg. Zero**	0.08	-0.11	0.00	
Bias	**Initial UpScale**	11.88	4.79	4.85	
Bias	**Final UpScale**	11.85	4.84	4.87	
Bias	**Avg. UpScale**	11.87	4.82	4.86	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	11.97	2.67	0.51	2.36
Concentration (ppm@ 15%O_2)	N/A	1.77	0.34	1.56
Emission Rate (lb/hr)	N/A	17.72	2.05	5.78
Emission Rate (lb/MMBtu)	N/A	0.0065	0.001	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,589,920	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,589,920	SCFH

Weather Data

Barometric Pressure	29.58	in. Hg
Relative Humidity	84	%
Ambient Temperature	37	°F
Specific Humidity	0.003916	lb H_2O / lb air

Unit Data

Unit Load	372.6	megawatts
Stack Exhaust Flow (M19)	55,729,872	SCFH

Base Load Load, Run - 4

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 13:20:10	20	11.90	2.55	0.48	2.01	5.63
02/06/20 13:20:40	50	11.90	2.54	0.53	2.03	5.73
02/06/20 13:21:10	80	11.89	2.51	0.52	2.09	5.80
02/06/20 13:21:40	110	11.90	2.50	0.56	2.06	5.96
02/06/20 13:22:10	140	11.90	2.50	0.55	2.19	6.51
02/06/20 13:22:40	170	11.90	2.48	0.72	2.22	6.78
02/06/20 13:23:10	200	11.90	2.49	0.73	2.14	6.91
02/06/20 13:23:40	230	11.90	2.48	0.78	2.18	7.07
02/06/20 13:24:10	260	11.91	2.53	0.92	2.16	7.15
02/06/20 13:24:40	290	11.90	2.54	0.87	2.19	7.74
02/06/20 13:25:10	320	11.91	2.51	0.66	2.14	7.55
02/06/20 13:25:40	350	11.91	2.51	0.39	2.22	7.76
02/06/20 13:26:10	380	11.92	2.52	0.35	2.28	7.48
02/06/20 13:26:40	410	11.92	2.50	0.28	2.19	7.44
02/06/20 13:27:10	440	11.90	2.51	0.36	2.27	7.59
02/06/20 13:27:40	470	11.90	2.51	0.31	2.29	7.65
02/06/20 13:28:10	500	11.88	2.48	0.41	2.27	8.11
02/06/20 13:28:40	530	11.88	2.49	0.60	2.29	8.11
02/06/20 13:29:10	560	11.88	2.54	0.85	2.20	7.86
02/06/20 13:29:40	590	11.88	2.52	1.09	2.12	7.68
02/06/20 13:30:10	620	11.89	2.51	1.37	2.05	7.50
02/06/20 13:30:40	650	11.89	2.53	1.27	2.01	7.53
02/06/20 13:31:10	680	11.89	2.52	1.38	2.07	7.47
02/06/20 13:31:40	710	11.89	2.51	1.20	2.15	7.68
02/06/20 13:32:10	740	11.89	2.49	1.02	2.02	8.22
02/06/20 13:32:40	770	11.89	2.51	0.95	1.78	8.34
02/06/20 13:33:10	800	11.91	2.49	0.93	2.00	7.89
02/06/20 13:33:40	830	11.92	2.45	1.42	1.93	8.44
02/06/20 13:34:10	860	11.92	2.48	0.81	2.07	9.23
02/06/20 13:34:40	890	11.93	2.55	0.57	2.05	8.57
02/06/20 13:35:10	920	11.93	2.65	0.42	2.05	8.76
02/06/20 13:35:40	950	11.93	2.63	0.39	2.13	8.30
02/06/20 13:36:10	980	11.93	2.68	0.43	2.16	8.17
02/06/20 13:36:40	1010	11.93	2.67	0.49	2.10	7.82
02/06/20 13:37:10	1040	11.93	2.48	0.47	2.16	7.98
02/06/20 13:37:40	1070	11.93	2.47	0.49	2.18	7.74
02/06/20 13:38:10	1100	11.93	2.46	0.60	2.09	7.80
02/06/20 13:38:40	1130	11.93	2.45	0.57	2.23	7.73
02/06/20 13:39:10	1160	11.92	2.45	0.53	2.28	8.21
02/06/20 13:39:40	1190	11.92	2.47	0.53	2.06	8.82
02/06/20 13:40:10	1220	11.92	2.46	0.45	2.07	8.65
02/06/20 13:40:40	1250	11.92	2.45	0.57	2.19	9.00
RAW AVERAGE		**11.91**	**2.44**	**0.74**	**2.13**	**7.68**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	0.07	-0.13	0.00	
	Final Zero	0.11	-0.14	0.00	
	Avg. Zero	0.09	-0.14	0.00	
	Initial UpScale	11.85	4.84	4.87	
	Final UpScale	11.85	4.65	4.95	
	Avg. UpScale	11.85	4.75	4.91	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.02	2.64	0.76	2.31
Concentration (ppm@ 15%O_2)	N/A	1.75	0.51	1.53
Emission Rate (lb/hr)	N/A	17.55	3.10	5.68
Emission Rate (lb/MMBtu)	N/A	0.0065	0.001	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,588,170	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,588,170	SCFH

Weather Data

Barometric Pressure	29.57	in. Hg
Relative Humidity	80	%
Ambient Temperature	38	°F
Specific Humidity	0.003881	lb H_2O / lb air

Unit Data

Unit Load	372.8	megawatts
Stack Exhaust Flow (M19)	55,694,575	SCFH

Base Load Load, Run - 5

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 13:55:10	30350	11.92	2.48	0.81	2.05	5.63
02/06/20 13:55:40	30380	11.93	2.55	0.57	2.07	5.73
02/06/20 13:56:10	30410	11.93	2.65	0.42	2.13	5.80
02/06/20 13:56:40	30440	11.93	2.63	0.39	2.10	5.96
02/06/20 13:57:10	30470	11.93	2.68	0.43	2.23	6.51
02/06/20 13:57:40	30500	11.93	2.67	0.49	2.26	6.78
02/06/20 13:58:10	30530	11.93	2.48	0.47	2.18	6.91
02/06/20 13:58:40	30560	11.93	2.47	0.49	2.22	7.07
02/06/20 13:59:10	30590	11.93	2.46	0.60	2.20	7.15
02/06/20 13:59:40	30620	11.93	2.45	0.57	2.23	7.74
02/06/20 14:00:10	30650	11.92	2.45	0.53	2.18	7.55
02/06/20 14:00:40	30680	11.92	2.47	0.53	2.26	7.76
02/06/20 14:01:10	30710	11.92	2.46	0.45	2.32	7.48
02/06/20 14:01:40	30740	11.92	2.45	0.57	2.23	7.44
02/06/20 14:02:10	30770	11.91	2.45	0.66	2.31	7.59
02/06/20 14:02:40	30800	11.91	2.44	0.74	2.33	7.65
02/06/20 14:03:10	30830	11.91	2.42	0.79	2.31	8.11
02/06/20 14:03:40	30860	11.91	2.42	1.03	2.33	8.11
02/06/20 14:04:10	30890	11.90	2.42	1.26	2.24	7.86
02/06/20 14:04:40	30920	11.91	2.42	1.39	2.16	7.68
02/06/20 14:05:10	30950	11.90	2.42	1.39	2.09	7.50
02/06/20 14:05:40	30980	11.91	2.44	1.47	2.05	7.53
02/06/20 14:06:10	31010	11.91	2.45	1.42	2.11	7.47
02/06/20 14:06:40	31040	11.92	2.48	1.36	2.19	7.68
02/06/20 14:07:10	31070	11.91	2.45	1.20	2.06	8.22
02/06/20 14:07:40	31100	11.91	2.44	1.04	1.82	8.34
02/06/20 14:08:10	31130	11.92	2.43	0.99	2.04	7.89
02/06/20 14:08:40	31160	11.92	2.42	0.96	1.97	8.44
02/06/20 14:09:10	31190	11.91	2.42	0.93	2.11	9.23
02/06/20 14:09:40	31220	11.91	2.42	0.87	2.09	8.57
02/06/20 14:10:10	31250	11.91	2.45	0.91	2.09	8.76
02/06/20 14:10:40	31280	11.91	2.43	0.93	2.17	8.30
02/06/20 14:11:10	31310	11.92	2.42	0.90	2.20	8.17
02/06/20 14:11:40	31340	11.89	2.42	1.06	2.14	7.82
02/06/20 14:12:10	31370	11.89	2.45	1.26	2.20	7.98
02/06/20 14:12:40	31400	11.89	2.47	1.49	2.22	7.74
02/06/20 14:13:10	31430	11.88	2.48	1.44	2.13	7.80
02/06/20 14:13:40	31460	11.88	2.48	1.42	2.27	7.73
02/06/20 14:14:10	31490	11.89	2.48	1.16	2.32	8.21
02/06/20 14:14:40	31520	11.89	2.48	0.85	2.10	8.82
02/06/20 14:15:10	31550	11.89	2.51	0.88	2.11	8.65
02/06/20 14:15:40	31580	11.90	2.48	0.90	2.23	9.00
RAW AVERAGE		**11.91**	**2.47**	**0.91**	**2.17**	**7.68**

		O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
Bias	**Initial Zero**	0.11	-0.14	0.00	
	Final Zero	0.09	-0.15	0.00	
	Avg. Zero	0.10	-0.15	0.00	
	Initial UpScale	11.85	4.65	4.95	
	Final UpScale	11.86	4.80	4.91	
	Avg. UpScale	11.86	4.73	4.93	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.02	2.68	0.93	2.35
Concentration (ppm@ 15%O_2)	N/A	1.78	0.62	1.56
Emission Rate (lb/hr)	N/A	17.84	3.78	5.78
Emission Rate (lb/MMBtu)	N/A	0.0066	0.001	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,587,280	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,587,280	SCFH

Weather Data

Barometric Pressure	29.54	in. Hg
Relative Humidity	79	%
Ambient Temperature	38	°F
Specific Humidity	0.003836	lb H_2O / lb air

Unit Data

Unit Load	372.7	megawatts
Stack Exhaust Flow (M19)	55,811,118	SCFH

Base Load Load, Run - 6

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 14:27:10	32420	11.94	2.43	1.03	1.73	8.51
02/06/20 14:27:40	32450	11.94	2.47	0.69	1.83	9.63
02/06/20 14:28:10	32480	11.93	2.55	0.66	1.84	10.38
02/06/20 14:28:40	32510	11.94	2.49	0.54	1.89	9.16
02/06/20 14:29:10	32540	11.94	2.32	0.51	1.92	8.99
02/06/20 14:29:40	32570	11.94	2.31	0.47	1.88	8.83
02/06/20 14:30:10	32600	11.94	2.29	0.42	1.91	9.28
02/06/20 14:30:40	32630	11.95	2.30	0.46	1.89	8.90
02/06/20 14:31:10	32660	11.94	2.33	0.59	1.90	8.94
02/06/20 14:31:40	32690	11.95	2.33	0.54	1.90	9.49
02/06/20 14:32:10	32720	11.94	2.35	0.52	1.96	3.97
02/06/20 14:32:40	32750	11.94	2.34	0.54	1.99	4.08
02/06/20 14:33:10	32780	11.94	2.35	0.73	1.97	4.11
02/06/20 14:33:40	32810	11.94	2.36	0.77	2.16	6.15
02/06/20 14:34:10	32840	11.94	2.34	0.76	2.35	6.36
02/06/20 14:34:40	32870	11.93	2.33	0.85	2.39	6.00
02/06/20 14:35:10	32900	11.91	2.34	0.84	2.35	6.95
02/06/20 14:35:40	32930	11.90	2.36	0.95	2.27	6.28
02/06/20 14:36:10	32960	11.89	2.36	0.96	2.26	7.03
02/06/20 14:36:40	32990	11.90	2.36	1.07	2.20	6.57
02/06/20 14:37:10	33020	11.89	2.36	1.08	2.18	6.85
02/06/20 14:37:40	33050	11.90	2.39	1.21	2.17	6.83
02/06/20 14:38:10	33080	11.90	2.37	1.16	2.10	6.88
02/06/20 14:38:40	33110	11.90	2.37	1.25	2.03	6.95
02/06/20 14:39:10	33140	11.91	2.36	1.24	2.00	7.03
02/06/20 14:39:40	33170	11.91	2.37	1.28	1.67	8.55
02/06/20 14:40:10	33200	11.91	2.36	1.26	1.66	7.99
02/06/20 14:40:40	33230	11.92	2.37	1.30	1.83	7.75
02/06/20 14:41:10	33260	11.92	2.35	1.33	1.82	7.97
02/06/20 14:41:40	33290	11.93	2.32	1.28	1.78	7.80
02/06/20 14:42:10	33320	11.93	2.29	1.34	1.77	7.98
02/06/20 14:42:40	33350	11.93	2.27	1.35	1.80	7.80
02/06/20 14:43:10	33380	11.93	2.29	1.34	1.72	7.77
02/06/20 14:43:40	33410	11.93	2.27	1.35	1.74	7.94
02/06/20 14:44:10	33440	11.93	2.30	1.26	1.73	7.80
02/06/20 14:44:40	33470	11.92	2.30	1.32	1.67	7.84
02/06/20 14:45:10	33500	11.91	2.31	1.31	1.67	7.89
02/06/20 14:45:40	33530	11.91	2.33	1.21	1.70	8.96
02/06/20 14:46:10	33560	11.90	2.36	1.09	1.69	8.40
02/06/20 14:46:40	33590	11.91	2.37	0.99	2.04	8.93
02/06/20 14:47:10	33620	11.91	2.37	0.91	2.10	8.29
02/06/20 14:47:40	33650	11.91	2.37	0.88	1.83	8.16
RAW AVERAGE		**11.92**	**2.35**	**0.97**	**1.94**	**7.67**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	0.09	-0.15	0.00	
	Final Zero	0.07	0.08	0.00	
	Avg. Zero	0.08	-0.04	0.00	
	Initial UpScale	11.86	4.80	4.91	
	Final UpScale	11.83	4.77	4.89	
	Avg. UpScale	11.85	4.79	4.90	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.04	2.47	1.01	2.10
Concentration (ppm@ 15%O_2)	N/A	1.64	0.67	1.40
Emission Rate (lb/hr)	N/A	16.47	4.08	5.17
Emission Rate (lb/MMBtu)	N/A	0.0061	0.002	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,587,680	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,587,680	SCFH

Weather Data

Barometric Pressure	29.54	in. Hg
Relative Humidity	87	%
Ambient Temperature	35	°F
Specific Humidity	0.003751	lb H_2O / lb air

Unit Data

Unit Load	372.7	megawatts
Stack Exhaust Flow (M19)	55,925,314	SCFH

Base Load Load, Run - 7

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 15:01:10	34460	11.96	2.69	2.77	1.83	3.97
02/06/20 15:01:40	34490	11.96	2.82	2.56	1.85	4.08
02/06/20 15:02:10	34520	11.96	2.83	2.06	1.91	4.11
02/06/20 15:02:40	34550	11.96	2.62	1.66	1.88	6.15
02/06/20 15:03:10	34580	11.96	2.57	1.35	2.01	6.36
02/06/20 15:03:40	34610	11.96	2.57	1.27	2.04	6.00
02/06/20 15:04:10	34640	11.95	2.61	1.09	1.96	6.95
02/06/20 15:04:40	34670	11.93	2.62	1.04	2.00	6.28
02/06/20 15:05:10	34700	11.92	2.60	1.11	1.98	7.03
02/06/20 15:05:40	34730	11.92	2.60	1.07	2.01	6.57
02/06/20 15:06:10	34760	11.92	2.62	1.02	1.96	6.85
02/06/20 15:06:40	34790	11.92	2.63	0.95	2.04	6.83
02/06/20 15:07:10	34820	11.92	2.71	0.78	2.10	6.88
02/06/20 15:07:40	34850	11.92	2.80	0.76	2.01	6.95
02/06/20 15:08:10	34880	11.93	2.87	0.77	2.09	7.03
02/06/20 15:08:40	34910	11.92	2.92	0.81	2.11	8.55
02/06/20 15:09:10	34940	11.93	2.97	0.82	2.09	7.99
02/06/20 15:09:40	34970	11.93	2.99	0.92	2.11	7.75
02/06/20 15:10:10	35000	11.93	2.97	0.92	2.02	7.97
02/06/20 15:10:40	35030	11.93	2.98	0.98	1.94	7.80
02/06/20 15:11:10	35060	11.94	2.95	0.84	1.87	7.98
02/06/20 15:11:40	35090	11.94	2.91	0.87	1.83	7.80
02/06/20 15:12:10	35120	11.94	2.86	0.95	1.89	7.77
02/06/20 15:12:40	35150	11.95	2.90	0.95	1.97	7.94
02/06/20 15:13:10	35180	11.94	2.92	1.01	1.84	7.80
02/06/20 15:13:40	35210	11.95	2.95	0.95	1.60	7.84
02/06/20 15:14:10	35240	11.95	2.98	0.85	1.82	7.89
02/06/20 15:14:40	35270	11.96	2.99	0.93	1.75	8.96
02/06/20 15:15:10	35300	11.96	3.01	0.93	1.89	8.40
02/06/20 15:15:40	35330	11.95	2.98	1.01	1.87	8.93
02/06/20 15:16:10	35360	11.96	2.98	0.93	1.87	8.29
02/06/20 15:16:40	35390	11.96	2.98	1.04	1.95	8.16
02/06/20 15:17:10	35420	11.96	2.94	1.04	1.98	8.51
02/06/20 15:17:40	35450	11.95	2.92	1.03	1.92	9.63
02/06/20 15:18:10	35480	11.95	2.92	1.13	1.98	10.38
02/06/20 15:18:40	35510	11.92	2.91	0.96	2.00	9.16
02/06/20 15:19:10	35540	11.91	2.89	1.08	1.91	8.99
02/06/20 15:19:40	35570	11.90	2.89	1.03	2.05	8.83
02/06/20 15:20:10	35600	11.89	2.88	1.02	2.10	9.28
02/06/20 15:20:40	35630	11.90	2.87	1.10	1.88	8.90
02/06/20 15:21:10	35660	11.82	2.85	1.15	1.89	8.94
02/06/20 15:21:40	35690	11.89	2.90	1.89	2.01	9.49
RAW AVERAGE		**11.93**	**2.84**	**1.13**	**1.95**	**7.67**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	(ppmvd)	(ppmvd)	
Bias	**Initial Zero**	0.07	0.08	0.00	
Bias	**Final Zero**	0.11	-0.07	0.00	
Bias	**Avg. Zero**	0.09	0.01	0.00	
Bias	**Initial UpScale**	11.83	4.77	4.89	
Bias	**Final UpScale**	11.85	4.84	4.84	
Bias	**Avg. UpScale**	11.84	4.81	4.87	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.06	2.95	1.18	2.11
Concentration (ppm@ 15%O_2)	N/A	1.97	0.79	1.41
Emission Rate (lb/hr)	N/A	19.70	4.80	5.22
Emission Rate (lb/MMBtu)	N/A	0.0073	0.002	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,587,770	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,587,770	SCFH

Weather Data

Barometric Pressure	29.53	in. Hg
Relative Humidity	86	%
Ambient Temperature	36	°F
Specific Humidity	0.003860	lb H_2O / lb air

Unit Data

Unit Load	372.8	megawatts
Stack Exhaust Flow (M19)	56,023,514	SCFH

Base Load Load, Run - 8

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 15:36:10	36530	11.96	2.65	1.94	1.90	8.55
02/06/20 15:36:40	36560	11.96	2.60	1.56	1.89	7.99
02/06/20 15:37:10	36590	11.97	2.62	1.11	2.06	7.75
02/06/20 15:37:40	36620	11.97	2.73	0.99	2.05	7.97
02/06/20 15:38:10	36650	11.97	2.77	0.76	2.01	7.80
02/06/20 15:38:40	36680	11.98	2.76	0.60	2.00	7.98
02/06/20 15:39:10	36710	11.98	2.80	0.56	2.03	7.80
02/06/20 15:39:40	36740	11.99	2.81	0.46	1.95	7.77
02/06/20 15:40:10	36770	11.97	2.83	0.57	1.97	7.94
02/06/20 15:40:40	36800	11.96	2.88	0.51	1.96	7.80
02/06/20 15:41:10	36830	11.95	2.89	0.43	1.90	7.84
02/06/20 15:41:40	36860	11.95	2.89	0.57	1.90	7.89
02/06/20 15:42:10	36890	11.94	2.89	0.64	1.93	8.96
02/06/20 15:42:40	36920	11.94	2.87	0.60	1.92	8.40
02/06/20 15:43:10	36950	11.94	2.82	0.71	2.27	8.93
02/06/20 15:43:40	36980	11.93	2.82	0.80	2.33	8.29
02/06/20 15:44:10	37010	11.94	2.79	0.87	2.06	8.16
02/06/20 15:44:40	37040	11.94	2.76	0.90	1.99	8.51
02/06/20 15:45:10	37070	11.95	2.72	0.88	2.06	9.63
02/06/20 15:45:40	37100	11.94	2.73	0.85	2.50	10.38
02/06/20 15:46:10	37130	11.94	2.72	0.75	1.96	9.16
02/06/20 15:46:40	37160	11.94	2.72	0.80	1.90	8.99
02/06/20 15:47:10	37190	11.94	2.70	0.72	1.98	8.83
02/06/20 15:47:40	37220	11.94	2.69	0.74	2.07	9.28
02/06/20 15:48:10	37250	11.94	2.69	0.80	2.16	8.90
02/06/20 15:48:40	37280	11.94	2.68	0.71	2.05	8.94
02/06/20 15:49:10	37310	11.94	2.65	0.93	2.18	9.49
02/06/20 15:49:40	37340	11.95	2.63	0.90	1.77	9.32
02/06/20 15:50:10	37370	11.95	2.62	1.09	1.56	9.96
02/06/20 15:50:40	37400	11.95	2.60	1.35	2.77	11.18
02/06/20 15:51:10	37430	11.95	2.63	1.35	1.80	8.75
02/06/20 15:51:40	37460	11.95	2.60	1.59	1.88	8.11
02/06/20 15:52:10	37490	11.94	2.59	1.50	1.88	7.77
02/06/20 15:52:40	37520	11.94	2.60	1.44	2.05	7.32
02/06/20 15:53:10	37550	11.92	2.59	1.41	2.01	6.91
02/06/20 15:53:40	37580	11.92	2.60	1.28	2.02	6.46
02/06/20 15:54:10	37610	11.92	2.62	1.20	2.06	6.05
02/06/20 15:54:40	37640	11.91	2.60	1.16	2.20	5.55
02/06/20 15:55:10	37670	11.91	2.58	1.02	2.12	5.06
02/06/20 15:55:40	37700	11.91	2.60	1.09	1.97	4.61
02/06/20 15:56:10	37730	11.92	2.64	1.09	1.91	5.03
02/06/20 15:56:40	37760	11.93	2.62	1.06	1.92	6.69
RAW AVERAGE		**11.94**	**2.70**	**0.96**	**2.02**	**8.06**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	(ppmvd)	(ppmvd)	
Bias	**Initial Zero**	0.11	-0.07	0.00	
	Final Zero	0.10	0.04	0.00	
	Avg. Zero	0.11	-0.02	0.00	
	Initial UpScale	11.85	4.84	4.84	
	Final UpScale	11.82	4.89	4.84	
	Avg. UpScale	11.84	4.87	4.84	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.07	2.78	1.01	2.20
Concentration (ppm@ 15%O_2)	N/A	1.86	0.67	1.47
Emission Rate (lb/hr)	N/A	18.61	4.11	5.45
Emission Rate (lb/MMBtu)	N/A	0.0068	0.002	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,587,110	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,587,110	SCFH

Weather Data

Barometric Pressure	29.51	in. Hg
Relative Humidity	87	%
Ambient Temperature	36	°F
Specific Humidity	0.003908	lb H_2O / lb air

Unit Data

Unit Load	372.6	megawatts
Stack Exhaust Flow (M19)	55,712,705	SCFH

Base Load Load, Run - 9

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 16:08:10	38600	11.90	2.77	1.83	2.13	9.54
02/06/20 16:08:40	38630	11.89	2.70	1.53	2.33	9.16
02/06/20 16:09:10	38660	11.88	2.69	1.44	2.40	8.76
02/06/20 16:09:40	38690	11.87	2.69	1.24	2.32	8.43
02/06/20 16:10:10	38720	11.87	2.69	0.98	2.44	7.97
02/06/20 16:10:40	38750	11.88	2.71	0.85	2.46	7.63
02/06/20 16:11:10	38780	11.87	2.69	0.76	2.73	7.45
02/06/20 16:11:40	38810	11.88	2.73	0.64	2.24	8.82
02/06/20 16:12:10	38840	11.88	2.72	0.54	2.39	8.29
02/06/20 16:12:40	38870	11.89	2.69	0.67	2.23	7.95
02/06/20 16:13:10	38900	11.89	2.68	0.52	1.84	8.07
02/06/20 16:13:40	38930	11.89	2.66	0.48	1.70	8.23
02/06/20 16:14:10	38960	11.90	2.65	0.48	1.56	8.66
02/06/20 16:14:40	38990	11.91	2.66	0.56	1.67	9.17
02/06/20 16:15:10	39020	11.91	2.63	0.60	1.98	10.47
02/06/20 16:15:40	39050	11.91	2.60	0.60	1.85	9.47
02/06/20 16:16:10	39080	11.92	2.60	0.61	1.89	9.27
02/06/20 16:16:40	39110	11.93	2.60	0.66	1.87	9.08
02/06/20 16:17:10	39140	11.94	2.60	0.59	1.88	8.96
02/06/20 16:17:40	39170	11.93	2.60	0.68	1.97	9.14
02/06/20 16:18:10	39200	11.93	2.61	0.64	1.95	8.86
02/06/20 16:18:40	39230	11.93	2.60	0.65	1.84	9.12
02/06/20 16:19:10	39260	11.93	2.59	0.67	2.02	9.23
02/06/20 16:19:40	39290	11.94	2.59	0.73	2.08	8.96
02/06/20 16:20:10	39320	11.94	2.60	0.92	1.95	9.53
02/06/20 16:20:40	39350	11.94	2.60	0.82	1.90	5.94
02/06/20 16:21:10	39380	11.94	2.60	0.87	1.84	6.23
02/06/20 16:21:40	39410	11.94	2.60	0.84	1.99	7.11
02/06/20 16:22:10	39440	11.94	2.60	0.93	1.87	6.92
02/06/20 16:22:40	39470	11.94	2.63	0.99	1.86	7.31
02/06/20 16:23:10	39500	11.93	2.62	1.03	1.74	7.16
02/06/20 16:23:40	39530	11.94	2.63	1.20	1.76	7.27
02/06/20 16:24:10	39560	11.94	2.65	1.24	1.75	7.52
02/06/20 16:24:40	39590	11.94	2.71	1.27	1.55	7.40
02/06/20 16:25:10	39620	11.92	2.76	1.38	1.59	7.36
02/06/20 16:25:40	39650	11.91	2.71	1.47	2.08	7.97
02/06/20 16:26:10	39680	11.90	2.69	1.47	1.79	8.50
02/06/20 16:26:40	39710	11.90	2.60	1.56	1.89	8.02
02/06/20 16:27:10	39740	11.90	2.60	1.48	1.95	7.77
02/06/20 16:27:40	39770	11.91	2.60	1.38	2.02	7.62
02/06/20 16:28:10	39800	11.92	2.60	1.31	2.07	7.57
02/06/20 16:28:40	39830	11.92	2.61	1.45	1.97	8.18
RAW AVERAGE		**11.91**	**2.65**	**0.97**	**1.98**	**8.24**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	(ppmvd)	(ppmvd)	
Bias	**Initial Zero**	0.10	0.04	0.00	
Bias	**Final Zero**	0.08	0.08	0.00	
Bias	**Avg. Zero**	0.09	0.06	0.00	
Bias	**Initial UpScale**	11.82	4.89	4.84	
Bias	**Final UpScale**	11.88	4.88	4.84	
Bias	**Avg. UpScale**	11.85	4.89	4.84	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.02	2.67	1.01	2.16
Concentration (ppm@ 15%O_2)	N/A	1.78	0.67	1.44
Emission Rate (lb/hr)	N/A	17.80	4.11	5.33
Emission Rate (lb/MMBtu)	N/A	0.0066	0.002	0.002

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,582,950	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,582,950	SCFH

Weather Data

Barometric Pressure	29.53	in. Hg
Relative Humidity	88	%
Ambient Temperature	35	°F
Specific Humidity	0.003796	lb H_2O / lb air

Unit Data

Unit Load	372.2	megawatts
Stack Exhaust Flow (M19)	55,301,432	SCFH

Base Load Load, Run - 10

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/06/20 16:46:10	41270	11.90	2.69	1.94	2.35	9.27
02/06/20 16:46:40	41300	11.89	2.72	1.89	2.42	8.89
02/06/20 16:47:10	41330	11.88	2.73	1.70	2.37	8.49
02/06/20 16:47:40	41360	11.87	2.73	1.58	2.26	8.16
02/06/20 16:48:10	41390	11.87	2.69	1.43	2.25	7.70
02/06/20 16:48:40	41420	11.88	2.70	1.47	2.28	7.36
02/06/20 16:49:10	41450	11.88	2.72	1.58	2.47	7.17
02/06/20 16:49:40	41480	11.88	2.72	1.59	2.23	8.54
02/06/20 16:50:10	41510	11.89	2.70	1.60	2.31	8.02
02/06/20 16:50:40	41540	11.89	2.69	1.71	2.28	7.67
02/06/20 16:51:10	41570	11.88	2.69	1.76	2.11	7.80
02/06/20 16:51:40	41600	11.89	2.69	1.70	2.01	7.96
02/06/20 16:52:10	41630	11.89	2.69	1.70	1.94	8.39
02/06/20 16:52:40	41660	11.90	2.71	1.73	2.01	8.90
02/06/20 16:53:10	41690	11.88	2.73	1.49	2.04	10.19
02/06/20 16:53:40	41720	11.90	2.72	1.43	1.95	9.20
02/06/20 16:54:10	41750	11.90	2.75	1.33	1.92	9.00
02/06/20 16:54:40	41780	11.90	2.80	1.25	1.87	8.81
02/06/20 16:55:10	41810	11.92	2.81	1.22	1.86	8.69
02/06/20 16:55:40	41840	11.92	2.74	1.24	1.92	8.86
02/06/20 16:56:10	41870	11.92	2.69	1.33	1.96	8.59
02/06/20 16:56:40	41900	11.93	2.69	1.52	1.99	8.85
02/06/20 16:57:10	41930	11.93	2.68	1.58	2.11	8.95
02/06/20 16:57:40	41960	11.94	2.66	1.76	2.23	8.69
02/06/20 16:58:10	41990	11.94	2.66	1.69	2.13	9.26
02/06/20 16:58:40	42020	11.89	2.66	1.79	2.16	5.67
02/06/20 16:59:10	42050	11.89	3.55	3.57	3.02	5.96
02/06/20 16:59:40	42080	11.90	4.76	4.32	3.47	6.83
02/06/20 17:00:10	42110	11.88	4.90	4.64	3.57	6.64
02/06/20 17:00:40	42140	11.90	4.90	4.87	3.67	7.04
02/06/20 17:01:10	42170	11.90	4.90	4.84	3.60	6.89
02/06/20 17:01:40	42200	11.90	4.92	4.90	3.64	7.00
02/06/20 17:02:10	42230	11.92	4.99	4.87	3.62	7.24
02/06/20 17:02:40	42260	11.89	2.73	4.85	3.51	7.12
02/06/20 17:03:10	42290	11.50	2.73	1.58	1.89	7.08
02/06/20 17:03:40	42320	11.77	2.72	1.59	2.15	7.70
02/06/20 17:04:10	42350	11.80	2.75	1.60	2.01	8.22
02/06/20 17:04:40	42380	11.82	2.80	1.71	2.11	7.75
02/06/20 17:05:10	42410	11.83	2.81	1.76	2.16	7.50
02/06/20 17:05:40	42440	11.84	2.74	1.70	2.17	7.35
02/06/20 17:06:10	42470	11.86	2.69	1.70	2.19	7.30
02/06/20 17:06:40	42500	11.88	2.69	1.73	2.16	7.91
RAW AVERAGE		**11.88**	**3.05**	**2.17**	**2.39**	**7.97**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-OO14	INST-NX-0020	INST-CO-0045	INST-IR-0004
		(%)	(ppmvd)	(ppmvd)	
Bias	**Initial Zero**	0.08	0.08	0.00	
Bias	**Final Zero**	0.10	0.05	0.00	
Bias	**Avg. Zero**	0.09	0.07	0.00	
Bias	**Initial UpScale**	11.88	4.88	4.84	
Bias	**Final UpScale**	11.85	4.80	4.86	
Bias	**Avg. UpScale**	11.87	4.84	4.85	
Upscale Cal Gas		11.96	4.99	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	11.97	3.12	2.28	2.60
Concentration (ppm@ 15%O_2)	N/A	2.06	1.51	1.72
Emission Rate (lb/hr)	N/A	20.59	9.16	6.35
Emission Rate (lb/MMBtu)	N/A	0.0076	0.003	0.002

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
AETB/QI and PGVP RATA Data Sheet
Cricket Valley Energy Center

AirEmissionTestingData - Level 3

QILastName	QIFirstName	QIMiddleInitial	AETBName	AETBPhoneNumber	AETBEmail	ExamDate	ProviderName	ProviderEmail
Blum	Aaron	M	Air Hygiene International Inc	888-461-8778	info@airhygiene.com	01/31/2019	Source Evaluation Society	qstiprogram@gmail.com

ProtocolGasData - Level 3

GasLevelCode	GasTypeCode	CylinderIdentifier	VendorIdentifier	ExpirationDate
LOW	ZERO			
HIGH	BALN,CO2,O2	EB0080940	G12019	6/25/2027
MID	BALN,CO2,O2	EB0069916	G12019	6/30/2027
HIGH	BALN,CO,NO,NOX	EB0040961	G12019	10/30/2022
MID	BALN,CO,NO,NOX	EB0101718	G12019	7/25/2022

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

CERTIFICATE OF ANALYSIS
(Zero Ambient Nitrogen)

Cylinder Number:	CC731563	**Certification Date:**	12/12/2019
Product ID Number:	121026	**Expiration Date:**	12/10/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	CC731563.20191212-0	**Lot Number:**	CC731563.20191212
Customer PO. NO.:		**Tracking Number:**	098934324
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
PGVP Vendor ID # G12019
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

Anthony Cyr
Assistant Operations Manager

Version 02-B, Revised on 2015-05-27

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0051299	**Certification Date:**	03/29/2019
Product ID Number:	124731	**Expiration Date:**	03/28/2022
Cylinder Pressure:	1700 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0051299.20190304-0	**Lot Number:**	EB0051299.20190304
Customer PO. NO.:		**Tracking Number:**	073563600
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	**49.7 PPM**	±0.6 PPM	FTIR	03/08/2019, 03/22/2019, 03/29/2019

Air Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
D685060	D685060	11/16/2019	PRM	N2	NO2	98.8 PPM	1.01	C1579010.01
EB0090081	EB0090081.20161201	02/04/2021	GMIS	N2	NO2	96 PPM	1.055	5605008
EB0090101	EB0090101.20161201	08/26/2021	GMIS	AIR	NO2	63.6 PPM	1.031	5605008
EB0096848	EB0096848.20190102	03/21/2022	GMIS	AIR	NO2	61.1 PPM	1.072	C1579010.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	03/01/2019
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	03/21/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0101718	**Certification Date:**	07/26/2019
Product ID Number:	125564	**Expiration Date:**	07/25/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0101718.20190710-0	**Lot Number:**	EB0101718.20190710
Customer PO. NO.:		**Tracking Number:**	095705907
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**5.09 PPM**	±0.07 PPM	FTIR	07/25/2019
Nitric Oxide	**4.98 PPM**	±0.06 PPM	Chemiluminescence	07/16/2019, 07/26/2019
Total Oxides of Nitrogen	4.99 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0032297	EB0032297.20160725	09/06/2025	GMIS	N2	CO	6.15 PPM	1.067	091002
EB0060662	EB0060662.20151012	01/02/2022	GMIS	N2	NO	2.97 PPM	1.062	12100115
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002
EB0078555	EB0078555.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.113	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	07/08/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0040961	**Certification Date:**	10/31/2019
Product ID Number:	124737	**Expiration Date:**	10/30/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0040961.20191017-0	**Lot Number:**	EB0040961.20191017
Customer PO. NO.:		**Tracking Number:**	065159907
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**9.1 PPM**	±0.12 PPM	FTIR	10/30/2019
Nitric Oxide	**8.8 PPM**	±0.10 PPM	Chemiluminescence	10/23/2019, 10/31/2019
Total Oxides of Nitrogen	8.9 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM005307	ALM0053007.20181025	10/09/2022	GMIS	N2	NO	34.2 PPM	1.062	1684B
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002
EB0089797	EB0089797.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.085	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	10/18/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/30/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0018282	**Certification Date:**	02/27/2018
Product ID Number:	124606	**Expiration Date:**	02/25/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0018282.20180219-0	**Lot Number:**	EB0018282.20180219
Customer PO. NO.:		**Tracking Number:**	040342887
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.94 %**	±0.06 %	NDIR	02/27/2018
Oxygen	**11.96 %**	±0.06 %	MPA	02/23/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0019964	EB0019964.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0097755	EB0097755.20171018-0	12/26/2025	GMIS	N2	CO2	24.86 %	0.212	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	02/23/2018
CO2	NDIR	Thermo	410i	1162980025	02/26/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0096307	**Certification Date:**	09/13/2018
Product ID Number:	124605	**Expiration Date:**	09/11/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0096307.20180830-0	**Lot Number:**	EB0096307.20180830
Customer PO. NO.:		**Tracking Number:**	095690632
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**18.7 %**	±0.14 %	NDIR	09/13/2018
Oxygen	**21.1 %**	±0.11 %	MPA	09/04/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004987	EB0004987.20180323	07/15/2026	GMIS	N2	CO2	19.5 %	0.767	101001
EB0032246	EB0032246.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001
EB0097755	EB0097755.20171018-0	12/26/2025	GMIS	N2	CO2	24.86 %	0.212	C1309410.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	09/04/2018
CO2	NDIR	Thermo	410i	1162980025	08/14/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-I, Revised on 2017-09-07

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

Accreditation #62754

CERTIFIED GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0100161	**Certification Date:**	12/30/2019
Product ID Number:	125123	**Expiration Date:**	12/29/2020
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0100161.20191230-0	**Lot Number:**	EB0100161.20191230
Customer PO. NO.:		**Tracking Number:**	095703088
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Ammonia	**50.4 PPM**	± 2% NIST	FTIR
Sulfur Hexafluoride	**9.02 PPM**	± 2% NIST	FTIR
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
SA18481	70086910005	04/12/2020	PS	N2	NH3	21.1 PPM	1.2	73248226
EB0079029	EB0079029	06/27/2020	PS	N2	SF6	10.1 PPM	5	191064

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NH3	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	
SF6	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-G, Revised on 2017-07-02

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the "hands of the test" on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the "hands of the test" on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3 A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

Data Provided by Client

Data provided by the Client is clearly identified in the report. Air Hygiene accepts data provided by the Client as accurate.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO_2 to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO_2 in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS
QUALITY ASSURANCE DATA

Date: February 6, 2020
Company: Cricket Valley Energy Center LLC
Location: Dover Plains, New York
Techs: AB / SB / MJ / RW

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
February 6, 2020	1	0

Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This laboratory also meets the A2LA *R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (*refer to joint ISO-ILAC-IAF Communiqué dated April 2017*).

Presented this 18th day of December 2019

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2021

For the tests to which this accreditation applies, please refer to the laboratory's Envrionmental Scope of Accreditation.

STAC STACK TESTING ACCREDITATION COUNCIL

A2LA American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 18th day of December 2019.

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2021

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY

Qualified Source Testing Individual

LET IT BE KNOWN THAT

AARON M. BLUM

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 31ST DAY OF JANUARY 2019 AND EFFECTIVE UNTIL JANUARY 30TH, 2024

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Tina Sanderson, QSTI/QSTO Review Board

J. Wade Bice, QSTI/QSTO Review Board

Karen D. Kajiya-Mills , QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board


CERTIFICATE NO. 2019-1042

Calibration Date: February 6, 2020 **Location:** Cricket Valley Energy Center - Unit U-00001

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 8.90

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.13	1.46	0.13	YES (%)
4.99	4.90	-1.01	0.09	YES (%)
8.90	8.85	-0.56	0.05	YES (%)
Linearity = 1.022				




CO Span (ppm) = 9.10

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	0.00	0.00	0.00	YES (%)
5.09	5.04	-0.55	0.05	YES (%)
9.10	9.04	-0.66	0.06	YES (%)
Linearity = 1.007				



O_2 Span (%) = 21.10

SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	0.03	0.14	0.03	YES (%)
11.96	12.13	0.81	0.17	YES (%)
21.10	21.15	0.24	0.05	YES (%)
Linearity = 0.998				



NOx Converter Efficiency

Date: February 6, 2020

Analyzer: INST-NX-0020

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**49.10**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**1.98**
	Analyzer Reading, NOx Channel, ppmvd	**46.20**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**44.22**
	Converter Efficiency, %	**90.06**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{44.22 \text{ ppmvd}}{49.10 \text{ ppmvd}}$ x 100 = 90.06%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
02/06/20 04:08:41	10	43.70	1.31
02/06/20 04:09:11	20	45.78	1.44
02/06/20 04:09:41	30	46.13	1.98
02/06/20 04:10:11	40	46.16	1.87
02/06/20 04:10:41	50	46.09	1.59
02/06/20 04:11:11	60	46.08	1.53
02/06/20 04:11:41	***70***	***46.20***	***1.98***
02/06/20 04:12:11	80	46.16	1.29
02/06/20 04:12:41	90	46.11	1.59
02/06/20 04:13:11	100	46.04	1.98
02/06/20 04:13:41	110	46.02	1.89

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/06/20	4:02:10	UNIT 1 CTS_0016.LAB	9.1499
02/06/20	4:02:40	UNIT 1 CTS_0017.LAB	9.1572
02/06/20	4:03:10	UNIT 1 CTS_0018.LAB	9.1676
02/06/20	4:03:40	UNIT 1 CTS_0019.LAB	9.1188
02/06/20	4:04:10	UNIT 1 CTS_0020.LAB	9.0882

PRE TEST AVERAGE **9.14**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/06/20	17:06:23	UNIT 1 RUN 1_1554.LAB	8.8657
02/06/20	17:06:53	UNIT 1 RUN 1_1555.LAB	8.9168
02/06/20	17:07:23	UNIT 1 RUN 1_1556.LAB	8.9420
02/06/20	17:07:53	UNIT 1 RUN 1_1557.LAB	8.9551
02/06/20	17:08:23	UNIT 1 RUN 1_1558.LAB	8.9652

POST TEST AVERAGE **8.93**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.94

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.14	2.20	PASS
Post Test	8.93	-0.12	PASS

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/06/20	4:12:11	UNIT 1 CTS_0036.LAB	48.1623
02/06/20	4:12:41	UNIT 1 CTS_0037.LAB	48.3070
02/06/20	4:13:11	UNIT 1 CTS_0038.LAB	48.2363
02/06/20	4:13:41	UNIT 1 CTS_0039.LAB	48.3171
02/06/20	4:14:11	UNIT 1 CTS_0040.LAB	52.5737

PRE TEST AVERAGE **49.12**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/06/20	17:11:23	UNIT 1 RUN 1_1564.LAB	48.6648
02/06/20	17:11:53	UNIT 1 RUN 1_1565.LAB	48.5126
02/06/20	17:12:23	UNIT 1 RUN 1_1566.LAB	48.6104
02/06/20	17:12:53	UNIT 1 RUN 1_1567.LAB	48.6856
02/06/20	17:13:24	UNIT 1 RUN 1_1568.LAB	48.6479

POST TEST AVERAGE **48.62**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 50.40

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	49.12	-2.54	PASS
Post Test	48.62	-3.52	PASS

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd
02/06/20	10:01:12	UNIT 1 MKS_0715.LAB	49.8937
02/06/20	10:01:42	UNIT 1 MKS_0716.LAB	50.5868
02/06/20	10:02:12	UNIT 1 MKS_0717.LAB	50.7773
02/06/20	10:02:42	UNIT 1 MKS_0718.LAB	51.1750
02/06/20	10:03:12	UNIT 1 MKS_0719.LAB	50.8340
02/06/20	10:03:42	UNIT 1 MKS_0720.LAB	50.1201
02/06/20	10:04:12	UNIT 1 MKS_0721.LAB	50.4008
02/06/20	10:04:42	UNIT 1 MKS_0722.LAB	51.3256
RAW AVERAGE			**50.639**

Calibration Gas #2

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	SF_6 ppmvd
02/06/20	10:01:12	UNIT 1 MKS_0715.LAB	8.5800
02/06/20	10:01:42	UNIT 1 MKS_0716.LAB	9.2505
02/06/20	10:02:12	UNIT 1 MKS_0717.LAB	9.2269
02/06/20	10:02:42	UNIT 1 MKS_0718.LAB	8.3160
02/06/20	10:03:12	UNIT 1 MKS_0719.LAB	9.0714
02/06/20	10:03:42	UNIT 1 MKS_0720.LAB	8.9049
02/06/20	10:04:12	UNIT 1 MKS_0721.LAB	8.6702
02/06/20	10:04:42	UNIT 1 MKS_0722.LAB	9.0300
RAW AVERAGE			**8.881**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/06/20	10:13:44	UNIT 1 MKS_0740.LAB	4.9045	8.0644	2.6119	0.0023
02/06/20	10:14:13	UNIT 1 MKS_0741.LAB	4.8966	7.8960	2.7031	0.0007
02/06/20	10:14:43	UNIT 1 MKS_0742.LAB	4.8539	7.9603	2.7059	0.0040
02/06/20	10:15:14	UNIT 1 MKS_0743.LAB	4.9116	7.7106	2.6900	0.0011
02/06/20	10:15:44	UNIT 1 MKS_0744.LAB	4.9059	7.3395	2.7702	0.0034
02/06/20	10:16:14	UNIT 1 MKS_0745.LAB	4.9138	7.8191	2.7365	0.0027
02/06/20	10:16:44	UNIT 1 MKS_0746.LAB	4.9122	7.7627	2.8926	0.0016
02/06/20	10:17:14	UNIT 1 MKS_0747.LAB	4.9006	8.0150	2.8940	0.0012
RAW AVERAGE			**4.900**	**7.821**	**2.751**	**0.002**

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/06/20	10:22:14	UNIT 1 MKS_0757.LAB	4.4336	7.9904	0.6463	6.0694
02/06/20	10:22:45	UNIT 1 MKS_0758.LAB	4.6351	8.3572	0.4799	6.0142
02/06/20	10:23:15	UNIT 1 MKS_0759.LAB	4.4550	7.9387	0.6058	5.7743
02/06/20	10:23:45	UNIT 1 MKS_0760.LAB	4.5580	8.1196	0.5835	5.8970
02/06/20	10:24:15	UNIT 1 MKS_0761.LAB	4.7423	7.8069	0.6630	5.9287
02/06/20	10:24:45	UNIT 1 MKS_0762.LAB	4.7522	8.2259	0.5950	6.0521
02/06/20	10:25:15	UNIT 1 MKS_0763.LAB	4.7665	8.5664	0.8921	5.9248
02/06/20	10:25:45	UNIT 1 MKS_0764.LAB	4.5803	7.2462	0.8888	6.4658
RAW AVERAGE			**4.615**	**8.031**	**0.669**	**6.016**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/06/20	10:30:46	UNIT 1 MKS_0774.LAB	4.7072	7.7407	2.4026	0.0042
02/06/20	10:31:16	UNIT 1 MKS_0775.LAB	4.6366	7.4983	2.5836	0.0007
02/06/20	10:31:46	UNIT 1 MKS_0776.LAB	4.9443	7.3680	2.4952	0.0001
02/06/20	10:32:16	UNIT 1 MKS_0777.LAB	4.9212	7.8898	2.5232	-0.0011
02/06/20	10:32:46	UNIT 1 MKS_0778.LAB	4.9885	7.3362	2.9571	0.0023
02/06/20	10:33:16	UNIT 1 MKS_0779.LAB	4.9604	7.9213	2.3678	0.0041
02/06/20	10:33:46	UNIT 1 MKS_0780.LAB	4.8099	6.9881	2.3014	0.0048
02/06/20	10:34:16	UNIT 1 MKS_0781.LAB	4.7276	5.9417	3.2364	0.0042
RAW AVERAGE			**4.837**	**7.336**	**2.608**	**0.002**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/06/20	10:39:17	UNIT 1 MKS_0791.LAB	4.1330	8.1989	0.6653	6.2547
02/06/20	10:39:47	UNIT 1 MKS_0792.LAB	4.1392	8.1999	0.6304	6.0938
02/06/20	10:40:17	UNIT 1 MKS_0793.LAB	4.2215	8.2067	0.9029	6.7659
02/06/20	10:40:47	UNIT 1 MKS_0794.LAB	4.0741	8.2021	0.6562	6.2427
02/06/20	10:41:17	UNIT 1 MKS_0795.LAB	4.1539	8.2087	0.6616	5.9554
02/06/20	10:41:47	UNIT 1 MKS_0796.LAB	4.1656	8.2019	0.8568	5.9122
02/06/20	10:42:17	UNIT 1 MKS_0797.LAB	4.0611	8.2057	0.6001	5.8259
02/06/20	10:42:47	UNIT 1 MKS_0798.LAB	4.0528	8.2077	0.6741	5.8395
RAW AVERAGE			**4.125**	**8.204**	**0.706**	**6.111**

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvd	SF_6 ppmvd
02/06/20	10:47:48	UNIT 1 MKS_0808.LAB	5.0644	9.7160	3.1750	0.0049
02/06/20	10:48:18	UNIT 1 MKS_0809.LAB	4.8960	10.4714	3.1842	0.0044
02/06/20	10:48:48	UNIT 1 MKS_0810.LAB	4.9603	10.3049	3.1884	0.0015
02/06/20	10:49:18	UNIT 1 MKS_0811.LAB	4.7106	10.0702	3.1852	0.0008
02/06/20	10:49:48	UNIT 1 MKS_0812.LAB	4.3395	10.4300	3.1926	0.0021
02/06/20	10:50:18	UNIT 1 MKS_0813.LAB	4.8191	11.0380	3.1948	0.0028
02/06/20	10:50:48	UNIT 1 MKS_0814.LAB	4.7627	10.6346	3.2010	0.0046
02/06/20	10:51:18	UNIT 1 MKS_0815.LAB	5.0150	10.5166	3.1974	0.0035
RAW AVERAGE			**4.821**	**10.398**	**3.190**	**0.003**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvd	NH_3 ppmvd
02/06/20	10:56:19	UNIT 1 MKS_0825.LAB	4.2569	9.0291	0.7228	6.8281
02/06/20	10:56:49	UNIT 1 MKS_0826.LAB	4.2440	9.2053	0.8092	6.9286
02/06/20	10:57:19	UNIT 1 MKS_0827.LAB	4.2897	9.2605	0.6978	6.8757
02/06/20	10:57:49	UNIT 1 MKS_0828.LAB	4.3125	9.2440	0.6540	6.6419
02/06/20	10:58:19	UNIT 1 MKS_0829.LAB	4.2672	9.3134	0.7552	6.8622
02/06/20	10:58:49	UNIT 1 MKS_0830.LAB	4.2659	9.3660	0.6105	6.7587
02/06/20	10:59:19	UNIT 1 MKS_0831.LAB	4.2967	9.3788	0.7112	6.9752
02/06/20	10:59:50	UNIT 1 MKS_0832.LAB	4.2763	9.4653	0.8302	6.8134
RAW AVERAGE			**4.276**	**9.283**	**0.724**	**6.835**

Cricket Valley Energy Center LLC
February 6, 2020
General Electric, 7F.05, Unit #U-00001
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	50.64	50.64	50.64
Concentration of SF_6 Cylinder	ppmvd	8.88	8.88	8.88

Spike A

Stack CO_2 Concentration	%vw	4.900	4.837	4.821
Stack H_2O Concentration	%	7.821	7.336	10.398
Stack NH_3 Concentration	ppmvd	2.751	2.608	3.190
Stack SF_6 Concentration	ppmvd	0.002	0.002	0.003
Stack + Spike CO_2 Concentration	%vw	4.615	4.125	4.276
Stack + Spike H_2O Concentration	%	8.031	8.204	9.283
Stack + Spike NH_3 Concentration	ppmvd	6.016	6.111	6.835
Stack + Spike SF_6 Concentration	ppmvd	0.669	0.706	0.724
Dilution Ratio		0.075	0.079	0.082
Ideal NH_3 Spike Yield	ppmvd	6.360	6.426	7.057
Percent Recovery NH_3	%	90.99%	92.18%	94.63%

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	0.07	0.13
Final Zero	0.07	0.35
Avg. Zero	0.07	0.24
Initial UpScale	11.99	4.87
Final UpScale	11.86	4.71
Avg. UpScale	11.93	4.79
Sys Resp (Zero)	0.04	0.00
Sys Resp (Upscale)	11.99	4.98
Upscale Cal Gas	11.96	4.99
Initial Zero Bias	0.14%	1.46%
Final Zero Bias	0.14%	3.93%
Zero Drift	0.00%	2.47%
Initial Upscale Bias	0.00%	-1.24%
Final Upscale Bias	-0.62%	-3.03%
Upscale Drift	0.62%	1.80%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.13
Alternative Specification Abs Diff **Final Zero**	0.03	0.35
Alternative Specification Abs Diff **Initial Upscale**	0.00	0.11
Alternative Specification Abs Diff **Final Upscale**	0.13	0.27
Calibration Span	21.10	8.90
3% of Cal. Span (drift)	0.63	0.27
5% of Cal. Span (bias)	1.06	0.45

Respone Time (min)	1.7	4.0
Sys. Response (min)	4.0	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
02/05/20 14:15:10		**12.14**			3.02		x
02/05/20 14:15:20		**11.60**			3.02		
02/05/20 14:15:30		11.06			3.02		
02/05/20 14:15:40		10.52			3.02		
02/05/20 14:15:50		11.03			2.55		
02/05/20 14:16:00		**11.55**	x		2.08		
02/05/20 14:16:10		**12.07**			1.60		
02/05/20 14:16:20		**12.07**			1.27		
02/05/20 14:16:30		**12.07**			0.93		
02/05/20 14:16:40		**12.08**			0.60		
02/05/20 14:16:50		**12.08**			0.59		
02/05/20 14:17:00		**12.08**			0.58		
02/05/20 14:17:10		**12.08**			0.57		
02/05/20 14:17:20		**12.08**		x	**0.39**		
02/05/20 14:17:30		**12.08**			**0.21**		
02/05/20 14:17:40		**12.08**			**0.03**		
02/05/20 14:17:50		**12.08**			**-0.02**		
02/05/20 14:18:00		**12.08**			**-0.07**		
02/05/20 14:18:10		**12.08**			**-0.12**		
02/05/20 14:18:20		**12.08**			**-0.11**		
02/05/20 14:18:30		**12.09**			**-0.09**		x
02/05/20 14:18:40		**12.09**			**-0.07**		
02/05/20 14:18:50		**12.09**			**-0.07**		
02/05/20 14:19:00		**12.09**			**-0.07**		
02/05/20 14:19:10		**12.10**			**-0.07**		
02/05/20 14:19:20		9.77			**-0.05**		
02/05/20 14:19:30		7.44			**-0.03**		
02/05/20 14:19:40		5.11			**0.00**		
02/05/20 14:19:50		3.59			0.79		
02/05/20 14:20:00		2.08			1.58		
02/05/20 14:20:10	x	**0.56**			2.38		
02/05/20 14:20:20		**0.43**			3.11		
02/05/20 14:20:30		**0.30**			3.84		
02/05/20 14:20:40		**0.16**			4.57		
02/05/20 14:20:50		**0.14**			4.57		
02/05/20 14:21:00		**0.11**			4.58		
02/05/20 14:21:10		**0.09**			4.58		
02/05/20 14:21:20		**0.08**			4.57		
02/05/20 14:21:30		**0.08**			4.55		
02/05/20 14:21:40		**0.07**			4.54		
02/05/20 14:21:50		**0.07**			4.54		
02/05/20 14:22:00		**0.06**			4.55		
02/05/20 14:22:10		**0.06**			4.55		
02/05/20 14:22:20		**0.05**			4.62		
02/05/20 14:22:30		**0.05**			**4.68**		x
02/05/20 14:22:40		**0.05**			**4.75**		
02/05/20 14:22:50		**0.05**			**4.77**		

DRIFT AND BIAS CHECK			
Base Load Load, Run - 1	**O_2**	**NOx**	**CO**
Raw Average	11.96	2.90	0.03
Corrected Average	11.86	3.01	0.02
Initial Zero	0.04	-0.13	0.03
Final Zero	0.12	0.14	0.00
Avg. Zero	0.08	0.01	0.02
Initial UpScale	12.05	4.82	5.02
Final UpScale	12.06	4.81	4.97
Avg. UpScale	12.06	4.82	5.00
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.05%	-2.92%	0.33%
Final Zero Bias	0.43%	0.11%	0.00%
Zero Drift	0.38%	3.03%	0.33%
Initial Upscale Bias	-0.38%	-0.90%	-0.22%
Final Upscale Bias	-0.33%	-1.01%	-0.77%
Upscale Drift	0.05%	0.11%	0.55%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.26	0.03
Alternative Specification Abs Diff **Final Zero**	0.09	0.01	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.08	0.08	0.02
Alternative Specification Abs Diff **Final Upscale**	0.07	0.09	0.07
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 2	**O_2**	**NOx**	**CO**
Raw Average	11.69	2.54	0.43
Corrected Average	11.68	2.63	0.44
Initial Zero	0.12	0.14	0.00
Final Zero	0.09	-0.09	0.00
Avg. Zero	0.11	0.03	0.00
Initial UpScale	12.06	4.81	4.97
Final UpScale	11.88	4.79	4.85
Avg. UpScale	11.97	4.80	4.91
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.43%	0.11%	0.00%
Final Zero Bias	0.28%	-2.47%	0.00%
Zero Drift	0.14%	2.58%	0.00%
Initial Upscale Bias	-0.33%	-1.01%	-0.77%
Final Upscale Bias	-1.18%	-1.24%	-2.09%
Upscale Drift	0.85%	0.22%	1.32%
Alternative Specification Abs Diff **Initial Zero**	0.09	0.01	0.00
Alternative Specification Abs Diff **Final Zero**	0.06	0.22	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.07	0.09	0.07
Alternative Specification Abs Diff **Final Upscale**	0.25	0.11	0.19
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 3	**O_2**	**NOx**	**CO**
Raw Average	11.88	2.53	0.48
Corrected Average	11.97	2.67	0.51
Initial Zero	0.09	-0.09	0.00
Final Zero	0.07	-0.13	0.00
Avg. Zero	0.08	-0.11	0.00
Initial UpScale	11.88	4.79	4.85
Final UpScale	11.85	4.84	4.87
Avg. UpScale	11.87	4.82	4.86
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.28%	-2.47%	0.00%
Final Zero Bias	0.19%	-2.92%	0.00%
Zero Drift	0.09%	0.45%	0.00%
Initial Upscale Bias	-1.18%	-1.24%	-2.09%
Final Upscale Bias	-1.33%	-0.67%	-1.87%
Upscale Drift	0.14%	0.56%	0.22%
Alternative Specification Abs Diff **Initial Zero**	0.06	0.22	0.00
Alternative Specification Abs Diff **Final Zero**	0.04	0.26	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.25	0.11	0.19
Alternative Specification Abs Diff **Final Upscale**	0.28	0.06	0.17
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 4	**O_2**	**NOx**	**CO**
Raw Average	11.91	2.44	0.74
Corrected Average	12.02	2.64	0.76
Initial Zero	0.07	-0.13	0.00
Final Zero	0.11	-0.14	0.00
Avg. Zero	0.09	-0.14	0.00
Initial UpScale	11.85	4.84	4.87
Final UpScale	11.85	4.65	4.95
Avg. UpScale	11.85	4.75	4.91
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.19%	-2.92%	0.00%
Final Zero Bias	0.38%	-3.03%	0.00%
Zero Drift	0.19%	0.11%	0.00%
Initial Upscale Bias	-1.33%	-0.67%	-1.87%
Final Upscale Bias	-1.33%	-2.81%	-0.99%
Upscale Drift	0.00%	2.13%	0.88%
Alternative Specification Abs Diff **Initial Zero**	0.04	0.26	0.00
Alternative Specification Abs Diff **Final Zero**	0.08	0.27	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.28	0.06	0.17
Alternative Specification Abs Diff **Final Upscale**	0.28	0.25	0.09
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 5	**O_2**	**NOx**	**CO**
Raw Average	11.91	2.47	0.91
Corrected Average	12.02	2.68	0.93
Initial Zero	0.11	-0.14	0.00
Final Zero	0.09	-0.15	0.00
Avg. Zero	0.10	-0.15	0.00
Initial UpScale	11.85	4.65	4.95
Final UpScale	11.86	4.80	4.91
Avg. UpScale	11.86	4.73	4.93
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.38%	-3.03%	0.00%
Final Zero Bias	0.28%	-3.15%	0.00%
Zero Drift	0.09%	0.11%	0.00%
Initial Upscale Bias	-1.33%	-2.81%	-0.99%
Final Upscale Bias	-1.28%	-1.12%	-1.43%
Upscale Drift	0.05%	1.69%	0.44%
Alternative Specification Abs Diff **Initial Zero**	0.08	0.27	0.00
Alternative Specification Abs Diff **Final Zero**	0.06	0.28	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.28	0.25	0.09
Alternative Specification Abs Diff **Final Upscale**	0.27	0.10	0.13
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 6	**O_2**	**NOx**	**CO**
Raw Average	11.92	2.35	0.97
Corrected Average	12.04	2.47	1.01
Initial Zero	0.09	-0.15	0.00
Final Zero	0.07	0.08	0.00
Avg. Zero	0.08	-0.04	0.00
Initial UpScale	11.86	4.80	4.91
Final UpScale	11.83	4.77	4.89
Avg. UpScale	11.85	4.79	4.90
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.28%	-3.15%	0.00%
Final Zero Bias	0.19%	-0.56%	0.00%
Zero Drift	0.09%	2.58%	0.00%
Initial Upscale Bias	-1.28%	-1.12%	-1.43%
Final Upscale Bias	-1.42%	-1.46%	-1.65%
Upscale Drift	0.14%	0.34%	0.22%
Alternative Specification Abs Diff **Initial Zero**	0.06	0.28	0.00
Alternative Specification Abs Diff **Final Zero**	0.04	0.05	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.27	0.10	0.13
Alternative Specification Abs Diff **Final Upscale**	0.30	0.13	0.15
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 7	O_2	NOx	CO
Raw Average	11.93	2.84	1.13
Corrected Average	12.06	2.95	1.18
Initial Zero	0.07	0.08	0.00
Final Zero	0.11	-0.07	0.00
Avg. Zero	0.09	0.01	0.00
Initial UpScale	11.83	4.77	4.89
Final UpScale	11.85	4.84	4.84
Avg. UpScale	11.84	4.81	4.87
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.19%	-0.56%	0.00%
Final Zero Bias	0.38%	-2.25%	0.00%
Zero Drift	0.19%	1.69%	0.00%
Initial Upscale Bias	-1.42%	-1.46%	-1.65%
Final Upscale Bias	-1.33%	-0.67%	-2.20%
Upscale Drift	0.09%	0.79%	0.55%
Alternative Specification Abs Diff: Initial Zero	0.04	0.05	0.00
Alternative Specification Abs Diff: Final Zero	0.08	0.20	0.00
Alternative Specification Abs Diff: Initial Upscale	0.30	0.13	0.15
Alternative Specification Abs Diff: Final Upscale	0.28	0.06	0.20
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 8	O_2	NOx	CO
Raw Average	11.94	2.70	0.96
Corrected Average	12.07	2.78	1.01
Initial Zero	0.11	-0.07	0.00
Final Zero	0.10	0.04	0.00
Avg. Zero	0.11	-0.02	0.00
Initial UpScale	11.85	4.84	4.84
Final UpScale	11.82	4.89	4.84
Avg. UpScale	11.84	4.87	4.84
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.38%	-2.25%	0.00%
Final Zero Bias	0.33%	-1.01%	0.00%
Zero Drift	0.05%	1.24%	0.00%
Initial Upscale Bias	-1.33%	-0.67%	-2.20%
Final Upscale Bias	-1.47%	-0.11%	-2.20%
Upscale Drift	0.14%	0.56%	0.00%
Alternative Specification Abs Diff: Initial Zero	0.08	0.20	0.00
Alternative Specification Abs Diff: Final Zero	0.07	0.09	0.00
Alternative Specification Abs Diff: Initial Upscale	0.28	0.06	0.20
Alternative Specification Abs Diff: Final Upscale	0.31	0.01	0.20
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 9	**O_2**	**NOx**	**CO**
Raw Average	11.91	2.65	0.97
Corrected Average	12.02	2.67	1.01
Initial Zero	0.10	0.04	0.00
Final Zero	0.08	0.08	0.00
Avg. Zero	0.09	0.06	0.00
Initial UpScale	11.82	4.89	4.84
Final UpScale	11.88	4.88	4.84
Avg. UpScale	11.85	4.89	4.84
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.33%	-1.01%	0.00%
Final Zero Bias	0.24%	-0.56%	0.00%
Zero Drift	0.09%	0.45%	0.00%
Initial Upscale Bias	-1.47%	-0.11%	-2.20%
Final Upscale Bias	-1.18%	-0.22%	-2.20%
Upscale Drift	0.28%	0.11%	0.00%
Alternative Specification Abs Diff **Initial Zero**	0.07	0.09	0.00
Alternative Specification Abs Diff **Final Zero**	0.05	0.05	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.31	0.01	0.20
Alternative Specification Abs Diff **Final Upscale**	0.25	0.02	0.20
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 10	**O_2**	**NOx**	**CO**
Raw Average	11.88	3.05	2.17
Corrected Average	11.97	3.12	2.28
Initial Zero	0.08	0.08	0.00
Final Zero	0.10	0.05	0.00
Avg. Zero	0.09	0.07	0.00
Initial UpScale	11.88	4.88	4.84
Final UpScale	11.85	4.80	4.86
Avg. UpScale	11.87	4.84	4.85
Sys Resp (Zero)	0.03	0.13	0.00
Sys Resp (Upscale)	12.13	4.90	5.04
Upscale Cal Gas	11.96	4.99	5.09
Initial Zero Bias	0.24%	-0.56%	0.00%
Final Zero Bias	0.33%	-0.90%	0.00%
Zero Drift	0.09%	0.34%	0.00%
Initial Upscale Bias	-1.18%	-0.22%	-2.20%
Final Upscale Bias	-1.33%	-1.12%	-1.98%
Upscale Drift	0.14%	0.90%	0.22%
Alternative Specification Abs Diff **Initial Zero**	0.05	0.05	0.00
Alternative Specification Abs Diff **Final Zero**	0.07	0.08	0.00
Alternative Specification Abs Diff **Initial Upscale**	0.25	0.02	0.20
Alternative Specification Abs Diff **Final Upscale**	0.28	0.10	0.18
Calibration Span	21.10	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.06	0.45	0.46

APPENDIX E

STRATIFICATION TEST DATA

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric (GE) 7F.05 Combustion Turbine
Location	Dover Plains, New York

Test Information	
Date	02/05/20
Project #	cis-19-cricketvalley.ny-start#1
Unit Number	U-00001
Load	normal
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)**	☐ Part 60 ☑ Part 75	

Created with Traverse-AHI v20190211


METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	02/05/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.*
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2

*assume 8 in. reference (must be measured and verified in field)

Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters




Number of Traverse Points Required

Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points Comp Stratification	
Down (B_D)	Up (A_D)	Particulate	Velocity	Criteria	Points
Stream	Stream	Points	Points		
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
					points


[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	02/05/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	14:35:09	**Run End**	16:38:09

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	8.00	14:35:09	14:43:09	12.15	0.50%	2.57	7.47%
D-2	8.00	14:43:09	14:51:09	12.24	0.24%	2.62	5.67%
D-1	8.00	14:51:09	14:59:09	12.24	0.24%	2.56	**7.83%**
C-3	9.00	14:59:09	15:07:09	12.18	0.25%	2.70	2.79%
C-2	8.00	15:03:09	15:11:09	12.16	0.42%	2.77	0.27%
C-1	8.00	15:11:09	15:19:09	12.15	0.50%	2.87	3.33%
B-3	9.00	15:45:09	15:54:09	12.30	0.73%	2.90	4.41%
B-2	8.00	15:54:09	16:02:09	12.30	0.73%	2.76	0.63%
B-1	8.00	16:02:09	16:10:09	12.32	**0.89%**	2.93	5.49%
A-3	9.00	16:13:09	16:22:09	12.12	0.74%	2.97	6.93%
A-2	8.00	16:22:09	16:30:09	12.16	0.42%	2.88	3.69%
A-1	8.00	16:30:09	16:38:09	12.21	0.01%	2.80	0.81%
Average				12.21		2.78	

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	02/05/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	14:35:09	**Run End**	16:38:09

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	0.89 % for O_2
Maximum Pollutant Conc. Diff.	0.22 ppm for NOx
Maximum Diluent Conc. Diff.	0.11 % for O_2

Stratification Conclusions	
Comparison	at least one diluent/pollutant
Stack Diameter	D > 93.6 in.


Under Part 75 criteria at least one measured pollutant or diluent demonstrates a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type

- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

- ☐ Use 6.5.6.3(a) points?
- ☐ 6.5.6(b)(2) alt. points could apply



this page intentionally left blank
end of report

APPENDIX 7

FUEL FLOWMETER ACCURACY TEST/PRIMARY ELEMENT VISUAL INSPECTION DOCUMENTATION

Endress+Hauser

People for Process Automation

Standard Density Calibration with Adjustment

31128647-4374500-5130590

PROMASS 83 F 6"
Transmitter/Sensor


N301CF16000
Serial N°

FCP-7.1.F
Calibration rig

C0 = -2138.5 C1 = 1.8178E+8
Density coefficient

C2 = -87071 C3 = 8543.6
Density coefficient

Medium	Temp. [°F]	ρ target [kg/m³]	ρ meas. [kg/m³]	Δρ [kg/m³]	Freq. [Hz]
Air	70.1	1.20	1.20	0.00	290.1
Water	67.3	999.07	999.07	0.00	239.7
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–



Endress+Hauser Flowtec operates ISO/IEC 17025 accredited calibration facilities in Reinach (CH), Cernay (FR), Greenwood (USA), Aurangabad (IN), Suzhou (CN) and Itatiba (BR).

Scott Newcomer

03-14-2018
Date of calibration

S. Newcomer
Operator

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Certified acc. to
ISO 9001, Reg.-N° 030502.2
ISO 14001, Reg.-N° EMS561046

Endress+Hauser
People for Process Automation

Certificate

Flow Calibration with Adjustment

30427954

American Association for Laboratory Accreditation, Cert. No 1897.01

Calibration laboratory accredited according to ISO/IEC 17025:2005


3800368764 Purchase order number	FCP-7.1.F / gravimetric Calibration rig/Method
CORETECH INDUSTRIAL CORPORATION Customer	4776.682 lb/min (≙ 100%) Calibrated full scale
US-3005947899-10 / Endress+Hauser Flowtec Order N°/Manufacturer	Service interface Calibrated output
PROMASS 83 F 6" Transmitter/Sensor	0.90972 Calibration factor
N301CF16000 / N301CF16000 Serial N°	-35 Zero point
Manufacture for GE, Supplier:Core Tech Tag N°	66.9 °F ±0.12 °F Water temperature
New Condition	0.048 % Expanded uncertainty of measurement

Flow [%]	Flow [lb/min]	Duration [s]	m target [lb]	m meas. [lb]	Δ o.r.* [%]	Outp.** [mA]
20.0	956.801	60.3	961.151	961.091	-0.006	7.20
35.5	1696.51	35.3	997.569	997.711	0.014	9.68
49.6	2367.42	30.3	1194.72	1194.68	-0.003	11.93
75.2	3592.07	30.3	1813.13	1812.86	-0.015	16.03
99.0	4727.02	30.3	2385.52	2385.44	-0.003	19.83
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–

*o.r.: of reading

**Calculated value (4 - 20 mA)

Measured error % o.r.



For detailed data concerning output specifications of the unit under test, see Technical Information (TI), chapter Performance characteristics.

Calibration, traceable to NIST, has been completed on the instruments used in the equipment calibration process (see attached listing).

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approx. 95%. The expanded uncertainty of measurement includes uncertainty components of the reference, the calibration method, the environment and of the device under test. A typical value is used for the uncertainty component of the device

Scott Newcomer

03-14-2018
Date of calibration

S. Newcomer
Operator

This certificate shall not be published or reproduced other than in full, except with the prior written approval of the issuing laboratory.

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Certificate Addendum

Endress+Hauser
People for Process Automation

CORETECH INDUSTRIAL CORPORATION	12020 - BALLSTON SPA
Customer name	Customer address
Endress+Hauser Flowtec, Div. USA	6"
Manufacturer	Nominal diameter
US-3005947899-10 / 83F1F-CP77/0	FCP-7.1.F
Customer order N°/Order code	Calibration rig
N301CF16000 / N301CF16000	30427954
Serial N°	Record N°
New	03-14-2018
Condition	Calibration date
-	0.048 %
Customer specified calibration due date	Uncertainty of measurement (o.r.%)
PRD-TI-024	
Calibration work procedure	

Instruments used in the calibration rig:

Asset N°	Manufacturer	Model	Description	NIST/Cert N°	Cal. date	Cal. due date
F10795	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008066	05-19-2017	06-01-2018
F10796	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008067	05-19-2017	06-01-2018
F10797	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Outlet)	008068	05-19-2017	06-01-2018
F10798	Endress+Hauser	TST434-K1B3A0	RTD - Ambient	008078	05-19-2017	06-01-2018
F10799	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008069	05-19-2017	06-01-2018
F10800	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008070	05-19-2017	06-01-2018
F10801	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008072	05-19-2017	06-01-2018
F10802	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008073	05-19-2017	06-01-2018
F10803	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008075	05-19-2017	06-01-2018
F10804	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008074	05-19-2017	06-01-2018
F10806	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008076	05-19-2017	06-01-2018
F10807	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008077	05-19-2017	06-01-2018
F10808	Endress+Hauser	-	Large Scale Diverter	008062	05-19-2017	06-01-2018
F10809	Beckhoff	KL1501	Counter/Timer	008064	05-19-2017	06-01-2018
F10810	Beckhoff	KL1501	Counter/Timer	008063	05-19-2017	06-01-2018
F10811	Endress+Hauser	-	Small Scale Diverter	008061	05-19-2017	06-01-2018
F10813	HBM	DMP 40	Digital Scale Amplifier and scales	008060	05-19-2017	06-01-2018
-	-	-	-	-	-	-

Calibration traceable to NIST has been completed on the instrument listed above by using known working procedures and standards certified by the manufacturers and/or secondary testing laboratories to traceable to NIST. This calibration has been completed using standards having a minimum accuracy of at least four times greater than the instrument listed above. This calibration was conducted in accordance with ISO 17025:2005 and ANSI/NCSL Z540-1. Reported uncertainties represent expanded uncertainties expressed at approximately 95% confidence level using a coverage factor of k=2.

Debbie Carver

ilac-MRA A2LA ACCREDITED

Certified according to ISO 17025:2005
Certification N° 1897.01

Debbie Carver
Calibration supervisor

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Endress+Hauser

People for Process Automation

Abnahmeprüfzeugnis nach EN 10204 – 3.1
Inspection certificate acc. to EN 10204 – 3.1

Zeugnis-Nr./Certificate No. US – 3005947899

Es wird bescheinigt, dass die gelieferten Erzeugnisse den Vereinbarungen bei der Bestellung entsprechen. Darüber hinaus wird bescheinigt, dass bei der Herstellung der nachstehend aufgeführten Erzeugnisse die vorgeschriebenen Prüfungen und/oder die zusätzlich aufgeführten Prüfungen nach den bestehenden Prüfvorgaben durchgeführt und die erforderlichen Freigaben erteilt wurden. Die unten aufgeführten Prüfungen wurden durch eine dazu autorisierte Person durchgeführt.

It is certified that the products supplied are in compliance with the requirements of the order. Furthermore, it is confirmed that during the manufacturing of the subsequently listed products the specified inspections and/or the additionally ordered tests have been performed according to the valid procedures and the necessary releases have been given. The subsequently listed inspections have been performed by especially authorized personnel.

Kunde/Customer	:	CORETECH INDUSTRIAL CORPORATION US – 12020 – BALLSTON SPA
Kunden Bestell-Nr./Customer Order No.	:	111063
E+H-Auftrags-Nr./E+H Order No.	:	3800368764

Pos./Item	Menge/Qty.	Produktbezeichnung/Description
10	1	83F1F-CP77/0 PROMASS 83 F 6" S/N.: N301CF16000 Tag-Nr.: Manufacture for GE, Supplier:Core Tech

Abnahmeprüfzeugnisse nach EN 10204 – 3.1/Inspection Certificates acc. to EN 10204 – 3.1:
Messrohr/Measuring tube: 51588, Franz Iten AG
Verteilerstück/Flow splitter: 270138, Bächler Feintech AG
Prozessanschluss/Process connection: 16CT12819, Jiangyin Unique Flange Manufacturing Co., Ltd.

Datum/Date 03-15-2018

Endress+Hauser Flowtec, Division USA
Greenwood, IN 46143 USA

Chris Brown

Abnahmebeauftragter
Inspector

Dieses Dokument wurde elektronisch nach EN 10204 erstellt und ist ohne Unterschrift gültig.
This document was generated electronically acc. to EN 10204 and is valid without signature.

Endress+Hauser
People for Process Automation

Parameter Setting

30409322-4374500

3800368764	PROMASS 83 F
Purchase order number	Transmitter/Sensor
3005947899-10 / Endress+Hauser Flowtec	6"
Order N°/Manufacturer	Nominal diameter
83F1F-CP77/0	Manufacture for GE, Supplier:Core Tech
Order code	Tag N°
N301CF16000	
Serial N°	

The below parameters are set according to your order.
Please refer to the Operating Manual for any parameters not mentioned.

Communication type	MODBUS RS485
Device software	V3.06.10
Device address	247
<u>Current output 1</u>	
Current span	4-20 mA US
Value 0/4 mA	0 lb/min
Value 20 mA	4800 lb/min
Time constant	1 s
Failsafe mode	Minimum current
<u>Pulse output 1</u>	
Pulse value	200 lb
Pulse width	100 ms
Output signal	passive/positive
Failsafe mode	Fallback value

03-13-2018
Date

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

ENDRESS + HAUSER INC.
2350 Endress Place
Greenwood, IN 46143
Phone: (888)ENDRESS

Endress+Hauser
People for Process Automation

CERTIFICATE OF COMPLIANCE

CUSTOMER NAME : CORETECH INDUSTRIAL CORPORATION

CUSTOMER P.O.#: 112245

ALL ITEMS FURNISHED WITH THIS SHIPMENT ARE IN COMPLIANCE WITH THE MODEL NUMBERS ORDERED ON THE REFERENCED PURCHASE ORDER, AND PUBLISHED ENDRESS+HAUSER SPECIFICATION REQUIREMENTS.
THE INSTRUMENT(S) PROVIDED ARE MANUFACTURED, TESTED, AND INSPECTED IN ACCORDANCE WITH ACCEPTED INDUSTRY MANUFACTURING PRACTICES, ISO9001 GUIDELINES, THE GRAVIMETRIC METHOD USED IN ACCORDANCE WITH ASME MFC 9M:2006, AND ENDRESS+HAUSER SPECIFICATIONS.

ENDRESS+HAUSER SALES ORDER NUMBER: 3003821102

Signed and Dated By: Gregg Miller 02/12/2020
(Dispatching Manager)

S.O. LINE	MODEL NUMBER	QTY	EXT. MODEL NUMBER	TAG NUMBER	SERIAL NUMBER
10	83F1F-CP77/0	1	83F1F-CABSBGR4BABN+Z1	125T3664G001 GE PO# 610575460/3	N600E816000

EMERSON

24 February, 2018

Emerson Automation Solutions
8200 Market Blvd
Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information

Name: FORNEY CORP
PO: 790542

Manufacturer Information

Sales Order: 5116125
Line: 1

Device Information

Device Type: Pressure Transmitter
Customer Ref/ID: N/A
Serial No: 0011949

Model No: 3051SMV5M13G3R2A11A1AC12C2E5M5Q4

Module Serial No: 18019960
Output: Linear
Device ID: 33194

Calibration Information

Factory: Chanhassen, MN, USA
Station Name: CHAN_DPFLOW_CALIBRATION_01
Operator ID: 59869
Calibration Date: 02/23/2018 08:22:01 AM

Internal Ref #: 30073090

Permanent Tag Information

DUCT BURNER
FLOW TRANSMITTER

Wire-On Tag Information

Attached Models

0305RC92B21B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-58610	Load Box	7/20/2018 2:17:00PM
E3-60655	Multimeter	9/20/2018 3:07:00PM
E3-60786	Precision Resistance Decade	7/9/2018 10:38:00AM
P3-54917	Pressure Controller	4/12/2018 1:13:00PM
P3-55113	Pressure Controller	5/2/2018 10:27:00AM

Calibration Data

DP

Reference of Calibration: Differential

Range: 0.000 TO 150.000 InH2O@68degF

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (InH2O@68degF)	% Span Error	Pass/Fail
99.994	5.409 PSI	149.99050 InH2O@68degF	149.98700	-0.00233	PASS
79.991	4.327 PSI	119.98680 InH2O@68degF	119.98820	0.00093	PASS
59.989	3.245 PSI	89.98320 InH2O@68degF	89.97474	-0.00564	PASS
39.986	2.163 PSI	59.97956 InH2O@68degF	59.97218	-0.00492	PASS
19.984	1.081 PSI	29.97591 InH2O@68degF	29.97556	-0.00023	PASS
0.000	0.000 PSI	0.00000 InH2O@68degF	-0.00493	-0.00329	PASS

SP

Reference of Calibration: Gauge

Range: 0.000 TO 100.000 PSI

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (PSI)	% Span Error	Pass/Fail
100.000	100.000 PSI	100.00000 PSI	100.00050	0.00050	PASS
80.000	80.000 PSI	80.00000 PSI	80.00269	0.00269	PASS
60.000	60.000 PSI	60.00000 PSI	60.00123	0.00123	PASS
40.000	40.000 PSI	40.00000 PSI	40.00577	0.00577	PASS
20.000	20.000 PSI	20.00000 PSI	20.00554	0.00554	PASS
0.000	0.000 PSI	0.00000 PSI	0.00476	0.00476	PASS

PT

Range: 0.000 TO 150.000 DEG F

Damping: 0.40 seconds

% of Range	Applied Resistence	Applied Resistence	Digital Output (DEG F)	Error (DEG F)	Pass/Fail
100.000	125.373 Ohms	150.00000 DEG F	149.98980	-0.01020	PASS
80.000	118.969 Ohms	120.00000 DEG F	119.97740	-0.02260	PASS
60.000	112.533 Ohms	90.00000 DEG F	90.00949	0.00949	PASS
40.000	106.066 Ohms	60.00000 DEG F	59.98681	-0.01319	PASS
20.000	99.566 Ohms	30.00000 DEG F	29.95533	-0.04467	PASS
0.000	93.033 Ohms	0.00000 DEG F	-0.03553	-0.03553	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Heather Matthiesen
Quality Manager

Reginald Williams

From: Carr, Peter <pcarr@bechtel.com>
Sent: Saturday, March 07, 2020 3:22 PM
To: Reginald Williams
Cc: Cricket Valley RES; Kenner, Bruce; Putman, Christopher
Subject: Duct Burner Flow Gas Meter - Statement for CEMS Certification Report
Attachments: RE: CVEC Unit 1 CEMS Certification Report - Bechtel and Owner Comments [*EXTERNAL*]

Reggie:

This statement below from Evan Keiper hopefully satisfies your request regarding the duct burner gas flow meter orifice plate.

This statement and the other email from Evan (attached) regarding the calibration drift matters should satisfy most of your Unit 1 CEMS concerns.

The questions (7 and 8) regarding calibration gases for the linearity tests were not in Evan's purview. I would recommend contacting the CISCO specialist performing the linearity test regarding this information.

Please let me know, if you any additional concerns regarding completion of the Unit 1 CEMS Certification Report.

Regards,

Peter Carr
Principal Environmental Scientist
Reston Office (RO1, 5th floor, C090)
571-392-6737 (Work)
240-344-0897 (Cell)

From: Keiper, Evan <edkeiper@bechtel.com>
Sent: Saturday, March 7, 2020 4:33 PM
To: Carr, Peter <pcarr@bechtel.com>
Cc: Gaydon, Matthew <magaydon@bechtel.com>; Putman, Christopher <csputman@bechtel.com>; Kenner, Bruce <bkenner@bechtel.com>; Curran, John <jdcurran@bechtel.com>
Subject: RE: Duct Burner Flow Gas Meter - Statement for CEMS Certification Report

Peter,

As the responsible I&C Startup lead on the project, I can attest that the Unit 1 duct burner fuel flow meter including the orifice run was installed correctly onsite and no nonconformances or defects were noted during its initial checkout and placement into operation. Similarly, the orifice plate and transmitter taps were installed per design and are correctly orientated for proper fuel flow measurement. I have also reviewed the AGA calibration records related to the Unit 1 fuel flow meter and noted no issues.

Regards,

Evan Keiper
Bechtel Infrastructure and Power Corp.

Cricket Valley Energy Center
Startup Instrumentation & Controls
D: 571-392-6330
M: 234-207-0424

APPENDIX 8

GAS CYLINDER CERTIFICATION SHEETS

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC712750	**Certification Date:**	06/28/2019
Product ID Number:	125597	**Expiration Date:**	06/27/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC712750.20190613-0	**Lot Number:**	CC712750.20190613
Customer PO. NO.:		**Tracking Number:**	097026895
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**48.8 PPM**	±0.13 PPM	FTIR	06/19/2019
Nitric Oxide	**49.4 PPM**	±0.5 PPM	Chemiluminescence	06/19/2019, 06/28/2019
Total Oxides of Nitrogen	49.7 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
FF18347	04-L-68	04/04/2021	SRM	N2	CO	49.136 PPM	0.132	1678c
CC238430	CC238430.20181025	02/03/2027	GMIS	N2	NO	92 PPM	1.06	12100115
CC726153	CC726153.20190328	06/04/2027	GMIS	N2	CO	48.6 PPM	0.239	1678c
EB0049172	EB0049172.20181025	02/05/2022	GMIS	N2	NO	34 PPM	1.104	12100115
EB0078547	EB0078547.20171228	07/17/2026	GMIS	N2	NO	62.4 PPM	1.064	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	42i-HL	1152610017	06/05/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/06/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Jasmine Godfrey

Jasmine Godfrey
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC719253	**Certification Date:**	09/26/2018
Product ID Number:	124122	**Expiration Date:**	09/24/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC719253.20180910-0	**Lot Number:**	CC719253.20180910
Customer PO. NO.:		**Tracking Number:**	098490608
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**113.0 PPM**	±0.9 PPM	FTIR	09/24/2018
Nitric Oxide	**109.4 PPM**	±0.8 PPM	Chemiluminescence	09/17/2018, 09/26/2018
Total Oxides of Nitrogen	110.8 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC349590	CC349590.20170821	12/03/2025	GMIS	N2	NO	294 PPM	0.451	2735
EB0024184	EB0024184.20171228	05/22/2026	GMIS	N2	NO	91 PPM	1.061	12100115
EB0059475	EB0059475.20180102	09/18/2026	GMIS	N2	CO	710 PPM	0.635	1681B

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	42i-HL	1152610017	08/31/2018
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/24/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Airgas
an Air Liquide company

02/15/20

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI78E15A0124	Reference Number:	160-401495594-1
Cylinder Number:	ALM010779	Cylinder Volume:	146.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	May 09, 2019

Expiration Date: May 09, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	22.00 %	22.15 %	G1	+/- 0.3% NIST Traceable	05/09/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120620	CC367413	22.883 % OXYGEN/NITROGEN	0.22%	May 14, 2026

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS OXYMAT 6 - W5951 - O2	PARAMAGNETIC	Apr 25, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

01/24/20 NO/NOX-CO/N

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401543888-1
Cylinder Number:	ALM034669	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 22, 2019

Expiration Date: Jul 22, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	176.8 PPM	G1	+/- 0.5% NIST Traceable	07/15/2019, 07/22/2019
NITRIC OXIDE	180.0 PPM	176.8 PPM	G1	+/- 0.5% NIST Traceable	07/15/2019, 07/22/2019
CARBON MONOXIDE	1700 PPM	1709 PPM	G1	+/- 0.5% NIST Traceable	07/15/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060130	KAL004288	249.9 PPM NITRIC OXIDE/NITROGEN	+/- 0.4%	Nov 08, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

01/25/20

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401524134-1
Cylinder Number:	ALM-032192	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	179.2 PPM	G1	+/- 0.6% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	180.0 PPM	179.2 PPM	G1	+/- 0.6% NIST Traceable	06/17/2019, 06/24/2019
CARBON MONOXIDE	1700 PPM	1731 PPM	G1	+/- 0.6% NIST Traceable	06/17/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060130	KAL004288	249.9 PPM NITRIC OXIDE/NITROGEN	+/- 0.4%	Nov 08, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jun 06, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 06, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 06, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

12/29/19

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401523613-1
Cylinder Number:	CC103280	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jun 20, 2019

Expiration Date: Jun 20, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	7.064 PPM	G1	+/- 0.6% NIST Traceable	06/20/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	061207	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	0.51%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jun 07, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401523613-1
Cylinder Number:	CC152351	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jun 20, 2019

Expiration Date: Jun 20, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	7.044 PPM	G1	+/- 0.6% NIST Traceable	06/20/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	061207	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	0.51%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jun 07, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
600 Union Landing Road
Cinnaminson, NJ 08077-0000
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	82-401326179-1
Cylinder Number:	CC477737	Cylinder Volume:	144.3 CF
Laboratory:	124 - Riverton (SAP) - NJ	Cylinder Pressure:	2015 PSIG
PGVP Number:	B52018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Oct 25, 2018

Expiration Date: Oct 25, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.037 PPM	G1	+/- 1.4% NIST Traceable	10/17/2018, 10/25/2018
NITRIC OXIDE	9.000 PPM	9.037 PPM	G1	+/- 1.1% NIST Traceable	10/17/2018, 10/25/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRMplus	13061101	CC403855	10.14 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jan 02, 2021
NTRMplus	13061101	CC403855-NOX	10.14 PPM NOx/NITROGEN	+/- 1.0%	Jan 02, 2021

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 42i-LS-NO-1123749326	Chemiluminescence	Oct 05, 2018
Thermo 42i-LS-NOx-1123749326	Chemiluminescence	Oct 05, 2018

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI78E15A0124	Reference Number:	160-401525182-1
Cylinder Number:	ALM047631	Cylinder Volume:	146.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jun 18, 2019

Expiration Date: Jun 18, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	22.00 %	22.21 %	G1	+/- 0.7% NIST Traceable	06/18/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120620	CC367413	22.883 % OXYGEN/NITROGEN	0.22%	May 14, 2026

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS OXYMAT 6 - W5951 - O2	PARAMAGNETIC	May 23, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

01/15/20

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	CC342258	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.895 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.865 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

12/16/19
NOX/L

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401515527-1
Cylinder Number:	CC259107	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 19, 2019

Expiration Date: Jun 19, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.816 PPM	G1	+/- 1.0% NIST Traceable	06/12/2019, 06/19/2019
NITRIC OXIDE	9.000 PPM	8.761 PPM	G1	+/- 0.9% NIST Traceable	06/12/2019, 06/19/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	May 22, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	May 22, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

12/26/19
NOX/H-CO/H

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401524134-1
Cylinder Number:	SG9164791BAL	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	179.2 PPM	G1	+/- 0.5% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	180.0 PPM	179.1 PPM	G1	+/- 0.5% NIST Traceable	06/17/2019, 06/24/2019
CARBON MONOXIDE	1700 PPM	1728 PPM	G1	+/- 0.7% NIST Traceable	06/17/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060130	KAL004288	249.9 PPM NITRIC OXIDE/NITROGEN	+/- 0.4%	Nov 08, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jun 06, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 06, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 06, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

C/L
02/22/20

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401523613-1
Cylinder Number:	SG910481	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jun 20, 2019

Expiration Date: Jun 20, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	7.067 PPM	G1	+/- 0.6% NIST Traceable	06/20/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	061207	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	0.51%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jun 07, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401523613-1
Cylinder Number:	ALM050865	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jun 20, 2019

Expiration Date: Jun 20, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	7.060 PPM	G1	+/- 0.6% NIST Traceable	06/20/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	061207	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	0.51%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jun 07, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

10/L 12/04/19

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	CC327876	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.903 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.855 PPM	G1	+/- 0.8% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

12/13/19 O2

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI78E15A0124	Reference Number:	160-401525182-1
Cylinder Number:	CC362148	Cylinder Volume:	146.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jun 18, 2019

Expiration Date: Jun 18, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	22.00 %	22.19 %	G1	+/- 0.4% NIST Traceable	06/18/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120620	CC367413	22.883 % OXYGEN/NITROGEN	0.22%	May 14, 2026

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS OXYMAT 6 - W5951 - O2	PARAMAGNETIC	May 23, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

0920 02/04/20 no/L

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	EB0108627	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.926 PPM	G1	+/- 1.2% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.893 PPM	G1	+/- 1.2% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

✓ 11/8/19 JLB

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	CC485366	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.878 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.849 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	CC220526	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.791 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.758 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

CHANGED 10/19
-EDH

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	CC 700357	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.005 PPM	G1	+/- 1.0% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.979 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

Approved for Release

HiQ® Certificate / Certificat HiQ®

LINDE CANADA LIMITED
530 Watson St. East
Whitby, ON, Canada L1N 5R9

CERTIFICATE OF ANALYSIS — EPA PROTOCOL MIXTURE

Purchase order # 110585036
Lot # 1263941
Cylinder Number: EB 0049417

PGVP ID # L12013
Procedure: G1
Gas Type Code: OC2
Cylinder pressure: 2000 psig

Certification date
August 12, 2013

Expiration Date
August 13, 2021

ANALYTICAL RESULTS

Component	Requested Concentration ± blending tolerance	Date of Assay	Mean Concentration	Certified Concentration Uncertainty expressed at 95% confidence
Carbon Dioxide	5 % ± 5%	August 12, 2013	5.01 %	5.01 ± 0.02 %
Oxygen	6 % ± 5%	August 9, 2013	6.03 %	6.03 ± 0.01 %

BALANCE GAS: Nitrogen

REFERENCE STANDARDS

Component	Type	Serial Number	Reference Number	Concentration	Expiration Date
Carbon Dioxide	GMIS NTRM	SX 21992 SG 9916842	1187915 101001	10 ± 0.02 % 19.98 ± 0.14 %	August 20, 2013 April 15, 2016
Oxygen	GMIS NTRM	SX 31579 CC 237234	1107503 071001	9.975 ± 0.06 % 24.12 ± 0.12 %	August 18, 2013 March 27, 2017

CERTIFICATION INSTRUMENTS

Component	Make/Model	Measurement Principle	Serial Number	Last Calibration
Carbon Dioxide	SICK MCS 100E	Infrared Photometer	04310670	August 1, 2013
Oxygen	Servomex 04100 C1	Paramagnetic Sensor	392350	August 9, 2013

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE 2012 EPA PROTOCOL PROCEDURE

DO NOT USE THIS CYLINDER WHEN THE PRESSURE FALLS BELOW 100 PSIG

Analyst: Keith Cybulski Signature _____ Date 08/12/13

Notes:

Tel: 1-(866) 385-5349 Fax:1-(866) 385-5347 service@lindecanada.com

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0053431	**Certification Date:**	06/15/2015
Product ID Number:	124822	**Expiration Date:**	06/13/2023
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0053431.20150611-0	**Lot Number:**	EB0053431.20150611
Customer PO. NO.:		**Tracking Number:**	074201901
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Oxygen	**13.46 %**	±0.06 %	MPA
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0055414.20140228-1C	10/07/2022	GMIS	N2	O2	23.8 %	0.505	071001
LD131022.115903.1G	10/07/2022	GMIS	N2	O2	11.97 %	0.527	071001

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
O2	MPA	Horiba	VA-3013	H0000P11	5/22/2015 12:35:56 PM

Red Ball Technical Gas Service
PGVP Vendor ID # G12015
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

LaMeka Dennis
Assistant Operations Manager

Airgas
an Air Liquide company

02/15/20

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI78E15A0124	Reference Number:	160-401495594-1
Cylinder Number:	ALM010779	Cylinder Volume:	146.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	May 09, 2019

Expiration Date: May 09, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	22.00 %	22.15 %	G1	+/- 0.3% NIST Traceable	05/09/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120620	CC367413	22.883 % OXYGEN/NITROGEN	0.22%	May 14, 2026

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS OXYMAT 6 - W5951 - O2	PARAMAGNETIC	Apr 25, 2019

Triad Data Available Upon Request

Approved for Release

<<<<END OF DOCUMENT>>>>

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CRICKET VALLEY ENERGY CENTER
DUTCHESS COUNTY, NEW YORK

ORIS CODE: 57185
UNIT U-00002 (U002)

PART 75 INITIAL CEMS AND FUEL FLOWMETERS CERTIFICATION TEST REPORTS

AND

PART 60 INITIAL CEMS CERTIFICATION TEST REPORTS

PREPARED FOR: GENERAL ELECTRIC

PREPARED BY: CUSTOM INSTRUMENTATION SERVICES, CORP. (CiSCO)

Date: March 29, 2020

Revision: 0a COPY NO:

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX: (303) 790-7292

TABLE OF CONTENTS

1. INTRODUCTION **3**

2. CEMS CERTIFICATION **6**

2.1 RELATIVE ACCURACY TEST AUDIT 6
2.2 BIAS CHECK 7
2.3 7-DAY CALIBRATION ERROR/DRIFT & ONLINE/OFFLINE DEMONSTRATION TESTS 7
2.4 LINEARITY CHECK 7
2.5 CYCLE TIME & RESPONSE TIME TESTS 8

3. DAHS VERIFIFICATION **8**

4. FUEL FLOWMETER CERTIFICATION TESTS DOCUMENTATION **8**

5. DISCUSSION OF RESULTS **8**

APPENDIX 1 Emissions Collection and Monitoring Plan System (ECMPS) Printout

APPENDIX 2 7-Day Error Drift Tests & Online/Offline Demonstration Test Documentation

APPENDIX 3 Linearity Check Documentation

APPENDIX 4 Cycle Time & Response Time Test Documentation

APPENDIX 5 DAHS Verification Documentation

APPENDIX 6 Relative Accuracy Test Audit Report

APPENDIX 7 Fuel Flowmeter Accuracy Test/Primary Element Visual Inspection Documentation

APPENDIX 8 Gas Cylinder Certification Sheets

1. INTRODUCTION

Cricket Valley Energy Center is a facility located in Dover Plains, New York. The facility consists of three natural gas-fired combined cycle electric generating units identified as U-00001 (U001), U-00002 (U002), and U-00003 (U003) . In addition to the air emitting equipment, the Facility will include three steam turbine generators (STGs), an air cooled condenser (ACC) and associated auxiliary equipment and systems. This certification report pertains to the U-00002 (U002) which consists of a General Electric (GE) Model 7FA.05 combustion turbine generators (CTGs) operating in combined-cycle mode with supplemental firing of the heat recovery steam generators (HRSGs) which has a nominal generating capacity of 333 MW. The maximum potential when incorporated with the steam turbine generator megawatts as per 40 CFR 75 is 383 MW. Natural gas will be the sole fuel fired in the CTGs and duct burners. Each combined cycle generating unit consisting of the CTG, HRSG and STG will be exhausted through its own stack. In addition, to oxidation catalyst being used to control CO emission, both dry-low NO_X burners (DLNB) and Selective Catalytic Reduction (SCR) are used for NO_X control on each unit. Exhaust gases from the turbines are discharged into the atmosphere through a stack approximately 282.5 feet above grade. A dedicated CEMS will monitor NO_X, CO, NH_3(NO_X) and O_2 emissions and gas fuel flow from each of the three units. This report focuses on the U-00002 CEMS.

Custom Instrumentation Services Corporation of Englewood, Colorado built the Continuous Emission Monitoring System. Data from the CEMS is recorded and stored on a Data Acquisition and Handling System (DAHS).

The CEMS on the U-00002 unit was designed to meet the monitoring and reporting requirements of New York State Department of Environmental Conservation (NYSDEC) Permit No. 3-1326-00275/00009 and the regulatory requirements of 40 CFR 60 (NO_X, NH_3, CO and O_2 analyzers) and 40 CFR 75 (NO_x and O_2 analyzers). This report presents the results of the initial certification tests performed on the NO_x, NO_X/NH_3, CO and O_2 analyzers. The testing was performed in accordance with the requirements of 40 CFR 60, Appendix B, Performance Specification 2, 3; 4a and 40 CFR 75, Appendix A.

In addition, this report provides documentation of the DAHS missing data substitution and formula verification as well as fuel flow meter transmitter accuracy tests and orifice plate primary element visual inspections performed as required by 40 CFR 75 for the initial certification.

Field certification testing on Unit U-00002 occurred between January 29, 2020 and February 25, 2020. The tests conducted under 40 CFR 75 on the NO_x and O_2 CEMS included Relative Accuracy Test Audit (RATA), Bias Check, 7-Day Calibration Error Test, Linearity Check and Cycle Time Test. The tests conducted under 40 CFR 60 on NO_X, NH_3/NO_X, CO and O_2 CEMS included RATA, 7-Day Calibration Drift Test and CO Response Time Test. A summary of the tests performed on each analyzer is provided in Table 1.

Printouts of the tests results and revised monitoring plans for the 40 CFR 75 NO_x and O_2 CEMS from EPA's Emissions Collection and Monitoring Plan System (ECMPS) Software are provided in Appendix 1.

Air Hygiene, International(AHI) of Broken Arrow, Oklahoma conducted the RATAs on the NO_x, NH_3/NO_X, CO and O_2 CEMS. On February 25, 2020 eleven (11) 21-minute runs were completed on the unit. The results of the RATAs are summarized in Table 1. As shown, the Relative Accuracy calculations on the analyzers were within the EPA and NYSDEC specifications for all parameters. A detailed description of the RATAs conducted are provided in Section 2.1 and the AHI test report in Appendix 6.

A bias check evaluation was made on the NO_x lb/mmBtu relative accuracy results as required in 40 CFR 75. The bias adjustment factor for the NO_x monitoring systems (NO_x lb/mmBtu) is provided in Table 1. The bias test results are discussed in Section 2.2. Supporting data is provided in the relative accuracy tables in the AHI RA report in Appendix 6.

The 40 CFR 60 7-day Calibration Drift and 40 CFR 75 7-Day Calibration Error tests for U-00002 CEMS occurred during seven consecutive unit operating days from January 29, 2020 through February 6, 2020. The results of these tests are summarized in Table 1. As shown, the analyzers operated well within the applicable specifications. An explanation of the calibration drift and calibration error tests is provided in Section 2.3 and supporting documentation is provided in Appendix 2 of this report.

Although not required for the initial certification, Online/Offline Calibration Error Demonstration tests were performed on the 40 CFR 75 NO_x and O_2 analyzers on February 1, 2020 to allow the use of offline calibrations to validate the Part 75 data during subsequent normal operation. Information on the Online/Offline calibration error demonstration tests is also provided in Section 2.3 and Appendix 2 of this report.

The U-00002 Linearity Checks were performed on the 40 CFR 75 NO_x and O_2 analyzers on February 6, 2020. The NO_x and O_2 Cycle Time Tests and the CO Response Time tests were performed February 6, 2020. The results of these tests are summarized in Table 1. As shown, the analyzers operated well within EPA specifications for all parameters. An explanation of the linearity check is provided in Section 2.4. Explanations of the cycle time and response time tests are provided in Section 2.5. Audit reports for the linearity checks and supporting documents for the cycle time/response time tests are provided in Appendices 3 and 4, respectively.

The DAHS missing data substitution verification and formula verification tests took place January 6, 2020. The DAHS passed all the tests required by EPA. The DAHS tests are described in Section 3 and supporting documents are provided in Appendix 5. Please note that although not required by 40 CFR 60, DAHS formula verifications are also provided for the CO analyzers.

In summary, based on the results of the initial certification tests performed on the CEMS installed on the U-00002 stacks at the Cricket Valley Energy Center, the CEMSs met the

requirements in 40 CFR 60, Appendix B Performance Specification 2, 3, 4a and 40 CFR 75, Appendix A and are therefore certified to provide accurate and reliable data under these regulations and under the NYSDEC air permit. These CEMS will continue to be calibrated, maintained, and operated following the requirements of 40 CFR 60, Appendix F and 40 CFR 75, Appendix B.

TABLE 1.

SUMMARY OF CEMS CERTIFICATION TESTS RESULTS

	RESULTS	STANDARD	PASS / FAIL
	RELATIVE ACCURACY		
NO_x ppm @ 15% O_2	7.84% RA RM	20% RA RM or 10% ARA[1]	PASS
NO_x lb/hr	7.32% RA RM	20% RA RM or 10% ARA	PASS
NO_x lb/mmBtu	0.000 lb/mmBtu MD	7.5% RA RM or 0.015 lb/mmBtu MD[2]	PASS
CO ppm @ 15% O_2	0.1 ppm MD	10% RA RM or 5% ARA or ±5 ppm MD[3]	PASS
CO lb/hr	0.1 ppm MD	10% RA RM or 5% ARA or ±5 ppm MD	PASS
NH_3 ppm @ 15% O_2	4.38% RA RM	20% RA RM or 10% ARA	PASS
NH_3 lb/hr	6.50% RA ARA[4]	20% RA RM or 10% ARA	PASS
O_2 %	1.70% RA RM	20% RA RM or 1% O_2 MD	PASS
	BIAS TEST		
Adjustment Factor	1.000	NA	PASS
	24-HOUR ZERO DRIFT[5]		
NO_x low	1.8% of span	2.5 % of span	PASS
NO_x high	0.1% of span	2.5 % of span	PASS
CO low	4.00% of span	5 % of span	PASS
CO high	0.05% of span	5 % of span	PASS
$NH_3/(NO_x)$	1.19% of span	2.5 % of span	PASS
O_2 %	0.02% O_2	0.5% O_2	PASS
	24-HOUR SPAN DRIFT[5]		
NO_x low	0.5% of span	2.5 % of span	PASS
NO_x high	0.7% of span	2.5 % of span	PASS
CO low	4.20% of span	5 % of span	PASS
CO high	0.34% of span	5 % of span	PASS
$NH_3/(NO_x)$	1.56% of span	2.5 % of span	PASS
‘O_2 %	0.03% O_2	0.5% O_2	PASS
	LINEARITY[5]		
NO_x high ppm	1.6% LE	5% LE	PASS
O_2 %	0.4% LE	5% LE	PASS
	CYCLE TIME/CO RESPONSE TIME TEST(S) [5]		
NO_x lb/mmBtu	2 Minutes	15 Minutes	PASS
CO low	127 Avg. Seconds	240 Avg. Seconds	PASS
	DAHS VERIFICATION		
DAHS Computer	Verified (01/06/2020)	Verify	PASS
ANALYZER SERIAL NUMBERS			
NO_x		1013	
O_2		129	
CO		519	
NH_3/NO_X		1048	

[1] ARA = alternative relative accuracy determined from the permit applicable standard.

[2] RATA RESULTS REQUIRED FOR ANNUAL RATA FREQUENCY FOR 40 CFR 75

[3] MD =|d| +|2.5% CC

[4] NYSDEC permit ID 3-1326-00275/00009 does not have a current NH3 lb/hr limit, so a conservative value (16.55 lb/hr) was back-calculated from the existing 5 ppm corrected limit. Calculation is provided in AiR Hygiene RATA report in Appendix 6.

[5] DRIFT, LINEARITY CTT/RTT RESULTS ARE THE HIGHEST ENCOUNTERED DURING ALL TESTS

2. CEMS CERTIFICATION TESTS

Field tests were performed for the initial CEMS certification in accordance with the requirements of 40 CFR 60, Appendix B and 40 CFR Part 75, Appendix A. The results for all tests were determined from the data collected by the DAHS. The computer printouts for each field test are included in the Appendices.

2.1 RELATIVE ACCURACY TEST AUDIT

Relative accuracy testing was performed on February 25, 2020 by AHI a source testing company that meets the EPA Air Emissions Testing Body (AETB) requirements. Each test run was a minimum of 21 minutes in duration and consisted of sampling for NO_x, NH_3 (NO_X), CO and O_2. The times during which the tests were performed and additional information on stratification test, NO_x converter efficiency check and reference method calibrations are provided in the AHI report in Appendix 6.

The reference methods used by AHI are outlined below:

CONSTITUENT	METHOD
O_2	EPA METHOD 3A
NO_x	EPA METHOD 7E
$NH_3(NO_x)$	EPA METHOD 7E
CO	EPA METHOD 10

As shown in the Relative Accuracy tables in the AHI report in Appendix 6, relative accuracy is reported as an error and is the sum of the absolute mean value of the differences between the reference method tests and the instrument readings, plus the 95 percent confidence interval of the differences, expressed as a percentage of the mean reference method value or the emission standard. As an alternative, 40 CFR 75 allows low NO_x emitters (less than 0.20 lb/mmBtu) to express relative accuracy as the difference between the average reference method value and the average CEMS value. Performance Specification 4a in 40 CFR 60, Appendix B also allows for CO relative accuracy results to be expressed as a mean difference between the reference method average value and CEMS average value.

The analyzer response was determined from the average of readings taken every minute for the duration of the time the relative accuracy tests were performed. The 1-Minute Data Reports from the CEMS are included in the AHI report.

The NO_x, $NH_3(NO_X)$, CO and O_2. analyzers passed the relative accuracy requirements (as stated in 40 CRF 60, Appendix B 2,3, 4a). In addition, the NO_x diluent systems (NO_x and O_2 analyzers combined) passed the relative accuracy requirements as stated in 40 CRF 75, Appendix A and based on the RATA results, these systems qualify for annual RATA frequency under 40 CFR 75.

2.2 BIAS CHECK

The relative accuracy result for the NO_x diluent systems reported in lb/mmBtu was checked for low bias by determining if the mean difference between the test team's values and the CEMS values was greater than the absolute value of the confidence coefficient. U-00002 NO_x diluent systems exhibited bias. Therefore, the bias adjustment factor (BAF) for the unit was 1.000. In general, the BAF is determined after each RATA test.

Should have been better stated as "diluent systems met the bias test requirement."

2.3 7 DAY CALIBRATION ERROR/DRIFT TEST & ONLINE/OFFLINE DEMONSTRATION TESTS

In general, the U-00002 7-day calibration error/drift tests required by 40 CFR 60 and 40 CFR 75 on the NO_x, NH_3 (NO_X), CO and O_2. analyzers occurred between January 29, 2020 and February 6, 2020. All tests occurred on seven consecutive unit-operating days when the unit was combusting fuel. The NO_x and O_2 calibration gases used for the zero and span calibration error tests meet the requirements of the EPA 40 CFR 75, Appendix A, Protocol Gas Verification Program (PGVP). The certificates of analysis for the cylinders used to meet the requirements of both 40 CFR 60 and 40 CFR 75 drift/calibration error requirements are included in Appendix 8 of this report.

Although not required for the initial certification, this report includes the results of the Online/Offline Calibration Error Demonstration tests that were performed on February 1, 2020. 40 CFR 75 Appendix B §2.1.1.2 allows the use of offline calibrations for the purpose of validating online data if both offline and online calibrations are performed within 26-clock hours and meets the performance specification criteria of 40 CFR 75 Append A, §3.1.

The data from calibrations occurring over seven days and the offline determination occurring within 26-clock hours are summarized in Appendix 2 of this report. As shown, the calibration error/drift for all analyzers were well within EPA requirements as stated in 40 CFR 60, Appendix B and 40 CFR 75, Appendix A. The calibration summary reports are provided in Appendix 2.

2.4 LINEARITY CHECKS

The U-00002 NO_x and O_2 linearity checks were performed on February 6, 2020. To perform the linearity check, the high ranges of the NO_x analyzers and the O_2 analyzers were challenged three times with each of three levels of calibration gas (low, mid and high). The mean difference between the analyzer response and the calibration gas value, as a percentage of the calibration gas value, must be within 5%. Results are also acceptable if the difference between the mean response and the calibration gas value is within 0.5% O_2 or 5 ppm NO_x. The results were well within the requirements of 40 CFR 75, Appendix A.

A summary of the linearity check results are provided in Appendix 3 and the certificates of analysis for the calibration gases used during the checks are provided in Appendix 8. The calibration gases used for the linearity checks met the US EPA PGVP requirements of 40 CFR 75, Appendix A.

2.5 CYCLE TIME & RESPONSE TIME TESTS

The U-00002 cycle time tests were performed on February 6, 2020. To perform the test, the NO_x and O_2 analyzers were challenged with a zero gas and a high level (80 to 100% of span) calibration gas. Both the upscale and down scale response times were determined. As stated in 40 CFR 75, Appendix A, the response time to reach 95% of the gas value must be less than 15 minutes.

40 CFR 75, Appendix A, Section 6.4 specifies that on and after January 1, 2009, the cycle time for each component analyzer of a NO_x diluent system must be recorded separately. It also specifies that for monitors with dual ranges, the test results for each range must be reported separately. Cycle time test results are acceptable for monitoring system certification if none of the cycle times exceed 15 minutes. The down scale and upscale cycle times for the NO_x low range, NO_x high range and O_2 analyzers met this specification.

The U-00002 CO response time tests were performed on February 6, 2020 to meet the requirements of 40 CFR 60. To perform this test, the low range of the CO analyzer was challenged with a zero gas and a high level (50 to 100% of range) calibration gas. Both the upscale and down scale response time averages were determined. As stated in 40 CFR 60, Appendix B, Performance Specification 4A the response time to reach 95% of the gas value must be less than 240 seconds. For the upscale and downscale readings the longer of the two response times is the response time for the analyzer. The response time for the low range of the CO analyzers met this requirement. The gas cylinders used to perform the CO response time tests are provided in Appendix 8.

Audit reports that show the analyzers response in ten second increments are located in Appendix 4. The gas cylinders used to perform the NO_X/O_2 cycle time tests meet the US EPA PGVP requirements of 40 CFR 75, Appendix A and are provided in Appendix 8.

3. DAHS VERIFICATION

A letter from the 40 CFR 75 software vendor (CiSCO CEMS) stating that each of the missing data routines and calculations performed by the DAHS was verified is included in Appendix 5. A formula verification is also included. All variables included in the calculations (bias adjustment factor, fuel inputs) were used. The formula verification spreadsheet and associated printouts are also included in Appendix 5.

4. FUEL FLOWMETER CERTIFICATION TESTS DOCUMENTATION

Documents demonstrating that the fuel flowmeters installed in each combustion turbine and duct burner meet the 2% upper range accuracy specified in 40 CFR 75 Appendix D are provided in Appendix 7. This includes Certificate of Compliance document which references ASME NFC 9M:2006 calibration which demonstrates compliance with 40 CFR 75 Appendix D Section 2.1.5.1 certification criteria.

Should be: ASME MFC 9M:2006

5. DISCUSSION OF RESULTS

The CEMS and DAHS on the U-00002 combustion turbine generators at the Cricket Valley Energy Center successfully met all the requirements of the EPA as outlined in 40 CFR 60 and 40 CFR 75. An electronic QA certification file in the format specified by EPA Clean Air Markets Division for 40 CFR 75 has been prepared for each unit and will be submitted via ECMPS within 45 days of test completion.

APPENDIX 1

EMISSIONS MONITORING AND MONITORING PLAN SYSTEM PRINTOUTS

ECMPS Client Tool

Version 1.* 2019 Q3

QA/Cert Events Printout Report

March 10, 2020 05:56 PM

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL):	57185
State:	NY
County:	Dutchess County

QA Certification Events Details

Unit/Stack Identifier	Event Code	Event Date/Hour	System ID / Type	Component ID / Type	Required Tests	Conditional Data Begin Date/Hour	Last Test Completed Date/Hour	Submitted?
U002	125	01/28/2020 23	N20/NOX	210/NOX	4		02/25/2020 18	Not Yet Submitted
				220/O2	4		02/25/2020 18	Not Yet Submitted

Event Codes: 125 - Initial Certification of Gas Monitoring System

Required Test Codes: 4 - Normal Load RATA, 7-day Calibration Error Test, Linearity Check, Cycle Time Test, DAHS Verification

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL): 57185
State: NY
County: Dutchess County

Unit/Stack/Pipe ID: U002

7-Day Calibration

Component ID: 210
Component Type: NOX
Test Completion: 02/06/2020 00:01
Test Number: 7DCAL-NOX_H-
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: High
Span Value: 200.000
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
01/29/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
01/29/2020 00	HIGH	176.800	88.4	177.600	0.40		0.40	
02/01/2020 12	ZERO	0.000	0	0.000	0.00		0.00	
02/01/2020 12	HIGH	176.800	88.4	176.900	0.10		0.10	
02/02/2020 00	ZERO	0.000	0	0.010	0.00		0.00	
02/02/2020 00	HIGH	176.800	88.4	178.200	0.70		0.70	
02/03/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
02/03/2020 00	HIGH	177.200	88.6	176.800	0.20		0.20	
02/04/2020 00	ZERO	0.000	0	0.100	0.10		0.10	
02/04/2020 00	HIGH	177.200	88.6	177.100	0.10		0.10	
02/05/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
02/05/2020 00	HIGH	177.200	88.6	177.400	0.10		0.10	
02/06/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
02/06/2020 00	HIGH	177.200	88.6	177.800	0.30		0.30	

Additional Information:
No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A &3.1)

Unit/Stack/Pipe ID: U002

7-Day Calibration

Component ID: 220
Test Number: 7DCAL-O2_H-
Span Scale Level: High
Component Type: O2
Reason for Test: INITIAL
Span Value: 25.000
Test Completion: 02/06/2020 00:01
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
01/29/2020 00	ZERO	0.000	0	0.010	0.00		0.00	
01/29/2020 00	HIGH	22.140	88.6	22.130	0.00		0.00	
02/01/2020 12	ZERO	0.000	0	0.020	0.00		0.00	
02/01/2020 12	HIGH	22.140	88.6	22.150	0.00		0.00	
02/02/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
02/02/2020 00	HIGH	22.140	88.6	22.160	0.00		0.00	
02/03/2020 00	ZERO	0.000	0	0.010	0.00		0.00	
02/03/2020 00	HIGH	22.140	88.6	22.170	0.00		0.00	
02/04/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
02/04/2020 00	HIGH	22.140	88.6	22.140	0.00		0.00	
02/05/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
02/05/2020 00	HIGH	22.140	88.6	22.120	0.00		0.00	
02/06/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
02/06/2020 00	HIGH	22.140	88.6	22.130	0.00		0.00	

Additional Information:
No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A &3.1)

Unit/Stack/Pipe ID: U002
Cycle Time Test

Component ID:	220	**Component Type:**	O2	**Test Completion:**	02/06/2020 19:00
Test Number:	CTT-220-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	25.000	**EPA Calculated Result:**	PASSED
Total Cycle Time:	2	**Calculated Total Cycle Time:**	2		
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/02/06	18:54	18:56	ZERO	0.000	12.857	0.001	2	2
2020/02/06	18:58	19:00	HIGH	22.140	12.850	22.081	2	2

Additional Information:
No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U002
Cycle Time Test

Component ID:	210	**Component Type:**	NOX	**Test Completion:**	02/06/2020 18:39
Test Number:	CTT-210L-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	Low	**Span Value:**	10.000	**EPA Calculated Result:**	PASSED
Total Cycle Time:	3	**Calculated Total Cycle Time:**	3		
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/02/06	18:32	18:35	ZERO	0.000	2.169	-0.144	3	3
2020/02/06	18:38	18:39	HIGH	8.930	2.164	8.771	1	1

Additional Information:
No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U002

Cycle Time Test

Component ID: 210
Component Type: NOX
Test Completion: 02/06/2020 18:50
Test Number: CTT-210H-2020Q1
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: High
Span Value: 200.000
EPA Calculated Result: PASSED
Total Cycle Time: 2
Calculated Total Cycle Time: 2

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/02/06	18:43	18:44	ZERO	0.000	2.284	0.019	1	1
2020/02/06	18:48	18:50	HIGH	176.800	2.246	175.483	2	2

Additional Information:
No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U002

Fuel Flowmeter Accuracy Test

Component ID: 270
Component Type: GFFM
Test Completion: 04/09/2018 10:00
Test Number: FFAT-270-2020Q1
Reported Test Results: PASSED
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Accuracy Test Method	High Level Accuracy	Mid Level Accuracy	Low Level Accuracy	Reinstallation Date/Hour
ASME	0.0	0.0	0.0	11/21/2019 00

Additional Information:
No comment.

Unit/Stack/Pipe ID: U002

Linearity Check

Facility Name: Cricket Valley Energy Center

QA/Cert Test Detail Report

March 28, 2020 11:58 AM

Facility ID (ORISPL): 57185

Component ID:	210	**Component Type:**	NOX	**Test Completion:**	02/06/2020 11:25
Test Number:	210-LIN-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	200.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
Grace period Tested?				**Submission Date/Time:**	

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,NO,NOX,BALN	B22019	SG9160199BAL	07/22/2027
Mid	CO,NO,NOX,BALN	B22019	EB0070742	12/13/2027
Low	CO,NO,NOX,BALN	G12019	AAL073505	07/19/2027

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	177.200	177.200	112.400	112.400	51.200	51.200
Mass CEM Value	176.067	176.067	112.100	112.100	50.400	50.400
Alt. Perf. Indicator						
Results	0.6	0.6	0.3	0.3	1.6	1.6

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
02/06/2020 11:04	LOW	50.500	51.200	25.6%
02/06/2020 10:51	LOW	50.200	51.200	25.6%
02/06/2020 11:16	LOW	50.500	51.200	25.6%
02/06/2020 11:00	HIGH	176.100	177.200	88.6%
02/06/2020 11:12	HIGH	176.200	177.200	88.6%
02/06/2020 11:25	HIGH	175.900	177.200	88.6%
02/06/2020 10:56	MID	112.100	112.400	56.2%
02/06/2020 11:08	MID	112.100	112.400	56.2%
02/06/2020 11:21	MID	112.100	112.400	56.2%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: U002

Linearity Check

Component ID:	220	**Component Type:**	O2	**Test Completion:**	02/06/2020 13:12
Test Number:	220-LIN-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	25.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
Grace period Tested?				**Submission Date/Time:**	

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO2,O2,BALN	B72018	ALM064777	05/09/2027
Low	CO2,O2,BALN	L12013	EB0049417	08/13/2021
Mid	O2,BALN	G12015	EB0053431	06/13/2023

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	22.140	22.140	13.460	13.460	6.030	6.030
Mass CEM Value	22.083	22.083	13.520	13.520	6.027	6.027
Alt. Perf. Indicator						
Results	0.3	0.3	0.4	0.4	0.1	0.1

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
02/06/2020 12:42	HIGH	22.080	22.140	88.6%
02/06/2020 12:57	HIGH	22.080	22.140	88.6%
02/06/2020 13:12	HIGH	22.090	22.140	88.6%
02/06/2020 13:07	MID	13.520	13.460	53.8%
02/06/2020 12:37	MID	13.520	13.460	53.8%
02/06/2020 12:52	MID	13.520	13.460	53.8%
02/06/2020 12:47	LOW	6.030	6.030	24.1%
02/06/2020 12:32	LOW	6.020	6.030	24.1%
02/06/2020 13:02	LOW	6.030	6.030	24.1%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: U002

On-Line/Off-Line Calibration

Component ID: 210
Component Type: NOX
Test Completion: 02/01/2020 12
Test Number: ON_OFF-210L-
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: Low
Span Value:
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	02/01/2020 12	ZERO	0.000		-0.020	0.20		0.20	
Online	02/01/2020 12	HIGH	8.935		8.930	0.10		0	
Offline	02/01/2020 00	ZERO	0.000		-0.040	0.40		0.40	
Offline	02/01/2020 00	HIGH	8.935		8.860	0.80		0.80	

Additional Information:

No comment.

Unit/Stack/Pipe ID: U002

On-Line/Off-Line Calibration

Component ID: 220
Component Type: O2
Test Completion: 02/01/2020 12
Test Number: ON_OFF-220-
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: High
Span Value:
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	02/01/2020 12	ZERO	0.000		0.020	0.00		0.00	
Online	02/01/2020 12	HIGH	22.140		22.150	0.00		0	
Offline	02/01/2020 00	ZERO	0.000		0.020	0.00		0.00	
Offline	02/01/2020 00	HIGH	22.140		22.140	0.00		0.00	

Additional Information:

No comment.

Unit/Stack/Pipe ID: U002

On-Line/Off-Line Calibration

Component ID: 210
Component Type: NOX
Test Completion: 02/01/2020 12
Test Number: ON_OFF-210H-
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: High
Span Value:
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	02/01/2020 12	ZERO	0.000		0.000	0.00		0.00	
Online	02/01/2020 12	HIGH	176.800		178.200	0.70		0	
Offline	02/01/2020 00	ZERO	0.000		0.000	0.00		0.00	
Offline	02/01/2020 00	HIGH	176.800		177.600	0.40		0.40	

Additional Information:

No comment.

Unit/Stack/Pipe ID: U002

Relative Accuracy Test

System ID:	N20	**System Parameter:**	NOX	**Test Completion:**	02/25/2020 18:17
Test Number:	N20-2020Q1	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSAPS
# of Op. Levels:	1	**Grace Period Test?**		**EPA Calculated Result:**	PASSAPS
Evaluation Status:	No Errors			**Reported BAF:**	1.000
Submission Status:	Not Submitted			**EPA Calculated BAF:**	1.000
Submission Date:				**RATA Frequency:**	4QTRS

Air Emissions Testing Data

QI Name:	McBRIDE, MICHAEL S	**AETB Name:**	AIR HYGIENE INTERNATIONAL
Exam Date:	01/27/2019	**AETB Phone Number:**	888-461-8778
Provider Name:	SOURCE EVALUATION SOCIETY (SES)	**AETB Email:**	info@airhygiene.com
Provider Email:	QSTIPROGRAM@GMAIL.COM		

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	BALN,CO,NO,NOX	G12019	EB0018492	05/02/2022
Mid	BALN,CO,NO,NOX	G12019	EB0065964	07/22/2022
High	BALN,CO2,O2	G12019	CC721614	11/01/2026
Mid	BALN,CO2,O2	G12019	CC722590	06/08/2027
Low	ZERO			

Operating Level: High
Reference Method Used: 7E,3A: NOX RM 7E and CO2/O2 RM 3A

Summary Statistics:

	Reported	Recalculated		Reported	Recalculated
Mean of Monitoring System	0.00617	0.00617	**Relative Accuracy**	7.88	7.88
Mean of Reference Method Values	0.00577	0.00577	**Bias Adjustment Factor**	1.000	1.000
Mean of Difference	-0.00040	-0.00040	**APS Indicator**	Y	Y
Standard Deviation of Difference	0.00007	0.00007	**T-Value**	2.306	2.306
Confidence Coefficient	0.00005	0.00005	**Gross Unit Load or Velocity**	356	356

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

Run Data:

Run	Start Date	End Date	Run Status	Monitoring System Value	Reference Method Value	Gross Load or Velocity
1	02/25/2020 11:53	02/25/2020 12:13	RUNUSED	0.00620	0.00580	347
2	02/25/2020 12:32	02/25/2020 12:52	RUNUSED	0.00610	0.00570	346
3	02/25/2020 13:07	02/25/2020 13:27	NOTUSED	0.00530	0.00570	345
4	02/25/2020 13:36	02/25/2020 13:56	RUNUSED	0.00620	0.00580	346
5	02/25/2020 14:15	02/25/2020 14:35	RUNUSED	0.00580	0.00550	345
6	02/25/2020 14:46	02/25/2020 15:06	NOTUSED	0.00550	0.00520	3346 mistake
7	02/25/2020 15:17	02/25/2020 15:37	RUNUSED	0.00590	0.00560	345
8	02/25/2020 15:47	02/25/2020 16:07	RUNUSED	0.00630	0.00580	346
9	02/25/2020 16:20	02/25/2020 16:40	RUNUSED	0.00650	0.00610	373
10	02/25/2020 16:51	02/25/2020 17:11	RUNUSED	0.00630	0.00580	378
11	02/25/2020 17:57	02/25/2020 18:17	RUNUSED	0.00620	0.00580	380

Additional Information:

No comment.

*Performance Spec: RA <= 10% or Mean Difference <= +/- 2.0fps:
Reduced Frequency Spec: RA <= 7.5% or Mean Difference +/- 1.5 fps (Appendix A &3.3.4)

Unit/Stack/Pipe ID: U002

Transmitter Transducer Test

Component ID: 275
Test Number: FFTTT-275-2020Q1
Component Type: GFFM
Reason for Test: INITIAL
Test Completion: 02/24/2018 04:39
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

High Level Accuracy	High Level Accuracy Specification	Mid Level Accuracy	Mid Level Accuracy Specification	Low Level Accuracy	Low Level Accuracy Specification
0.0	SUM	0.0	SUM	0.0	SUM

Additional Information:

No comment.

Unit/Stack/Pipe ID: U002

DAHS Verification

System ID:		**System Type:**		**Test Completion:**	01/06/2020 15:00
Component ID:	D01	**Component Type:**	DAHS	**Reported Test Results:**	PASSED
Test Number:	DAHS_2020Q1	**Reason for Test:**	INITIAL	**Grace Period Test?**	
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted

Test Description:

Additional Information:

DAHS VERIFICATION

Unit/Stack/Pipe ID: U002

Primary Element Inspection

System ID:		**System Type:**		**Test Completion:**	11/21/2019 00:00
Component ID:	275	**Component Type:**	GFFM	**Reported Test Results:**	PASSED
Test Number:	275-PEI-2020Q1	**Reason for Test:**	INITIAL	**Grace Period Test?**	
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted

Test Description:

Additional Information:

ORIFICE PLATE INSPECTION

APPENDIX 2

7-DAY ERROR/DRIFT TESTS
&
ONLINE/OFFLINE DEMONSTRATION TESTS
DOCUMENTATION

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 75-NOx ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/29/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.60	0.80	5.00	On-Line
1/30/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.90	1.10	5.00	Off-Line
1/31/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.90	1.10	5.00	Off-Line
2/1/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.60	0.80	5.00	Off-Line
2/1/2020 12:45	200	0.00	0.00	0.00	5.00	176.80	178.20	1.40	5.00	On-Line
2/1/2020 15:03	200	0.00	0.00	0.00	5.00	176.80	176.70	-0.10	5.00	On-Line
2/2/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	176.90	0.10	5.00	On-Line
2/3/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	176.80	0.00	5.00	On-Line
2/3/2020 11:42	200	0.00	-0.10	-0.10	5.00	177.20	177.30	0.10	5.00	On-Line
2/4/2020 00:01	200	0.00	0.10	0.10	5.00	177.20	177.10	-0.10	5.00	On-Line
2/5/2020 00:01	200	0.00	0.00	0.00	5.00	177.20	177.40	0.20	5.00	On-Line
2/6/2020 00:01	200	0.00	0.00	0.00	5.00	177.20	177.80	0.60	5.00	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 60-NOx ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/29/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.60	0.80	5.00	On-Line
1/30/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.90	1.10	5.00	Off-Line
1/31/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.90	1.10	5.00	Off-Line
2/1/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.60	0.80	5.00	Off-Line
2/1/2020 12:45	200	0.00	0.00	0.00	5.00	176.80	178.20	1.40	5.00	On-Line
2/1/2020 15:03	200	0.00	0.00	0.00	5.00	176.80	176.70	-0.10	5.00	On-Line
2/2/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	176.90	0.10	5.00	On-Line
2/3/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	176.80	0.00	5.00	On-Line
2/3/2020 11:42	200	0.00	-0.10	-0.10	5.00	176.80	177.30	0.50	5.00	On-Line
2/4/2020 00:01	200	0.00	0.10	0.10	5.00	176.80	177.10	0.30	5.00	On-Line
2/5/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.40	0.60	5.00	On-Line
2/6/2020 00:01	200	0.00	0.00	0.00	5.00	176.80	177.80	1.00	5.00	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 60-NOx ppm/L

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/29/2020 00:01	10	0.00	-0.03	-0.03	0.25	8.94	8.90	-0.04	0.25	On-Line
1/30/2020 00:01	10	0.00	-0.04	-0.04	0.25	8.94	8.88	-0.06	0.25	Off-Line
1/31/2020 00:01	10	0.00	-0.04	-0.04	0.25	8.94	8.89	-0.05	0.25	Off-Line
2/1/2020 00:01	10	0.00	-0.04	-0.04	0.25	8.94	8.86	-0.08	0.25	Off-Line
2/1/2020 12:45	10	0.00	-0.02	-0.02	0.25	8.94	8.93	-0.01	0.25	On-Line
2/1/2020 15:03	10	0.00	0.04	0.04	0.25	8.94	8.91	-0.03	0.25	On-Line
2/2/2020 00:01	10	0.00	-0.01	-0.01	0.25	8.94	8.91	-0.03	0.25	On-Line
2/3/2020 00:01	10	0.00	0.00	0.00	0.25	8.94	8.90	-0.04	0.25	On-Line
2/4/2020 00:01	10	0.00	0.11	0.11	0.25	8.94	8.98	0.05	0.25	On-Line
2/4/2020 10:20	10	0.00	-0.07	-0.07	0.25	8.93	8.92	-0.01	0.25	On-Line
2/5/2020 00:01	10	0.00	-0.09	-0.09	0.25	8.93	8.97	0.04	0.25	On-Line
2/6/2020 00:01	10	0.00	-0.18	-0.18	0.25	8.93	8.93	0.00	0.25	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 CO ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
2/1/2020 00:01	2050	0.00	0.00	0.00	102.50	1709.00	1695.00	-14.00	102.50	Off-Line
2/1/2020 12:45	2050	0.00	0.00	0.00	102.50	1709.00	1705.00	-4.00	102.50	On-Line
2/1/2020 15:03	2050	0.00	0.00	0.00	102.50	1709.00	1706.00	-3.00	102.50	On-Line
2/2/2020 00:01	2050	0.00	-1.00	-1.00	102.50	1709.00	1710.00	1.00	102.50	On-Line
2/3/2020 00:01	2050	0.00	0.00	0.00	102.50	1709.00	1715.00	6.00	102.50	On-Line
2/3/2020 11:42	2050	0.00	-1.00	-1.00	102.50	1712.00	1713.00	1.00	102.50	On-Line
2/4/2020 00:01	2050	0.00	1.00	1.00	102.50	1712.00	1713.00	1.00	102.50	On-Line
2/5/2020 00:01	2050	0.00	1.00	1.00	102.50	1712.00	1713.00	1.00	102.50	On-Line
2/6/2020 00:01	2050	0.00	0.00	0.00	102.50	1712.00	1715.00	3.00	102.50	On-Line
2/7/2020 00:01	2050	0.00	0.00	0.00	102.50	1712.00	1719.00	7.00	102.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 CO ppm/L

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
2/1/2020 00:01	10	0.00	0.03	0.03	0.50	7.07	6.27	**-0.80**	0.50	Off-Line
2/1/2020 12:45	10	0.00	0.35	0.35	0.50	7.05	6.63	-0.42	0.50	On-Line
2/1/2020 15:03	10	0.00	0.14	0.14	0.50	7.05	7.10	0.05	0.50	On-Line
2/2/2020 00:01	10	0.00	-0.15	-0.15	0.50	7.05	7.17	0.12	0.50	On-Line
2/3/2020 00:01	10	0.00	-0.01	-0.01	0.50	7.05	7.29	0.24	0.50	On-Line
2/4/2020 00:01	10	0.00	1.91	**1.91**	0.50	7.05	7.93	**0.88**	0.50	On-Line
2/4/2020 10:20	10	0.00	-0.40	-0.40	0.50	7.05	6.91	-0.14	0.50	On-Line
2/5/2020 00:01	10	0.00	-0.40	-0.40	0.50	7.05	6.77	-0.28	0.50	On-Line
2/6/2020 00:01	10	0.00	-0.40	-0.40	0.50	7.05	7.01	-0.04	0.50	On-Line
2/7/2020 00:01	10	0.00	0.05	0.05	0.50	7.05	7.43	0.38	0.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 NH3/NOx ppm

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/29/2020 00:01	16	0.00	-0.18	-0.18	0.48	8.94	8.69	-0.25	0.48	On-Line
1/30/2020 00:01	16	0.00	-0.22	-0.22	0.48	8.94	8.67	-0.27	0.48	Off-Line
1/31/2020 00:01	16	0.00	-0.21	-0.21	0.48	8.94	8.65	-0.29	0.48	Off-Line
2/1/2020 00:01	16	0.00	-0.22	-0.22	0.48	8.94	8.66	-0.28	0.48	Off-Line
2/1/2020 12:45	16	0.00	-0.11	-0.11	0.48	8.94	8.73	-0.21	0.48	On-Line
2/1/2020 15:03	16	0.00	-0.03	-0.03	0.48	8.94	8.92	-0.02	0.48	On-Line
2/2/2020 00:01	16	0.00	-0.03	-0.03	0.48	8.94	8.92	-0.02	0.48	On-Line
2/3/2020 00:01	16	0.00	-0.03	-0.03	0.48	8.94	8.91	-0.03	0.48	On-Line
2/4/2020 00:01	16	0.00	0.19	0.19	0.48	8.94	8.98	0.05	0.48	On-Line
2/4/2020 10:20	16	0.00	-0.08	-0.08	0.48	8.93	8.93	0.00	0.48	On-Line
2/5/2020 00:01	16	0.00	-0.10	-0.10	0.48	8.93	8.97	0.04	0.48	On-Line
2/6/2020 00:01	16	0.00	-0.17	-0.17	0.48	8.93	8.95	0.02	0.48	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 75-O2 %

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/29/2020 00:01	25	0.00	0.01	0.01	0.50	22.14	22.13	-0.01	0.50	On-Line
1/30/2020 00:01	25	0.00	0.02	0.02	0.50	22.14	22.14	0.00	0.50	Off-Line
1/31/2020 00:01	25	0.00	0.02	0.02	0.50	22.14	22.15	0.01	0.50	Off-Line
2/1/2020 00:01	25	0.00	0.02	0.02	0.50	22.14	22.14	0.00	0.50	Off-Line
2/1/2020 12:45	25	0.00	0.02	0.02	0.50	22.14	22.15	0.01	0.50	On-Line
2/1/2020 15:03	25	0.00	0.00	0.00	0.50	22.14	22.16	0.02	0.50	On-Line
2/2/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.16	0.02	0.50	On-Line
2/3/2020 00:01	25	0.00	0.01	0.01	0.50	22.14	22.17	0.03	0.50	On-Line
2/4/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.14	0.00	0.50	On-Line
2/5/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.12	-0.02	0.50	On-Line
2/6/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.13	-0.01	0.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 2 60-O2 %

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
1/29/2020 00:01	25	0.00	0.01	0.01	0.50	22.14	22.13	-0.01	0.50	On-Line
1/30/2020 00:01	25	0.00	0.02	0.02	0.50	22.14	22.14	0.00	0.50	Off-Line
1/31/2020 00:01	25	0.00	0.02	0.02	0.50	22.14	22.15	0.01	0.50	Off-Line
2/1/2020 00:01	25	0.00	0.02	0.02	0.50	22.14	22.14	0.00	0.50	Off-Line
2/1/2020 12:45	25	0.00	0.02	0.02	0.50	22.14	22.15	0.01	0.50	On-Line
2/1/2020 15:03	25	0.00	0.00	0.00	0.50	22.14	22.16	0.02	0.50	On-Line
2/2/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.16	0.02	0.50	On-Line
2/3/2020 00:01	25	0.00	0.01	0.01	0.50	22.14	22.17	0.03	0.50	On-Line
2/4/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.14	0.00	0.50	On-Line
2/5/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.12	-0.02	0.50	On-Line
2/6/2020 00:01	25	0.00	0.00	0.00	0.50	22.14	22.13	-0.01	0.50	On-Line

The 7-Day Drift Test has been passed.

Turbine 2 Calibration Checks

Cricket Valley Energy Center
Cal Checks for 2/1/2020

Date/Time	Parameter	Analyzer Scale	Test Level	Reference Value	Measured Value	Actual Drift	Allowable Drift	Instrument Span	Results
			Cylinder ID	*Expiration Date*		*EPA Vendor ID*	*EPA Gas Type Codes*		
2/1/2020 12:01 AM	75-NOx ppm	High	Zero	0.0 ppm	0.0 ppm	0 ppm	±10 ppm	200 ppm	Unit offline; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 12:01 AM	75-NOx ppm	High	Span	176.8 ppm	177.6 ppm	0.8 ppm	±10 ppm	200 ppm	Unit offline; Passed
			ALM034669	*7/22/2027*		*B22019*	*CO,NO,NOX,BALN*		
2/1/2020 12:01 AM	75-NOx ppm	Low	Zero	0.00 ppm	-0.04 ppm	-0.04 ppm	±0.5 ppm	10 ppm	Unit offline; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 12:01 AM	75-NOx ppm	Low	Span	8.94 ppm	8.86 ppm	-0.08 ppm	±0.5 ppm	10 ppm	Unit offline; Passed
			CC722081	*6/24/2022*		*B22019*	*NO,NOX,BALN*		
2/1/2020 12:01 AM	75-O2 %	Single	Zero	0.00%	0.02%	0.02%	±1%	25%	Unit offline; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 12:01 AM	75-O2 %	Single	Span	22.14%	22.14%	0%	±1%	25%	Unit offline; Passed
			ALM064777	*5/9/2027*		*B72018*	*CO2,O2,BALN*		
2/1/2020 12:45 PM	75-NOx ppm	High	Zero	0.0 ppm	0.0 ppm	0 ppm	±10 ppm	200 ppm	Unit online; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 12:45 PM	75-NOx ppm	High	Span	176.8 ppm	178.2 ppm	1.4 ppm	±10 ppm	200 ppm	Unit online; Passed
			ALM034669	*7/22/2027*		*B22019*	*CO,NO,NOX,BALN*		
2/1/2020 12:45 PM	75-NOx ppm	Low	Zero	0.00 ppm	-0.02 ppm	-0.02 ppm	±0.5 ppm	10 ppm	Unit online; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 12:45 PM	75-NOx ppm	Low	Span	8.94 ppm	8.93 ppm	-0.01 ppm	±0.5 ppm	10 ppm	Unit online; Passed
			CC722081	*6/24/2022*		*B22019*	*NO,NOX,BALN*		
2/1/2020 12:45 PM	75-O2 %	Single	Zero	0.00%	0.02%	0.02%	±1%	25%	Unit online; Passed
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 12:45 PM	75-O2 %	Single	Span	22.14%	22.15%	0.01%	±1%	25%	Unit online; Passed
			ALM064777	*5/9/2027*		*B72018*	*CO2,O2,BALN*		
2/1/2020 3:03 PM	75-NOx ppm	High	Zero	0.0 ppm	0.0 ppm	0 ppm	±10 ppm	200 ppm	Unit online; Passed; Manual
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		

Date/Time	Parameter	Analyzer Scale	Test Level	Reference Value	Measured Value	Actual Drift	Allowable Drift	Instrument Span	Results
			Cylinder ID	*Expiration Date*		*EPA Vendor ID*	*EPA Gas Type Codes*		
2/1/2020 3:03 PM	75-NOx ppm	High	Span	176.8 ppm	176.7 ppm	-0.1 ppm	±10 ppm	200 ppm	Unit online; Passed; Manual
			ALM034669	*7/22/2027*		*B22019*	*CO,NO,NOX,BALN*		
2/1/2020 3:03 PM	75-NOx ppm	Low	Zero	0.00 ppm	0.04 ppm	0.04 ppm	±0.5 ppm	10 ppm	Unit online; Passed; Manual
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 3:03 PM	75-NOx ppm	Low	Span	8.94 ppm	8.91 ppm	-0.03 ppm	±0.5 ppm	10 ppm	Unit online; Passed; Manual
			CC722081	*6/24/2022*		*B22019*	*NO,NOX,BALN*		
2/1/2020 3:03 PM	75-O2 %	Single	Zero	0.00%	0.00%	0%	±1%	25%	Unit online; Passed; Manual
			NI CZ15A	*1/2/2028*		*B22019*	*N2*		
2/1/2020 3:03 PM	75-O2 %	Single	Span	22.14%	22.16%	0.02%	±1%	25%	Unit online; Passed; Manual
			ALM064777	*5/9/2027*		*B72018*	*CO2,O2,BALN*		

APPENDIX 3

LINEARITY CHECK DOCUMENTATION

Turbine 2 NOx/H Linearity

Cricket Valley Energy Center

Test Information

Test Date: **2/6/2020**
Test Reason:
Grace Period: No
Aborted: No
Unit online during QA test

Analyzer and Monitor Information

Range: High
Instrument Span: 200 ppm
Component ID: 210
Manufacturer: TELEDYNE
Model: T200M
Serial Number: 1013

Run Number	Time	Reference Gas	CEMS Response			Cylinder Information
Low Gas						
1	10:51 AM	51.2	50.2			Allowable Reference Values: 40-60 ppm (20-30% of span)
2	11:04 AM	51.2	50.5			
3	11:16 AM	51.2	50.5			Cylinder ID: AAL073505
	Mean (ppm)	51.2	50.4			Expiration Date: 7/19/2027
	Difference of means (|R-A|) (ppm)	0.8	*Limit 5*	*Passed*		EPA Vendor ID: G12019
	Linearity Error (%)	1.6	*Limit 5.0*	*Passed*		Cylinder contains: CO,NO,NOX,BALN
Mid Gas						
1	10:56 AM	112.4	111.8			Allowable Reference Values: 100-120 ppm (50-60% of span)
2	11:08 AM	112.4	112.1			
3	11:21 AM	112.4	112.1			Cylinder ID: EB0070742
	Mean (ppm)	112.4	112.0			Expiration Date: 12/13/2027
	Difference of means (|R-A|) (ppm)	0.4	*Limit 5*	*Passed*		EPA Vendor ID: B22019
	Linearity Error (%)	0.4	*Limit 5.0*	*Passed*		Cylinder contains: CO,NO,NOX,BALN
High Gas						
1	11:00 AM	177.2	176.1			Allowable Reference Values: 160-200 ppm (80-100% of span)
2	11:12 AM	177.2	176.2			
3	11:25 AM	177.2	175.9			Cylinder ID: SG9160199BAL
	Mean (ppm)	177.2	176.1			Expiration Date: 7/22/2027
	Difference of means (|R-A|) (ppm)	1.1	*Limit 5*	*Passed*		EPA Vendor ID: B22019
	Linearity Error (%)	0.6	*Limit 5.0*	*Passed*		Cylinder contains: CO,NO,NOX,BALN

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

Turbine 2 O2 Linearity

Cricket Valley Energy Center

Test Information

Test Date:	**2/6/2020**
Test Reason:	
Grace Period:	No
Aborted:	No

Unit online during QA test

Analyzer and Monitor Information

Range:	Single Scale
Instrument Span:	25 %O2
Component ID:	220
Manufacturer:	TELEDYNE
Model:	T802
Serial Number:	129

Run Number	Time	Reference Gas	CEMS Response		Cylinder Information
Low Gas					
1	12:32 PM	6.03	6.02		
2	12:47 PM	6.03	6.03		Allowable Reference Values:
3	1:02 PM	6.03	6.03		5-7.5 %O2 (20-30% of span)
	Mean (%O2)	6.03	6.03		Cylinder ID: EB0049417
	Difference of means (|R-A|) (%O2)	0.0	*Limit 0.5*	*Passed*	Expiration Date: 8/13/2021
	Linearity Error (%)	0.1	*Limit 5.0*	*Passed*	EPA Vendor ID: L12013
					Cylinder contains: CO2,O2,BALN
Mid Gas					
1	12:37 PM	13.46	13.52		
2	12:52 PM	13.46	13.52		Allowable Reference Values:
3	1:07 PM	13.46	13.52		12.5-15 %O2 (50-60% of span)
	Mean (%O2)	13.46	13.52		Cylinder ID: EB0053431
	Difference of means (|R-A|) (%O2)	0.1	*Limit 0.5*	*Passed*	Expiration Date: 6/13/2023
	Linearity Error (%)	0.4	*Limit 5.0*	*Passed*	EPA Vendor ID: G12015
					Cylinder contains: O2,BALN
High Gas					
1	12:42 PM	22.14	22.08		
2	12:57 PM	22.14	22.08		Allowable Reference Values:
3	1:12 PM	22.14	22.09		20-25 %O2 (80-100% of span)
	Mean (%O2)	22.14	22.08		Cylinder ID: ALM064777
	Difference of means (|R-A|) (%O2)	0.1	*Limit 0.5*	*Passed*	Expiration Date: 5/9/2027
	Linearity Error (%)	0.3	*Limit 5.0*	*Passed*	EPA Vendor ID: B72018
					Cylinder contains: CO2,O2,BALN

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

APPENDIX 4

CYCLE TIME & RESPONSE TIME TESTS DOCUMENTATION

I/O Audit Data

Cricket Valley Energy Center

Data for 2/6/2020 7:05:10 PM thru 2/6/2020 7:24:50 PM

Timestamp	(Turbine 2) CO Value		(Turbine 2) O2 Value	(Turbine 2) GT Megawatts Value
7:05:13 PM	-0.138		12.877	--
7:05:23 PM	-0.140		12.871	--
7:05:33 PM	-0.140		12.875	--
7:05:43 PM	-0.144		12.878	--
7:05:53 PM	-0.138		12.871	--
7:06:03 PM	-0.104		12.870	--
7:06:13 PM	-0.084		12.871	--
7:06:23 PM	-0.067		12.871	--
7:06:33 PM	-0.033		12.871	--
7:06:43 PM	-0.024		12.869	--
7:06:53 PM	-0.035		12.872	--
7:07:03 PM	--		12.872	--
7:07:13 PM	-0.046		12.871	--
7:07:23 PM	-0.069		12.871	--
7:07:33 PM	-0.045	U1	12.877	--
7:07:43 PM	-0.043		12.872	--
7:07:53 PM	0.179		18.588	--
7:08:03 PM	1.087		6.141	--
7:08:13 PM	2.554		0.777	--
7:08:23 PM	4.242		0.190	--
7:08:33 PM	5.737		0.081	--
7:08:43 PM	6.651		0.049	--
7:08:54 PM	7.063		0.034	234.465
7:09:04 PM	--		--	234.718
7:09:14 PM	--		--	234.543
7:09:28 PM	7.261		0.013	234.716
7:09:38 PM	7.262		0.008	--
7:09:48 PM	7.279		0.007	234.494
7:09:58 PM	7.257		0.008	--
7:10:08 PM	7.245	D1	0.007	234.443
7:10:18 PM	7.257		0.001	234.673
7:10:28 PM	6.925		0.095	--
7:10:38 PM	6.011		0.014	234.769
7:10:48 PM	4.607		0.009	--
7:10:59 PM	2.746		0.003	234.399
7:11:09 PM	1.359		0.000	234.186
7:11:19 PM	0.556		0.003	234.554
7:11:29 PM	0.141		0.000	--
7:11:39 PM	0.007		0.002	234.467
7:11:49 PM	-0.035		-0.006	234.475
7:11:59 PM	-0.048		-0.005	--
7:12:09 PM	-0.038		0.002	234.337
7:12:19 PM	-0.062	U2	-0.006	234.804
7:12:29 PM	-0.049		0.001	234.570
7:12:39 PM	-0.013		-0.007	234.270

Timestamp	(Turbine 2) CO Value	(Turbine 2) O2 Value	(Turbine 2) GT Megawatts Value
7:12:49 PM	0.054	-0.005	234.493
7:12:59 PM	0.650	-0.006	234.511
7:13:09 PM	1.815	-0.006	--
7:13:19 PM	3.290	-0.007	--
7:13:29 PM	4.967	-0.006	--
7:13:39 PM	6.175	-0.006	234.471
7:13:49 PM	6.861	-0.007	--
7:13:59 PM	7.200	-0.013	234.554
7:14:09 PM	7.336	-0.008	234.390
7:14:19 PM	7.427	-0.005	234.638
7:14:29 PM	7.432	-0.008	234.601
7:14:39 PM	7.432	-0.013	234.495
7:14:49 PM	7.456	-0.008	--
7:14:59 PM	7.440	-0.012	--
7:15:09 PM	7.440	-0.005	234.386
7:15:19 PM	7.429	-0.006	--
7:15:29 PM	7.015	0.008	234.433
7:15:39 PM	5.986	-0.006	--
7:15:49 PM	4.558	-0.005	--
7:15:59 PM	2.889	-0.013	234.235
7:16:09 PM	1.514	-0.006	--
7:16:19 PM	0.694	-0.012	234.365
7:16:29 PM	0.303	-0.005	234.477
7:16:39 PM	0.091	-0.013	234.838
7:16:49 PM	0.005	-0.013	234.451
7:16:59 PM	-0.003	-0.013	234.053
7:17:09 PM	-0.019	-0.007	234.382
7:17:19 PM	-0.005	-0.012	234.518
7:17:29 PM	0.010	-0.013	--
7:17:39 PM	0.000	-0.012	234.239
7:17:49 PM	0.103	-0.013	234.519
7:17:59 PM	0.763	-0.012	234.637
7:18:09 PM	2.010	-0.013	234.438
7:18:19 PM	3.555	-0.012	--
7:18:29 PM	5.208	-0.013	--
7:18:39 PM	6.345	-0.013	234.615
7:18:49 PM	6.920	-0.006	234.633
7:18:59 PM	7.203	-0.013	234.020
7:19:09 PM	7.292	-0.012	--
7:19:19 PM	7.308	-0.013	234.607
7:19:29 PM	7.324	-0.012	234.368
7:19:39 PM	7.316	-0.013	234.321
7:19:49 PM	7.335	-0.013	234.705
7:19:59 PM	7.349	-0.015	--
7:20:09 PM	7.364	-0.013	--
7:20:19 PM	7.376	-0.013	--
7:20:29 PM	7.289	-0.005	234.580
7:20:39 PM	6.651	-0.005	235.035
7:20:49 PM	5.432	-0.013	--

D2

U3

D3

Timestamp	(Turbine 2) CO Value	(Turbine 2) O2 Value	(Turbine 2) GT Megawatts Value
7:20:59 PM	3.895	-0.005	234.657
7:21:09 PM	2.242	-0.013	--
7:21:19 PM	1.083	-0.011	234.568
7:21:29 PM	0.469	-0.013	234.466
7:21:39 PM	0.210	-0.012	--
7:21:49 PM	0.095	-0.013	234.589
7:21:59 PM	0.044	-0.012	--
7:22:09 PM	0.030	-0.005	234.813
7:22:19 PM	0.036	-0.013	234.684
7:22:29 PM	0.008	-0.012	234.480
7:22:39 PM	0.014	-0.013	234.851
7:22:49 PM	0.008	-0.005	234.563
7:22:59 PM	0.033	0.895	234.706
7:23:09 PM	0.087	10.963	234.649
7:23:19 PM	0.136	12.529	--
7:23:29 PM	0.195	12.753	234.423
7:23:39 PM	0.222	12.796	234.501
7:23:49 PM	0.238	12.822	--
7:23:59 PM	0.236	12.823	234.640
7:24:09 PM	0.220	12.829	--
7:24:19 PM	0.225	12.837	234.482
7:24:29 PM	0.230	12.842	234.309
7:24:39 PM	0.255	12.843	234.461
7:24:49 PM	0.262	12.849	--
Average	2.835	3.200	234.519
Minimum	-0.144	-0.015	234.020
Maximum	7.456	18.588	235.035

I/O Audit Data

Cricket Valley Energy Center

Data for 2/6/2020 6:31:50 PM thru 2/6/2020 7:03:20 PM

Timestamp	(Turbine 2) NOx Value	(Turbine 2) O2 Value	(Turbine 2) GT Megawatts Value
6:31:53 PM	2.166	12.864	--
6:32:03 PM	2.166	12.872	--
6:32:13 PM	2.166	12.870	--
6:32:23 PM	2.167	12.872	--
6:32:34 PM	2.167	12.871	234.522
6:32:44 PM	--	--	234.950
6:32:54 PM	2.169	12.863	234.581
6:33:04 PM	--	--	234.975
6:33:14 PM	--	--	234.670
6:33:24 PM	--	12.863	234.696
6:33:34 PM	--	--	234.884
6:33:44 PM	--	--	234.377
6:33:54 PM	--	--	234.740
6:34:04 PM	--	--	234.507
6:34:14 PM	--	--	234.647
6:34:24 PM	--	--	235.160
6:34:34 PM	--	--	234.911
6:34:44 PM	--	--	234.581
6:34:54 PM	--	--	234.583
6:35:04 PM	--	--	234.708
6:35:14 PM	--	--	235.084
6:35:24 PM	--	--	234.532
6:35:38 PM	-0.144	0.002	234.911
6:35:48 PM	-0.144	-0.001	235.070
6:35:58 PM	-0.142	0.002	--
6:36:08 PM	-0.143	--	--
6:36:18 PM	-0.144	0.002	234.931
6:36:28 PM	-0.142	0.020	234.878
6:36:38 PM	1.339	10.050	--
6:36:48 PM	2.123	12.391	234.520
6:36:58 PM	2.153	12.726	234.861
6:37:08 PM	2.158	12.800	--
6:37:18 PM	2.152	12.821	234.754
6:37:28 PM	2.168	12.828	234.478
6:37:38 PM	2.169	12.834	--
6:37:48 PM	2.169	12.842	--
6:37:58 PM	2.167	--	--
6:38:08 PM	2.166	12.850	--
6:38:18 PM	2.167	12.842	--
6:38:28 PM	2.163	12.853	234.690
6:38:38 PM	2.164	12.847	234.257
6:38:48 PM	1.996	12.828	234.310
6:38:58 PM	1.582	2.742	234.747
6:39:08 PM	6.398	0.434	--
6:39:18 PM	8.629	0.102	234.640

Timestamp	(Turbine 2) NOx Value	(Turbine 2) O2 Value	(Turbine 2) GT Megawatts Value
6:39:28 PM	8.689	0.045	--
6:39:38 PM	8.771	0.021	234.803
6:39:48 PM	8.772	0.020	234.652
6:39:58 PM	8.784	0.008	234.673
6:40:08 PM	8.783	0.008	234.346
6:40:18 PM	8.785	0.001	--
6:40:28 PM	8.784	0.001	--
6:40:38 PM	8.784	-0.007	--
6:40:48 PM	8.784	0.001	--
6:40:59 PM	8.784	0.002	234.562
6:41:09 PM	8.784	-0.008	--
6:41:19 PM	8.784	-0.005	234.606
6:41:29 PM	8.383	0.066	234.837
6:41:39 PM	4.633	10.336	234.672
6:41:49 PM	2.303	12.432	--
6:41:59 PM	2.230	12.741	--
6:42:09 PM	2.223	12.801	234.839
6:42:19 PM	2.205	12.821	234.935
6:42:29 PM	2.189	12.835	234.298
6:42:39 PM	2.186	12.842	234.366
6:42:49 PM	2.183	12.849	234.552
6:42:59 PM	2.182	12.856	234.705
6:43:09 PM	2.296	12.849	234.553
6:43:19 PM	2.290	12.849	234.794
6:43:29 PM	2.284	12.849	234.769
6:43:39 PM	2.284	12.849	--
6:43:49 PM	4.292	9.074	235.006
6:43:59 PM	7.545	1.150	234.489
6:44:09 PM	1.064	0.207	--
6:44:19 PM	0.088	0.063	234.934
6:44:29 PM	0.019	0.026	234.886
6:44:39 PM	0.038	0.015	234.860
6:44:49 PM	0.038	0.013	234.637
6:44:59 PM	0.050	0.008	234.778
6:45:09 PM	0.025	0.002	234.768
6:45:19 PM	-0.013	0.002	234.720
6:45:29 PM	-0.031	0.001	--
6:45:39 PM	-0.134	0.001	234.692
6:45:49 PM	-0.134	-0.005	234.336
6:45:59 PM	-0.135	-0.006	234.627
6:46:09 PM	-0.135	0.000	234.501
6:46:19 PM	-0.138	-0.006	234.678
6:46:29 PM	0.255	0.975	234.618
6:46:39 PM	1.659	11.002	234.414
6:46:49 PM	2.127	12.543	--
6:46:59 PM	2.156	12.753	234.797
6:47:09 PM	2.164	12.807	234.522
6:47:19 PM	2.162	12.822	234.639
6:47:29 PM	2.164	12.835	234.565

Timestamp	(Turbine 2) NOx Value	(Turbine 2) O2 Value	(Turbine 2) GT Megawatts Value
6:47:39 PM	2.162	12.843	234.689
6:47:49 PM	2.162	12.842	234.586
6:47:59 PM	2.161	12.850	--
6:48:09 PM	2.221	12.849	--
6:48:19 PM	2.240	12.850	--
6:48:29 PM	2.246	12.857	234.495
6:48:39 PM	2.246	12.849	234.404
6:48:49 PM	1.464	8.876	234.590
6:48:59 PM	53.166	1.197	--
6:49:09 PM	136.894	0.207	234.897
6:49:19 PM	167.312	0.073	234.960
6:49:29 PM	174.770	0.041	--
6:49:39 PM	175.139	0.026	234.475
6:49:49 PM	175.358	0.020	--
6:49:59 PM	175.308	0.013	--
6:50:09 PM	175.408	0.013	--
6:50:19 PM	175.483	0.013	234.724
6:50:29 PM	175.477	0.005	--
6:50:39 PM	175.477	0.006	234.504
6:50:49 PM	175.520	0.004	235.065
6:50:59 PM	175.533	0.006	234.722
6:51:09 PM	175.539	0.005	--
6:51:19 PM	175.558	0.007	235.077
6:51:29 PM	169.139	0.248	234.409
6:51:39 PM	47.129	10.383	234.602
6:51:49 PM	5.869	12.463	234.813
6:51:59 PM	3.159	12.753	234.480
6:52:09 PM	2.846	12.808	234.636
6:52:19 PM	2.633	12.821	234.482
6:52:29 PM	2.546	12.829	234.582
6:52:39 PM	2.476	12.841	234.618
6:52:49 PM	2.420	12.842	234.798
6:52:59 PM	2.380	12.849	234.664
6:53:09 PM	2.376	12.849	234.336
6:53:19 PM	2.374	12.849	234.504
6:53:29 PM	2.369	12.849	234.941
6:53:39 PM	2.366	12.850	234.813
6:53:49 PM	2.361	12.848	234.656
6:53:59 PM	2.350	12.849	234.108
6:54:09 PM	2.343	12.848	--
6:54:19 PM	2.333	12.857	234.539
6:54:29 PM	2.324	12.847	234.834
6:54:39 PM	10.250	12.378	234.641
6:54:49 PM	10.250	2.176	234.567
6:54:59 PM	10.250	0.349	--
6:55:09 PM	1.381	0.088	234.384
6:55:19 PM	0.223	0.040	234.244
6:55:29 PM	-0.007	0.020	--
6:55:39 PM	-0.065	0.013	--

Timestamp	(Turbine 2) NOx Value	(Turbine 2) O2 Value	(Turbine 2) GT Megawatts Value
6:55:49 PM	-0.067	0.007	234.286
6:55:59 PM	-0.134	0.006	234.727
6:56:09 PM	-0.157	0.001	234.464
6:56:19 PM	-0.164	0.000	234.572
6:56:29 PM	-0.167	0.002	234.538
6:56:39 PM	-0.170	-0.006	--
6:56:49 PM	-0.170	-0.006	234.687
6:56:59 PM	-0.173	-0.005	--
6:57:09 PM	-0.178	-0.007	234.666
6:57:19 PM	-0.044	0.469	--
6:57:29 PM	1.712	10.606	234.533
6:57:39 PM	2.158	12.509	234.595
6:57:49 PM	2.183	12.760	234.432
6:57:59 PM	2.183	12.810	234.731
6:58:09 PM	2.198	12.827	--
6:58:19 PM	2.201	12.830	234.279
6:58:29 PM	2.205	12.841	234.702
6:58:39 PM	2.205	12.850	234.484
6:58:49 PM	2.006	12.398	234.984
6:58:59 PM	0.305	2.273	234.419
6:59:09 PM	-0.099	18.536	--
6:59:19 PM	-0.218	21.560	234.907
6:59:29 PM	-0.232	21.946	234.343
6:59:39 PM	-0.235	22.019	234.447
6:59:49 PM	-0.237	22.047	234.557
6:59:59 PM	-0.239	22.060	234.704
7:00:09 PM	-0.240	22.067	234.516
7:00:19 PM	-0.240	22.075	--
7:00:29 PM	-0.240	22.081	234.797
7:00:39 PM	-0.240	22.083	--
7:00:49 PM	-0.240	22.080	--
7:00:59 PM	-0.239	22.082	234.556
7:01:09 PM	-0.243	22.086	--
7:01:19 PM	-0.242	22.089	234.645
7:01:29 PM	-0.127	22.055	--
7:01:39 PM	1.231	15.025	234.482
7:01:49 PM	2.159	13.205	234.492
7:01:59 PM	2.211	12.951	234.423
7:02:09 PM	2.213	12.911	--
7:02:19 PM	2.217	12.891	234.784
7:02:29 PM	2.224	12.884	234.493
7:02:39 PM	2.222	12.877	--
7:02:49 PM	2.224	12.878	234.689
7:02:59 PM	2.225	12.870	234.526
7:03:09 PM	2.224	12.871	--
7:03:19 PM	2.225	12.871	--
Average	17.568	8.358	234.644
Minimum	-0.243	-0.008	234.108
Maximum	175.558	22.089	235.160

APPENDIX 5

DAHS VERIFICATION DOCUMENTATION

CUSTOM INSTRUMENTATION SERVICES CORPORATION

Data Acquisition and Handling System (DAHS) Verification Documentation

CeDAR and Breez75X ECMPS Reporting Software

Developed by:
Custom Instrumentation Services Corporation

EPA Regulations

- 40CFR75 Acid Rain
- 40CFR97 CSAPR NOx and SO_2

This letter serves as notice that the required 40 CFR 75 DAHS (missing data and formula) verification have been conducted and passed.

The attached formula verification document which includes CeDAR printouts demonstrates that the DAHS accurately calculates regulated parameters using raw data. In addition, verification tests have been conducted and passed for all missing data substitution routines for ECMPS reporting according to all applicable regulations and specifications in 40 CFR 75 Appendix D and Subpart D. The attached checklist, as adapted from Section 15 of the Acid Rain Program Policy Manual (revised) for 40CFR75, provides the regulatory description of the data substitution criteria.
These verification tests were conducted using numerous data sets at varying loads and operating conditions as well as various missing data periods as described in each set of tests. The tests were conducted using data sets with known outcomes and criteria and were verified against those outcomes. All missing data substitution procedures have been verified to be accurate and correct. Detailed data sets and documentation and test documentation are provided below

Walt Bastron
President

SO_2 Missing Data Verification Checklist [1]

Initial SO_2 Data Substitution: 75.31

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard SO_2 Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous SO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

1 The SO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

O_2 Missing Data Verification Checklist

Initial O_2 Data Substitution: 75.31

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(b) 75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.36(b) 75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard O2 Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 10th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 10th percentile of the lookback period.	75.36(d) 75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 5th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 5th percentile of the lookback period.	75.36(d) 75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the minimum value in the lookback period.	75.36(d) 75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.36(d) 75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.36(d) 75.33(a)

Miscellaneous SO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)

For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(c)(4)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous NOx Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

Appendix D Fuel Flow Rate Missing Data Verification Checklist

Single Fuel Hours, Load Based: Appendix D

Description	Regulation
Non-QA data is substituted with the average of the lookback period at the corresponding load range when only the same fuel was combusted.	App. D 2.4.2.2.1
Non-QA data is substituted with the average of the lookback period at the next higher available load range when only the same fuel was combusted if no data in the corresponding load range exists.	App. D 2.4.2.2.1
Non-QA data is substituted with the a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when only the same fuel was combusted exists.	App. D 2.4.2.2.1
Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3

Co-Fired Fuel Hours, Load Based: Appendix D

Description	Regulation
Non-QA data is substituted with the maximum in the lookback period at the corresponding load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Non-QA data is substituted with the maximum in the lookback period at the next higher available load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Non-QA data is substituted with a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when the same fuel is co-fired with another fuel exists.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3

Note: If Maximum Heat Rate is exceeded, manual adjustment of Fuel Flows is allowed so that reported Heat Rate equals the maximum. (App. D 2.4.2.3.4)

Fuel Specific NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Fuel Specific NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)

For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(3) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a fuel specific MPC.	75.33(c)(4) 75.33(c)(8)(iii)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(5) 75.33(c)(8)(i) 75.33(c)(8)(ii)
If no data in the corresponding or higher load ranges exists in the lookback period, the fuel specific MPC is used.	75.33(c)(6) 75.33(c)(8)(iii)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.33(c)(8)

Miscellaneous Fuel Specific NO_X Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

Season Specific NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(1) 75.74(c)(7)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(2) 75.74(c)(7)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges. Historical data is separated into season specific pools.	75.31(c)(3) 75.74(c)(7)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Season Specific NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(i) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(A) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(B) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(i) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(A) 75.34(a)(2) 75.74(c)(7)

For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(B) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(3) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with an MPC.	75.33(c)(4) 75.74(c)(7)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into season specific pools.	75.33(c)(5) 75.34(a)(2) 75.74(c)(7)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6) 75.34(a)(2) 75.74(c)(7)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.34(a)(2) 75.74(c)(7)

Miscellaneous Season Specific NO_X Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

CO_2 Missing Data Verification Checklist [2]

Initial CO_2 Data Substitution: 75.35(b) [75.31]

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard CO_2 Data Substitution: 75.35(d) [75.33]

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous CO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

2 The CO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

Missing Data Verification Checklist [3]

Initial Stack Flow Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard Stack Flow Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)

For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(c)(4)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous Stack Flow Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

3 The stack flow missing data verification mentioned here does not apply to Cricket Valley Energy Center

TECHNICAL DOCUMENT - DATA SUBSTITUTION - 1 [4]

SO2 Missing Data Verification Checklist [5]

Initial SO2 Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)	DS1 1/1/99
	Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)	DS2 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Standard SO2 Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)	DS1 3/3/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)	DS1 6/14/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)	DS1 6/30/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.33(b)(4)	DS1 7/31/99
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)	DS3 3/31/02

Miscellaneous SO2 Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

O2 Missing Data Verification Checklist

Initial O2 Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(b) 75.31(b)(1)	DS1 1/1/99
	Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.36(b) 75.31(b)(2)	DS2 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Standard O2 Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 10^{th} percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(ii)(A)	DS1 3/3/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 10^{th} percentile of the lookback period.	75.36(d) 75.33(b)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 5^{th} percentile of the	75.36(d) 75.33(b)(2)(ii)(A)	DS1 6/14/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.		
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 5th percentile of the lookback period.	75.36(d) 75.33(b)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the minimum value in the lookback period.	75.36(d) 75.33(b)(3)	DS1 6/30/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.36(d) 75.33(b)(4)	DS1 7/31/99
	Substitution routines have a maximum lookback period of 26280 hours.	75.36(d) 75.33(a)	DS3 3/31/02

Miscellaneous SO2 Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

NOx Missing Data Verification Checklist

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)	DS1 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

4 The dates and data sets for in-house testing of formulas, monitor code logic and general software testing is historical, but is consistent with the operations required by the most recent regulatory requirements.

5 The stack SO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Standard NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)	DS2 1/3/00
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.33(c)(4)	DS1 8/3/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)	DS2 1/3/00
	If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)	DS2 1/3/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Miscellaneous NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

Appendix D Fuel Flow Rate Missing Data Verification Checklist

Single Fuel Hours, Load Based: Appendix D

P/F	Description	Regulation	Test
	Non-QA data is substituted with the average of the lookback period at the corresponding load range when only the same fuel was combusted.	App. D 2.4.2.2.1	DS1 1/24/99
	Non-QA data is substituted with the average of the lookback period at the next higher available load range when only the same fuel was combusted if no data in the corresponding load range exists.	App. D 2.4.2.2.1	DS2 1/2/00
	Non-QA data is substituted with the a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when only the same fuel was combusted exists.	App. D 2.4.2.2.1	DS2 1/1/99
	Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3	DS3 6/30/03

Co-Fired Fuel Hours, Load Based: Appendix D

P/F	Description	Regulation	Test
	Non-QA data is substituted with the maximum in the lookback period at the corresponding load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS1 1/1/99
	Non-QA data is substituted with the maximum in the lookback period at the next higher available load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS2 1/3/00
	Non-QA data is substituted with a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when the same fuel is co-fired with another fuel exists.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS1 1/1/99
	Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3	DS3 6/30/03

Note: If Maximum Heat Rate is exceeded, manual adjustment of Fuel Flows is allowed so that reported Heat Rate equals the maximum. (App. D 2.4.2.3.4)

Fuel Specific NOx Missing Data Verification Checklist

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)	DS1 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Fuel Specific NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 5/31/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/16/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(3) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a fuel specific MPC.	75.33(c)(4) 75.33(c)(8)(iii)	DS1 7/31/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(5) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 7/31/99
	If no data in the corresponding or higher load ranges exists in the lookback period, the fuel specific MPC is used.	75.33(c)(6) 75.33(c)(8)(iii)	DS1 1/30/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.33(c)(8)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Miscellaneous Fuel Specific NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

Season Specific NOx Missing Data Verification Checklist

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(1) 75.74(c)(7)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(2) 75.74(c)(7)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges. Historical data is separated into season specific pools.	75.31(c)(3) 75.74(c)(7)	DS1 1/31/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Season Specific NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(i) 75.34(a)(2) 75.74(c)(7)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(A) 75.34(a)(2) 75.74(c)(7)	DS1 5/31/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(B) 75.34(a)(2) 75.74(c)(7)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(i) 75.34(a)(2) 75.74(c)(7)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(A) 75.34(a)(2) 75.74(c)(7)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(B) 75.34(a)(2) 75.74(c)(7)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(3) 75.34(a)(2) 75.74(c)(7)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with an MPC.	75.33(c)(4) 75.74(c)(7)	DS1 7/31/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into season specific pools.	75.33(c)(5) 75.34(a)(2) 75.74(c)(7)	DS1 7/31/99
	If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6) 75.34(a)(2) 75.74(c)(7)	DS1 1/30/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.34(a)(2) 75.74(c)(7)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Miscellaneous Season Specific NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Cricket Valley All Settings

Cricket Valley Energy Center

Group	Setting	Value	Last changed
Facility- Fuel Constants			
	Nat Gas GCV Btu/scf	1050	1/25/2019 5:19 PM
	Fd Factor Gas dscf/mmBtu	8710	1/25/2019 5:19 PM
	Fc Factor Gas dscf/mmBtu	1040	1/25/2019 5:19 PM
	Gas Density lb/scf	0.042	1/25/2019 5:19 PM
Turbine 2 40CFR75 Settings			
	75-NOx ppm Scale Max	200	1/28/2020 7:27 PM
	75-NOx ppm Scale Exceedance Default	400	1/28/2020 7:27 PM
	75-NOx Bias Factor	1	1/28/2020 7:27 PM
Turbine 2 Emission Factor Settings [6]			
	PM10/PM2.5 lb/mmBtu	0.0005	1/28/2020 7:21 PM
	VOC lb/mmBtu	0.0002	1/28/2020 7:21 PM
	H2SO4 lb/mmBtu	0.0001	1/28/2020 7:21 PM

6 Emission factors found here are only sample settings used to confirm that software is calculating correctly.

Formula Verification Examples

Unit Name:	**CRICKET VALLEY ENERGY CENTER**	**Oris Code:**	**57185**
Date/ Time:	**1/6/2020 HOUR 1500**	**Unit /Stack #**	**U002**

Formula **19-1**
Parameter **NOx lb/mmBtu for gas**

Fd dscf/mmbtu	K units lb/dscf-ppm Nox	NOx ppmv	O2 dry %	**NOx lb/mmBtu**	BAF	**Bias adj. NOx lb/mmBtu**
8710	1.194E-07	11.30	14.12	**0.0362**	1.000	**0.0362**

Formula **F-20**
Parameter **Heat Input - gas**

CT Total NG hscf/hr	CT Op Time hr	DB Total NG hscf/hr	DB Op Time hr	**Total NG hscf**
12171.4	1	90.8	1.00	**12262.2**

NG GCV Btu/hscf	mmBtu/Btu	CT Heat input mmBtu	DB Heat input mmBtu	**Total Heat input mmBtu**
105000	1.00E-06	1278.0	9.6	**1287.5**

Formula **F-24A**
Parameter **NOx lb/hr** **gas**

NOx lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NOx lb/hr**	BAF	**Bias adj. NOx lb/hr**
0.036	1278.0	9.6	**46.6**	1.000	**46.6**

Formula **G-4**
Parameter **CO2 ton/hr** **gas**

Fc scf/mmbtu	CT HI gas mmBtu/hr	DB HI gas mmBtu/hr	M Wt CO2 g/g-mole	Conversion 1/385 scf CO2/lbmole	Convers lb/ton	**CO2 Ton/hr**
1040	1278.0	9.6	44	2.60E-03	2000	**76.5**

Formula **D-5**
Parameter **SO2 lb/hr** **gas**

CT HI gas mmBtu/hr	DB HI gas mmBtu/hr	SO2 EF lb/mmBtu	**SO2 lb/hr**
1278.0	9.6	0.0006	**0.78**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 2- Daily 40CFR75 Emissions & Operations Report

January 6, 2020

Hour	O2 %	NOx ppm	NOx lb/mmBtu	Bias Factor	Bias Adj NOx lb/mmBtu	NOx lbs	SO2 lbs	CO2 tons	Gas Flow hscf/hr	Nat Gas GCV Btu/hscf	Heat Input mmBtu/hr	Turbine On-Time	Total Megawatts	Bin Load Range
00	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
01	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
02	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
03	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
04	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
05	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
06	**DCal**	**DCal**	**DCal**	1.000	**DCal**	**DCal**	**Down**	**Down**	**Down**	105000	**Down**	0.00	**Down**	**Down**
07	17.31	36.10	0.2186	1.000	0.2186	34.4	0.10	9.4	6000.0	105000	630.0	0.25	9.7	1
08	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	0.01	0.3	85.7	105000	9.0	0.63	**Down**	**Down**
09	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	0.01	0.5	79.8	105000	8.4	0.97	**Down**	**Down**
10	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	0.00	0.5	78.7	105000	8.3	0.93	**Down**	**Down**
11	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	0.00	0.4	78.7	105000	8.3	0.75	**Down**	**Down**
12	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	0.00	0.2	72.2	105000	7.6	0.42	**Down**	**Down**
13	16.98	40.40	0.2240	1.000	0.2240	154.2	0.41	40.9	6764.9	105000	710.3	0.98	19.0	1
14	14.10	10.75	0.0344	1.000	0.0344	44.0	0.77	76.0	12174.1	105000	1278.3	1.00	82.0	5
15	14.12	11.30	0.0362	1.000	0.0362	46.6	0.78	76.5	12262.2	105000	1287.5	1.00	82.4	5
16	13.28	14.09	0.0402	1.000	0.0402	83.6	1.25	123.6	19806.3	105000	2079.7	1.00	189.7	10
17	13.02	15.66	0.0432	1.000	0.0432	106.2	1.48	146.0	23402.0	105000	2457.2	1.00	235.4	10
18	13.02	15.31	0.0422	1.000	0.0422	103.7	1.48	146.0	23400.7	105000	2457.1	1.00	235.8	10
19	13.02	14.40	0.0397	1.000	0.0397	97.6	1.48	146.1	23404.3	105000	2457.5	1.00	236.4	10
20	13.02	13.98	0.0386	1.000	0.0386	94.8	1.48	146.0	23394.9	105000	2456.5	1.00	236.6	10
21	13.29	14.37	0.0410	1.000	0.0410	36.3	0.54	52.7	19538.2	105000	2051.5	1.00	186.8	10
22	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	0.01	0.5	83.8	105000	8.8	1.00	**Down**	**Down**
23	**Down**	**Down**	**Down**	1.000	**Down**	**Down**	0.01	0.5	85.1	105000	8.9	1.00	**Down**	**Down**

Formula Verification Examples

Unit Name: **CRICKET VALLEY ENERGY CENTER** **Oris Code:** **57185**
Date/ Time: **1/6/2020 HOUR 1500** **Unit /Stack #** **U002**

Formula **19-1**
Parameter **NOx lb/mmBtu for gas**

Fd dscf/mmbtu	K units lb/dscf-ppm Nox	NOx ppmv	O2 dry %	**NOx lb/mmBtu**
8710	1.194E-07	11.30	14.12	**0.0362**

Formula **F-20**
Parameter **Heat Input - gas**

CT Total NG hscf/hr	CT Op Time hr	DB Total NG hscf/hr	DB Op Time hr	Total PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**Total Heat input mmBtu**
12171.4	1	90.8	1.00	12262.2	105000	1.00E-06	**1287.5**

CT Total PNG klb/hr	PNG Density klb/hscf	CT Op Time hr	Total CT PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**CT Heat input mmBtu**
51.1	0.0042	1	12171.4	105000	1.00E-06	**1278.0**

DB Total PNG kscf/hr	conversion hscf/kscf	DB Op Time hr	Total DB PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**DB Heat input mmBtu**
9.1	10.0	1	90.8	105000	1.00E-06	**9.5**

Parameter **NOx ppm@15% O2**

NOx ppm	O2 dry %	**NOx ppm corr**
11.30	14.12	**9.83**

Parameter **NOx lb/hr** **gas**

NOx lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NOx lb/hr**
0.0362	1278.0	9.5	**46.61**

Parameter **CO ppm@15% O2**

Formula **19-1**
Parameter **CO lb/mmBtu for gas**

Fc scf CO2/mmbtu	K ppmvd)	CO MW lb/lb-mol	CO ppmv	O2 dry %	**CO lb/mmBtu**
8710	2.59E-09	28	9.42	14.12	**0.0183**

CO ppm	O2 dry %	**CO ppm corr**
9.42	14.12	**8.20**

Parameter **CO lb/hr** **gas**

CO lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**CO lb/hr**
0.0183	1278.0	9.5	**23.56**

Formula **19-1**
Parameter **NH3 lb/mmBtu for gas**

Fc scf CO2/mmbtu	K ppmvd)	NH3 MW lb/lb-mol	NH3 ppmv	O2 dry %	**NH3 lb/mmBtu**
8710	2.59E-09	17.03	0.36	14.12	**0.0004**

NH3 ppm	O2 dry %	**NH3 ppm corr**
0.36	14.12	**0.31**

Parameter **CO lb/hr** **gas**

NH3 lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NH3 lb/hr**
0.0004	1278.0	9.5	**0.51**

Parameter **PM10/PM2.5 lb/hr** **gas**

CT HI gas mmBtu/hr	CT PM10/PM2.5 EF lb/mmBtu	**CT PM10/PM2.5 lb/hr**	DB HI gas mmBtu/hr	DB PM10/PM2.5 EF lb/mmBtu	**DB PM10/PM2.5 lb/hr**	**Total PM10/PM2.5 lb/hr**
1278.0	0.0005	**0.64**	9.5	0.0005	**0.00**	**0.64**

Parameter **VOC lb/hr** **gas**

CT HI gas mmBtu/hr	VOC EF lb/mmBtu	**CT VOC lb/hr**	DB HI gas mmBtu/hr	VOC EF lb/mmBtu	**DB VOC lb/hr**	**Total VOC lb/hr**
1278.0	0.0002	**0.26**	9.5	0.0002	**0.00**	**0.26**

Parameter **H2SO4 lb/hr** **gas**

CT HI gas mmBtu/hr	H2SO4 EF lb/mmBtu	**CT H2SO4 lb/hr**	DB HI gas mmBtu/hr	H2SO4 EF lb/mmBtu	**DB H2SO4 lb/hr**	**Total H2SO4 lb/hr**
1278.0	0.0001	**0.13**	9.5	0.0001	**0.00**	**0.13**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 2- Daily Emissions Report

January 6, 2020

Hourly Emission Limits

Normal Ops NOx ppm @15% O2 - 2 | Normal Ops CO ppm @15% O2 - 2 | NH3 Slip ppm @15% O2 - 5

30-Day Rolling Emission Limits

NOx ppm @15% O2 - <Null>

Hour	O2 %	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lbs	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lbs	NH3 Slip ppm	NH3 Slip ppm @15% O2	NH3 Slip lb/mmBtu	NH3 Slip lbs	Process Status
00	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
01	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
02	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
03	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
04	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
05	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
06	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	**DCal**	Down
07	17.31	36.10	59.33	0.2186	34.43	418.68	688.08	1.5396	242.49	0.00	0.00	0.0000	0.00	Hot SU
08	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
09	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
10	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
11	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
12	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
13	16.98	40.40	60.81	0.2240	154.24	285.01	428.97	0.9598	660.91	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
14	14.10	10.75	9.33	0.0344	43.97	10.65	9.24	0.0207	26.46	0.36	0.31	0.0004	0.51	Hot SU
15	14.12	11.30	9.83	0.0362	46.61	9.42	8.20	0.0183	23.56	0.36	0.31	0.0004	0.51	Hot SU
16	13.28	14.09	10.91	0.0402	83.60	2.10	1.63	0.0036	7.48	0.36	0.28	0.0004	0.83	Hot SU
17	13.02	15.66	11.73	0.0432	106.15	0.93	0.70	0.0016	3.93	0.41	0.31	0.0004	0.98	Hot SU
18	13.02	15.31	11.46	0.0422	103.69	0.84	0.63	0.0014	3.44	0.38	0.28	0.0004	0.98	Hot SU
19	13.02	14.40	10.78	0.0397	97.57	0.85	0.64	0.0014	3.44	0.36	0.27	0.0004	0.98	Hot SU
20	13.02	13.98	10.47	0.0386	94.81	0.97	0.73	0.0016	3.93	0.37	0.28	0.0004	0.98	Hot SU
21	13.29	14.37	11.14	0.0410	36.35	60.05	46.56	0.1042	92.37	0.48	0.37	0.0005	0.44	Hot SU
22	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
23	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
Average	14.12	18.64	20.58	0.0758	80.14	78.95	118.54	0.2652	106.80	0.34	0.27	0.0004	0.69	
Total					801.42				1068.01				6.21	
30-Day			**NSD**											

Cricket Valley Energy Center

Dover Plains, NY

Turbine 2- Daily Operations & EMS Inlet Emissions Report

January 6, 2020

Hour	SCR NOx ppm	SCR O2 %	CO Cat CO ppm	CT Nat Gas Flow klb	CT Heat Input mmBtu	DB Nat Gas Flow kscf	DB Heat Input mmBtu	Total Heat Input mmBtu	GT Megawatt Hours	ST Megawatt Hours	Process Status
00	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
01	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
02	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
03	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
04	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
05	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
06	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	Down
07	**Cal**	**Cal**	358.15	6.3	157.5	**Down**	**Down**	157.5	2.4	**Down**	Hot SU
08	**Down**	**Down**	**DCal**	**Down**	**Down**	5.4	5.7	5.7	**Down**	**Down**	Down
09	**Down**	**Down**	**Down**	**Down**	**Down**	7.8	8.1	8.1	**Down**	**Down**	Down
10	**Down**	**Down**	**Down**	**Down**	**Down**	7.3	7.7	7.7	**Down**	**Down**	Down
11	**Down**	**Down**	**Down**	**Down**	**Down**	5.9	6.2	6.2	**Down**	**Down**	Down
12	**Down**	**Down**	**Down**	**Down**	**Down**	3.0	3.2	3.2	**Down**	**Down**	Down
13	38.37	16.74	267.50	27.3	680.9	7.3	7.6	688.5	18.6	**Down**	Hot SU
14	10.32	13.96	11.78	50.8	1269.0	8.8	9.3	1278.3	82.0	**Down**	Hot SU
15	10.74	13.98	10.75	51.1	1278.0	9.1	9.5	1287.5	82.4	**Down**	Hot SU
16	13.65	13.11	1.41	82.8	2070.0	9.2	9.7	2079.7	189.7	**Down**	Hot SU
17	15.27	12.84	0.00	97.9	2448.0	8.8	9.2	2457.2	235.4	**Down**	Hot SU
18	14.88	12.85	0.00	97.9	2448.0	8.6	9.1	2457.1	235.8	**Down**	Hot SU
19	14.00	12.85	0.00	97.9	2448.0	9.0	9.5	2457.5	236.4	**Down**	Hot SU
20	13.52	12.85	0.00	97.9	2448.0	7.9	8.3	2456.3	236.6	**Down**	Hot SU
21	15.15	13.25	79.60	35.1	878.5	7.5	7.9	886.4	186.8	**Down**	Hot SU
22	**Down**	**Down**	**Down**	**Down**	**Down**	8.4	8.8	8.8	**Down**	**Down**	Down
23	**Down**	**Down**	**Down**	**Down**	**Down**	8.5	8.9	8.9	**Down**	**Down**	Down
Average	16.21	13.60	72.92	64.5	1612.6	7.7	8.0	956.2	150.6	**Down**	
Total				645.0	16125.9	122.5	128.7	16254.6	1506.1	**Down**	

Cricket Valley Energy Center

Dover Plains, NY

Turbine 2- Daily Mass Emissions Report

January 6, 2020

Hour	NOx lbs	CO lbs	PM10/PM2.5 lbs	NH3 Slip lbs	VOC lbs	H2SO4 lbs	Turbine On-Time
00	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
01	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
02	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
03	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
04	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
05	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
06	**DCal**	**DCal**	**Down**	**DCal**	**Down**	**Down**	0.00
07	34.43	242.49	0.08	0.00	0.03	0.02	0.25
08	**Down**	**Down**	0.00	**Down**	0.00	0.00	0.63
09	**Down**	**Down**	0.00	**Down**	0.00	0.00	0.97
10	**Down**	**Down**	0.00	**Down**	0.00	0.00	0.93
11	**Down**	**Down**	0.00	**Down**	0.00	0.00	0.75
12	**Down**	**Down**	0.00	**Down**	0.00	0.00	0.42
13	154.24	660.91	0.34	**OOR**	0.14	0.07	0.98
14	43.97	26.46	0.63	0.51	0.25	0.13	1.00
15	46.61	23.56	0.64	0.51	0.26	0.13	1.00
16	83.60	7.48	1.04	0.83	0.41	0.21	1.00
17	106.15	3.93	1.22	0.98	0.49	0.24	1.00
18	103.69	3.44	1.22	0.98	0.49	0.24	1.00
19	97.57	3.44	1.22	0.98	0.49	0.24	1.00
20	94.81	3.93	1.22	0.98	0.49	0.24	1.00
21	36.35	92.37	0.44	0.44	0.18	0.09	1.00
22	**Down**	**Down**	0.00	**Down**	0.00	0.00	1.00
23	**Down**	**Down**	0.00	**Down**	0.00	0.00	1.00
Average	80.14	106.80	0.47	0.69	0.19	0.09	
Total	801.42	1068.01	8.05	6.21	3.23	1.61	14.93

Formula Verification Examples

Unit Name:	**144.5CRICKET VALLEY ENERGY CENTER**	**Oris Code:**	**57185**
Date/ Time:	**01/06/2020 HOUR 1500**	**Unit /Stack #**	**U002**

Formula **Conversion**
Parameter **CO2 metric tons-PNG**

CO2 (Eq. G-4) tons	conversion factor tons/metric ton	**CO2 metric tons**	GWP Factor	**CO2e (CO2) metric tons**
76.5	1.1023	**69.40**	1	**69.40**

Formula **C-10**
Parameter **CH4 metric tons-PNG**

Total CT HI mmBtu	Total DB HI mmBtu	CH4 EF kgCH4/mmBtu	Conversion metric ton/kg	**CH4 metric tons**	GWP Factor	**CO2e (CH4) metric tons**
1278.0	9.5	0.001	0.001	**0.00129**	25	**0.03225**

Formula **C-10**
Parameter **N2O metric tons-PNG**

Total CT HI mmBtu	Total DB HI mmBtu	N2O EF kgN2O/mmBtu	Conversion metric ton/kg	**N2O metric tons**	GWP Factor	**CO2e (N2O) metric tons**
1278.0	9.5	0.0001	0.001	**0.00013**	298	**0.03874**

Parameter **CO2e metric tons-PNG**

CO2e (CO2) metric tons	CO2e (CH4) metric tons	CO2e(N2O) metric tons	**CO2e (total) metric tons**
69.4	0.03225	0.03874	**69.47099**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 2- Daily GHG Emissions Report

January 6, 2020

Hour	Nat Gas GCV Btu/scf	Heat Input mmBtu	CO2 tons	CO2 Metric Tons	N2O Metric Tons	CH4 Metric Tons	N2O (CO2e) Metric Tons	CH4 (CO2e) Metric Tons	Total CO2e Metric Tons	Turbine On-Time
00	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
01	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
02	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
03	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
04	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
05	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
06	1050.0	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	**Down**	0.00
07	1050.0	157.5	9.4	8.53	0.00002	0.00016	0.00596	0.00400	8.53996	0.25
08	1050.0	5.7	0.3	0.27	0.00000	0.00001	0.00000	0.00025	0.27025	0.63
09	1050.0	8.1	0.5	0.45	0.00000	0.00001	0.00000	0.00025	0.45025	0.97
10	1050.0	7.7	0.5	0.45	0.00000	0.00001	0.00000	0.00025	0.45025	0.93
11	1050.0	6.2	0.4	0.36	0.00000	0.00001	0.00000	0.00025	0.36025	0.75
12	1050.0	3.2	0.2	0.18	0.00000	0.00000	0.00000	0.00000	0.18000	0.42
13	1050.0	688.5	40.9	37.10	0.00007	0.00069	0.02086	0.01725	37.13811	0.98
14	1050.0	1278.3	76.0	68.95	0.00013	0.00128	0.03874	0.03200	69.02074	1.00
15	1050.0	1287.5	76.5	69.40	0.00013	0.00129	0.03874	0.03225	69.47099	1.00
16	1050.0	2079.7	123.6	112.13	0.00021	0.00208	0.06258	0.05200	112.24458	1.00
17	1050.0	2457.2	146.0	132.45	0.00024	0.00246	0.07152	0.06150	132.58302	1.00
18	1050.0	2457.1	146.0	132.45	0.00024	0.00246	0.07152	0.06150	132.58302	1.00
19	1050.0	2457.5	146.1	132.54	0.00024	0.00246	0.07152	0.06150	132.67302	1.00
20	1050.0	2456.3	146.0	132.45	0.00024	0.00246	0.07152	0.06150	132.58302	1.00
21	1050.0	886.4	52.7	47.81	0.00009	0.00089	0.02682	0.02225	47.85907	1.00
22	1050.0	8.8	0.5	0.45	0.00000	0.00001	0.00000	0.00025	0.45025	1.00
23	1050.0	8.9	0.5	0.45	0.00000	0.00001	0.00000	0.00025	0.45025	1.00
Average Total	1050.0	16254.6	966.1	876.42	0.00161	0.01629	0.47978	0.40725	877.30703	14.93

APPENDIX 6

RELATIVE ACCURACY TEST AUDIT REPORT

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00002 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 25, 2020

Report Date: March 11, 2020



Corporate Headquarters
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012

AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices
Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00002 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 25, 2020

Prepared and Reviewed by:

Logan K. Tsotsoros

Logan Tsotsoros
AHU Support Staff

Gavin Dolsky

Gavin Dolsky, QI
Staff Engineer – Report Manager

I, _____

Matt McBride, QSTI
Sr. Project Manager
certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

Table of Contents

1.0 INTRODUCTION 1

1.1 TEST PURPOSE AND OBJECTIVES 1

1.2 SUMMARY OF TEST PROGRAM 2

1.2.1 Participating Organizations 2
1.2.2 Industry 2
1.2.3 Air Permit and Federal Requirements 2
1.2.4 Plant Location 2
1.2.5 Equipment Tested 2
1.2.6 Emission Points 2
1.2.7 Emission Parameters Measured 2
1.2.8 Date of Emission Test 2
1.2.9 Federal Certifications 3

1.3 KEY PERSONNEL 3

2.0 SUMMARY OF TEST RESULTS 3

3.0 SOURCE OPERATION 5

3.1 PROCESS DESCRIPTION 5

3.2 SAMPLING LOCATION 5

4.0 SAMPLING AND ANALYTICAL PROCEDURES 5

4.1 TEST METHODS 5

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS 6

APPENDICES

Appendix A Test Results and Calculations

Appendix B CEMS and Reference Method Data

Appendix C Calibration Gas Certifications

Appendix D Quality Assurance and Quality Control Data

Appendix E Stratification Test Data

Relative Accuracy Test Audit
General Electric, 7F.05, Unit #U-00002 CEMS
Cricket Valley Energy Center LLC
Cricket Valley Energy Center
Dover Plains, New York
February 25, 2020

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Relative Accuracy Test Audit (RATA) for nitrogen oxides (NOx), carbon monoxide (CO), ammonia (NH_3), and oxygen (O_2) from the exhaust of the General Electric, 7F.05, Unit #U-00002 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on February 25, 2020.

The accumulated data from the RATA provides the figures for evaluating the acceptability of the operation of the on-site continuous emission monitoring system (CEMS) for the monitoring of NOx, CO, NH_3, and O_2 from the General Electric, 7F.05, Unit #U-00002 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to perform the initial certification RATA on the CEMS that serves the General Electric, 7F.05, Unit #U-00002 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. Reference method (RM) testing followed the Code of Federal Regulations (CFR), Title 40 (40 CFR), Part 60 (40 CFR 60), Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320. RM values are compared with the on-site CEMS to document performance as required in the 40 CFR 60, Appendix B, Performance Specifications (PS) and 40 CFR 75 Appendix A and B. All relative accuracies were established on-site and were governed by the following sets of rules:

In accordance with 40 CFR 60, Appendix B, PS 2, Section 13.2, the NOx and NH_3 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent when average emissions during the test are greater than 50 percent of the emission standard or alternative relative accuracy (ARA) does not exceed 10.0 percent when the average emissions during the test are less than 50 percent of the emission standard. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

In accordance with 40 CFR 75, Appendix A, Section 3.3.2(a) and (b), the NOx RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and reference method (RM) values does not exceed 0.020 lb/MMBtu. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (f), and Appendix B, Figure 2, the NOx RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and RM values does not exceed 0.015 lb/MMBtu. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 3, Section 13.2, the O_2 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent or if the average difference between the CEMS and reference method (RM) values does not exceed plus or minus 1.0 percent of the measured value.

In accordance with 40 CFR 60, Appendix B, PS 4 and 4A, Sections 13.2 of each, the CO relative accuracy (RA) test results are acceptable if the RA does not exceed 10.0 percent, if the average difference between the CEMS and reference method (RM) values plus the 2.5 percent confidence coefficient (2.5%CC) does not exceed 5.0 parts per million (ppm), or if the alternative relative accuracy (ARA) does not exceed 5.0 percent. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations
- New York State Department of Environmental Conservation (NYSDEC)
- Cricket Valley Energy Center LLC
- Custom Instrumentation Services Corporation (CiSCO)
- Bechtel
- Air Hygiene

1.2.2 Industry
- Electric Utility / Electric Services

1.2.3 Air Permit and Federal Requirements
- Permit Number: 3-1326-00275/00009
- DEC ID: 3132600275
- 40 CFR 60, Appendix B, Performance Specifications (PS)
- 40 CFR 75, Appendix A and B

1.2.4 Plant Location
- Cricket Valley Energy Center in Dover Plains, New York
  - GPS Coordinates [Latitude 41.67616, Longitude -73.576914]
  - 2241 Route NY 22, Dover Plains, New York 12522
  - Federal Registry System / Facility Registry Service (FRS) No. – 110043333372
  - Source Classification Code (SCC) – 20100209

1.2.5 Equipment Tested
- General Electric, 7F.05, Unit #U-00002
  - NOx Analyzer (TAPI T200M, Serial No. 1013)
  - NH_3 Analyzer (TAPI T200M, Serial No. 1048)
  - CO Analyzer (TAPI T300M, Serial No. 519)
  - O_2 Analyzer (TAPI T803, Serial No. 129)

1.2.6 Emission Points
- Exhaust from the General Electric, 7F.05, Unit #U-00002
- For all gases, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00002, determined after conducting a stratification test

1.2.7 Emission Parameters Measured
- NOx
- CO
- NH_3
- O_2

1.2.8 Date of Emission Test
- February 25, 2020

1.2.9 Federal Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Cricket Valley Energy Center LLC:	Marc Duquette (mduquette@cricketvalley.com)	617-320-5219
Bechtel:	Ron Swanson (reswanson@bechtel.com)	571-262-0198
CiSCO:	Reginald Williams (rwilliams@ciscocems.com)	720-419-0177
Air Hygiene:	Matt McBride (mmcbride@airhygiene.com)	918-307-8865
Air Hygiene:	Swanson Bierman	918-307-8865
Air Hygiene:	Rob White	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00002 located at the Cricket Valley Energy Center on February 25, 2020 are summarized in the following table and relate only to the items tested.

TABLE 2.1
SUMMARY OF GENERAL ELECTRIC, 7F.05, UNIT #U-00002 RATA RESULTS

Pollutant	Units	Criteria			Results	Passed / Test Frequency
		CFR	Specification / Section	Standard		
NOx	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 7.84%	YES / ANNUAL
NOx	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 7.32%	YES / ANNUAL
NOx	lb/MMBtu	Part 75	Appendix A, Section 3.3.2(a),(b) Appendix B, Section 2.3.1.2(a),(f), Figure 2	RA ≤ 10%, or if lb/MMBtu ≤ 0.200, d ≤ ±0.020 lb/MMBtu Annual Incentive RA ≤ 7.5%, or if lb/MMBtu ≤ 0.2, d ≤ ±0.015 lb/MMBtu	RA = 7.88% RM = 0.01 lb/MMBtu d = 0.000 lb/MMBtu BAF=1.000	YES / ANNUAL
O_2	%vd	Part 60	Appendix B, Performance Specification 3, Section 13.2	RA ≤ 20%, or d ≤ ±1.0%	RA = 1.70% d = 0.2 %	YES / ANNUAL
CO	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	RA = 87.96% |d|+2.5%CC = 0.1 ppm	YES / ANNUAL
CO	lb/hr	Part 60	Appendix B, Performance Specification 4, 4A Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 lb/hr, or ARA ≤ 5%	RA = 98.88% |d|+2.5%CC = 0.1 ppm (|d|+2.5%CC = 0.7 lb/hr)	YES / ANNUAL
NH_3	ppmvd@15%O_2	Assumed Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	ARA = 4.38%	YES / ANNUAL
NH_3	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	ARA = 6.50%	YES / ANNUAL
Load	MW	Part 60	Appendix B, Performance Specifications	> 50% max load	354.2	WITHIN TOLERANCE
Load	MW	Part 75	Appendix A and B	normal load range	354.2	WITHIN TOLERANCE

Notes: RA = relative accuracy, ARA = alternative relative accuracy, RM = reference method value, d = difference between RM and CEMS value, CC = confidence coefficient, v = velocity, BAF = bias adjustment factor

The RATA passed for all pollutants (NOx, CO, NH_3, and O_2) in all units (ppm@15%O_2, lb/hr, lb/MMBtu, and %) under all 40 CFR 60 and 40 CFR 75 criteria.

Specifically, NOx in units of ppm@15%O_2 and lb/hr, passed 40 CFR 60 criteria with an RA less than 20 percent. NOx in units of lb/MMBtu passed the 40 CFR 75 alternative annual incentive criteria with an emissions rate of less than 0.200 lb/MMBtu and a difference between the RM and CEMS analyzers of less than 0.015 lb/MMBtu. Also the Bias Adjustment Factor test resulted in an adjustment factor equal to 1.0 (no adjustment required). O_2 in units of % passed the 40 CFR 60 criteria with an RA less than 20 percent. CO in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 alternative criteria with a concentration difference between the RM and CEMS analyzers plus the confidence coefficient of less than 5 ppm and 5 lb/hr respectively. NH_3 in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 criteria with an RA less than 20 percent.

Unit load was within the 40 CFR 60 required criteria of greater than 50 percent of the maximum load and also fell within the normal load criteria as defined by the plants Quality Control and Monitoring Plan which defined the upper and lower boundary on the unit and the normal and secondary normal load ranges.

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

Cricket Valley Energy Center LLC (CVEC) owns and operates the Cricket Valley Energy Center located at 2241 ST RTE 22 in Dover Plains, New York. Located on the Cricket Valley Energy Center are three General Electric (GE) 7F.05 Combustion Turbine Generators (CTGs), designated as U-00001, U-00002, and U-0003, and each unit is equipped with one heat recovery steam generator (HRSG) with supplemental duct firing. Each unit is rated at 381 megawatts (MW). The nominal MW per unit as per the NYSDEC Permit ID 3-1326-00275/00009 is identified as 333 MW.

A single, dedicated dry extraction based continuous emissions monitoring system (CEMS) is installed on each unit. The CEMS configurations include nitrogen oxide (NOx) analyzers, ammonia (NH_3) analyzers, carbon monoxide (CO) analyzers, diluent gas oxygen (O_2) analyzers, and data acquisition and handling systems (DAHS).

3.2 SAMPLING LOCATION

The CTG stack is vertical, circular, and measures 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 265.8 ft above grade level with an exit elevation of approximately 282.5 ft above grade level. The test ports are located approximately 70.8 ft (850 inches) downstream and approximately 16.7 ft (200.4 inches) upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by Cricket Valley Energy Center LLC. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test. During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the General Electric, 7F.05, Unit #U-00002 at the Cricket Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on February 25, 2020.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Oxygen	EPA Method 3A	Paramagnetic Cell
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor
Ammonia and Moisture	EPA Method 320	Fourier Transform Infrared

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory / portable analyzer via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer, interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations. Spectral data was analyzed by the MKS MG2000 software.

Eleven test runs of approximately 21 minutes each were conducted on the General Electric, 7F.05, Unit #U-00002 for NOx, CO, NH_3, and O_2.

The stack gas analysis for O_2 concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O_2 analyzer uses a paramagnetic cell detector.

EPA Method 7E was used to determine concentrations of NOx. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO_2 in nitrogen certified gas cylinder was used to verify at least a 90 percent NO_2 conversion on the day of the test.


CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

An MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer, or equivalent, was used for NH_3 and H_2O analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm^{-1}. The system employed a silicon carbide infrared source at 1200ºC, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191ºC. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 4.0 liters per minute, the sample gas in the cell is refreshed approximately four times each minute. Interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations.


TABLE 4.2
ANALYTICAL INSTRUMENTATION

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NOx	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO_2 to NO. Chemiluminescence of reaction of NO with O_3. Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
NH_3 and H_2O	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
O_2	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

COPYRIGHT © 2011 AIR HYGIENE INTERNATIONAL, INC.



LEGEND
- Heated Teflon Tubing (pre-conditioned sample)
- Unheated Teflon Tubing (conditioned sample)
- Diluted Calibration Gas
- Calibration Gas
- Electronic Input/Output



PROCESS INLET OR 2ND STACK

dual line heated sample umbilical

STACK EXHAUST

TEST TRAILER EXTERIOR

TEST TRAILER INTERIOR


DATA RECORDER



COMPUTER




GAS CONDITIONER



dual line heated sample umbilical

MOBILE SECONDARY ANALYZERS

MANIFOLD





GAS DILUTER

THC, VOC



O_2, CO_2, NOx, CO, SO_2



HOT/WET ANALYZERS
COLD/DRY ANALYZERS




COLD/DRY ANALYZERS HOT/WET



O_2, CO_2, NOx, CO, SO_2

FLOW CONTROL MANIFOLD





FTIR


THC, VOC



CONDITIONER

VENT

CALIBRATION/ BIAS GAS BOTTLES



VENT

FIXED PRIMARY ANALYZERS

Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.

AIR HYGIENE

Figure 4.1
EMISSIONS TESTING LAB

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1:
EMISSIONS TESTING SCHEDULE

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
U-00002	Base Load	Stratification Test	1	02/25/20	6:14:22	7:12:22	DAHS
U-00002	Base Load	Gas RATA	1	02/25/20	11:53:28	12:13:58	DAHS
U-00002	Base Load	Gas RATA	2	02/25/20	12:32:28	12:52:58	DAHS
U-00002	Base Load	Gas RATA	3	02/25/20	13:07:28	13:27:58	DAHS
U-00002	Base Load	Gas RATA	4	02/25/20	13:36:28	13:56:58	DAHS
U-00002	Base Load	Gas RATA	5	02/25/20	14:15:28	14:35:58	DAHS
U-00002	Base Load	Gas RATA	6	02/25/20	14:46:28	15:06:58	DAHS
U-00002	Base Load	Gas RATA	7	02/25/20	15:17:28	15:37:58	DAHS
U-00002	Base Load	Gas RATA	8	02/25/20	15:47:28	16:07:58	DAHS
U-00002	Base Load	Gas RATA	9	02/25/20	16:20:28	16:40:58	DAHS
U-00002	Base Load	Gas RATA	10	02/25/20	16:51:28	17:11:58	DAHS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
O_2 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(%vd)	(%vd)	(diff)	($diff^2$)
1	11:53 - 12:13	NO	346.6	13.36	13.04		
2	12:32 - 12:52	YES	345.9	13.25	13.06	0.19	0.04
3	13:07 - 13:27	YES	345.4	13.29	13.07	0.22	0.05
4	13:36 - 13:56	NO	345.6	11.85	13.07		
5	14:15 - 14:35	YES	345.4	13.30	13.06	0.24	0.06
6	14:46 - 15:06	YES	345.5	13.25	13.07	0.18	0.03
7	15:17 - 15:37	YES	345.3	13.27	13.06	0.21	0.04
8	15:47 - 16:07	YES	345.8	13.25	13.05	0.20	0.04
9	16:20 - 16:40	YES	373.2	12.43	12.23	0.20	0.04
10	16:51 - 17:11	YES	378.1	12.29	12.11	0.18	0.03
11	17:57 - 18:17	YES	379.9	12.31	12.08	0.23	0.05
12		NO					
	Total		**3204.5**	**116.63**	**114.79**	**1.84**	**0.38**
	Average		**356.1**	**12.96**	**12.75**	**0.20**	

Number of Runs	9
Standard Deviation	0.02
T-value	2.306
Confidence Coefficient	0.02

Average Difference =	**0.2**
Relative Accuracy =	**1.7%**

Part 60, Appendix B, Performance Specification 3,
13.2 CEMS Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent of the mean value of the reference method (RM) data. The results are also acceptable if the absolute value of the difference between the mean RM value and the mean CEMS value is less than or equal to 1.0 percent O2 (or CO2).

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:53 - 12:13	YES	346.6	1.58	1.70	-0.12	0.02
2	12:32 - 12:52	YES	345.9	1.54	1.65	-0.11	0.01
3	13:07 - 13:27	NO	345.4	1.55	1.45		
4	13:36 - 13:56	YES	345.6	1.58	1.68	-0.10	0.01
5	14:15 - 14:35	YES	345.4	1.50	1.57	-0.07	0.00
6	14:46 - 15:06	NO	345.5	1.42	1.50		
7	15:17 - 15:37	YES	345.3	1.51	1.60	-0.09	0.01
8	15:47 - 16:07	YES	345.8	1.58	1.71	-0.13	0.02
9	16:20 - 16:40	YES	373.2	1.65	1.77	-0.12	0.02
10	16:51 - 17:11	YES	378.1	1.58	1.70	-0.12	0.01
11	17:57 - 18:17	YES	379.9	1.59	1.70	-0.11	0.01
12		NO					
	Total		**3205.8**	**14.10**	**15.08**	**-0.98**	**0.11**
	Average		**356.2**	**1.57**	**1.68**	**-0.11**	

Number of Runs	9
Standard Deviation	0.02
T-value	2.306
Confidence Coefficient	0.01

Relative Accuracy = 7.8%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:53 - 12:13	YES	346.6	0.11	0.28	-0.17	0.03
2	12:32 - 12:52	NO	345.9	0.35	0.09		
3	13:07 - 13:27	YES	345.4	0.13	0.17	-0.04	0.00
4	13:36 - 13:56	NO	345.6	0.51	0.34		
5	14:15 - 14:35	YES	345.4	0.13	0.26	-0.13	0.02
6	14:46 - 15:06	YES	345.5	0.16	0.07	0.09	0.01
7	15:17 - 15:37	YES	345.3	0.14	0.07	0.07	0.00
8	15:47 - 16:07	YES	345.8	0.14	0.04	0.10	0.01
9	16:20 - 16:40	YES	373.2	0.11	0.00	0.11	0.01
10	16:51 - 17:11	YES	378.1	0.11	0.00	0.11	0.01
11	17:57 - 18:17	YES	379.9	0.12	0.02	0.10	0.01
12		NO					
	Total		**3205.2**	**1.15**	**0.91**	**0.24**	**0.11**
	Average		**356.1**	**0.13**	**0.10**	**0.03**	

Number of Runs	9
Standard Deviation	0.11
T-value	2.306
Confidence Coefficient	0.09

Relative Accuracy =	**88.0%**
|d (difference in ppm)| + CC =	**0.11**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:53 - 12:13	YES	346.6	0.66	0.71	-0.05	0.00
2	12:32 - 12:52	YES	345.9	0.85	0.73	0.12	0.02
3	13:07 - 13:27	YES	345.4	0.87	1.02	-0.15	0.02
4	13:36 - 13:56	YES	345.6	0.68	0.74	-0.06	0.00
5	14:15 - 14:35	YES	345.4	0.87	0.83	0.04	0.00
6	14:46 - 15:06	YES	345.5	0.66	0.87	-0.21	0.04
7	15:17 - 15:37	YES	345.3	0.66	0.81	-0.15	0.02
8	15:47 - 16:07	YES	345.8	0.61	0.94	-0.33	0.11
9	16:20 - 16:40	NO	373.2	0.48	0.82		
10	16:51 - 17:11	NO	378.1	0.60	0.99		
11	17:57 - 18:17	YES	379.9	1.53	1.00	0.53	0.28
12		NO					
	Total		**3145.4**	**7.40**	**7.65**	**-0.25**	**0.50**
	Average		**349.5**	**0.82**	**0.85**	**-0.03**	

Number of Runs	9
Standard Deviation	0.25
T-value	2.306
Confidence Coefficient	0.19

Relative Accuracy =	**26.6%**
Applicable Standard =	**5.00**
Alternative Relative Accuracy =	**4.4%**

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	14.14	15.13	-0.99	0.97
2	12:32 - 12:52	YES	345.9	13.77	14.65	-0.88	0.78
3	13:07 - 13:27	NO	345.4	13.85	12.89		
4	13:36 - 13:56	YES	345.6	14.11	14.90	-0.79	0.62
5	14:15 - 14:35	YES	345.4	13.41	13.95	-0.54	0.30
6	14:46 - 15:06	NO	345.5	12.65	13.27		
7	15:17 - 15:37	YES	345.3	13.45	14.13	-0.68	0.47
8	15:47 - 16:07	YES	345.8	14.15	15.18	-1.03	1.05
9	16:20 - 16:40	YES	373.2	16.10	17.22	-1.12	1.26
10	16:51 - 17:11	YES	378.1	15.67	16.80	-1.13	1.28
11	17:57 - 18:17	YES	379.9	15.73	16.73	-1.00	1.01
12		NO					
	Total		**3205.8**	**130.52**	**138.69**	**-8.17**	**7.74**
	Average		**356.2**	**14.50**	**15.41**	**-0.91**	

Number of Runs	9
Standard Deviation	0.20
T-value	2.306
Confidence Coefficient	0.15

Relative Accuracy = 7.3%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	0.58	1.15	-0.57	0.32
2	12:32 - 12:52	NO	345.9	1.93	0.38		
3	13:07 - 13:27	YES	345.4	0.69	0.91	-0.22	0.05
4	13:36 - 13:56	NO	345.6	2.76	0.26		
5	14:15 - 14:35	YES	345.4	0.72	0.20	0.52	0.27
6	14:46 - 15:06	YES	345.5	0.89	0.37	0.52	0.28
7	15:17 - 15:37	YES	345.3	0.74	0.31	0.43	0.19
8	15:47 - 16:07	YES	345.8	0.77	0.21	0.56	0.31
9	16:20 - 16:40	YES	373.2	0.64	0.00	0.64	0.41
10	16:51 - 17:11	YES	378.1	0.68	0.00	0.68	0.47
11	17:57 - 18:17	YES	379.9	0.71	0.01	0.70	0.49
12		NO					
	Total		**3205.2**	**6.43**	**3.16**	**3.27**	**2.78**
	Average		**356.1**	**0.71**	**0.35**	**0.36**	

Number of Runs	9
Standard Deviation	0.45
T-value	2.306
Confidence Coefficient	0.34

Relative Accuracy =	**98.9%**
|d (difference in lb/hr)| + CC =	**0.71**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	2.20	2.40	-0.20	0.04
2	12:32 - 12:52	YES	345.9	2.83	2.44	0.39	0.15
3	13:07 - 13:27	YES	345.4	2.88	3.38	-0.50	0.25
4	13:36 - 13:56	YES	345.6	2.26	2.46	-0.20	0.04
5	14:15 - 14:35	YES	345.4	2.87	2.71	0.16	0.02
6	14:46 - 15:06	YES	345.5	2.19	2.87	-0.68	0.46
7	15:17 - 15:37	YES	345.3	2.17	2.64	-0.47	0.22
8	15:47 - 16:07	YES	345.8	2.01	2.39	-0.38	0.14
9	16:20 - 16:40	NO	373.2	1.73	2.91		
10	16:51 - 17:11	NO	378.1	2.20	3.59		
11	17:57 - 18:17	YES	379.9	5.62	3.60	2.02	4.10
12		NO					
	Total		**3145.4**	**25.03**	**24.89**	**0.14**	**5.42**
	Average		**349.5**	**2.78**	**2.77**	**0.02**	

Number of Runs	9
Standard Deviation	0.82
T-value	2.306
Confidence Coefficient	0.63

Relative Accuracy =	**23.3%**
Applicable Standard* =	**9.98**
Alternative Relative Accuracy =	**6.5%**

* Value calculated using the Applicable Standard of 5 ppm@15%O_2 and the average stack flow and O_2 concentration for the first three runs.

$$NH_3\ {}^{lb}/_{hr} = \frac{(20.9-15)*C_{adj}*Q_s*MW}{(20.9-\%O_2)*10^6*G} = \frac{(20.9-15)*5*58{,}140{,}133*17.03}{(20.9-13.3)*10^6*385.23} = 9.98$$

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/MMBtu)	(lb/MMBtu)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	0.0058	0.0062	-0.0004	0.0000
2	12:32 - 12:52	YES	345.9	0.0057	0.0061	-0.0004	0.0000
3	13:07 - 13:27	NO	345.4	0.0057	0.0053		
4	13:36 - 13:56	YES	345.6	0.0058	0.0062	-0.0004	0.0000
5	14:15 - 14:35	YES	345.4	0.0055	0.0058	-0.0003	0.0000
6	14:46 - 15:06	NO	345.5	0.0052	0.0055		
7	15:17 - 15:37	YES	345.3	0.0056	0.0059	-0.0003	0.0000
8	15:47 - 16:07	YES	345.8	0.0058	0.0063	-0.0005	0.0000
9	16:20 - 16:40	YES	373.2	0.0061	0.0065	-0.0004	0.0000
10	16:51 - 17:11	YES	378.1	0.0058	0.0063	-0.0005	0.0000
11	17:57 - 18:17	YES	379.9	0.0058	0.0062	-0.0004	0.0000
12		NO					
	Total		**3205.8**	**0.0519**	**0.0555**	**-0.0036**	**0.0000**
	Average		**356.2**	**0.0058**	**0.0062**	**-0.0004**	

Number of Runs	9
Standard Deviation	0.0001
T-value	2.306
Confidence Coefficient	0.0001

Relative Accuracy = 7.88%

If the mean difference is less than or equal to the absolute value of the confidence coefficient, then the Bias Test passes and the bias adjustment factor is not applicable.

Mean Difference =	-0.0004
Confidence Coefficient =	0.0001

BAF = 1 + (abs. value mean difference/avg. CEMS reading)

Average CEMS Reading =	0.0062
BAF =	**1.000**

Part 75, Appendix A,
3.3.2 Relative Accuracy for NOX-Diluent Continuous Emission Monitoring Systems
(a) The relative accuracy for NOX-diluent continuous emission monitoring systems shall not exceed 10.0 percent.
(b) For affected units where the average of the reference method measurements of NOX emission rate (this means lb/MMBtu) during the relative accuracy test audit is less than or equal to 0.200 lb/mmBtu, the difference between the mean value of the continuous emission monitoring system measurements and the reference method mean value shall not exceed ±0.020 lb/mmBtu, wherever the relative accuracy specification of 10.0 percent is not achieved.

7.6.5 Bias Adjustment
(b) For single-load RATAs of SO2 pollutant concentration monitors, NOX concentration monitoring systems, and NOX-diluent monitoring systems and for the single-load flow RATAs required or allowed under section 6.5.2 of this appendix and sections 2.3.1.3(b) and 2.3.1.3(c) of Appendix B to this part, the appropriate BAF is determined directly from the RATA results at normal load, using Equation A-12. Notwithstanding, when a NOX concentration CEMS or an SO2 CEMS or a NOX-diluent CEMS installed on a low-emitting affected unit (i.e., average SO2 or NOX concentration during the RATA &IE; 250 ppm or average NOX emission rate &IE; 0.200 lb/mmBtu) meets the normal 10.0 percent relative accuracy specification (as calculated using Equation A-10) or the alternate relative accuracy specification in section 3.3 of this appendix for low-emitters, but fails the bias test, the BAF may either be determined using Equation A-12, or a default BAF of 1.111 may be used.

Part 75, Appendix B,
2.3.1.2 Reduced RATA Frequencies. Relative accuracy test audits of primary and redundant backup SO2 pollutant concentration monitors, CO2 pollutant concentration monitors (including O2 monitors used to determine CO2 emissions), CO2 or O2 diluent monitors used to determine heat input, moisture monitoring systems, NOX concentration monitoring systems, flow monitors, NOX-diluent monitoring systems or SO2-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:
(a) The relative accuracy during the audit of an SO2 or CO2 pollutant concentration monitor (including an O2 pollutant monitor used to measure CO2 using the procedures in appendix F to this part), or of a CO2 or O2 diluent monitor used to determine heat input, or of a NOX concentration monitoring system, or of a NOX-diluent monitoring system, or of an SO2-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(f) For units with low NOX emission rates (average NOX emission rate measured by the reference method during the RATA ≤ 0.200 lb/mmBtu), when a NOX-diluent continuous emission monitoring system fails to achieve a relative accuracy ≤ 7.5 percent, but the monitoring system mean value from the RATA, calculated using Equation A-7 in appendix A to this part, is within ± 0.015 lb/mmBtu of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO2 or NOX(3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO2-diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NOX-diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO2 or O2	7.5% < RA ≤ 10.0% or ± 1.0% CO2/O2(2)	RA ≤ 7.5% or ± 0.7% CO2/O2(2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H2O(2)	RA ≤ 7.5% or ± 1.0% H2O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO2 monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.
(2) The difference between monitor and reference method mean values applies to moisture monitors, CO2, and O2 monitors, low emitters, or low flow, only.
(3) A NOX concentration monitoring system used to determine NOX mass emissions under § 75.71.

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO_2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH_3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO_2 (lb/lb-mole) =	44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO_2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH_3 =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO_2 =	0.0000001142434

NOTE: units are lb/ppm*ft^3

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right)$$

2. Correction to % O_2, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}} \right)$$

3. Correction to % O_2 and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_O - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O_2 based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp \cdot hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} or \frac{E_{lb/hr} \times 453.6}{hp}$$

RATA SHEET CALCULATIONS

d = Reference Method Data - CEMS Data

S_d = Standard Deviation

CC = Confident Coefficient

n = number of runs

$t_{0.025}$ = 2.5 percent confidence coefficient T-values

RA = relative accuracy

ARA = alternative relative accuracy

BAF = Bias adjustment factor

n	t	n	t	n	t
2	12.706	7	2.447	12	2.201
3	4.303	8	2.365	13	2.179
4	3.182	9	2.306	14	2.160
5	2.776	10	2.262	15	2.145
6	2.571	11	2.228	16	2.131

1. Difference

$$d = \sum_{i=1}^{n} d_i$$

2. Standard Deviation

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \left[\frac{\left(\sum_{i=1}^{n} d_i \right)^2}{n} \right]}{n-1}}$$

3. Confident Coefficient

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$

4. Relative Accuracy

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$

5. Alternative Relative Accuracy

$$ARA = \frac{|d_{AVG}| + |CC|}{AS} \times 100$$

5. Bias Adjustment Factor

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right)$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO_2 to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H_2O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
$\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
$\%_{CO2d}$,$\%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g.,24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO_2 rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O_2.
E_{jo},E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft^3 = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
$\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
$\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = $2x10^4$ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p,L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
$\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
$M_{\%}$ = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)[1]
NCM = net Btu per SCF (constant based on compound)
$\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
$\%_{O2d}$, $\%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO2 emissions, percent.
$\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
$\%_{Sf}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
$\%S_p$, $\%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
$t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2}=CO_2 Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RHsp (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp}(lb/lb) = \left[\left(\frac{gr}{lb}\right) \times \frac{lb}{7000\ gr}\right]$$

RH_{sp}= 32.23 gr / lb x 1 lb / 7000 gr = 0.004604 lb H_2O / lb Air

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

ACE = (5.09 ppm - 4.91 ppm) / 9.20 ppm x 100 = 1.96 %

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS}\right) \times 100$$ Eq. 7E-2

SB = (4.93 ppm - 5.09 ppm) / 9.20 ppm x 100 = -1.74 %

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = \left|SB_{final} - SB_t\right|$$ Eq. 7E-4

D = | -2.83 % - -1.74 % | = 1.09 %

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs – Cdir| is ≤ 0.5 ppmv or if |Cs – Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = \left|C_S - C_{Dir}\right|$$ Eq. Section 13.2 and 13.3

SB / D_{Alt} = | 4.93 ppm - 5.09 ppm | = 0.16 ppm

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$ Eq. 7E-5b

C_{Gas} = (1.85 ppm - -0.26 ppm) (4.91 ppm / 4.88 ppm - -0.26 ppm) = 2.02 ppm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Stack Exhaust Flow (Q_S) - RM19

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000}\right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}}\right)$$

Note: Equation presented in EPA Emission Measurement Center (EMC), Frequently Asked Questions (FAQ) for Method 19

Q_S = 8,710.00 SCF/MMBtu x 2,317,550.00 SCF/hr x 1,050.00 Btu/SCF x MMBtu/10^6 Btu x [20.90% / (20.9% - 13.4 %)] = 58,713,359.00 SCFH

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_W = C_D \times (1 - B_{WS})$$

$$C_D = \frac{C_W}{1 - B_{WS}}$$ Eq. 7E-10

C_D = 1.85 ppmvw / (1 - 0.08) = 2.02 ppmvd or inversely, C_W = 2.02 ppmvd x (1 - 0.08) = 1.85 ppmvw

Diluent-Corrected Pollutant Concentration, O_2 Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O_2 Concentration. Calculate the O_2 corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$ Eq. 20-4

C_{adj} = 2.02 ppm x [(20.9% - 15.00 %) / (20.9% - 13.36 %)] = 1.58 ppm@15%O_2

Emissions Rate (lb/hr)

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

$E_{lb/hr}$ = 2.02 ppmvd / 10^6 ppm/part x 58,713,359 DSCFH x 46.01 lb/lb-mol / 385.23 SCF/lb-mol = 14.14 lb/hr

Emissions Rate (lb/MMBtu)

RM 19, (02-27-14), 12.2 Emission Rates of PM, SO_2, and NOx. Select from the following sections the applicable procedure to compute the PM, SO_2, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for NOx gas Run 1, if applicable)

Oxygen Based

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O_2 ($\%O_2$d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$ Eq. 19-1

$E_{lb/MMBtu}$ = 2.02 ppm x 8,710.00 SCF/MMBtu x 0.0000001194 lb/ppm*ft^3 x 20.9% / (20.9% - 13.36 %) = 0.006 lb/MMBtu

Conversion Constant

Convc for NOx

$$Conv_c(lb/ppm \cdot ft^3) = \frac{\frac{MW}{G}}{10^6}$$

$Conv_c$ = (46.01 lb/lb•mole x lb•mole/385.23 SCF) / 10^6 = 0.0000001194 lb/ppm-ft^3

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RATA RESULTS)

Difference (d)

40 CFR 75, App A, (12-17-09), 7.3.1 Arithmetic Mean. Calculate the arithmetic mean of the differences, d , of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$d = \sum_{i=1}^{n} d_i$$ Eq. A-7

d = 0.006 lb/MMBtu - 0.006 lb/MMBtu = 0.000 lb/MMBtu

Standard Deviation

40 CFR 75, App A, (12-17-09), 7.3.2 Standard Deviation. Calculate the standard deviation, Sd, of a data set as follows:
(calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \frac{\left[\left(\sum_{i=1}^{n} d_i\right)^2\right]}{n}}{n-1}}$$ Eq. A-8

$$S_d = \sqrt{\frac{0.000 \text{ lb/MMBtu}^2 - \frac{(-0.004 \text{ lb/MMBtu})^2}{9}}{9 - 1}} = 0.000 \text{ lb/MMBtu}$$

Confidence Coefficient

40 CFR 75, App A, (12-17-09), 7.3.3 Confidence Coefficient. Calculate the confidence coefficient (one-tailed), cc, of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$ Eq. A-9

CC = 2.306 x $\frac{0.000 \text{ lb/MMBtu}}{\sqrt{9}}$ = 0.000 lb/MMBtu

T-Values	n	2	3	4	5	6	7	8	9
	$t_{0.025}$	12.706	4.303	3.182	2.776	2.571	2.447	2.365	2.306

2.5 percent confidence coefficients

Relative Accuracy

40 CFR 75, App A, (12-17-09), 7.3.4 Relative Accuracy. Calculate the relative accuracy of a data set using the following equation. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$ Eq. A-10

RA = $\frac{|0.000 \text{ lb/MMBtu}| + |0.000 \text{ lb/MMBtu}|}{0.006 \text{ lb/MMBtu}}$ x 100 = 7.88 %

Bias Adjustment Factor (BAF)

40 CFR 75, App A, (12-17-09), 7.6.5 Bias Adjustment. (a) If the monitor or monitoring system fails to meet the bias test requirement, adjust the value obtained from the monitor using the following equation: (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}}\right)$$ Eq. A-12

d_{AVG}= 0.000 < |CC| = 0.000 ⇨ BAF = 1 + $\frac{|\quad| \text{ lb/MMBtu}}{\text{lb/MMBtu}}$ = 1.000 lb/MMBtu

Note: BAF only applies if the mean difference (d) is greater than the absolute value of the confidence coefficient.

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B

CEMS AND REFERENCE METHOD DATA

Cricket Valley Energy Center LLC

Air Permit Number:	3-1326-00275/00009
Plant Name or Location:	Cricket Valley Energy Center
Date:	February 25, 2020
Project Number:	cis-19-cricketvalley.ny-start#1
Manufacturer & Equipment:	General Electric
Model:	7F.05
Unit Number:	U-00002
Test Load:	Base Load
Tester(s) / Test Unit(s):	MM/215

		RUN										
	UNITS	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**10**	**11**
Start Time	hh:mm:ss	11:53:28	12:32:28	13:07:28	13:36:28	14:15:28	14:46:28	15:17:28	15:47:28	16:20:28	16:51:28	17:57:28
End Time	hh:mm:ss	12:13:58	12:52:58	13:27:58	13:56:58	14:35:58	15:06:58	15:37:58	16:07:58	16:40:58	17:11:58	18:17:58
Bar. Pressure	in. Hg	29.38	29.36	29.34	29.33	29.30	29.33	29.33	29.33	29.33	29.34	29.37
Amb. Temp.	°F	54	55	55	56	59	56	56	55	55	54	51
Rel. Humidity	%	51	51	49	48	45	48	50	51	54	57	76
Spec. Humidity	lb water / lb air	0.004604	0.004760	0.004540	0.004504	0.004816	0.004585	0.004805	0.004759	0.004894	0.005008	0.006092
Turbine Fuel Flow	SCFH	2,317,550	2,310,200	2,308,160	2,308,570	2,306,530	2,306,940	2,305,710	2,311,140	2,528,440	2,554,920	2,563,390
Total Fuel Flow	SCFH	2,317,550	2,310,200	2,308,160	2,308,570	2,306,530	2,306,940	2,305,710	2,311,140	2,528,440	2,554,920	2,563,390
Power Output	megawatts	346.6	345.9	345.4	345.6	345.4	345.5	345.3	345.8	373.2	378.1	379.9
O_2 CEMS Data	%vd	13.04	13.06	13.07	13.07	13.06	13.07	13.06	13.05	12.23	12.11	12.1
NOx CEMS Data	ppmvd@15%O_2	1.70	1.65	1.45	1.68	1.57	1.50	1.60	1.71	1.77	1.70	1.70
	lb/hr	15.13	14.65	12.89	14.90	13.95	13.27	14.13	15.18	17.22	16.80	16.73
	lb/MMBtu	0.0062	0.0061	0.0053	0.0062	0.0058	0.0055	0.0059	0.0063	0.0065	0.0063	0.0062
CO CEMS Data	ppmvd@15%O_2	0.28	0.09	0.17	0.34	0.26	0.07	0.07	0.04	0.00	0.00	0.02
	lb/hr	1.15	0.38	0.91	0.26	0.20	0.37	0.31	0.21	0.00	0.00	0.01
NH_3 CEMS Data	ppmvd@15%O_2	0.71	0.73	1.02	0.74	0.83	0.87	0.81	0.94	0.82	0.99	1.00
	lb/hr	2.40	2.44	3.38	2.46	2.71	2.87	2.64	2.39	2.91	3.59	3.60
NH_3 RM Data	ppmvd@15%O_2	0.66	0.85	0.87	0.68	0.87	0.66	0.66	0.61	0.48	0.60	1.53
	lb/hr	2.20	2.83	2.88	2.26	2.87	2.19	2.17	2.01	1.73	2.20	5.62

Created with Comp&RATA&Eng-AHI v20190529

CEMS AND REFERENCE METHOD DATA

CEMS Data
(provided by Cricket Valley Energy Center LLC)

Relative Accuracy Test Data
CEMS Results (NOx)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxides of Nitrogen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Chemiluminescence
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1013

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		1.70	15.13	0.0062
2	12:32 - 12:52	345.9		1.65	14.65	0.0061
3	13:07 - 13:27	345.4		1.45	12.89	0.0053
4	13:36 - 13:56	345.6		1.68	14.90	0.0062
5	14:15 - 14:35	345.4		1.57	13.95	0.0058
6	14:46 - 15:06	345.5		1.50	13.27	0.0055
7	15:17 - 15:37	345.3		1.60	14.13	0.0059
8	15:47 - 16:07	345.8		1.71	15.18	0.0063
9	16:20 - 16:40	373.2		1.77	17.22	0.0065
10	16:51 - 17:11	378.1		1.70	16.80	0.0063
11	17:57 - 18:17	379.9		1.70	16.73	0.0062
12						

Relative Accuracy Test Data
CEMS Results (CO)
General Electric, 7F.05, Unit #U-00002

Parameter:	Carbon Monoxide
Date of Test:	February 25, 2020
Reference Method:	EPA Method 10
CEMS Analyzer Type:	Infrared Absorption
Manufacturer:	TAPI
Model #:	T300M
Serial #:	519

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.28	1.15	
2	12:32 - 12:52	345.9		0.09	0.38	
3	13:07 - 13:27	345.4		0.17	0.91	
4	13:36 - 13:56	345.6		0.34	0.26	
5	14:15 - 14:35	345.4		0.26	0.20	
6	14:46 - 15:06	345.5		0.07	0.37	
7	15:17 - 15:37	345.3		0.07	0.31	
8	15:47 - 16:07	345.8		0.04	0.21	
9	16:20 - 16:40	373.2		0.00	0.00	
10	16:51 - 17:11	378.1		0.00	0.00	
11	17:57 - 18:17	379.9		0.02	0.01	
12						

Relative Accuracy Test Data
CEMS Results (NH_3)
General Electric, 7F.05, Unit #U-00002

Parameter:	Ammonia
Date of Test:	February 25, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Dual NOx w/ NH3 conversion
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1048

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.71	2.40	
2	12:32 - 12:52	345.9		0.73	2.44	
3	13:07 - 13:27	345.4		1.02	3.38	
4	13:36 - 13:56	345.6		0.74	2.46	
5	14:15 - 14:35	345.4		0.83	2.71	
6	14:46 - 15:06	345.5		0.87	2.87	
7	15:17 - 15:37	345.3		0.81	2.64	
8	15:47 - 16:07	345.8		0.94	2.39	
9	16:20 - 16:40	373.2		0.82	2.91	
10	16:51 - 17:11	378.1		0.99	3.59	
11	17:57 - 18:17	379.9		1.00	3.60	
12						

Relative Accuracy Test Data
CEMS Results (O_2)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxygen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 3A
CEMS Analyzer Type:	Paramagnetic Cell
Manufacturer:	TAPI
Model #:	T803
Serial #:	129

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	11:53 - 12:13	346.6	13.04
2	12:32 - 12:52	345.9	13.06
3	13:07 - 13:27	345.4	13.07
4	13:36 - 13:56	345.6	13.07
5	14:15 - 14:35	345.4	13.06
6	14:46 - 15:06	345.5	13.07
7	15:17 - 15:37	345.3	13.06
8	15:47 - 16:07	345.8	13.05
9	16:20 - 16:40	373.2	12.23
10	16:51 - 17:11	378.1	12.11
11	17:57 - 18:17	379.9	12.08
12			

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 11:53 AM thru 2/25/2020 12:13 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 11:53	2.29	1.72	0.0063	15.29	0.25	0.19	0.97	0.94	0.71
2/25 11:54	2.30	1.73	0.0064	15.54	0.26	0.20	0.97	0.93	0.70
2/25 11:55	2.29	1.72	0.0063	15.29	0.26	0.20	0.97	0.93	0.70
2/25 11:56	2.28	1.71	0.0063	15.24	0.26	0.20	0.97	0.94	0.71
2/25 11:57	2.27	1.70	0.0063	15.24	0.23	0.17	0.97	0.94	0.71
2/25 11:58	2.26	1.70	0.0062	14.99	0.21	0.16	0.97	0.94	0.71
2/25 11:59	2.26	1.70	0.0062	15.05	0.17	0.13	0.73	0.94	0.71
2/25 12:00	2.25	1.69	0.0062	14.99	0.19	0.14	0.73	0.95	0.71
2/25 12:01	2.24	1.68	0.0062	14.99	0.24	0.18	0.97	0.95	0.71
2/25 12:02	2.24	1.68	0.0062	15.05	0.22	0.17	0.97	0.95	0.71
2/25 12:03	2.25	1.69	0.0062	15.05	0.25	0.19	0.97	0.95	0.71
2/25 12:04	2.27	1.70	0.0063	15.29	0.27	0.20	1.21	0.95	0.71
2/25 12:05	2.28	1.71	0.0063	15.24	0.27	0.20	1.21	0.95	0.71
2/25 12:06	2.28	1.71	0.0063	15.24	0.30	0.23	1.21	0.94	0.71
2/25 12:07	2.28	1.71	0.0063	15.29	0.29	0.22	1.21	0.95	0.71
2/25 12:08	2.26	1.70	0.0062	14.99	0.32	0.24	1.21	0.95	0.71
2/25 12:09	2.24	1.68	0.0062	14.99	0.36	0.27	1.45	0.95	0.71
2/25 12:10	2.24	1.68	0.0062	14.99	0.41	0.31	1.69	0.94	0.71
2/25 12:11	2.24	1.68	0.0062	15.05	0.44	0.33	1.70	0.94	0.71
2/25 12:12	2.24	1.68	0.0062	14.99	0.39	0.29	1.69	0.94	0.71
2/25 12:13	2.25	1.69	0.0062	14.94	0.35	0.26	1.45	0.94	0.71
Average (all)	2.26	1.70	0.0062	15.13	0.28	0.21	1.15	0.94	0.71
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.24	1.68	0.0062	14.94	0.17	0.13	0.73	0.93	0.70
Maximum (all)	2.30	1.73	0.0064	15.54	0.44	0.33	1.70	0.95	0.71
Average (valid values only)	2.26	1.70	0.0062	15.13	0.28	0.21	1.15	0.94	0.71
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 11:53 AM thru 2/25/2020 12:13 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 11:53	2.43	13.04	23228.6	232.6	346.9
2/25 11:54	2.18	13.04	23228.6	232.5	346.7
2/25 11:55	2.18	13.04	23228.6	232.5	346.8
2/25 11:56	2.42	13.04	23142.9	232.4	346.7
2/25 11:57	2.42	13.04	23142.9	232.5	346.7
2/25 11:58	2.42	13.04	23142.9	232.6	346.8
2/25 11:59	2.43	13.04	23228.6	232.5	346.8
2/25 12:00	2.42	13.04	23142.9	232.5	346.8
2/25 12:01	2.42	13.04	23142.9	232.4	346.7
2/25 12:02	2.43	13.04	23228.6	232.5	346.8
2/25 12:03	2.43	13.04	23228.6	232.5	346.8
2/25 12:04	2.43	13.03	23228.6	232.4	346.8
2/25 12:05	2.42	13.04	23142.9	232.4	346.7
2/25 12:06	2.42	13.04	23142.9	232.4	346.7
2/25 12:07	2.43	13.05	23228.6	232.3	346.5
2/25 12:08	2.42	13.04	23142.9	232.2	346.5
2/25 12:09	2.42	13.04	23142.9	232.4	346.1
2/25 12:10	2.42	13.04	23142.9	232.3	346.4
2/25 12:11	2.43	13.05	23228.6	232.2	346.4
2/25 12:12	2.42	13.05	23142.9	232.0	346.1
2/25 12:13	2.41	13.05	23057.1	232.1	346.2
Average (all)	2.40	13.04	23175.5	232.4	346.6
Total (all)	--	--	--	--	--
Minimum (all)	2.18	13.03	23057.1	232.0	346.1
Maximum (all)	2.43	13.05	23228.6	232.6	346.9
Average (valid values only)	2.40	13.04	23175.5	232.4	346.6
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 12:32 PM thru 2/25/2020 12:52 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 12:32	2.28	1.71	0.0063	15.24	0.28	0.21	1.21	0.93	0.70
2/25 12:33	2.27	1.71	0.0063	15.24	0.25	0.19	0.97	0.93	0.70
2/25 12:34	2.26	1.70	0.0063	15.18	0.19	0.14	0.72	0.94	0.71
2/25 12:35	2.24	1.68	0.0062	14.99	0.16	0.12	0.73	0.94	0.71
2/25 12:36	2.24	1.69	0.0062	14.94	0.16	0.12	0.72	0.93	0.70
2/25 12:37	2.23	1.68	0.0062	14.94	0.20	0.15	0.72	0.94	0.71
2/25 12:38	2.23	1.68	0.0062	14.99	0.17	0.13	0.73	0.95	0.71
2/25 12:39	2.22	1.67	0.0062	14.99	0.12	0.09	0.48	0.95	0.71
2/25 12:40	2.24	1.69	0.0062	14.99	0.11	0.08	0.48	0.94	0.71
2/25 12:41	2.25	1.69	0.0062	14.99	0.07	0.05	0.24	0.94	0.71
2/25 12:42	2.26	1.70	0.0063	15.18	0.01	0.01	0.00	0.94	0.71
2/25 12:43	2.27	1.71	0.0063	15.24	0.01	0.01	0.00	0.94	0.71
2/25 12:44	2.27	1.71	0.0063	15.18	0.00	0.00	0.00	0.94	0.71
2/25 12:45	2.27	1.71	0.0063	15.18	0.00	0.00	0.00	0.93	0.70
2/25 12:46	2.28	1.72	0.0063	15.24	0.00	0.00	0.00	0.93	0.70
2/25 12:47	2.27	1.71	0.0063	15.24	0.00	0.00	0.00	0.95	0.71
2/25 12:48	2.18	1.64	0.0060	14.46	0.00	0.00	0.00	0.99	0.75
2/25 12:49	2.07	1.56	0.0057	13.73	0.00	0.00	0.00	1.02	0.77
2/25 12:50	1.96	1.48	0.0054	13.01	0.00	0.00	0.00	1.06	0.80
2/25 12:51	1.86	1.40	0.0052	12.53	0.09	0.07	0.48	1.11	0.84
2/25 12:52	1.79	1.35	0.0050	12.09	0.10	0.08	0.48	1.17	0.88
Average (all)	2.19	1.65	0.0061	14.65	0.09	0.07	0.38	0.97	0.73
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.79	1.35	0.0050	12.09	0.00	0.00	0.00	0.93	0.70
Maximum (all)	2.28	1.72	0.0063	15.24	0.28	0.21	1.21	1.17	0.88
Average (valid values only)	2.19	1.65	0.0061	14.65	0.09	0.07	0.38	0.97	0.73
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 12:32 PM thru 2/25/2020 12:52 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 12:32	2.18	13.05	23142.9	231.8	346.1
2/25 12:33	2.18	13.05	23142.9	231.7	345.9
2/25 12:34	2.41	13.05	23057.1	231.9	346.2
2/25 12:35	2.42	13.05	23142.9	231.5	345.7
2/25 12:36	2.41	13.06	23057.1	231.7	346.0
2/25 12:37	2.41	13.06	23057.1	231.5	345.7
2/25 12:38	2.42	13.06	23142.9	231.6	345.8
2/25 12:39	2.42	13.06	23142.9	231.6	345.8
2/25 12:40	2.42	13.06	23142.9	231.7	345.9
2/25 12:41	2.42	13.06	23142.9	231.6	345.8
2/25 12:42	2.41	13.06	23057.1	231.7	346.0
2/25 12:43	2.42	13.06	23142.9	231.4	345.7
2/25 12:44	2.41	13.06	23057.1	231.4	345.7
2/25 12:45	2.41	13.06	23057.1	231.5	345.8
2/25 12:46	2.42	13.06	23142.9	231.5	345.7
2/25 12:47	2.42	13.06	23142.9	231.6	345.9
2/25 12:48	2.41	13.06	23057.1	231.7	345.9
2/25 12:49	2.41	13.06	23057.1	231.6	345.8
2/25 12:50	2.65	13.06	23057.1	231.7	345.9
2/25 12:51	2.65	13.06	23057.1	231.5	345.7
2/25 12:52	2.90	13.06	23142.9	231.6	345.9
Average (all)	2.44	13.06	23102.0	231.6	345.9
Total (all)	--	--	--	--	--
Minimum (all)	2.18	13.05	23057.1	231.4	345.7
Maximum (all)	2.90	13.06	23142.9	231.9	346.2
Average (valid values only)	2.44	13.06	23102.0	231.6	345.9
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:07 PM thru 2/25/2020 1:27 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 13:07	1.93	1.45	0.0054	13.01	0.01	0.01	0.00	1.38	1.04
2/25 13:08	1.93	1.45	0.0054	13.01	0.01	0.01	0.00	1.36	1.02
2/25 13:09	1.92	1.44	0.0053	12.82	0.04	0.03	0.24	1.35	1.02
2/25 13:10	1.91	1.44	0.0053	12.77	0.04	0.03	0.24	1.34	1.01
2/25 13:11	1.90	1.43	0.0053	12.82	0.10	0.08	0.48	1.34	1.01
2/25 13:12	1.90	1.43	0.0053	12.77	0.14	0.11	0.48	1.33	1.00
2/25 13:13	1.90	1.43	0.0053	12.77	0.20	0.15	0.72	1.33	1.00
2/25 13:14	1.90	1.43	0.0053	12.77	0.25	0.19	0.96	1.33	1.00
2/25 13:15	1.89	1.42	0.0052	12.58	0.35	0.26	1.45	1.35	1.02
2/25 13:16	1.87	1.41	0.0052	12.53	0.37	0.28	1.45	1.36	1.02
2/25 13:17	1.86	1.40	0.0052	12.53	0.34	0.26	1.45	1.37	1.03
2/25 13:18	1.85	1.39	0.0051	12.29	0.30	0.23	1.20	1.38	1.04
2/25 13:19	1.84	1.39	0.0051	12.29	0.32	0.24	1.20	1.40	1.05
2/25 13:20	1.83	1.38	0.0051	12.33	0.27	0.20	1.21	1.42	1.07
2/25 13:21	1.82	1.37	0.0050	12.05	0.26	0.20	0.96	1.43	1.08
2/25 13:22	1.82	1.37	0.0050	12.09	0.28	0.21	1.21	1.43	1.08
2/25 13:23	1.86	1.40	0.0052	12.58	0.27	0.20	1.21	1.41	1.06
2/25 13:24	1.92	1.45	0.0053	12.77	0.28	0.21	1.20	1.38	1.04
2/25 13:25	2.03	1.53	0.0056	13.49	0.26	0.20	0.96	1.32	0.99
2/25 13:26	2.18	1.64	0.0061	14.70	0.31	0.23	1.20	1.24	0.93
2/25 13:27	2.33	1.76	0.0065	15.66	0.27	0.20	1.20	1.16	0.87
Average (all)	1.92	1.45	0.0053	12.89	0.22	0.17	0.91	1.35	1.02
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.82	1.37	0.0050	12.05	0.01	0.01	0.00	1.16	0.87
Maximum (all)	2.33	1.76	0.0065	15.66	0.37	0.28	1.45	1.43	1.08
Average (valid values only)	1.92	1.45	0.0053	12.89	0.22	0.17	0.91	1.35	1.02
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:07 PM thru 2/25/2020 1:27 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 13:07	3.37	13.06	23057.1	231.2	345.3
2/25 13:08	3.37	13.06	23057.1	231.4	345.0
2/25 13:09	3.39	13.06	23142.9	231.4	345.5
2/25 13:10	3.37	13.06	23057.1	231.4	345.6
2/25 13:11	3.39	13.06	23142.9	231.3	345.5
2/25 13:12	3.37	13.07	23057.1	231.3	345.5
2/25 13:13	3.37	13.07	23057.1	231.3	345.4
2/25 13:14	3.37	13.08	23057.1	231.4	345.5
2/25 13:15	3.39	13.07	23142.9	231.4	345.5
2/25 13:16	3.37	13.07	23057.1	231.5	345.5
2/25 13:17	3.37	13.06	23057.1	231.4	345.5
2/25 13:18	3.37	13.06	23057.1	231.4	345.5
2/25 13:19	3.37	13.07	23057.1	231.5	345.6
2/25 13:20	3.63	13.06	23142.9	231.5	345.7
2/25 13:21	3.61	13.06	23057.1	231.3	345.4
2/25 13:22	3.63	13.06	23142.9	231.4	345.5
2/25 13:23	3.39	13.07	23142.9	231.4	345.5
2/25 13:24	3.37	13.07	23057.1	231.3	345.4
2/25 13:25	3.37	13.07	23057.1	231.1	345.3
2/25 13:26	3.13	13.07	23057.1	231.1	345.3
2/25 13:27	2.89	13.07	23057.1	231.1	345.2
Average (all)	3.38	13.07	23081.6	231.3	345.4
Total (all)	--	--	--	--	--
Minimum (all)	2.89	13.06	23057.1	231.1	345.0
Maximum (all)	3.63	13.08	23142.9	231.5	345.7
Average (valid values only)	3.38	13.07	23081.6	231.3	345.4
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:36 PM thru 2/25/2020 1:56 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 13:36	2.15	1.62	0.0060	14.46	0.20	0.15	0.72	0.99	0.75
2/25 13:37	2.09	1.57	0.0058	13.97	0.22	0.17	0.96	1.01	0.76
2/25 13:38	2.05	1.54	0.0057	13.73	0.23	0.17	0.96	1.04	0.78
2/25 13:39	2.04	1.54	0.0057	13.79	0.22	0.17	0.97	1.05	0.79
2/25 13:40	2.06	1.55	0.0057	13.73	0.21	0.16	0.96	1.05	0.79
2/25 13:41	2.12	1.60	0.0059	14.22	0.26	0.20	0.96	1.04	0.78
2/25 13:42	2.19	1.65	0.0061	14.75	0.27	0.20	1.21	1.02	0.77
2/25 13:43	2.28	1.72	0.0063	15.18	0.30	0.23	1.20	0.99	0.75
2/25 13:44	2.36	1.78	0.0065	15.66	0.34	0.26	1.45	0.97	0.73
2/25 13:45	2.43	1.83	0.0067	16.14	0.35	0.26	1.45	0.94	0.71
2/25 13:46	2.47	1.86	0.0069	16.69	0.37	0.28	1.45	0.93	0.70
2/25 13:47	2.46	1.85	0.0068	16.45	0.40	0.30	1.69	0.93	0.70
2/25 13:48	2.42	1.82	0.0067	16.14	0.43	0.32	1.69	0.93	0.70
2/25 13:49	2.36	1.78	0.0065	15.66	0.41	0.31	1.69	0.94	0.71
2/25 13:50	2.28	1.72	0.0063	15.18	0.41	0.31	1.69	0.95	0.72
2/25 13:51	2.21	1.66	0.0061	14.75	0.42	0.32	1.69	0.96	0.72
2/25 13:52	2.15	1.62	0.0060	14.51	0.43	0.32	1.69	0.97	0.73
2/25 13:53	2.12	1.60	0.0059	14.22	0.41	0.31	1.69	0.97	0.73
2/25 13:54	2.12	1.60	0.0059	14.22	0.43	0.32	1.69	0.97	0.73
2/25 13:55	2.16	1.63	0.0060	14.51	0.47	0.35	1.93	0.96	0.72
2/25 13:56	2.24	1.69	0.0062	14.94	0.42	0.32	1.69	0.94	0.71
Average (all)	2.23	1.68	0.0062	14.90	0.34	0.26	1.40	0.98	0.74
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.04	1.54	0.0057	13.73	0.20	0.15	0.72	0.93	0.70
Maximum (all)	2.47	1.86	0.0069	16.69	0.47	0.35	1.93	1.05	0.79
Average (valid values only)	2.23	1.68	0.0062	14.90	0.34	0.26	1.40	0.98	0.74
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:36 PM thru 2/25/2020 1:56 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 13:36	2.41	13.07	23057.1	231.4	345.8
2/25 13:37	2.41	13.07	23057.1	231.3	345.2
2/25 13:38	2.65	13.07	23057.1	231.4	345.6
2/25 13:39	2.66	13.06	23142.9	231.4	345.7
2/25 13:40	2.65	13.06	23057.1	231.4	345.7
2/25 13:41	2.65	13.06	23057.1	231.4	345.7
2/25 13:42	2.42	13.06	23142.9	231.4	345.7
2/25 13:43	2.41	13.06	23057.1	231.4	345.7
2/25 13:44	2.41	13.06	23057.1	231.4	345.7
2/25 13:45	2.41	13.06	23057.1	231.3	345.5
2/25 13:46	2.42	13.07	23142.9	231.3	345.5
2/25 13:47	2.42	13.07	23142.9	231.4	345.6
2/25 13:48	2.41	13.07	23057.1	231.4	345.6
2/25 13:49	2.41	13.06	23057.1	231.3	345.4
2/25 13:50	2.41	13.07	23057.1	231.3	345.4
2/25 13:51	2.42	13.06	23142.9	231.3	345.5
2/25 13:52	2.42	13.07	23142.9	231.2	345.4
2/25 13:53	2.41	13.07	23057.1	231.3	345.5
2/25 13:54	2.41	13.07	23057.1	231.3	345.5
2/25 13:55	2.42	13.06	23142.9	231.3	345.5
2/25 13:56	2.41	13.07	23057.1	231.2	345.5
Average (all)	2.46	13.07	23085.7	231.3	345.6
Total (all)	--	--	--	--	--
Minimum (all)	2.41	13.06	23057.1	231.2	345.2
Maximum (all)	2.66	13.07	23142.9	231.4	345.8
Average (valid values only)	2.46	13.07	23085.7	231.3	345.6
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:15 PM thru 2/25/2020 2:35 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 14:15	2.33	1.76	0.0065	15.72	0.22	0.17	0.97	0.94	0.71
2/25 14:16	2.39	1.80	0.0066	15.96	0.26	0.20	0.97	0.92	0.69
2/25 14:17	2.42	1.82	0.0067	16.14	0.28	0.21	1.20	0.92	0.69
2/25 14:18	2.42	1.82	0.0067	16.14	0.26	0.20	0.96	0.92	0.69
2/25 14:19	2.39	1.80	0.0066	15.90	0.28	0.21	1.20	0.92	0.69
2/25 14:20	2.35	1.77	0.0065	15.66	0.25	0.19	0.96	0.92	0.69
2/25 14:21	2.28	1.72	0.0063	15.18	0.28	0.21	1.20	0.94	0.71
2/25 14:22	2.14	1.61	0.0059	14.22	0.21	0.16	0.96	1.00	0.75
2/25 14:23	1.97	1.48	0.0055	13.20	0.20	0.15	0.72	1.05	0.79
2/25 14:24	1.84	1.38	0.0051	12.33	0.20	0.15	0.73	1.09	0.82
2/25 14:25	1.77	1.33	0.0049	11.81	0.25	0.19	0.96	1.15	0.87
2/25 14:26	1.75	1.32	0.0049	11.81	0.27	0.20	1.20	1.22	0.92
2/25 14:27	1.74	1.31	0.0048	11.57	0.26	0.20	0.96	1.29	0.97
2/25 14:28	1.76	1.33	0.0049	11.76	0.27	0.20	1.20	1.32	0.99
2/25 14:29	1.81	1.36	0.0050	12.05	0.27	0.20	1.20	1.33	1.00
2/25 14:30	1.88	1.42	0.0052	12.58	0.29	0.22	1.21	1.31	0.99
2/25 14:31	1.98	1.49	0.0055	13.25	0.27	0.20	1.20	1.26	0.95
2/25 14:32	2.06	1.55	0.0057	13.73	0.29	0.22	1.20	1.23	0.93
2/25 14:33	2.14	1.61	0.0059	14.22	0.31	0.23	1.20	1.17	0.88
2/25 14:34	2.20	1.66	0.0061	14.70	0.31	0.23	1.20	1.13	0.85
2/25 14:35	2.24	1.69	0.0062	14.94	0.24	0.18	0.96	1.10	0.83
Average (all)	2.09	1.57	0.0058	13.95	0.26	0.20	1.06	1.10	0.83
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.74	1.31	0.0048	11.57	0.20	0.15	0.72	0.92	0.69
Maximum (all)	2.42	1.82	0.0067	16.14	0.31	0.23	1.21	1.33	1.00
Average (valid values only)	2.09	1.57	0.0058	13.95	0.26	0.20	1.06	1.10	0.83
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:15 PM thru 2/25/2020 2:35 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 14:15	2.42	13.07	23142.9	231.2	345.1
2/25 14:16	2.18	13.06	23142.9	231.1	345.1
2/25 14:17	2.17	13.06	23057.1	231.1	345.2
2/25 14:18	2.17	13.06	23057.1	231.0	345.1
2/25 14:19	2.17	13.06	23057.1	230.9	345.0
2/25 14:20	2.17	13.06	23057.1	231.1	345.4
2/25 14:21	2.41	13.06	23057.1	231.1	345.4
2/25 14:22	2.41	13.06	23057.1	231.2	345.6
2/25 14:23	2.64	13.06	22971.4	231.0	345.4
2/25 14:24	2.66	13.06	23142.9	231.1	345.5
2/25 14:25	2.89	13.06	23057.1	231.0	344.9
2/25 14:26	2.89	13.07	23057.1	230.9	345.3
2/25 14:27	3.13	13.07	23057.1	231.1	345.6
2/25 14:28	3.36	13.07	22971.4	231.0	345.5
2/25 14:29	3.37	13.07	23057.1	231.0	345.5
2/25 14:30	3.14	13.07	23142.9	231.0	345.5
2/25 14:31	3.13	13.07	23057.1	231.1	345.6
2/25 14:32	3.13	13.07	23057.1	231.2	345.6
2/25 14:33	2.89	13.07	23057.1	231.1	345.5
2/25 14:34	2.89	13.06	23057.1	231.2	345.5
2/25 14:35	2.65	13.07	23057.1	231.1	345.4
Average (all)	2.71	13.06	23065.3	231.1	345.4
Total (all)	--	--	--	--	--
Minimum (all)	2.17	13.06	22971.4	230.9	344.9
Maximum (all)	3.37	13.07	23142.9	231.2	345.6
Average (valid values only)	2.71	13.06	23065.3	231.1	345.4
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:46 PM thru 2/25/2020 3:06 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 14:46	2.21	1.66	0.0061	14.70	0.11	0.08	0.48	0.99	0.75
2/25 14:47	2.14	1.61	0.0059	14.22	0.14	0.11	0.48	1.03	0.78
2/25 14:48	2.06	1.55	0.0057	13.73	0.18	0.14	0.72	1.06	0.80
2/25 14:49	2.00	1.51	0.0055	13.25	0.14	0.11	0.48	1.06	0.80
2/25 14:50	1.98	1.49	0.0055	13.30	0.06	0.05	0.24	1.07	0.81
2/25 14:51	1.98	1.49	0.0055	13.25	0.09	0.07	0.48	1.09	0.82
2/25 14:52	1.99	1.50	0.0055	13.25	0.06	0.05	0.24	1.11	0.84
2/25 14:53	2.00	1.51	0.0056	13.54	0.04	0.03	0.24	1.12	0.84
2/25 14:54	2.00	1.51	0.0056	13.44	0.04	0.03	0.24	1.14	0.86
2/25 14:55	2.00	1.51	0.0055	13.25	0.08	0.06	0.24	1.15	0.87
2/25 14:56	2.00	1.51	0.0056	13.49	0.08	0.06	0.24	1.15	0.87
2/25 14:57	1.99	1.50	0.0055	13.25	0.09	0.07	0.48	1.17	0.88
2/25 14:58	1.93	1.45	0.0054	13.06	0.10	0.08	0.48	1.20	0.90
2/25 14:59	1.86	1.40	0.0052	12.53	0.08	0.06	0.24	1.24	0.93
2/25 15:00	1.83	1.38	0.0051	12.29	0.08	0.06	0.24	1.25	0.94
2/25 15:01	1.85	1.39	0.0051	12.29	0.10	0.08	0.48	1.28	0.96
2/25 15:02	1.88	1.42	0.0052	12.48	0.08	0.06	0.24	1.29	0.97
2/25 15:03	1.92	1.45	0.0053	12.82	0.08	0.06	0.24	1.28	0.96
2/25 15:04	1.97	1.48	0.0055	13.30	0.08	0.06	0.24	1.26	0.95
2/25 15:05	2.02	1.52	0.0056	13.49	0.13	0.10	0.48	1.24	0.93
2/25 15:06	2.07	1.56	0.0057	13.73	0.10	0.08	0.48	1.21	0.91
Average (all)	1.98	1.50	0.0055	13.27	0.09	0.07	0.37	1.16	0.87
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.83	1.38	0.0051	12.29	0.04	0.03	0.24	0.99	0.75
Maximum (all)	2.21	1.66	0.0061	14.70	0.18	0.14	0.72	1.29	0.97
Average (valid values only)	1.98	1.50	0.0055	13.27	0.09	0.07	0.37	1.16	0.87
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:46 PM thru 2/25/2020 3:06 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 14:46	2.41	13.06	23057.1	231.2	345.7
2/25 14:47	2.65	13.06	23057.1	231.2	345.7
2/25 14:48	2.65	13.06	23057.1	231.0	345.5
2/25 14:49	2.65	13.06	23057.1	231.2	345.7
2/25 14:50	2.66	13.07	23142.9	231.0	345.5
2/25 14:51	2.65	13.06	23057.1	231.2	345.7
2/25 14:52	2.65	13.07	23057.1	231.0	345.5
2/25 14:53	2.66	13.07	23142.9	231.1	345.7
2/25 14:54	2.88	13.07	22971.4	230.9	345.4
2/25 14:55	2.89	13.06	23057.1	231.0	345.6
2/25 14:56	2.89	13.07	23057.1	231.0	345.5
2/25 14:57	2.89	13.07	23057.1	230.9	345.4
2/25 14:58	2.90	13.07	23142.9	231.1	345.6
2/25 14:59	3.13	13.06	23057.1	231.0	345.5
2/25 15:00	3.13	13.07	23057.1	230.9	345.4
2/25 15:01	3.13	13.07	23057.1	231.0	345.5
2/25 15:02	3.12	13.07	22971.4	231.0	345.4
2/25 15:03	3.14	13.07	23142.9	231.1	345.4
2/25 15:04	3.14	13.06	23142.9	231.1	345.5
2/25 15:05	3.13	13.06	23057.1	231.0	345.3
2/25 15:06	2.89	13.06	23057.1	231.0	345.1
Average (all)	2.87	13.07	23069.4	231.0	345.5
Total (all)	--	--	--	--	--
Minimum (all)	2.41	13.06	22971.4	230.9	345.1
Maximum (all)	3.14	13.07	23142.9	231.2	345.7
Average (valid values only)	2.87	13.07	23069.4	231.0	345.5
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:17 PM thru 2/25/2020 3:37 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 15:17	2.20	1.66	0.0061	14.70	0.16	0.12	0.72	1.04	0.78
2/25 15:18	2.23	1.68	0.0062	14.88	0.16	0.12	0.72	1.03	0.78
2/25 15:19	2.25	1.70	0.0062	14.94	0.11	0.08	0.48	1.02	0.77
2/25 15:20	2.25	1.70	0.0062	14.94	0.11	0.08	0.48	1.02	0.77
2/25 15:21	2.25	1.70	0.0062	14.94	0.11	0.08	0.48	1.01	0.76
2/25 15:22	2.25	1.69	0.0062	14.94	0.08	0.06	0.24	1.00	0.75
2/25 15:23	2.24	1.69	0.0062	14.94	0.10	0.08	0.48	1.00	0.75
2/25 15:24	2.23	1.68	0.0062	14.88	0.07	0.05	0.24	1.00	0.75
2/25 15:25	2.20	1.66	0.0061	14.75	0.03	0.02	0.24	1.01	0.76
2/25 15:26	2.14	1.61	0.0059	14.22	0.02	0.02	0.00	1.04	0.78
2/25 15:27	2.07	1.56	0.0057	13.73	0.03	0.02	0.24	1.07	0.81
2/25 15:28	2.02	1.52	0.0056	13.54	0.04	0.03	0.24	1.08	0.81
2/25 15:29	1.99	1.50	0.0055	13.25	0.00	0.00	0.00	1.10	0.83
2/25 15:30	1.98	1.49	0.0055	13.20	0.00	0.00	0.00	1.13	0.85
2/25 15:31	1.98	1.49	0.0055	13.25	0.04	0.03	0.24	1.14	0.86
2/25 15:32	1.97	1.48	0.0055	13.25	0.08	0.06	0.24	1.16	0.87
2/25 15:33	1.96	1.48	0.0054	13.01	0.06	0.05	0.24	1.17	0.88
2/25 15:34	1.96	1.48	0.0054	13.01	0.09	0.07	0.48	1.17	0.88
2/25 15:35	2.02	1.52	0.0056	13.49	0.06	0.05	0.24	1.14	0.86
2/25 15:36	2.12	1.60	0.0059	14.22	0.07	0.05	0.24	1.11	0.84
2/25 15:37	2.21	1.67	0.0061	14.75	0.07	0.05	0.24	1.07	0.81
Average (all)	2.12	1.60	0.0059	14.13	0.07	0.05	0.31	1.07	0.81
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.96	1.48	0.0054	13.01	0.00	0.00	0.00	1.00	0.75
Maximum (all)	2.25	1.70	0.0062	14.94	0.16	0.12	0.72	1.17	0.88
Average (valid values only)	2.12	1.60	0.0059	14.13	0.07	0.05	0.31	1.07	0.81
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:17 PM thru 2/25/2020 3:37 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 15:17	2.65	13.07	23057.1	231.0	345.1
2/25 15:18	2.64	13.07	22971.4	231.0	345.1
2/25 15:19	2.41	13.07	23057.1	231.0	345.1
2/25 15:20	2.41	13.07	23057.1	231.1	345.3
2/25 15:21	2.41	13.07	23057.1	231.0	345.2
2/25 15:22	2.41	13.06	23057.1	230.9	345.1
2/25 15:23	2.41	13.06	23057.1	231.0	345.3
2/25 15:24	2.40	13.06	22971.4	231.0	345.3
2/25 15:25	2.42	13.06	23142.9	231.0	345.4
2/25 15:26	2.65	13.06	23057.1	231.1	345.3
2/25 15:27	2.65	13.06	23057.1	231.0	345.1
2/25 15:28	2.66	13.06	23142.9	231.1	345.2
2/25 15:29	2.65	13.06	23057.1	231.0	345.1
2/25 15:30	2.88	13.06	22971.4	231.1	345.4
2/25 15:31	2.89	13.06	23057.1	231.0	345.3
2/25 15:32	2.89	13.06	23057.1	231.1	345.4
2/25 15:33	2.89	13.06	23057.1	231.1	345.4
2/25 15:34	2.89	13.06	23057.1	231.0	345.4
2/25 15:35	2.89	13.06	23057.1	231.1	345.5
2/25 15:36	2.65	13.06	23057.1	231.1	345.5
2/25 15:37	2.66	13.07	23142.9	231.1	345.5
Average (all)	2.64	13.06	23057.1	231.0	345.3
Total (all)	--	--	--	--	--
Minimum (all)	2.40	13.06	22971.4	230.9	345.1
Maximum (all)	2.89	13.07	23142.9	231.1	345.5
Average (valid values only)	2.64	13.06	23057.1	231.0	345.3
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:47 PM thru 2/25/2020 4:07 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 15:47	2.27	1.71	0.0063	15.18	0.09	0.07	0.48	0.96	0.72
2/25 15:48	2.28	1.72	0.0063	15.24	0.05	0.04	0.24	0.96	0.72
2/25 15:49	2.28	1.72	0.0063	15.24	0.05	0.04	0.24	0.96	0.72
2/25 15:50	2.28	1.72	0.0063	15.18	0.08	0.06	0.24	0.95	0.71
2/25 15:51	2.27	1.71	0.0063	15.18	0.04	0.03	0.24	0.96	0.72
2/25 15:52	2.27	1.71	0.0063	15.12	0.09	0.07	0.48	0.95	0.71
2/25 15:53	2.26	1.70	0.0063	15.24	0.03	0.02	0.24	0.95	0.71
2/25 15:54	2.25	1.69	0.0062	14.94	0.01	0.01	0.00	0.95	0.71
2/25 15:55	2.25	1.69	0.0062	14.94	0.03	0.02	0.24	0.94	0.71
2/25 15:56	2.27	1.71	0.0063	15.24	0.07	0.05	0.24	0.93	0.70
2/25 15:57	2.28	1.72	0.0063	15.18	0.08	0.06	0.24	0.93	0.70
2/25 15:58	2.28	1.72	0.0063	15.24	0.03	0.02	0.24	0.93	0.70
2/25 15:59	2.28	1.72	0.0063	15.18	0.02	0.02	0.00	0.94	0.71
2/25 16:00	2.27	1.71	0.0063	15.24	0.04	0.03	0.24	0.93	0.70
2/25 16:01	2.28	1.72	0.0063	15.18	0.06	0.05	0.24	0.92	0.69
2/25 16:02	2.28	1.72	0.0063	15.18	0.07	0.05	0.24	0.93	0.70
2/25 16:03	2.27	1.71	0.0063	15.18	0.02	0.02	0.00	0.93	0.70
2/25 16:04	2.26	1.70	0.0063	15.18	0.05	0.04	0.24	0.93	0.70
2/25 16:05	2.26	1.70	0.0063	15.18	0.01	0.01	0.00	0.94	0.71
2/25 16:06	2.26	1.70	0.0063	15.18	0.04	0.03	0.24	0.94	0.71
2/25 16:07	2.27	1.67	0.0062	15.40	0.03	0.02	0.00	0.93	0.68
Average (all)	2.27	1.71	0.0063	15.18	0.05	0.04	0.21	0.94	0.71
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.25	1.67	0.0062	14.94	0.01	0.01	0.00	0.92	0.68
Maximum (all)	2.28	1.72	0.0063	15.40	0.09	0.07	0.48	0.96	0.72
Average (valid values only)	2.27	1.71	0.0063	15.18	0.05	0.04	0.21	0.94	0.71
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:47 PM thru 2/25/2020 4:07 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 15:47	2.41	13.06	23057.1	231.1	345.5
2/25 15:48	2.42	13.06	23142.9	231.0	345.4
2/25 15:49	2.42	13.06	23142.9	231.2	345.7
2/25 15:50	2.41	13.06	23057.1	231.1	345.6
2/25 15:51	2.41	13.06	23057.1	231.2	345.8
2/25 15:52	2.40	13.06	22971.4	231.1	345.6
2/25 15:53	2.42	13.06	23142.9	231.1	345.5
2/25 15:54	2.41	13.06	23057.1	231.2	345.7
2/25 15:55	2.41	13.06	23057.1	231.2	345.7
2/25 15:56	2.42	13.06	23142.9	231.2	345.7
2/25 15:57	2.41	13.06	23057.1	231.2	345.7
2/25 15:58	2.42	13.06	23142.9	231.2	345.7
2/25 15:59	2.41	13.06	23057.1	231.2	345.9
2/25 16:00	2.42	13.06	23142.9	231.2	346.0
2/25 16:01	2.17	13.06	23057.1	231.3	346.0
2/25 16:02	2.41	13.06	23057.1	231.2	345.9
2/25 16:03	2.41	13.06	23057.1	231.3	346.0
2/25 16:04	2.41	13.06	23057.1	231.1	345.8
2/25 16:05	2.41	13.05	23057.1	231.1	345.8
2/25 16:06	2.41	13.06	23057.1	231.1	346.0
2/25 16:07	2.24	12.88	23768.8	231.2	347.6
Average (all)	2.39	13.05	23111.4	231.2	345.8
Total (all)	--	--	--	--	--
Minimum (all)	2.17	12.88	22971.4	231.0	345.4
Maximum (all)	2.42	13.06	23768.8	231.3	347.6
Average (valid values only)	2.39	13.05	23111.4	231.2	345.8
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:20 PM thru 2/25/2020 4:40 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 16:20	2.60	1.82	0.0067	17.36	0.00	0.00	0.00	1.03	0.72
2/25 16:21	2.56	1.78	0.0066	17.10	0.00	0.00	0.00	1.06	0.74
2/25 16:22	2.54	1.76	0.0065	16.95	0.00	0.00	0.00	1.08	0.75
2/25 16:23	2.53	1.75	0.0064	16.73	0.00	0.00	0.00	1.10	0.76
2/25 16:24	2.54	1.75	0.0064	16.84	0.00	0.00	0.00	1.11	0.76
2/25 16:25	2.57	1.77	0.0065	17.02	0.00	0.00	0.00	1.11	0.76
2/25 16:26	2.61	1.79	0.0066	17.38	0.00	0.00	0.00	1.12	0.77
2/25 16:27	2.63	1.80	0.0066	17.35	0.00	0.00	0.00	1.14	0.78
2/25 16:28	2.64	1.80	0.0066	17.39	0.00	0.00	0.00	1.15	0.78
2/25 16:29	2.63	1.79	0.0066	17.42	0.00	0.00	0.00	1.18	0.80
2/25 16:30	2.61	1.77	0.0065	17.19	0.00	0.00	0.00	1.19	0.81
2/25 16:31	2.60	1.76	0.0065	17.22	0.00	0.00	0.00	1.21	0.82
2/25 16:32	2.62	1.77	0.0065	17.25	0.00	0.00	0.00	1.22	0.82
2/25 16:33	2.65	1.79	0.0066	17.54	0.00	0.00	0.00	1.23	0.83
2/25 16:34	2.67	1.80	0.0066	17.62	0.00	0.00	0.00	1.25	0.84
2/25 16:35	2.67	1.79	0.0066	17.64	0.00	0.00	0.00	1.28	0.86
2/25 16:36	2.65	1.78	0.0066	17.64	0.00	0.00	0.00	1.30	0.87
2/25 16:37	2.62	1.76	0.0065	17.31	0.00	0.00	0.00	1.33	0.89
2/25 16:38	2.59	1.74	0.0064	17.11	0.00	0.00	0.00	1.35	0.91
2/25 16:39	2.57	1.72	0.0063	16.84	0.00	0.00	0.00	1.37	0.92
2/25 16:40	2.56	1.72	0.0063	16.79	0.00	0.00	0.00	1.38	0.93
Average (all)	2.60	1.77	0.0065	17.22	0.00	0.00	0.00	1.20	0.82
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.53	1.72	0.0063	16.73	0.00	0.00	0.00	1.03	0.72
Maximum (all)	2.67	1.82	0.0067	17.64	0.00	0.00	0.00	1.38	0.93
Average (valid values only)	2.60	1.77	0.0065	17.22	0.00	0.00	0.00	1.20	0.82
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:20 PM thru 2/25/2020 4:40 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 16:20	2.59	12.46	24799.3	231.3	364.6
2/25 16:21	2.59	12.42	24793.3	231.5	365.5
2/25 16:22	2.61	12.38	24950.2	231.3	367.0
2/25 16:23	2.62	12.36	25016.3	231.3	368.1
2/25 16:24	2.63	12.33	25167.7	231.3	369.1
2/25 16:25	2.62	12.31	25054.7	231.4	370.1
2/25 16:26	2.63	12.28	25197.2	231.5	371.0
2/25 16:27	2.89	12.26	25164.6	231.5	371.9
2/25 16:28	2.90	12.24	25220.2	231.5	372.6
2/25 16:29	2.90	12.22	25267.2	231.5	373.4
2/25 16:30	2.91	12.21	25307.8	231.6	374.2
2/25 16:31	2.91	12.18	25352.8	231.5	374.2
2/25 16:32	2.92	12.17	25397.6	231.6	375.3
2/25 16:33	2.92	12.15	25432.3	231.7	376.2
2/25 16:34	2.94	12.13	25554.5	231.6	376.6
2/25 16:35	3.20	12.12	25571.8	231.6	377.2
2/25 16:36	3.20	12.11	25575.1	231.7	377.7
2/25 16:37	3.20	12.12	25490.0	231.6	377.9
2/25 16:38	3.20	12.12	25574.9	231.7	378.2
2/25 16:39	3.21	12.10	25577.6	231.7	378.4
2/25 16:40	3.46	12.10	25506.5	231.8	378.5
Average (all)	2.91	12.23	25284.4	231.5	373.2
Total (all)	--	--	--	--	--
Minimum (all)	2.59	12.10	24793.3	231.3	364.6
Maximum (all)	3.46	12.46	25577.6	231.8	378.5
Average (valid values only)	2.91	12.23	25284.4	231.5	373.2
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:51 PM thru 2/25/2020 5:11 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 16:51	2.53	1.70	0.0063	16.83	0.00	0.00	0.00	1.47	0.99
2/25 16:52	2.53	1.70	0.0063	16.76	0.00	0.00	0.00	1.47	0.99
2/25 16:53	2.54	1.71	0.0063	16.81	0.00	0.00	0.00	1.46	0.98
2/25 16:54	2.56	1.72	0.0063	16.79	0.00	0.00	0.00	1.46	0.98
2/25 16:55	2.55	1.72	0.0063	16.79	0.00	0.00	0.00	1.48	1.00
2/25 16:56	2.53	1.70	0.0063	16.73	0.00	0.00	0.00	1.48	1.00
2/25 16:57	2.52	1.69	0.0062	16.55	0.00	0.00	0.00	1.48	0.99
2/25 16:58	2.52	1.69	0.0062	16.66	0.00	0.00	0.00	1.47	0.99
2/25 16:59	2.54	1.70	0.0063	16.91	0.00	0.00	0.00	1.46	0.98
2/25 17:00	2.57	1.71	0.0063	16.93	0.00	0.00	0.00	1.46	0.97
2/25 17:01	2.60	1.73	0.0064	17.13	0.00	0.00	0.00	1.47	0.98
2/25 17:02	2.59	1.73	0.0064	17.06	0.00	0.00	0.00	1.49	1.00
2/25 17:03	2.55	1.72	0.0063	16.74	0.00	0.00	0.00	1.51	1.02
2/25 17:04	2.49	1.68	0.0062	16.51	0.00	0.00	0.00	1.51	1.02
2/25 17:05	2.45	1.66	0.0061	16.21	0.00	0.00	0.00	1.50	1.01
2/25 17:06	2.45	1.65	0.0061	16.25	0.00	0.00	0.00	1.48	1.00
2/25 17:07	2.49	1.67	0.0062	16.56	0.00	0.00	0.00	1.47	0.99
2/25 17:08	2.54	1.70	0.0063	16.88	0.00	0.00	0.00	1.46	0.98
2/25 17:09	2.59	1.73	0.0064	17.14	0.00	0.00	0.00	1.46	0.98
2/25 17:10	2.62	1.75	0.0065	17.42	0.00	0.00	0.00	1.47	0.98
2/25 17:11	2.60	1.74	0.0064	17.05	0.00	0.00	0.00	1.49	1.00
Average (all)	2.54	1.70	0.0063	16.80	0.00	0.00	0.00	1.48	0.99
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.45	1.65	0.0061	16.21	0.00	0.00	0.00	1.46	0.97
Maximum (all)	2.62	1.75	0.0065	17.42	0.00	0.00	0.00	1.51	1.02
Average (valid values only)	2.54	1.70	0.0063	16.80	0.00	0.00	0.00	1.48	0.99
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:51 PM thru 2/25/2020 5:11 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 16:51	3.47	12.12	25552.3	231.7	377.9
2/25 16:52	3.46	12.12	25458.7	231.7	378.0
2/25 16:53	3.46	12.12	25525.4	231.8	378.3
2/25 16:54	3.46	12.12	25502.5	231.8	378.4
2/25 16:55	3.73	12.13	25499.5	231.8	378.3
2/25 16:56	3.72	12.13	25418.6	232.0	378.3
2/25 16:57	3.74	12.12	25548.6	232.0	378.0
2/25 16:58	3.50	12.10	25707.3	232.0	377.5
2/25 16:59	3.49	12.07	25686.2	232.1	377.5
2/25 17:00	3.49	12.05	25710.4	232.1	377.7
2/25 17:01	3.48	12.05	25617.3	232.1	378.0
2/25 17:02	3.73	12.08	25500.4	232.2	378.3
2/25 17:03	3.72	12.13	25420.5	232.1	378.4
2/25 17:04	3.73	12.16	25478.5	232.2	378.5
2/25 17:05	3.73	12.18	25434.1	232.2	378.0
2/25 17:06	3.74	12.15	25502.6	232.2	377.6
2/25 17:07	3.47	12.12	25573.7	232.2	377.5
2/25 17:08	3.48	12.09	25630.5	232.3	377.8
2/25 17:09	3.48	12.07	25620.6	232.2	378.2
2/25 17:10	3.49	12.09	25648.5	232.2	378.7
2/25 17:11	3.73	12.10	25496.6	232.3	379.2
Average (all)	3.59	12.11	25549.2	232.1	378.1
Total (all)	--	--	--	--	--
Minimum (all)	3.46	12.05	25418.6	231.7	377.5
Maximum (all)	3.74	12.18	25710.4	232.3	379.2
Average (valid values only)	3.59	12.11	25549.2	232.1	378.1
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 5:57 PM thru 2/25/2020 6:17 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 17:57	2.53	1.69	0.0062	16.65	0.00	0.00	0.00	1.48	0.99
2/25 17:58	2.51	1.68	0.0062	16.65	0.00	0.00	0.00	1.48	0.99
2/25 17:59	2.52	1.68	0.0062	16.61	0.00	0.00	0.00	1.48	0.99
2/25 18:00	2.54	1.70	0.0063	16.94	0.00	0.00	0.00	1.47	0.98
2/25 18:01	2.56	1.71	0.0063	16.89	0.00	0.00	0.00	1.47	0.98
2/25 18:02	2.57	1.72	0.0063	16.84	0.01	0.01	0.00	1.47	0.98
2/25 18:03	2.56	1.71	0.0063	16.84	0.02	0.01	0.00	1.48	0.99
2/25 18:04	2.55	1.71	0.0063	16.88	0.03	0.02	0.00	1.48	0.99
2/25 18:05	2.54	1.70	0.0063	16.82	0.02	0.01	0.00	1.48	0.99
2/25 18:06	2.55	1.71	0.0063	16.86	0.00	0.00	0.00	1.47	0.99
2/25 18:07	2.56	1.72	0.0063	16.92	0.00	0.00	0.00	1.47	0.99
2/25 18:08	2.55	1.71	0.0063	16.81	0.00	0.00	0.00	1.48	0.99
2/25 18:09	2.53	1.70	0.0062	16.60	0.00	0.00	0.00	1.49	1.00
2/25 18:10	2.52	1.69	0.0062	16.61	0.01	0.01	0.00	1.49	1.00
2/25 18:11	2.52	1.69	0.0062	16.62	0.00	0.00	0.00	1.49	1.00
2/25 18:12	2.51	1.68	0.0062	16.62	0.02	0.01	0.00	1.51	1.01
2/25 18:13	2.51	1.68	0.0062	16.62	0.05	0.03	0.27	1.51	1.01
2/25 18:14	2.51	1.68	0.0062	16.61	0.08	0.05	0.27	1.51	1.01
2/25 18:15	2.51	1.68	0.0062	16.60	0.02	0.01	0.00	1.51	1.01
2/25 18:16	2.51	1.68	0.0062	16.59	0.03	0.02	0.00	1.51	1.01
2/25 18:17	2.52	1.69	0.0062	16.65	0.04	0.03	0.26	1.51	1.01
Average (all)	2.53	1.70	0.0062	16.73	0.02	0.01	0.04	1.49	1.00
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.51	1.68	0.0062	16.59	0.00	0.00	0.00	1.47	0.98
Maximum (all)	2.57	1.72	0.0063	16.94	0.08	0.05	0.27	1.51	1.01
Average (valid values only)	2.53	1.70	0.0062	16.73	0.02	0.01	0.04	1.49	1.00
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 5:57 PM thru 2/25/2020 6:17 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 17:57	3.49	12.09	25688.5	233.4	380.1
2/25 17:58	3.49	12.09	25698.0	233.4	380.1
2/25 17:59	3.49	12.07	25628.7	233.5	379.9
2/25 18:00	3.50	12.07	25730.2	233.4	379.8
2/25 18:01	3.49	12.07	25651.7	233.5	379.9
2/25 18:02	3.47	12.07	25568.9	233.2	379.6
2/25 18:03	3.47	12.08	25567.6	233.0	379.5
2/25 18:04	3.49	12.09	25638.4	232.8	379.3
2/25 18:05	3.47	12.09	25538.6	233.0	379.8
2/25 18:06	3.48	12.10	25615.9	232.9	379.7
2/25 18:07	3.49	12.10	25697.1	233.0	379.8
2/25 18:08	3.46	12.10	25526.1	233.0	379.7
2/25 18:09	3.75	12.10	25624.6	233.1	379.6
2/25 18:10	3.75	12.08	25642.0	233.3	379.7
2/25 18:11	3.75	12.08	25652.8	233.2	379.5
2/25 18:12	3.75	12.08	25654.0	233.3	379.7
2/25 18:13	3.75	12.08	25645.3	233.3	379.8
2/25 18:14	3.75	12.07	25632.5	233.5	380.3
2/25 18:15	3.75	12.07	25616.7	233.5	380.6
2/25 18:16	3.75	12.08	25605.4	233.6	380.7
2/25 18:17	3.76	12.08	25689.3	233.7	380.9
Average (all)	3.60	12.08	25633.9	233.3	379.9
Total (all)	--	--	--	--	--
Minimum (all)	3.46	12.07	25526.1	232.8	379.3
Maximum (all)	3.76	12.10	25730.2	233.7	380.9
Average (valid values only)	3.60	12.08	25633.9	233.3	379.9
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CEMS AND REFERENCE METHOD DATA

Reference Method Data

Relative Accuracy Test Data
Reference Method Results (NOx)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxides of Nitrogen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 7E
RM Analyzer Type:	Chemiluminescence
Manufacturer:	
Model #:	THERMO 42 series
Serial #:	INST-NX-0031

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		1.58	14.14	0.0058
2	12:32 - 12:52	345.9		1.54	13.77	0.0057
3	13:07 - 13:27	345.4		1.55	13.85	0.0057
4	13:36 - 13:56	345.6		1.58	14.11	0.0058
5	14:15 - 14:35	345.4		1.50	13.41	0.0055
6	14:46 - 15:06	345.5		1.42	12.65	0.0052
7	15:17 - 15:37	345.3		1.51	13.45	0.0056
8	15:47 - 16:07	345.8		1.58	14.15	0.0058
9	16:20 - 16:40	373.2		1.65	16.10	0.0061
10	16:51 - 17:11	378.1		1.58	15.67	0.0058
11	17:57 - 18:17	379.9		1.59	15.73	0.0058
12						

Relative Accuracy Test Data
Reference Method Results (CO)
General Electric, 7F.05, Unit #U-00002

Parameter:	Carbon Monoxide
Date of Test:	February 25, 2020
Reference Method:	EPA Method 10
RM Analyzer Type:	Infrared Absorption
Manufacturer:	
Model #:	THERMO 48 series
Serial #:	INST-CO-0029

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.11	0.58	
2	12:32 - 12:52	345.9		0.35	1.93	
3	13:07 - 13:27	345.4		0.13	0.69	
4	13:36 - 13:56	345.6		0.51	2.76	
5	14:15 - 14:35	345.4		0.13	0.72	
6	14:46 - 15:06	345.5		0.16	0.89	
7	15:17 - 15:37	345.3		0.14	0.74	
8	15:47 - 16:07	345.8		0.14	0.77	
9	16:20 - 16:40	373.2		0.11	0.64	
10	16:51 - 17:11	378.1		0.11	0.68	
11	17:57 - 18:17	379.9		0.12	0.71	
12						

Relative Accuracy Test Data
Reference Method Results (NH_3)
General Electric, 7F.05, Unit #U-00002

Parameter:	Ammonia
Date of Test:	February 25, 2020
Reference Method:	EPA Method 027
RM Analyzer Type:	Fourier Transform infared
Manufacturer:	MKS
Model #:	2030
Serial #:	INST-IR-0004

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.66	2.20	
2	12:32 - 12:52	345.9		0.85	2.83	
3	13:07 - 13:27	345.4		0.87	2.88	
4	13:36 - 13:56	345.6		0.68	2.26	
5	14:15 - 14:35	345.4		0.87	2.87	
6	14:46 - 15:06	345.5		0.66	2.19	
7	15:17 - 15:37	345.3		0.66	2.17	
8	15:47 - 16:07	345.8		0.61	2.01	
9	16:20 - 16:40	373.2		0.48	1.73	
10	16:51 - 17:11	378.1		0.60	2.20	
11	17:57 - 18:17	379.9		1.53	5.62	
12						

Relative Accuracy Test Data
Reference Method Results (O_2)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxygen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 3A
RM Analyzer Type:	Paramagnetic Cell
Manufacturer: Model #:	SERVOMEX 1440
Serial #:	INST-O2-0024

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	11:53 - 12:13	346.6	13.36
2	12:32 - 12:52	345.9	13.25
3	13:07 - 13:27	345.4	13.29
4	13:36 - 13:56	345.6	11.85
5	14:15 - 14:35	345.4	13.30
6	14:46 - 15:06	345.5	13.25
7	15:17 - 15:37	345.3	13.27
8	15:47 - 16:07	345.8	13.25
9	16:20 - 16:40	373.2	12.43
10	16:51 - 17:11	378.1	12.29
11	17:57 - 18:17	379.9	12.31
12			

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,317,550	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,317,550	SCFH

Weather Data

Barometric Pressure	29.38	in. Hg
Relative Humidity	51	%
Ambient Temperature	54	°F
Specific Humidity	0.004604	lb H_2O / lb air

Unit Data

Unit Load	346.6	megawatts
Stack Exhaust Flow (M19)	58,713,359	SCFH

Base Load Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 11:53:28	60	13.47	1.90	0.16	0.85	8.02
02/25/20 11:53:58	90	13.46	1.92	0.17	0.85	7.89
02/25/20 11:54:28	120	13.47	1.91	0.17	0.84	7.79
02/25/20 11:54:58	150	13.46	1.87	0.14	0.88	8.34
02/25/20 11:55:28	180	13.46	1.87	0.16	0.85	7.96
02/25/20 11:55:58	210	13.46	1.86	0.14	0.83	7.90
02/25/20 11:56:28	240	13.46	1.87	0.13	0.83	8.04
02/25/20 11:56:58	270	13.45	1.88	0.13	0.84	7.80
02/25/20 11:57:28	300	13.46	1.88	0.13	0.85	8.15
02/25/20 11:57:58	330	13.46	1.86	0.16	0.82	7.92
02/25/20 11:58:28	360	13.46	1.85	0.13	0.81	7.97
02/25/20 11:58:58	390	13.45	1.84	0.11	0.83	8.09
02/25/20 11:59:28	420	13.45	1.85	0.16	0.83	7.92
02/25/20 11:59:58	450	13.45	1.84	0.15	0.83	8.37
02/25/20 12:00:28	480	13.44	1.80	0.15	0.79	7.92
02/25/20 12:00:58	510	13.46	1.83	0.17	0.81	8.09
02/25/20 12:01:28	540	13.46	1.83	0.17	0.82	8.13
02/25/20 12:01:58	570	13.46	1.85	0.14	0.81	8.01
02/25/20 12:02:28	600	13.45	1.86	0.16	0.80	8.55
02/25/20 12:02:58	630	13.44	1.82	0.17	0.78	7.97
02/25/20 12:03:28	660	13.44	1.84	0.16	0.81	8.22
02/25/20 12:03:58	690	13.40	1.85	0.15	0.79	8.08
02/25/20 12:04:28	720	13.36	1.86	0.15	0.81	8.40
02/25/20 12:04:58	750	13.35	1.87	0.14	0.77	8.30
02/25/20 12:05:28	780	13.35	1.86	0.12	0.73	8.47
02/25/20 12:05:58	810	13.33	1.87	0.15	0.76	10.24
02/25/20 12:06:28	840	13.34	1.86	0.11	0.70	8.71
02/25/20 12:06:58	870	13.34	1.86	0.14	0.71	8.69
02/25/20 12:07:28	900	13.33	1.86	0.11	0.71	8.47
02/25/20 12:07:58	930	13.33	1.84	0.13	0.72	8.42
02/25/20 12:08:28	960	13.34	1.82	0.13	0.73	8.35
02/25/20 12:08:58	990	13.34	1.80	0.13	0.73	8.46
02/25/20 12:09:28	1020	13.34	1.82	0.13	0.72	8.70
02/25/20 12:09:58	1050	13.33	1.80	0.11	0.70	8.40
02/25/20 12:10:28	1080	13.34	1.83	0.13	0.71	8.48
02/25/20 12:10:58	1110	13.34	1.86	0.11	0.72	8.59
02/25/20 12:11:28	1140	13.34	1.86	0.14	0.72	8.38
02/25/20 12:11:58	1170	13.33	1.88	0.14	0.71	8.34
02/25/20 12:12:28	1200	13.33	1.85	0.18	0.73	8.64
02/25/20 12:12:58	1230	13.34	1.89	0.12	0.69	8.49
02/25/20 12:13:28	1260	13.34	1.87	0.15	0.71	8.39
02/25/20 12:13:58	1290	13.34	1.86	0.12	0.71	8.32
RAW AVERAGE		**13.40**	**1.85**	**0.14**	**0.78**	**8.30**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.03	0.02	0.05	
	Final Zero	-0.05	-0.53	-0.04	
	Avg. Zero	-0.04	-0.26	0.01	
	Initial UpScale	11.99	4.93	5.13	
	Final UpScale	12.02	4.83	5.14	
	Avg. UpScale	12.01	4.88	5.14	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.36	2.02	0.14	0.85
Concentration (ppm@ 15%O_2)	N/A	1.58	0.11	0.66
Emission Rate (lb/hr)	N/A	14.14	0.58	2.20
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,310,200	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,310,200	SCFH

Weather Data

Barometric Pressure	29.36	in. Hg
Relative Humidity	51	%
Ambient Temperature	55	°F
Specific Humidity	0.004760	lb H_2O / lb air

Unit Data

Unit Load	345.9	megawatts
Stack Exhaust Flow (M19)	57,751,340	SCFH

Base Load Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 12:32:28	2400	13.33	1.85	0.11	1.23	8.19
02/25/20 12:32:58	2430	13.33	1.85	0.13	1.18	8.16
02/25/20 12:33:28	2460	13.33	1.81	0.10	1.17	8.11
02/25/20 12:33:58	2490	13.33	1.80	0.13	1.18	8.09
02/25/20 12:34:28	2520	13.33	1.79	0.16	1.17	8.12
02/25/20 12:34:58	2550	13.34	1.78	0.12	1.17	8.15
02/25/20 12:35:28	2580	13.33	1.82	0.14	1.15	8.19
02/25/20 12:35:58	2610	13.33	1.81	0.13	1.15	8.18
02/25/20 12:36:28	2640	13.33	1.82	0.13	1.19	8.33
02/25/20 12:36:58	2670	13.33	1.82	0.12	1.22	8.37
02/25/20 12:37:28	2700	13.33	1.81	0.13	1.21	8.35
02/25/20 12:37:58	2730	13.33	1.77	0.12	1.15	8.33
02/25/20 12:38:28	2760	13.33	1.80	0.12	1.14	8.31
02/25/20 12:38:58	2790	13.34	1.79	0.11	1.15	8.31
02/25/20 12:39:28	2820	13.34	1.81	0.12	1.12	8.33
02/25/20 12:39:58	2850	13.33	1.81	0.13	1.13	8.32
02/25/20 12:40:28	2880	13.34	1.81	0.11	1.09	8.33
02/25/20 12:40:58	2910	13.34	1.81	0.11	1.02	8.36
02/25/20 12:41:28	2940	13.33	1.82	0.11	1.05	8.65
02/25/20 12:41:58	2970	13.33	1.87	0.12	1.03	8.57
02/25/20 12:42:28	3000	13.33	1.87	0.14	1.03	8.48
02/25/20 12:42:58	3030	13.33	1.88	0.15	1.03	8.44
02/25/20 12:43:28	3060	13.33	1.88	0.16	1.01	8.39
02/25/20 12:43:58	3090	13.33	1.85	0.13	0.97	8.38
02/25/20 12:44:28	3120	13.33	1.83	0.14	0.95	8.36
02/25/20 12:44:58	3150	13.33	1.85	0.15	0.96	8.32
02/25/20 12:45:28	3180	13.31	1.88	0.14	0.95	8.28
02/25/20 12:45:58	3210	13.28	1.90	0.12	0.99	8.26
02/25/20 12:46:28	3240	13.25	1.87	0.12	0.95	8.22
02/25/20 12:46:58	3270	13.24	1.85	0.13	0.90	8.28
02/25/20 12:47:28	3300	13.22	1.77	0.11	0.88	8.31
02/25/20 12:47:58	3330	13.22	1.68	0.11	0.83	8.33
02/25/20 12:48:28	3360	13.22	1.63	0.11	0.82	8.34
02/25/20 12:48:58	3390	13.21	1.56	0.13	0.79	8.39
02/25/20 12:49:28	3420	13.22	1.48	0.13	0.77	8.44
02/25/20 12:49:58	3450	13.25	1.45	0.16	0.82	8.45
02/25/20 12:50:28	3480	13.29	1.41	0.12	0.80	8.42
02/25/20 12:50:58	3510	13.31	1.37	0.11	0.77	8.33
02/25/20 12:51:28	3540	13.33	1.33	0.11	0.87	8.23
02/25/20 12:51:58	3570	13.35	1.31	0.14	0.85	8.23
02/25/20 12:52:28	3600	13.36	1.27	0.13	0.86	8.20
02/25/20 12:52:58	3630	13.37	1.26	0.12	0.91	8.18
RAW AVERAGE		**13.31**	**1.72**	**0.43**	**1.01**	**8.31**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.05	-0.53	-0.04	
	Final Zero	0.00	-0.35	-0.04	
	Avg. Zero	-0.03	-0.44	-0.04	
	Initial UpScale	12.02	4.83	5.14	
	Final UpScale	12.02	4.94	5.09	
	Avg. UpScale	12.02	4.89	5.12	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.25	2.00	0.46	1.11
Concentration (ppm@ 15%O_2)	N/A	1.54	0.35	0.85
Emission Rate (lb/hr)	N/A	13.77	1.93	2.83
Emission Rate (lb/MMBtu)	N/A	0.0057	0.001	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,308,160	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,308,160	SCFH

Weather Data

Barometric Pressure	29.34	in. Hg
Relative Humidity	49	%
Ambient Temperature	55	°F
Specific Humidity	0.004540	lb H_2O / lb air

Unit Data

Unit Load	345.4	megawatts
Stack Exhaust Flow (M19)	57,955,701	SCFH

Base Load Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 13:07:28	4500	13.27	1.90	0.13	1.17	7.19
02/25/20 13:07:58	4530	13.28	1.89	0.15	1.07	7.22
02/25/20 13:08:28	4560	13.29	1.86	0.13	1.03	7.28
02/25/20 13:08:58	4590	13.30	1.88	0.18	1.08	7.35
02/25/20 13:09:28	4620	13.30	1.88	0.17	1.06	7.40
02/25/20 13:09:58	4650	13.32	1.88	0.16	1.06	7.43
02/25/20 13:10:28	4680	13.33	1.87	0.15	1.06	7.50
02/25/20 13:10:58	4710	13.31	1.86	0.12	1.05	7.52
02/25/20 13:11:28	4740	13.32	1.86	0.13	1.07	8.62
02/25/20 13:11:58	4770	13.33	1.87	0.10	1.03	8.32
02/25/20 13:12:28	4800	13.33	1.89	0.12	1.09	9.15
02/25/20 13:12:58	4830	13.33	1.87	0.12	1.03	9.36
02/25/20 13:13:28	4860	13.34	1.86	0.12	1.02	8.82
02/25/20 13:13:58	4890	13.34	1.88	0.12	1.00	8.74
02/25/20 13:14:28	4920	13.34	1.87	0.14	0.98	8.35
02/25/20 13:14:58	4950	13.34	1.86	0.11	1.03	8.94
02/25/20 13:15:28	4980	13.34	1.82	0.13	1.00	8.18
02/25/20 13:15:58	5010	13.34	1.85	0.14	0.98	8.27
02/25/20 13:16:28	5040	13.35	1.82	0.12	0.99	8.23
02/25/20 13:16:58	5070	13.34	1.82	0.13	0.97	7.99
02/25/20 13:17:28	5100	13.36	1.82	0.11	1.02	8.43
02/25/20 13:17:58	5130	13.35	1.83	0.12	0.99	8.20
02/25/20 13:18:28	5160	13.35	1.82	0.14	1.01	8.29
02/25/20 13:18:58	5190	13.35	1.78	0.13	1.02	8.60
02/25/20 13:19:28	5220	13.35	1.82	0.12	0.99	8.11
02/25/20 13:19:58	5250	13.35	1.80	0.11	1.02	8.31
02/25/20 13:20:28	5280	13.35	1.75	0.11	1.00	8.16
02/25/20 13:20:58	5310	13.34	1.75	0.12	1.01	7.96
02/25/20 13:21:28	5340	13.35	1.75	0.11	1.07	8.60
02/25/20 13:21:58	5370	13.34	1.77	0.13	0.99	8.13
02/25/20 13:22:28	5400	13.35	1.78	0.15	1.02	7.96
02/25/20 13:22:58	5430	13.35	1.79	0.11	1.02	8.38
02/25/20 13:23:28	5460	13.34	1.85	0.13	1.01	8.02
02/25/20 13:23:58	5490	13.35	1.89	0.10	1.01	7.95
02/25/20 13:24:28	5520	13.35	1.94	0.13	1.07	8.65
02/25/20 13:24:58	5550	13.35	2.00	0.11	1.02	8.06
02/25/20 13:25:28	5580	13.35	2.10	0.13	1.06	8.09
02/25/20 13:25:58	5610	13.34	2.13	0.12	1.04	8.34
02/25/20 13:26:28	5640	13.35	2.23	0.12	1.08	7.96
02/25/20 13:26:58	5670	13.36	2.29	0.12	1.07	8.15
02/25/20 13:27:28	5700	13.35	2.35	0.08	1.07	8.38
02/25/20 13:27:58	5730	13.35	2.40	0.13	1.03	8.00
RAW AVERAGE		**13.34**	**1.90**	**0.13**	**1.03**	**8.16**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	0.00	-0.35	-0.04	
	Final Zero	-0.04	-0.01	-0.04	
	Avg. Zero	-0.02	-0.18	-0.04	
	Initial UpScale	12.02	4.94	5.09	
	Final UpScale	12.01	4.92	5.08	
	Avg. UpScale	12.01	4.93	5.09	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.29	2.00	0.16	1.13
Concentration (ppm@ 15%O_2)	N/A	1.55	0.13	0.87
Emission Rate (lb/hr)	N/A	13.85	0.69	2.88
Emission Rate (lb/MMBtu)	N/A	0.0057	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,308,570	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,308,570	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	48	%
Ambient Temperature	56	°F
Specific Humidity	0.004504	lb H_2O / lb air

Unit Data

Unit Load	345.6	megawatts
Stack Exhaust Flow (M19)	48,756,000	SCFH

Base Load Load, Run - 4

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 13:36:28	6240	13.30	2.02	0.12	1.11	7.00
02/25/20 13:36:58	6270	13.32	2.01	0.14	1.05	7.11
02/25/20 13:37:28	6300	13.32	2.01	0.15	1.00	7.17
02/25/20 13:37:58	6330	13.34	1.98	0.16	0.98	7.20
02/25/20 13:38:28	6360	13.34	1.99	0.13	1.01	7.24
02/25/20 13:38:58	6390	13.33	1.97	0.12	0.97	7.31
02/25/20 13:39:28	6420	13.35	2.02	0.12	1.03	8.43
02/25/20 13:39:58	6450	13.34	2.01	0.13	0.99	8.42
02/25/20 13:40:28	6480	13.35	2.02	0.13	0.99	8.10
02/25/20 13:40:58	6510	13.36	2.05	0.10	1.02	10.02
02/25/20 13:41:28	6540	13.35	2.08	0.11	0.96	8.79
02/25/20 13:41:58	6570	13.35	2.13	0.13	0.96	8.58
02/25/20 13:42:28	6600	13.36	2.18	0.14	0.97	8.43
02/25/20 13:42:58	6630	13.36	2.23	0.12	0.94	8.21
02/25/20 13:43:28	6660	13.36	2.25	0.12	0.98	8.14
02/25/20 13:43:58	6690	13.36	2.28	0.13	0.97	8.11
02/25/20 13:44:28	6720	13.35	2.31	0.11	0.98	8.09
02/25/20 13:44:58	6750	13.36	2.36	0.12	0.96	8.08
02/25/20 13:45:28	6780	13.37	2.37	0.10	0.93	8.08
02/25/20 13:45:58	6810	13.36	2.37	0.12	0.97	8.08
02/25/20 13:46:28	6840	13.36	2.38	0.13	0.99	8.07
02/25/20 13:46:58	6870	13.37	2.36	0.12	0.94	8.08
02/25/20 13:47:28	6900	13.37	2.37	0.11	0.96	8.06
02/25/20 13:47:58	6930	13.37	2.33	0.10	0.96	8.05
02/25/20 13:48:28	6960	13.37	2.31	0.13	0.98	8.05
02/25/20 13:48:58	6990	13.36	2.26	0.08	0.94	8.03
02/25/20 13:49:28	7020	13.37	2.21	0.10	0.91	8.03
02/25/20 13:49:58	7050	13.36	2.19	0.10	0.90	8.02
02/25/20 13:50:28	7080	13.37	2.18	0.12	0.91	8.03
02/25/20 13:50:58	7110	13.38	2.08	0.09	0.93	8.00
02/25/20 13:51:28	7140	13.38	2.06	0.12	0.92	7.98
02/25/20 13:51:58	7170	13.39	2.06	0.10	0.94	7.98
02/25/20 13:52:28	7200	13.39	2.06	0.12	0.92	8.01
02/25/20 13:52:58	7230	13.38	2.03	0.11	0.94	8.05
02/25/20 13:53:28	7260	13.38	2.02	0.12	0.92	8.08
02/25/20 13:53:58	7290	13.39	2.01	0.10	0.93	8.16
02/25/20 13:54:28	7320	13.39	2.03	0.10	0.93	8.16
02/25/20 13:54:58	7350	13.39	2.07	0.11	0.93	8.13
02/25/20 13:55:28	7380	13.38	2.09	0.10	0.96	8.09
02/25/20 13:55:58	7410	13.39	2.13	0.12	0.95	8.06
02/25/20 13:56:28	7440	13.38	2.18	0.12	0.96	8.05
02/25/20 13:56:58	7470	13.38	2.26	0.12	1.00	8.02
RAW AVERAGE		**11.91**	**2.44**	**0.74**	**0.96**	**8.04**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.04	-0.01	-0.04	
	Final Zero	-0.02	0.03	-0.05	
	Avg. Zero	-0.03	0.01	-0.05	
	Initial UpScale	12.01	4.92	5.08	
	Final UpScale	12.05	4.96	5.08	
	Avg. UpScale	12.03	4.94	5.08	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	11.85	2.42	0.78	1.05
Concentration (ppm@ 15%O_2)	N/A	1.58	0.51	0.68
Emission Rate (lb/hr)	N/A	14.11	2.76	2.26
Emission Rate (lb/MMBtu)	N/A	0.0058	0.001	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,306,530	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,306,530	SCFH

Weather Data

Barometric Pressure	29.30	in. Hg
Relative Humidity	45	%
Ambient Temperature	59	°F
Specific Humidity	0.004816	lb H_2O / lb air

Unit Data

Unit Load	345.4	megawatts
Stack Exhaust Flow (M19)	57,994,954	SCFH

Base Load Load, Run - 5

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 14:15:28	8580	13.40	2.24	0.10	1.11	7.92
02/25/20 14:15:58	8610	13.41	2.26	0.13	1.11	7.90
02/25/20 14:16:28	8640	13.40	2.27	0.12	1.13	7.94
02/25/20 14:16:58	8670	13.42	2.33	0.10	1.09	7.95
02/25/20 14:17:28	8700	13.41	2.29	0.13	1.09	7.95
02/25/20 14:17:58	8730	13.40	2.26	0.12	1.08	7.94
02/25/20 14:18:28	8760	13.40	2.26	0.09	1.07	7.95
02/25/20 14:18:58	8790	13.40	2.27	0.13	1.06	7.96
02/25/20 14:19:28	8820	13.40	2.26	0.11	1.06	7.95
02/25/20 14:19:58	8850	13.39	2.22	0.13	1.04	7.94
02/25/20 14:20:28	8880	13.39	2.20	0.10	1.02	7.94
02/25/20 14:20:58	8910	13.39	2.15	0.11	1.02	7.96
02/25/20 14:21:28	8940	13.39	2.14	0.12	1.04	7.88
02/25/20 14:21:58	8970	13.39	2.05	0.12	1.06	7.97
02/25/20 14:22:28	9000	13.39	1.94	0.10	1.11	9.26
02/25/20 14:22:58	9030	13.39	1.84	0.11	1.04	8.64
02/25/20 14:23:28	9060	13.39	1.77	0.10	0.99	8.17
02/25/20 14:23:58	9090	13.38	1.73	0.12	1.03	8.13
02/25/20 14:24:28	9120	13.38	1.71	0.10	1.05	8.10
02/25/20 14:24:58	9150	13.39	1.67	0.11	1.02	8.08
02/25/20 14:25:28	9180	13.39	1.67	0.08	0.98	8.10
02/25/20 14:25:58	9210	13.38	1.65	0.10	0.99	8.12
02/25/20 14:26:28	9240	13.39	1.65	0.11	0.99	8.11
02/25/20 14:26:58	9270	13.39	1.65	0.10	0.99	8.09
02/25/20 14:27:28	9300	13.39	1.71	0.10	1.00	8.11
02/25/20 14:27:58	9330	13.39	1.71	0.10	1.08	9.45
02/25/20 14:28:28	9360	13.39	1.71	0.11	0.94	8.50
02/25/20 14:28:58	9390	13.39	1.70	0.09	0.99	8.26
02/25/20 14:29:28	9420	13.39	1.74	0.12	0.98	8.23
02/25/20 14:29:58	9450	13.38	1.78	0.11	1.00	8.19
02/25/20 14:30:28	9480	13.38	1.82	0.13	0.98	8.20
02/25/20 14:30:58	9510	13.38	1.92	0.08	0.95	8.20
02/25/20 14:31:28	9540	13.38	1.91	0.12	1.02	8.19
02/25/20 14:31:58	9570	13.38	1.97	0.12	1.00	8.16
02/25/20 14:32:28	9600	13.37	2.01	0.12	1.02	8.13
02/25/20 14:32:58	9630	13.38	2.02	0.11	0.94	8.13
02/25/20 14:33:28	9660	13.39	2.07	0.08	1.03	8.13
02/25/20 14:33:58	9690	13.39	2.09	0.12	1.02	8.20
02/25/20 14:34:28	9720	13.38	2.12	0.08	0.99	8.23
02/25/20 14:34:58	9750	13.38	2.12	0.10	1.03	8.27
02/25/20 14:35:28	9780	13.38	2.11	0.08	1.01	8.26
02/25/20 14:35:58	9810	13.38	2.11	0.11	1.00	8.25
RAW AVERAGE		**13.39**	**1.98**	**0.11**	**1.03**	**8.17**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	0.03	-0.05	
	Final Zero	-0.02	0.06	-0.08	
	Avg. Zero	-0.02	0.05	-0.07	
	Initial UpScale	12.05	4.96	5.08	
	Final UpScale	12.05	4.94	5.04	
	Avg. UpScale	12.05	4.95	5.06	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.30	1.94	0.17	1.12
Concentration (ppm@ 15%O_2)	N/A	1.50	0.13	0.87
Emission Rate (lb/hr)	N/A	13.41	0.72	2.87
Emission Rate (lb/MMBtu)	N/A	0.0055	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,306,940	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,306,940	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	48	%
Ambient Temperature	56	°F
Specific Humidity	0.004585	lb H_2O / lb air

Unit Data

Unit Load	345.5	megawatts
Stack Exhaust Flow (M19)	57,620,510	SCFH

Base Load Load, Run - 6

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 14:46:28	10440	13.30	2.13	0.10	0.85	7.13
02/25/20 14:46:58	10470	13.30	2.03	0.12	0.83	7.15
02/25/20 14:47:28	10500	13.30	1.98	0.11	0.83	7.25
02/25/20 14:47:58	10530	13.31	1.93	0.12	0.82	7.35
02/25/20 14:48:28	10560	13.31	1.91	0.10	0.80	7.40
02/25/20 14:48:58	10590	13.32	1.87	0.08	0.80	7.83
02/25/20 14:49:28	10620	13.32	1.85	0.10	0.81	8.04
02/25/20 14:49:58	10650	13.33	1.85	0.10	0.78	7.85
02/25/20 14:50:28	10680	13.34	1.89	0.11	0.82	8.73
02/25/20 14:50:58	10710	13.34	1.91	0.07	0.83	9.89
02/25/20 14:51:28	10740	13.32	1.86	0.09	0.78	8.84
02/25/20 14:51:58	10770	13.31	1.87	0.07	0.82	8.69
02/25/20 14:52:28	10800	13.31	1.88	0.09	0.74	8.51
02/25/20 14:52:58	10830	13.32	1.87	0.10	0.74	8.25
02/25/20 14:53:28	10860	13.33	1.86	0.08	0.69	8.19
02/25/20 14:53:58	10890	13.32	2.09	0.09	0.74	8.39
02/25/20 14:54:28	10920	13.32	1.85	0.08	0.75	8.42
02/25/20 14:54:58	10950	13.32	2.21	0.11	0.74	8.33
02/25/20 14:55:28	10980	13.32	1.87	0.09	0.75	8.25
02/25/20 14:55:58	11010	13.31	1.87	0.23	0.75	8.18
02/25/20 14:56:28	11040	13.33	1.87	0.09	0.78	8.50
02/25/20 14:56:58	11070	13.32	1.86	0.09	0.75	8.32
02/25/20 14:57:28	11100	13.33	1.86	0.09	0.73	8.23
02/25/20 14:57:58	11130	13.32	1.77	0.10	0.78	8.34
02/25/20 14:58:28	11160	13.33	1.71	0.10	0.78	9.06
02/25/20 14:58:58	11190	13.33	1.71	0.10	0.81	10.71
02/25/20 14:59:28	11220	13.33	1.72	0.08	0.76	8.66
02/25/20 14:59:58	11250	13.33	1.70	0.08	0.75	8.53
02/25/20 15:00:28	11280	13.33	1.70	0.10	0.77	8.41
02/25/20 15:00:58	11310	13.33	1.70	0.07	0.78	8.35
02/25/20 15:01:28	11340	13.33	1.70	0.12	0.78	8.28
02/25/20 15:01:58	11370	13.33	1.74	0.08	0.82	8.50
02/25/20 15:02:28	11400	13.33	1.75	0.08	0.82	8.42
02/25/20 15:02:58	11430	13.32	1.81	0.12	0.82	8.31
02/25/20 15:03:28	11460	13.32	1.84	0.10	0.81	8.29
02/25/20 15:03:58	11490	13.33	1.84	0.80	0.79	8.23
02/25/20 15:04:28	11520	13.33	2.01	0.22	0.76	8.18
02/25/20 15:04:58	11550	13.33	1.90	0.25	0.80	8.21
02/25/20 15:05:28	11580	13.33	1.96	0.08	0.79	8.72
02/25/20 15:05:58	11610	13.33	1.91	0.08	0.81	8.45
02/25/20 15:06:28	11640	13.32	1.97	0.13	0.91	10.39
02/25/20 15:06:58	11670	13.33	1.95	0.08	0.90	8.51
RAW AVERAGE		**13.32**	**1.87**	**0.12**	**0.79**	**8.39**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	0.06	-0.08	
	Final Zero	-0.06	0.02	-0.11	
	Avg. Zero	-0.04	0.04	-0.10	
	Initial UpScale	12.05	4.94	5.04	
	Final UpScale	12.02	4.92	5.07	
	Avg. UpScale	12.04	4.93	5.06	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.25	1.84	0.21	0.86
Concentration (ppm@ 15%O_2)	N/A	1.42	0.16	0.66
Emission Rate (lb/hr)	N/A	12.65	0.89	2.19
Emission Rate (lb/MMBtu)	N/A	0.0052	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,305,710	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,305,710	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	50	%
Ambient Temperature	56	°F
Specific Humidity	0.004805	lb H_2O / lb air

Unit Data

Unit Load	345.3	megawatts
Stack Exhaust Flow (M19)	57,735,796	SCFH

Base Load Load, Run - 7

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 15:17:28	12300	13.28	2.07	0.10	0.85	7.57
02/25/20 15:17:58	12330	13.29	2.05	0.11	0.86	7.57
02/25/20 15:18:28	12360	13.29	2.07	0.10	0.84	7.56
02/25/20 15:18:58	12390	13.29	2.06	0.11	0.81	7.56
02/25/20 15:19:28	12420	13.30	2.07	0.09	0.82	7.54
02/25/20 15:19:58	12450	13.32	2.06	0.07	0.79	7.51
02/25/20 15:20:28	12480	13.32	2.07	0.09	0.85	8.68
02/25/20 15:20:58	12510	13.33	2.07	0.10	0.93	10.81
02/25/20 15:21:28	12540	13.32	2.12	0.09	0.80	9.36
02/25/20 15:21:58	12570	13.32	2.12	0.10	0.73	8.61
02/25/20 15:22:28	12600	13.32	2.08	0.11	0.79	8.34
02/25/20 15:22:58	12630	13.32	2.05	0.06	0.81	8.15
02/25/20 15:23:28	12660	13.32	2.03	0.08	0.78	8.11
02/25/20 15:23:58	12690	13.32	2.02	0.08	0.80	8.08
02/25/20 15:24:28	12720	13.33	2.03	0.09	0.81	8.07
02/25/20 15:24:58	12750	13.32	2.04	0.08	0.84	8.05
02/25/20 15:25:28	12780	13.32	2.01	0.08	0.84	8.03
02/25/20 15:25:58	12810	13.32	1.95	0.07	0.78	8.07
02/25/20 15:26:28	12840	13.33	1.91	0.06	0.79	8.12
02/25/20 15:26:58	12870	13.33	1.89	0.08	0.77	8.20
02/25/20 15:27:28	12900	13.34	1.87	0.08	0.77	8.21
02/25/20 15:27:58	12930	13.34	1.91	0.16	0.72	8.21
02/25/20 15:28:28	12960	13.33	3.05	0.41	0.72	8.22
02/25/20 15:28:58	12990	13.32	1.80	0.07	0.71	8.23
02/25/20 15:29:28	13020	13.33	1.87	0.06	0.72	8.23
02/25/20 15:29:58	13050	13.33	1.82	0.08	0.73	8.22
02/25/20 15:30:28	13080	13.33	1.82	0.08	0.71	8.19
02/25/20 15:30:58	13110	13.33	1.80	0.09	0.74	8.16
02/25/20 15:31:28	13140	13.33	1.81	0.09	0.72	8.18
02/25/20 15:31:58	13170	13.33	1.82	0.07	0.75	8.98
02/25/20 15:32:28	13200	13.35	1.84	0.08	0.73	9.13
02/25/20 15:32:58	13230	13.33	1.77	0.10	0.74	8.33
02/25/20 15:33:28	13260	13.33	1.76	0.06	0.74	8.30
02/25/20 15:33:58	13290	13.32	1.80	0.07	0.73	8.24
02/25/20 15:34:28	13320	13.32	1.79	0.07	0.77	8.18
02/25/20 15:34:58	13350	13.33	1.88	0.07	0.77	8.16
02/25/20 15:35:28	13380	13.33	1.92	0.07	0.80	8.13
02/25/20 15:35:58	13410	13.33	1.96	0.05	0.76	8.15
02/25/20 15:36:28	13440	13.32	1.97	0.05	0.77	8.18
02/25/20 15:36:58	13470	13.33	2.02	0.06	0.73	8.20
02/25/20 15:37:28	13500	13.33	2.09	0.07	0.80	9.01
02/25/20 15:37:58	13530	13.33	2.11	0.06	0.78	8.34
RAW AVERAGE		**13.32**	**1.98**	**0.09**	**0.78**	**8.27**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.06	0.02	-0.11	
	Final Zero	-0.06	0.06	-0.07	
	Avg. Zero	-0.06	0.04	-0.09	
	Initial UpScale	12.02	4.92	5.07	
	Final UpScale	12.01	4.94	5.09	
	Avg. UpScale	12.02	4.93	5.08	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.27	1.95	0.18	0.85
Concentration (ppm@ 15%O_2)	N/A	1.51	0.14	0.66
Emission Rate (lb/hr)	N/A	13.45	0.74	2.17
Emission Rate (lb/MMBtu)	N/A	0.0056	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,311,140	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,311,140	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	51	%
Ambient Temperature	55	°F
Specific Humidity	0.004759	lb H_2O / lb air

Unit Data

Unit Load	345.8	megawatts
Stack Exhaust Flow (M19)	57,743,475	SCFH

Base Load Load, Run - 8

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 15:47:28	14100	13.25	2.11	0.11	0.82	7.35
02/25/20 15:47:58	14130	13.26	2.12	0.12	0.78	7.43
02/25/20 15:48:28	14160	13.26	2.12	0.10	0.75	7.47
02/25/20 15:48:58	14190	13.28	2.12	0.12	0.77	7.50
02/25/20 15:49:28	14220	13.29	2.11	0.10	0.76	7.51
02/25/20 15:49:58	14250	13.29	2.06	0.07	0.74	7.53
02/25/20 15:50:28	14280	13.29	2.06	0.06	0.75	7.54
02/25/20 15:50:58	14310	13.31	2.07	0.08	0.77	7.56
02/25/20 15:51:28	14340	13.32	2.07	0.09	0.74	7.57
02/25/20 15:51:58	14370	13.32	2.06	0.07	0.76	8.67
02/25/20 15:52:28	14400	13.32	2.06	0.08	0.69	8.08
02/25/20 15:52:58	14430	13.32	2.07	0.62	0.77	9.79
02/25/20 15:53:28	14460	13.32	2.09	0.07	0.70	8.72
02/25/20 15:53:58	14490	13.32	2.06	0.10	0.76	8.63
02/25/20 15:54:28	14520	13.32	2.06	0.07	0.76	8.40
02/25/20 15:54:58	14550	13.33	2.07	0.08	0.76	8.27
02/25/20 15:55:28	14580	13.33	2.07	0.08	0.73	8.08
02/25/20 15:55:58	14610	13.34	2.06	0.07	0.71	8.45
02/25/20 15:56:28	14640	13.33	2.05	0.06	0.74	8.07
02/25/20 15:56:58	14670	13.32	2.07	0.08	0.70	8.13
02/25/20 15:57:28	14700	13.32	2.07	0.08	0.70	8.25
02/25/20 15:57:58	14730	13.33	2.07	0.09	0.71	8.05
02/25/20 15:58:28	14760	13.33	2.08	0.07	0.71	8.49
02/25/20 15:58:58	14790	13.34	2.06	0.08	0.72	8.16
02/25/20 15:59:28	14820	13.33	2.05	0.10	0.72	8.10
02/25/20 15:59:58	14850	13.33	2.09	0.11	0.70	8.27
02/25/20 16:00:28	14880	13.33	2.07	0.08	0.68	7.99
02/25/20 16:00:58	14910	13.33	2.04	0.07	0.71	8.21
02/25/20 16:01:28	14940	13.33	2.05	0.06	0.69	8.04
02/25/20 16:01:58	14970	13.33	2.07	0.08	0.67	7.92
02/25/20 16:02:28	15000	13.33	2.07	0.05	0.70	8.38
02/25/20 16:02:58	15030	13.33	2.07	0.08	0.70	8.14
02/25/20 16:03:28	15060	13.33	2.07	0.06	0.73	8.21
02/25/20 16:03:58	15090	13.33	2.07	0.07	0.75	8.45
02/25/20 16:04:28	15120	13.33	2.07	0.09	0.75	8.04
02/25/20 16:04:58	15150	13.34	2.06	0.08	0.73	8.31
02/25/20 16:05:28	15180	13.33	2.54	0.09	0.69	8.21
02/25/20 16:05:58	15210	13.33	2.05	0.07	0.69	8.06
02/25/20 16:06:28	15240	13.33	2.17	0.47	0.70	8.45
02/25/20 16:06:58	15270	13.33	2.01	0.12	0.65	8.05
02/25/20 16:07:28	15300	13.14	2.09	0.13	0.67	8.28
02/25/20 16:07:58	15330	13.16	2.12	0.07	0.66	8.22
RAW AVERAGE		**13.31**	**2.09**	**0.11**	**0.72**	**8.12**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.06	0.06	-0.07	
	Final Zero	-0.04	0.01	-0.09	
	Avg. Zero	-0.05	0.04	-0.08	
	Initial UpScale	12.01	4.94	5.09	
	Final UpScale	12.03	4.94	5.08	
	Avg. UpScale	12.02	4.94	5.09	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.25	2.05	0.18	0.79
Concentration (ppm@ 15%O_2)	N/A	1.58	0.14	0.61
Emission Rate (lb/hr)	N/A	14.15	0.77	2.01
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,528,440	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,528,440	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	54	%
Ambient Temperature	55	°F
Specific Humidity	0.004894	lb H_2O / lb air

Unit Data

Unit Load	373.2	megawatts
Stack Exhaust Flow (M19)	57,042,226	SCFH

Base Load Load, Run - 9

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 16:20:28	16080	12.72	2.35	0.06	0.65	9.20
02/25/20 16:20:58	16110	12.72	2.36	0.05	0.67	9.97
02/25/20 16:21:28	16140	12.70	2.31	0.04	0.63	9.56
02/25/20 16:21:58	16170	12.69	2.36	0.05	0.60	9.03
02/25/20 16:22:28	16200	12.68	2.36	0.05	0.61	8.78
02/25/20 16:22:58	16230	12.66	2.32	0.07	0.60	8.56
02/25/20 16:23:28	16260	12.62	2.32	0.05	0.61	8.71
02/25/20 16:23:58	16290	12.58	2.32	0.08	0.61	8.90
02/25/20 16:24:28	16320	12.58	2.33	0.08	0.57	9.03
02/25/20 16:24:58	16350	12.59	2.35	0.04	0.53	8.80
02/25/20 16:25:28	16380	12.58	2.41	0.07	0.60	8.91
02/25/20 16:25:58	16410	12.58	2.42	0.06	0.56	8.69
02/25/20 16:26:28	16440	12.55	2.43	0.09	0.58	8.87
02/25/20 16:26:58	16470	12.53	2.41	0.05	0.57	8.61
02/25/20 16:27:28	16500	12.52	2.42	0.08	0.56	8.87
02/25/20 16:27:58	16530	12.53	2.42	0.10	0.56	8.76
02/25/20 16:28:28	16560	12.51	2.43	0.09	0.58	9.26
02/25/20 16:28:58	16590	12.50	2.41	0.07	0.54	8.80
02/25/20 16:29:28	16620	12.49	2.41	0.05	0.57	9.00
02/25/20 16:29:58	16650	12.49	2.41	0.08	0.57	8.97
02/25/20 16:30:28	16680	12.48	2.41	0.09	0.60	8.87
02/25/20 16:30:58	16710	12.47	2.35	0.09	0.55	8.81
02/25/20 16:31:28	16740	12.46	2.35	0.06	0.58	9.05
02/25/20 16:31:58	16770	12.45	2.39	0.06	0.64	9.83
02/25/20 16:32:28	16800	12.45	2.41	0.08	0.62	9.03
02/25/20 16:32:58	16830	12.43	2.42	0.07	0.60	9.28
02/25/20 16:33:28	16860	12.42	2.45	0.11	0.63	9.10
02/25/20 16:33:58	16890	12.41	2.48	0.10	0.62	9.51
02/25/20 16:34:28	16920	12.41	2.47	0.09	0.65	9.00
02/25/20 16:34:58	16950	12.39	2.45	0.08	0.65	8.91
02/25/20 16:35:28	16980	12.39	2.44	0.08	0.65	9.15
02/25/20 16:35:58	17010	12.39	2.42	0.12	0.62	8.98
02/25/20 16:36:28	17040	12.38	2.44	0.11	0.70	10.47
02/25/20 16:36:58	17070	12.37	2.41	0.09	0.66	9.55
02/25/20 16:37:28	17100	12.38	2.39	0.08	0.67	9.35
02/25/20 16:37:58	17130	12.37	2.35	0.10	0.67	9.09
02/25/20 16:38:28	17160	12.36	2.33	0.07	0.66	9.07
02/25/20 16:38:58	17190	12.38	2.33	0.07	0.71	9.00
02/25/20 16:39:28	17220	12.37	2.31	0.08	0.76	9.23
02/25/20 16:39:58	17250	12.37	2.39	0.09	0.71	9.19
02/25/20 16:40:28	17280	12.36	2.32	0.07	0.74	9.10
02/25/20 16:40:58	17310	12.37	2.31	0.10	0.71	9.25
RAW AVERAGE		**12.49**	**2.38**	**0.08**	**0.62**	**9.10**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.04	0.01	-0.09	
	Final Zero	-0.06	0.02	-0.07	
	Avg. Zero	-0.05	0.02	-0.08	
	Initial UpScale	12.03	4.94	5.08	
	Final UpScale	12.03	4.94	5.05	
	Avg. UpScale	12.03	4.94	5.07	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.43	2.36	0.15	0.69
Concentration (ppm@ 15%O_2)	N/A	1.65	0.11	0.48
Emission Rate (lb/hr)	N/A	16.10	0.64	1.73
Emission Rate (lb/MMBtu)	N/A	0.0061	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,554,920	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,554,920	SCFH

Weather Data

Barometric Pressure	29.34	in. Hg
Relative Humidity	57	%
Ambient Temperature	54	°F
Specific Humidity	0.005008	lb H_2O / lb air

Unit Data

Unit Load	378.1	megawatts
Stack Exhaust Flow (M19)	56,695,483	SCFH

Base Load Load, Run - 10

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 16:51:28	17940	12.31	2.31	0.12	0.77	8.03
02/25/20 16:51:58	17970	12.33	2.29	0.09	0.72	8.07
02/25/20 16:52:28	18000	12.32	2.28	0.09	0.69	8.14
02/25/20 16:52:58	18030	12.34	2.32	0.11	0.69	8.19
02/25/20 16:53:28	18060	12.35	2.33	0.10	0.74	10.22
02/25/20 16:53:58	18090	12.34	2.31	0.09	0.67	9.70
02/25/20 16:54:28	18120	12.36	2.35	0.09	0.64	9.67
02/25/20 16:54:58	18150	12.35	2.33	0.11	0.58	9.41
02/25/20 16:55:28	18180	12.37	2.31	0.09	0.58	9.04
02/25/20 16:55:58	18210	12.37	2.34	0.11	0.62	9.35
02/25/20 16:56:28	18240	12.36	2.31	0.10	0.61	8.93
02/25/20 16:56:58	18270	12.37	2.30	0.10	0.63	9.13
02/25/20 16:57:28	18300	12.37	2.29	0.16	0.65	9.00
02/25/20 16:57:58	18330	12.35	2.27	0.11	0.66	9.03
02/25/20 16:58:28	18360	12.34	2.26	0.08	0.66	9.03
02/25/20 16:58:58	18390	12.34	2.31	0.13	0.64	8.91
02/25/20 16:59:28	18420	12.32	2.31	0.13	0.60	8.92
02/25/20 16:59:58	18450	12.29	2.34	0.12	0.65	9.26
02/25/20 17:00:28	18480	12.29	2.36	0.11	0.67	9.15
02/25/20 17:00:58	18510	12.28	2.40	0.11	0.67	9.13
02/25/20 17:01:28	18540	12.28	2.40	0.11	0.67	9.09
02/25/20 17:01:58	18570	12.31	2.40	0.10	0.71	10.00
02/25/20 17:02:28	18600	12.32	2.33	0.11	0.74	9.49
02/25/20 17:02:58	18630	12.35	2.29	0.09	0.79	9.16
02/25/20 17:03:28	18660	12.35	2.27	0.08	0.80	9.20
02/25/20 17:03:58	18690	12.38	2.28	0.08	0.78	9.22
02/25/20 17:04:28	18720	12.38	2.22	0.07	0.81	9.88
02/25/20 17:04:58	18750	12.40	2.28	0.08	0.82	9.25
02/25/20 17:05:28	18780	12.37	2.20	0.04	0.90	10.10
02/25/20 17:05:58	18810	12.39	2.23	0.07	0.89	9.16
02/25/20 17:06:28	18840	12.37	2.21	0.08	0.98	9.22
02/25/20 17:06:58	18870	12.36	2.25	0.06	1.05	9.80
02/25/20 17:07:28	18900	12.35	2.28	0.06	1.05	9.36
02/25/20 17:07:58	18930	12.35	2.30	0.10	1.05	9.20
02/25/20 17:08:28	18960	12.33	2.32	0.08	1.03	9.33
02/25/20 17:08:58	18990	12.31	2.35	0.11	0.96	9.45
02/25/20 17:09:28	19020	12.31	2.38	0.09	1.04	9.99
02/25/20 17:09:58	19050	12.30	2.37	0.10	1.09	9.30
02/25/20 17:10:28	19080	12.32	2.40	0.09	1.10	9.38
02/25/20 17:10:58	19110	12.32	2.35	0.11	1.06	9.14
02/25/20 17:11:28	19140	12.33	2.31	0.07	1.01	9.15
02/25/20 17:11:58	19170	12.34	2.30	0.13	1.01	9.13
RAW AVERAGE		**12.34**	**2.31**	**0.10**	**0.80**	**9.22**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.06	0.02	-0.07	
	Final Zero	-0.08	-0.04	-0.07	
	Avg. Zero	-0.07	-0.01	-0.07	
	Initial UpScale	12.03	4.94	5.05	
	Final UpScale	12.01	4.89	5.04	
	Avg. UpScale	12.02	4.92	5.05	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.29	2.31	0.17	0.88
Concentration (ppm@ 15%O_2)	N/A	1.58	0.11	0.60
Emission Rate (lb/hr)	N/A	15.67	0.68	2.20
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,563,390	SCFH
Total Fuel Flow	2,563,390	SCFH

Weather Data

Barometric Pressure	29.37	in. Hg
Relative Humidity	76	%
Ambient Temperature	51	°F
Specific Humidity	0.006092	lb H_2O / lb air

Unit Data

Unit Load	379.9	megawatts
Stack Exhaust Flow (M19)	57,031,539	SCFH

Base Load Load, Run - 11

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 17:57:28	21900	12.37	2.36	0.07	2.52	9.25
02/25/20 17:57:58	21930	12.37	2.32	0.09	2.51	9.31
02/25/20 17:58:28	21960	12.36	2.35	0.07	2.39	9.15
02/25/20 17:58:58	21990	12.38	2.34	0.08	2.36	8.96
02/25/20 17:59:28	22020	12.37	2.32	0.07	2.44	9.24
02/25/20 17:59:58	22050	12.36	2.36	0.07	2.32	8.91
02/25/20 18:00:28	22080	12.35	2.36	0.05	2.29	8.98
02/25/20 18:00:58	22110	12.35	2.39	0.08	2.12	8.89
02/25/20 18:01:28	22140	12.34	2.37	0.07	2.04	8.70
02/25/20 18:01:58	22170	12.36	2.36	0.08	2.00	8.65
02/25/20 18:02:28	22200	12.35	2.36	0.08	2.04	8.49
02/25/20 18:02:58	22230	12.36	2.38	0.08	2.04	8.90
02/25/20 18:03:28	22260	12.36	2.36	0.07	1.90	8.59
02/25/20 18:03:58	22290	12.36	2.37	0.09	1.89	8.85
02/25/20 18:04:28	22320	12.36	2.42	0.09	1.91	9.02
02/25/20 18:04:58	22350	12.36	2.36	0.06	1.90	8.54
02/25/20 18:05:28	22380	12.37	2.37	0.07	1.88	8.76
02/25/20 18:05:58	22410	12.37	2.36	0.07	1.85	8.54
02/25/20 18:06:28	22440	12.38	2.41	0.07	1.90	9.14
02/25/20 18:06:58	22470	12.36	2.38	0.07	1.89	9.31
02/25/20 18:07:28	22500	12.37	2.37	0.08	1.78	8.56
02/25/20 18:07:58	22530	12.38	2.37	0.08	1.80	8.84
02/25/20 18:08:28	22560	12.37	2.32	0.07	1.72	8.53
02/25/20 18:08:58	22590	12.37	2.34	0.06	1.71	8.65
02/25/20 18:09:28	22620	12.37	2.35	0.07	1.76	9.69
02/25/20 18:09:58	22650	12.36	2.33	0.08	1.81	9.65
02/25/20 18:10:28	22680	12.36	2.33	0.08	1.90	9.07
02/25/20 18:10:58	22710	12.35	2.32	0.07	1.88	8.64
02/25/20 18:11:28	22740	12.35	2.43	0.06	2.03	10.70
02/25/20 18:11:58	22770	12.35	2.36	0.07	2.09	9.65
02/25/20 18:12:28	22800	12.35	2.35	0.08	2.45	9.96
02/25/20 18:12:58	22830	12.35	2.37	0.06	2.36	9.12
02/25/20 18:13:28	22860	12.35	2.40	0.10	2.25	9.48
02/25/20 18:13:58	22890	12.34	2.41	0.07	2.03	9.14
02/25/20 18:14:28	22920	12.34	2.33	0.09	2.00	8.84
02/25/20 18:14:58	22950	12.35	2.34	0.07	2.04	8.75
02/25/20 18:15:28	22980	12.34	2.32	0.08	2.01	8.58
02/25/20 18:15:58	23010	12.34	2.30	0.07	1.98	9.21
02/25/20 18:16:28	23040	12.34	2.31	0.07	1.79	8.77
02/25/20 18:16:58	23070	12.34	2.37	0.07	1.90	10.30
02/25/20 18:17:28	23100	12.34	2.37	0.07	1.87	10.57
02/25/20 18:17:58	23130	12.34	2.37	0.08	1.80	9.59
RAW AVERAGE		**12.36**	**2.36**	**0.07**	**2.03**	**9.11**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.08	-0.04	-0.07	
	Final Zero	-0.06	0.18	-0.13	
	Avg. Zero	-0.07	0.07	-0.10	
	Initial UpScale	12.01	4.89	5.04	
	Final UpScale	12.02	4.98	5.05	
	Avg. UpScale	12.02	4.94	5.05	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.31	2.31	0.17	2.23
Concentration (ppm@ 15%O_2)	N/A	1.59	0.12	1.53
Emission Rate (lb/hr)	N/A	15.73	0.71	5.62
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.006

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
AETB/QI and PGVP RATA Data Sheet
Cricket Valley Energy Center

AirEmissionTestingData - Level 3

QILastName	QIFirstName	QIMiddleInitial	AETBName	AETBPhoneNumber	AETBEmail	ExamDate	ProviderName	ProviderEmail
McBride	Matthew	S	Air Hygiene International Inc	888-461-8778	info@airhygiene.com	01/27/2019	Source Evaluation Society	qstiprogram@gmail.com

ProtocolGasData - Level 3

GasLevelCode	GasTypeCode	CylinderIdentifier	VendorIdentifier	ExpirationDate
LOW	ZERO			
HIGH	BALN,CO2,O2	CC721614	G12018	11/11/2026
MID	BALN,CO2,O2	CC722590	G12019	6/8/2027
HIGH	BALN,CO,NO,NOX	EB0018492	G12019	5/2/2022
MID	BALN,CO,NO,NOX	EB0065964	G12019	7/22/2022

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

CERTIFICATE OF ANALYSIS
(Zero Ambient Nitrogen)

Cylinder Number:	EB0072934	**Certification Date:**	05/21/2019
Product ID Number:	121026	**Expiration Date:**	05/19/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0072934.20190521-0	**Lot Number:**	EB0072934.20190521
Customer PO. NO.:		**Tracking Number:**	084249399
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
PGVP Vendor ID # G12019
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

Anthony Cyr
Assistant Operations Manager

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0098845	**Certification Date:**	05/03/2019
Product ID Number:	124731	**Expiration Date:**	05/02/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0098845.20190416-0	**Lot Number:**	EB0098845.20190416
Customer PO. NO.:		**Tracking Number:**	095689140
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	**48.7 PPM**	±0.6 PPM	FTIR	04/26/2019, 05/03/2019

Air Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003640	EB0003640.20190102	03/20/2022	GMIS	AIR	NO2	87.8 PPM	1.061	C1579010.01
EB0096848	EB0096848.20190102	03/21/2022	GMIS	AIR	NO2	61.1 PPM	1.072	C1579010.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/26/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0065964	**Certification Date:**	07/23/2019
Product ID Number:	125564	**Expiration Date:**	07/22/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0065964.20190611-0	**Lot Number:**	EB0065964.20190611
Customer PO. NO.:		**Tracking Number:**	083030934
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**5.09 PPM**	±0.07 PPM	FTIR	06/19/2019
Nitric Oxide	**4.88 PPM**	±0.06 PPM	Chemiluminescence	06/18/2019, 07/08/2019, 07/23/2019
Total Oxides of Nitrogen	4.91 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM066143	ALM066143.20171116	11/09/2022	GMIS	N2	NO	9.6 PPM	1.062	12100115
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0032297	EB0032297.20160725	09/06/2025	GMIS	N2	CO	6.15 PPM	1.067	091002
EB0060662	EB0060662.20151012	01/02/2022	GMIS	N2	NO	2.97 PPM	1.062	12100115
EB0078555	EB0078555.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.113	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	05/30/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	05/30/2019
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0018492	**Certification Date:**	05/03/2019
Product ID Number:	124737	**Expiration Date:**	05/02/2022
Cylinder Pressure:	1850 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0018492.20190404-0	**Lot Number:**	EB0018492.20190404
Customer PO. NO.:		**Tracking Number:**	040261874
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**9.5 PPM**	±0.11 PPM	FTIR	04/29/2019
Nitric Oxide	**9.2 PPM**	±0.11 PPM	Chemiluminescence	04/09/2019, 04/17/2019, 05/03/2019

Total Oxides of Nitrogen 9.2 PPM
Nitrogen Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC279029	091002	03/10/2020	NTRM	N2	CO	19.14 PPM	0.9927	091002
ALM066143	ALM066143.20171116	11/09/2022	GMIS	N2	NO	9.6 PPM	1.062	12100115
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
CC209392	CC209392.20180209	11/15/2021	GMIS	N2	NO	32.4 PPM	1.068	121001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	04/08/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	03/29/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC722590	**Certification Date:**	06/10/2019
Product ID Number:	124606	**Expiration Date:**	06/08/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC722590.20190603-0	**Lot Number:**	CC722590.20190603
Customer PO. NO.:		**Tracking Number:**	098497708
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.98 %**	±0.08 %	NDIR	06/10/2019
Oxygen	**11.97 %**	±0.07 %	MPA	06/07/2019
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003672	EB0003672.20180118	07/21/2026	GMIS	N2	O2	11.97 %	0.507	071001
EB0049614	EB0049614.20180504	07/21/2026	GMIS	N2	O2	24 %	0.497	071001
EB0050249	EB0050249.20180323	07/15/2026	GMIS	N2	CO2	15 %	0.777	101001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	05/31/2019
CO2	NDIR	Thermo	410i	1162980025	05/14/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Jasmine Godfrey
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC721614	**Certification Date:**	11/13/2018
Product ID Number:	124605	**Expiration Date:**	11/11/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC721614.20181109-0	**Lot Number:**	CC721614.20181109
Customer PO. NO.:		**Tracking Number:**	098499636
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**19.0 %**	±0.16 %	NDIR	11/13/2018
Oxygen	**21.0 %**	±0.12 %	MPA	11/13/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004987	EB0004987.20180323	07/15/2026	GMIS	N2	CO2	19.5 %	0.767	101001
EB0005996	EB0005996.20170209	05/09/2026	GMIS	N2	O2	20 %	0.077	071001
EB0032246	EB0032246.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	11/06/2018
CO2	NDIR	Thermo	410i	1162980025	10/24/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

CERTIFIED GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0100161	**Certification Date:**	12/30/2019
Product ID Number:	125123	**Expiration Date:**	12/29/2020
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0100161.20191230-0	**Lot Number:**	EB0100161.20191230
Customer PO. NO.:		**Tracking Number:**	095703088
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Ammonia	**50.4 PPM**	± 2% NIST	FTIR
Sulfur Hexafluoride	**9.02 PPM**	± 2% NIST	FTIR
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
SA18481	70086910005	04/12/2020	PS	N2	NH3	21.1 PPM	1.2	73248226
EB0079029	EB0079029	06/27/2020	PS	N2	SF6	10.1 PPM	5	191064

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NH3	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	
SF6	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-G, Revised on 2017-07-02

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the "hands of the test" on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the "hands of the test" on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3 A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

Data Provided by Client

Data provided by the Client is clearly identified in the report. Air Hygiene accepts data provided by the Client as accurate.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO_2 to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO_2 in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS
QUALITY ASSURANCE DATA

Date: February 25, 2020
Company: Cricket Valley Energy Center LLC
Location: Dover Plains, New York
Techs: MM / SB / RW

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
February 25, 2020	1	0

Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This laboratory also meets the A2LA *R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (*refer to joint ISO-ILAC-IAF Communiqué dated April 2017*).

Presented this 18th day of December 2019

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2021

For the tests to which this accreditation applies, please refer to the laboratory's Envrionmental Scope of Accreditation.

STAC
STACK TESTING ACCREDITATION COUNCIL

A2LA
American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.



Presented this 18th day of December 2019.

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2021

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY

Qualified Source Testing Individual

LET IT BE KNOWN THAT

MATTHEW S. McBRIDE

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 27TH DAY OF JANAURY 2019 AND EFFECTIVE UNTIL JANUARY 26TH, 2024

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Tina Sanderson, QSTI/QSTO Review Board

J. Wade Bice, QSTI/QSTO Review Board

Karen D. Kajiya-Mills , QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board


CERTIFICATE NO. 2014-847

Calibration Date: February 25, 2020 **Location:** Cricket Valley Energy Center - Unit U-00002

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 9.20

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.05	-0.54	0.05	YES (%)
4.91	5.09	1.96	0.18	YES (%)
9.20	9.28	0.87	0.08	YES (%)
Linearity = 0.985				




CO Span (ppm) = 9.50

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.01	-0.11	0.01	YES (%)
5.09	5.08	-0.11	0.01	YES (%)
9.50	9.62	1.26	0.12	YES (%)
Linearity = 0.987				



O_2 Span (%) = 21.00

SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	-0.01	-0.05	0.01	YES (%)
11.97	12.28	1.48	0.31	YES (%)
21.00	21.25	1.19	0.25	YES (%)
Linearity = 0.987				



NOx Converter Efficiency

Date: February 25, 2020

Analyzer: INST-NX-0031

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**48.70**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**1.40**
	Analyzer Reading, NOx Channel, ppmvd	**48.79**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**47.39**
	Converter Efficiency, %	**97.31**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{47.39 \text{ ppmvd}}{48.70 \text{ ppmvd}}$ x 100 = 97.31%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
02/25/20 05:10:12	380	48.20	1.54
02/25/20 05:10:22	390	48.62	1.58
02/25/20 05:10:32	400	48.69	1.51
02/25/20 05:10:42	410	48.69	1.50
02/25/20 05:10:52	420	48.73	1.50
02/25/20 05:11:02	430	48.78	1.54
02/25/20 05:11:12	440	48.74	1.39
02/25/20 05:11:22	***450***	***48.79***	***1.40***
02/25/20 05:11:32	460	48.76	1.42

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/25/20	10:50:28	BKG_0028.LAB	9.2175
02/25/20	10:50:42	BKG_0029.LAB	9.2171
02/25/20	10:50:56	BKG_0030.LAB	9.2332
02/25/20	10:51:10	BKG_0031.LAB	9.2632
02/25/20	10:51:23	BKG_0032.LAB	9.2413

PRE TEST AVERAGE **9.23**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/25/20	18:41:07	CTS_0013.LAB	9.1965
02/25/20	18:41:21	CTS_0014.LAB	9.2350
02/25/20	18:41:35	CTS_0015.LAB	9.2467
02/25/20	18:41:49	CTS_0016.LAB	9.2559
02/25/20	18:42:02	CTS_0017.LAB	9.2619

POST TEST AVERAGE **9.24**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.98

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.23	2.83	PASS
Post Test	9.24	2.89	PASS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/25/20	9:03:35	SPIKE_0074.LAB	50.6911
02/25/20	9:03:48	SPIKE_0075.LAB	50.8156
02/25/20	9:04:01	SPIKE_0076.LAB	50.8104
02/25/20	9:04:14	SPIKE_0077.LAB	50.9847
02/25/20	9:04:27	SPIKE_0078.LAB	51.0389

PRE TEST AVERAGE **50.87**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/25/20	18:53:43	CTS_0068.LAB	50.6090
02/25/20	18:53:57	CTS_0069.LAB	50.7610
02/25/20	18:54:11	CTS_0070.LAB	50.4207
02/25/20	18:54:25	CTS_0071.LAB	50.3055
02/25/20	18:54:39	CTS_0072.LAB	50.6951

POST TEST AVERAGE **50.56**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 50.40

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	50.87	0.93	PASS
Post Test	50.56	0.31	PASS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd	SF_6 ppmvd
02/25/20	18:53:02	CTS_0065.LAB	49.4376	9.6995
02/25/20	18:53:16	CTS_0066.LAB	49.8893	9.7029
02/25/20	18:53:30	CTS_0067.LAB	50.1982	9.6963
02/25/20	18:53:43	CTS_0068.LAB	50.6090	9.7062
02/25/20	18:53:57	CTS_0069.LAB	50.7610	9.6990
02/25/20	18:54:11	CTS_0070.LAB	50.4207	9.6701
02/25/20	18:54:25	CTS_0071.LAB	50.3055	9.6545
02/25/20	18:54:39	CTS_0072.LAB	50.6951	9.6904
RAW AVERAGE			**50.290**	**9.690**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
02/25/20	18:58:12	SPIKEA_0011.LAB	4.5224	10.3164	2.0434	-0.0017
02/25/20	18:58:26	SPIKEA_0012.LAB	4.5272	10.2733	1.9964	0.0023
02/25/20	18:58:40	SPIKEA_0013.LAB	4.5351	10.3082	1.9227	0.0012
02/25/20	18:58:54	SPIKEA_0014.LAB	4.5242	10.1841	1.9010	0.0043
02/25/20	18:59:08	SPIKEA_0015.LAB	4.5202	10.3074	1.8297	0.0021
02/25/20	18:59:21	SPIKEA_0016.LAB	4.5223	10.3226	1.8202	0.0014
02/25/20	18:59:35	SPIKEA_0017.LAB	4.5175	10.3704	1.8775	-0.0005
02/25/20	18:59:49	SPIKEA_0018.LAB	4.5186	10.4159	1.8772	-0.0017
RAW AVERAGE			**4.523**	**10.312**	**1.909**	**0.001**

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
02/25/20	19:14:42	SPIKEA_0083.LAB	4.2255	8.8933	0.7469	4.8027
02/25/20	19:14:56	SPIKEA_0084.LAB	4.2352	8.8749	0.7540	4.9654
02/25/20	19:15:10	SPIKEA_0085.LAB	4.2292	8.8755	0.7478	5.0308
02/25/20	19:15:23	SPIKEA_0086.LAB	4.2385	8.8667	0.7528	5.1024
02/25/20	19:15:37	SPIKEA_0087.LAB	4.2363	8.8807	0.7529	5.1074
02/25/20	19:15:51	SPIKEA_0088.LAB	4.2121	8.8493	0.7507	5.1148
02/25/20	19:16:05	SPIKEA_0089.LAB	4.2317	8.8510	0.7552	5.1317
02/25/20	19:16:18	SPIKEA_0090.LAB	4.2202	8.8275	0.7582	5.0736
RAW AVERAGE			**4.229**	**8.865**	**0.752**	**5.041**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
02/25/20	19:28:55	SPIKEA_0145.LAB	4.5872	9.5217	2.2365	0.0006
02/25/20	19:29:08	SPIKEA_0146.LAB	4.5784	9.5366	2.2389	0.0067
02/25/20	19:29:22	SPIKEA_0147.LAB	4.5825	9.5005	2.1338	0.0004
02/25/20	19:29:36	SPIKEA_0148.LAB	4.5891	9.5161	2.1187	0.0051
02/25/20	19:29:49	SPIKEA_0149.LAB	4.5844	9.5198	2.1194	0.0007
02/25/20	19:30:03	SPIKEA_0150.LAB	4.5840	9.5534	2.1266	0.0024
02/25/20	19:30:17	SPIKEA_0151.LAB	4.5505	10.0484	2.1577	-0.0049
02/25/20	19:30:31	SPIKEA_0152.LAB	4.5667	9.8760	2.1536	-0.0008
RAW AVERAGE			**4.578**	**9.634**	**2.161**	**0.001**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
02/25/20	19:34:52	SPIKEA_0171.LAB	4.2457	8.8554	0.7409	5.3409
02/25/20	19:35:06	SPIKEA_0172.LAB	4.2458	8.8409	0.7430	5.3043
02/25/20	19:35:19	SPIKEA_0173.LAB	4.2347	8.8397	0.7447	5.2658
02/25/20	19:35:33	SPIKEA_0174.LAB	4.2535	8.8035	0.7459	5.1583
02/25/20	19:35:47	SPIKEA_0175.LAB	4.2444	8.7976	0.7480	5.0769
02/25/20	19:36:01	SPIKEA_0176.LAB	4.2350	8.7795	0.7494	5.0325
02/25/20	19:36:15	SPIKEA_0177.LAB	4.2373	8.7592	0.7512	4.9294
02/25/20	19:36:28	SPIKEA_0178.LAB	4.2837	8.8170	0.6576	4.9571
RAW AVERAGE			**4.248**	**8.812**	**0.735**	**5.133**

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
02/25/20	19:41:03	SPIKEA_0198.LAB	4.5824	9.4929	2.0110	0.0053
02/25/20	19:41:17	SPIKEA_0199.LAB	4.6064	9.4872	1.9369	-0.0026
02/25/20	19:41:31	SPIKEA_0200.LAB	4.5913	9.4811	1.9793	0.0020
02/25/20	19:41:44	SPIKEA_0201.LAB	4.5849	9.4857	1.9839	-0.0024
02/25/20	19:41:58	SPIKEA_0202.LAB	4.5880	9.4799	1.9764	0.0018
02/25/20	19:42:12	SPIKEA_0203.LAB	4.5935	9.4664	1.9715	-0.0039
02/25/20	19:42:26	SPIKEA_0204.LAB	4.5924	9.4794	1.9360	0.0004
02/25/20	19:42:39	SPIKEA_0205.LAB	4.5819	9.5087	1.9563	0.0005
RAW AVERAGE			**4.590**	**9.485**	**1.969**	**0.000**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
02/25/20	19:48:23	SPIKEA_0230.LAB	4.2485	8.6077	0.7432	5.8106
02/25/20	19:48:37	SPIKEA_0231.LAB	4.2446	8.5992	0.7497	5.6583
02/25/20	19:48:50	SPIKEA_0232.LAB	4.2390	8.5942	0.7522	5.4796
02/25/20	19:49:04	SPIKEA_0233.LAB	4.2462	8.5921	0.7514	5.4695
02/25/20	19:49:18	SPIKEA_0234.LAB	4.2421	8.6067	0.7574	5.4405
02/25/20	19:49:32	SPIKEA_0235.LAB	4.2373	8.5977	0.7529	5.3990
02/25/20	19:49:45	SPIKEA_0236.LAB	4.2379	8.5604	0.7521	5.3451
02/25/20	19:49:59	SPIKEA_0237.LAB	4.2344	8.5425	0.7541	5.3697
RAW AVERAGE			**4.241**	**8.588**	**0.752**	**5.497**

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	50.29	50.29	50.29
Concentration of SF_6 Cylinder	ppmvd	9.69	9.69	9.69

Spike A

Stack CO_2 Concentration	%vw	4.523	4.578	4.590
Stack H_2O Concentration	%	10.312	9.634	9.485
Stack NH_3 Concentration	ppmvw	1.909	2.161	1.969
Stack SF_6 Concentration	ppmvw	0.001	0.001	0.000
Stack + Spike CO_2 Concentration	%vw	4.229	4.248	4.241
Stack + Spike H_2O Concentration	%	8.865	8.812	8.588
Stack + Spike NH_3 Concentration	ppmvw	5.041	5.133	5.497
Stack + Spike SF_6 Concentration	ppmvw	0.752	0.735	0.752
Dilution Ratio		0.085	0.083	0.085
Ideal NH_3 Spike Yield	ppmvd	6.231	6.376	6.258
Percent Recovery NH_3	%	83.67%	82.15%	94.26%

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	-0.02	-0.02
Final Zero	-0.01	0.02
Avg. Zero		0.00
Initial UpScale	12.13	5.05
Final UpScale	12.02	4.83
Avg. UpScale	12.08	4.94
Sys Resp (Zero)	-0.01	0.00
Sys Resp (Upscale)	12.28	5.09
Upscale Cal Gas	11.97	4.91
Initial Zero Bias	-0.05%	-0.22%
Final Zero Bias	0.00%	0.22%
Zero Drift	0.05%	0.43%
Initial Upscale Bias	-0.71%	-0.43%
Final Upscale Bias	-1.24%	-2.83%
Upscale Drift	0.52%	2.39%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.02
Alternative Specification Abs Diff **Final Zero**	0.00	0.02
Alternative Specification Abs Diff **Initial Upscale**	0.15	0.04
Alternative Specification Abs Diff **Final Upscale**	0.26	0.26
Calibration Span	21.00	9.20
3% of Cal. Span (drift)	0.63	0.28
5% of Cal. Span (bias)	1.05	0.46

Respone Time (min)	1.3	2.0
Sys. Response (min)	2.0	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
02/25/20 06:05:32		13.44			1.36		x
02/25/20 06:05:42		13.38			1.35		
02/25/20 06:05:52		13.39			1.33		
02/25/20 06:06:02		13.39			1.34		
02/25/20 06:06:12		13.38			1.38		
02/25/20 06:06:22		8.55			1.38		
02/25/20 06:06:32		0.72			1.24		
02/25/20 06:06:42	x	**0.16**			2.29		
02/25/20 06:06:52		**0.11**			4.25		
02/25/20 06:07:02		**0.07**			**4.95**	x	
02/25/20 06:07:12		**0.05**			**4.89**		
02/25/20 06:07:22		**0.04**			**4.94**		
02/25/20 06:07:32		**0.02**			**4.91**		
02/25/20 06:07:42		**0.01**			**4.95**		
02/25/20 06:07:52		**0.01**			**4.94**		
02/25/20 06:08:02		**0.00**			**4.94**		x
02/25/20 06:08:12		**-0.01**			**4.94**		
02/25/20 06:08:22		**-0.01**			**4.94**		
02/25/20 06:08:32		**-0.02**			**4.94**		
02/25/20 06:08:42		**-0.03**			**4.92**		
02/25/20 06:08:52		**-0.02**			**4.89**		
02/25/20 06:09:02		**-0.03**			**4.94**		
02/25/20 06:09:12		5.12			**4.93**		
02/25/20 06:09:22		**11.55**	x		4.06		
02/25/20 06:09:32		**11.85**			3.07		
02/25/20 06:09:42		**11.89**			2.25		
02/25/20 06:09:52		**11.91**			0.84		
02/25/20 06:10:02		**11.93**		x	**0.12**		
02/25/20 06:10:12		**11.94**			**0.09**		
02/25/20 06:10:22		**11.95**			**0.05**		

DRIFT AND BIAS CHECK			
Base Load Load, Run - 1	**O_2**	**NOx**	**CO**
Raw Average	13.40	1.85	0.14
Corrected Average	13.36	2.02	0.14
Initial Zero	-0.03	0.02	0.05
Final Zero	-0.05	-0.53	-0.04
Avg. Zero	-0.04	-0.26	0.01
Initial UpScale	11.99	4.93	5.13
Final UpScale	12.02	4.83	5.14
Avg. UpScale	12.01	4.88	5.14
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.10%	0.76%	0.63%
Final Zero Bias	-0.19%	-5.22%	-0.32%
Zero Drift	0.10%	5.98%	0.95%
Initial Upscale Bias	-1.38%	-1.74%	0.53%
Final Upscale Bias	-1.24%	-2.83%	0.63%
Upscale Drift	0.14%	1.09%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.02	0.07	0.06
Alternative Specification Abs Diff **Final Zero**	0.04	0.48	0.03
Alternative Specification Abs Diff **Initial Upscale**	0.29	0.16	0.05
Alternative Specification Abs Diff **Final Upscale**	0.26	0.26	0.06
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 2	**O_2**	**NOx**	**CO**
Raw Average	13.31	1.72	0.43
Corrected Average	13.25	2.00	0.46
Initial Zero	-0.05	-0.53	-0.04
Final Zero	0.00	-0.35	-0.04
Avg. Zero	-0.03	-0.44	-0.04
Initial UpScale	12.02	4.83	5.14
Final UpScale	12.02	4.94	5.09
Avg. UpScale	12.02	4.89	5.12
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.19%	-5.22%	-0.32%
Final Zero Bias	0.05%	-3.26%	-0.32%
Zero Drift	0.24%	1.96%	0.00%
Initial Upscale Bias	-1.24%	-2.83%	0.63%
Final Upscale Bias	-1.24%	-1.63%	0.11%
Upscale Drift	0.00%	1.20%	0.53%
Alternative Specification Abs Diff **Initial Zero**	0.04	0.48	0.03
Alternative Specification Abs Diff **Final Zero**	0.01	0.30	0.03
Alternative Specification Abs Diff **Initial Upscale**	0.26	0.26	0.06
Alternative Specification Abs Diff **Final Upscale**	0.26	0.15	0.01
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 3	**O_2**	**NOx**	**CO**
Raw Average	13.34	1.90	0.13
Corrected Average	13.29	2.00	0.16
Initial Zero	0.00	-0.35	-0.04
Final Zero	-0.04	-0.01	-0.04
Avg. Zero	-0.02	-0.18	-0.04
Initial UpScale	12.02	4.94	5.09
Final UpScale	12.01	4.92	5.08
Avg. UpScale	12.01	4.93	5.09
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	0.05%	-3.26%	-0.32%
Final Zero Bias	-0.14%	0.43%	-0.32%
Zero Drift	0.19%	3.70%	0.00%
Initial Upscale Bias	-1.24%	-1.63%	0.11%
Final Upscale Bias	-1.31%	-1.85%	0.00%
Upscale Drift	0.07%	0.22%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.30	0.03
Alternative Specification Abs Diff **Final Zero**	0.03	0.04	0.03
Alternative Specification Abs Diff **Initial Upscale**	0.26	0.15	0.01
Alternative Specification Abs Diff **Final Upscale**	0.27	0.17	0.00
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 4	**O_2**	**NOx**	**CO**
Raw Average	11.91	2.44	0.74
Corrected Average	11.85	2.42	0.78
Initial Zero	-0.04	-0.01	-0.04
Final Zero	-0.02	0.03	-0.05
Avg. Zero	-0.03	0.01	-0.05
Initial UpScale	12.01	4.92	5.08
Final UpScale	12.05	4.96	5.08
Avg. UpScale	12.03	4.94	5.08
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.14%	0.43%	-0.32%
Final Zero Bias	-0.05%	0.87%	-0.42%
Zero Drift	0.10%	0.43%	0.11%
Initial Upscale Bias	-1.31%	-1.85%	0.00%
Final Upscale Bias	-1.10%	-1.41%	0.00%
Upscale Drift	0.21%	0.43%	0.00%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.04	0.03
Alternative Specification Abs Diff **Final Zero**	0.01	0.08	0.04
Alternative Specification Abs Diff **Initial Upscale**	0.27	0.17	0.00
Alternative Specification Abs Diff **Final Upscale**	0.23	0.13	0.00
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 5	**O_2**	**NOx**	**CO**
Raw Average	13.39	1.98	0.11
Corrected Average	13.30	1.94	0.17
Initial Zero	-0.02	0.03	-0.05
Final Zero	-0.02	0.06	-0.08
Avg. Zero	-0.02	0.05	-0.07
Initial UpScale	12.05	4.96	5.08
Final UpScale	12.05	4.94	5.04
Avg. UpScale	12.05	4.95	5.06
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.05%	0.87%	-0.42%
Final Zero Bias	-0.05%	1.20%	-0.74%
Zero Drift	0.00%	0.33%	0.32%
Initial Upscale Bias	-1.10%	-1.41%	0.00%
Final Upscale Bias	-1.10%	-1.63%	-0.42%
Upscale Drift	0.00%	0.22%	0.42%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.08	0.04
Alternative Specification Abs Diff **Final Zero**	0.01	0.11	0.07
Alternative Specification Abs Diff **Initial Upscale**	0.23	0.13	0.00
Alternative Specification Abs Diff **Final Upscale**	0.23	0.15	0.04
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 6	**O_2**	**NOx**	**CO**
Raw Average	13.32	1.87	0.12
Corrected Average	13.25	1.84	0.21
Initial Zero	-0.02	0.06	-0.08
Final Zero	-0.06	0.02	-0.11
Avg. Zero	-0.04	0.04	-0.10
Initial UpScale	12.05	4.94	5.04
Final UpScale	12.02	4.92	5.07
Avg. UpScale	12.04	4.93	5.06
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.05%	1.20%	-0.74%
Final Zero Bias	-0.24%	0.76%	-1.05%
Zero Drift	0.19%	0.43%	0.32%
Initial Upscale Bias	-1.10%	-1.63%	-0.42%
Final Upscale Bias	-1.24%	-1.85%	-0.11%
Upscale Drift	0.14%	0.22%	0.32%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.11	0.07
Alternative Specification Abs Diff **Final Zero**	0.05	0.07	0.10
Alternative Specification Abs Diff **Initial Upscale**	0.23	0.15	0.04
Alternative Specification Abs Diff **Final Upscale**	0.26	0.17	0.01
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 7	**O_2**	**NOx**	**CO**
Raw Average	13.32	1.98	0.09
Corrected Average	13.27	1.95	0.18
Initial Zero	-0.06	0.02	-0.11
Final Zero	-0.06	0.06	-0.07
Avg. Zero	-0.06	0.04	-0.09
Initial UpScale	12.02	4.92	5.07
Final UpScale	12.01	4.94	5.09
Avg. UpScale	12.02	4.93	5.08
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.24%	0.76%	-1.05%
Final Zero Bias	-0.24%	1.20%	-0.63%
Zero Drift	0.00%	0.43%	0.42%
Initial Upscale Bias	-1.24%	-1.85%	-0.11%
Final Upscale Bias	-1.29%	-1.63%	0.11%
Upscale Drift	0.05%	0.22%	0.21%
Alternative Specification Abs Diff **Initial Zero**	0.05	0.07	0.10
Alternative Specification Abs Diff **Final Zero**	0.05	0.11	0.06
Alternative Specification Abs Diff **Initial Upscale**	0.26	0.17	0.01
Alternative Specification Abs Diff **Final Upscale**	0.27	0.15	0.01
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 8	**O_2**	**NOx**	**CO**
Raw Average	13.31	2.09	0.11
Corrected Average	13.25	2.05	0.18
Initial Zero	-0.06	0.06	-0.07
Final Zero	-0.04	0.01	-0.09
Avg. Zero	-0.05	0.04	-0.08
Initial UpScale	12.01	4.94	5.09
Final UpScale	12.03	4.94	5.08
Avg. UpScale	12.02	4.94	5.09
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.24%	1.20%	-0.63%
Final Zero Bias	-0.14%	0.65%	-0.84%
Zero Drift	0.10%	0.54%	0.21%
Initial Upscale Bias	-1.29%	-1.63%	0.11%
Final Upscale Bias	-1.19%	-1.63%	0.00%
Upscale Drift	0.10%	0.00%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.05	0.11	0.06
Alternative Specification Abs Diff **Final Zero**	0.03	0.06	0.08
Alternative Specification Abs Diff **Initial Upscale**	0.27	0.15	0.01
Alternative Specification Abs Diff **Final Upscale**	0.25	0.15	0.00
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 9	**O_2**	**NOx**	**CO**
Raw Average	12.49	2.38	0.08
Corrected Average	12.43	2.36	0.15
Initial Zero	-0.04	0.01	-0.09
Final Zero	-0.06	0.02	-0.07
Avg. Zero	-0.05	0.02	-0.08
Initial UpScale	12.03	4.94	5.08
Final UpScale	12.03	4.94	5.05
Avg. UpScale	12.03	4.94	5.07
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.14%	0.65%	-0.84%
Final Zero Bias	-0.24%	0.76%	-0.63%
Zero Drift	0.10%	0.11%	0.21%
Initial Upscale Bias	-1.19%	-1.63%	0.00%
Final Upscale Bias	-1.19%	-1.63%	-0.32%
Upscale Drift	0.00%	0.00%	0.32%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.06	0.08
Alternative Specification Abs Diff **Final Zero**	0.05	0.07	0.06
Alternative Specification Abs Diff **Initial Upscale**	0.25	0.15	0.00
Alternative Specification Abs Diff **Final Upscale**	0.25	0.15	0.03
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 10	**O_2**	**NOx**	**CO**
Raw Average	12.34	2.31	0.10
Corrected Average	12.29	2.31	0.17
Initial Zero	-0.06	0.02	-0.07
Final Zero	-0.08	-0.04	-0.07
Avg. Zero	-0.07	-0.01	-0.07
Initial UpScale	12.03	4.94	5.05
Final UpScale	12.01	4.89	5.04
Avg. UpScale	12.02	4.92	5.05
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.24%	0.76%	-0.63%
Final Zero Bias	-0.33%	0.11%	-0.63%
Zero Drift	0.10%	0.65%	0.00%
Initial Upscale Bias	-1.19%	-1.63%	-0.32%
Final Upscale Bias	-1.29%	-2.17%	-0.42%
Upscale Drift	0.10%	0.54%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.05	0.07	0.06
Alternative Specification Abs Diff **Final Zero**	0.07	0.01	0.06
Alternative Specification Abs Diff **Initial Upscale**	0.25	0.15	0.03
Alternative Specification Abs Diff **Final Upscale**	0.27	0.20	0.04
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 11	**O_2**	**NOx**	**CO**
Raw Average	12.36	2.36	0.07
Corrected Average	12.31	2.31	0.17
Initial Zero	-0.08	-0.04	-0.07
Final Zero	-0.06	0.18	-0.13
Avg. Zero	-0.07	0.07	-0.10
Initial UpScale	12.01	4.89	5.04
Final UpScale	12.02	4.98	5.05
Avg. UpScale	12.02	4.94	5.05
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.33%	0.11%	-0.63%
Final Zero Bias	-0.24%	2.50%	-1.26%
Zero Drift	0.10%	2.39%	0.63%
Initial Upscale Bias	-1.29%	-2.17%	-0.42%
Final Upscale Bias	-1.24%	-1.20%	-0.32%
Upscale Drift	0.05%	0.98%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.07	0.01	0.06
Alternative Specification Abs Diff **Final Zero**	0.05	0.23	0.12
Alternative Specification Abs Diff **Initial Upscale**	0.27	0.20	0.04
Alternative Specification Abs Diff **Final Upscale**	0.26	0.11	0.03
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

RATA - FIELD DATA SHEET

AIR HYGIENE

Company:	CIS
Location:	Cricket Valley
Date:	2/25/20 Project Code: 20-CIS-A-CricketValley
Unit Make and Model:	7F-05
Unit Number:	U-00002
Serial Number:	
Data Recorded By:	MA
Tested With AHI Unit(s):	Truck(s): 176 Trailer(s): 215
LDEQ Warmup/Cal Req:	On (Day/Time): 2/25/20 Cal (Day/Time): 5:00

Stack Dia. = 228
Measured By: RW
Measured With: Laser
*Start

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0072434	→	
	Mid	CC722590	EB0065464	3
	High	CC721614	EB00B492	

NH3

CYLINDER SERIAL NUMBERS		~~THC~~	CO_2	SO_2
	Low	EB0065964		
	Mid			
	High			

RUN INFORMATION	Run #1	Run #2	Run #3	Run #4	Run #5	Run #6	Run #7	Run #8	Run #9	Run #10	Run #11	Run #12
Time Start (hh:mm:ss)	11:46:22	12:32:28	13:07:58	13:36:28	14:15:28	14:46:28	15:17:28	15:47:28	16:20:28	16:51:28	17:27:28	
Time Stop (hh:mm:ss)	11:53:28	12:52:58	13:27:58	13:56:58	14:35:58	15:06:58	15:37:58	16:07:58	16:40:58	17:11:58	18:17:58	
Rated Power (MW or hp)	12:13:58											
Actual Power (MW or hp)												
Barometric Pressure (In. Hg)	29.33	29.36	29.34	29.33	29.34	29.33	29.33	29.33	29.33	29.34	29.37	
Ambient Temperature (°F)	~~53.5~~ 54.8	55.3	55.1	55.5	59.0	55.7	~~53.8~~ 55.8	55.1	54.5	53.5	51.0	
Relative Humidity (%)	50.8	50.6	48.6	47.5	44.7	48.0	50.1	50.9	53.5	56.8	75.7	
CEMS DATA for O_2												
CEMS DATA for NOx												
CEMS DATA for CO												
CEMS DATA for SO_2												

CALIBRATION	O_2		NOx		CO		SO_2	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0.0	-.01	0.0	-.05	0.0	-.01		
Low Gas	11.47	12.28	4.91	5.09	5.09	5.08		
Mid Gas	21.0	21.25	9.20	9.28	9.50	9.62		
High Gas								

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	1.40
NOx Reading (ppm)	48.79
Cylinder Num	EB009843

BIAS	O_2		NOx		CO		SO_2	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Run #1	-.03	11.99	.02	4.93	.05	5.13		
Run #1 / Run #2	-.05	12.02	-.03	4.83	-.04	5.14		
Run #2 / Run #3	0.0	12.02	-.35	4.94	-.04	5.09		
Run #3 / Run #4	-.04	12.01	-.01	4.92	-.04	5.08		
Run #4 / Run #5	-.02	12.05	.06	4.96	-.05	5.03		
Run #5 / Run #6	-.06	12.02	.02	4.92	-.11	5.07		
Run #6 / Run #7	-.06	12.01	.06	4.94	-.07	5.09		
Run #7 / Run #8	-.04	12.03	.01	4.94	-.09	5.08		
Run #8 / Run #9	-.06	12.03	.02	4.94	-.07	5.05		
Run #9 / Run #10	-.03	12.01	-.04	4.89	-.07	5.04		
Run #10 / Run #11	-.06	12.02	.18	4.98	-.13	5.05		
Run #11 / Run #12								
Run #12 Final								
Bias Gas Actual Conc.		11.97		4.91		5.09		

REPORT INFORMATION	INSTRUMENT	SERIAL #
O_2	SERVO 1440	02-0021
NOx	ThermO 42C	NX-003
CO	Enst-co 300 ThermO 48C	
~~THC~~MS	MKS	EF-0008
CO_2		
SO_2		

RESPONSE TIME	TIME (hh:mm)	RESP (min)
Gas Inject	/ /	
1st Inst. @ 95%	/ /	/ /
2nd Inst. @ 95%	/ /	/ /
3rd Inst. @ 95%	/ /	/ /

Signature

APPENDIX E

STRATIFICATION TEST DATA

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric (GE) 7F.05 Combustion Turbine
Location	Dover Plains, New York

Test Information	
Date	02/25/20
Project #	cis-19-cricketvalley.ny-start#1
Unit Number	U-00002
Load	Base Load
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)**	☐ Part 60 ☑ Part 75	

Created with Traverse-AHI v20190211


METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.*
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2

*assume 8 in. reference (must be measured and verified in field)


Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points Comp Stratification	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
					points


[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	6:14:22	**Run End**	7:12:22

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	4.00	6:14:22	6:18:22	13.43	0.75%	1.52	4.45%
D-2	4.00	6:18:22	6:22:22	13.40	0.52%	1.50	5.70%
D-1	4.00	6:22:22	6:26:22	13.39	0.45%	1.48	6.96%
C-3	8.00	6:26:22	6:34:22	13.32	0.07%	1.49	6.33%
C-2	4.00	6:30:22	6:34:22	13.31	0.15%	1.49	6.33%
C-1	4.00	6:34:22	6:38:22	13.31	0.15%	1.58	0.68%
B-3	10.00	6:38:22	6:48:22	13.47	1.05%	1.47	7.59%
B-2	4.00	6:48:22	6:52:22	13.45	0.90%	1.45	8.85%
B-1	4.00	6:52:22	6:56:22	13.43	0.75%	1.49	6.33%
A-3	8.00	6:56:22	7:04:22	13.03	**2.25%**	1.91	**20.07%**
A-2	4.00	7:04:22	7:08:22	13.21	0.90%	1.91	**20.07%**
A-1	4.00	7:08:22	7:12:22	13.21	0.90%	1.80	13.09%
Average				13.33		1.59	

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	6:14:22	**Run End**	7:12:22

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	2.25 % for O_2
Maximum Pollutant Conc. Diff.	0.32 ppm for NOx
Maximum Diluent Conc. Diff.	0.30 % for O_2
Stratification Conclusions	
Comparison	at least one diluent/pollutant
Stack Diameter	D > 93.6 in.


Under Part 75 criteria at least one measured pollutant or diluent demonstrates a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type

- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

- ☐ Use 6.5.6.3(a) points?
- ☐ 6.5.6(b)(2) alt. points could apply



this page intentionally left blank
end of report

APPENDIX 7

FUEL FLOWMETER ACCURACY TEST/PRIMARY ELEMENT VISUAL INSPECTION DOCUMENTATION

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00002 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 25, 2020

Report Date: March 11, 2020



Corporate Headquarters
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012

AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

Remote Testing Offices
Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00002 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
FEBRUARY 25, 2020

Prepared and Reviewed by:

Logan K. Tsotsoros

Logan Tsotsoros
AHU Support Staff

Gavin Dolsky

Gavin Dolsky, QI
Staff Engineer – Report Manager

I, _____

Matt McBride, QSTI
Sr. Project Manager
certify that this testing was conducted and
this report was created in conformance
with the requirements of ASTM D7036

(this page intentionally left blank)

Table of Contents

1.0 INTRODUCTION 1

1.1 TEST PURPOSE AND OBJECTIVES 1

1.2 SUMMARY OF TEST PROGRAM 2

1.2.1 Participating Organizations 2
1.2.2 Industry 2
1.2.3 Air Permit and Federal Requirements 2
1.2.4 Plant Location 2
1.2.5 Equipment Tested 2
1.2.6 Emission Points 2
1.2.7 Emission Parameters Measured 2
1.2.8 Date of Emission Test 2
1.2.9 Federal Certifications 3

1.3 KEY PERSONNEL 3

2.0 SUMMARY OF TEST RESULTS 3

3.0 SOURCE OPERATION 5

3.1 PROCESS DESCRIPTION 5

3.2 SAMPLING LOCATION 5

4.0 SAMPLING AND ANALYTICAL PROCEDURES 5

4.1 TEST METHODS 5

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS 6

APPENDICES

Appendix A Test Results and Calculations

Appendix B CEMS and Reference Method Data

Appendix C Calibration Gas Certifications

Appendix D Quality Assurance and Quality Control Data

Appendix E Stratification Test Data

Relative Accuracy Test Audit
General Electric, 7F.05, Unit #U-00002 CEMS
Cricket Valley Energy Center LLC
Cricket Valley Energy Center
Dover Plains, New York
February 25, 2020

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Relative Accuracy Test Audit (RATA) for nitrogen oxides (NOx), carbon monoxide (CO), ammonia (NH_3), and oxygen (O_2) from the exhaust of the General Electric, 7F.05, Unit #U-00002 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on February 25, 2020.

The accumulated data from the RATA provides the figures for evaluating the acceptability of the operation of the on-site continuous emission monitoring system (CEMS) for the monitoring of NOx, CO, NH_3, and O_2 from the General Electric, 7F.05, Unit #U-00002 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to perform the initial certification RATA on the CEMS that serves the General Electric, 7F.05, Unit #U-00002 for Cricket Valley Energy Center LLC at the Cricket Valley Energy Center in Dover Plains, New York. Reference method (RM) testing followed the Code of Federal Regulations (CFR), Title 40 (40 CFR), Part 60 (40 CFR 60), Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320. RM values are compared with the on-site CEMS to document performance as required in the 40 CFR 60, Appendix B, Performance Specifications (PS) and 40 CFR 75 Appendix A and B. All relative accuracies were established on-site and were governed by the following sets of rules:

In accordance with 40 CFR 60, Appendix B, PS 2, Section 13.2, the NOx and NH_3 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent when average emissions during the test are greater than 50 percent of the emission standard or alternative relative accuracy (ARA) does not exceed 10.0 percent when the average emissions during the test are less than 50 percent of the emission standard. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

In accordance with 40 CFR 75, Appendix A, Section 3.3.2(a) and (b), the NOx RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and reference method (RM) values does not exceed 0.020 lb/MMBtu. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (f), and Appendix B, Figure 2, the NOx RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and RM values does not exceed 0.015 lb/MMBtu. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 3, Section 13.2, the O_2 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent or if the average difference between the CEMS and reference method (RM) values does not exceed plus or minus 1.0 percent of the measured value.

In accordance with 40 CFR 60, Appendix B, PS 4 and 4A, Sections 13.2 of each, the CO relative accuracy (RA) test results are acceptable if the RA does not exceed 10.0 percent, if the average difference between the CEMS and reference method (RM) values plus the 2.5 percent confidence coefficient (2.5%CC) does not exceed 5.0 parts per million (ppm), or if the alternative relative accuracy (ARA) does not exceed 5.0 percent. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations
- New York State Department of Environmental Conservation (NYSDEC)
- Cricket Valley Energy Center LLC
- Custom Instrumentation Services Corporation (CiSCO)
- Bechtel
- Air Hygiene

1.2.2 Industry
- Electric Utility / Electric Services

1.2.3 Air Permit and Federal Requirements
- Permit Number: 3-1326-00275/00009
- DEC ID: 3132600275
- 40 CFR 60, Appendix B, Performance Specifications (PS)
- 40 CFR 75, Appendix A and B

1.2.4 Plant Location
- Cricket Valley Energy Center in Dover Plains, New York
  - GPS Coordinates [Latitude 41.67616, Longitude -73.576914]
  - 2241 Route NY 22, Dover Plains, New York 12522
  - Federal Registry System / Facility Registry Service (FRS) No. – 110043333372
  - Source Classification Code (SCC) – 20100209

1.2.5 Equipment Tested
- General Electric, 7F.05, Unit #U-00002
  - NOx Analyzer (TAPI T200M, Serial No. 1013)
  - NH_3 Analyzer (TAPI T200M, Serial No. 1048)
  - CO Analyzer (TAPI T300M, Serial No. 519)
  - O_2 Analyzer (TAPI T803, Serial No. 129)

1.2.6 Emission Points
- Exhaust from the General Electric, 7F.05, Unit #U-00002
- For all gases, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00002, determined after conducting a stratification test

1.2.7 Emission Parameters Measured
- NOx
- CO
- NH_3
- O_2

1.2.8 Date of Emission Test
- February 25, 2020

1.2.9 Federal Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Cricket Valley Energy Center LLC:	Marc Duquette (mduquette@cricketvalley.com)	617-320-5219
Bechtel:	Ron Swanson (reswanson@bechtel.com)	571-262-0198
CiSCO:	Reginald Williams (rwilliams@ciscocems.com)	720-419-0177
Air Hygiene:	Matt McBride (mmcbride@airhygiene.com)	918-307-8865
Air Hygiene:	Swanson Bierman	918-307-8865
Air Hygiene:	Rob White	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Cricket Valley Energy Center LLC's General Electric, 7F.05, Unit #U-00002 located at the Cricket Valley Energy Center on February 25, 2020 are summarized in the following table and relate only to the items tested.

TABLE 2.1
SUMMARY OF GENERAL ELECTRIC, 7F.05, UNIT #U-00002 RATA RESULTS

Pollutant	Units	Criteria			Results	Passed / Test Frequency
		CFR	Specification / Section	Standard		
NOx	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 7.84%	YES / ANNUAL
NOx	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 7.32%	YES / ANNUAL
NOx	lb/MMBtu	Part 75	Appendix A, Section 3.3.2(a),(b) Appendix B, Section 2.3.1.2(a),(f), Figure 2	RA ≤ 10%, or if lb/MMBtu ≤ 0.200, d ≤ ±0.020 lb/MMBtu Annual Incentive RA ≤ 7.5%, or if lb/MMBtu ≤ 0.2, d ≤ ±0.015 lb/MMBtu	RA = 7.88% RM = 0.01 lb/MMBtu d = 0.000 lb/MMBtu BAF=1.000	YES / ANNUAL
O_2	%vd	Part 60	Appendix B, Performance Specification 3, Section 13.2	RA ≤ 20%, or d ≤ ±1.0%	RA = 1.70% d = 0.2 %	YES / ANNUAL
CO	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	RA = 87.96% |d|+2.5%CC = 0.1 ppm	YES / ANNUAL
CO	lb/hr	Part 60	Appendix B, Performance Specification 4, 4A Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 lb/hr, or ARA ≤ 5%	RA = 98.88% |d|+2.5%CC = 0.1 ppm (|d|+2.5%CC = 0.7 lb/hr)	YES / ANNUAL
NH_3	ppmvd@15%O_2	Assumed Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	ARA = 4.38%	YES / ANNUAL
NH_3	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	ARA = 6.50%	YES / ANNUAL
Load	MW	Part 60	Appendix B, Performance Specifications	> 50% max load	354.2	WITHIN TOLERANCE
Load	MW	Part 75	Appendix A and B	normal load range	354.2	WITHIN TOLERANCE

Notes: RA = relative accuracy, ARA = alternative relative accuracy, RM = reference method value, d = difference between RM and CEMS value, CC = confidence coefficient, v = velocity, BAF = bias adjustment factor

The RATA passed for all pollutants (NOx, CO, NH_3, and O_2) in all units (ppm@15%O_2, lb/hr, lb/MMBtu, and %) under all 40 CFR 60 and 40 CFR 75 criteria.

Specifically, NOx in units of ppm@15%O_2 and lb/hr, passed 40 CFR 60 criteria with an RA less than 20 percent. NOx in units of lb/MMBtu passed the 40 CFR 75 alternative annual incentive criteria with an emissions rate of less than 0.200 lb/MMBtu and a difference between the RM and CEMS analyzers of less than 0.015 lb/MMBtu. Also the Bias Adjustment Factor test resulted in an adjustment factor equal to 1.0 (no adjustment required). O_2 in units of % passed the 40 CFR 60 criteria with an RA less than 20 percent. CO in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 alternative criteria with a concentration difference between the RM and CEMS analyzers plus the confidence coefficient of less than 5 ppm and 5 lb/hr respectively. NH_3 in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 criteria with an RA less than 20 percent.

Unit load was within the 40 CFR 60 required criteria of greater than 50 percent of the maximum load and also fell within the normal load criteria as defined by the plants Quality Control and Monitoring Plan which defined the upper and lower boundary on the unit and the normal and secondary normal load ranges.

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

Cricket Valley Energy Center LLC (CVEC) owns and operates the Cricket Valley Energy Center located at 2241 ST RTE 22 in Dover Plains, New York. Located on the Cricket Valley Energy Center are three General Electric (GE) 7F.05 Combustion Turbine Generators (CTGs), designated as U-00001, U-00002, and U-0003, and each unit is equipped with one heat recovery steam generator (HRSG) with supplemental duct firing. Each unit is rated at 381 megawatts (MW). The nominal MW per unit as per the NYSDEC Permit ID 3-1326-00275/00009 is identified as 333 MW.

A single, dedicated dry extraction based continuous emissions monitoring system (CEMS) is installed on each unit. The CEMS configurations include nitrogen oxide (NOx) analyzers, ammonia (NH_3) analyzers, carbon monoxide (CO) analyzers, diluent gas oxygen (O_2) analyzers, and data acquisition and handling systems (DAHS).

3.2 SAMPLING LOCATION

The CTG stack is vertical, circular, and measures 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 265.8 ft above grade level with an exit elevation of approximately 282.5 ft above grade level. The test ports are located approximately 70.8 ft (850 inches) downstream and approximately 16.7 ft (200.4 inches) upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by Cricket Valley Energy Center LLC. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test. During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the General Electric, 7F.05, Unit #U-00002 at the Cricket Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on February 25, 2020.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Oxygen	EPA Method 3A	Paramagnetic Cell
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor
Ammonia and Moisture	EPA Method 320	Fourier Transform Infrared

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory / portable analyzer via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer, interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations. Spectral data was analyzed by the MKS MG2000 software.

Eleven test runs of approximately 21 minutes each were conducted on the General Electric, 7F.05, Unit #U-00002 for NOx, CO, NH_3, and O_2.

The stack gas analysis for O_2 concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O_2 analyzer uses a paramagnetic cell detector.

EPA Method 7E was used to determine concentrations of NOx. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO_2 in nitrogen certified gas cylinder was used to verify at least a 90 percent NO_2 conversion on the day of the test.


CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

An MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer, or equivalent, was used for NH_3 and H_2O analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm^{-1}. The system employed a silicon carbide infrared source at 1200ºC, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191ºC. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 4.0 liters per minute, the sample gas in the cell is refreshed approximately four times each minute. Interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations.


TABLE 4.2
ANALYTICAL INSTRUMENTATION

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NOx	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO_2 to NO. Chemiluminescence of reaction of NO with O_3. Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
NH_3 and H_2O	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
O_2	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

COPYRIGHT © 2011 AIR HYGIENE INTERNATIONAL, INC.



LEGEND
- Heated Teflon Tubing (pre-conditioned sample)
- Unheated Teflon Tubing (conditioned sample)
- Diluted Calibration Gas
- Calibration Gas
- Electronic Input/Output



PROCESS INLET OR 2ND STACK

dual line heated sample umbilical

STACK EXHAUST

TEST TRAILER EXTERIOR

TEST TRAILER INTERIOR


DATA RECORDER



COMPUTER




GAS CONDITIONER



dual line heated sample umbilical

MOBILE SECONDARY ANALYZERS

MANIFOLD





GAS DILUTER

THC, VOC



O_2, CO_2, NOx, CO, SO_2



HOT/WET ANALYZERS
COLD/DRY ANALYZERS




COLD/DRY ANALYZERS HOT/WET



O_2, CO_2, NOx, CO, SO_2

FLOW CONTROL MANIFOLD





FTIR


THC, VOC



CONDITIONER

VENT

CALIBRATION/ BIAS GAS BOTTLES



VENT

FIXED PRIMARY ANALYZERS

Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.

AIR HYGIENE

Figure 4.1
EMISSIONS TESTING LAB

1600 W Tacoma Street
Broken Arrow, Oklahoma 74012
www.airhygiene.com
(888) 461-8778

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1:
EMISSIONS TESTING SCHEDULE

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
U-00002	Base Load	Stratification Test	1	02/25/20	6:14:22	7:12:22	DAHS
U-00002	Base Load	Gas RATA	1	02/25/20	11:53:28	12:13:58	DAHS
U-00002	Base Load	Gas RATA	2	02/25/20	12:32:28	12:52:58	DAHS
U-00002	Base Load	Gas RATA	3	02/25/20	13:07:28	13:27:58	DAHS
U-00002	Base Load	Gas RATA	4	02/25/20	13:36:28	13:56:58	DAHS
U-00002	Base Load	Gas RATA	5	02/25/20	14:15:28	14:35:58	DAHS
U-00002	Base Load	Gas RATA	6	02/25/20	14:46:28	15:06:58	DAHS
U-00002	Base Load	Gas RATA	7	02/25/20	15:17:28	15:37:58	DAHS
U-00002	Base Load	Gas RATA	8	02/25/20	15:47:28	16:07:58	DAHS
U-00002	Base Load	Gas RATA	9	02/25/20	16:20:28	16:40:58	DAHS
U-00002	Base Load	Gas RATA	10	02/25/20	16:51:28	17:11:58	DAHS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
O_2 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(%vd)	(%vd)	(diff)	($diff^2$)
1	11:53 - 12:13	NO	346.6	13.36	13.04		
2	12:32 - 12:52	YES	345.9	13.25	13.06	0.19	0.04
3	13:07 - 13:27	YES	345.4	13.29	13.07	0.22	0.05
4	13:36 - 13:56	NO	345.6	11.85	13.07		
5	14:15 - 14:35	YES	345.4	13.30	13.06	0.24	0.06
6	14:46 - 15:06	YES	345.5	13.25	13.07	0.18	0.03
7	15:17 - 15:37	YES	345.3	13.27	13.06	0.21	0.04
8	15:47 - 16:07	YES	345.8	13.25	13.05	0.20	0.04
9	16:20 - 16:40	YES	373.2	12.43	12.23	0.20	0.04
10	16:51 - 17:11	YES	378.1	12.29	12.11	0.18	0.03
11	17:57 - 18:17	YES	379.9	12.31	12.08	0.23	0.05
12		NO					
	Total		**3204.5**	**116.63**	**114.79**	**1.84**	**0.38**
	Average		**356.1**	**12.96**	**12.75**	**0.20**	

Number of Runs	9
Standard Deviation	0.02
T-value	2.306
Confidence Coefficient	0.02

Average Difference =	**0.2**
Relative Accuracy =	**1.7%**

Part 60, Appendix B, Performance Specification 3,
13.2 CEMS Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent of the mean value of the reference method (RM) data. The results are also acceptable if the absolute value of the difference between the mean RM value and the mean CEMS value is less than or equal to 1.0 percent O2 (or CO2).

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:53 - 12:13	YES	346.6	1.58	1.70	-0.12	0.02
2	12:32 - 12:52	YES	345.9	1.54	1.65	-0.11	0.01
3	13:07 - 13:27	NO	345.4	1.55	1.45		
4	13:36 - 13:56	YES	345.6	1.58	1.68	-0.10	0.01
5	14:15 - 14:35	YES	345.4	1.50	1.57	-0.07	0.00
6	14:46 - 15:06	NO	345.5	1.42	1.50		
7	15:17 - 15:37	YES	345.3	1.51	1.60	-0.09	0.01
8	15:47 - 16:07	YES	345.8	1.58	1.71	-0.13	0.02
9	16:20 - 16:40	YES	373.2	1.65	1.77	-0.12	0.02
10	16:51 - 17:11	YES	378.1	1.58	1.70	-0.12	0.01
11	17:57 - 18:17	YES	379.9	1.59	1.70	-0.11	0.01
12		NO					
	Total		**3205.8**	**14.10**	**15.08**	**-0.98**	**0.11**
	Average		**356.2**	**1.57**	**1.68**	**-0.11**	

Number of Runs	9
Standard Deviation	0.02
T-value	2.306
Confidence Coefficient	0.01

Relative Accuracy = 7.8%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:53 - 12:13	YES	346.6	0.11	0.28	-0.17	0.03
2	12:32 - 12:52	NO	345.9	0.35	0.09		
3	13:07 - 13:27	YES	345.4	0.13	0.17	-0.04	0.00
4	13:36 - 13:56	NO	345.6	0.51	0.34		
5	14:15 - 14:35	YES	345.4	0.13	0.26	-0.13	0.02
6	14:46 - 15:06	YES	345.5	0.16	0.07	0.09	0.01
7	15:17 - 15:37	YES	345.3	0.14	0.07	0.07	0.00
8	15:47 - 16:07	YES	345.8	0.14	0.04	0.10	0.01
9	16:20 - 16:40	YES	373.2	0.11	0.00	0.11	0.01
10	16:51 - 17:11	YES	378.1	0.11	0.00	0.11	0.01
11	17:57 - 18:17	YES	379.9	0.12	0.02	0.10	0.01
12		NO					
	Total		**3205.2**	**1.15**	**0.91**	**0.24**	**0.11**
	Average		**356.1**	**0.13**	**0.10**	**0.03**	

Number of Runs	9
Standard Deviation	0.11
T-value	2.306
Confidence Coefficient	0.09

Relative Accuracy =	**88.0%**
|d (difference in ppm)| + CC =	**0.11**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	11:53 - 12:13	YES	346.6	0.66	0.71	-0.05	0.00
2	12:32 - 12:52	YES	345.9	0.85	0.73	0.12	0.02
3	13:07 - 13:27	YES	345.4	0.87	1.02	-0.15	0.02
4	13:36 - 13:56	YES	345.6	0.68	0.74	-0.06	0.00
5	14:15 - 14:35	YES	345.4	0.87	0.83	0.04	0.00
6	14:46 - 15:06	YES	345.5	0.66	0.87	-0.21	0.04
7	15:17 - 15:37	YES	345.3	0.66	0.81	-0.15	0.02
8	15:47 - 16:07	YES	345.8	0.61	0.94	-0.33	0.11
9	16:20 - 16:40	NO	373.2	0.48	0.82		
10	16:51 - 17:11	NO	378.1	0.60	0.99		
11	17:57 - 18:17	YES	379.9	1.53	1.00	0.53	0.28
12		NO					
	Total		**3145.4**	**7.40**	**7.65**	**-0.25**	**0.50**
	Average		**349.5**	**0.82**	**0.85**	**-0.03**	

Number of Runs	9
Standard Deviation	0.25
T-value	2.306
Confidence Coefficient	0.19

Relative Accuracy =	**26.6%**
Applicable Standard =	**5.00**
Alternative Relative Accuracy =	**4.4%**

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	14.14	15.13	-0.99	0.97
2	12:32 - 12:52	YES	345.9	13.77	14.65	-0.88	0.78
3	13:07 - 13:27	NO	345.4	13.85	12.89		
4	13:36 - 13:56	YES	345.6	14.11	14.90	-0.79	0.62
5	14:15 - 14:35	YES	345.4	13.41	13.95	-0.54	0.30
6	14:46 - 15:06	NO	345.5	12.65	13.27		
7	15:17 - 15:37	YES	345.3	13.45	14.13	-0.68	0.47
8	15:47 - 16:07	YES	345.8	14.15	15.18	-1.03	1.05
9	16:20 - 16:40	YES	373.2	16.10	17.22	-1.12	1.26
10	16:51 - 17:11	YES	378.1	15.67	16.80	-1.13	1.28
11	17:57 - 18:17	YES	379.9	15.73	16.73	-1.00	1.01
12		NO					
	Total		**3205.8**	**130.52**	**138.69**	**-8.17**	**7.74**
	Average		**356.2**	**14.50**	**15.41**	**-0.91**	

Number of Runs	9
Standard Deviation	0.20
T-value	2.306
Confidence Coefficient	0.15

Relative Accuracy = 7.3%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	0.58	1.15	-0.57	0.32
2	12:32 - 12:52	NO	345.9	1.93	0.38		
3	13:07 - 13:27	YES	345.4	0.69	0.91	-0.22	0.05
4	13:36 - 13:56	NO	345.6	2.76	0.26		
5	14:15 - 14:35	YES	345.4	0.72	0.20	0.52	0.27
6	14:46 - 15:06	YES	345.5	0.89	0.37	0.52	0.28
7	15:17 - 15:37	YES	345.3	0.74	0.31	0.43	0.19
8	15:47 - 16:07	YES	345.8	0.77	0.21	0.56	0.31
9	16:20 - 16:40	YES	373.2	0.64	0.00	0.64	0.41
10	16:51 - 17:11	YES	378.1	0.68	0.00	0.68	0.47
11	17:57 - 18:17	YES	379.9	0.71	0.01	0.70	0.49
12		NO					
	Total		**3205.2**	**6.43**	**3.16**	**3.27**	**2.78**
	Average		**356.1**	**0.71**	**0.35**	**0.36**	

Number of Runs	9
Standard Deviation	0.45
T-value	2.306
Confidence Coefficient	0.34

Relative Accuracy =	**98.9%**
|d (difference in lb/hr)| + CC =	**0.71**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	2.20	2.40	-0.20	0.04
2	12:32 - 12:52	YES	345.9	2.83	2.44	0.39	0.15
3	13:07 - 13:27	YES	345.4	2.88	3.38	-0.50	0.25
4	13:36 - 13:56	YES	345.6	2.26	2.46	-0.20	0.04
5	14:15 - 14:35	YES	345.4	2.87	2.71	0.16	0.02
6	14:46 - 15:06	YES	345.5	2.19	2.87	-0.68	0.46
7	15:17 - 15:37	YES	345.3	2.17	2.64	-0.47	0.22
8	15:47 - 16:07	YES	345.8	2.01	2.39	-0.38	0.14
9	16:20 - 16:40	NO	373.2	1.73	2.91		
10	16:51 - 17:11	NO	378.1	2.20	3.59		
11	17:57 - 18:17	YES	379.9	5.62	3.60	2.02	4.10
12		NO					
	Total		**3145.4**	**25.03**	**24.89**	**0.14**	**5.42**
	Average		**349.5**	**2.78**	**2.77**	**0.02**	

Number of Runs	9
Standard Deviation	0.82
T-value	2.306
Confidence Coefficient	0.63

Relative Accuracy =	**23.3%**
Applicable Standard* =	**9.98**
Alternative Relative Accuracy =	**6.5%**

* Value calculated using the Applicable Standard of 5 ppm@15%O_2 and the average stack flow and O_2 concentration for the first three runs.

$$NH_3\ {}^{lb}/_{hr} = \frac{(20.9-15)*C_{adj}*Q_s*MW}{(20.9-\%O_2)*10^6*G} = \frac{(20.9-15)*5*58{,}140{,}133*17.03}{(20.9-13.3)*10^6*385.23} = 9.98$$

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/MMBtu)	(lb/MMBtu)	(diff)	($diff^2$)
1	11:53 - 12:13	YES	346.6	0.0058	0.0062	-0.0004	0.0000
2	12:32 - 12:52	YES	345.9	0.0057	0.0061	-0.0004	0.0000
3	13:07 - 13:27	NO	345.4	0.0057	0.0053		
4	13:36 - 13:56	YES	345.6	0.0058	0.0062	-0.0004	0.0000
5	14:15 - 14:35	YES	345.4	0.0055	0.0058	-0.0003	0.0000
6	14:46 - 15:06	NO	345.5	0.0052	0.0055		
7	15:17 - 15:37	YES	345.3	0.0056	0.0059	-0.0003	0.0000
8	15:47 - 16:07	YES	345.8	0.0058	0.0063	-0.0005	0.0000
9	16:20 - 16:40	YES	373.2	0.0061	0.0065	-0.0004	0.0000
10	16:51 - 17:11	YES	378.1	0.0058	0.0063	-0.0005	0.0000
11	17:57 - 18:17	YES	379.9	0.0058	0.0062	-0.0004	0.0000
12		NO					
	Total		**3205.8**	**0.0519**	**0.0555**	**-0.0036**	**0.0000**
	Average		**356.2**	**0.0058**	**0.0062**	**-0.0004**	

Number of Runs	9
Standard Deviation	0.0001
T-value	2.306
Confidence Coefficient	0.0001

Relative Accuracy = 7.88%

If the mean difference is less than or equal to the absolute value of the confidence coefficient, then the Bias Test passes and the bias adjustment factor is not applicable.

Mean Difference =	-0.0004
Confidence Coefficient =	0.0001

BAF = 1 + (abs. value mean difference/avg. CEMS reading)

Average CEMS Reading =	0.0062
BAF =	**1.000**

Part 75, Appendix A,
3.3.2 Relative Accuracy for NOX-Diluent Continuous Emission Monitoring Systems
(a) The relative accuracy for NOX-diluent continuous emission monitoring systems shall not exceed 10.0 percent.
(b) For affected units where the average of the reference method measurements of NOX emission rate (this means lb/MMBtu) during the relative accuracy test audit is less than or equal to 0.200 lb/mmBtu, the difference between the mean value of the continuous emission monitoring system measurements and the reference method mean value shall not exceed ±0.020 lb/mmBtu, wherever the relative accuracy specification of 10.0 percent is not achieved.

7.6.5 Bias Adjustment
(b) For single-load RATAs of SO2 pollutant concentration monitors, NOX concentration monitoring systems, and NOX-diluent monitoring systems and for the single-load flow RATAs required or allowed under section 6.5.2 of this appendix and sections 2.3.1.3(b) and 2.3.1.3(c) of Appendix B to this part, the appropriate BAF is determined directly from the RATA results at normal load, using Equation A-12. Notwithstanding, when a NOX concentration CEMS or an SO2 CEMS or a NOX-diluent CEMS installed on a low-emitting affected unit (i.e., average SO2 or NOX concentration during the RATA &IE; 250 ppm or average NOX emission rate &IE; 0.200 lb/mmBtu) meets the normal 10.0 percent relative accuracy specification (as calculated using Equation A-10) or the alternate relative accuracy specification in section 3.3 of this appendix for low-emitters, but fails the bias test, the BAF may either be determined using Equation A-12, or a default BAF of 1.111 may be used.

Part 75, Appendix B,
2.3.1.2 Reduced RATA Frequencies. Relative accuracy test audits of primary and redundant backup SO2 pollutant concentration monitors, CO2 pollutant concentration monitors (including O2 monitors used to determine CO2 emissions), CO2 or O2 diluent monitors used to determine heat input, moisture monitoring systems, NOX concentration monitoring systems, flow monitors, NOX-diluent monitoring systems or SO2-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:
(a) The relative accuracy during the audit of an SO2 or CO2 pollutant concentration monitor (including an O2 pollutant monitor used to measure CO2 using the procedures in appendix F to this part), or of a CO2 or O2 diluent monitor used to determine heat input, or of a NOX concentration monitoring system, or of a NOX-diluent monitoring system, or of an SO2-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(f) For units with low NOX emission rates (average NOX emission rate measured by the reference method during the RATA ≤ 0.200 lb/mmBtu), when a NOX-diluent continuous emission monitoring system fails to achieve a relative accuracy ≤ 7.5 percent, but the monitoring system mean value from the RATA, calculated using Equation A-7 in appendix A to this part, is within ± 0.015 lb/mmBtu of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO2 or NOX(3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO2-diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NOX-diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO2 or O2	7.5% < RA ≤ 10.0% or ± 1.0% CO2/O2(2)	RA ≤ 7.5% or ± 0.7% CO2/O2(2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H2O(2)	RA ≤ 7.5% or ± 1.0% H2O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO2 monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.
(2) The difference between monitor and reference method mean values applies to moisture monitors, CO2, and O2 monitors, low emitters, or low flow, only.
(3) A NOX concentration monitoring system used to determine NOX mass emissions under § 75.71.

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO_2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH_3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO_2 (lb/lb-mole) =	44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO_2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH_3 =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO_2 =	0.0000001142434

NOTE: units are lb/ppm*ft^3

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right)$$

2. Correction to % O_2, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}} \right)$$

3. Correction to % O_2 and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_O - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O_2 based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp \cdot hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} or \frac{E_{lb/hr} \times 453.6}{hp}$$

RATA SHEET CALCULATIONS

d = Reference Method Data - CEMS Data

S_d = Standard Deviation

CC = Confident Coefficient

n = number of runs

$t_{0.025}$ = 2.5 percent confidence coefficient T-values

RA = relative accuracy

ARA = alternative relative accuracy

BAF = Bias adjustment factor

n	t	n	t	n	t
2	12.706	7	2.447	12	2.201
3	4.303	8	2.365	13	2.179
4	3.182	9	2.306	14	2.160
5	2.776	10	2.262	15	2.145
6	2.571	11	2.228	16	2.131

1. Difference

$$d = \sum_{i=1}^{n} d_i$$

2. Standard Deviation

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \left[\frac{\left(\sum_{i=1}^{n} d_i \right)^2}{n} \right]}{n-1}}$$

3. Confident Coefficient

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$

4. Relative Accuracy

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$

5. Alternative Relative Accuracy

$$ARA = \frac{|d_{AVG}| + |CC|}{AS} \times 100$$

5. Bias Adjustment Factor

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right)$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO_2 to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H_2O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
$\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
$\%_{CO2d}$,$\%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g.,24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO_2 rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O_2.
E_{jo},E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft^3 = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
$\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
$\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = $2x10^4$ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p,L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
$\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
$M_{\%}$ = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)[1]
NCM = net Btu per SCF (constant based on compound)
$\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
$\%_{O2d}$, $\%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO2 emissions, percent.
$\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
$\%_{Sf}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
$\%S_p$, $\%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
$t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2}=CO_2 Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RHsp (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp}(lb/lb) = \left[\left(\frac{gr}{lb}\right) \times \frac{lb}{7000\ gr}\right]$$

RH_{sp}= 32.23 gr / lb x 1 lb / 7000 gr = 0.004604 lb H_2O / lb Air

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

ACE = (5.09 ppm - 4.91 ppm) / 9.20 ppm x 100 = 1.96 %

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS}\right) \times 100$$ Eq. 7E-2

SB = (4.93 ppm - 5.09 ppm) / 9.20 ppm x 100 = -1.74 %

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = \left|SB_{final} - SB_t\right|$$ Eq. 7E-4

D = | -2.83 % - -1.74 % | = 1.09 %

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs – Cdir| is ≤ 0.5 ppmv or if |Cs – Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = \left|C_S - C_{Dir}\right|$$ Eq. Section 13.2 and 13.3

SB / D_{Alt} = | 4.93 ppm - 5.09 ppm | = 0.16 ppm

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$ Eq. 7E-5b

C_{Gas} = (1.85 ppm - -0.26 ppm) (4.91 ppm / 4.88 ppm - -0.26 ppm) = 2.02 ppm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Stack Exhaust Flow (Q_S) - RM19

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000}\right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}}\right)$$

Note: Equation presented in EPA Emission Measurement Center (EMC), Frequently Asked Questions (FAQ) for Method 19

Q_S = 8,710.00 SCF/MMBtu x 2,317,550.00 SCF/hr x 1,050.00 Btu/SCF x MMBtu/10^6 Btu x [20.90% / (20.9% - 13.4 %)] = 58,713,359.00 SCFH

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_W = C_D \times (1 - B_{WS})$$

$$C_D = \frac{C_W}{1 - B_{WS}}$$ Eq. 7E-10

C_D = 1.85 ppmvw / (1 - 0.08) = 2.02 ppmvd or inversely, C_W = 2.02 ppmvd x (1 - 0.08) = 1.85 ppmvw

Diluent-Corrected Pollutant Concentration, O_2 Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O_2 Concentration. Calculate the O_2 corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}}\right)$$ Eq. 20-4

C_{adj} = 2.02 ppm x [(20.9% - 15.00 %) / (20.9% - 13.36 %)] = 1.58 ppm@15%O_2

Emissions Rate (lb/hr)

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

$E_{lb/hr}$ = 2.02 ppmvd / 10^6 ppm/part x 58,713,359 DSCFH x 46.01 lb/lb-mol / 385.23 SCF/lb-mol = 14.14 lb/hr

Emissions Rate (lb/MMBtu)

RM 19, (02-27-14), 12.2 Emission Rates of PM, SO_2, and NOx. Select from the following sections the applicable procedure to compute the PM, SO_2, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for NOx gas Run 1, if applicable)

Oxygen Based

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O_2 ($\%O_2$d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$ Eq. 19-1

$E_{lb/MMBtu}$ = 2.02 ppm x 8,710.00 SCF/MMBtu x 0.0000001194 lb/ppm*ft^3 x 20.9% / (20.9% - 13.36 %) = 0.006 lb/MMBtu

Conversion Constant

Convc for NOx

$$Conv_c(lb/ppm \cdot ft^3) = \frac{\frac{MW}{G}}{10^6}$$

$Conv_c$ = (46.01 lb/lb•mole x lb•mole/385.23 SCF) / 10^6 = 0.0000001194 lb/ppm-ft^3

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RATA RESULTS)

Difference (d)

40 CFR 75, App A, (12-17-09), 7.3.1 Arithmetic Mean. Calculate the arithmetic mean of the differences, d , of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$d = \sum_{i=1}^{n} d_i$$ Eq. A-7

d = 0.006 lb/MMBtu - 0.006 lb/MMBtu = 0.000 lb/MMBtu

Standard Deviation

40 CFR 75, App A, (12-17-09), 7.3.2 Standard Deviation. Calculate the standard deviation, Sd, of a data set as follows:
(calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \frac{\left[\left(\sum_{i=1}^{n} d_i\right)^2\right]}{n}}{n-1}}$$ Eq. A-8

$$S_d = \sqrt{\frac{0.000 \text{ lb/MMBtu}^2 - \frac{(-0.004 \text{ lb/MMBtu})^2}{9}}{9 - 1}} = 0.000 \text{ lb/MMBtu}$$

Confidence Coefficient

40 CFR 75, App A, (12-17-09), 7.3.3 Confidence Coefficient. Calculate the confidence coefficient (one-tailed), cc, of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$ Eq. A-9

CC = 2.306 x $\frac{0.000 \text{ lb/MMBtu}}{\sqrt{9}}$ = 0.000 lb/MMBtu

T-Values	n	2	3	4	5	6	7	8	9
	$t_{0.025}$	12.706	4.303	3.182	2.776	2.571	2.447	2.365	2.306

2.5 percent confidence coefficients

Relative Accuracy

40 CFR 75, App A, (12-17-09), 7.3.4 Relative Accuracy. Calculate the relative accuracy of a data set using the following equation. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$ Eq. A-10

RA = $\frac{|0.000 \text{ lb/MMBtu}| + |0.000 \text{ lb/MMBtu}|}{0.006 \text{ lb/MMBtu}}$ x 100 = 7.88 %

Bias Adjustment Factor (BAF)

40 CFR 75, App A, (12-17-09), 7.6.5 Bias Adjustment. (a) If the monitor or monitoring system fails to meet the bias test requirement, adjust the value obtained from the monitor using the following equation: (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}}\right)$$ Eq. A-12

d_{AVG}= 0.000 < |CC| = 0.000 ⇨ BAF = 1 + $\frac{|\quad| \text{ lb/MMBtu}}{\text{lb/MMBtu}}$ = 1.000 lb/MMBtu

Note: BAF only applies if the mean difference (d) is greater than the absolute value of the confidence coefficient.

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B

CEMS AND REFERENCE METHOD DATA

Cricket Valley Energy Center LLC

Air Permit Number:	3-1326-00275/00009
Plant Name or Location:	Cricket Valley Energy Center
Date:	February 25, 2020
Project Number:	cis-19-cricketvalley.ny-start#1
Manufacturer & Equipment:	General Electric
Model:	7F.05
Unit Number:	U-00002
Test Load:	Base Load
Tester(s) / Test Unit(s):	MM/215

		RUN										
	UNITS	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**10**	**11**
Start Time	hh:mm:ss	11:53:28	12:32:28	13:07:28	13:36:28	14:15:28	14:46:28	15:17:28	15:47:28	16:20:28	16:51:28	17:57:28
End Time	hh:mm:ss	12:13:58	12:52:58	13:27:58	13:56:58	14:35:58	15:06:58	15:37:58	16:07:58	16:40:58	17:11:58	18:17:58
Bar. Pressure	in. Hg	29.38	29.36	29.34	29.33	29.30	29.33	29.33	29.33	29.33	29.34	29.37
Amb. Temp.	°F	54	55	55	56	59	56	56	55	55	54	51
Rel. Humidity	%	51	51	49	48	45	48	50	51	54	57	76
Spec. Humidity	lb water / lb air	0.004604	0.004760	0.004540	0.004504	0.004816	0.004585	0.004805	0.004759	0.004894	0.005008	0.006092
Turbine Fuel Flow	SCFH	2,317,550	2,310,200	2,308,160	2,308,570	2,306,530	2,306,940	2,305,710	2,311,140	2,528,440	2,554,920	2,563,390
Total Fuel Flow	SCFH	2,317,550	2,310,200	2,308,160	2,308,570	2,306,530	2,306,940	2,305,710	2,311,140	2,528,440	2,554,920	2,563,390
Power Output	megawatts	346.6	345.9	345.4	345.6	345.4	345.5	345.3	345.8	373.2	378.1	379.9
O_2 CEMS Data	%vd	13.04	13.06	13.07	13.07	13.06	13.07	13.06	13.05	12.23	12.11	12.1
NOx CEMS Data	ppmvd@15%O_2	1.70	1.65	1.45	1.68	1.57	1.50	1.60	1.71	1.77	1.70	1.70
	lb/hr	15.13	14.65	12.89	14.90	13.95	13.27	14.13	15.18	17.22	16.80	16.73
	lb/MMBtu	0.0062	0.0061	0.0053	0.0062	0.0058	0.0055	0.0059	0.0063	0.0065	0.0063	0.0062
CO CEMS Data	ppmvd@15%O_2	0.28	0.09	0.17	0.34	0.26	0.07	0.07	0.04	0.00	0.00	0.02
	lb/hr	1.15	0.38	0.91	0.26	0.20	0.37	0.31	0.21	0.00	0.00	0.01
NH_3 CEMS Data	ppmvd@15%O_2	0.71	0.73	1.02	0.74	0.83	0.87	0.81	0.94	0.82	0.99	1.00
	lb/hr	2.40	2.44	3.38	2.46	2.71	2.87	2.64	2.39	2.91	3.59	3.60
NH_3 RM Data	ppmvd@15%O_2	0.66	0.85	0.87	0.68	0.87	0.66	0.66	0.61	0.48	0.60	1.53
	lb/hr	2.20	2.83	2.88	2.26	2.87	2.19	2.17	2.01	1.73	2.20	5.62

Created with Comp&RATA&Eng-AHI v20190529

CEMS AND REFERENCE METHOD DATA

CEMS Data
(provided by Cricket Valley Energy Center LLC)

Relative Accuracy Test Data
CEMS Results (NOx)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxides of Nitrogen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Chemiluminescence
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1013

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		1.70	15.13	0.0062
2	12:32 - 12:52	345.9		1.65	14.65	0.0061
3	13:07 - 13:27	345.4		1.45	12.89	0.0053
4	13:36 - 13:56	345.6		1.68	14.90	0.0062
5	14:15 - 14:35	345.4		1.57	13.95	0.0058
6	14:46 - 15:06	345.5		1.50	13.27	0.0055
7	15:17 - 15:37	345.3		1.60	14.13	0.0059
8	15:47 - 16:07	345.8		1.71	15.18	0.0063
9	16:20 - 16:40	373.2		1.77	17.22	0.0065
10	16:51 - 17:11	378.1		1.70	16.80	0.0063
11	17:57 - 18:17	379.9		1.70	16.73	0.0062
12						

Relative Accuracy Test Data
CEMS Results (CO)
General Electric, 7F.05, Unit #U-00002

Parameter:	Carbon Monoxide
Date of Test:	February 25, 2020
Reference Method:	EPA Method 10
CEMS Analyzer Type:	Infrared Absorption
Manufacturer:	TAPI
Model #:	T300M
Serial #:	519

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.28	1.15	
2	12:32 - 12:52	345.9		0.09	0.38	
3	13:07 - 13:27	345.4		0.17	0.91	
4	13:36 - 13:56	345.6		0.34	0.26	
5	14:15 - 14:35	345.4		0.26	0.20	
6	14:46 - 15:06	345.5		0.07	0.37	
7	15:17 - 15:37	345.3		0.07	0.31	
8	15:47 - 16:07	345.8		0.04	0.21	
9	16:20 - 16:40	373.2		0.00	0.00	
10	16:51 - 17:11	378.1		0.00	0.00	
11	17:57 - 18:17	379.9		0.02	0.01	
12						

Relative Accuracy Test Data
CEMS Results (NH_3)
General Electric, 7F.05, Unit #U-00002

Parameter:	Ammonia
Date of Test:	February 25, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Dual NOx w/ NH3 conversion
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1048

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.71	2.40	
2	12:32 - 12:52	345.9		0.73	2.44	
3	13:07 - 13:27	345.4		1.02	3.38	
4	13:36 - 13:56	345.6		0.74	2.46	
5	14:15 - 14:35	345.4		0.83	2.71	
6	14:46 - 15:06	345.5		0.87	2.87	
7	15:17 - 15:37	345.3		0.81	2.64	
8	15:47 - 16:07	345.8		0.94	2.39	
9	16:20 - 16:40	373.2		0.82	2.91	
10	16:51 - 17:11	378.1		0.99	3.59	
11	17:57 - 18:17	379.9		1.00	3.60	
12						

Relative Accuracy Test Data
CEMS Results (O_2)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxygen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 3A
CEMS Analyzer Type:	Paramagnetic Cell
Manufacturer:	TAPI
Model #:	T803
Serial #:	129

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	11:53 - 12:13	346.6	13.04
2	12:32 - 12:52	345.9	13.06
3	13:07 - 13:27	345.4	13.07
4	13:36 - 13:56	345.6	13.07
5	14:15 - 14:35	345.4	13.06
6	14:46 - 15:06	345.5	13.07
7	15:17 - 15:37	345.3	13.06
8	15:47 - 16:07	345.8	13.05
9	16:20 - 16:40	373.2	12.23
10	16:51 - 17:11	378.1	12.11
11	17:57 - 18:17	379.9	12.08
12			

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 11:53 AM thru 2/25/2020 12:13 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 11:53	2.29	1.72	0.0063	15.29	0.25	0.19	0.97	0.94	0.71
2/25 11:54	2.30	1.73	0.0064	15.54	0.26	0.20	0.97	0.93	0.70
2/25 11:55	2.29	1.72	0.0063	15.29	0.26	0.20	0.97	0.93	0.70
2/25 11:56	2.28	1.71	0.0063	15.24	0.26	0.20	0.97	0.94	0.71
2/25 11:57	2.27	1.70	0.0063	15.24	0.23	0.17	0.97	0.94	0.71
2/25 11:58	2.26	1.70	0.0062	14.99	0.21	0.16	0.97	0.94	0.71
2/25 11:59	2.26	1.70	0.0062	15.05	0.17	0.13	0.73	0.94	0.71
2/25 12:00	2.25	1.69	0.0062	14.99	0.19	0.14	0.73	0.95	0.71
2/25 12:01	2.24	1.68	0.0062	14.99	0.24	0.18	0.97	0.95	0.71
2/25 12:02	2.24	1.68	0.0062	15.05	0.22	0.17	0.97	0.95	0.71
2/25 12:03	2.25	1.69	0.0062	15.05	0.25	0.19	0.97	0.95	0.71
2/25 12:04	2.27	1.70	0.0063	15.29	0.27	0.20	1.21	0.95	0.71
2/25 12:05	2.28	1.71	0.0063	15.24	0.27	0.20	1.21	0.95	0.71
2/25 12:06	2.28	1.71	0.0063	15.24	0.30	0.23	1.21	0.94	0.71
2/25 12:07	2.28	1.71	0.0063	15.29	0.29	0.22	1.21	0.95	0.71
2/25 12:08	2.26	1.70	0.0062	14.99	0.32	0.24	1.21	0.95	0.71
2/25 12:09	2.24	1.68	0.0062	14.99	0.36	0.27	1.45	0.95	0.71
2/25 12:10	2.24	1.68	0.0062	14.99	0.41	0.31	1.69	0.94	0.71
2/25 12:11	2.24	1.68	0.0062	15.05	0.44	0.33	1.70	0.94	0.71
2/25 12:12	2.24	1.68	0.0062	14.99	0.39	0.29	1.69	0.94	0.71
2/25 12:13	2.25	1.69	0.0062	14.94	0.35	0.26	1.45	0.94	0.71
Average (all)	2.26	1.70	0.0062	15.13	0.28	0.21	1.15	0.94	0.71
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.24	1.68	0.0062	14.94	0.17	0.13	0.73	0.93	0.70
Maximum (all)	2.30	1.73	0.0064	15.54	0.44	0.33	1.70	0.95	0.71
Average (valid values only)	2.26	1.70	0.0062	15.13	0.28	0.21	1.15	0.94	0.71
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 11:53 AM thru 2/25/2020 12:13 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 11:53	2.43	13.04	23228.6	232.6	346.9
2/25 11:54	2.18	13.04	23228.6	232.5	346.7
2/25 11:55	2.18	13.04	23228.6	232.5	346.8
2/25 11:56	2.42	13.04	23142.9	232.4	346.7
2/25 11:57	2.42	13.04	23142.9	232.5	346.7
2/25 11:58	2.42	13.04	23142.9	232.6	346.8
2/25 11:59	2.43	13.04	23228.6	232.5	346.8
2/25 12:00	2.42	13.04	23142.9	232.5	346.8
2/25 12:01	2.42	13.04	23142.9	232.4	346.7
2/25 12:02	2.43	13.04	23228.6	232.5	346.8
2/25 12:03	2.43	13.04	23228.6	232.5	346.8
2/25 12:04	2.43	13.03	23228.6	232.4	346.8
2/25 12:05	2.42	13.04	23142.9	232.4	346.7
2/25 12:06	2.42	13.04	23142.9	232.4	346.7
2/25 12:07	2.43	13.05	23228.6	232.3	346.5
2/25 12:08	2.42	13.04	23142.9	232.2	346.5
2/25 12:09	2.42	13.04	23142.9	232.4	346.1
2/25 12:10	2.42	13.04	23142.9	232.3	346.4
2/25 12:11	2.43	13.05	23228.6	232.2	346.4
2/25 12:12	2.42	13.05	23142.9	232.0	346.1
2/25 12:13	2.41	13.05	23057.1	232.1	346.2
Average (all)	2.40	13.04	23175.5	232.4	346.6
Total (all)	--	--	--	--	--
Minimum (all)	2.18	13.03	23057.1	232.0	346.1
Maximum (all)	2.43	13.05	23228.6	232.6	346.9
Average (valid values only)	2.40	13.04	23175.5	232.4	346.6
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 12:32 PM thru 2/25/2020 12:52 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 12:32	2.28	1.71	0.0063	15.24	0.28	0.21	1.21	0.93	0.70
2/25 12:33	2.27	1.71	0.0063	15.24	0.25	0.19	0.97	0.93	0.70
2/25 12:34	2.26	1.70	0.0063	15.18	0.19	0.14	0.72	0.94	0.71
2/25 12:35	2.24	1.68	0.0062	14.99	0.16	0.12	0.73	0.94	0.71
2/25 12:36	2.24	1.69	0.0062	14.94	0.16	0.12	0.72	0.93	0.70
2/25 12:37	2.23	1.68	0.0062	14.94	0.20	0.15	0.72	0.94	0.71
2/25 12:38	2.23	1.68	0.0062	14.99	0.17	0.13	0.73	0.95	0.71
2/25 12:39	2.22	1.67	0.0062	14.99	0.12	0.09	0.48	0.95	0.71
2/25 12:40	2.24	1.69	0.0062	14.99	0.11	0.08	0.48	0.94	0.71
2/25 12:41	2.25	1.69	0.0062	14.99	0.07	0.05	0.24	0.94	0.71
2/25 12:42	2.26	1.70	0.0063	15.18	0.01	0.01	0.00	0.94	0.71
2/25 12:43	2.27	1.71	0.0063	15.24	0.01	0.01	0.00	0.94	0.71
2/25 12:44	2.27	1.71	0.0063	15.18	0.00	0.00	0.00	0.94	0.71
2/25 12:45	2.27	1.71	0.0063	15.18	0.00	0.00	0.00	0.93	0.70
2/25 12:46	2.28	1.72	0.0063	15.24	0.00	0.00	0.00	0.93	0.70
2/25 12:47	2.27	1.71	0.0063	15.24	0.00	0.00	0.00	0.95	0.71
2/25 12:48	2.18	1.64	0.0060	14.46	0.00	0.00	0.00	0.99	0.75
2/25 12:49	2.07	1.56	0.0057	13.73	0.00	0.00	0.00	1.02	0.77
2/25 12:50	1.96	1.48	0.0054	13.01	0.00	0.00	0.00	1.06	0.80
2/25 12:51	1.86	1.40	0.0052	12.53	0.09	0.07	0.48	1.11	0.84
2/25 12:52	1.79	1.35	0.0050	12.09	0.10	0.08	0.48	1.17	0.88
Average (all)	2.19	1.65	0.0061	14.65	0.09	0.07	0.38	0.97	0.73
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.79	1.35	0.0050	12.09	0.00	0.00	0.00	0.93	0.70
Maximum (all)	2.28	1.72	0.0063	15.24	0.28	0.21	1.21	1.17	0.88
Average (valid values only)	2.19	1.65	0.0061	14.65	0.09	0.07	0.38	0.97	0.73
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 12:32 PM thru 2/25/2020 12:52 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 12:32	2.18	13.05	23142.9	231.8	346.1
2/25 12:33	2.18	13.05	23142.9	231.7	345.9
2/25 12:34	2.41	13.05	23057.1	231.9	346.2
2/25 12:35	2.42	13.05	23142.9	231.5	345.7
2/25 12:36	2.41	13.06	23057.1	231.7	346.0
2/25 12:37	2.41	13.06	23057.1	231.5	345.7
2/25 12:38	2.42	13.06	23142.9	231.6	345.8
2/25 12:39	2.42	13.06	23142.9	231.6	345.8
2/25 12:40	2.42	13.06	23142.9	231.7	345.9
2/25 12:41	2.42	13.06	23142.9	231.6	345.8
2/25 12:42	2.41	13.06	23057.1	231.7	346.0
2/25 12:43	2.42	13.06	23142.9	231.4	345.7
2/25 12:44	2.41	13.06	23057.1	231.4	345.7
2/25 12:45	2.41	13.06	23057.1	231.5	345.8
2/25 12:46	2.42	13.06	23142.9	231.5	345.7
2/25 12:47	2.42	13.06	23142.9	231.6	345.9
2/25 12:48	2.41	13.06	23057.1	231.7	345.9
2/25 12:49	2.41	13.06	23057.1	231.6	345.8
2/25 12:50	2.65	13.06	23057.1	231.7	345.9
2/25 12:51	2.65	13.06	23057.1	231.5	345.7
2/25 12:52	2.90	13.06	23142.9	231.6	345.9
Average (all)	2.44	13.06	23102.0	231.6	345.9
Total (all)	--	--	--	--	--
Minimum (all)	2.18	13.05	23057.1	231.4	345.7
Maximum (all)	2.90	13.06	23142.9	231.9	346.2
Average (valid values only)	2.44	13.06	23102.0	231.6	345.9
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:07 PM thru 2/25/2020 1:27 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 13:07	1.93	1.45	0.0054	13.01	0.01	0.01	0.00	1.38	1.04
2/25 13:08	1.93	1.45	0.0054	13.01	0.01	0.01	0.00	1.36	1.02
2/25 13:09	1.92	1.44	0.0053	12.82	0.04	0.03	0.24	1.35	1.02
2/25 13:10	1.91	1.44	0.0053	12.77	0.04	0.03	0.24	1.34	1.01
2/25 13:11	1.90	1.43	0.0053	12.82	0.10	0.08	0.48	1.34	1.01
2/25 13:12	1.90	1.43	0.0053	12.77	0.14	0.11	0.48	1.33	1.00
2/25 13:13	1.90	1.43	0.0053	12.77	0.20	0.15	0.72	1.33	1.00
2/25 13:14	1.90	1.43	0.0053	12.77	0.25	0.19	0.96	1.33	1.00
2/25 13:15	1.89	1.42	0.0052	12.58	0.35	0.26	1.45	1.35	1.02
2/25 13:16	1.87	1.41	0.0052	12.53	0.37	0.28	1.45	1.36	1.02
2/25 13:17	1.86	1.40	0.0052	12.53	0.34	0.26	1.45	1.37	1.03
2/25 13:18	1.85	1.39	0.0051	12.29	0.30	0.23	1.20	1.38	1.04
2/25 13:19	1.84	1.39	0.0051	12.29	0.32	0.24	1.20	1.40	1.05
2/25 13:20	1.83	1.38	0.0051	12.33	0.27	0.20	1.21	1.42	1.07
2/25 13:21	1.82	1.37	0.0050	12.05	0.26	0.20	0.96	1.43	1.08
2/25 13:22	1.82	1.37	0.0050	12.09	0.28	0.21	1.21	1.43	1.08
2/25 13:23	1.86	1.40	0.0052	12.58	0.27	0.20	1.21	1.41	1.06
2/25 13:24	1.92	1.45	0.0053	12.77	0.28	0.21	1.20	1.38	1.04
2/25 13:25	2.03	1.53	0.0056	13.49	0.26	0.20	0.96	1.32	0.99
2/25 13:26	2.18	1.64	0.0061	14.70	0.31	0.23	1.20	1.24	0.93
2/25 13:27	2.33	1.76	0.0065	15.66	0.27	0.20	1.20	1.16	0.87
Average (all)	1.92	1.45	0.0053	12.89	0.22	0.17	0.91	1.35	1.02
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.82	1.37	0.0050	12.05	0.01	0.01	0.00	1.16	0.87
Maximum (all)	2.33	1.76	0.0065	15.66	0.37	0.28	1.45	1.43	1.08
Average (valid values only)	1.92	1.45	0.0053	12.89	0.22	0.17	0.91	1.35	1.02
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:07 PM thru 2/25/2020 1:27 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 13:07	3.37	13.06	23057.1	231.2	345.3
2/25 13:08	3.37	13.06	23057.1	231.4	345.0
2/25 13:09	3.39	13.06	23142.9	231.4	345.5
2/25 13:10	3.37	13.06	23057.1	231.4	345.6
2/25 13:11	3.39	13.06	23142.9	231.3	345.5
2/25 13:12	3.37	13.07	23057.1	231.3	345.5
2/25 13:13	3.37	13.07	23057.1	231.3	345.4
2/25 13:14	3.37	13.08	23057.1	231.4	345.5
2/25 13:15	3.39	13.07	23142.9	231.4	345.5
2/25 13:16	3.37	13.07	23057.1	231.5	345.5
2/25 13:17	3.37	13.06	23057.1	231.4	345.5
2/25 13:18	3.37	13.06	23057.1	231.4	345.5
2/25 13:19	3.37	13.07	23057.1	231.5	345.6
2/25 13:20	3.63	13.06	23142.9	231.5	345.7
2/25 13:21	3.61	13.06	23057.1	231.3	345.4
2/25 13:22	3.63	13.06	23142.9	231.4	345.5
2/25 13:23	3.39	13.07	23142.9	231.4	345.5
2/25 13:24	3.37	13.07	23057.1	231.3	345.4
2/25 13:25	3.37	13.07	23057.1	231.1	345.3
2/25 13:26	3.13	13.07	23057.1	231.1	345.3
2/25 13:27	2.89	13.07	23057.1	231.1	345.2
Average (all)	3.38	13.07	23081.6	231.3	345.4
Total (all)	--	--	--	--	--
Minimum (all)	2.89	13.06	23057.1	231.1	345.0
Maximum (all)	3.63	13.08	23142.9	231.5	345.7
Average (valid values only)	3.38	13.07	23081.6	231.3	345.4
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:36 PM thru 2/25/2020 1:56 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 13:36	2.15	1.62	0.0060	14.46	0.20	0.15	0.72	0.99	0.75
2/25 13:37	2.09	1.57	0.0058	13.97	0.22	0.17	0.96	1.01	0.76
2/25 13:38	2.05	1.54	0.0057	13.73	0.23	0.17	0.96	1.04	0.78
2/25 13:39	2.04	1.54	0.0057	13.79	0.22	0.17	0.97	1.05	0.79
2/25 13:40	2.06	1.55	0.0057	13.73	0.21	0.16	0.96	1.05	0.79
2/25 13:41	2.12	1.60	0.0059	14.22	0.26	0.20	0.96	1.04	0.78
2/25 13:42	2.19	1.65	0.0061	14.75	0.27	0.20	1.21	1.02	0.77
2/25 13:43	2.28	1.72	0.0063	15.18	0.30	0.23	1.20	0.99	0.75
2/25 13:44	2.36	1.78	0.0065	15.66	0.34	0.26	1.45	0.97	0.73
2/25 13:45	2.43	1.83	0.0067	16.14	0.35	0.26	1.45	0.94	0.71
2/25 13:46	2.47	1.86	0.0069	16.69	0.37	0.28	1.45	0.93	0.70
2/25 13:47	2.46	1.85	0.0068	16.45	0.40	0.30	1.69	0.93	0.70
2/25 13:48	2.42	1.82	0.0067	16.14	0.43	0.32	1.69	0.93	0.70
2/25 13:49	2.36	1.78	0.0065	15.66	0.41	0.31	1.69	0.94	0.71
2/25 13:50	2.28	1.72	0.0063	15.18	0.41	0.31	1.69	0.95	0.72
2/25 13:51	2.21	1.66	0.0061	14.75	0.42	0.32	1.69	0.96	0.72
2/25 13:52	2.15	1.62	0.0060	14.51	0.43	0.32	1.69	0.97	0.73
2/25 13:53	2.12	1.60	0.0059	14.22	0.41	0.31	1.69	0.97	0.73
2/25 13:54	2.12	1.60	0.0059	14.22	0.43	0.32	1.69	0.97	0.73
2/25 13:55	2.16	1.63	0.0060	14.51	0.47	0.35	1.93	0.96	0.72
2/25 13:56	2.24	1.69	0.0062	14.94	0.42	0.32	1.69	0.94	0.71
Average (all)	2.23	1.68	0.0062	14.90	0.34	0.26	1.40	0.98	0.74
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.04	1.54	0.0057	13.73	0.20	0.15	0.72	0.93	0.70
Maximum (all)	2.47	1.86	0.0069	16.69	0.47	0.35	1.93	1.05	0.79
Average (valid values only)	2.23	1.68	0.0062	14.90	0.34	0.26	1.40	0.98	0.74
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 1:36 PM thru 2/25/2020 1:56 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 13:36	2.41	13.07	23057.1	231.4	345.8
2/25 13:37	2.41	13.07	23057.1	231.3	345.2
2/25 13:38	2.65	13.07	23057.1	231.4	345.6
2/25 13:39	2.66	13.06	23142.9	231.4	345.7
2/25 13:40	2.65	13.06	23057.1	231.4	345.7
2/25 13:41	2.65	13.06	23057.1	231.4	345.7
2/25 13:42	2.42	13.06	23142.9	231.4	345.7
2/25 13:43	2.41	13.06	23057.1	231.4	345.7
2/25 13:44	2.41	13.06	23057.1	231.4	345.7
2/25 13:45	2.41	13.06	23057.1	231.3	345.5
2/25 13:46	2.42	13.07	23142.9	231.3	345.5
2/25 13:47	2.42	13.07	23142.9	231.4	345.6
2/25 13:48	2.41	13.07	23057.1	231.4	345.6
2/25 13:49	2.41	13.06	23057.1	231.3	345.4
2/25 13:50	2.41	13.07	23057.1	231.3	345.4
2/25 13:51	2.42	13.06	23142.9	231.3	345.5
2/25 13:52	2.42	13.07	23142.9	231.2	345.4
2/25 13:53	2.41	13.07	23057.1	231.3	345.5
2/25 13:54	2.41	13.07	23057.1	231.3	345.5
2/25 13:55	2.42	13.06	23142.9	231.3	345.5
2/25 13:56	2.41	13.07	23057.1	231.2	345.5
Average (all)	2.46	13.07	23085.7	231.3	345.6
Total (all)	--	--	--	--	--
Minimum (all)	2.41	13.06	23057.1	231.2	345.2
Maximum (all)	2.66	13.07	23142.9	231.4	345.8
Average (valid values only)	2.46	13.07	23085.7	231.3	345.6
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:15 PM thru 2/25/2020 2:35 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 14:15	2.33	1.76	0.0065	15.72	0.22	0.17	0.97	0.94	0.71
2/25 14:16	2.39	1.80	0.0066	15.96	0.26	0.20	0.97	0.92	0.69
2/25 14:17	2.42	1.82	0.0067	16.14	0.28	0.21	1.20	0.92	0.69
2/25 14:18	2.42	1.82	0.0067	16.14	0.26	0.20	0.96	0.92	0.69
2/25 14:19	2.39	1.80	0.0066	15.90	0.28	0.21	1.20	0.92	0.69
2/25 14:20	2.35	1.77	0.0065	15.66	0.25	0.19	0.96	0.92	0.69
2/25 14:21	2.28	1.72	0.0063	15.18	0.28	0.21	1.20	0.94	0.71
2/25 14:22	2.14	1.61	0.0059	14.22	0.21	0.16	0.96	1.00	0.75
2/25 14:23	1.97	1.48	0.0055	13.20	0.20	0.15	0.72	1.05	0.79
2/25 14:24	1.84	1.38	0.0051	12.33	0.20	0.15	0.73	1.09	0.82
2/25 14:25	1.77	1.33	0.0049	11.81	0.25	0.19	0.96	1.15	0.87
2/25 14:26	1.75	1.32	0.0049	11.81	0.27	0.20	1.20	1.22	0.92
2/25 14:27	1.74	1.31	0.0048	11.57	0.26	0.20	0.96	1.29	0.97
2/25 14:28	1.76	1.33	0.0049	11.76	0.27	0.20	1.20	1.32	0.99
2/25 14:29	1.81	1.36	0.0050	12.05	0.27	0.20	1.20	1.33	1.00
2/25 14:30	1.88	1.42	0.0052	12.58	0.29	0.22	1.21	1.31	0.99
2/25 14:31	1.98	1.49	0.0055	13.25	0.27	0.20	1.20	1.26	0.95
2/25 14:32	2.06	1.55	0.0057	13.73	0.29	0.22	1.20	1.23	0.93
2/25 14:33	2.14	1.61	0.0059	14.22	0.31	0.23	1.20	1.17	0.88
2/25 14:34	2.20	1.66	0.0061	14.70	0.31	0.23	1.20	1.13	0.85
2/25 14:35	2.24	1.69	0.0062	14.94	0.24	0.18	0.96	1.10	0.83
Average (all)	2.09	1.57	0.0058	13.95	0.26	0.20	1.06	1.10	0.83
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.74	1.31	0.0048	11.57	0.20	0.15	0.72	0.92	0.69
Maximum (all)	2.42	1.82	0.0067	16.14	0.31	0.23	1.21	1.33	1.00
Average (valid values only)	2.09	1.57	0.0058	13.95	0.26	0.20	1.06	1.10	0.83
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:15 PM thru 2/25/2020 2:35 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 14:15	2.42	13.07	23142.9	231.2	345.1
2/25 14:16	2.18	13.06	23142.9	231.1	345.1
2/25 14:17	2.17	13.06	23057.1	231.1	345.2
2/25 14:18	2.17	13.06	23057.1	231.0	345.1
2/25 14:19	2.17	13.06	23057.1	230.9	345.0
2/25 14:20	2.17	13.06	23057.1	231.1	345.4
2/25 14:21	2.41	13.06	23057.1	231.1	345.4
2/25 14:22	2.41	13.06	23057.1	231.2	345.6
2/25 14:23	2.64	13.06	22971.4	231.0	345.4
2/25 14:24	2.66	13.06	23142.9	231.1	345.5
2/25 14:25	2.89	13.06	23057.1	231.0	344.9
2/25 14:26	2.89	13.07	23057.1	230.9	345.3
2/25 14:27	3.13	13.07	23057.1	231.1	345.6
2/25 14:28	3.36	13.07	22971.4	231.0	345.5
2/25 14:29	3.37	13.07	23057.1	231.0	345.5
2/25 14:30	3.14	13.07	23142.9	231.0	345.5
2/25 14:31	3.13	13.07	23057.1	231.1	345.6
2/25 14:32	3.13	13.07	23057.1	231.2	345.6
2/25 14:33	2.89	13.07	23057.1	231.1	345.5
2/25 14:34	2.89	13.06	23057.1	231.2	345.5
2/25 14:35	2.65	13.07	23057.1	231.1	345.4
Average (all)	2.71	13.06	23065.3	231.1	345.4
Total (all)	--	--	--	--	--
Minimum (all)	2.17	13.06	22971.4	230.9	344.9
Maximum (all)	3.37	13.07	23142.9	231.2	345.6
Average (valid values only)	2.71	13.06	23065.3	231.1	345.4
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:46 PM thru 2/25/2020 3:06 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 14:46	2.21	1.66	0.0061	14.70	0.11	0.08	0.48	0.99	0.75
2/25 14:47	2.14	1.61	0.0059	14.22	0.14	0.11	0.48	1.03	0.78
2/25 14:48	2.06	1.55	0.0057	13.73	0.18	0.14	0.72	1.06	0.80
2/25 14:49	2.00	1.51	0.0055	13.25	0.14	0.11	0.48	1.06	0.80
2/25 14:50	1.98	1.49	0.0055	13.30	0.06	0.05	0.24	1.07	0.81
2/25 14:51	1.98	1.49	0.0055	13.25	0.09	0.07	0.48	1.09	0.82
2/25 14:52	1.99	1.50	0.0055	13.25	0.06	0.05	0.24	1.11	0.84
2/25 14:53	2.00	1.51	0.0056	13.54	0.04	0.03	0.24	1.12	0.84
2/25 14:54	2.00	1.51	0.0056	13.44	0.04	0.03	0.24	1.14	0.86
2/25 14:55	2.00	1.51	0.0055	13.25	0.08	0.06	0.24	1.15	0.87
2/25 14:56	2.00	1.51	0.0056	13.49	0.08	0.06	0.24	1.15	0.87
2/25 14:57	1.99	1.50	0.0055	13.25	0.09	0.07	0.48	1.17	0.88
2/25 14:58	1.93	1.45	0.0054	13.06	0.10	0.08	0.48	1.20	0.90
2/25 14:59	1.86	1.40	0.0052	12.53	0.08	0.06	0.24	1.24	0.93
2/25 15:00	1.83	1.38	0.0051	12.29	0.08	0.06	0.24	1.25	0.94
2/25 15:01	1.85	1.39	0.0051	12.29	0.10	0.08	0.48	1.28	0.96
2/25 15:02	1.88	1.42	0.0052	12.48	0.08	0.06	0.24	1.29	0.97
2/25 15:03	1.92	1.45	0.0053	12.82	0.08	0.06	0.24	1.28	0.96
2/25 15:04	1.97	1.48	0.0055	13.30	0.08	0.06	0.24	1.26	0.95
2/25 15:05	2.02	1.52	0.0056	13.49	0.13	0.10	0.48	1.24	0.93
2/25 15:06	2.07	1.56	0.0057	13.73	0.10	0.08	0.48	1.21	0.91
Average (all)	1.98	1.50	0.0055	13.27	0.09	0.07	0.37	1.16	0.87
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.83	1.38	0.0051	12.29	0.04	0.03	0.24	0.99	0.75
Maximum (all)	2.21	1.66	0.0061	14.70	0.18	0.14	0.72	1.29	0.97
Average (valid values only)	1.98	1.50	0.0055	13.27	0.09	0.07	0.37	1.16	0.87
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 2:46 PM thru 2/25/2020 3:06 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 14:46	2.41	13.06	23057.1	231.2	345.7
2/25 14:47	2.65	13.06	23057.1	231.2	345.7
2/25 14:48	2.65	13.06	23057.1	231.0	345.5
2/25 14:49	2.65	13.06	23057.1	231.2	345.7
2/25 14:50	2.66	13.07	23142.9	231.0	345.5
2/25 14:51	2.65	13.06	23057.1	231.2	345.7
2/25 14:52	2.65	13.07	23057.1	231.0	345.5
2/25 14:53	2.66	13.07	23142.9	231.1	345.7
2/25 14:54	2.88	13.07	22971.4	230.9	345.4
2/25 14:55	2.89	13.06	23057.1	231.0	345.6
2/25 14:56	2.89	13.07	23057.1	231.0	345.5
2/25 14:57	2.89	13.07	23057.1	230.9	345.4
2/25 14:58	2.90	13.07	23142.9	231.1	345.6
2/25 14:59	3.13	13.06	23057.1	231.0	345.5
2/25 15:00	3.13	13.07	23057.1	230.9	345.4
2/25 15:01	3.13	13.07	23057.1	231.0	345.5
2/25 15:02	3.12	13.07	22971.4	231.0	345.4
2/25 15:03	3.14	13.07	23142.9	231.1	345.4
2/25 15:04	3.14	13.06	23142.9	231.1	345.5
2/25 15:05	3.13	13.06	23057.1	231.0	345.3
2/25 15:06	2.89	13.06	23057.1	231.0	345.1
Average (all)	2.87	13.07	23069.4	231.0	345.5
Total (all)	--	--	--	--	--
Minimum (all)	2.41	13.06	22971.4	230.9	345.1
Maximum (all)	3.14	13.07	23142.9	231.2	345.7
Average (valid values only)	2.87	13.07	23069.4	231.0	345.5
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:17 PM thru 2/25/2020 3:37 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 15:17	2.20	1.66	0.0061	14.70	0.16	0.12	0.72	1.04	0.78
2/25 15:18	2.23	1.68	0.0062	14.88	0.16	0.12	0.72	1.03	0.78
2/25 15:19	2.25	1.70	0.0062	14.94	0.11	0.08	0.48	1.02	0.77
2/25 15:20	2.25	1.70	0.0062	14.94	0.11	0.08	0.48	1.02	0.77
2/25 15:21	2.25	1.70	0.0062	14.94	0.11	0.08	0.48	1.01	0.76
2/25 15:22	2.25	1.69	0.0062	14.94	0.08	0.06	0.24	1.00	0.75
2/25 15:23	2.24	1.69	0.0062	14.94	0.10	0.08	0.48	1.00	0.75
2/25 15:24	2.23	1.68	0.0062	14.88	0.07	0.05	0.24	1.00	0.75
2/25 15:25	2.20	1.66	0.0061	14.75	0.03	0.02	0.24	1.01	0.76
2/25 15:26	2.14	1.61	0.0059	14.22	0.02	0.02	0.00	1.04	0.78
2/25 15:27	2.07	1.56	0.0057	13.73	0.03	0.02	0.24	1.07	0.81
2/25 15:28	2.02	1.52	0.0056	13.54	0.04	0.03	0.24	1.08	0.81
2/25 15:29	1.99	1.50	0.0055	13.25	0.00	0.00	0.00	1.10	0.83
2/25 15:30	1.98	1.49	0.0055	13.20	0.00	0.00	0.00	1.13	0.85
2/25 15:31	1.98	1.49	0.0055	13.25	0.04	0.03	0.24	1.14	0.86
2/25 15:32	1.97	1.48	0.0055	13.25	0.08	0.06	0.24	1.16	0.87
2/25 15:33	1.96	1.48	0.0054	13.01	0.06	0.05	0.24	1.17	0.88
2/25 15:34	1.96	1.48	0.0054	13.01	0.09	0.07	0.48	1.17	0.88
2/25 15:35	2.02	1.52	0.0056	13.49	0.06	0.05	0.24	1.14	0.86
2/25 15:36	2.12	1.60	0.0059	14.22	0.07	0.05	0.24	1.11	0.84
2/25 15:37	2.21	1.67	0.0061	14.75	0.07	0.05	0.24	1.07	0.81
Average (all)	2.12	1.60	0.0059	14.13	0.07	0.05	0.31	1.07	0.81
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	1.96	1.48	0.0054	13.01	0.00	0.00	0.00	1.00	0.75
Maximum (all)	2.25	1.70	0.0062	14.94	0.16	0.12	0.72	1.17	0.88
Average (valid values only)	2.12	1.60	0.0059	14.13	0.07	0.05	0.31	1.07	0.81
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:17 PM thru 2/25/2020 3:37 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 15:17	2.65	13.07	23057.1	231.0	345.1
2/25 15:18	2.64	13.07	22971.4	231.0	345.1
2/25 15:19	2.41	13.07	23057.1	231.0	345.1
2/25 15:20	2.41	13.07	23057.1	231.1	345.3
2/25 15:21	2.41	13.07	23057.1	231.0	345.2
2/25 15:22	2.41	13.06	23057.1	230.9	345.1
2/25 15:23	2.41	13.06	23057.1	231.0	345.3
2/25 15:24	2.40	13.06	22971.4	231.0	345.3
2/25 15:25	2.42	13.06	23142.9	231.0	345.4
2/25 15:26	2.65	13.06	23057.1	231.1	345.3
2/25 15:27	2.65	13.06	23057.1	231.0	345.1
2/25 15:28	2.66	13.06	23142.9	231.1	345.2
2/25 15:29	2.65	13.06	23057.1	231.0	345.1
2/25 15:30	2.88	13.06	22971.4	231.1	345.4
2/25 15:31	2.89	13.06	23057.1	231.0	345.3
2/25 15:32	2.89	13.06	23057.1	231.1	345.4
2/25 15:33	2.89	13.06	23057.1	231.1	345.4
2/25 15:34	2.89	13.06	23057.1	231.0	345.4
2/25 15:35	2.89	13.06	23057.1	231.1	345.5
2/25 15:36	2.65	13.06	23057.1	231.1	345.5
2/25 15:37	2.66	13.07	23142.9	231.1	345.5
Average (all)	2.64	13.06	23057.1	231.0	345.3
Total (all)	--	--	--	--	--
Minimum (all)	2.40	13.06	22971.4	230.9	345.1
Maximum (all)	2.89	13.07	23142.9	231.1	345.5
Average (valid values only)	2.64	13.06	23057.1	231.0	345.3
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:47 PM thru 2/25/2020 4:07 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 15:47	2.27	1.71	0.0063	15.18	0.09	0.07	0.48	0.96	0.72
2/25 15:48	2.28	1.72	0.0063	15.24	0.05	0.04	0.24	0.96	0.72
2/25 15:49	2.28	1.72	0.0063	15.24	0.05	0.04	0.24	0.96	0.72
2/25 15:50	2.28	1.72	0.0063	15.18	0.08	0.06	0.24	0.95	0.71
2/25 15:51	2.27	1.71	0.0063	15.18	0.04	0.03	0.24	0.96	0.72
2/25 15:52	2.27	1.71	0.0063	15.12	0.09	0.07	0.48	0.95	0.71
2/25 15:53	2.26	1.70	0.0063	15.24	0.03	0.02	0.24	0.95	0.71
2/25 15:54	2.25	1.69	0.0062	14.94	0.01	0.01	0.00	0.95	0.71
2/25 15:55	2.25	1.69	0.0062	14.94	0.03	0.02	0.24	0.94	0.71
2/25 15:56	2.27	1.71	0.0063	15.24	0.07	0.05	0.24	0.93	0.70
2/25 15:57	2.28	1.72	0.0063	15.18	0.08	0.06	0.24	0.93	0.70
2/25 15:58	2.28	1.72	0.0063	15.24	0.03	0.02	0.24	0.93	0.70
2/25 15:59	2.28	1.72	0.0063	15.18	0.02	0.02	0.00	0.94	0.71
2/25 16:00	2.27	1.71	0.0063	15.24	0.04	0.03	0.24	0.93	0.70
2/25 16:01	2.28	1.72	0.0063	15.18	0.06	0.05	0.24	0.92	0.69
2/25 16:02	2.28	1.72	0.0063	15.18	0.07	0.05	0.24	0.93	0.70
2/25 16:03	2.27	1.71	0.0063	15.18	0.02	0.02	0.00	0.93	0.70
2/25 16:04	2.26	1.70	0.0063	15.18	0.05	0.04	0.24	0.93	0.70
2/25 16:05	2.26	1.70	0.0063	15.18	0.01	0.01	0.00	0.94	0.71
2/25 16:06	2.26	1.70	0.0063	15.18	0.04	0.03	0.24	0.94	0.71
2/25 16:07	2.27	1.67	0.0062	15.40	0.03	0.02	0.00	0.93	0.68
Average (all)	2.27	1.71	0.0063	15.18	0.05	0.04	0.21	0.94	0.71
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.25	1.67	0.0062	14.94	0.01	0.01	0.00	0.92	0.68
Maximum (all)	2.28	1.72	0.0063	15.40	0.09	0.07	0.48	0.96	0.72
Average (valid values only)	2.27	1.71	0.0063	15.18	0.05	0.04	0.21	0.94	0.71
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 3:47 PM thru 2/25/2020 4:07 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 15:47	2.41	13.06	23057.1	231.1	345.5
2/25 15:48	2.42	13.06	23142.9	231.0	345.4
2/25 15:49	2.42	13.06	23142.9	231.2	345.7
2/25 15:50	2.41	13.06	23057.1	231.1	345.6
2/25 15:51	2.41	13.06	23057.1	231.2	345.8
2/25 15:52	2.40	13.06	22971.4	231.1	345.6
2/25 15:53	2.42	13.06	23142.9	231.1	345.5
2/25 15:54	2.41	13.06	23057.1	231.2	345.7
2/25 15:55	2.41	13.06	23057.1	231.2	345.7
2/25 15:56	2.42	13.06	23142.9	231.2	345.7
2/25 15:57	2.41	13.06	23057.1	231.2	345.7
2/25 15:58	2.42	13.06	23142.9	231.2	345.7
2/25 15:59	2.41	13.06	23057.1	231.2	345.9
2/25 16:00	2.42	13.06	23142.9	231.2	346.0
2/25 16:01	2.17	13.06	23057.1	231.3	346.0
2/25 16:02	2.41	13.06	23057.1	231.2	345.9
2/25 16:03	2.41	13.06	23057.1	231.3	346.0
2/25 16:04	2.41	13.06	23057.1	231.1	345.8
2/25 16:05	2.41	13.05	23057.1	231.1	345.8
2/25 16:06	2.41	13.06	23057.1	231.1	346.0
2/25 16:07	2.24	12.88	23768.8	231.2	347.6
Average (all)	2.39	13.05	23111.4	231.2	345.8
Total (all)	--	--	--	--	--
Minimum (all)	2.17	12.88	22971.4	231.0	345.4
Maximum (all)	2.42	13.06	23768.8	231.3	347.6
Average (valid values only)	2.39	13.05	23111.4	231.2	345.8
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:20 PM thru 2/25/2020 4:40 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 16:20	2.60	1.82	0.0067	17.36	0.00	0.00	0.00	1.03	0.72
2/25 16:21	2.56	1.78	0.0066	17.10	0.00	0.00	0.00	1.06	0.74
2/25 16:22	2.54	1.76	0.0065	16.95	0.00	0.00	0.00	1.08	0.75
2/25 16:23	2.53	1.75	0.0064	16.73	0.00	0.00	0.00	1.10	0.76
2/25 16:24	2.54	1.75	0.0064	16.84	0.00	0.00	0.00	1.11	0.76
2/25 16:25	2.57	1.77	0.0065	17.02	0.00	0.00	0.00	1.11	0.76
2/25 16:26	2.61	1.79	0.0066	17.38	0.00	0.00	0.00	1.12	0.77
2/25 16:27	2.63	1.80	0.0066	17.35	0.00	0.00	0.00	1.14	0.78
2/25 16:28	2.64	1.80	0.0066	17.39	0.00	0.00	0.00	1.15	0.78
2/25 16:29	2.63	1.79	0.0066	17.42	0.00	0.00	0.00	1.18	0.80
2/25 16:30	2.61	1.77	0.0065	17.19	0.00	0.00	0.00	1.19	0.81
2/25 16:31	2.60	1.76	0.0065	17.22	0.00	0.00	0.00	1.21	0.82
2/25 16:32	2.62	1.77	0.0065	17.25	0.00	0.00	0.00	1.22	0.82
2/25 16:33	2.65	1.79	0.0066	17.54	0.00	0.00	0.00	1.23	0.83
2/25 16:34	2.67	1.80	0.0066	17.62	0.00	0.00	0.00	1.25	0.84
2/25 16:35	2.67	1.79	0.0066	17.64	0.00	0.00	0.00	1.28	0.86
2/25 16:36	2.65	1.78	0.0066	17.64	0.00	0.00	0.00	1.30	0.87
2/25 16:37	2.62	1.76	0.0065	17.31	0.00	0.00	0.00	1.33	0.89
2/25 16:38	2.59	1.74	0.0064	17.11	0.00	0.00	0.00	1.35	0.91
2/25 16:39	2.57	1.72	0.0063	16.84	0.00	0.00	0.00	1.37	0.92
2/25 16:40	2.56	1.72	0.0063	16.79	0.00	0.00	0.00	1.38	0.93
Average (all)	2.60	1.77	0.0065	17.22	0.00	0.00	0.00	1.20	0.82
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.53	1.72	0.0063	16.73	0.00	0.00	0.00	1.03	0.72
Maximum (all)	2.67	1.82	0.0067	17.64	0.00	0.00	0.00	1.38	0.93
Average (valid values only)	2.60	1.77	0.0065	17.22	0.00	0.00	0.00	1.20	0.82
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:20 PM thru 2/25/2020 4:40 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 16:20	2.59	12.46	24799.3	231.3	364.6
2/25 16:21	2.59	12.42	24793.3	231.5	365.5
2/25 16:22	2.61	12.38	24950.2	231.3	367.0
2/25 16:23	2.62	12.36	25016.3	231.3	368.1
2/25 16:24	2.63	12.33	25167.7	231.3	369.1
2/25 16:25	2.62	12.31	25054.7	231.4	370.1
2/25 16:26	2.63	12.28	25197.2	231.5	371.0
2/25 16:27	2.89	12.26	25164.6	231.5	371.9
2/25 16:28	2.90	12.24	25220.2	231.5	372.6
2/25 16:29	2.90	12.22	25267.2	231.5	373.4
2/25 16:30	2.91	12.21	25307.8	231.6	374.2
2/25 16:31	2.91	12.18	25352.8	231.5	374.2
2/25 16:32	2.92	12.17	25397.6	231.6	375.3
2/25 16:33	2.92	12.15	25432.3	231.7	376.2
2/25 16:34	2.94	12.13	25554.5	231.6	376.6
2/25 16:35	3.20	12.12	25571.8	231.6	377.2
2/25 16:36	3.20	12.11	25575.1	231.7	377.7
2/25 16:37	3.20	12.12	25490.0	231.6	377.9
2/25 16:38	3.20	12.12	25574.9	231.7	378.2
2/25 16:39	3.21	12.10	25577.6	231.7	378.4
2/25 16:40	3.46	12.10	25506.5	231.8	378.5
Average (all)	2.91	12.23	25284.4	231.5	373.2
Total (all)	--	--	--	--	--
Minimum (all)	2.59	12.10	24793.3	231.3	364.6
Maximum (all)	3.46	12.46	25577.6	231.8	378.5
Average (valid values only)	2.91	12.23	25284.4	231.5	373.2
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:51 PM thru 2/25/2020 5:11 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 16:51	2.53	1.70	0.0063	16.83	0.00	0.00	0.00	1.47	0.99
2/25 16:52	2.53	1.70	0.0063	16.76	0.00	0.00	0.00	1.47	0.99
2/25 16:53	2.54	1.71	0.0063	16.81	0.00	0.00	0.00	1.46	0.98
2/25 16:54	2.56	1.72	0.0063	16.79	0.00	0.00	0.00	1.46	0.98
2/25 16:55	2.55	1.72	0.0063	16.79	0.00	0.00	0.00	1.48	1.00
2/25 16:56	2.53	1.70	0.0063	16.73	0.00	0.00	0.00	1.48	1.00
2/25 16:57	2.52	1.69	0.0062	16.55	0.00	0.00	0.00	1.48	0.99
2/25 16:58	2.52	1.69	0.0062	16.66	0.00	0.00	0.00	1.47	0.99
2/25 16:59	2.54	1.70	0.0063	16.91	0.00	0.00	0.00	1.46	0.98
2/25 17:00	2.57	1.71	0.0063	16.93	0.00	0.00	0.00	1.46	0.97
2/25 17:01	2.60	1.73	0.0064	17.13	0.00	0.00	0.00	1.47	0.98
2/25 17:02	2.59	1.73	0.0064	17.06	0.00	0.00	0.00	1.49	1.00
2/25 17:03	2.55	1.72	0.0063	16.74	0.00	0.00	0.00	1.51	1.02
2/25 17:04	2.49	1.68	0.0062	16.51	0.00	0.00	0.00	1.51	1.02
2/25 17:05	2.45	1.66	0.0061	16.21	0.00	0.00	0.00	1.50	1.01
2/25 17:06	2.45	1.65	0.0061	16.25	0.00	0.00	0.00	1.48	1.00
2/25 17:07	2.49	1.67	0.0062	16.56	0.00	0.00	0.00	1.47	0.99
2/25 17:08	2.54	1.70	0.0063	16.88	0.00	0.00	0.00	1.46	0.98
2/25 17:09	2.59	1.73	0.0064	17.14	0.00	0.00	0.00	1.46	0.98
2/25 17:10	2.62	1.75	0.0065	17.42	0.00	0.00	0.00	1.47	0.98
2/25 17:11	2.60	1.74	0.0064	17.05	0.00	0.00	0.00	1.49	1.00
Average (all)	2.54	1.70	0.0063	16.80	0.00	0.00	0.00	1.48	0.99
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.45	1.65	0.0061	16.21	0.00	0.00	0.00	1.46	0.97
Maximum (all)	2.62	1.75	0.0065	17.42	0.00	0.00	0.00	1.51	1.02
Average (valid values only)	2.54	1.70	0.0063	16.80	0.00	0.00	0.00	1.48	0.99
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 4:51 PM thru 2/25/2020 5:11 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 16:51	3.47	12.12	25552.3	231.7	377.9
2/25 16:52	3.46	12.12	25458.7	231.7	378.0
2/25 16:53	3.46	12.12	25525.4	231.8	378.3
2/25 16:54	3.46	12.12	25502.5	231.8	378.4
2/25 16:55	3.73	12.13	25499.5	231.8	378.3
2/25 16:56	3.72	12.13	25418.6	232.0	378.3
2/25 16:57	3.74	12.12	25548.6	232.0	378.0
2/25 16:58	3.50	12.10	25707.3	232.0	377.5
2/25 16:59	3.49	12.07	25686.2	232.1	377.5
2/25 17:00	3.49	12.05	25710.4	232.1	377.7
2/25 17:01	3.48	12.05	25617.3	232.1	378.0
2/25 17:02	3.73	12.08	25500.4	232.2	378.3
2/25 17:03	3.72	12.13	25420.5	232.1	378.4
2/25 17:04	3.73	12.16	25478.5	232.2	378.5
2/25 17:05	3.73	12.18	25434.1	232.2	378.0
2/25 17:06	3.74	12.15	25502.6	232.2	377.6
2/25 17:07	3.47	12.12	25573.7	232.2	377.5
2/25 17:08	3.48	12.09	25630.5	232.3	377.8
2/25 17:09	3.48	12.07	25620.6	232.2	378.2
2/25 17:10	3.49	12.09	25648.5	232.2	378.7
2/25 17:11	3.73	12.10	25496.6	232.3	379.2
Average (all)	3.59	12.11	25549.2	232.1	378.1
Total (all)	--	--	--	--	--
Minimum (all)	3.46	12.05	25418.6	231.7	377.5
Maximum (all)	3.74	12.18	25710.4	232.3	379.2
Average (valid values only)	3.59	12.11	25549.2	232.1	378.1
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 5:57 PM thru 2/25/2020 6:17 PM

Timestamp	(Turbine 2) 75-NOx ppm 1-Min	(Turbine 2) NOx ppm @15% O2 1-Min	(Turbine 2) 75-NOx lb/mmBtu 1-Min	(Turbine 2) NOx lb/hr 1-Min	(Turbine 2) CO ppm 1-Min	(Turbine 2) CO ppm @15% O2 1-Min	(Turbine 2) CO lb/hr 1-Min	(Turbine 2) NH3 Slip ppm 1-Min	(Turbine 2) NH3 Slip ppm @15% O2 1-Min
2/25 17:57	2.53	1.69	0.0062	16.65	0.00	0.00	0.00	1.48	0.99
2/25 17:58	2.51	1.68	0.0062	16.65	0.00	0.00	0.00	1.48	0.99
2/25 17:59	2.52	1.68	0.0062	16.61	0.00	0.00	0.00	1.48	0.99
2/25 18:00	2.54	1.70	0.0063	16.94	0.00	0.00	0.00	1.47	0.98
2/25 18:01	2.56	1.71	0.0063	16.89	0.00	0.00	0.00	1.47	0.98
2/25 18:02	2.57	1.72	0.0063	16.84	0.01	0.01	0.00	1.47	0.98
2/25 18:03	2.56	1.71	0.0063	16.84	0.02	0.01	0.00	1.48	0.99
2/25 18:04	2.55	1.71	0.0063	16.88	0.03	0.02	0.00	1.48	0.99
2/25 18:05	2.54	1.70	0.0063	16.82	0.02	0.01	0.00	1.48	0.99
2/25 18:06	2.55	1.71	0.0063	16.86	0.00	0.00	0.00	1.47	0.99
2/25 18:07	2.56	1.72	0.0063	16.92	0.00	0.00	0.00	1.47	0.99
2/25 18:08	2.55	1.71	0.0063	16.81	0.00	0.00	0.00	1.48	0.99
2/25 18:09	2.53	1.70	0.0062	16.60	0.00	0.00	0.00	1.49	1.00
2/25 18:10	2.52	1.69	0.0062	16.61	0.01	0.01	0.00	1.49	1.00
2/25 18:11	2.52	1.69	0.0062	16.62	0.00	0.00	0.00	1.49	1.00
2/25 18:12	2.51	1.68	0.0062	16.62	0.02	0.01	0.00	1.51	1.01
2/25 18:13	2.51	1.68	0.0062	16.62	0.05	0.03	0.27	1.51	1.01
2/25 18:14	2.51	1.68	0.0062	16.61	0.08	0.05	0.27	1.51	1.01
2/25 18:15	2.51	1.68	0.0062	16.60	0.02	0.01	0.00	1.51	1.01
2/25 18:16	2.51	1.68	0.0062	16.59	0.03	0.02	0.00	1.51	1.01
2/25 18:17	2.52	1.69	0.0062	16.65	0.04	0.03	0.26	1.51	1.01
Average (all)	2.53	1.70	0.0062	16.73	0.02	0.01	0.04	1.49	1.00
Total (all)	--	--	--	--	--	--	--	--	--
Minimum (all)	2.51	1.68	0.0062	16.59	0.00	0.00	0.00	1.47	0.98
Maximum (all)	2.57	1.72	0.0063	16.94	0.08	0.05	0.27	1.51	1.01
Average (valid values only)	2.53	1.70	0.0062	16.73	0.02	0.01	0.04	1.49	1.00
Total (valid values only)	--	--	--	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 2/25/2020 5:57 PM thru 2/25/2020 6:17 PM

Timestamp	(Turbine 2) NH3 Slip lb/hr 1-Min	(Turbine 2) 75-O2 % 1-Min	(Turbine 2) Total Gas Flow hscf/hr 1-Min	(Turbine 2) GT Megawatts 1-Min	(Turbine 2) Total Megawatts 1-Min
2/25 17:57	3.49	12.09	25688.5	233.4	380.1
2/25 17:58	3.49	12.09	25698.0	233.4	380.1
2/25 17:59	3.49	12.07	25628.7	233.5	379.9
2/25 18:00	3.50	12.07	25730.2	233.4	379.8
2/25 18:01	3.49	12.07	25651.7	233.5	379.9
2/25 18:02	3.47	12.07	25568.9	233.2	379.6
2/25 18:03	3.47	12.08	25567.6	233.0	379.5
2/25 18:04	3.49	12.09	25638.4	232.8	379.3
2/25 18:05	3.47	12.09	25538.6	233.0	379.8
2/25 18:06	3.48	12.10	25615.9	232.9	379.7
2/25 18:07	3.49	12.10	25697.1	233.0	379.8
2/25 18:08	3.46	12.10	25526.1	233.0	379.7
2/25 18:09	3.75	12.10	25624.6	233.1	379.6
2/25 18:10	3.75	12.08	25642.0	233.3	379.7
2/25 18:11	3.75	12.08	25652.8	233.2	379.5
2/25 18:12	3.75	12.08	25654.0	233.3	379.7
2/25 18:13	3.75	12.08	25645.3	233.3	379.8
2/25 18:14	3.75	12.07	25632.5	233.5	380.3
2/25 18:15	3.75	12.07	25616.7	233.5	380.6
2/25 18:16	3.75	12.08	25605.4	233.6	380.7
2/25 18:17	3.76	12.08	25689.3	233.7	380.9
Average (all)	3.60	12.08	25633.9	233.3	379.9
Total (all)	--	--	--	--	--
Minimum (all)	3.46	12.07	25526.1	232.8	379.3
Maximum (all)	3.76	12.10	25730.2	233.7	380.9
Average (valid values only)	3.60	12.08	25633.9	233.3	379.9
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CEMS AND REFERENCE METHOD DATA

Reference Method Data

Relative Accuracy Test Data
Reference Method Results (NOx)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxides of Nitrogen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 7E
RM Analyzer Type:	Chemiluminescence
Manufacturer:	
Model #:	THERMO 42 series
Serial #:	INST-NX-0031

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		1.58	14.14	0.0058
2	12:32 - 12:52	345.9		1.54	13.77	0.0057
3	13:07 - 13:27	345.4		1.55	13.85	0.0057
4	13:36 - 13:56	345.6		1.58	14.11	0.0058
5	14:15 - 14:35	345.4		1.50	13.41	0.0055
6	14:46 - 15:06	345.5		1.42	12.65	0.0052
7	15:17 - 15:37	345.3		1.51	13.45	0.0056
8	15:47 - 16:07	345.8		1.58	14.15	0.0058
9	16:20 - 16:40	373.2		1.65	16.10	0.0061
10	16:51 - 17:11	378.1		1.58	15.67	0.0058
11	17:57 - 18:17	379.9		1.59	15.73	0.0058
12						

Relative Accuracy Test Data
Reference Method Results (CO)
General Electric, 7F.05, Unit #U-00002

Parameter:	Carbon Monoxide
Date of Test:	February 25, 2020
Reference Method:	EPA Method 10
RM Analyzer Type:	Infrared Absorption
Manufacturer:	
Model #:	THERMO 48 series
Serial #:	INST-CO-0029

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.11	0.58	
2	12:32 - 12:52	345.9		0.35	1.93	
3	13:07 - 13:27	345.4		0.13	0.69	
4	13:36 - 13:56	345.6		0.51	2.76	
5	14:15 - 14:35	345.4		0.13	0.72	
6	14:46 - 15:06	345.5		0.16	0.89	
7	15:17 - 15:37	345.3		0.14	0.74	
8	15:47 - 16:07	345.8		0.14	0.77	
9	16:20 - 16:40	373.2		0.11	0.64	
10	16:51 - 17:11	378.1		0.11	0.68	
11	17:57 - 18:17	379.9		0.12	0.71	
12						

Relative Accuracy Test Data
Reference Method Results (NH_3)
General Electric, 7F.05, Unit #U-00002

Parameter:	Ammonia
Date of Test:	February 25, 2020
Reference Method:	EPA Method 027
RM Analyzer Type:	Fourier Transform infared
Manufacturer:	MKS
Model #:	2030
Serial #:	INST-IR-0004

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	11:53 - 12:13	346.6		0.66	2.20	
2	12:32 - 12:52	345.9		0.85	2.83	
3	13:07 - 13:27	345.4		0.87	2.88	
4	13:36 - 13:56	345.6		0.68	2.26	
5	14:15 - 14:35	345.4		0.87	2.87	
6	14:46 - 15:06	345.5		0.66	2.19	
7	15:17 - 15:37	345.3		0.66	2.17	
8	15:47 - 16:07	345.8		0.61	2.01	
9	16:20 - 16:40	373.2		0.48	1.73	
10	16:51 - 17:11	378.1		0.60	2.20	
11	17:57 - 18:17	379.9		1.53	5.62	
12						

Relative Accuracy Test Data
Reference Method Results (O_2)
General Electric, 7F.05, Unit #U-00002

Parameter:	Oxygen
Date of Test:	February 25, 2020
Reference Method:	EPA Method 3A
RM Analyzer Type:	Paramagnetic Cell
Manufacturer: Model #:	SERVOMEX 1440
Serial #:	INST-O2-0024

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	11:53 - 12:13	346.6	13.36
2	12:32 - 12:52	345.9	13.25
3	13:07 - 13:27	345.4	13.29
4	13:36 - 13:56	345.6	11.85
5	14:15 - 14:35	345.4	13.30
6	14:46 - 15:06	345.5	13.25
7	15:17 - 15:37	345.3	13.27
8	15:47 - 16:07	345.8	13.25
9	16:20 - 16:40	373.2	12.43
10	16:51 - 17:11	378.1	12.29
11	17:57 - 18:17	379.9	12.31
12			

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,317,550	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,317,550	SCFH

Weather Data

Barometric Pressure	29.38	in. Hg
Relative Humidity	51	%
Ambient Temperature	54	°F
Specific Humidity	0.004604	lb H_2O / lb air

Unit Data

Unit Load	346.6	megawatts
Stack Exhaust Flow (M19)	58,713,359	SCFH

Base Load Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 11:53:28	60	13.47	1.90	0.16	0.85	8.02
02/25/20 11:53:58	90	13.46	1.92	0.17	0.85	7.89
02/25/20 11:54:28	120	13.47	1.91	0.17	0.84	7.79
02/25/20 11:54:58	150	13.46	1.87	0.14	0.88	8.34
02/25/20 11:55:28	180	13.46	1.87	0.16	0.85	7.96
02/25/20 11:55:58	210	13.46	1.86	0.14	0.83	7.90
02/25/20 11:56:28	240	13.46	1.87	0.13	0.83	8.04
02/25/20 11:56:58	270	13.45	1.88	0.13	0.84	7.80
02/25/20 11:57:28	300	13.46	1.88	0.13	0.85	8.15
02/25/20 11:57:58	330	13.46	1.86	0.16	0.82	7.92
02/25/20 11:58:28	360	13.46	1.85	0.13	0.81	7.97
02/25/20 11:58:58	390	13.45	1.84	0.11	0.83	8.09
02/25/20 11:59:28	420	13.45	1.85	0.16	0.83	7.92
02/25/20 11:59:58	450	13.45	1.84	0.15	0.83	8.37
02/25/20 12:00:28	480	13.44	1.80	0.15	0.79	7.92
02/25/20 12:00:58	510	13.46	1.83	0.17	0.81	8.09
02/25/20 12:01:28	540	13.46	1.83	0.17	0.82	8.13
02/25/20 12:01:58	570	13.46	1.85	0.14	0.81	8.01
02/25/20 12:02:28	600	13.45	1.86	0.16	0.80	8.55
02/25/20 12:02:58	630	13.44	1.82	0.17	0.78	7.97
02/25/20 12:03:28	660	13.44	1.84	0.16	0.81	8.22
02/25/20 12:03:58	690	13.40	1.85	0.15	0.79	8.08
02/25/20 12:04:28	720	13.36	1.86	0.15	0.81	8.40
02/25/20 12:04:58	750	13.35	1.87	0.14	0.77	8.30
02/25/20 12:05:28	780	13.35	1.86	0.12	0.73	8.47
02/25/20 12:05:58	810	13.33	1.87	0.15	0.76	10.24
02/25/20 12:06:28	840	13.34	1.86	0.11	0.70	8.71
02/25/20 12:06:58	870	13.34	1.86	0.14	0.71	8.69
02/25/20 12:07:28	900	13.33	1.86	0.11	0.71	8.47
02/25/20 12:07:58	930	13.33	1.84	0.13	0.72	8.42
02/25/20 12:08:28	960	13.34	1.82	0.13	0.73	8.35
02/25/20 12:08:58	990	13.34	1.80	0.13	0.73	8.46
02/25/20 12:09:28	1020	13.34	1.82	0.13	0.72	8.70
02/25/20 12:09:58	1050	13.33	1.80	0.11	0.70	8.40
02/25/20 12:10:28	1080	13.34	1.83	0.13	0.71	8.48
02/25/20 12:10:58	1110	13.34	1.86	0.11	0.72	8.59
02/25/20 12:11:28	1140	13.34	1.86	0.14	0.72	8.38
02/25/20 12:11:58	1170	13.33	1.88	0.14	0.71	8.34
02/25/20 12:12:28	1200	13.33	1.85	0.18	0.73	8.64
02/25/20 12:12:58	1230	13.34	1.89	0.12	0.69	8.49
02/25/20 12:13:28	1260	13.34	1.87	0.15	0.71	8.39
02/25/20 12:13:58	1290	13.34	1.86	0.12	0.71	8.32
RAW AVERAGE		**13.40**	**1.85**	**0.14**	**0.78**	**8.30**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.03	0.02	0.05	
	Final Zero	-0.05	-0.53	-0.04	
	Avg. Zero	-0.04	-0.26	0.01	
	Initial UpScale	11.99	4.93	5.13	
	Final UpScale	12.02	4.83	5.14	
	Avg. UpScale	12.01	4.88	5.14	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.36	2.02	0.14	0.85
Concentration (ppm@ 15%O_2)	N/A	1.58	0.11	0.66
Emission Rate (lb/hr)	N/A	14.14	0.58	2.20
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,310,200	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,310,200	SCFH

Weather Data

Barometric Pressure	29.36	in. Hg
Relative Humidity	51	%
Ambient Temperature	55	°F
Specific Humidity	0.004760	lb H_2O / lb air

Unit Data

Unit Load	345.9	megawatts
Stack Exhaust Flow (M19)	57,751,340	SCFH

Base Load Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 12:32:28	2400	13.33	1.85	0.11	1.23	8.19
02/25/20 12:32:58	2430	13.33	1.85	0.13	1.18	8.16
02/25/20 12:33:28	2460	13.33	1.81	0.10	1.17	8.11
02/25/20 12:33:58	2490	13.33	1.80	0.13	1.18	8.09
02/25/20 12:34:28	2520	13.33	1.79	0.16	1.17	8.12
02/25/20 12:34:58	2550	13.34	1.78	0.12	1.17	8.15
02/25/20 12:35:28	2580	13.33	1.82	0.14	1.15	8.19
02/25/20 12:35:58	2610	13.33	1.81	0.13	1.15	8.18
02/25/20 12:36:28	2640	13.33	1.82	0.13	1.19	8.33
02/25/20 12:36:58	2670	13.33	1.82	0.12	1.22	8.37
02/25/20 12:37:28	2700	13.33	1.81	0.13	1.21	8.35
02/25/20 12:37:58	2730	13.33	1.77	0.12	1.15	8.33
02/25/20 12:38:28	2760	13.33	1.80	0.12	1.14	8.31
02/25/20 12:38:58	2790	13.34	1.79	0.11	1.15	8.31
02/25/20 12:39:28	2820	13.34	1.81	0.12	1.12	8.33
02/25/20 12:39:58	2850	13.33	1.81	0.13	1.13	8.32
02/25/20 12:40:28	2880	13.34	1.81	0.11	1.09	8.33
02/25/20 12:40:58	2910	13.34	1.81	0.11	1.02	8.36
02/25/20 12:41:28	2940	13.33	1.82	0.11	1.05	8.65
02/25/20 12:41:58	2970	13.33	1.87	0.12	1.03	8.57
02/25/20 12:42:28	3000	13.33	1.87	0.14	1.03	8.48
02/25/20 12:42:58	3030	13.33	1.88	0.15	1.03	8.44
02/25/20 12:43:28	3060	13.33	1.88	0.16	1.01	8.39
02/25/20 12:43:58	3090	13.33	1.85	0.13	0.97	8.38
02/25/20 12:44:28	3120	13.33	1.83	0.14	0.95	8.36
02/25/20 12:44:58	3150	13.33	1.85	0.15	0.96	8.32
02/25/20 12:45:28	3180	13.31	1.88	0.14	0.95	8.28
02/25/20 12:45:58	3210	13.28	1.90	0.12	0.99	8.26
02/25/20 12:46:28	3240	13.25	1.87	0.12	0.95	8.22
02/25/20 12:46:58	3270	13.24	1.85	0.13	0.90	8.28
02/25/20 12:47:28	3300	13.22	1.77	0.11	0.88	8.31
02/25/20 12:47:58	3330	13.22	1.68	0.11	0.83	8.33
02/25/20 12:48:28	3360	13.22	1.63	0.11	0.82	8.34
02/25/20 12:48:58	3390	13.21	1.56	0.13	0.79	8.39
02/25/20 12:49:28	3420	13.22	1.48	0.13	0.77	8.44
02/25/20 12:49:58	3450	13.25	1.45	0.16	0.82	8.45
02/25/20 12:50:28	3480	13.29	1.41	0.12	0.80	8.42
02/25/20 12:50:58	3510	13.31	1.37	0.11	0.77	8.33
02/25/20 12:51:28	3540	13.33	1.33	0.11	0.87	8.23
02/25/20 12:51:58	3570	13.35	1.31	0.14	0.85	8.23
02/25/20 12:52:28	3600	13.36	1.27	0.13	0.86	8.20
02/25/20 12:52:58	3630	13.37	1.26	0.12	0.91	8.18
RAW AVERAGE		**13.31**	**1.72**	**0.43**	**1.01**	**8.31**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.05	-0.53	-0.04	
	Final Zero	0.00	-0.35	-0.04	
	Avg. Zero	-0.03	-0.44	-0.04	
	Initial UpScale	12.02	4.83	5.14	
	Final UpScale	12.02	4.94	5.09	
	Avg. UpScale	12.02	4.89	5.12	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.25	2.00	0.46	1.11
Concentration (ppm@ 15%O_2)	N/A	1.54	0.35	0.85
Emission Rate (lb/hr)	N/A	13.77	1.93	2.83
Emission Rate (lb/MMBtu)	N/A	0.0057	0.001	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,308,160	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,308,160	SCFH

Weather Data

Barometric Pressure	29.34	in. Hg
Relative Humidity	49	%
Ambient Temperature	55	°F
Specific Humidity	0.004540	lb H_2O / lb air

Unit Data

Unit Load	345.4	megawatts
Stack Exhaust Flow (M19)	57,955,701	SCFH

Base Load Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 13:07:28	4500	13.27	1.90	0.13	1.17	7.19
02/25/20 13:07:58	4530	13.28	1.89	0.15	1.07	7.22
02/25/20 13:08:28	4560	13.29	1.86	0.13	1.03	7.28
02/25/20 13:08:58	4590	13.30	1.88	0.18	1.08	7.35
02/25/20 13:09:28	4620	13.30	1.88	0.17	1.06	7.40
02/25/20 13:09:58	4650	13.32	1.88	0.16	1.06	7.43
02/25/20 13:10:28	4680	13.33	1.87	0.15	1.06	7.50
02/25/20 13:10:58	4710	13.31	1.86	0.12	1.05	7.52
02/25/20 13:11:28	4740	13.32	1.86	0.13	1.07	8.62
02/25/20 13:11:58	4770	13.33	1.87	0.10	1.03	8.32
02/25/20 13:12:28	4800	13.33	1.89	0.12	1.09	9.15
02/25/20 13:12:58	4830	13.33	1.87	0.12	1.03	9.36
02/25/20 13:13:28	4860	13.34	1.86	0.12	1.02	8.82
02/25/20 13:13:58	4890	13.34	1.88	0.12	1.00	8.74
02/25/20 13:14:28	4920	13.34	1.87	0.14	0.98	8.35
02/25/20 13:14:58	4950	13.34	1.86	0.11	1.03	8.94
02/25/20 13:15:28	4980	13.34	1.82	0.13	1.00	8.18
02/25/20 13:15:58	5010	13.34	1.85	0.14	0.98	8.27
02/25/20 13:16:28	5040	13.35	1.82	0.12	0.99	8.23
02/25/20 13:16:58	5070	13.34	1.82	0.13	0.97	7.99
02/25/20 13:17:28	5100	13.36	1.82	0.11	1.02	8.43
02/25/20 13:17:58	5130	13.35	1.83	0.12	0.99	8.20
02/25/20 13:18:28	5160	13.35	1.82	0.14	1.01	8.29
02/25/20 13:18:58	5190	13.35	1.78	0.13	1.02	8.60
02/25/20 13:19:28	5220	13.35	1.82	0.12	0.99	8.11
02/25/20 13:19:58	5250	13.35	1.80	0.11	1.02	8.31
02/25/20 13:20:28	5280	13.35	1.75	0.11	1.00	8.16
02/25/20 13:20:58	5310	13.34	1.75	0.12	1.01	7.96
02/25/20 13:21:28	5340	13.35	1.75	0.11	1.07	8.60
02/25/20 13:21:58	5370	13.34	1.77	0.13	0.99	8.13
02/25/20 13:22:28	5400	13.35	1.78	0.15	1.02	7.96
02/25/20 13:22:58	5430	13.35	1.79	0.11	1.02	8.38
02/25/20 13:23:28	5460	13.34	1.85	0.13	1.01	8.02
02/25/20 13:23:58	5490	13.35	1.89	0.10	1.01	7.95
02/25/20 13:24:28	5520	13.35	1.94	0.13	1.07	8.65
02/25/20 13:24:58	5550	13.35	2.00	0.11	1.02	8.06
02/25/20 13:25:28	5580	13.35	2.10	0.13	1.06	8.09
02/25/20 13:25:58	5610	13.34	2.13	0.12	1.04	8.34
02/25/20 13:26:28	5640	13.35	2.23	0.12	1.08	7.96
02/25/20 13:26:58	5670	13.36	2.29	0.12	1.07	8.15
02/25/20 13:27:28	5700	13.35	2.35	0.08	1.07	8.38
02/25/20 13:27:58	5730	13.35	2.40	0.13	1.03	8.00
RAW AVERAGE		**13.34**	**1.90**	**0.13**	**1.03**	**8.16**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	0.00	-0.35	-0.04	
	Final Zero	-0.04	-0.01	-0.04	
	Avg. Zero	-0.02	-0.18	-0.04	
	Initial UpScale	12.02	4.94	5.09	
	Final UpScale	12.01	4.92	5.08	
	Avg. UpScale	12.01	4.93	5.09	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.29	2.00	0.16	1.13
Concentration (ppm@ 15%O_2)	N/A	1.55	0.13	0.87
Emission Rate (lb/hr)	N/A	13.85	0.69	2.88
Emission Rate (lb/MMBtu)	N/A	0.0057	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,308,570	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,308,570	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	48	%
Ambient Temperature	56	°F
Specific Humidity	0.004504	lb H_2O / lb air

Unit Data

Unit Load	345.6	megawatts
Stack Exhaust Flow (M19)	48,756,000	SCFH

Base Load Load, Run - 4

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 13:36:28	6240	13.30	2.02	0.12	1.11	7.00
02/25/20 13:36:58	6270	13.32	2.01	0.14	1.05	7.11
02/25/20 13:37:28	6300	13.32	2.01	0.15	1.00	7.17
02/25/20 13:37:58	6330	13.34	1.98	0.16	0.98	7.20
02/25/20 13:38:28	6360	13.34	1.99	0.13	1.01	7.24
02/25/20 13:38:58	6390	13.33	1.97	0.12	0.97	7.31
02/25/20 13:39:28	6420	13.35	2.02	0.12	1.03	8.43
02/25/20 13:39:58	6450	13.34	2.01	0.13	0.99	8.42
02/25/20 13:40:28	6480	13.35	2.02	0.13	0.99	8.10
02/25/20 13:40:58	6510	13.36	2.05	0.10	1.02	10.02
02/25/20 13:41:28	6540	13.35	2.08	0.11	0.96	8.79
02/25/20 13:41:58	6570	13.35	2.13	0.13	0.96	8.58
02/25/20 13:42:28	6600	13.36	2.18	0.14	0.97	8.43
02/25/20 13:42:58	6630	13.36	2.23	0.12	0.94	8.21
02/25/20 13:43:28	6660	13.36	2.25	0.12	0.98	8.14
02/25/20 13:43:58	6690	13.36	2.28	0.13	0.97	8.11
02/25/20 13:44:28	6720	13.35	2.31	0.11	0.98	8.09
02/25/20 13:44:58	6750	13.36	2.36	0.12	0.96	8.08
02/25/20 13:45:28	6780	13.37	2.37	0.10	0.93	8.08
02/25/20 13:45:58	6810	13.36	2.37	0.12	0.97	8.08
02/25/20 13:46:28	6840	13.36	2.38	0.13	0.99	8.07
02/25/20 13:46:58	6870	13.37	2.36	0.12	0.94	8.08
02/25/20 13:47:28	6900	13.37	2.37	0.11	0.96	8.06
02/25/20 13:47:58	6930	13.37	2.33	0.10	0.96	8.05
02/25/20 13:48:28	6960	13.37	2.31	0.13	0.98	8.05
02/25/20 13:48:58	6990	13.36	2.26	0.08	0.94	8.03
02/25/20 13:49:28	7020	13.37	2.21	0.10	0.91	8.03
02/25/20 13:49:58	7050	13.36	2.19	0.10	0.90	8.02
02/25/20 13:50:28	7080	13.37	2.18	0.12	0.91	8.03
02/25/20 13:50:58	7110	13.38	2.08	0.09	0.93	8.00
02/25/20 13:51:28	7140	13.38	2.06	0.12	0.92	7.98
02/25/20 13:51:58	7170	13.39	2.06	0.10	0.94	7.98
02/25/20 13:52:28	7200	13.39	2.06	0.12	0.92	8.01
02/25/20 13:52:58	7230	13.38	2.03	0.11	0.94	8.05
02/25/20 13:53:28	7260	13.38	2.02	0.12	0.92	8.08
02/25/20 13:53:58	7290	13.39	2.01	0.10	0.93	8.16
02/25/20 13:54:28	7320	13.39	2.03	0.10	0.93	8.16
02/25/20 13:54:58	7350	13.39	2.07	0.11	0.93	8.13
02/25/20 13:55:28	7380	13.38	2.09	0.10	0.96	8.09
02/25/20 13:55:58	7410	13.39	2.13	0.12	0.95	8.06
02/25/20 13:56:28	7440	13.38	2.18	0.12	0.96	8.05
02/25/20 13:56:58	7470	13.38	2.26	0.12	1.00	8.02
RAW AVERAGE		**11.91**	**2.44**	**0.74**	**0.96**	**8.04**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.04	-0.01	-0.04	
	Final Zero	-0.02	0.03	-0.05	
	Avg. Zero	-0.03	0.01	-0.05	
	Initial UpScale	12.01	4.92	5.08	
	Final UpScale	12.05	4.96	5.08	
	Avg. UpScale	12.03	4.94	5.08	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	11.85	2.42	0.78	1.05
Concentration (ppm@ 15%O_2)	N/A	1.58	0.51	0.68
Emission Rate (lb/hr)	N/A	14.11	2.76	2.26
Emission Rate (lb/MMBtu)	N/A	0.0058	0.001	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,306,530	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,306,530	SCFH

Weather Data

Barometric Pressure	29.30	in. Hg
Relative Humidity	45	%
Ambient Temperature	59	°F
Specific Humidity	0.004816	lb H_2O / lb air

Unit Data

Unit Load	345.4	megawatts
Stack Exhaust Flow (M19)	57,994,954	SCFH

Base Load Load, Run - 5

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 14:15:28	8580	13.40	2.24	0.10	1.11	7.92
02/25/20 14:15:58	8610	13.41	2.26	0.13	1.11	7.90
02/25/20 14:16:28	8640	13.40	2.27	0.12	1.13	7.94
02/25/20 14:16:58	8670	13.42	2.33	0.10	1.09	7.95
02/25/20 14:17:28	8700	13.41	2.29	0.13	1.09	7.95
02/25/20 14:17:58	8730	13.40	2.26	0.12	1.08	7.94
02/25/20 14:18:28	8760	13.40	2.26	0.09	1.07	7.95
02/25/20 14:18:58	8790	13.40	2.27	0.13	1.06	7.96
02/25/20 14:19:28	8820	13.40	2.26	0.11	1.06	7.95
02/25/20 14:19:58	8850	13.39	2.22	0.13	1.04	7.94
02/25/20 14:20:28	8880	13.39	2.20	0.10	1.02	7.94
02/25/20 14:20:58	8910	13.39	2.15	0.11	1.02	7.96
02/25/20 14:21:28	8940	13.39	2.14	0.12	1.04	7.88
02/25/20 14:21:58	8970	13.39	2.05	0.12	1.06	7.97
02/25/20 14:22:28	9000	13.39	1.94	0.10	1.11	9.26
02/25/20 14:22:58	9030	13.39	1.84	0.11	1.04	8.64
02/25/20 14:23:28	9060	13.39	1.77	0.10	0.99	8.17
02/25/20 14:23:58	9090	13.38	1.73	0.12	1.03	8.13
02/25/20 14:24:28	9120	13.38	1.71	0.10	1.05	8.10
02/25/20 14:24:58	9150	13.39	1.67	0.11	1.02	8.08
02/25/20 14:25:28	9180	13.39	1.67	0.08	0.98	8.10
02/25/20 14:25:58	9210	13.38	1.65	0.10	0.99	8.12
02/25/20 14:26:28	9240	13.39	1.65	0.11	0.99	8.11
02/25/20 14:26:58	9270	13.39	1.65	0.10	0.99	8.09
02/25/20 14:27:28	9300	13.39	1.71	0.10	1.00	8.11
02/25/20 14:27:58	9330	13.39	1.71	0.10	1.08	9.45
02/25/20 14:28:28	9360	13.39	1.71	0.11	0.94	8.50
02/25/20 14:28:58	9390	13.39	1.70	0.09	0.99	8.26
02/25/20 14:29:28	9420	13.39	1.74	0.12	0.98	8.23
02/25/20 14:29:58	9450	13.38	1.78	0.11	1.00	8.19
02/25/20 14:30:28	9480	13.38	1.82	0.13	0.98	8.20
02/25/20 14:30:58	9510	13.38	1.92	0.08	0.95	8.20
02/25/20 14:31:28	9540	13.38	1.91	0.12	1.02	8.19
02/25/20 14:31:58	9570	13.38	1.97	0.12	1.00	8.16
02/25/20 14:32:28	9600	13.37	2.01	0.12	1.02	8.13
02/25/20 14:32:58	9630	13.38	2.02	0.11	0.94	8.13
02/25/20 14:33:28	9660	13.39	2.07	0.08	1.03	8.13
02/25/20 14:33:58	9690	13.39	2.09	0.12	1.02	8.20
02/25/20 14:34:28	9720	13.38	2.12	0.08	0.99	8.23
02/25/20 14:34:58	9750	13.38	2.12	0.10	1.03	8.27
02/25/20 14:35:28	9780	13.38	2.11	0.08	1.01	8.26
02/25/20 14:35:58	9810	13.38	2.11	0.11	1.00	8.25
RAW AVERAGE		**13.39**	**1.98**	**0.11**	**1.03**	**8.17**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	0.03	-0.05	
	Final Zero	-0.02	0.06	-0.08	
	Avg. Zero	-0.02	0.05	-0.07	
	Initial UpScale	12.05	4.96	5.08	
	Final UpScale	12.05	4.94	5.04	
	Avg. UpScale	12.05	4.95	5.06	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.30	1.94	0.17	1.12
Concentration (ppm@ 15%O_2)	N/A	1.50	0.13	0.87
Emission Rate (lb/hr)	N/A	13.41	0.72	2.87
Emission Rate (lb/MMBtu)	N/A	0.0055	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,306,940	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,306,940	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	48	%
Ambient Temperature	56	°F
Specific Humidity	0.004585	lb H_2O / lb air

Unit Data

Unit Load	345.5	megawatts
Stack Exhaust Flow (M19)	57,620,510	SCFH

Base Load Load, Run - 6

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 14:46:28	10440	13.30	2.13	0.10	0.85	7.13
02/25/20 14:46:58	10470	13.30	2.03	0.12	0.83	7.15
02/25/20 14:47:28	10500	13.30	1.98	0.11	0.83	7.25
02/25/20 14:47:58	10530	13.31	1.93	0.12	0.82	7.35
02/25/20 14:48:28	10560	13.31	1.91	0.10	0.80	7.40
02/25/20 14:48:58	10590	13.32	1.87	0.08	0.80	7.83
02/25/20 14:49:28	10620	13.32	1.85	0.10	0.81	8.04
02/25/20 14:49:58	10650	13.33	1.85	0.10	0.78	7.85
02/25/20 14:50:28	10680	13.34	1.89	0.11	0.82	8.73
02/25/20 14:50:58	10710	13.34	1.91	0.07	0.83	9.89
02/25/20 14:51:28	10740	13.32	1.86	0.09	0.78	8.84
02/25/20 14:51:58	10770	13.31	1.87	0.07	0.82	8.69
02/25/20 14:52:28	10800	13.31	1.88	0.09	0.74	8.51
02/25/20 14:52:58	10830	13.32	1.87	0.10	0.74	8.25
02/25/20 14:53:28	10860	13.33	1.86	0.08	0.69	8.19
02/25/20 14:53:58	10890	13.32	2.09	0.09	0.74	8.39
02/25/20 14:54:28	10920	13.32	1.85	0.08	0.75	8.42
02/25/20 14:54:58	10950	13.32	2.21	0.11	0.74	8.33
02/25/20 14:55:28	10980	13.32	1.87	0.09	0.75	8.25
02/25/20 14:55:58	11010	13.31	1.87	0.23	0.75	8.18
02/25/20 14:56:28	11040	13.33	1.87	0.09	0.78	8.50
02/25/20 14:56:58	11070	13.32	1.86	0.09	0.75	8.32
02/25/20 14:57:28	11100	13.33	1.86	0.09	0.73	8.23
02/25/20 14:57:58	11130	13.32	1.77	0.10	0.78	8.34
02/25/20 14:58:28	11160	13.33	1.71	0.10	0.78	9.06
02/25/20 14:58:58	11190	13.33	1.71	0.10	0.81	10.71
02/25/20 14:59:28	11220	13.33	1.72	0.08	0.76	8.66
02/25/20 14:59:58	11250	13.33	1.70	0.08	0.75	8.53
02/25/20 15:00:28	11280	13.33	1.70	0.10	0.77	8.41
02/25/20 15:00:58	11310	13.33	1.70	0.07	0.78	8.35
02/25/20 15:01:28	11340	13.33	1.70	0.12	0.78	8.28
02/25/20 15:01:58	11370	13.33	1.74	0.08	0.82	8.50
02/25/20 15:02:28	11400	13.33	1.75	0.08	0.82	8.42
02/25/20 15:02:58	11430	13.32	1.81	0.12	0.82	8.31
02/25/20 15:03:28	11460	13.32	1.84	0.10	0.81	8.29
02/25/20 15:03:58	11490	13.33	1.84	0.80	0.79	8.23
02/25/20 15:04:28	11520	13.33	2.01	0.22	0.76	8.18
02/25/20 15:04:58	11550	13.33	1.90	0.25	0.80	8.21
02/25/20 15:05:28	11580	13.33	1.96	0.08	0.79	8.72
02/25/20 15:05:58	11610	13.33	1.91	0.08	0.81	8.45
02/25/20 15:06:28	11640	13.32	1.97	0.13	0.91	10.39
02/25/20 15:06:58	11670	13.33	1.95	0.08	0.90	8.51
RAW AVERAGE		**13.32**	**1.87**	**0.12**	**0.79**	**8.39**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	0.06	-0.08	
	Final Zero	-0.06	0.02	-0.11	
	Avg. Zero	-0.04	0.04	-0.10	
	Initial UpScale	12.05	4.94	5.04	
	Final UpScale	12.02	4.92	5.07	
	Avg. UpScale	12.04	4.93	5.06	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.25	1.84	0.21	0.86
Concentration (ppm@ 15%O_2)	N/A	1.42	0.16	0.66
Emission Rate (lb/hr)	N/A	12.65	0.89	2.19
Emission Rate (lb/MMBtu)	N/A	0.0052	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,305,710	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,305,710	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	50	%
Ambient Temperature	56	°F
Specific Humidity	0.004805	lb H_2O / lb air

Unit Data

Unit Load	345.3	megawatts
Stack Exhaust Flow (M19)	57,735,796	SCFH

Base Load Load, Run - 7

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 15:17:28	12300	13.28	2.07	0.10	0.85	7.57
02/25/20 15:17:58	12330	13.29	2.05	0.11	0.86	7.57
02/25/20 15:18:28	12360	13.29	2.07	0.10	0.84	7.56
02/25/20 15:18:58	12390	13.29	2.06	0.11	0.81	7.56
02/25/20 15:19:28	12420	13.30	2.07	0.09	0.82	7.54
02/25/20 15:19:58	12450	13.32	2.06	0.07	0.79	7.51
02/25/20 15:20:28	12480	13.32	2.07	0.09	0.85	8.68
02/25/20 15:20:58	12510	13.33	2.07	0.10	0.93	10.81
02/25/20 15:21:28	12540	13.32	2.12	0.09	0.80	9.36
02/25/20 15:21:58	12570	13.32	2.12	0.10	0.73	8.61
02/25/20 15:22:28	12600	13.32	2.08	0.11	0.79	8.34
02/25/20 15:22:58	12630	13.32	2.05	0.06	0.81	8.15
02/25/20 15:23:28	12660	13.32	2.03	0.08	0.78	8.11
02/25/20 15:23:58	12690	13.32	2.02	0.08	0.80	8.08
02/25/20 15:24:28	12720	13.33	2.03	0.09	0.81	8.07
02/25/20 15:24:58	12750	13.32	2.04	0.08	0.84	8.05
02/25/20 15:25:28	12780	13.32	2.01	0.08	0.84	8.03
02/25/20 15:25:58	12810	13.32	1.95	0.07	0.78	8.07
02/25/20 15:26:28	12840	13.33	1.91	0.06	0.79	8.12
02/25/20 15:26:58	12870	13.33	1.89	0.08	0.77	8.20
02/25/20 15:27:28	12900	13.34	1.87	0.08	0.77	8.21
02/25/20 15:27:58	12930	13.34	1.91	0.16	0.72	8.21
02/25/20 15:28:28	12960	13.33	3.05	0.41	0.72	8.22
02/25/20 15:28:58	12990	13.32	1.80	0.07	0.71	8.23
02/25/20 15:29:28	13020	13.33	1.87	0.06	0.72	8.23
02/25/20 15:29:58	13050	13.33	1.82	0.08	0.73	8.22
02/25/20 15:30:28	13080	13.33	1.82	0.08	0.71	8.19
02/25/20 15:30:58	13110	13.33	1.80	0.09	0.74	8.16
02/25/20 15:31:28	13140	13.33	1.81	0.09	0.72	8.18
02/25/20 15:31:58	13170	13.33	1.82	0.07	0.75	8.98
02/25/20 15:32:28	13200	13.35	1.84	0.08	0.73	9.13
02/25/20 15:32:58	13230	13.33	1.77	0.10	0.74	8.33
02/25/20 15:33:28	13260	13.33	1.76	0.06	0.74	8.30
02/25/20 15:33:58	13290	13.32	1.80	0.07	0.73	8.24
02/25/20 15:34:28	13320	13.32	1.79	0.07	0.77	8.18
02/25/20 15:34:58	13350	13.33	1.88	0.07	0.77	8.16
02/25/20 15:35:28	13380	13.33	1.92	0.07	0.80	8.13
02/25/20 15:35:58	13410	13.33	1.96	0.05	0.76	8.15
02/25/20 15:36:28	13440	13.32	1.97	0.05	0.77	8.18
02/25/20 15:36:58	13470	13.33	2.02	0.06	0.73	8.20
02/25/20 15:37:28	13500	13.33	2.09	0.07	0.80	9.01
02/25/20 15:37:58	13530	13.33	2.11	0.06	0.78	8.34
RAW AVERAGE		**13.32**	**1.98**	**0.09**	**0.78**	**8.27**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.06	0.02	-0.11	
	Final Zero	-0.06	0.06	-0.07	
	Avg. Zero	-0.06	0.04	-0.09	
	Initial UpScale	12.02	4.92	5.07	
	Final UpScale	12.01	4.94	5.09	
	Avg. UpScale	12.02	4.93	5.08	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.27	1.95	0.18	0.85
Concentration (ppm@ 15%O_2)	N/A	1.51	0.14	0.66
Emission Rate (lb/hr)	N/A	13.45	0.74	2.17
Emission Rate (lb/MMBtu)	N/A	0.0056	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,311,140	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,311,140	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	51	%
Ambient Temperature	55	°F
Specific Humidity	0.004759	lb H_2O / lb air

Unit Data

Unit Load	345.8	megawatts
Stack Exhaust Flow (M19)	57,743,475	SCFH

Base Load Load, Run - 8

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 15:47:28	14100	13.25	2.11	0.11	0.82	7.35
02/25/20 15:47:58	14130	13.26	2.12	0.12	0.78	7.43
02/25/20 15:48:28	14160	13.26	2.12	0.10	0.75	7.47
02/25/20 15:48:58	14190	13.28	2.12	0.12	0.77	7.50
02/25/20 15:49:28	14220	13.29	2.11	0.10	0.76	7.51
02/25/20 15:49:58	14250	13.29	2.06	0.07	0.74	7.53
02/25/20 15:50:28	14280	13.29	2.06	0.06	0.75	7.54
02/25/20 15:50:58	14310	13.31	2.07	0.08	0.77	7.56
02/25/20 15:51:28	14340	13.32	2.07	0.09	0.74	7.57
02/25/20 15:51:58	14370	13.32	2.06	0.07	0.76	8.67
02/25/20 15:52:28	14400	13.32	2.06	0.08	0.69	8.08
02/25/20 15:52:58	14430	13.32	2.07	0.62	0.77	9.79
02/25/20 15:53:28	14460	13.32	2.09	0.07	0.70	8.72
02/25/20 15:53:58	14490	13.32	2.06	0.10	0.76	8.63
02/25/20 15:54:28	14520	13.32	2.06	0.07	0.76	8.40
02/25/20 15:54:58	14550	13.33	2.07	0.08	0.76	8.27
02/25/20 15:55:28	14580	13.33	2.07	0.08	0.73	8.08
02/25/20 15:55:58	14610	13.34	2.06	0.07	0.71	8.45
02/25/20 15:56:28	14640	13.33	2.05	0.06	0.74	8.07
02/25/20 15:56:58	14670	13.32	2.07	0.08	0.70	8.13
02/25/20 15:57:28	14700	13.32	2.07	0.08	0.70	8.25
02/25/20 15:57:58	14730	13.33	2.07	0.09	0.71	8.05
02/25/20 15:58:28	14760	13.33	2.08	0.07	0.71	8.49
02/25/20 15:58:58	14790	13.34	2.06	0.08	0.72	8.16
02/25/20 15:59:28	14820	13.33	2.05	0.10	0.72	8.10
02/25/20 15:59:58	14850	13.33	2.09	0.11	0.70	8.27
02/25/20 16:00:28	14880	13.33	2.07	0.08	0.68	7.99
02/25/20 16:00:58	14910	13.33	2.04	0.07	0.71	8.21
02/25/20 16:01:28	14940	13.33	2.05	0.06	0.69	8.04
02/25/20 16:01:58	14970	13.33	2.07	0.08	0.67	7.92
02/25/20 16:02:28	15000	13.33	2.07	0.05	0.70	8.38
02/25/20 16:02:58	15030	13.33	2.07	0.08	0.70	8.14
02/25/20 16:03:28	15060	13.33	2.07	0.06	0.73	8.21
02/25/20 16:03:58	15090	13.33	2.07	0.07	0.75	8.45
02/25/20 16:04:28	15120	13.33	2.07	0.09	0.75	8.04
02/25/20 16:04:58	15150	13.34	2.06	0.08	0.73	8.31
02/25/20 16:05:28	15180	13.33	2.54	0.09	0.69	8.21
02/25/20 16:05:58	15210	13.33	2.05	0.07	0.69	8.06
02/25/20 16:06:28	15240	13.33	2.17	0.47	0.70	8.45
02/25/20 16:06:58	15270	13.33	2.01	0.12	0.65	8.05
02/25/20 16:07:28	15300	13.14	2.09	0.13	0.67	8.28
02/25/20 16:07:58	15330	13.16	2.12	0.07	0.66	8.22
RAW AVERAGE		**13.31**	**2.09**	**0.11**	**0.72**	**8.12**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.06	0.06	-0.07	
	Final Zero	-0.04	0.01	-0.09	
	Avg. Zero	-0.05	0.04	-0.08	
	Initial UpScale	12.01	4.94	5.09	
	Final UpScale	12.03	4.94	5.08	
	Avg. UpScale	12.02	4.94	5.09	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.25	2.05	0.18	0.79
Concentration (ppm@ 15%O_2)	N/A	1.58	0.14	0.61
Emission Rate (lb/hr)	N/A	14.15	0.77	2.01
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,528,440	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,528,440	SCFH

Weather Data

Barometric Pressure	29.33	in. Hg
Relative Humidity	54	%
Ambient Temperature	55	°F
Specific Humidity	0.004894	lb H_2O / lb air

Unit Data

Unit Load	373.2	megawatts
Stack Exhaust Flow (M19)	57,042,226	SCFH

Base Load Load, Run - 9

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 16:20:28	16080	12.72	2.35	0.06	0.65	9.20
02/25/20 16:20:58	16110	12.72	2.36	0.05	0.67	9.97
02/25/20 16:21:28	16140	12.70	2.31	0.04	0.63	9.56
02/25/20 16:21:58	16170	12.69	2.36	0.05	0.60	9.03
02/25/20 16:22:28	16200	12.68	2.36	0.05	0.61	8.78
02/25/20 16:22:58	16230	12.66	2.32	0.07	0.60	8.56
02/25/20 16:23:28	16260	12.62	2.32	0.05	0.61	8.71
02/25/20 16:23:58	16290	12.58	2.32	0.08	0.61	8.90
02/25/20 16:24:28	16320	12.58	2.33	0.08	0.57	9.03
02/25/20 16:24:58	16350	12.59	2.35	0.04	0.53	8.80
02/25/20 16:25:28	16380	12.58	2.41	0.07	0.60	8.91
02/25/20 16:25:58	16410	12.58	2.42	0.06	0.56	8.69
02/25/20 16:26:28	16440	12.55	2.43	0.09	0.58	8.87
02/25/20 16:26:58	16470	12.53	2.41	0.05	0.57	8.61
02/25/20 16:27:28	16500	12.52	2.42	0.08	0.56	8.87
02/25/20 16:27:58	16530	12.53	2.42	0.10	0.56	8.76
02/25/20 16:28:28	16560	12.51	2.43	0.09	0.58	9.26
02/25/20 16:28:58	16590	12.50	2.41	0.07	0.54	8.80
02/25/20 16:29:28	16620	12.49	2.41	0.05	0.57	9.00
02/25/20 16:29:58	16650	12.49	2.41	0.08	0.57	8.97
02/25/20 16:30:28	16680	12.48	2.41	0.09	0.60	8.87
02/25/20 16:30:58	16710	12.47	2.35	0.09	0.55	8.81
02/25/20 16:31:28	16740	12.46	2.35	0.06	0.58	9.05
02/25/20 16:31:58	16770	12.45	2.39	0.06	0.64	9.83
02/25/20 16:32:28	16800	12.45	2.41	0.08	0.62	9.03
02/25/20 16:32:58	16830	12.43	2.42	0.07	0.60	9.28
02/25/20 16:33:28	16860	12.42	2.45	0.11	0.63	9.10
02/25/20 16:33:58	16890	12.41	2.48	0.10	0.62	9.51
02/25/20 16:34:28	16920	12.41	2.47	0.09	0.65	9.00
02/25/20 16:34:58	16950	12.39	2.45	0.08	0.65	8.91
02/25/20 16:35:28	16980	12.39	2.44	0.08	0.65	9.15
02/25/20 16:35:58	17010	12.39	2.42	0.12	0.62	8.98
02/25/20 16:36:28	17040	12.38	2.44	0.11	0.70	10.47
02/25/20 16:36:58	17070	12.37	2.41	0.09	0.66	9.55
02/25/20 16:37:28	17100	12.38	2.39	0.08	0.67	9.35
02/25/20 16:37:58	17130	12.37	2.35	0.10	0.67	9.09
02/25/20 16:38:28	17160	12.36	2.33	0.07	0.66	9.07
02/25/20 16:38:58	17190	12.38	2.33	0.07	0.71	9.00
02/25/20 16:39:28	17220	12.37	2.31	0.08	0.76	9.23
02/25/20 16:39:58	17250	12.37	2.39	0.09	0.71	9.19
02/25/20 16:40:28	17280	12.36	2.32	0.07	0.74	9.10
02/25/20 16:40:58	17310	12.37	2.31	0.10	0.71	9.25
RAW AVERAGE		**12.49**	**2.38**	**0.08**	**0.62**	**9.10**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.04	0.01	-0.09	
	Final Zero	-0.06	0.02	-0.07	
	Avg. Zero	-0.05	0.02	-0.08	
	Initial UpScale	12.03	4.94	5.08	
	Final UpScale	12.03	4.94	5.05	
	Avg. UpScale	12.03	4.94	5.07	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.43	2.36	0.15	0.69
Concentration (ppm@ 15%O_2)	N/A	1.65	0.11	0.48
Emission Rate (lb/hr)	N/A	16.10	0.64	1.73
Emission Rate (lb/MMBtu)	N/A	0.0061	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,554,920	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,554,920	SCFH

Weather Data

Barometric Pressure	29.34	in. Hg
Relative Humidity	57	%
Ambient Temperature	54	°F
Specific Humidity	0.005008	lb H_2O / lb air

Unit Data

Unit Load	378.1	megawatts
Stack Exhaust Flow (M19)	56,695,483	SCFH

Base Load Load, Run - 10

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 16:51:28	17940	12.31	2.31	0.12	0.77	8.03
02/25/20 16:51:58	17970	12.33	2.29	0.09	0.72	8.07
02/25/20 16:52:28	18000	12.32	2.28	0.09	0.69	8.14
02/25/20 16:52:58	18030	12.34	2.32	0.11	0.69	8.19
02/25/20 16:53:28	18060	12.35	2.33	0.10	0.74	10.22
02/25/20 16:53:58	18090	12.34	2.31	0.09	0.67	9.70
02/25/20 16:54:28	18120	12.36	2.35	0.09	0.64	9.67
02/25/20 16:54:58	18150	12.35	2.33	0.11	0.58	9.41
02/25/20 16:55:28	18180	12.37	2.31	0.09	0.58	9.04
02/25/20 16:55:58	18210	12.37	2.34	0.11	0.62	9.35
02/25/20 16:56:28	18240	12.36	2.31	0.10	0.61	8.93
02/25/20 16:56:58	18270	12.37	2.30	0.10	0.63	9.13
02/25/20 16:57:28	18300	12.37	2.29	0.16	0.65	9.00
02/25/20 16:57:58	18330	12.35	2.27	0.11	0.66	9.03
02/25/20 16:58:28	18360	12.34	2.26	0.08	0.66	9.03
02/25/20 16:58:58	18390	12.34	2.31	0.13	0.64	8.91
02/25/20 16:59:28	18420	12.32	2.31	0.13	0.60	8.92
02/25/20 16:59:58	18450	12.29	2.34	0.12	0.65	9.26
02/25/20 17:00:28	18480	12.29	2.36	0.11	0.67	9.15
02/25/20 17:00:58	18510	12.28	2.40	0.11	0.67	9.13
02/25/20 17:01:28	18540	12.28	2.40	0.11	0.67	9.09
02/25/20 17:01:58	18570	12.31	2.40	0.10	0.71	10.00
02/25/20 17:02:28	18600	12.32	2.33	0.11	0.74	9.49
02/25/20 17:02:58	18630	12.35	2.29	0.09	0.79	9.16
02/25/20 17:03:28	18660	12.35	2.27	0.08	0.80	9.20
02/25/20 17:03:58	18690	12.38	2.28	0.08	0.78	9.22
02/25/20 17:04:28	18720	12.38	2.22	0.07	0.81	9.88
02/25/20 17:04:58	18750	12.40	2.28	0.08	0.82	9.25
02/25/20 17:05:28	18780	12.37	2.20	0.04	0.90	10.10
02/25/20 17:05:58	18810	12.39	2.23	0.07	0.89	9.16
02/25/20 17:06:28	18840	12.37	2.21	0.08	0.98	9.22
02/25/20 17:06:58	18870	12.36	2.25	0.06	1.05	9.80
02/25/20 17:07:28	18900	12.35	2.28	0.06	1.05	9.36
02/25/20 17:07:58	18930	12.35	2.30	0.10	1.05	9.20
02/25/20 17:08:28	18960	12.33	2.32	0.08	1.03	9.33
02/25/20 17:08:58	18990	12.31	2.35	0.11	0.96	9.45
02/25/20 17:09:28	19020	12.31	2.38	0.09	1.04	9.99
02/25/20 17:09:58	19050	12.30	2.37	0.10	1.09	9.30
02/25/20 17:10:28	19080	12.32	2.40	0.09	1.10	9.38
02/25/20 17:10:58	19110	12.32	2.35	0.11	1.06	9.14
02/25/20 17:11:28	19140	12.33	2.31	0.07	1.01	9.15
02/25/20 17:11:58	19170	12.34	2.30	0.13	1.01	9.13
RAW AVERAGE		**12.34**	**2.31**	**0.10**	**0.80**	**9.22**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.06	0.02	-0.07	
	Final Zero	-0.08	-0.04	-0.07	
	Avg. Zero	-0.07	-0.01	-0.07	
	Initial UpScale	12.03	4.94	5.05	
	Final UpScale	12.01	4.89	5.04	
	Avg. UpScale	12.02	4.92	5.05	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.29	2.31	0.17	0.88
Concentration (ppm@ 15%O_2)	N/A	1.58	0.11	0.60
Emission Rate (lb/hr)	N/A	15.67	0.68	2.20
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.001

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,563,390	SCFH
Total Fuel Flow	2,563,390	SCFH

Weather Data

Barometric Pressure	29.37	in. Hg
Relative Humidity	76	%
Ambient Temperature	51	°F
Specific Humidity	0.006092	lb H_2O / lb air

Unit Data

Unit Load	379.9	megawatts
Stack Exhaust Flow (M19)	57,031,539	SCFH

Base Load Load, Run - 11

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
02/25/20 17:57:28	21900	12.37	2.36	0.07	2.52	9.25
02/25/20 17:57:58	21930	12.37	2.32	0.09	2.51	9.31
02/25/20 17:58:28	21960	12.36	2.35	0.07	2.39	9.15
02/25/20 17:58:58	21990	12.38	2.34	0.08	2.36	8.96
02/25/20 17:59:28	22020	12.37	2.32	0.07	2.44	9.24
02/25/20 17:59:58	22050	12.36	2.36	0.07	2.32	8.91
02/25/20 18:00:28	22080	12.35	2.36	0.05	2.29	8.98
02/25/20 18:00:58	22110	12.35	2.39	0.08	2.12	8.89
02/25/20 18:01:28	22140	12.34	2.37	0.07	2.04	8.70
02/25/20 18:01:58	22170	12.36	2.36	0.08	2.00	8.65
02/25/20 18:02:28	22200	12.35	2.36	0.08	2.04	8.49
02/25/20 18:02:58	22230	12.36	2.38	0.08	2.04	8.90
02/25/20 18:03:28	22260	12.36	2.36	0.07	1.90	8.59
02/25/20 18:03:58	22290	12.36	2.37	0.09	1.89	8.85
02/25/20 18:04:28	22320	12.36	2.42	0.09	1.91	9.02
02/25/20 18:04:58	22350	12.36	2.36	0.06	1.90	8.54
02/25/20 18:05:28	22380	12.37	2.37	0.07	1.88	8.76
02/25/20 18:05:58	22410	12.37	2.36	0.07	1.85	8.54
02/25/20 18:06:28	22440	12.38	2.41	0.07	1.90	9.14
02/25/20 18:06:58	22470	12.36	2.38	0.07	1.89	9.31
02/25/20 18:07:28	22500	12.37	2.37	0.08	1.78	8.56
02/25/20 18:07:58	22530	12.38	2.37	0.08	1.80	8.84
02/25/20 18:08:28	22560	12.37	2.32	0.07	1.72	8.53
02/25/20 18:08:58	22590	12.37	2.34	0.06	1.71	8.65
02/25/20 18:09:28	22620	12.37	2.35	0.07	1.76	9.69
02/25/20 18:09:58	22650	12.36	2.33	0.08	1.81	9.65
02/25/20 18:10:28	22680	12.36	2.33	0.08	1.90	9.07
02/25/20 18:10:58	22710	12.35	2.32	0.07	1.88	8.64
02/25/20 18:11:28	22740	12.35	2.43	0.06	2.03	10.70
02/25/20 18:11:58	22770	12.35	2.36	0.07	2.09	9.65
02/25/20 18:12:28	22800	12.35	2.35	0.08	2.45	9.96
02/25/20 18:12:58	22830	12.35	2.37	0.06	2.36	9.12
02/25/20 18:13:28	22860	12.35	2.40	0.10	2.25	9.48
02/25/20 18:13:58	22890	12.34	2.41	0.07	2.03	9.14
02/25/20 18:14:28	22920	12.34	2.33	0.09	2.00	8.84
02/25/20 18:14:58	22950	12.35	2.34	0.07	2.04	8.75
02/25/20 18:15:28	22980	12.34	2.32	0.08	2.01	8.58
02/25/20 18:15:58	23010	12.34	2.30	0.07	1.98	9.21
02/25/20 18:16:28	23040	12.34	2.31	0.07	1.79	8.77
02/25/20 18:16:58	23070	12.34	2.37	0.07	1.90	10.30
02/25/20 18:17:28	23100	12.34	2.37	0.07	1.87	10.57
02/25/20 18:17:58	23130	12.34	2.37	0.08	1.80	9.59
RAW AVERAGE		**12.36**	**2.36**	**0.07**	**2.03**	**9.11**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0024	INST-NX-0031	INST-CO-0029	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.08	-0.04	-0.07	
	Final Zero	-0.06	0.18	-0.13	
	Avg. Zero	-0.07	0.07	-0.10	
	Initial UpScale	12.01	4.89	5.04	
	Final UpScale	12.02	4.98	5.05	
	Avg. UpScale	12.02	4.94	5.05	
Upscale Cal Gas		11.97	4.91	5.09	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	12.31	2.31	0.17	2.23
Concentration (ppm@ 15%O_2)	N/A	1.59	0.12	1.53
Emission Rate (lb/hr)	N/A	15.73	0.71	5.62
Emission Rate (lb/MMBtu)	N/A	0.0058	0.000	0.006

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
AETB/QI and PGVP RATA Data Sheet
Cricket Valley Energy Center

AirEmissionTestingData - Level 3

QILastName	QIFirstName	QIMiddleInitial	AETBName	AETBPhoneNumber	AETBEmail	ExamDate	ProviderName	ProviderEmail
McBride	Matthew	S	Air Hygiene International Inc	888-461-8778	info@airhygiene.com	01/27/2019	Source Evaluation Society	qstiprogram@gmail.com

ProtocolGasData - Level 3

GasLevelCode	GasTypeCode	CylinderIdentifier	VendorIdentifier	ExpirationDate
LOW	ZERO			
HIGH	BALN,CO2,O2	CC721614	G12018	11/11/2026
MID	BALN,CO2,O2	CC722590	G12019	6/8/2027
HIGH	BALN,CO,NO,NOX	EB0018492	G12019	5/2/2022
MID	BALN,CO,NO,NOX	EB0065964	G12019	7/22/2022

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

CERTIFICATE OF ANALYSIS
(Zero Ambient Nitrogen)

Cylinder Number:	EB0072934	**Certification Date:**	05/21/2019
Product ID Number:	121026	**Expiration Date:**	05/19/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0072934.20190521-0	**Lot Number:**	EB0072934.20190521
Customer PO. NO.:		**Tracking Number:**	084249399
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
PGVP Vendor ID # G12019
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

Anthony Cyr
Assistant Operations Manager

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0098845	**Certification Date:**	05/03/2019
Product ID Number:	124731	**Expiration Date:**	05/02/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0098845.20190416-0	**Lot Number:**	EB0098845.20190416
Customer PO. NO.:		**Tracking Number:**	095689140
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	**48.7 PPM**	±0.6 PPM	FTIR	04/26/2019, 05/03/2019

Air Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003640	EB0003640.20190102	03/20/2022	GMIS	AIR	NO2	87.8 PPM	1.061	C1579010.01
EB0096848	EB0096848.20190102	03/21/2022	GMIS	AIR	NO2	61.1 PPM	1.072	C1579010.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/26/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0065964	**Certification Date:**	07/23/2019
Product ID Number:	125564	**Expiration Date:**	07/22/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0065964.20190611-0	**Lot Number:**	EB0065964.20190611
Customer PO. NO.:		**Tracking Number:**	083030934
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**5.09 PPM**	±0.07 PPM	FTIR	06/19/2019
Nitric Oxide	**4.88 PPM**	±0.06 PPM	Chemiluminescence	06/18/2019, 07/08/2019, 07/23/2019
Total Oxides of Nitrogen	4.91 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM066143	ALM066143.20171116	11/09/2022	GMIS	N2	NO	9.6 PPM	1.062	12100115
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0032297	EB0032297.20160725	09/06/2025	GMIS	N2	CO	6.15 PPM	1.067	091002
EB0060662	EB0060662.20151012	01/02/2022	GMIS	N2	NO	2.97 PPM	1.062	12100115
EB0078555	EB0078555.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.113	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	05/30/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	05/30/2019
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	07/08/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0018492	**Certification Date:**	05/03/2019
Product ID Number:	124737	**Expiration Date:**	05/02/2022
Cylinder Pressure:	1850 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0018492.20190404-0	**Lot Number:**	EB0018492.20190404
Customer PO. NO.:		**Tracking Number:**	040261874
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**9.5 PPM**	±0.11 PPM	FTIR	04/29/2019
Nitric Oxide	**9.2 PPM**	±0.11 PPM	Chemiluminescence	04/09/2019, 04/17/2019, 05/03/2019

Total Oxides of Nitrogen 9.2 PPM
Nitrogen Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC279029	091002	03/10/2020	NTRM	N2	CO	19.14 PPM	0.9927	091002
ALM066143	ALM066143.20171116	11/09/2022	GMIS	N2	NO	9.6 PPM	1.062	12100115
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
CC209392	CC209392.20180209	11/15/2021	GMIS	N2	NO	32.4 PPM	1.068	121001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	04/08/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	03/29/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC722590	**Certification Date:**	06/10/2019
Product ID Number:	124606	**Expiration Date:**	06/08/2027
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC722590.20190603-0	**Lot Number:**	CC722590.20190603
Customer PO. NO.:		**Tracking Number:**	098497708
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.98 %**	±0.08 %	NDIR	06/10/2019
Oxygen	**11.97 %**	±0.07 %	MPA	06/07/2019
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003672	EB0003672.20180118	07/21/2026	GMIS	N2	O2	11.97 %	0.507	071001
EB0049614	EB0049614.20180504	07/21/2026	GMIS	N2	O2	24 %	0.497	071001
EB0050249	EB0050249.20180323	07/15/2026	GMIS	N2	CO2	15 %	0.777	101001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	05/31/2019
CO2	NDIR	Thermo	410i	1162980025	05/14/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Jasmine Godfrey
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

RED BALL TECHNICAL GAS SERVICES

PJLA Calibration and Testing
Accreditation #62754

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC721614	**Certification Date:**	11/13/2018
Product ID Number:	124605	**Expiration Date:**	11/11/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC721614.20181109-0	**Lot Number:**	CC721614.20181109
Customer PO. NO.:		**Tracking Number:**	098499636
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**19.0 %**	±0.16 %	NDIR	11/13/2018
Oxygen	**21.0 %**	±0.12 %	MPA	11/13/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004987	EB0004987.20180323	07/15/2026	GMIS	N2	CO2	19.5 %	0.767	101001
EB0005996	EB0005996.20170209	05/09/2026	GMIS	N2	O2	20 %	0.077	071001
EB0032246	EB0032246.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	11/06/2018
CO2	NDIR	Thermo	410i	1162980025	10/24/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

CERTIFIED GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0100161	**Certification Date:**	12/30/2019
Product ID Number:	125123	**Expiration Date:**	12/29/2020
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0100161.20191230-0	**Lot Number:**	EB0100161.20191230
Customer PO. NO.:		**Tracking Number:**	095703088
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Ammonia	**50.4 PPM**	± 2% NIST	FTIR
Sulfur Hexafluoride	**9.02 PPM**	± 2% NIST	FTIR
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
SA18481	70086910005	04/12/2020	PS	N2	NH3	21.1 PPM	1.2	73248226
EB0079029	EB0079029	06/27/2020	PS	N2	SF6	10.1 PPM	5	191064

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NH3	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	
SF6	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-G, Revised on 2017-07-02

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the "hands of the test" on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the "hands of the test" on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3 A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

Data Provided by Client

Data provided by the Client is clearly identified in the report. Air Hygiene accepts data provided by the Client as accurate.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO_2 to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO_2 in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS
QUALITY ASSURANCE DATA

Date: February 25, 2020
Company: Cricket Valley Energy Center LLC
Location: Dover Plains, New York
Techs: MM / SB / RW

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
February 25, 2020	1	0

Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This laboratory also meets the A2LA *R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (*refer to joint ISO-ILAC-IAF Communiqué dated April 2017*).

Presented this 18th day of December 2019

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2021

For the tests to which this accreditation applies, please refer to the laboratory's Envrionmental Scope of Accreditation.

STAC
STACK TESTING ACCREDITATION COUNCIL

A2LA
American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.



Presented this 18th day of December 2019.

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2021

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

SOURCE EVALUATION SOCIETY

Qualified Source Testing Individual

LET IT BE KNOWN THAT

MATTHEW S. McBRIDE

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 27TH DAY OF JANAURY 2019 AND EFFECTIVE UNTIL JANUARY 26TH, 2024

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Tina Sanderson, QSTI/QSTO Review Board

J. Wade Bice, QSTI/QSTO Review Board

Karen D. Kajiya-Mills , QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board


CERTIFICATE NO. 2014-847

Calibration Date: February 25, 2020 **Location:** Cricket Valley Energy Center - Unit U-00002

Client: Cricket Valley Energy Center LLC


NOx Span (ppm) = 9.20

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.05	-0.54	0.05	YES (%)
4.91	5.09	1.96	0.18	YES (%)
9.20	9.28	0.87	0.08	YES (%)
Linearity = 0.985				




CO Span (ppm) = 9.50

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.01	-0.11	0.01	YES (%)
5.09	5.08	-0.11	0.01	YES (%)
9.50	9.62	1.26	0.12	YES (%)
Linearity = 0.987				



O_2 Span (%) = 21.00

SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	-0.01	-0.05	0.01	YES (%)
11.97	12.28	1.48	0.31	YES (%)
21.00	21.25	1.19	0.25	YES (%)
Linearity = 0.987				



NOx Converter Efficiency

Date: February 25, 2020

Analyzer: INST-NX-0031

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**48.70**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**1.40**
	Analyzer Reading, NOx Channel, ppmvd	**48.79**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**47.39**
	Converter Efficiency, %	**97.31**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{47.39 \text{ ppmvd}}{48.70 \text{ ppmvd}}$ x 100 = 97.31%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
02/25/20 05:10:12	380	48.20	1.54
02/25/20 05:10:22	390	48.62	1.58
02/25/20 05:10:32	400	48.69	1.51
02/25/20 05:10:42	410	48.69	1.50
02/25/20 05:10:52	420	48.73	1.50
02/25/20 05:11:02	430	48.78	1.54
02/25/20 05:11:12	440	48.74	1.39
02/25/20 05:11:22	***450***	***48.79***	***1.40***
02/25/20 05:11:32	460	48.76	1.42

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/25/20	10:50:28	BKG_0028.LAB	9.2175
02/25/20	10:50:42	BKG_0029.LAB	9.2171
02/25/20	10:50:56	BKG_0030.LAB	9.2332
02/25/20	10:51:10	BKG_0031.LAB	9.2632
02/25/20	10:51:23	BKG_0032.LAB	9.2413

PRE TEST AVERAGE **9.23**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
02/25/20	18:41:07	CTS_0013.LAB	9.1965
02/25/20	18:41:21	CTS_0014.LAB	9.2350
02/25/20	18:41:35	CTS_0015.LAB	9.2467
02/25/20	18:41:49	CTS_0016.LAB	9.2559
02/25/20	18:42:02	CTS_0017.LAB	9.2619

POST TEST AVERAGE **9.24**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.98

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.23	2.83	PASS
Post Test	9.24	2.89	PASS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/25/20	9:03:35	SPIKE_0074.LAB	50.6911
02/25/20	9:03:48	SPIKE_0075.LAB	50.8156
02/25/20	9:04:01	SPIKE_0076.LAB	50.8104
02/25/20	9:04:14	SPIKE_0077.LAB	50.9847
02/25/20	9:04:27	SPIKE_0078.LAB	51.0389

PRE TEST AVERAGE **50.87**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
02/25/20	18:53:43	CTS_0068.LAB	50.6090
02/25/20	18:53:57	CTS_0069.LAB	50.7610
02/25/20	18:54:11	CTS_0070.LAB	50.4207
02/25/20	18:54:25	CTS_0071.LAB	50.3055
02/25/20	18:54:39	CTS_0072.LAB	50.6951

POST TEST AVERAGE **50.56**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 50.40

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	50.87	0.93	PASS
Post Test	50.56	0.31	PASS

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd	SF_6 ppmvd
02/25/20	18:53:02	CTS_0065.LAB	49.4376	9.6995
02/25/20	18:53:16	CTS_0066.LAB	49.8893	9.7029
02/25/20	18:53:30	CTS_0067.LAB	50.1982	9.6963
02/25/20	18:53:43	CTS_0068.LAB	50.6090	9.7062
02/25/20	18:53:57	CTS_0069.LAB	50.7610	9.6990
02/25/20	18:54:11	CTS_0070.LAB	50.4207	9.6701
02/25/20	18:54:25	CTS_0071.LAB	50.3055	9.6545
02/25/20	18:54:39	CTS_0072.LAB	50.6951	9.6904
RAW AVERAGE			**50.290**	**9.690**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
02/25/20	18:58:12	SPIKEA_0011.LAB	4.5224	10.3164	2.0434	-0.0017
02/25/20	18:58:26	SPIKEA_0012.LAB	4.5272	10.2733	1.9964	0.0023
02/25/20	18:58:40	SPIKEA_0013.LAB	4.5351	10.3082	1.9227	0.0012
02/25/20	18:58:54	SPIKEA_0014.LAB	4.5242	10.1841	1.9010	0.0043
02/25/20	18:59:08	SPIKEA_0015.LAB	4.5202	10.3074	1.8297	0.0021
02/25/20	18:59:21	SPIKEA_0016.LAB	4.5223	10.3226	1.8202	0.0014
02/25/20	18:59:35	SPIKEA_0017.LAB	4.5175	10.3704	1.8775	-0.0005
02/25/20	18:59:49	SPIKEA_0018.LAB	4.5186	10.4159	1.8772	-0.0017
RAW AVERAGE			**4.523**	**10.312**	**1.909**	**0.001**

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
02/25/20	19:14:42	SPIKEA_0083.LAB	4.2255	8.8933	0.7469	4.8027
02/25/20	19:14:56	SPIKEA_0084.LAB	4.2352	8.8749	0.7540	4.9654
02/25/20	19:15:10	SPIKEA_0085.LAB	4.2292	8.8755	0.7478	5.0308
02/25/20	19:15:23	SPIKEA_0086.LAB	4.2385	8.8667	0.7528	5.1024
02/25/20	19:15:37	SPIKEA_0087.LAB	4.2363	8.8807	0.7529	5.1074
02/25/20	19:15:51	SPIKEA_0088.LAB	4.2121	8.8493	0.7507	5.1148
02/25/20	19:16:05	SPIKEA_0089.LAB	4.2317	8.8510	0.7552	5.1317
02/25/20	19:16:18	SPIKEA_0090.LAB	4.2202	8.8275	0.7582	5.0736
RAW AVERAGE			**4.229**	**8.865**	**0.752**	**5.041**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
02/25/20	19:28:55	SPIKEA_0145.LAB	4.5872	9.5217	2.2365	0.0006
02/25/20	19:29:08	SPIKEA_0146.LAB	4.5784	9.5366	2.2389	0.0067
02/25/20	19:29:22	SPIKEA_0147.LAB	4.5825	9.5005	2.1338	0.0004
02/25/20	19:29:36	SPIKEA_0148.LAB	4.5891	9.5161	2.1187	0.0051
02/25/20	19:29:49	SPIKEA_0149.LAB	4.5844	9.5198	2.1194	0.0007
02/25/20	19:30:03	SPIKEA_0150.LAB	4.5840	9.5534	2.1266	0.0024
02/25/20	19:30:17	SPIKEA_0151.LAB	4.5505	10.0484	2.1577	-0.0049
02/25/20	19:30:31	SPIKEA_0152.LAB	4.5667	9.8760	2.1536	-0.0008
RAW AVERAGE			**4.578**	**9.634**	**2.161**	**0.001**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
02/25/20	19:34:52	SPIKEA_0171.LAB	4.2457	8.8554	0.7409	5.3409
02/25/20	19:35:06	SPIKEA_0172.LAB	4.2458	8.8409	0.7430	5.3043
02/25/20	19:35:19	SPIKEA_0173.LAB	4.2347	8.8397	0.7447	5.2658
02/25/20	19:35:33	SPIKEA_0174.LAB	4.2535	8.8035	0.7459	5.1583
02/25/20	19:35:47	SPIKEA_0175.LAB	4.2444	8.7976	0.7480	5.0769
02/25/20	19:36:01	SPIKEA_0176.LAB	4.2350	8.7795	0.7494	5.0325
02/25/20	19:36:15	SPIKEA_0177.LAB	4.2373	8.7592	0.7512	4.9294
02/25/20	19:36:28	SPIKEA_0178.LAB	4.2837	8.8170	0.6576	4.9571
RAW AVERAGE			**4.248**	**8.812**	**0.735**	**5.133**

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
02/25/20	19:41:03	SPIKEA_0198.LAB	4.5824	9.4929	2.0110	0.0053
02/25/20	19:41:17	SPIKEA_0199.LAB	4.6064	9.4872	1.9369	-0.0026
02/25/20	19:41:31	SPIKEA_0200.LAB	4.5913	9.4811	1.9793	0.0020
02/25/20	19:41:44	SPIKEA_0201.LAB	4.5849	9.4857	1.9839	-0.0024
02/25/20	19:41:58	SPIKEA_0202.LAB	4.5880	9.4799	1.9764	0.0018
02/25/20	19:42:12	SPIKEA_0203.LAB	4.5935	9.4664	1.9715	-0.0039
02/25/20	19:42:26	SPIKEA_0204.LAB	4.5924	9.4794	1.9360	0.0004
02/25/20	19:42:39	SPIKEA_0205.LAB	4.5819	9.5087	1.9563	0.0005
RAW AVERAGE			**4.590**	**9.485**	**1.969**	**0.000**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
02/25/20	19:48:23	SPIKEA_0230.LAB	4.2485	8.6077	0.7432	5.8106
02/25/20	19:48:37	SPIKEA_0231.LAB	4.2446	8.5992	0.7497	5.6583
02/25/20	19:48:50	SPIKEA_0232.LAB	4.2390	8.5942	0.7522	5.4796
02/25/20	19:49:04	SPIKEA_0233.LAB	4.2462	8.5921	0.7514	5.4695
02/25/20	19:49:18	SPIKEA_0234.LAB	4.2421	8.6067	0.7574	5.4405
02/25/20	19:49:32	SPIKEA_0235.LAB	4.2373	8.5977	0.7529	5.3990
02/25/20	19:49:45	SPIKEA_0236.LAB	4.2379	8.5604	0.7521	5.3451
02/25/20	19:49:59	SPIKEA_0237.LAB	4.2344	8.5425	0.7541	5.3697
RAW AVERAGE			**4.241**	**8.588**	**0.752**	**5.497**

Cricket Valley Energy Center LLC
February 25, 2020
General Electric, 7F.05, Unit #U-00002
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	50.29	50.29	50.29
Concentration of SF_6 Cylinder	ppmvd	9.69	9.69	9.69

Spike A

Stack CO_2 Concentration	%vw	4.523	4.578	4.590
Stack H_2O Concentration	%	10.312	9.634	9.485
Stack NH_3 Concentration	ppmvw	1.909	2.161	1.969
Stack SF_6 Concentration	ppmvw	0.001	0.001	0.000
Stack + Spike CO_2 Concentration	%vw	4.229	4.248	4.241
Stack + Spike H_2O Concentration	%	8.865	8.812	8.588
Stack + Spike NH_3 Concentration	ppmvw	5.041	5.133	5.497
Stack + Spike SF_6 Concentration	ppmvw	0.752	0.735	0.752
Dilution Ratio		0.085	0.083	0.085
Ideal NH_3 Spike Yield	ppmvd	6.231	6.376	6.258
Percent Recovery NH_3	%	83.67%	82.15%	94.26%

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	-0.02	-0.02
Final Zero	-0.01	0.02
Avg. Zero		0.00
Initial UpScale	12.13	5.05
Final UpScale	12.02	4.83
Avg. UpScale	12.08	4.94
Sys Resp (Zero)	-0.01	0.00
Sys Resp (Upscale)	12.28	5.09
Upscale Cal Gas	11.97	4.91
Initial Zero Bias	-0.05%	-0.22%
Final Zero Bias	0.00%	0.22%
Zero Drift	0.05%	0.43%
Initial Upscale Bias	-0.71%	-0.43%
Final Upscale Bias	-1.24%	-2.83%
Upscale Drift	0.52%	2.39%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.02
Alternative Specification Abs Diff **Final Zero**	0.00	0.02
Alternative Specification Abs Diff **Initial Upscale**	0.15	0.04
Alternative Specification Abs Diff **Final Upscale**	0.26	0.26
Calibration Span	21.00	9.20
3% of Cal. Span (drift)	0.63	0.28
5% of Cal. Span (bias)	1.05	0.46

Respone Time (min)	1.3	2.0
Sys. Response (min)	2.0	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
02/25/20 06:05:32		13.44			1.36		x
02/25/20 06:05:42		13.38			1.35		
02/25/20 06:05:52		13.39			1.33		
02/25/20 06:06:02		13.39			1.34		
02/25/20 06:06:12		13.38			1.38		
02/25/20 06:06:22		8.55			1.38		
02/25/20 06:06:32		0.72			1.24		
02/25/20 06:06:42	x	**0.16**			2.29		
02/25/20 06:06:52		**0.11**			4.25		
02/25/20 06:07:02		**0.07**			**4.95**	x	
02/25/20 06:07:12		**0.05**			**4.89**		
02/25/20 06:07:22		**0.04**			**4.94**		
02/25/20 06:07:32		**0.02**			**4.91**		
02/25/20 06:07:42		**0.01**			**4.95**		
02/25/20 06:07:52		**0.01**			**4.94**		
02/25/20 06:08:02		**0.00**			**4.94**		x
02/25/20 06:08:12		**-0.01**			**4.94**		
02/25/20 06:08:22		**-0.01**			**4.94**		
02/25/20 06:08:32		**-0.02**			**4.94**		
02/25/20 06:08:42		**-0.03**			**4.92**		
02/25/20 06:08:52		**-0.02**			**4.89**		
02/25/20 06:09:02		**-0.03**			**4.94**		
02/25/20 06:09:12		5.12			**4.93**		
02/25/20 06:09:22		**11.55**	x		4.06		
02/25/20 06:09:32		**11.85**			3.07		
02/25/20 06:09:42		**11.89**			2.25		
02/25/20 06:09:52		**11.91**			0.84		
02/25/20 06:10:02		**11.93**		x	**0.12**		
02/25/20 06:10:12		**11.94**			**0.09**		
02/25/20 06:10:22		**11.95**			**0.05**		

DRIFT AND BIAS CHECK			
Base Load Load, Run - 1	**O_2**	**NOx**	**CO**
Raw Average	13.40	1.85	0.14
Corrected Average	13.36	2.02	0.14
Initial Zero	-0.03	0.02	0.05
Final Zero	-0.05	-0.53	-0.04
Avg. Zero	-0.04	-0.26	0.01
Initial UpScale	11.99	4.93	5.13
Final UpScale	12.02	4.83	5.14
Avg. UpScale	12.01	4.88	5.14
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.10%	0.76%	0.63%
Final Zero Bias	-0.19%	-5.22%	-0.32%
Zero Drift	0.10%	5.98%	0.95%
Initial Upscale Bias	-1.38%	-1.74%	0.53%
Final Upscale Bias	-1.24%	-2.83%	0.63%
Upscale Drift	0.14%	1.09%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.02	0.07	0.06
Alternative Specification Abs Diff **Final Zero**	0.04	0.48	0.03
Alternative Specification Abs Diff **Initial Upscale**	0.29	0.16	0.05
Alternative Specification Abs Diff **Final Upscale**	0.26	0.26	0.06
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 2	**O_2**	**NOx**	**CO**
Raw Average	13.31	1.72	0.43
Corrected Average	13.25	2.00	0.46
Initial Zero	-0.05	-0.53	-0.04
Final Zero	0.00	-0.35	-0.04
Avg. Zero	-0.03	-0.44	-0.04
Initial UpScale	12.02	4.83	5.14
Final UpScale	12.02	4.94	5.09
Avg. UpScale	12.02	4.89	5.12
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.19%	-5.22%	-0.32%
Final Zero Bias	0.05%	-3.26%	-0.32%
Zero Drift	0.24%	1.96%	0.00%
Initial Upscale Bias	-1.24%	-2.83%	0.63%
Final Upscale Bias	-1.24%	-1.63%	0.11%
Upscale Drift	0.00%	1.20%	0.53%
Alternative Specification Abs Diff **Initial Zero**	0.04	0.48	0.03
Alternative Specification Abs Diff **Final Zero**	0.01	0.30	0.03
Alternative Specification Abs Diff **Initial Upscale**	0.26	0.26	0.06
Alternative Specification Abs Diff **Final Upscale**	0.26	0.15	0.01
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 3	**O_2**	**NOx**	**CO**
Raw Average	13.34	1.90	0.13
Corrected Average	13.29	2.00	0.16
Initial Zero	0.00	-0.35	-0.04
Final Zero	-0.04	-0.01	-0.04
Avg. Zero	-0.02	-0.18	-0.04
Initial UpScale	12.02	4.94	5.09
Final UpScale	12.01	4.92	5.08
Avg. UpScale	12.01	4.93	5.09
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	0.05%	-3.26%	-0.32%
Final Zero Bias	-0.14%	0.43%	-0.32%
Zero Drift	0.19%	3.70%	0.00%
Initial Upscale Bias	-1.24%	-1.63%	0.11%
Final Upscale Bias	-1.31%	-1.85%	0.00%
Upscale Drift	0.07%	0.22%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.30	0.03
Alternative Specification Abs Diff **Final Zero**	0.03	0.04	0.03
Alternative Specification Abs Diff **Initial Upscale**	0.26	0.15	0.01
Alternative Specification Abs Diff **Final Upscale**	0.27	0.17	0.00
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 4	**O_2**	**NOx**	**CO**
Raw Average	11.91	2.44	0.74
Corrected Average	11.85	2.42	0.78
Initial Zero	-0.04	-0.01	-0.04
Final Zero	-0.02	0.03	-0.05
Avg. Zero	-0.03	0.01	-0.05
Initial UpScale	12.01	4.92	5.08
Final UpScale	12.05	4.96	5.08
Avg. UpScale	12.03	4.94	5.08
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.14%	0.43%	-0.32%
Final Zero Bias	-0.05%	0.87%	-0.42%
Zero Drift	0.10%	0.43%	0.11%
Initial Upscale Bias	-1.31%	-1.85%	0.00%
Final Upscale Bias	-1.10%	-1.41%	0.00%
Upscale Drift	0.21%	0.43%	0.00%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.04	0.03
Alternative Specification Abs Diff **Final Zero**	0.01	0.08	0.04
Alternative Specification Abs Diff **Initial Upscale**	0.27	0.17	0.00
Alternative Specification Abs Diff **Final Upscale**	0.23	0.13	0.00
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 5	**O_2**	**NOx**	**CO**
Raw Average	13.39	1.98	0.11
Corrected Average	13.30	1.94	0.17
Initial Zero	-0.02	0.03	-0.05
Final Zero	-0.02	0.06	-0.08
Avg. Zero	-0.02	0.05	-0.07
Initial UpScale	12.05	4.96	5.08
Final UpScale	12.05	4.94	5.04
Avg. UpScale	12.05	4.95	5.06
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.05%	0.87%	-0.42%
Final Zero Bias	-0.05%	1.20%	-0.74%
Zero Drift	0.00%	0.33%	0.32%
Initial Upscale Bias	-1.10%	-1.41%	0.00%
Final Upscale Bias	-1.10%	-1.63%	-0.42%
Upscale Drift	0.00%	0.22%	0.42%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.08	0.04
Alternative Specification Abs Diff **Final Zero**	0.01	0.11	0.07
Alternative Specification Abs Diff **Initial Upscale**	0.23	0.13	0.00
Alternative Specification Abs Diff **Final Upscale**	0.23	0.15	0.04
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 6	**O_2**	**NOx**	**CO**
Raw Average	13.32	1.87	0.12
Corrected Average	13.25	1.84	0.21
Initial Zero	-0.02	0.06	-0.08
Final Zero	-0.06	0.02	-0.11
Avg. Zero	-0.04	0.04	-0.10
Initial UpScale	12.05	4.94	5.04
Final UpScale	12.02	4.92	5.07
Avg. UpScale	12.04	4.93	5.06
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.05%	1.20%	-0.74%
Final Zero Bias	-0.24%	0.76%	-1.05%
Zero Drift	0.19%	0.43%	0.32%
Initial Upscale Bias	-1.10%	-1.63%	-0.42%
Final Upscale Bias	-1.24%	-1.85%	-0.11%
Upscale Drift	0.14%	0.22%	0.32%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.11	0.07
Alternative Specification Abs Diff **Final Zero**	0.05	0.07	0.10
Alternative Specification Abs Diff **Initial Upscale**	0.23	0.15	0.04
Alternative Specification Abs Diff **Final Upscale**	0.26	0.17	0.01
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 7	**O_2**	**NOx**	**CO**
Raw Average	13.32	1.98	0.09
Corrected Average	13.27	1.95	0.18
Initial Zero	-0.06	0.02	-0.11
Final Zero	-0.06	0.06	-0.07
Avg. Zero	-0.06	0.04	-0.09
Initial UpScale	12.02	4.92	5.07
Final UpScale	12.01	4.94	5.09
Avg. UpScale	12.02	4.93	5.08
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.24%	0.76%	-1.05%
Final Zero Bias	-0.24%	1.20%	-0.63%
Zero Drift	0.00%	0.43%	0.42%
Initial Upscale Bias	-1.24%	-1.85%	-0.11%
Final Upscale Bias	-1.29%	-1.63%	0.11%
Upscale Drift	0.05%	0.22%	0.21%
Alternative Specification Abs Diff **Initial Zero**	0.05	0.07	0.10
Alternative Specification Abs Diff **Final Zero**	0.05	0.11	0.06
Alternative Specification Abs Diff **Initial Upscale**	0.26	0.17	0.01
Alternative Specification Abs Diff **Final Upscale**	0.27	0.15	0.01
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 8	**O_2**	**NOx**	**CO**
Raw Average	13.31	2.09	0.11
Corrected Average	13.25	2.05	0.18
Initial Zero	-0.06	0.06	-0.07
Final Zero	-0.04	0.01	-0.09
Avg. Zero	-0.05	0.04	-0.08
Initial UpScale	12.01	4.94	5.09
Final UpScale	12.03	4.94	5.08
Avg. UpScale	12.02	4.94	5.09
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.24%	1.20%	-0.63%
Final Zero Bias	-0.14%	0.65%	-0.84%
Zero Drift	0.10%	0.54%	0.21%
Initial Upscale Bias	-1.29%	-1.63%	0.11%
Final Upscale Bias	-1.19%	-1.63%	0.00%
Upscale Drift	0.10%	0.00%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.05	0.11	0.06
Alternative Specification Abs Diff **Final Zero**	0.03	0.06	0.08
Alternative Specification Abs Diff **Initial Upscale**	0.27	0.15	0.01
Alternative Specification Abs Diff **Final Upscale**	0.25	0.15	0.00
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 9	**O_2**	**NOx**	**CO**
Raw Average	12.49	2.38	0.08
Corrected Average	12.43	2.36	0.15
Initial Zero	-0.04	0.01	-0.09
Final Zero	-0.06	0.02	-0.07
Avg. Zero	-0.05	0.02	-0.08
Initial UpScale	12.03	4.94	5.08
Final UpScale	12.03	4.94	5.05
Avg. UpScale	12.03	4.94	5.07
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.14%	0.65%	-0.84%
Final Zero Bias	-0.24%	0.76%	-0.63%
Zero Drift	0.10%	0.11%	0.21%
Initial Upscale Bias	-1.19%	-1.63%	0.00%
Final Upscale Bias	-1.19%	-1.63%	-0.32%
Upscale Drift	0.00%	0.00%	0.32%
Alternative Specification Abs Diff **Initial Zero**	0.03	0.06	0.08
Alternative Specification Abs Diff **Final Zero**	0.05	0.07	0.06
Alternative Specification Abs Diff **Initial Upscale**	0.25	0.15	0.00
Alternative Specification Abs Diff **Final Upscale**	0.25	0.15	0.03
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 10	**O_2**	**NOx**	**CO**
Raw Average	12.34	2.31	0.10
Corrected Average	12.29	2.31	0.17
Initial Zero	-0.06	0.02	-0.07
Final Zero	-0.08	-0.04	-0.07
Avg. Zero	-0.07	-0.01	-0.07
Initial UpScale	12.03	4.94	5.05
Final UpScale	12.01	4.89	5.04
Avg. UpScale	12.02	4.92	5.05
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.24%	0.76%	-0.63%
Final Zero Bias	-0.33%	0.11%	-0.63%
Zero Drift	0.10%	0.65%	0.00%
Initial Upscale Bias	-1.19%	-1.63%	-0.32%
Final Upscale Bias	-1.29%	-2.17%	-0.42%
Upscale Drift	0.10%	0.54%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.05	0.07	0.06
Alternative Specification Abs Diff **Final Zero**	0.07	0.01	0.06
Alternative Specification Abs Diff **Initial Upscale**	0.25	0.15	0.03
Alternative Specification Abs Diff **Final Upscale**	0.27	0.20	0.04
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

DRIFT AND BIAS CHECK			
Base Load Load, Run - 11	**O_2**	**NOx**	**CO**
Raw Average	12.36	2.36	0.07
Corrected Average	12.31	2.31	0.17
Initial Zero	-0.08	-0.04	-0.07
Final Zero	-0.06	0.18	-0.13
Avg. Zero	-0.07	0.07	-0.10
Initial UpScale	12.01	4.89	5.04
Final UpScale	12.02	4.98	5.05
Avg. UpScale	12.02	4.94	5.05
Sys Resp (Zero)	-0.01	-0.05	-0.01
Sys Resp (Upscale)	12.28	5.09	5.08
Upscale Cal Gas	11.97	4.91	5.09
Initial Zero Bias	-0.33%	0.11%	-0.63%
Final Zero Bias	-0.24%	2.50%	-1.26%
Zero Drift	0.10%	2.39%	0.63%
Initial Upscale Bias	-1.29%	-2.17%	-0.42%
Final Upscale Bias	-1.24%	-1.20%	-0.32%
Upscale Drift	0.05%	0.98%	0.11%
Alternative Specification Abs Diff **Initial Zero**	0.07	0.01	0.06
Alternative Specification Abs Diff **Final Zero**	0.05	0.23	0.12
Alternative Specification Abs Diff **Initial Upscale**	0.27	0.20	0.04
Alternative Specification Abs Diff **Final Upscale**	0.26	0.11	0.03
Calibration Span	21.00	9.20	9.50
3% of Cal. Span (drift)	0.63	0.28	0.29
5% of Cal. Span (bias)	1.05	0.46	0.48

RATA - FIELD DATA SHEET

AIR HYGIENE

Company:	CIS
Location:	Cricket Valley
Date:	2/25/20 Project Code: 20-CIS-A-CricketValley
Unit Make and Model:	7F-05
Unit Number:	U-00002
Serial Number:	
Data Recorded By:	MA
Tested With AHI Unit(s):	Truck(s): 176 Trailer(s): 215
LDEQ Warmup/Cal Req:	On (Day/Time): 2/25/20 Cal (Day/Time): 5:00

Stack Dia. = 228
Measured By: RW
Measured With: Laser
*Start

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0072434	→	
	Mid	CC722590	EB0065464	3
	High	CC721614	EB00B492	

NH3

CYLINDER SERIAL NUMBERS		~~THC~~	CO_2	SO_2
	Low	EB0065964		
	Mid			
	High			

RUN INFORMATION	Run #1	Run #2	Run #3	Run #4	Run #5	Run #6	Run #7	Run #8	Run #9	Run #10	Run #11	Run #12
Time Start (hh:mm:ss)	11:46:22	12:32:28	13:07:58	13:36:28	14:15:28	14:46:28	15:17:28	15:47:28	16:20:28	16:51:28	17:27:28	
Time Stop (hh:mm:ss)	11:53:28	12:52:58	13:27:58	13:56:58	14:35:58	15:06:58	15:37:58	16:07:58	16:40:58	17:11:58	18:17:58	
Rated Power (MW or hp)	12:13:58											
Actual Power (MW or hp)												
Barometric Pressure (In. Hg)	29.33	29.36	29.34	29.33	29.34	29.33	29.33	29.33	29.33	29.34	29.37	
Ambient Temperature (°F)	~~53.5~~ 54.8	55.3	55.1	55.5	59.0	55.7	~~53.8~~ 55.8	55.1	54.5	53.5	51.0	
Relative Humidity (%)	50.8	50.6	48.6	47.5	44.7	48.0	50.1	50.9	53.5	56.8	75.7	
CEMS DATA for O_2												
CEMS DATA for NOx												
CEMS DATA for CO												
CEMS DATA for SO_2												

CALIBRATION	O_2		NOx		CO		SO_2	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0.0	-.01	0.0	-.05	0.0	-.01		
Low Gas	11.47	12.28	4.91	5.09	5.09	5.08		
Mid Gas	21.0	21.25	9.20	9.28	9.50	9.62		
High Gas								

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	1.40
NOx Reading (ppm)	48.79
Cylinder Num	EB009843

BIAS	O_2		NOx		CO		SO_2	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Run #1	-.03	11.99	.02	4.93	.05	5.13		
Run #1 / Run #2	-.05	12.02	-.03	4.83	-.04	5.14		
Run #2 / Run #3	0.0	12.02	-.35	4.94	-.04	5.09		
Run #3 / Run #4	-.04	12.01	-.01	4.92	-.04	5.08		
Run #4 / Run #5	-.02	12.05	.06	4.96	-.05	5.03		
Run #5 / Run #6	-.06	12.02	.02	4.92	-.11	5.07		
Run #6 / Run #7	-.06	12.01	.06	4.94	-.07	5.09		
Run #7 / Run #8	-.04	12.03	.01	4.94	-.09	5.08		
Run #8 / Run #9	-.06	12.03	.02	4.94	-.07	5.05		
Run #9 / Run #10	-.03	12.01	-.04	4.89	-.07	5.04		
Run #10 / Run #11	-.06	12.02	.18	4.98	-.13	5.05		
Run #11 / Run #12								
Run #12 Final								
Bias Gas Actual Conc.		11.97		4.91		5.09		

REPORT INFORMATION	INSTRUMENT	SERIAL #
O_2	SERVO 1440	02-0021
NOx	ThermO 42C	NX-003
CO	Enst-co 300 ThermO 48C	
~~THC~~MS	MKS	EF-0008
CO_2		
SO_2		

RESPONSE TIME	TIME (hh:mm)	RESP (min)
Gas Inject	/ /	
1st Inst. @ 95%	/ /	/ /
2nd Inst. @ 95%	/ /	/ /
3rd Inst. @ 95%	/ /	/ /

Signature

APPENDIX E

STRATIFICATION TEST DATA

Source Information	
Company	Cricket Valley Energy Center LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric (GE) 7F.05 Combustion Turbine
Location	Dover Plains, New York

Test Information	
Date	02/25/20
Project #	cis-19-cricketvalley.ny-start#1
Unit Number	U-00002
Load	Base Load
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type			
○	Isokinetic Traverse (Wet Chemistry Testing)		**Circular Stack**
○	Velocity Traverse (Flow and Flow RATA Test)		
○	Stratification Traverse (Compliance Test)	☐ RM 20	
◉	**Stratification Traverse (RATA)**	☐ Part 60 ☑ Part 75	

Created with Traverse-AHI v20190211


METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.*
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2

*assume 8 in. reference (must be measured and verified in field)


Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters



Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points Comp Stratification	
Down (B_D) Stream	Up (A_D) Stream	Particulate Points	Velocity Points	Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**
				Part75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points
					points


[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	6:14:22	**Run End**	7:12:22

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	4.00	6:14:22	6:18:22	13.43	0.75%	1.52	4.45%
D-2	4.00	6:18:22	6:22:22	13.40	0.52%	1.50	5.70%
D-1	4.00	6:22:22	6:26:22	13.39	0.45%	1.48	6.96%
C-3	8.00	6:26:22	6:34:22	13.32	0.07%	1.49	6.33%
C-2	4.00	6:30:22	6:34:22	13.31	0.15%	1.49	6.33%
C-1	4.00	6:34:22	6:38:22	13.31	0.15%	1.58	0.68%
B-3	10.00	6:38:22	6:48:22	13.47	1.05%	1.47	7.59%
B-2	4.00	6:48:22	6:52:22	13.45	0.90%	1.45	8.85%
B-1	4.00	6:52:22	6:56:22	13.43	0.75%	1.49	6.33%
A-3	8.00	6:56:22	7:04:22	13.03	**2.25%**	1.91	**20.07%**
A-2	4.00	7:04:22	7:08:22	13.21	0.90%	1.91	**20.07%**
A-1	4.00	7:08:22	7:12:22	13.21	0.90%	1.80	13.09%
Average				13.33		1.59	

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center LLC	**Date**	02/25/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	6:14:22	**Run End**	7:12:22

40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	2.25 % for O_2
Maximum Pollutant Conc. Diff.	0.32 ppm for NOx
Maximum Diluent Conc. Diff.	0.30 % for O_2
Stratification Conclusions	
Comparison	at least one diluent/pollutant
Stack Diameter	D > 93.6 in.


Under Part 75 criteria at least one measured pollutant or diluent demonstrates a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type

- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas

- ☐ Use 6.5.6.3(a) points?
- ☐ 6.5.6(b)(2) alt. points could apply



this page intentionally left blank
end of report

APPENDIX 8

GAS CYLINDER CERTIFICATION SHEETS

Airgas
an Air Liquide company

C0/L
02/22/20

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401523613-1
Cylinder Number:	SG910481	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jun 20, 2019

Expiration Date: Jun 20, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	7.067 PPM	G1	+/- 0.6% NIST Traceable	06/20/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	061207	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	0.51%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jun 07, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

02/24/20 NO/NOx-CO/N

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401543888-1
Cylinder Number:	ALM034669	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 22, 2019

Expiration Date: Jul 22, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	176.8 PPM	G1	+/- 0.5% NIST Traceable	07/15/2019, 07/22/2019
NITRIC OXIDE	180.0 PPM	176.8 PPM	G1	+/- 0.5% NIST Traceable	07/15/2019, 07/22/2019
CARBON MONOXIDE	1700 PPM	1709 PPM	G1	+/- 0.5% NIST Traceable	07/15/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060130	KAL004288	249.9 PPM NITRIC OXIDE/NITROGEN	+/-0.4%	Nov 08, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

02/02/2029 1051
CAL

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401523613-1
Cylinder Number:	ALM057981	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jun 20, 2019

Expiration Date: Jun 20, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531 using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	7.052 PPM	G1	+/- 0.6% NIST Traceable	06/20/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	061207	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	0.51%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jun 07, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

02/03/20
NO/H- CO/H 1058

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401543888-1
Cylinder Number:	SG9160199BAL	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 22, 2019

Expiration Date: Jul 22, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	177.2 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019, 07/22/2019
NITRIC OXIDE	180.0 PPM	177.0 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019, 07/22/2019
CARBON MONOXIDE	1700 PPM	1712 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060130	KAL004288	249.9 PPM NITRIC OXIDE/NITROGEN	+/- 0.4%	Nov 08, 2023
PRM	PRM	D582879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019

Triad Data Available Upon Request

Approved for Release

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI78E15A0124	Reference Number:	160-401495594-1
Cylinder Number:	ALM064777	Cylinder Volume:	146.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	May 09, 2019

Expiration Date: May 09, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	22.00 %	22.14 %	G1	+/- 0.3% NIST Traceable	05/09/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS OXYMAT 6 - W5951 - O2	PARAMAGNETIC	Apr 25, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	CC722081	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.935 PPM	G1	+/- 1.0% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.902 PPM	G1	+/- 0.9% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

0920 02/04/20 no/L

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401524346-1
Cylinder Number:	EB0108627	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 24, 2019

Expiration Date: Jun 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.926 PPM	G1	+/- 1.2% NIST Traceable	06/17/2019, 06/24/2019
NITRIC OXIDE	9.000 PPM	8.893 PPM	G1	+/- 1.2% NIST Traceable	06/17/2019, 06/24/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jun 20, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jun 20, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

02/06/20

Airgas Specialty Gases
Airgas USA, LLC
630 United Drive
Durham, NC 27713
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15AE020	Reference Number:	122-401671594-1
Cylinder Number:	EB0070742	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Dec 13, 2019

Expiration Date: Dec 13, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	112.4 PPM	G1	+/- 0.8% NIST Traceable	12/06/2019, 12/13/2019
NITRIC OXIDE	110.0 PPM	112.2 PPM	G1	+/- 0.8% NIST Traceable	12/06/2019, 12/13/2019
CARBON MONOXIDE	1100 PPM	1119 PPM	G1	+/- 1.1% NIST Traceable	12/06/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060108	KAL004078	249.9 PPM NITRIC OXIDE/NITROGEN	+/- 0.4%	Nov 08, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010359	KAL004729	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801333 CO	FTIR	Dec 04, 2019
Nicolet 6700 AHR0801333 NO	FTIR	Dec 04, 2019
Nicolet 6700 AHR0801333 NO2	FTIR	Dec 04, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

02/06/20

Airgas Specialty Gases
Airgas USA, LLC
6141 Easton Road
Bldg 1
Plumsteadville, PA 18949
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15AE015	Reference Number:	160-401543679-1
Cylinder Number:	AAL073505	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 19, 2019

Expiration Date: Jul 19, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	51.21 PPM	G1	+/- 0.8% NIST Traceable	07/12/2019, 07/19/2019
NITRIC OXIDE	50.00 PPM	51.21 PPM	G1	+/- 0.8% NIST Traceable	07/12/2019, 07/19/2019
CARBON MONOXIDE	500.0 PPM	518.9 PPM	G1	+/- 0.4% NIST Traceable	07/12/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18006110	KAL004085	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
NTRM	18060110	KAL004085-NOX	250.1 PPM NOx/NITROGEN	0.4%	Nov 08, 2023
NTRM	072508	KAL004570	970.0 PPM CARBON MONOXIDE/NITROGEN	0.36%	May 14, 2021

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS ULTRAMAT6E 7MB2123 1BD20 0BM1Z LOW CO	NDIR	Jun 13, 2019
THERMO 42i HL 1032345595 CHEMI NO	CHEMILUMINESCENCE	Jul 11, 2019
THERMO 42i HL 1032345595 CHEMI NOX	CHEMILUMINESCENCE	Jul 11, 2019

Triad Data Available Upon Request

Approved for Release

HiQ® Certificate / Certificat HiQ®

LINDE CANADA LIMITED
530 Watson St. East
Whitby, ON, Canada L1N 5R9

CERTIFICATE OF ANALYSIS — EPA PROTOCOL MIXTURE

Purchase order # 110585036
Lot # 1263941
Cylinder Number: EB 0049417

PGVP ID # L12013
Procedure: G1
Gas Type Code: OC2
Cylinder pressure: 2000 psig

Certification date
August 12, 2013

Expiration Date
August 13, 2021

ANALYTICAL RESULTS

Component	Requested Concentration ± blending tolerance	Date of Assay	Mean Concentration	Certified Concentration Uncertainty expressed at 95% confidence
Carbon Dioxide	5 % ± 5%	August 12, 2013	5.01 %	5.01 ± 0.02 %
Oxygen	6 % ± 5%	August 9, 2013	6.03 %	6.03 ± 0.01 %

BALANCE GAS: Nitrogen

REFERENCE STANDARDS

Component	Type	Serial Number	Reference Number	Concentration	Expiration Date
Carbon Dioxide	GMIS	SX 21992	1187915	10 ± 0.02 %	August 20, 2013
	NTRM	SG 9916842	101001	19.98 ± 0.14 %	April 15, 2016
Oxygen	GMIS	SX 31579	1107503	9.975 ± 0.06 %	August 18, 2013
	NTRM	CC 237234	071001	24.12 ± 0.12 %	March 27, 2017

CERTIFICATION INSTRUMENTS

Component	Make/Model	Measurement Principle	Serial Number	Last Calibration
Carbon Dioxide	SICK MCS 100E	Infrared Photometer	04310670	August 1, 2013
Oxygen	Servomex 04100 C1	Paramagnetic Sensor	392350	August 9, 2013

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE 2012 EPA PROTOCOL *PROCEDURE*

DO NOT USE THIS CYLINDER WHEN THE PRESSURE FALLS BELOW 100 PSIG

Analyst: Keith Cybulski Signature K Date 08/12/13

Notes:

Tel: 1-(866) 385-5349 Fax:1-(866) 385-5347 service@lindecanada.com

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0053431	**Certification Date:**	06/15/2015
Product ID Number:	124822	**Expiration Date:**	06/13/2023
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0053431.20150611-0	**Lot Number:**	EB0053431.20150611
Customer PO. NO.:		**Tracking Number:**	074201901
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Oxygen	**13.46 %**	±0.06 %	MPA
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0055414.20140228-1C	10/07/2022	GMIS	N2	O2	23.8 %	0.505	071001
LD131022.115903.1G	10/07/2022	GMIS	N2	O2	11.97 %	0.527	071001

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
O2	MPA	Horiba	VA-3013	H0000P11	5/22/2015 12:35:56 PM

Red Ball Technical Gas Service
PGVP Vendor ID # G12015
Information and Ordering
800-551-8150
Fax (318-425-6309)

PJLA Calibration and Testing
Accreditation #62754

LaMeka Dennis
Assistant Operations Manager

<<<<END OF DOCUMENT>>>>

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CRICKET VALLEY ENERGY CENTER
DUTCHESS COUNTY, NEW YORK

ORIS CODE: 57185
UNIT U-00003 (U003)

PART 75 INITIAL CEMS AND FUEL FLOWMETERS CERTIFICATION TEST REPORTS

AND

PART 60 INITIAL CEMS CERTIFICATION TEST REPORTS

PREPARED FOR: GENERAL ELECTRIC

PREPARED BY: CUSTOM INSTRUMENTATION SERVICES, CORP. (CiSCO)

Date: April 28, 2020

Revision: 0

COPY NO:

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX: (303) 790-7292

TABLE OF CONTENTS

1. INTRODUCTION 3

2. CEMS CERTIFICATION 6

2.1 RELATIVE ACCURACY TEST AUDIT 6
2.2 BIAS CHECK 7
2.3 7-DAY CALIBRATION ERROR/DRIFT & ONLINE/OFFLINE DEMONSTRATION TESTS 7
2.4 LINEARITY CHECK 7
2.5 CYCLE TIME & RESPONSE TIME TESTS 8

3. DAHS VERIFIFICATION 8

4. FUEL FLOWMETER CERTIFICATION TESTS DOCUMENTATION 8

5. DISCUSSION OF RESULTS 8

APPENDIX 1 Emissions Collection and Monitoring Plan System (ECMPS) Printout

APPENDIX 2 7-Day Error Drift Tests & Online/Offline Demonstration Test Documentation

APPENDIX 3 Linearity Check Documentation

APPENDIX 4 Cycle Time & Response Time Test Documentation

APPENDIX 5 DAHS Verification Documentation

APPENDIX 6 Relative Accuracy Test Audit Report

APPENDIX 7 Fuel Flowmeter Accuracy Test/Primary Element Visual Inspection Documentation

APPENDIX 8 Gas Cylinder Certification Sheets

1. INTRODUCTION

Cricket Valley Energy Center is a facility located in Dover Plains, New York. The facility consists of three natural gas-fired combined cycle electric generating units identified as U-00001 (U001), U-00002 (U002), and U-00003 (U003). In addition to the air emitting equipment, the Facility will include three steam turbine generators (STGs), an air cooled condenser (ACC) and associated auxiliary equipment and systems. This certification report pertains to the U-00003 (U003), which consists of a General Electric (GE) Model 7FA.05 combustion turbine generators (CTGs) operating in combined-cycle mode with supplemental firing of the heat recovery steam generators (HRSGs), which has a nominal generating capacity of 333 MW. The maximum potential when incorporated with the steam turbine generator megawatts as per 40 CFR 75 is 383 MW. Natural gas will be the sole fuel fired in the CTGs and duct burners. Each combined cycle generating unit consisting of the CTG, HRSG and STG will be exhausted through its own stack. In addition, to oxidation catalyst being used to control CO emission, both dry-low NO_X burners (DLNB) and Selective Catalytic Reduction (SCR) are used for NO_X control on each unit. Exhaust gases from the turbines are discharged into the atmosphere through a stack approximately 282.5 feet above grade. A dedicated CEMS will monitor NO_X, CO, NH_3(NO_X) and O_2 emissions and gas fuel flow from each of the three units. This report focuses on the U-00003 CEMS.

Custom Instrumentation Services Corporation of Englewood, Colorado built the Continuous Emission Monitoring System. Data from the CEMS is recorded and stored on a Data Acquisition and Handling System (DAHS).

The CEMS on the U-00003 unit was designed to meet the monitoring and reporting requirements of New York State Department of Environmental Conservation (NYSDEC) Permit No. 3-1326-00275/00009 and the regulatory requirements of 40 CFR 60 (NO_X, NH_3, CO and O_2 analyzers) and 40 CFR 75 (NO_x and O_2 analyzers). This report presents the results of the initial certification tests performed on the NO_x, NO_X/NH_3, CO and O_2 analyzers. The testing was performed in accordance with the requirements of 40 CFR 60, Appendix B, Performance Specification 2, 3, 4a and 40 CFR 75, Appendix A.

In addition, this report provides documentation of the DAHS missing data substitution and formula verification as well as fuel flow meter transmitter accuracy tests and orifice plate primary element visual inspections performed, as required by 40 CFR 75 for the initial certification.

Field certification testing on Unit U-00003 occurred between March 27, 2020 and April 4, 2020. The tests conducted under 40 CFR 75 on the NO_x and O_2 CEMS included Relative Accuracy Test Audit (RATA), Bias Check, 7-Day Calibration Error Test, Linearity Check and Cycle Time Test. The tests conducted under 40 CFR 60 on NO_X, NH_3/NO_X, CO and O_2 CEMS included RATA, 7-Day Calibration Drift Test and CO Response Time Test. A summary of the tests performed on each analyzer is provided in Table 1.

Printouts of the tests results and revised monitoring plans for the 40 CFR 75 NO_x and O_2 CEMS from EPA's Emissions Collection and Monitoring Plan System (ECMPS) Software are provided in Appendix 1.

Air Hygiene, International(AHI) of Broken Arrow, Oklahoma conducted the RATAs on the NO_x, NH_3/NO_X, CO and O_2 CEMS. On March 4, 2020 ten (10) 21-minute runs were completed on the unit. The results of the RATAs are summarized in Table 1. As shown, the Relative Accuracy calculations on the analyzers were within the EPA and NYSDEC specifications for all parameters. A detailed description of the RATAs conducted are provided in Section 2.1 and the AHI test report in Appendix 6.

A bias check evaluation was made on the NO_x lb/mmBtu relative accuracy results as required in 40 CFR 75. The bias adjustment factor for the NO_x monitoring systems (NO_x lb/mmBtu) is provided in Table 1. The bias test results are discussed in Section 2.2. Supporting data is provided in the relative accuracy tables in the AHI RA report in Appendix 6.

The 40 CFR 60 7-day Calibration Drift and 40 CFR 75 7-Day Calibration Error tests for U-00003 CEMS occurred during seven consecutive unit operating days from March 27, 2020 through April 2, 2020. The results of these tests are summarized in Table 1. As shown, the analyzers operated well within the applicable specifications. An explanation of the calibration drift and calibration error tests is provided in Section 2.3 and supporting documentation is provided in Appendix 2 of this report.

Although not required for the initial certification, Online/Offline Calibration Error Demonstration tests were performed on the 40 CFR 75 NO_x and O_2 analyzers on March 25, 2020 to allow the use of offline calibrations to validate the Part 75 data during subsequent normal operation. Information on the Online/Offline calibration error demonstration tests is also provided in Section 2.3 and Appendix 2 of this report.

The U-00003 Linearity Checks were performed on the 40 CFR 75 NO_x and O_2 analyzers on April 4, 2020. The NO_x and O_2 Cycle Time Tests and the CO Response Time tests were performed April 4, 2020. The results of these tests are summarized in Table 1. As shown, the analyzers operated well within EPA specifications for all parameters. An explanation of the linearity check is provided in Section 2.4. Explanations of the cycle time and response time tests are provided in Section 2.5. Audit reports for the linearity checks and supporting documents for the cycle time/response time tests are provided in Appendices 3 and 4, respectively.

The DAHS missing data substitution verification and formula verification tests took place March 8, 2020. The DAHS passed all the tests required by EPA. The DAHS tests are described in Section 3 and supporting documents are provided in Appendix 5. Please note that although not required by 40 CFR 60, DAHS formula verifications are also provided for the CO analyzers.

In summary, based on the results of the initial certification tests performed on the CEMS installed on the U-00003 stacks at the Cricket Valley Energy Center, the CEMSs met the

requirements in 40 CFR 60, Appendix B Performance Specification 2, 3, 4a and 40 CFR 75, Appendix A and are therefore certified to provide accurate and reliable data under these regulations and under the NYSDEC air permit. These CEMS will continue to be calibrated, maintained, and operated following the requirements of 40 CFR 60, Appendix F and 40 CFR 75, Appendix B.

TABLE 1.
SUMMARY OF CEMS CERTIFICATION TESTS RESULTS

U-00003 (U003)	RESULTS	STANDARD	PASS / FAIL
	RELATIVE ACCURACY		
NO_x ppm @ 15% O_2	14.33% RA RM	20% RA RM or 10% ARA[1]	PASS
NO_x lb/hr	11.59% RA RM	20% RA RM or 10% ARA	PASS
NO_x lb/mmBtu	0.001 lb/mmBtu MD	7.5% RA RM or 0.015 lb/mmBtu MD[2]	PASS
CO ppm @ 15% O_2	0.2 ppm MD	10% RA RM or 5% ARA or ±5 ppm MD[3]	PASS
CO lb/hr	0.2 ppm MD	10% RA RM or 5% ARA or ±5 ppm MD	PASS
NH_3 ppm @ 15% O_2	4.34% RA RM	20% RA RM or 10% ARA	PASS
NH_3 lb/hr	3.84% RA ARA[4]	20% RA RM or 10% ARA	PASS
O_2 %	0.08% RA RM	20% RA RM or 1% O_2 MD	PASS
	BIAS TEST		
Adjustment Factor	1.000	NA	PASS
	24-HOUR ZERO DRIFT[5]		
NO_x low	0.2% of span	2.5 % of span	PASS
NO_x high	0.0% of span	2.5 % of span	PASS
CO low	3.90% of span	5 % of span	PASS
CO high	0.00% of span	5 % of span	PASS
$NH_3/(NO_x)$	0.63% of span	2.5 % of span	PASS
O_2 %	0.04% O_2	0.5% O_2	PASS
	24-HOUR SPAN DRIFT[5]		
NO_x low	0.4% of span	2.5 % of span	PASS
NO_x high	0.4% of span	2.5 % of span	PASS
CO low	4.30% of span	5 % of span	PASS
CO high	0.34% of span	5 % of span	PASS
$NH_3/(NO_x)$	0.31% of span	2.5 % of span	PASS
O_2 %	0.03% O_2	0.5% O_2	PASS
	LINEARITY[5]		
NO_x high ppm	2.2% LE	5% LE	PASS
O_2 %	0.7% LE	5% LE	PASS
	CYCLE TIME/CO RESPONSE TIME TEST(S) [5]		
NO_x lb/mmBtu	2 Minutes	15 Minutes	PASS
CO low	173 Avg. Seconds	240 Avg. Seconds	PASS
	DAHS VERIFICATION		
DAHS Computer	Verified (03/08/2020)	Verify	PASS
ANALYZER SERIAL NUMBERS			
NO_x		1014	
O_2		151	
CO		520	
NH_3/NO_X		1049	

[1] ARA = alternative relative accuracy determined from the permit applicable standard.

[2] RATA RESULTS REQUIRED FOR ANNUAL RATA FREQUENCY FOR 40 CFR 75

[3] MD =|d| +|2.5% CC

[4] NYSDEC permit ID 3-1326-00275/00009 does not have a current NH3 lb/hr limit, so a conservative value (16.66 lb/hr) was back-calculated from the existing 5 ppm corrected limit. Calculation is provided in Air Hygiene RATA report in Appendix 6.

[5] DRIFT, LINEARITY CTT/RTT RESULTS ARE THE HIGHEST ENCOUNTERED DURING ALL TESTS

2. CEMS CERTIFICATION TESTS

Field tests were performed for the initial CEMS certification in accordance with the requirements of 40 CFR 60, Appendix B and 40 CFR Part 75, Appendix A. The results for all tests were determined from the data collected by the DAHS. The computer printouts for each field test are included in the Appendices.

2.1 RELATIVE ACCURACY TEST AUDIT

Relative accuracy testing was performed on April 4, 2020 by AHI, a source testing company that meets the EPA Air Emissions Testing Body (AETB) requirements. Each test run was a minimum of 21 minutes in duration and consisted of sampling for NO_x, NH_3 (NO_X), CO and O_2. The times during which the tests were performed and additional information on stratification test, NO_x converter efficiency check and reference method calibrations are provided in the AHI report in Appendix 6.

The reference methods used by AHI are outlined below:

CONSTITUENT	METHOD
O_2	EPA METHOD 3A
NO_x	EPA METHOD 7E
$NH_3(NO_x)$	EPA METHOD 7E
CO	EPA METHOD 10

As shown in the Relative Accuracy tables in the AHI report in Appendix 6, relative accuracy is reported as an error and is the sum of the absolute mean value of the differences between the reference method tests and the instrument readings, plus the 95 percent confidence interval of the differences, expressed as a percentage of the mean reference method value or the emission standard. As an alternative, 40 CFR 75 allows low NO_x emitters (less than 0.20 lb/mmBtu) to express relative accuracy as the difference between the average reference method value and the average CEMS value. Performance Specification 4a in 40 CFR 60, Appendix B also allows for CO relative accuracy results to be expressed as a mean difference between the reference method average value and CEMS average value.

The analyzer response was determined from the average of readings taken every minute for the duration of the time the relative accuracy tests were performed. The 1-Minute Data Reports from the CEMS are included in the AHI report.

The NO_x, $NH_3(NO_X)$, CO and O_2. analyzers passed the relative accuracy requirements (as stated in 40 CRF 60, Appendix B 2, 3, 4a). In addition, the NO_x diluent systems (NO_x and O_2 analyzers combined) passed the relative accuracy requirements as stated in 40 CRF 75, Appendix A and based on the RATA results, these systems qualify for annual RATA frequency under 40 CFR 75.

2.2 BIAS CHECK

The relative accuracy result for the NO_x diluent systems reported in lb/mmBtu was checked for low bias by determining if the mean difference between the test team's values and the CEMS values was greater than the absolute value of the confidence coefficient. U-00003 NO_x diluent systems did not exhibit bias. Therefore, the bias adjustment factor (BAF) for the unit was 1.000. In general, the BAF is determined after each RATA test.

2.3 7 DAY CALIBRATION ERROR/DRIFT TEST & ONLINE/OFFLINE DEMONSTRATION TESTS

In general, the U-00003 7-day calibration error/drift tests required by 40 CFR 60 and 40 CFR 75 on the NO_x, NH_3 (NO_X), CO and O_2. analyzers occurred between March 27, 2020 and April 2, 2020. All tests occurred on seven consecutive unit-operating days when the unit was combusting fuel. The NO_x and O_2 calibration gases used for the zero and span calibration error tests meet the requirements of the EPA 40 CFR 75, Appendix A, Protocol Gas Verification Program (PGVP). The certificates of analysis for the cylinders used to meet the requirements of both 40 CFR 60 and 40 CFR 75 drift/calibration error requirements are included in Appendix 8 of this report.

Although not required for the initial certification, this report includes the results of the Online/Offline Calibration Error Demonstration tests that were performed on March 25, 2020. 40 CFR 75 Appendix B §2.1.1.2 allows the use of offline calibrations for the purpose of validating online data if both offline and online calibrations are performed within 26-clock hours and meets the performance specification criteria of 40 CFR 75 Append A, §3.1.

The data from calibrations occurring over seven days and the offline determination occurring within 26-clock hours are summarized in Appendix 2 of this report. As shown, the calibration error/drift for all analyzers were well within EPA requirements as stated in 40 CFR 60, Appendix B and 40 CFR 75, Appendix A. The calibration summary reports are provided in Appendix 2.

2.4 LINEARITY CHECKS

The U-00003 NO_x and O_2 linearity checks were performed on April 4, 2020. To perform the linearity check, the high ranges of the NO_x analyzers and the O_2 analyzers were challenged three times with each of three levels of calibration gas (low, mid and high). The mean difference between the analyzer response and the calibration gas value, as a percentage of the calibration gas value, must be within 5%. Results are also acceptable if the difference between the mean response and the calibration gas value is within 0.5% O_2 or 5 ppm NO_x. The results were well within the requirements of 40 CFR 75, Appendix A.

A summary of the linearity check results are provided in Appendix 3 and the certificates of analysis for the calibration gases used during the checks are provided in Appendix 8. The calibration gases used for the linearity checks met the US EPA PGVP requirements of 40 CFR 75, Appendix A.

2.5 CYCLE TIME & RESPONSE TIME TESTS

The U-00003 cycle time tests were performed on April 4, 2020. To perform the test, the NO_x and O_2 analyzers were challenged with a zero gas and a high level (80 to 100% of span) calibration gas. Both the upscale and down scale response times were determined. As stated in 40 CFR 75, Appendix A, the response time to reach 95% of the gas value must be less than 15 minutes.

40 CFR 75, Appendix A, Section 6.4 specifies that on and after January 1, 2009, the cycle time for each component analyzer of a NO_x diluent system must be recorded separately. It also specifies that for monitors with dual ranges, the test results for each range must be reported separately. Cycle time test results are acceptable for monitoring system certification if none of the cycle times exceed 15 minutes. The down scale and upscale cycle times for the NO_x low range, NO_x high range and O_2 analyzers met this specification.

The U-00003 CO response time tests were performed on April 4, 2020 to meet the requirements of 40 CFR 60. To perform this test, the low range of the CO analyzer was challenged with a zero gas and a high level (50 to 100% of range) calibration gas. Both the upscale and down scale response time averages were determined. As stated in 40 CFR 60, Appendix B, Performance Specification 4A the response time to reach 95% of the gas value must be less than 240 seconds. For the upscale and downscale readings the longer of the two response times is the response time for the analyzer. The response time for the low range of the CO analyzers met this requirement. The gas cylinders used to perform the CO response time tests are provided in Appendix 8.

Audit reports that show the analyzers response in ten second increments are located in Appendix 4. The gas cylinders used to perform the NO_X/O_2 cycle time tests meet the US EPA PGVP requirements of 40 CFR 75, Appendix A and are provided in Appendix 8.

3. DAHS VERIFICATION

A letter from the 40 CFR 75 software vendor (CiSCO CEMS) stating that each of the missing data routines and calculations performed by the DAHS was verified is included in Appendix 5. A formula verification is also included. All variables included in the calculations (bias adjustment factor, fuel inputs) were used. The formula verification spreadsheet and associated printouts are also included in Appendix 5.

4. FUEL FLOWMETER CERTIFICATION TESTS DOCUMENTATION

Documents demonstrating that the fuel flowmeters installed in each combustion turbine and duct burner meet the 2% upper range accuracy specified in 40 CFR 75 Appendix D are provided in Appendix 7. This includes Certificate of Compliance document, which references ASME MFC 9M:2006 calibration which demonstrates compliance with 40 CFR 75 Appendix D Section 2.1.5.1 certification criteria.

5. DISCUSSION OF RESULTS

The CEMS and DAHS on the U-00003 combustion turbine generators at the Cricket Valley Energy Center successfully met all the requirements of the EPA, as outlined in 40 CFR 60 and 40 CFR 75. An electronic QA certification file in the format specified by EPA Clean Air Markets Division for 40 CFR 75 has been prepared for each unit and will be submitted via ECMPS within 45 days of test completion.

APPENDIX 1

EMISSIONS MONITORING AND MONITORING PLAN SYSTEM PRINTOUTS

ECMPS Client Tool

Version 1.* 2020 Q1

QA/Cert Events Printout Report

April 13, 2020 09:26 PM

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL):	57185
State:	NY
County:	Dutchess County

QA Certification Events Details

Unit/Stack Identifier	Event Code	Event Date/Hour	System ID / Type	Component ID / Type	Required Tests	Conditional Data Begin Date/Hour	Last Test Completed Date/Hour	Submitted?
U003	125	03/24/2020 23	N30/NOX	310/NOX	4		04/04/2020 23	Not Yet Submitted
				320/O2	4		04/04/2020 23	Not Yet Submitted

Event Codes: 125 - Initial Certification of Gas Monitoring System

Required Test Codes: 4 - Normal Load RATA, 7-day Calibration Error Test, Linearity Check, Cycle Time Test, DAHS Verification

ECMPS Client Tool

Version 1.* 2020 Q1

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL): 57185
State: NY
County: Dutchess County

Unit/Stack/Pipe ID: U003

7-Day Calibration

Component ID: 310
Test Number: 7DCAL-NOX_H-
Span Scale Level: High
Component Type: NOX
Reason for Test: INITIAL
Span Value: 200.000
Test Completion: 04/02/2020 00:01
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
03/27/2020 14	ZERO	0.000	0	0.000	0.00		0.00	
03/27/2020 14	HIGH	177.000	88.5	177.500	0.30		0.30	
03/28/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
03/28/2020 00	HIGH	177.000	88.5	176.690	0.20		0.20	
03/29/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
03/29/2020 00	HIGH	177.000	88.5	177.000	0.00		0.00	
03/30/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
03/30/2020 00	HIGH	177.000	88.5	176.600	0.20		0.20	
03/31/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
03/31/2020 00	HIGH	177.000	88.5	176.800	0.10		0.10	
04/01/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
04/01/2020 00	HIGH	177.000	88.5	177.700	0.40		0.40	
04/02/2020 00	ZERO	0.000	0	0.000	0.00		0.00	
04/02/2020 00	HIGH	177.000	88.5	177.500	0.30		0.30	

Additional Information:
No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A &3.1)

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Unit/Stack/Pipe ID: U003

7-Day Calibration

Component ID:	320	**Component Type:**	O2	**Test Completion:**	04/02/2020 00:01
Test Number:	7DCAL-O2_H-	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	25.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
03/27/2020 09	ZERO	0.000	0	0.020	0.00		0.00	
03/27/2020 09	HIGH	22.200	88.8	22.250	0.10		0.10	
03/28/2020 00	ZERO	0.000	0	0.030	0.00		0.00	
03/28/2020 00	HIGH	22.200	88.8	22.250	0.10		0.10	
03/29/2020 00	ZERO	0.000	0	0.030	0.00		0.00	
03/29/2020 00	HIGH	22.200	88.8	22.260	0.10		0.10	
03/30/2020 00	ZERO	0.000	0	0.030	0.00		0.00	
03/30/2020 00	HIGH	22.200	88.8	22.250	0.10		0.10	
03/31/2020 00	ZERO	0.000	0	0.040	0.00		0.00	
03/31/2020 00	HIGH	22.200	88.8	22.210	0.00		0.00	
04/01/2020 00	ZERO	0.000	0	0.040	0.00		0.00	
04/01/2020 00	HIGH	22.200	88.8	22.220	0.00		0.00	
04/02/2020 00	ZERO	0.000	0	0.040	0.00		0.00	
04/02/2020 00	HIGH	22.200	88.8	22.220	0.00		0.00	

Additional Information:
No comment.

*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A &3.1)

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Unit/Stack/Pipe ID: U003

Cycle Time Test

Component ID:	310	**Component Type:**	NOX	**Test Completion:**	04/04/2020 14:22
Test Number:	CTT-310L-2020Q2	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	Low	**Span Value:**	10.000	**EPA Calculated Result:**	PASSED
Total Cycle Time:	2	**Calculated Total Cycle Time:**	2		
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/04/04	14:14	14:15	ZERO	0.000	2.123	-0.027	1	1
2020/04/04	14:20	14:22	HIGH	8.820	2.094	9.015	2	2

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U003

Cycle Time Test

Component ID:	320	**Component Type:**	O2	**Test Completion:**	04/04/2020 22:44
Test Number:	CTT-320-2020Q2	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	25.000	**EPA Calculated Result:**	PASSED
Total Cycle Time:	2	**Calculated Total Cycle Time:**	2		
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
				Submission Date/Time:	

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/04/04	22:36	22:38	ZERO	0.000	13.058	0.048	2	2
2020/04/04	22:42	22:44	HIGH	22.200	13.051	22.233	2	2

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Unit/Stack/Pipe ID: U003

Cycle Time Test

Component ID: 310
Component Type: NOX
Test Completion: 04/04/2020 14:33
Test Number: CTT-310H-2020Q2
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: High
Span Value: 200.000
EPA Calculated Result: PASSED
Total Cycle Time: 1
Calculated Total Cycle Time: 1

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Date	Start Time	End Time	Gas Level	Reference Gas Value	Stable Values		Injection Cycle Time	
					Starting	Ending	Results	Recalculated
2020/04/04	14:26	14:27	ZERO	0.000	2.145	-0.069	1	1
2020/04/04	14:32	14:33	HIGH	176.900	2.074	180.938	1	1

Additional Information:

No comment.

*Performance Spec: Cycle Time <= 15 minutes (Appendix A &3.5)

Unit/Stack/Pipe ID: U003

Fuel Flowmeter Accuracy Test

Component ID: 370
Component Type: GFFM
Test Completion: 06/11/2018 10:00
Test Number: FFAT-370-2020Q2
Reported Test Results: PASSED
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Accuracy Test Method	High Level Accuracy	Mid Level Accuracy	Low Level Accuracy	Reinstallation Date/Hour
ASME	0.0	0.0	0.0	02/23/2020 00

Additional Information:

No comment.

Unit/Stack/Pipe ID: U003

Linearity Check

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Component ID:	310	**Component Type:**	NOX	**Test Completion:**	04/04/2020 19:38
Test Number:	310-LIN-2020Q2	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	200.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
Grace period Tested?				**Submission Date/Time:**	

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO,NO,NOX,BALN	B22019	CC435700	02/11/2028
Mid	CO,NO,NOX,BALN	G12019	CC719253	09/24/2026
Low	CO,NO,NOX,BALN	G12019	CC712750	06/27/2022

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	180.200	180.200	109.400	109.400	49.400	49.400
Mass CEM Value	180.567	180.567	110.567	110.567	48.333	48.333
Alt. Perf. Indicator						
Results	0.2	0.2	1.1	1.1	2.2	2.2

Injection Statistics:

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
04/04/2020 19:34	MID	110.400	109.400	54.7%
04/04/2020 19:22	MID	110.600	109.400	54.7%
04/04/2020 19:09	MID	110.700	109.400	54.7%
04/04/2020 19:38	HIGH	180.600	180.200	90.1%
04/04/2020 19:26	HIGH	180.500	180.200	90.1%
04/04/2020 19:13	HIGH	180.600	180.200	90.1%
04/04/2020 19:05	LOW	48.200	49.400	24.7%
04/04/2020 19:30	LOW	48.400	49.400	24.7%
04/04/2020 19:17	LOW	48.400	49.400	24.7%

Additional Information:

No comment.

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: U003

Linearity Check

Component ID:	320	**Component Type:**	O2	**Test Completion:**	04/04/2020 18:58
Test Number:	320-LIN-2020Q2	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSED
Span Scale Level:	High	**Span Value:**	25.000	**EPA Calculated Result:**	PASSED
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted
Grace period Tested?				**Submission Date/Time:**	

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO2,O2,BALN	A12019	ALMO47793	03/04/2027
Low	CO2,O2,BALN	L12013	EB0049417	08/13/2021
Mid	O2,BALN	G12015	EB0053431	06/13/2023

Summary Statistics:

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	22.200	22.200	13.460	13.460	6.030	6.030
Mass CEM Value	22.230	22.230	13.553	13.553	6.063	6.063
Alt. Perf. Indicator						
Results	0.1	0.1	0.7	0.7	0.6	0.6

Injection Statistics:

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
04/04/2020 18:28	HIGH	22.220	22.200	88.8%
04/04/2020 18:43	HIGH	22.230	22.200	88.8%
04/04/2020 18:58	HIGH	22.240	22.200	88.8%
04/04/2020 18:23	MID	13.550	13.460	53.8%
04/04/2020 18:53	MID	13.560	13.460	53.8%
04/04/2020 18:38	MID	13.550	13.460	53.8%
04/04/2020 18:48	LOW	6.070	6.030	24.1%
04/04/2020 18:18	LOW	6.060	6.030	24.1%
04/04/2020 18:33	LOW	6.060	6.030	24.1%

Additional Information:

No comment.

*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A &3.2)

Unit/Stack/Pipe ID: U003

On-Line/Off-Line Calibration

Component ID: 310
Test Number: ON_OFF-310H-
Span Scale Level: High
Component Type: NOX
Reason for Test: INITIAL
Span Value:
Test Completion: 03/25/2020 20
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	03/25/2020 20	ZERO	0.000		0.000	0.00		0.00	
Online	03/25/2020 20	HIGH	176.900		175.700	0.60		0	
Offline	03/25/2020 00	ZERO	0.000		0.000	0.00		0.00	
Offline	03/25/2020 00	HIGH	176.900		176.900	0.00		0.00	

Additional Information:

No comment.

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Unit/Stack/Pipe ID: U003

On-Line/Off-Line Calibration

Component ID: 320
Component Type: O2
Test Completion: 03/25/2020 20
Test Number: ON_OFF-320-
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: High
Span Value:
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	03/25/2020 20	ZERO	0.000		0.000	0.00		0.00	
Online	03/25/2020 20	HIGH	22.220		22.250	0.00		0	
Offline	03/25/2020 00	ZERO	0.000		0.010	0.00		0.00	
Offline	03/25/2020 00	HIGH	22.220		22.300	0.10		0.10	

Additional Information:

No comment.

Unit/Stack/Pipe ID: U003

On-Line/Off-Line Calibration

Component ID: 310
Component Type: NOX
Test Completion: 03/25/2020 20
Test Number: ON_OFF-310L-
Reason for Test: INITIAL
Reported Test Results: PASSED
Span Scale Level: Low
Span Value:
EPA Calculated Result: PASSED

Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

Calibration Type	Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
						Results	APS	Results	APS
Online	03/25/2020 20	ZERO	0.000		-0.020	0.20		0.20	
Online	03/25/2020 20	HIGH	8.820		8.620	2.00		0	
Offline	03/25/2020 00	ZERO	0.000		0.020	0.20		0.20	
Offline	03/25/2020 00	HIGH	8.820		8.610	2.10		2.10	

Additional Information:

No comment.

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Unit/Stack/Pipe ID: U003

Relative Accuracy Test

System ID:	N30	**System Parameter:**	NOX	**Test Completion:**	04/04/2020 22:10
Test Number:	N30-2020Q2	**Reason for Test:**	INITIAL	**Reported Test Results:**	PASSAPS
# of Op. Levels:	1	**Grace Period Test?**		**EPA Calculated Result:**	PASSAPS
Evaluation Status:	No Errors			**Reported BAF:**	1.000
Submission Status:	Not Submitted			**EPA Calculated BAF:**	1.000
Submission Date:				**RATA Frequency:**	4QTRS

Air Emissions Testing Data

QI Name:	McBRIDE, MATTHEW S	**AETB Name:**	AIR HYGIENE INTERNATIONAL
Exam Date:	01/27/2019	**AETB Phone Number:**	888-461-8778
Provider Name:	SOURCE EVALUATION SOCIETY (SES)	**AETB Email:**	info@airhygiene.com
Provider Email:	QSTIPROGRAM@GMAIL.COM		

Protocol Gas Data:

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	BALN,CO,NO,NOX	G12019	EB0040961	10/30/2022
Mid	BALN,CO,NO,NOX	G12019	CC727541	09/03/2022
High	BALN,CO2,O2	G12019	CC721614	11/11/2026
Mid	BALN,CO2,O2	G12019	CC716390	02/23/2028
Low	ZERO			

Operating Level: High
Reference Method Used: 7E,3A: NOX RM 7E and CO2/O2 RM 3A

Summary Statistics:

	Reported	Recalculated		Reported	Recalculated
Mean of Monitoring System	0.00618	0.00618	**Relative Accuracy**	15.05	15.05
Mean of Reference Method Values	0.00544	0.00544	**Bias Adjustment Factor**	1.000	1.000
Mean of Difference	-0.00074	-0.00074	**APS Indicator**	Y	Y
Standard Deviation of Difference	0.00011	0.00011	**T-Value**	2.306	2.306
Confidence Coefficient	0.00008	0.00008	**Gross Unit Load or Velocity**	352	352

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Run Data:

Run	Start Date	End Date	Run Status	Monitoring System Value	Reference Method Value	Gross Load or Velocity
1	04/04/2020 17:23	04/04/2020 17:43	RUNUSED	0.00630	0.00560	350
2	04/04/2020 17:52	04/04/2020 18:12	RUNUSED	0.00630	0.00560	350
3	04/04/2020 18:20	04/04/2020 18:40	RUNUSED	0.00623	0.00560	350
4	04/04/2020 18:51	04/04/2020 19:11	RUNUSED	0.00620	0.00560	351
5	04/04/2020 19:20	04/04/2020 19:40	RUNUSED	0.00630	0.00560	352
6	04/04/2020 19:48	04/04/2020 20:08	RUNUSED	0.00570	0.00500	352
7	04/04/2020 20:20	04/04/2020 20:40	RUNUSED	0.00640	0.00550	353
8	04/04/2020 20:49	04/04/2020 21:09	RUNUSED	0.00590	0.00510	353
9	04/04/2020 21:17	04/04/2020 21:37	RUNUSED	0.00630	0.00540	353
10	04/04/2020 21:50	04/04/2020 22:10	NOTUSED	0.00630	0.00540	352

Additional Information:

No comment.

*Performance Spec: RA <= 10% or Mean Difference <= +/- 2.0fps:
Reduced Frequency Spec: RA <= 7.5% or Mean Difference +/- 1.5 fps (Appendix A &3.3.4)

Unit/Stack/Pipe ID: U003

Transmitter Transducer Test

Component ID: 375
Test Number: FTTT-375-2020Q2
Component Type: GFFM
Reason for Test: INITIAL
Test Completion: 02/23/2018 08:47
Reported Test Results: PASSED
EPA Calculated Result: PASSED
Evaluation Status: No Errors
Submission Status: Not Submitted
Submission Date/Time:

High Level Accuracy	High Level Accuracy Specification	Mid Level Accuracy	Mid Level Accuracy Specification	Low Level Accuracy	Low Level Accuracy Specification
0.0	SUM	0.0	SUM	0.0	SUM

Additional Information:

No comment.

Facility Name: Cricket Valley Energy Center

Facility ID (ORISPL): 57185

QA/Cert Test Detail Report

April 28, 2020 12:05 PM

Unit/Stack/Pipe ID: U003

DAHS Verification

System ID:		**System Type:**		**Test Completion:**	03/08/2020 06:59
Component ID:	D01	**Component Type:**	DAHS	**Reported Test Results:**	PASSED
Test Number:	DAHS_FV-2020Q2	**Reason for Test:**	INITIAL	**Grace Period Test?**	
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted

Test Description:

Additional Information:

DAHS Verfication

Unit/Stack/Pipe ID: U003

Primary Element Inspection

System ID:		**System Type:**		**Test Completion:**	02/23/2020 10:00
Component ID:	375	**Component Type:**	GFFM	**Reported Test Results:**	PASSED
Test Number:	PEI-275-2020Q2	**Reason for Test:**	INITIAL	**Grace Period Test?**	
Evaluation Status:	No Errors			**Submission Status:**	Not Submitted

Test Description:

Additional Information:

Orifice Inspection

APPENDIX 2

7-DAY ERROR/DRIFT TESTS
&
ONLINE/OFFLINE DEMONSTRATION TESTS
DOCUMENTATION

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 75-NOx ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	200	0.00	0.80	0.80	5.00	176.90	175.10	-1.80	5.00	On-Line
3/27/2020 08:15	200	0.00	0.00	0.00	5.00	176.90	175.40	-1.50	5.00	Off-Line
3/27/2020 14:07	200	0.00	0.00	0.00	5.00	177.00	177.50	0.50	5.00	On-Line
3/28/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	176.60	-0.40	5.00	On-Line
3/29/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	177.00	0.00	5.00	On-Line
3/29/2020 06:52	200	0.00	0.00	0.00	5.00	177.00	176.50	-0.50	5.00	On-Line
3/29/2020 07:33	200	0.00	0.00	0.00	5.00	177.00	177.10	0.10	5.00	On-Line
3/30/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	176.60	-0.40	5.00	On-Line
3/31/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	176.80	-0.20	5.00	On-Line
3/31/2020 19:13	200	0.00	0.10	0.10	5.00	177.00	177.80	0.80	5.00	On-Line
4/1/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	177.70	0.70	5.00	On-Line
4/2/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	177.50	0.50	5.00	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 60-NOx ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	200	0.00	0.80	0.80	5.00	176.90	175.10	-1.80	5.00	On-Line
3/27/2020 08:15	200	0.00	0.00	0.00	5.00	176.90	175.40	-1.50	5.00	Off-Line
3/27/2020 14:07	200	0.00	0.00	0.00	5.00	177.00	177.50	0.50	5.00	On-Line
3/28/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	176.60	-0.40	5.00	On-Line
3/29/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	177.00	0.00	5.00	On-Line
3/29/2020 06:52	200	0.00	0.00	0.00	5.00	177.00	176.50	-0.50	5.00	On-Line
3/29/2020 07:33	200	0.00	0.00	0.00	5.00	177.00	177.10	0.10	5.00	On-Line
3/30/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	176.60	-0.40	5.00	On-Line
3/31/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	176.80	-0.20	5.00	On-Line
3/31/2020 19:13	200	0.00	0.10	0.10	5.00	177.00	177.80	0.80	5.00	On-Line
4/1/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	177.70	0.70	5.00	On-Line
4/2/2020 00:01	200	0.00	0.00	0.00	5.00	177.00	177.50	0.50	5.00	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 60-NOx ppm/L

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	10	0.00	0.83	**0.83**	0.25	8.82	8.56	**-0.26**	0.25	On-Line
3/27/2020 08:15	10	0.00	0.00	0.00	0.25	8.82	8.09	**-0.73**	0.25	Off-Line
3/27/2020 14:07	10	0.00	0.02	0.02	0.25	8.88	8.85	-0.03	0.25	On-Line
3/28/2020 00:01	10	0.00	0.00	0.00	0.25	8.88	8.92	0.04	0.25	On-Line
3/29/2020 00:01	10	0.00	0.01	0.01	0.25	8.88	8.88	0.00	0.25	On-Line
3/29/2020 06:52	10	0.00	0.01	0.01	0.25	8.88	8.89	0.01	0.25	On-Line
3/29/2020 07:33	10	0.00	0.01	0.01	0.25	8.88	8.89	0.01	0.25	On-Line
3/30/2020 00:01	10	0.00	0.00	0.00	0.25	8.88	8.87	-0.01	0.25	On-Line
3/31/2020 00:01	10	0.00	0.01	0.01	0.25	8.88	8.87	-0.01	0.25	On-Line
3/31/2020 19:13	10	0.00	0.02	0.02	0.25	8.88	8.93	0.05	0.25	On-Line
4/1/2020 00:01	10	0.00	0.01	0.01	0.25	8.88	8.92	0.04	0.25	On-Line
4/2/2020 00:01	10	0.00	0.00	0.00	0.25	8.88	8.91	0.03	0.25	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 CO ppm/H

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	2050	0.00	0.00	0.00	102.50	1711.00	1716.00	5.00	102.50	On-Line
3/27/2020 14:07	2050	0.00	0.00	0.00	102.50	1707.00	1704.00	-3.00	102.50	On-Line
3/28/2020 00:01	2050	0.00	0.00	0.00	102.50	1707.00	1700.00	-7.00	102.50	On-Line
3/29/2020 00:01	2050	0.00	0.00	0.00	102.50	1707.00	1700.00	-7.00	102.50	On-Line
3/29/2020 06:52	2050	0.00	0.00	0.00	102.50	1707.00	1702.00	-5.00	102.50	On-Line
3/29/2020 07:33	2050	0.00	0.00	0.00	102.50	1707.00	1701.00	-6.00	102.50	On-Line
3/30/2020 00:01	2050	0.00	0.00	0.00	102.50	1707.00	1702.00	-5.00	102.50	On-Line
3/31/2020 00:01	2050	0.00	0.00	0.00	102.50	1707.00	1703.00	-4.00	102.50	On-Line
3/31/2020 19:13	2050	0.00	0.00	0.00	102.50	1707.00	1704.00	-3.00	102.50	On-Line
4/1/2020 00:01	2050	0.00	0.00	0.00	102.50	1707.00	1705.00	-2.00	102.50	On-Line
4/2/2020 00:01	2050	0.00	0.00	0.00	102.50	1707.00	1707.00	0.00	102.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 CO ppm/L

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	10	0.00	0.39	0.39	0.50	6.98	6.74	-0.24	0.50	On-Line
3/27/2020 14:07	10	0.00	0.14	0.14	0.50	7.04	7.31	0.27	0.50	On-Line
3/28/2020 00:01	10	0.00	0.21	0.21	0.50	7.04	6.69	-0.35	0.50	On-Line
3/29/2020 00:01	10	0.00	0.07	0.07	0.50	7.04	6.61	-0.43	0.50	On-Line
3/29/2020 06:52	10	0.00	0.08	0.08	0.50	7.04	8.21	**1.17**	0.50	On-Line
3/29/2020 07:33	10	0.00	0.08	0.08	0.50	7.04	6.71	-0.33	0.50	On-Line
3/30/2020 00:01	10	0.00	0.13	0.13	0.50	7.04	6.69	-0.35	0.50	On-Line
3/31/2020 00:01	10	0.00	0.10	0.10	0.50	7.04	6.75	-0.29	0.50	On-Line
3/31/2020 19:13	10	0.00	0.18	0.18	0.50	7.04	7.41	0.37	0.50	On-Line
4/1/2020 00:01	10	0.00	0.19	0.19	0.50	7.04	7.42	0.38	0.50	On-Line
4/2/2020 00:01	10	0.00	0.09	0.09	0.50	7.04	7.40	0.36	0.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 NH3/NOx ppm

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	16	0.00	3.40	**3.40**	0.48	8.82	8.88	0.06	0.48	On-Line
3/27/2020 08:42	16	0.00	0.10	0.10	0.48	8.82	8.85	0.03	0.48	On-Line
3/27/2020 14:07	16	0.00	0.05	0.05	0.48	8.88	8.86	-0.02	0.48	On-Line
3/28/2020 00:01	16	0.00	0.00	0.00	0.48	8.88	8.89	0.01	0.48	On-Line
3/29/2020 00:01	16	0.00	-0.01	-0.01	0.48	8.88	8.86	-0.02	0.48	On-Line
3/29/2020 06:52	16	0.00	0.01	0.01	0.48	8.88	8.87	-0.01	0.48	On-Line
3/29/2020 07:33	16	0.00	0.19	0.19	0.48	8.88	8.92	0.04	0.48	On-Line
3/30/2020 00:01	16	0.00	-0.01	-0.01	0.48	8.88	8.84	-0.04	0.48	On-Line
3/31/2020 00:01	16	0.00	0.00	0.00	0.48	8.88	8.89	0.01	0.48	On-Line
3/31/2020 19:13	16	0.00	0.03	0.03	0.48	8.88	8.93	0.05	0.48	On-Line
4/1/2020 00:01	16	0.00	-0.01	-0.01	0.48	8.88	8.93	0.05	0.48	On-Line
4/2/2020 00:01	16	0.00	-0.01	-0.01	0.48	8.88	8.93	0.05	0.48	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 75-O2 %

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	25	0.00	13.48	**13.48**	0.50	22.22	22.24	0.02	0.50	On-Line
3/27/2020 09:32	25	0.00	0.02	0.02	0.50	22.22	22.25	0.03	0.50	On-Line
3/27/2020 14:07	25	0.00	0.03	0.03	0.50	22.20	22.27	0.07	0.50	On-Line
3/28/2020 00:01	25	0.00	0.03	0.03	0.50	22.20	22.25	0.05	0.50	On-Line
3/29/2020 00:01	25	0.00	0.03	0.03	0.50	22.20	22.26	0.06	0.50	On-Line
3/29/2020 06:52	25	0.00	0.03	0.03	0.50	22.20	22.27	0.07	0.50	On-Line
3/29/2020 07:33	25	0.00	0.03	0.03	0.50	22.20	22.26	0.06	0.50	On-Line
3/30/2020 00:01	25	0.00	0.03	0.03	0.50	22.20	22.25	0.05	0.50	On-Line
3/31/2020 00:01	25	0.00	0.04	0.04	0.50	22.20	22.21	0.01	0.50	On-Line
3/31/2020 19:13	25	0.00	0.04	0.04	0.50	22.20	22.24	0.04	0.50	On-Line
4/1/2020 00:01	25	0.00	0.04	0.04	0.50	22.20	22.22	0.02	0.50	On-Line
4/2/2020 00:01	25	0.00	0.04	0.04	0.50	22.20	22.22	0.02	0.50	On-Line

The 7-Day Drift Test has been passed.

Cricket Valley Energy Center

7-Day Drift Test

Turbine 3 60-O2 %

Time	Instrument Span	Zero Reference	Zero Measured	Zero Drift	Zero Drift Limit	Span Reference	Span Measured	Span Drift	Span Drift Limit	Status
3/27/2020 00:01	25	0.00	13.48	**13.48**	0.50	22.22	22.24	0.02	0.50	On-Line
3/27/2020 09:32	25	0.00	0.02	0.02	0.50	22.22	22.25	0.03	0.50	On-Line
3/27/2020 14:07	25	0.00	0.03	0.03	0.50	22.20	22.27	0.07	0.50	On-Line
3/28/2020 00:01	25	0.00	0.03	0.03	0.50	22.20	22.25	0.05	0.50	On-Line
3/29/2020 00:01	25	0.00	0.03	0.03	0.50	22.20	22.26	0.06	0.50	On-Line
3/29/2020 06:52	25	0.00	0.03	0.03	0.50	22.20	22.27	0.07	0.50	On-Line
3/29/2020 07:33	25	0.00	0.03	0.03	0.50	22.20	22.26	0.06	0.50	On-Line
3/30/2020 00:01	25	0.00	0.03	0.03	0.50	22.20	22.25	0.05	0.50	On-Line
3/31/2020 00:01	25	0.00	0.04	0.04	0.50	22.20	22.21	0.01	0.50	On-Line
3/31/2020 19:13	25	0.00	0.04	0.04	0.50	22.20	22.24	0.04	0.50	On-Line
4/1/2020 00:01	25	0.00	0.04	0.04	0.50	22.20	22.22	0.02	0.50	On-Line
4/2/2020 00:01	25	0.00	0.04	0.04	0.50	22.20	22.22	0.02	0.50	On-Line

The 7-Day Drift Test has been passed.

ONLINE/OFFLINE DETERMINATION

Turbine 3 Calibration Checks

Cricket Valley Energy Center
Cal Checks for 3/25/2020

Date/Time	Parameter	Analyzer Scale	Test Level	Reference Value	Measured Value	Actual Drift	Allowable Drift	Instrument Span	Results
			Cylinder ID	*Expiration Date*		*EPA Vendor ID*	*EPA Gas Type Codes*		
3/25/2020 12:01 AM	75-NOx ppm	High	Zero	0.0 ppm	0.0 ppm	0 ppm	±10 ppm	200 ppm	Unit offline; Passed
			NI CZ15A	*1/15/2028*		*B22019*	*N2*		
3/25/2020 12:01 AM	75-NOx ppm	High	Span	176.9 ppm	176.9 ppm	0 ppm	±10 ppm	200 ppm	Unit offline; Passed
			SG9147577BAL	*7/22/2027*		*B22019*	*CO,NO,NOX,BALN*		
3/25/2020 12:01 AM	75-NOx ppm	Low	Zero	0.00 ppm	-0.01 ppm	-0.01 ppm	±0.5 ppm	10 ppm	Unit offline; Passed
			NI CZ15A	*1/15/2028*		*B22019*	*N2*		
3/25/2020 12:01 AM	75-NOx ppm	Low	Span	8.82 ppm	8.61 ppm	-0.21 ppm	±0.5 ppm	10 ppm	Unit offline; Passed
			CC409686	*6/24/2022*		*B22019*	*NO,NOX,BALN*		
3/25/2020 12:01 AM	75-O2 %	Single	Zero	0.00%	0.01%	0.01%	±1%	25%	Unit offline; Passed
			NI CZ15A	*1/15/2028*		*B22019*	*N2*		
3/25/2020 12:01 AM	75-O2 %	Single	Span	22.22%	22.30%	0.08%	±1%	25%	Unit offline; Passed
			CC270907	*6/17/2027*		*A12019*	*O2,BALN*		
3/25/2020 8:11 PM	75-NOx ppm	High	Zero	0.0 ppm	0.0 ppm	0 ppm	±10 ppm	200 ppm	Unit online; Passed
			NI CZ15A	*1/15/2028*		*B22019*	*N2*		
3/25/2020 8:11 PM	75-NOx ppm	High	Span	176.9 ppm	175.7 ppm	-1.2 ppm	±10 ppm	200 ppm	Unit online; Passed
			SG9147577BAL	*7/22/2027*		*B22019*	*CO,NO,NOX,BALN*		
3/25/2020 8:11 PM	75-NOx ppm	Low	Zero	0.00 ppm	0.02 ppm	0.02 ppm	±0.5 ppm	10 ppm	Unit online; Passed
			NI CZ15A	*1/15/2028*		*B22019*	*N2*		
3/25/2020 8:11 PM	75-NOx ppm	Low	Span	8.82 ppm	8.62 ppm	-0.2 ppm	±0.5 ppm	10 ppm	Unit online; Passed
			CC409686	*6/24/2022*		*B22019*	*NO,NOX,BALN*		
3/25/2020 8:11 PM	75-O2 %	Single	Zero	0.00%	0.00%	0%	±1%	25%	Unit online; Passed
			NI CZ15A	*1/15/2028*		*B22019*	*N2*		
3/25/2020 8:11 PM	75-O2 %	Single	Span	22.22%	22.25%	0.03%	±1%	25%	Unit online; Passed
			CC270907	*6/17/2027*		*A12019*	*O2,BALN*		

APPENDIX 3

LINEARITY CHECK DOCUMENTATION

Turbine 3 NOx/H Linearity

Cricket Valley Energy Center

Test Information

Test Date: **4/3/2020**
Test Reason:
Grace Period: No
Aborted: No
Unit online during QA test

Analyzer and Monitor Information

Range: High
Instrument Span: 200 ppm
Component ID: 310
Manufacturer: TELEDYNE
Model: T200M
Serial Number: 1014

Run Number	Time	Reference Gas	CEMS Response		Cylinder Information
Low Gas					
1	7:05 PM	49.4	48.2		Allowable Reference Values: 40-60 ppm (20-30% of span)
2	7:17 PM	49.4	48.4		
3	7:30 PM	49.4	48.4		Cylinder ID: CC712750
	Mean (ppm)	49.4	48.3		Expiration Date: 6/27/2022
	Difference of means (|R-A|) (ppm)	1.1	*Limit 5*	*Passed*	EPA Vendor ID: G12019
	Linearity Error (%)	2.2	*Limit 5.0*	*Passed*	Cylinder contains: NO,NOX,CO,BALN
Mid Gas					
1	7:09 PM	109.4	110.7		Allowable Reference Values: 100-120 ppm (50-60% of span)
2	7:22 PM	109.4	110.6		
3	7:34 PM	109.4	110.4		Cylinder ID: CC719253
	Mean (ppm)	109.4	110.6		Expiration Date: 9/24/2026
	Difference of means (|R-A|) (ppm)	1.2	*Limit 5*	*Passed*	EPA Vendor ID: G12018
	Linearity Error (%)	1.1	*Limit 5.0*	*Passed*	Cylinder contains: NO,NOX,CO,BALN
High Gas					
1	7:13 PM	180.2	180.6		Allowable Reference Values: 160-200 ppm (80-100% of span)
2	7:26 PM	180.2	180.5		
3	7:38 PM	180.2	180.6		Cylinder ID: CC435700
	Mean (ppm)	180.2	180.6		Expiration Date: 2/11/2028
	Difference of means (|R-A|) (ppm)	0.4	*Limit 5*	*Passed*	EPA Vendor ID: B22019
	Linearity Error (%)	0.2	*Limit 5.0*	*Passed*	Cylinder contains: CO,NO,NOX,BALN

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

Turbine 3 O2 Linearity

Cricket Valley Energy Center

Test Information

Test Date: **4/3/2020**
Test Reason:
Grace Period: No
Aborted: No
Unit online during QA test

Analyzer and Monitor Information

Range: Single Scale
Instrument Span: 25 %O2
Component ID: 320
Manufacturer: TELEDYNE
Model: T802
Serial Number: 151

Run Number	Time	Reference Gas	CEMS Response		Cylinder Information
Low Gas					
1	6:18 PM	6.03	6.06		
2	6:33 PM	6.03	6.06		Allowable Reference Values:
3	6:48 PM	6.03	6.07		5-7.5 %O2 (20-30% of span)
	Mean (%O2)	6.03	6.06		Cylinder ID: EB0049417
	Difference of means (|R-A|) (%O2)	0.0	*Limit 0.5*	*Passed*	Expiration Date: 8/13/2021
					EPA Vendor ID: L12013
	Linearity Error (%)	0.6	*Limit 5.0*	*Passed*	Cylinder contains: CO2,O2,BALN
Mid Gas					
1	6:23 PM	13.46	13.55		
2	6:38 PM	13.46	13.55		Allowable Reference Values:
3	6:53 PM	13.46	13.56		12.5-15 %O2 (50-60% of span)
	Mean (%O2)	13.46	13.55		Cylinder ID: EB0053431
	Difference of means (|R-A|) (%O2)	0.1	*Limit 0.5*	*Passed*	Expiration Date: 6/13/2023
					EPA Vendor ID: G12015
	Linearity Error (%)	0.7	*Limit 5.0*	*Passed*	Cylinder contains: O2,BALN
High Gas					
1	6:28 PM	22.20	22.22		
2	6:43 PM	22.20	22.23		Allowable Reference Values:
3	6:58 PM	22.20	22.24		20-25 %O2 (80-100% of span)
	Mean (%O2)	22.20	22.23		Cylinder ID: ALMO47793
	Difference of means (|R-A|) (%O2)	0.0	*Limit 0.5*	*Passed*	Expiration Date: 3/4/2027
					EPA Vendor ID: A12019
	Linearity Error (%)	0.1	*Limit 5.0*	*Passed*	Cylinder contains: CO2,O2,BALN

Linearity Error (LE) Determination

*LE (%) = (|R-A| / R) * 100*

R = Reference gas value

A = Mean of actual CEMS responses

APPENDIX 4

CYCLE TIME & RESPONSE TIME TESTS DOCUMENTATION

I/O Audit Data

Cricket Valley Energy Center


Data for 4/4/2020 2:11:50 PM thru 4/4/2020 2:38:30 PM

Timestamp	(Turbine 3) NOx Value	(Turbine 3) GT Megawatts Value
2:11:53 PM	2.131	230.131
2:12:03 PM	2.130	230.151
2:12:13 PM	2.130	230.012
2:12:23 PM	2.131	--
2:12:33 PM	2.132	229.631
2:12:43 PM	2.132	229.954
2:12:53 PM	2.127	229.941
2:13:03 PM	2.129	230.177
2:13:13 PM	2.127	230.144
2:13:23 PM	2.126	230.498
2:13:33 PM	2.126	230.668
2:13:43 PM	2.124	230.263
2:13:53 PM	2.122	229.953
2:14:03 PM	2.123	229.966
2:14:13 PM	2.122	230.052
2:14:23 PM	2.122	230.447
2:14:33 PM	2.123	229.924
2:14:43 PM	2.123	230.192
2:14:53 PM	2.042	229.938
2:15:03 PM	0.904	--
2:15:13 PM	0.127	230.454
2:15:23 PM	-0.010	230.469
2:15:33 PM	-0.022	230.296
2:15:43 PM	-0.023	230.560
2:15:53 PM	-0.027	230.223
2:16:03 PM	-0.027	229.944
2:16:13 PM	-0.027	230.794
2:16:23 PM	-0.027	230.667
2:16:33 PM	-0.027	230.403
2:16:43 PM	-0.029	230.529
2:16:53 PM	-0.029	230.350
2:17:03 PM	-0.030	229.848
2:17:13 PM	-0.029	230.278
2:17:23 PM	-0.029	230.122
2:17:33 PM	-0.030	229.804
2:17:43 PM	-0.029	230.254
2:17:53 PM	-0.029	229.729
2:18:03 PM	0.187	229.779
2:18:13 PM	1.446	230.092
2:18:23 PM	2.066	229.967
2:18:33 PM	2.084	230.244
2:18:43 PM	2.077	229.656
2:18:53 PM	2.091	229.819
2:19:03 PM	2.091	230.208
2:19:13 PM	2.090	230.266

NOXL Down = 1'

NOXL Ref gas =9.05 ppm
0.05% of Ref = 0.453 ppm
95.0% of Ref = 8.598 ppm
NOXH Ref gas =180.2 ppm
0.05% of Ref = 9.01 ppm
95.0% of Ref = 171.19 ppm

Timestamp	(Turbine 3) NOx Value	(Turbine 3) GT Megawatts Value
2:19:23 PM	2.092	230.325
2:19:33 PM	2.092	229.977
2:19:43 PM	2.093	229.927
2:19:53 PM	2.093	230.087
2:20:03 PM	2.094	230.580
2:20:13 PM	2.092	230.493
2:20:23 PM	2.093	230.109
2:20:33 PM	2.095	230.040
2:20:43 PM	2.095	229.934
2:20:53 PM	2.088	230.249
2:21:03 PM	1.516	230.109
2:21:13 PM	3.275	--
2:21:23 PM	7.473	229.871
2:21:33 PM	8.992	229.495
2:21:43 PM	9.014	229.761
2:21:53 PM	9.012	--
2:22:03 PM	9.015	229.660
2:22:13 PM	9.022	229.520
2:22:23 PM	9.028	230.041
2:22:33 PM	9.030	229.767
2:22:43 PM	9.030	230.146
2:22:53 PM	9.030	230.287
2:23:03 PM	9.031	230.029
2:23:13 PM	9.030	229.951
2:23:23 PM	9.031	--
2:23:33 PM	9.030	229.698
2:23:43 PM	9.028	229.895
2:23:53 PM	9.028	229.917
2:24:03 PM	9.028	229.780
2:24:13 PM	7.337	230.221
2:24:23 PM	3.183	229.916
2:24:33 PM	2.241	229.487
2:24:43 PM	2.175	229.996
2:24:53 PM	2.166	229.913
2:25:03 PM	2.157	230.241
2:25:13 PM	2.147	230.090
2:25:23 PM	2.148	230.529
2:25:33 PM	2.147	229.864
2:25:43 PM	2.144	229.931
2:25:53 PM	2.144	230.119
2:26:03 PM	2.145	229.678
2:26:13 PM	2.108	230.307
2:26:23 PM	2.083	229.808
2:26:33 PM	2.096	229.987
2:26:43 PM	2.096	229.900
2:26:53 PM	2.090	229.730
2:27:03 PM	6.344	229.403
2:27:13 PM	3.610	230.106
2:27:23 PM	0.056	229.993



Timestamp	(Turbine 3) NOx Value	(Turbine 3) GT Megawatts Value
2:27:33 PM	-0.069	229.982
2:27:43 PM	-0.044	229.856
2:27:53 PM	-0.069	230.080
2:28:03 PM	-0.038	230.105
2:28:13 PM	-0.044	229.824
2:28:23 PM	-0.050	229.923
2:28:33 PM	-0.056	230.017
2:28:43 PM	-0.050	229.901
2:28:53 PM	-0.069	229.989
2:29:03 PM	-0.038	230.158
2:29:13 PM	-0.044	229.901
2:29:23 PM	-0.026	230.225
2:29:33 PM	-0.027	229.663
2:29:43 PM	-0.026	--
2:29:53 PM	-0.027	229.465
2:30:03 PM	-0.027	229.809
2:30:13 PM	1.143	230.077
2:30:23 PM	2.001	229.770
2:30:33 PM	2.073	229.925
2:30:43 PM	2.079	230.294
2:30:53 PM	2.084	230.310
2:31:03 PM	2.076	229.698
2:31:13 PM	2.074	229.579
2:31:23 PM	2.075	229.419
2:31:33 PM	2.073	229.803
2:31:43 PM	2.074	229.835
2:31:53 PM	2.073	230.191
2:32:03 PM	2.074	229.764
2:32:13 PM	1.996	--
2:32:23 PM	2.015	229.894
2:32:33 PM	1.983	230.075
2:32:43 PM	1.977	229.975
2:32:53 PM	1.883	230.055
2:33:03 PM	26.320	229.652
2:33:13 PM	159.823	230.044
2:33:23 PM	178.805	230.082
2:33:33 PM	180.200	229.896
2:33:43 PM	180.669	229.378
2:33:53 PM	180.938	229.894
2:34:03 PM	181.045	229.636
2:34:13 PM	181.045	229.604
2:34:23 PM	181.070	229.616
2:34:33 PM	181.051	229.779
2:34:43 PM	181.051	229.542
2:34:53 PM	181.095	229.652
2:35:03 PM	181.101	229.468
2:35:13 PM	181.089	229.938
2:35:23 PM	181.170	229.910
2:35:33 PM	181.157	229.271

NOXH Up = 1'

Timestamp	(Turbine 3) NOx Value	(Turbine 3) GT Megawatts Value
2:35:43 PM	181.157	230.091
2:35:53 PM	181.201	230.063
2:36:03 PM	181.220	229.828
2:36:13 PM	111.475	229.956
2:36:23 PM	9.284	229.677
2:36:33 PM	9.284	230.095
2:36:43 PM	3.427	229.440
2:36:53 PM	2.834	230.065
2:37:03 PM	2.619	229.405
2:37:13 PM	2.507	229.254
2:37:23 PM	2.461	229.689
2:37:33 PM	2.439	229.829
2:37:43 PM	2.424	229.680
2:37:53 PM	2.420	229.848
2:38:03 PM	2.418	229.572
2:38:13 PM	2.415	229.370
2:38:23 PM	2.404	229.452
Average	23.362	229.960
Minimum	-0.069	229.254
Maximum	181.220	230.794

I/O Audit Data

Cricket Valley Energy Center


Data for 4/4/2020 10:33:00 PM thru 4/4/2020 10:45:40 PM

Timestamp	(Turbine 3) O2 Value	(Turbine 3) GT Megawatts Value
10:33:03 PM	13.065	233.812
10:33:13 PM	13.056	233.728
10:33:23 PM	13.058	234.026
10:33:33 PM	13.056	234.034
10:33:43 PM	13.058	233.883
10:33:53 PM	13.056	233.901
10:34:03 PM	13.058	--
10:34:13 PM	13.054	233.894
10:34:23 PM	13.058	233.624
10:34:33 PM	13.057	233.553
10:34:43 PM	13.058	233.661
10:34:53 PM	13.063	234.026
10:35:03 PM	13.058	233.456
10:35:13 PM	13.058	233.549
10:35:23 PM	13.057	233.945
10:35:33 PM	13.058	233.922
10:35:43 PM	13.058	233.740
10:35:53 PM	13.058	233.550
10:36:03 PM	13.058	233.466
10:36:13 PM	13.058	233.680
10:36:23 PM	13.058	233.956
10:36:33 PM	13.050	--
10:36:43 PM	13.062	233.759
10:36:53 PM	13.056	233.576
10:37:03 PM	5.617	233.912
10:37:13 PM	1.075	233.668
10:37:23 PM	0.281	233.722
10:37:33 PM	0.109	233.838
10:37:43 PM	0.076	233.539
10:37:53 PM	0.055	234.026
10:38:03 PM	0.050	233.630
10:38:13 PM	0.048	233.321
10:38:23 PM	0.043	234.231
10:38:33 PM	0.041	233.739
10:38:43 PM	0.035	--
10:38:53 PM	0.037	233.610
10:39:03 PM	0.029	--
10:39:13 PM	0.038	233.804
10:39:23 PM	0.035	233.848
10:39:33 PM	0.030	233.958
10:39:43 PM	0.023	233.624
10:39:53 PM	0.023	233.954
10:40:03 PM	0.098	--
10:40:13 PM	9.772	233.865
10:40:23 PM	12.397	233.609

O2 Ref gas =22.20%
0.05% of Ref = 1.11%
95.0% of Ref = 21.09%

O2 Down = 2'

Timestamp	(Turbine 3) O2 Value	(Turbine 3) GT Megawatts Value
10:40:33 PM	12.876	233.790
10:40:43 PM	12.980	--
10:40:53 PM	13.019	233.883
10:41:03 PM	13.033	233.520
10:41:13 PM	13.044	233.882
10:41:23 PM	13.046	234.040
10:41:33 PM	13.044	233.574
10:41:43 PM	13.045	233.776
10:41:53 PM	13.045	233.750
10:42:03 PM	13.051	233.807
10:42:13 PM	13.051	233.623
10:42:23 PM	13.044	--
10:42:33 PM	13.051	234.075
10:42:43 PM	13.052	233.800
10:42:53 PM	13.058	233.627
10:43:03 PM	4.593	--
10:43:13 PM	17.425	--
10:43:23 PM	21.333	233.786
10:43:33 PM	22.003	233.839
10:43:43 PM	22.173	233.595
10:43:53 PM	22.212	234.465
10:44:03 PM	22.233	234.127
10:44:13 PM	22.239	233.635
10:44:23 PM	22.247	233.594
10:44:33 PM	22.256	233.623
10:44:43 PM	22.254	233.411
10:44:53 PM	22.258	233.995
10:45:03 PM	22.260	233.428
10:45:13 PM	22.258	233.614
10:45:23 PM	22.259	233.461
10:45:33 PM	22.259	233.640
Average	11.461	233.761
Minimum	0.023	233.321
Maximum	22.260	234.465




I/O Audit Data

Cricket Valley Energy Center

Data for 4/4/2020 1:44:00 PM thru 4/4/2020 2:10:30 PM

Timestamp	(Turbine 3) CO Value	(Turbine 3) GT Megawatts Value
1:44:03 PM	-0.247	230.727
1:44:13 PM	-0.231	230.606
1:44:23 PM	-0.246	230.973
1:44:33 PM	-0.264	231.211
1:44:43 PM	-0.294	230.657
1:44:53 PM	-0.291	230.679
1:45:03 PM	-0.280	231.153
1:45:13 PM	-0.269	230.873
1:45:23 PM	-0.272	230.937
1:45:33 PM	-0.256	231.128
1:45:43 PM	-0.302	231.241
1:45:53 PM	-0.313	231.068
1:46:03 PM	-0.316	231.096
1:46:13 PM	-0.318	230.716
1:46:23 PM	-0.280	231.468
1:46:33 PM	-0.303	231.174
1:46:43 PM	-0.302	231.556
1:46:53 PM	-0.317	--
1:47:03 PM	-0.316	230.979
1:47:13 PM	-0.291	230.888
1:47:23 PM	-0.010	231.170
1:47:33 PM	1.774	--
1:47:43 PM	3.722	231.312
1:47:53 PM	5.789	231.358
1:48:03 PM	7.577	231.267
1:48:13 PM	7.906	231.486
1:48:23 PM	7.821	230.992
1:48:33 PM	7.699	231.177
1:48:43 PM	7.597	231.712
1:48:53 PM	7.553	231.379
1:49:03 PM	7.503	231.139
1:49:13 PM	7.478	231.090
1:49:23 PM	7.457	231.058
1:49:33 PM	7.421	231.116
1:49:43 PM	7.395	--
1:49:53 PM	7.386	230.990
1:50:03 PM	7.397	231.248
1:50:13 PM	7.294	231.308
1:50:23 PM	6.610	231.136
1:50:33 PM	5.337	230.527
1:50:43 PM	3.763	230.850
1:50:53 PM	2.172	230.774
1:51:03 PM	1.081	231.007
1:51:13 PM	0.448	--
1:51:23 PM	0.169	230.464




CO Ref gas =7.04 ppm
0.05% of Ref = 0.352 ppm
95.0% of Ref = 6.688 ppm

Timestamp	(Turbine 3) CO Value	(Turbine 3) GT Megawatts Value
1:51:33 PM	0.028	230.298
1:51:43 PM	-0.057	230.464
1:51:53 PM	-0.092	230.229
1:52:03 PM	-0.086	--
1:52:13 PM	-0.111	--
1:52:23 PM	-0.113	230.473
1:52:33 PM	-0.103	230.087
1:52:43 PM	-0.140	230.166
1:52:53 PM	-0.132	230.537
1:53:03 PM	-0.145	230.495
1:53:13 PM	-0.162	230.346
1:53:23 PM	-0.138	230.204
1:53:33 PM	-0.135	--
1:53:43 PM	0.011	230.256
1:53:53 PM	0.763	229.975
1:54:03 PM	2.003	230.200
1:54:13 PM	3.539	230.290
1:54:23 PM	5.127	230.162
1:54:33 PM	6.224	230.029
1:54:43 PM	6.842	230.107
1:54:53 PM	7.138	230.409
1:55:03 PM	7.309	230.000
1:55:13 PM	7.378	229.856
1:55:23 PM	7.365	230.473
1:55:33 PM	7.394	229.823
1:55:43 PM	7.400	230.339
1:55:53 PM	7.416	230.342
1:56:03 PM	7.443	--
1:56:13 PM	7.407	230.158
1:56:23 PM	7.392	230.111
1:56:33 PM	7.354	230.126
1:56:43 PM	7.350	230.421
1:56:53 PM	7.392	230.278
1:57:03 PM	7.402	230.089
1:57:13 PM	7.139	230.340
1:57:23 PM	6.311	230.231
1:57:33 PM	4.919	230.353
1:57:43 PM	3.289	229.892
1:57:53 PM	1.832	230.244
1:58:03 PM	0.888	230.596
1:58:13 PM	0.363	230.043
1:58:23 PM	0.135	230.235
1:58:33 PM	0.003	230.051
1:58:43 PM	-0.062	230.232
1:58:53 PM	-0.079	229.821
1:59:03 PM	-0.118	229.342
1:59:13 PM	-0.118	--
1:59:23 PM	-0.116	230.208
1:59:33 PM	-0.100	229.961

Upscale 2 = 170"

Downscale 2 = 160"

Timestamp	(Turbine 3) CO Value	(Turbine 3) GT Megawatts Value
1:59:43 PM	-0.086	229.723
1:59:53 PM	-0.073	229.918
2:00:03 PM	-0.086	230.229
2:00:13 PM	-0.111	--
2:00:23 PM	-0.116	230.302
2:00:33 PM	-0.124	229.724
2:00:43 PM	-0.080	230.514
2:00:53 PM	0.527	230.123
2:01:03 PM	1.655	230.561
2:01:13 PM	3.196	--
2:01:23 PM	--	230.349
2:01:33 PM	5.477	230.488
2:01:43 PM	6.465	230.467
2:01:53 PM	6.947	230.696
2:02:03 PM	7.179	230.546
2:02:13 PM	7.290	230.605
2:02:23 PM	7.327	229.966
2:02:33 PM	7.379	230.804
2:02:43 PM	7.381	230.567
2:02:53 PM	7.397	230.463
2:03:03 PM	7.390	230.310
2:03:13 PM	7.344	230.494
2:03:23 PM	7.339	230.757
2:03:33 PM	7.347	230.647
2:03:43 PM	7.363	230.742
2:03:53 PM	7.406	230.698
2:04:03 PM	7.421	230.373
2:04:13 PM	7.148	230.209
2:04:23 PM	6.248	230.291
2:04:33 PM	4.866	230.043
2:04:43 PM	3.247	230.486
2:04:53 PM	1.719	230.598
2:05:03 PM	0.778	230.168
2:05:13 PM	0.297	230.094
2:05:23 PM	0.081	230.131
2:05:33 PM	-0.038	230.838
2:05:43 PM	-0.089	230.543
2:05:53 PM	-0.101	229.753
2:06:03 PM	-0.108	230.089
2:06:13 PM	-0.081	230.201
2:06:23 PM	-0.099	230.061
2:06:33 PM	-0.097	230.005
2:06:43 PM	-0.100	230.742
2:06:53 PM	-0.107	230.637
2:07:03 PM	-0.097	230.095
2:07:13 PM	-0.116	230.129
2:07:23 PM	-0.137	--
2:07:33 PM	-0.155	229.915
2:07:43 PM	-0.143	230.280



Timestamp	(Turbine 3) CO Value	(Turbine 3) GT Megawatts Value
2:07:53 PM	-0.167	230.330
2:08:03 PM	-0.198	230.176
2:08:13 PM	-0.206	230.222
2:08:23 PM	-0.281	230.553
2:08:33 PM	-0.303	230.238
2:08:43 PM	-0.285	229.761
2:08:53 PM	-0.313	229.719
2:09:03 PM	-0.294	230.089
2:09:13 PM	-0.308	229.966
2:09:23 PM	-0.348	229.756
2:09:33 PM	-0.332	230.008
2:09:43 PM	-0.363	230.292
2:09:53 PM	-0.368	229.918
2:10:03 PM	-0.357	229.805
2:10:13 PM	-0.356	230.053
2:10:23 PM	-0.346	230.081
Average	2.648	230.465
Minimum	-0.368	229.342
Maximum	7.906	231.712

APPENDIX 5

DAHS VERIFICATION DOCUMENTATION

CUSTOM INSTRUMENTATION SERVICES CORPORATION

Data Acquisition and Handling System (DAHS) Verification Documentation

CeDAR and Breez75X ECMPS Reporting Software

Developed by:
Custom Instrumentation Services Corporation

EPA Regulations

- 40CFR75 Acid Rain
- 40CFR97 CSAPR NOx and SO_2

This letter serves as notice that the required 40 CFR 75 DAHS (missing data and formula) verification have been conducted and passed.

The attached formula verification document which includes CeDAR printouts demonstrates that the DAHS accurately calculates regulated parameters using raw data. In addition, verification tests have been conducted and passed for all missing data substitution routines for ECMPS reporting according to all applicable regulations and specifications in 40 CFR 75 Appendix D and Subpart D. The attached checklist, as adapted from Section 15 of the Acid Rain Program Policy Manual (revised) for 40CFR75, provides the regulatory description of the data substitution criteria.
These verification tests were conducted using numerous data sets at varying loads and operating conditions as well as various missing data periods as described in each set of tests. The tests were conducted using data sets with known outcomes and criteria and were verified against those outcomes. All missing data substitution procedures have been verified to be accurate and correct. Detailed data sets and documentation and test documentation are provided below

Walt Bastron
President

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CISCO

SO_2 Missing Data Verification Checklist [1]

Initial SO_2 Data Substitution: 75.31

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard SO_2 Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous SO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

1 The SO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CISCO

O_2 Missing Data Verification Checklist

Initial O_2 Data Substitution: 75.31

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(b) 75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.36(b) 75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard O2 Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 10th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 10th percentile of the lookback period.	75.36(d) 75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 5th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 5th percentile of the lookback period.	75.36(d) 75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the minimum value in the lookback period.	75.36(d) 75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.36(d) 75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.36(d) 75.33(a)

Miscellaneous SO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)

For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(c)(4)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous NOx Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

Appendix D Fuel Flow Rate Missing Data Verification Checklist

Single Fuel Hours, Load Based: Appendix D

Description	Regulation
Non-QA data is substituted with the average of the lookback period at the corresponding load range when only the same fuel was combusted.	App. D 2.4.2.2.1
Non-QA data is substituted with the average of the lookback period at the next higher available load range when only the same fuel was combusted if no data in the corresponding load range exists.	App. D 2.4.2.2.1
Non-QA data is substituted with the a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when only the same fuel was combusted exists.	App. D 2.4.2.2.1
Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3

Co-Fired Fuel Hours, Load Based: Appendix D

Description	Regulation
Non-QA data is substituted with the maximum in the lookback period at the corresponding load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Non-QA data is substituted with the maximum in the lookback period at the next higher available load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Non-QA data is substituted with a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when the same fuel is co-fired with another fuel exists.	App. D 2.4.2.3.1 App. D 2.4.2.3.3
Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3

Note: If Maximum Heat Rate is exceeded, manual adjustment of Fuel Flows is allowed so that reported Heat Rate equals the maximum. (App. D 2.4.2.3.4)

Fuel Specific NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Fuel Specific NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)

For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(3) 75.33(c)(8)(i) 75.33(c)(8)(ii)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a fuel specific MPC.	75.33(c)(4) 75.33(c)(8)(iii)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(5) 75.33(c)(8)(i) 75.33(c)(8)(ii)
If no data in the corresponding or higher load ranges exists in the lookback period, the fuel specific MPC is used.	75.33(c)(6) 75.33(c)(8)(iii)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.33(c)(8)

Miscellaneous Fuel Specific NO_X Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

CUSTOM INSTRUMENTATION SERVICES CORPORATION

Season Specific NO_X Missing Data Verification Checklist

Initial NO_X Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(1) 75.74(c)(7)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(2) 75.74(c)(7)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges. Historical data is separated into season specific pools.	75.31(c)(3) 75.74(c)(7)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Season Specific NO_X Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(i) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(A) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(B) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(i) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(A) 75.34(a)(2) 75.74(c)(7)

For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(B) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(3) 75.34(a)(2) 75.74(c)(7)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with an MPC.	75.33(c)(4) 75.74(c)(7)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into season specific pools.	75.33(c)(5) 75.34(a)(2) 75.74(c)(7)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6) 75.34(a)(2) 75.74(c)(7)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.34(a)(2) 75.74(c)(7)

Miscellaneous Season Specific NO_X Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CISCO

CO_2 Missing Data Verification Checklist 2

Initial CO_2 Data Substitution: 75.35(b) [75.31]

Description	Regulation
Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)
Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard CO_2 Data Substitution: 75.35(d) [75.33]

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)
For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(b)(4)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous CO_2 Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

2 The CO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CISCO

Missing Data Verification Checklist [3]

Initial Stack Flow Data Substitution: 75.31

Description	Regulation
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)
Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)
Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)
Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)

Standard Stack Flow Data Substitution: 75.33

Description	Regulation
For non-QA data blocks less than or equal to 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)
For non-QA data blocks greater than 24 hours with an availability of 95.0% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)
For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)
For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90.0% and less than 95.0%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)

For non-QA data blocks with an availability greater than or equal to 80.0% and less than 90.0%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)
For non-QA data blocks with an availability below 80.0%, non-QA data is substituted with a MPC.	75.33(c)(4)
If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)
If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)
Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)

Miscellaneous Stack Flow Data Substitution

Description	Regulation
For Non-QA data blocks that cross quarter boundaries, the two missing data block portions will be handled individually with respect to the quarter they end or start.	Reporting Instructions II(C)(12)
For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)

3 The stack flow missing data verification mentioned here does not apply to Cricket Valley Energy Center

CUSTOM INSTRUMENTATION SERVICES CORPORATION

TECHNICAL DOCUMENT - DATA SUBSTITUTION - 1 [4]

SO2 Missing Data Verification Checklist [5]

Initial SO2 Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.31(b)(1)	DS1 1/1/99
	Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.31(b)(2)	DS2 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Standard SO2 Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(1)(ii)(A)	DS1 3/3/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period.	75.33(b)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.33(b)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(b)(2)(ii)(A)	DS1 6/14/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period.	75.33(b)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period.	75.33(b)(3)	DS1 6/30/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

CUSTOM INSTRUMENTATION SERVICES CORPORATION

	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.33(b)(4)	DS1 7/31/99
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)	DS3 3/31/02

Miscellaneous SO2 Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

O2 Missing Data Verification Checklist

Initial O2 Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 720 QA hours, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(b) 75.31(b)(1)	DS1 1/1/99
	Prior to 720 QA hours, non-QA data is substituted with the MPC if previous QA data does not exist.	75.36(b) 75.31(b)(2)	DS2 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Standard O2 Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 10^{th} percentile of the lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(1)(ii)(A)	DS1 3/3/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 10^{th} percentile of the lookback period.	75.36(d) 75.33(b)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage.	75.36(d) 75.33(b)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 5^{th} percentile of the	75.36(d) 75.33(b)(2)(ii)(A)	DS1 6/14/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

	lookback period if the substitution value is greater than the average of the data from the hour before and after the outage.		
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 5th percentile of the lookback period.	75.36(d) 75.33(b)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the minimum value in the lookback period.	75.36(d) 75.33(b)(3)	DS1 6/30/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.36(d) 75.33(b)(4)	DS1 7/31/99
	Substitution routines have a maximum lookback period of 26280 hours.	75.36(d) 75.33(a)	DS3 3/31/02

Miscellaneous SO2 Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

NOx Missing Data Verification Checklist

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)	DS1 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

4 The dates and data sets for in-house testing of formulas, monitor code logic and general software testing is historical, but is consistent with the operations required by the most recent regulatory requirements.

5 The stack SO2 missing data verification mentioned here does not apply to Cricket Valley Energy Center

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

CUSTOM INSTRUMENTATION SERVICES CORPORATION

Standard NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(1)(i)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(1)(ii)(A)	DS2 1/3/00
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range.	75.33(c)(1)(ii)(B)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.33(c)(2)(i)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage.	75.33(c)(2)(ii)(A)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range.	75.33(c)(2)(ii)(B)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range.	75.33(c)(3)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a MPC.	75.33(c)(4)	DS1 8/3/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used.	75.33(c)(5)	DS2 1/3/00
	If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6)	DS2 1/3/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Miscellaneous NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

Appendix D Fuel Flow Rate Missing Data Verification Checklist

Single Fuel Hours, Load Based: Appendix D

P/F	Description	Regulation	Test
	Non-QA data is substituted with the average of the lookback period at the corresponding load range when only the same fuel was combusted.	App. D 2.4.2.2.1	DS1 1/24/99
	Non-QA data is substituted with the average of the lookback period at the next higher available load range when only the same fuel was combusted if no data in the corresponding load range exists.	App. D 2.4.2.2.1	DS2 1/2/00
	Non-QA data is substituted with the a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when only the same fuel was combusted exists.	App. D 2.4.2.2.1	DS2 1/1/99
	Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3	DS3 6/30/03

Co-Fired Fuel Hours, Load Based: Appendix D

P/F	Description	Regulation	Test
	Non-QA data is substituted with the maximum in the lookback period at the corresponding load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS1 1/1/99
	Non-QA data is substituted with the maximum in the lookback period at the next higher available load range when the same fuel is co-fired with another fuel.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS2 1/3/00
	Non-QA data is substituted with a maximum potential flow rate if no data in the lookback period at the corresponding or higher load range when the same fuel is co-fired with another fuel exists.	App. D 2.4.2.3.1 App. D 2.4.2.3.3	DS1 1/1/99
	Substitution routines have a maximum lookback period of 26280 hours.	App. D 2.4.3	DS3 6/30/03

Note: If Maximum Heat Rate is exceeded, manual adjustment of Fuel Flows is allowed so that reported Heat Rate equals the maximum. (App. D 2.4.2.3.4)

Fuel Specific NOx Missing Data Verification Checklist

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range.	75.31(c)(1)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range.	75.31(c)(2)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges.	75.31(c)(3)	DS1 1/1/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Fuel Specific NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 5/31/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(1)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(i) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/16/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CISCO

	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(A) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(2)(ii)(B) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(3) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with a fuel specific MPC.	75.33(c)(4) 75.33(c)(8)(iii)	DS1 7/31/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into fuel specific pools with co-fired hours either treated as a separate fuel or the fuel with the highest emission rate.	75.33(c)(5) 75.33(c)(8)(i) 75.33(c)(8)(ii)	DS1 7/31/99
	If no data in the corresponding or higher load ranges exists in the lookback period, the fuel specific MPC is used.	75.33(c)(6) 75.33(c)(8)(iii)	DS1 1/30/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.33(c)(8)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

CUSTOM INSTRUMENTATION SERVICES CORPORATION

Miscellaneous Fuel Specific NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

Season Specific NOx Missing Data Verification Checklist

Initial NOx Data Substitution: 75.31

P/F	Description	Regulation	Test
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(1) 75.74(c)(7)	DS1 1/1/99
	Prior to 2160 QA hours, non-QA data is substituted with the average of the lookback period in the next higher available load range if prior data does not exist in the corresponding load range. Historical data is separated into season specific pools.	75.31(c)(2) 75.74(c)(7)	DS2 4/3/99
	Prior to 2160 QA hours, non-QA data is substituted with the MPC if previous data does not exist in the corresponding or higher load ranges. Historical data is separated into season specific pools.	75.31(c)(3) 75.74(c)(7)	DS1 1/31/99
	Initial data substitution routines are to be used no more than 26280 clock hours after certification.	75.31(a)	DS3 12/30/01

Season Specific NOx Data Substitution: 75.33

P/F	Description	Regulation	Test
	For non-QA data blocks less than or equal to 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(i) 75.34(a)(2) 75.74(c)(7)	DS1 4/20/99
	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the 90th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(A) 75.34(a)(2) 75.74(c)(7)	DS1 5/31/99

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

CUSTOM INSTRUMENTATION SERVICES CORPORATION

	For non-QA data blocks greater than 24 hours with an availability of 95% or greater, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 90th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(1)(ii)(B) 75.34(a)(2) 75.74(c)(7)	DS1 5/31/99
	For non-QA data blocks less than or equal to 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(i) 75.34(a)(2) 75.74(c)(7)	DS1 6/16/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the 95th percentile of the lookback period in the corresponding load range if the substitution value is greater than the average of the data from the hour before and after the outage. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(A) 75.34(a)(2) 75.74(c)(7)	DS1 6/17/99
	For non-QA data blocks greater than 8 hours with an availability greater than or equal to 90% and less than 95%, non-QA data is substituted with the average of the data from the hour before and after the outage if the substitution value is greater than the 95th percentile of the lookback period in the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(2)(ii)(B) 75.34(a)(2) 75.74(c)(7)	DS1 6/17/99
	For non-QA data blocks with an availability greater than or equal to 80% and less than 90%, non-QA data is substituted with the maximum value in the lookback period at the corresponding load range. Historical data is separated into season specific pools.	75.33(c)(3) 75.34(a)(2) 75.74(c)(7)	DS1 6/21/99
	For non-QA data blocks with an availability below 80%, non-QA data is substituted with an MPC.	75.33(c)(4) 75.74(c)(7)	DS1 7/31/99
	If no data in the lookback period exists for the corresponding load range, the maximum value at the next higher available load range is used. Historical data is separated into season specific pools.	75.33(c)(5) 75.34(a)(2) 75.74(c)(7)	DS1 7/31/99
	If no data in the corresponding or higher load ranges exists in the lookback period, the MPC is used.	75.33(c)(6) 75.34(a)(2) 75.74(c)(7)	DS1 1/30/00
	Substitution routines have a maximum lookback period of 26280 hours.	75.33(a) 75.34(a)(2) 75.74(c)(7)	DS3 3/31/02

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

CUSTOM INSTRUMENTATION SERVICES CORPORATION

Miscellaneous Season Specific NOx Data Substitution

P/F	Description	Regulation	Test
	For Non-QA data blocks that cross quarter boundaries, the missing data block ends or starts with the quarter.	Reporting Instructions II(C)(12)	DS3 6/30/03 7/1/03
	For non-combusting periods within an outage, the non-combusting hours are not counted in the size of the non-QA block.	Reporting Instructions II(C)(12)	DS3 8/6/03

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX (303) 790-7292

U003 40CFR75-PNG

Formula Verification Examples

Unit Name:	**CRICKET VALLEY ENERGY CENTER**	**Oris Code:**	**57185**
Date/ Time:	**3/8/2020 HOUR 0600**	**Unit /Stack #**	**U003**

Formula **19-1**
Parameter **NOx lb/mmBtu for gas**

Fd dscf/mmbtu	K units lb/dscf-ppm Nox	NOx ppmv	O2 dry %	**NOx lb/mmBtu**	BAF	**Bias adj. NOx lb/mmBtu**
8710	1.194E-07	10.85	14.05	**0.0344**	1.000	**0.0344**

Formula **F-20**
Parameter **Heat Input - gas**

CT Total NG hscf/hr	CT Op Time hr	DB Total NG hscf/hr	DB Op Time hr	**Total NG hscf**
12085.7	1	4263.7	1.00	**16349.4**

NG GCV Btu/hscf	mmBtu/Btu	CT Heat input mmBtu	DB Heat input mmBtu	**Total Heat input mmBtu**
104500	1.00E-06	1263.0	445.6	**1708.6**

Formula **F-24A**
Parameter **NOx lb/hr** **gas**

NOx lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NOx lb/hr**	BAF	**Bias adj. NOx lb/hr**
0.034	1263.0	445.6	**58.7**	1.000	**58.7**

Formula **G-4**
Parameter **CO2 ton/hr** **gas**

Fc scf/mmbtu	CT HI gas mmBtu/hr	DB HI gas mmBtu/hr	M Wt CO2 g/g-mole	Conversion 1/385 scf CO2/lbmole	Convers lb/ton	**CO2 Ton/hr**
1040	1263.0	445.6	44	2.60E-03	2000	**101.6**

Formula **D-5**
Parameter **SO2 lb/hr** **gas**

CT HI gas mmBtu/hr	DB HI gas mmBtu/hr	SO2 EF lb/mmBtu	**SO2 lb/hr**
1263.0	445.6	0.0006	**1.03**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 3- Daily 40CFR75 Emissions & Operations Report

March 8, 2020

Hour	O2 %	NOx ppm	NOx lb/mmBtu	Bias Factor	Bias Adj NOx lb/mmBtu	NOx lbs	SO2 lbs	CO2 tons	Gas Flow hscf/hr	Nat Gas GCV Btu/hscf	Heat Input mmBtu/hr	Turbine On-Time	Total Megawatts	Bin Load Range
00	14.09	11.16	0.0356	1.000	0.0356	60.9	1.03	101.6	16349.4	104500	1708.6	1.00	80.1	4
01	14.07	11.08	0.0353	1.000	0.0353	60.3	1.03	101.6	16349.4	104500	1708.6	1.00	80.0	4
02	14.06	10.98	0.0349	1.000	0.0349	59.7	1.03	101.6	16349.5	104500	1708.6	1.00	79.9	4
03	14.05	10.88	0.0345	1.000	0.0345	59.0	1.03	101.6	16349.4	104500	1708.6	1.00	80.1	4
04	14.05	10.74	0.0341	1.000	0.0341	58.0	1.02	101.0	16263.7	104500	1699.6	1.00	79.7	4
05	14.06	10.81	0.0344	1.000	0.0344	58.4	1.02	101.0	16263.7	104500	1699.6	1.00	79.8	4
06	14.05	10.85	0.0344	1.000	0.0344	58.7	1.03	101.6	16349.4	104500	1708.6	1.00	80.3	4
07	14.06	10.80	0.0343	1.000	0.0343	58.3	1.02	101.0	16263.7	104500	1699.6	1.00	79.5	4
08	13.79	12.31	0.0376	1.000	0.0376	68.3	1.09	107.9	17378.1	104500	1816.0	1.00	97.6	5
09	13.24	13.65	0.0387	1.000	0.0387	88.0	1.37	135.1	22092.4	104500	2308.7	1.00	168.2	9
10	13.10	14.16	0.0395	1.000	0.0395	101.1	1.54	152.1	25263.8	104500	2640.1	1.00	209.8	10
11	13.02	19.05	0.0525	1.000	0.0525	137.1	1.57	155.1	27662.9	104500	2890.8	1.00	236.1	10
12	13.04	19.45	0.0538	1.000	0.0538	134.9	1.51	149.1	27835.2	104500	2908.8	1.00	237.2	10
13	13.05	19.27	0.0534	1.000	0.0534	131.1	1.47	145.9	23485.7	104500	2454.3	1.00	236.3	10
14	13.07	19.06	0.0529	1.000	0.0529	129.9	1.48	145.8	27664.0	104500	2890.9	1.00	235.4	10
15	13.09	18.82	0.0524	1.000	0.0524	127.7	1.46	144.8	23314.3	104500	2436.3	1.00	234.3	10
16	13.11	18.68	0.0521	1.000	0.0521	126.9	1.46	144.8	23314.3	104500	2436.3	1.00	233.6	10
17	13.11	18.59	0.0519	1.000	0.0519	126.4	1.46	144.8	23314.3	104500	2436.3	1.00	233.6	10
18	13.07	18.62	0.0517	1.000	0.0517	128.0	1.49	147.2	27663.8	104500	2890.9	1.00	235.7	10
19	13.03	18.72	0.0517	1.000	0.0517	139.4	1.62	160.3	27809.9	104500	2906.1	1.00	237.5	10
20	13.00	18.23	0.0502	1.000	0.0502	146.4	1.75	173.3	27915.9	104500	2917.2	1.00	238.9	10
21	13.02	18.34	0.0506	1.000	0.0506	147.1	1.75	172.9	27835.2	104500	2908.8	1.00	238.0	10
22	13.01	18.61	0.0513	1.000	0.0513	149.3	1.75	172.9	27835.2	104500	2908.8	1.00	238.2	10
23	13.00	18.54	0.0510	1.000	0.0510	148.8	1.75	173.4	27920.9	104500	2917.8	1.00	238.6	10

CeDAR 1-Hour Data

Cricket Valley Energy Center

Data for 3/8/2020 12 AM thru 3/8/2020 11 PM

Timestamp	(Turbine 3) CT Nat Gas Flow hscf/hr 1-Hr	(Turbine 3) DB Nat Gas Flow hscf/hr 1-Hr	(Turbine 3) DB Nat Gas Flow On-Time 1-Hr	(Turbine 3) 75-Total Gas Flow hscf/hr 1-Hr	(Turbine 3) Unit On-Time 1-Hr
3/8/20 12 AM	12085.7	4263.7	1.00	16349.4	1.00
3/8/20 1 AM	12085.7	4263.7	1.00	16349.4	1.00
3/8/20 2 AM	12085.7	4263.8	1.00	16349.5	1.00
3/8/20 3 AM	12085.7	4263.7	1.00	16349.4	1.00
3/8/20 4 AM	12000.0	4263.7	1.00	16263.7	1.00
3/8/20 5 AM	12000.0	4263.7	1.00	16263.7	1.00
3/8/20 6 AM	12085.7	4263.7	1.00	16349.4	1.00
3/8/20 7 AM	12000.0	4263.7	1.00	16263.7	1.00
3/8/20 8 AM	13114.3	4263.8	1.00	17378.1	1.00
3/8/20 9 AM	17828.6	4263.8	0.92	22092.4	1.00
3/8/20 10 AM	21000.0	4263.8	0.82	25263.8	1.00
3/8/20 11 AM	23400.0	4262.9	0.37	27662.9	1.00
3/8/20 12 PM	23571.4	4263.8	0.10	27835.2	1.00
3/8/20 1 PM	23485.7	295.9 <13>	0.00	23485.7	1.00
3/8/20 2 PM	23400.0	4264.0	0.02	27664.0	1.00
3/8/20 3 PM	23314.3	38.2 <13>	0.00	23314.3	1.00
3/8/20 4 PM	23314.3	116.9 <13>	0.00	23314.3	1.00
3/8/20 5 PM	23314.3	103.3 <13>	0.00	23314.3	1.00
3/8/20 6 PM	23400.0	4263.8	0.07	27663.8	1.00
3/8/20 7 PM	23571.4	4238.5	0.53	27809.9	1.00
3/8/20 8 PM	23657.1	4258.8	1.00	27915.9	1.00
3/8/20 9 PM	23571.4	4263.8	1.00	27835.2	1.00
3/8/20 10 PM	23571.4	4263.8	1.00	27835.2	1.00
3/8/20 11 PM	23657.1	4263.8	1.00	27920.9	1.00
Average (all)	18900.0	3574.9	0.66	22451.8	1.00
Total (all)	--	--	15.83	538844.1	24.00
Minimum (all)	12000.0	38.2	0.00	16263.7	1.00
Maximum (all)	23657.1	4264.0	1.00	27920.9	1.00
Average (valid values only)	18900.0	4262.2	0.66	22451.8	1.00
Total (valid values only)	--	--	15.83	538844.1	24.00
Count (valid values only)	24	20	24	24	24

<13> = Down

U003 40CFR60-PNG

Formula Verification Examples

Unit Name: **CRICKET VALLEY ENERGY CENTER** **Oris Code:** **57185**
Date/ Time: **3/8/2020 HOUR 0600** **Unit /Stack #** **U003**

Formula **19-1**
Parameter **NOx lb/mmBtu for gas**

Fd dscf/mmbtu	K units lb/dscf-ppm Nox	NOx ppmv	O2 dry %	**NOx lb/mmBtu**
8710	1.194E-07	10.85	14.05	**0.0344**

Formula **F-20**
Parameter **Heat Input - gas**

CT Total NG hscf/hr	CT Op Time hr	DB Total NG hscf/hr	DB Op Time hr	Total PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**Total Heat input mmBtu**
12085.7	1.00	4263.7	1.00	16349.4	104500	1.00E-06	**1708.6**

CT Total PNG klb/hr	PNG Density klb/hscf	CT Op Time hr	Total CT PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**CT Heat input mmBtu**
50.8	0.0042	1	12085.7	104500	1.00E-06	**1263.0**

DB Total PNG kscf/hr	conversion hscf/kscf	DB Op Time hr	Total DB PNG hscf	PNG GCV Btu/hscf	mmBtu/Btu	**DB Heat input mmBtu**
426.4	10.0	1	4264.0	104500	1.00E-06	**445.6**

Parameter **NOx ppm@15% O2**

NOx ppm	O2 dry %	**NOx ppm corr**
10.85	14.05	**9.35**

Parameter **NOx lb/hr** **gas**

NOx lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NOx lb/hr**
0.0344	1263.0	445.6	**58.78**

Parameter **CO ppm@15% O2**

Formula **19-1**
Parameter **CO lb/mmBtu for gas**

Fc scf CO2/mmbtu	K ppmvd)	CO MW lb/lb-mol	CO ppmv	O2 dry %	**CO lb/mmBtu**
8710	2.59E-09	28	43.70	14.05	**0.0842**

CO ppm	O2 dry %	**CO ppm corr**
43.70	14.05	**37.64**

Parameter **CO lb/hr** **gas**

CO lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**CO lb/hr**
0.0842	1263.0	445.6	**143.86**

U003 40CFR60-PNG

Formula **19-1**
Parameter **NH3 lb/mmBtu for gas**

Fc scf CO2/mmbtu	K ppmvd)	NH3 MW lb/lb-mol	NH3 ppmv	O2 dry %	**NH3 lb/mmBtu**
8710	2.59E-09	17.03	0.98	14.05	**0.0011**

NH3 ppm	O2 dry %	**NH3 ppm corr**
0.98	14.05	**0.84**

Parameter **CO lb/hr** **gas**

NH3 lb/mmBtu	CT Heat input mmBtu/hr	DB Heat input mmBtu/hr	**NH3 lb/hr**
0.0011	1263.0	445.6	**1.88**

Parameter **PM10/PM2.5 lb/hr** **gas**

CT HI gas mmBtu/hr	CT PM10/PM2.5 EF lb/mmBtu	**CT PM10/PM2.5 lb/hr**	DB HI gas mmBtu/hr	DB PM10/PM2.5 EF lb/mmBtu	**DB PM10/PM2.5 lb/hr**	**Total PM10/PM2.5 lb/hr**
1263.0	0.0005	**0.63**	445.6	0.0005	**0.22**	**0.85**

Parameter **VOC lb/hr** **gas**

CT HI gas mmBtu/hr	VOC EF lb/mmBtu	**CT VOC lb/hr**	DB HI gas mmBtu/hr	VOC EF lb/mmBtu	**DB VOC lb/hr**	**Total VOC lb/hr**
1263.0	0.0002	**0.25**	445.6	0.0002	**0.09**	**0.34**

Parameter **H2SO4 lb/hr** **gas**

CT HI gas mmBtu/hr	H2SO4 EF lb/mmBtu	**CT H2SO4 lb/hr**	DB HI gas mmBtu/hr	H2SO4 EF lb/mmBtu	**DB H2SO4 lb/hr**	**Total H2SO4 lb/hr**
1263.0	0.0001	**0.13**	445.6	0.0001	**0.04**	**0.17**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 3- Daily Emissions Report

March 8, 2020

Hourly Emission Limits
Normal Ops NOx ppm @15% O2 - 2 | Normal Ops CO ppm @15% O2 - 2 | NH3 Slip ppm @15% O2 - 5

30-Day Rolling Emission Limits
NOx ppm @15% O2 - <Null>

Hour	O2 %	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lbs	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lbs	NH3 Slip ppm	NH3 Slip ppm @15% O2	NH3 Slip lb/mmBtu	NH3 Slip lbs	Process Status
00	14.09	11.16	9.67	0.0356	60.82	37.78	32.73	0.0732	125.06	0.76	0.66	0.0009	1.54	Hot SU
01	14.07	11.08	9.57	0.0353	60.31	39.27	33.92	0.0759	129.68	0.80	0.69	0.0009	1.54	Hot SU
02	14.06	10.98	9.47	0.0349	59.63	41.81	36.06	0.0807	137.88	0.84	0.72	0.0010	1.71	Hot SU
03	14.05	10.88	9.37	0.0345	58.94	41.53	35.77	0.0800	136.68	0.86	0.74	0.0010	1.71	Hot SU
04	14.05	10.74	9.25	0.0341	57.95	53.39	45.99	0.1029	174.89	0.94	0.81	0.0011	1.87	Hot SU
05	14.06	10.81	9.32	0.0344	58.47	47.15	40.67	0.0910	154.66	0.96	0.83	0.0011	1.87	Hot SU
06	14.05	10.85	9.35	0.0344	58.78	43.70	37.64	0.0842	143.86	0.98	0.84	0.0011	1.88	Hot SU
07	14.06	10.80	9.32	0.0343	58.29	45.71	39.43	0.0882	149.90	1.03	0.89	0.0012	2.03	Hot SU
08	13.79	12.31	10.22	0.0376	68.28	21.80	18.09	0.0405	73.55	0.73	0.61	0.0008	1.46	Hot SU
09	13.24	13.65	10.51	0.0387	87.96	0.99	0.76	0.0017	3.87	0.45	0.35	0.0005	1.13	Hot SU
10	13.10	14.16	10.71	0.0395	101.11	0.63	0.48	0.0011	2.81	0.46	0.35	0.0005	1.28	Hot SU
11	13.02	19.05	14.26	0.0525	137.03	0.60	0.45	0.0010	2.62	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
12	13.04	19.45	14.60	0.0538	134.92	0.60	0.45	0.0010	2.51	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
13	13.05	19.27	14.48	0.0534	131.06	0.57	0.43	0.0010	2.45	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
14	13.07	19.06	14.36	0.0529	129.83	0.56	0.42	0.0009	2.21	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
15	13.09	18.82	14.22	0.0524	127.66	0.55	0.42	0.0009	2.19	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
16	13.11	18.68	14.15	0.0521	126.93	0.53	0.40	0.0009	2.19	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
17	13.11	18.59	14.08	0.0519	126.45	0.53	0.40	0.0009	2.19	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
18	13.07	18.62	14.03	0.0517	128.03	0.47	0.35	0.0008	1.99	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
19	13.03	18.72	14.03	0.0517	139.49	0.50	0.37	0.0008	2.16	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
20	13.00	18.23	13.61	0.0502	146.44	0.49	0.37	0.0008	2.34	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
21	13.02	18.34	13.73	0.0506	147.19	0.48	0.36	0.0008	2.33	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
22	13.01	18.61	13.92	0.0513	149.22	0.50	0.37	0.0008	2.33	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
23	13.00	18.54	13.85	0.0510	148.80	0.49	0.37	0.0008	2.34	**OOR**	**OOR**	**OOR**	**OOR**	Hot SU
Average	13.43	15.48	12.09	0.0445	104.32	15.86	13.61	0.0305	52.61	0.80	0.68	0.0009	1.64	
Total					2503.59				1262.69				18.02	
30-Day			**NSD**											

Cricket Valley Energy Center

Dover Plains, NY

Turbine 3- Daily Mass Emissions Report

March 8, 2020

Hour	NOx lbs	CO lbs	PM10/PM2.5 lbs	NH3 Slip lbs	VOC lbs	H2SO4 lbs	Turbine On-Time
00	60.82	125.06	0.85	1.54	0.34	0.17	1.00
01	60.31	129.68	0.85	1.54	0.34	0.17	1.00
02	59.63	137.88	0.85	1.71	0.34	0.17	1.00
03	58.94	136.68	0.85	1.71	0.34	0.17	1.00
04	57.95	174.89	0.85	1.87	0.34	0.17	1.00
05	58.47	154.66	0.85	1.87	0.34	0.17	1.00
06	58.78	143.86	0.85	1.88	0.34	0.17	1.00
07	58.29	149.90	0.85	2.03	0.34	0.17	1.00
08	68.28	73.55	0.91	1.46	0.36	0.18	1.00
09	87.96	3.87	1.13	1.13	0.45	0.23	1.00
10	101.11	2.81	1.28	1.28	0.51	0.25	1.00
11	137.03	2.62	1.30	**OOR**	0.52	0.25	1.00
12	134.92	2.51	1.25	**OOR**	0.50	0.25	1.00
13	131.06	2.45	1.23	**OOR**	0.49	0.25	1.00
14	129.83	2.21	1.22	**OOR**	0.49	0.24	1.00
15	127.66	2.19	1.22	**OOR**	0.49	0.24	1.00
16	126.93	2.19	1.22	**OOR**	0.49	0.24	1.00
17	126.45	2.19	1.22	**OOR**	0.49	0.24	1.00
18	128.03	1.99	1.24	**OOR**	0.50	0.24	1.00
19	139.49	2.16	1.35	**OOR**	0.54	0.27	1.00
20	146.44	2.34	1.46	**OOR**	0.58	0.29	1.00
21	147.19	2.33	1.45	**OOR**	0.58	0.29	1.00
22	149.22	2.33	1.45	**OOR**	0.58	0.29	1.00
23	148.80	2.34	1.46	**OOR**	0.58	0.29	1.00
Average	104.32	52.61	1.13	1.64	0.45	0.23	
Total	2503.59	1262.69	27.19	18.02	10.87	5.40	24.00

Cricket Valley Energy Center

Dover Plains, NY

Turbine 3- Daily Operations & EMS Inlet Emissions Report

March 8, 2020

Hour	SCR NOx ppm	SCR O2 %	CO Cat CO ppm	CT Nat Gas Flow klb	CT Heat Input mmBtu	DB Nat Gas Flow kscf	DB Heat Input mmBtu	Total Heat Input mmBtu	GT Megawatt Hours	ST Megawatt Hours	Process Status
00	10.81	8.67	44.84	50.8	1263.0	426.4	445.6	1708.6	80.1	**Down**	Hot SU
01	10.77	13.74	46.45	50.8	1263.0	426.4	445.6	1708.6	80.0	**Down**	Hot SU
02	10.74	13.73	49.14	50.8	1263.0	426.4	445.6	1708.6	79.9	**Down**	Hot SU
03	10.62	13.72	48.87	50.8	1263.0	426.4	445.6	1708.6	80.1	**Down**	Hot SU
04	10.48	13.73	61.93	50.4	1254.0	426.4	445.6	1699.6	79.7	**Down**	Hot SU
05	10.57	13.73	55.23	50.4	1254.0	426.4	445.6	1699.6	79.8	**Down**	Hot SU
06	10.64	13.72	51.13	50.8	1263.0	426.4	445.6	1708.6	80.3	**Down**	Hot SU
07	10.64	13.74	53.48	50.4	1254.0	426.4	445.6	1699.6	79.5	**Down**	Hot SU
08	12.10	13.45	24.71	55.1	1370.4	426.4	445.6	1816.0	97.6	**Down**	Hot SU
09	13.30	12.90	0.73	74.9	1863.1	392.3	410.0	2273.1	168.2	**Down**	Hot SU
10	14.04	12.76	0.28	88.2	2194.5	349.6	365.4	2559.9	209.8	**Down**	Hot SU
11	19.37	12.61	0.26	98.3	2445.3	157.7	164.8	2610.1	236.1	**Down**	Hot SU
12	19.82	12.62	0.20	99.0	2463.2	42.6	44.6	2507.8	237.2	**Down**	Hot SU
13	19.61	12.64	0.25	98.6	2454.3	**Down**	**Down**	2454.3	236.3	**Down**	Hot SU
14	19.36	12.66	0.24	98.3	2445.3	8.5	8.9	2454.2	235.4	**Down**	Hot SU
15	19.07	12.68	0.25	97.9	2436.3	**Down**	**Down**	2436.3	234.3	**Down**	Hot SU
16	18.97	12.70	0.24	97.9	2436.3	**Down**	**Down**	2436.3	233.6	**Down**	Hot SU
17	18.86	12.70	0.23	97.9	2436.3	**Down**	**Down**	2436.3	233.6	**Down**	Hot SU
18	18.93	12.66	0.18	98.3	2445.3	29.8	31.2	2476.5	235.7	**Down**	Hot SU
19	19.15	12.61	0.18	99.0	2463.2	224.7	234.7	2697.9	237.5	**Down**	Hot SU
20	18.67	12.59	0.17	99.4	2472.2	425.9	445.0	2917.2	238.9	**Down**	Hot SU
21	18.79	12.60	0.16	99.0	2463.2	426.4	445.6	2908.8	238.0	**Down**	Hot SU
22	19.07	12.59	0.14	99.0	2463.2	426.4	445.6	2908.8	238.2	**Down**	Hot SU
23	19.01	12.59	0.14	99.4	2472.2	426.4	445.6	2917.8	238.6	**Down**	Hot SU
Average	15.56	12.84	18.31	79.4	1975.1	337.4	352.6	2268.9	174.5	**Down**	
Total				1905.4	47401.3	6747.9	7051.8	54453.1	4188.4	**Down**	

Formula Verification Examples

Unit Name:	**CRICKET VALLEY ENERGY CENTER**	**Oris Code:**	**57185**
Date/ Time:	**03/08/2020 HOUR 0600**	**Unit /Stack #**	**U003**

Formula **Conversion**
Parameter **CO2 metric tons-PNG**

CO2 (Eq. G-4) tons	conversion factor tons/metric ton	**CO2 metric tons**	GWP Factor	**CO2e (CO2) metric tons**
101.6	1.1023	**92.17**	1	**92.17**

Formula **C-10**
Parameter **CH4 metric tons-PNG**

Total CT HI mmBtu	Total DB HI mmBtu	CH4 EF kgCH4/mmBtu	Conversion metric ton/kg	**CH4 metric tons**	GWP Factor	**CO2e (CH4) metric tons**
1263.0	445.6	0.001	0.001	**0.00171**	25	**0.04275**

Formula **C-10**
Parameter **N2O metric tons-PNG**

Total CT HI mmBtu	Total DB HI mmBtu	N2O EF kgN2O/mmBtu	Conversion metric ton/kg	**N2O metric tons**	GWP Factor	**CO2e (N2O) metric tons**
1263.0	445.6	0.0001	0.001	**0.00017**	298	**0.05066**

Parameter **CO2e metric tons-PNG**

CO2e (CO2) metric tons	CO2e (CH4) metric tons	CO2e(N2O) metric tons	**CO2e (total) metric tons**
92.2	0.04275	0.05066	**92.26341**

Cricket Valley Energy Center

Dover Plains, NY

Turbine 3- Daily GHG Emissions Report

March 8, 2020

Hour	Nat Gas GCV Btu/scf	Heat Input mmBtu	CO2 tons	CO2 Metric Tons	N2O Metric Tons	CH4 Metric Tons	N2O (CO2e) Metric Tons	CH4 (CO2e) Metric Tons	Total CO2e Metric Tons	Turbine On-Time
00	1045.0	1708.6	101.6	92.17	0.00017	0.00171	0.05066	0.04275	92.26341	1.00
01	1045.0	1708.6	101.6	92.17	0.00017	0.00171	0.05066	0.04275	92.26341	1.00
02	1045.0	1708.6	101.6	92.17	0.00017	0.00171	0.05066	0.04275	92.26341	1.00
03	1045.0	1708.6	101.6	92.17	0.00017	0.00171	0.05066	0.04275	92.26341	1.00
04	1045.0	1699.6	101.0	91.63	0.00017	0.00170	0.05066	0.04250	91.72316	1.00
05	1045.0	1699.6	101.0	91.63	0.00017	0.00170	0.05066	0.04250	91.72316	1.00
06	1045.0	1708.6	101.6	92.17	0.00017	0.00171	0.05066	0.04275	92.26341	1.00
07	1045.0	1699.6	101.0	91.63	0.00017	0.00170	0.05066	0.04250	91.72316	1.00
08	1045.0	1816.0	107.9	97.89	0.00018	0.00182	0.05364	0.04550	97.98914	1.00
09	1045.0	2273.1	135.1	122.56	0.00023	0.00227	0.06854	0.05675	122.68529	1.00
10	1045.0	2559.9	152.1	137.98	0.00026	0.00256	0.07748	0.06400	138.12148	1.00
11	1045.0	2610.1	155.1	140.71	0.00026	0.00261	0.07748	0.06525	140.85273	1.00
12	1045.0	2507.8	149.1	135.26	0.00025	0.00250	0.07450	0.06250	135.39700	1.00
13	1045.0	2454.3	145.9	132.36	0.00025	0.00245	0.07450	0.06125	132.49575	1.00
14	1045.0	2454.2	145.8	132.27	0.00024	0.00246	0.07152	0.06150	132.40302	1.00
15	1045.0	2436.3	144.8	131.36	0.00024	0.00244	0.07152	0.06100	131.49252	1.00
16	1045.0	2436.3	144.8	131.36	0.00024	0.00244	0.07152	0.06100	131.49252	1.00
17	1045.0	2436.3	144.8	131.36	0.00024	0.00244	0.07152	0.06100	131.49252	1.00
18	1045.0	2476.5	147.2	133.54	0.00024	0.00248	0.07152	0.06200	133.67352	1.00
19	1045.0	2697.9	160.3	145.42	0.00027	0.00269	0.08046	0.06725	145.56771	1.00
20	1045.0	2917.2	173.3	157.22	0.00029	0.00292	0.08642	0.07300	157.37942	1.00
21	1045.0	2908.8	172.9	156.85	0.00029	0.00291	0.08642	0.07275	157.00917	1.00
22	1045.0	2908.8	172.9	156.85	0.00029	0.00291	0.08642	0.07275	157.00917	1.00
23	1045.0	2917.8	173.4	157.31	0.00029	0.00292	0.08642	0.07300	157.46942	1.00
Average	1045.0									
Total		54453.1	3236.4	2936.04	0.00542	0.05447	1.61516	1.36175	2939.01691	24.00

APPENDIX 6

RELATIVE ACCURACY TEST AUDIT REPORT

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00003 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER, LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
APRIL 4, 2020

Report Date: April 28, 2020



Corporate Headquarters
1600 W Tacoma Street
Broken Arrow, Oklahoma 74012

AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778
www.airhygiene.com


Remote Testing Offices
Las Vegas, NV 89156
Ft. Worth, TX 76028
Humble, TX 77338
Shreveport, LA 71115
Miami, FL 33101
Pittsburgh, PA 15205

RELATIVE ACCURACY TEST AUDIT
FOR THE
GENERAL ELECTRIC, 7F.05,
UNIT #U-00003 CEMS
PREPARED FOR
CRICKET VALLEY ENERGY CENTER, LLC
AT THE
CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
APRIL 4, 2020

Prepared and Reviewed by:



Darin Grimes
Sr. Testing Solutions Specialist



Gavin Dolsky, QI
Staff Engineer – Report Manager

I, 

Matt McBride, QSTI
Sr. Project Manager
certify that this testing was conducted and this report was created in conformance with the requirements of ASTM D7036

(this page intentionally left blank)

Table of Contents

1.0 INTRODUCTION *1*

1.1 TEST PURPOSE AND OBJECTIVES **1**

1.2 SUMMARY OF TEST PROGRAM **2**

1.2.1 Participating Organizations 2
1.2.2 Industry 2
1.2.3 Air Permit and Federal Requirements 2
1.2.4 Plant Location 2
1.2.5 Equipment Tested 2
1.2.6 Emission Points 2
1.2.7 Emission Parameters Measured 2
1.2.8 Date of Emission Test 2
1.2.9 Federal Certifications 3

1.3 KEY PERSONNEL **3**

2.0 SUMMARY OF TEST RESULTS *3*

3.0 SOURCE OPERATION *5*

3.1 PROCESS DESCRIPTION **5**

3.2 SAMPLING LOCATION **5**

4.0 SAMPLING AND ANALYTICAL PROCEDURES *5*

4.1 TEST METHODS **5**

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS **6**

APPENDICES

Appendix A Test Results and Calculations

Appendix B CEMS and Reference Method Data

Appendix C Calibration Gas Certifications

Appendix D Quality Assurance and Quality Control Data

Appendix E Stratification Test Data

Relative Accuracy Test Audit
General Electric, 7F.05, Unit #U-00003 CEMS
Cricket Valley Energy Center, LLC
Cricket Valley Energy Center
Dover Plains, New York
April 4, 2020

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the Relative Accuracy Test Audit (RATA) for nitrogen oxides (NOx), carbon monoxide (CO), ammonia (NH_3), and oxygen (O_2) from the exhaust of the General Electric, 7F.05, Unit #U-00003 for Cricket Valley Energy Center, LLC at the Cricket Valley Energy Center in Dover Plains, New York. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on April 4, 2020.

The accumulated data from the RATA provides the figures for evaluating the acceptability of the operation of the on-site continuous emission monitoring system (CEMS) for the monitoring of NOx, CO, NH_3, and O_2 from the General Electric, 7F.05, Unit #U-00003 for Cricket Valley Energy Center, LLC at the Cricket Valley Energy Center in Dover Plains, New York.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to perform the initial certification RATA on the CEMS that serves the General Electric, 7F.05, Unit #U-00003 for Cricket Valley Energy Center, LLC at the Cricket Valley Energy Center in Dover Plains, New York. Reference method (RM) testing followed the Code of Federal Regulations (CFR), Title 40 (40 CFR), Part 60 (40 CFR 60), Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320. RM values are compared with the on-site CEMS to document performance as required in the 40 CFR 60, Appendix B, Performance Specifications (PS) and 40 CFR 75 Appendix A and B. All relative accuracies were established on-site and were governed by the following sets of rules:

In accordance with 40 CFR 60, Appendix B, PS 2, Section 13.2, the NOx and NH_3 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent when average emissions during the test are greater than 50 percent of the emission standard or alternative relative accuracy (ARA) does not exceed 10.0 percent when the average emissions during the test are less than 50 percent of the emission standard. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

In accordance with 40 CFR 75, Appendix A, Section 3.3.2(a) and (b), the NOx RATA results are acceptable if the relative accuracy (RA) does not exceed 10.0 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and reference method (RM) values does not exceed 0.020 lb/MMBtu. Passing this set of criteria requires the CEMS to be retested after no more than two operating quarters. Alternatively, in accordance with 40 CFR 75, Appendix B, Section 2.3.1.2(a) and (f), and Appendix B, Figure 2, the NOx RATA results are acceptable if the RA does not exceed 7.5 percent or if during the RATA the average NOx emission rate is less than or equal to 0.200 lb/MMBtu and the average difference between the CEMS and RM values does not exceed 0.015 lb/MMBtu. Passing this set of criteria allows the CEMS to be retested after four operating quarters or at least within eight calendar quarters.

In accordance with 40 CFR 60, Appendix B, PS 3, Section 13.2, the O_2 RATA results are acceptable if the relative accuracy (RA) does not exceed 20.0 percent or if the average difference between the CEMS and reference method (RM) values does not exceed plus or minus 1.0 percent of the measured value.

In accordance with 40 CFR 60, Appendix B, PS 4 and 4A, Sections 13.2 of each, the CO relative accuracy (RA) test results are acceptable if the RA does not exceed 10.0 percent, if the average difference between the CEMS and reference method (RM) values plus the 2.5 percent confidence coefficient (2.5%CC) does not exceed 5.0 parts per million (ppm), or if the alternative relative accuracy (ARA) does not exceed 5.0 percent. Part 60 further requires that the unit be operating at greater than 50 percent of normal load.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

1.2.1 Participating Organizations
- New York State Department of Environmental Conservation (NYSDEC)
- Cricket Valley Energy Center, LLC
- Custom Instrumentation Services Corporation (CiSCO)
- Bechtel
- Air Hygiene

1.2.2 Industry
- Electric Utility / Electric Services

1.2.3 Air Permit and Federal Requirements
- Permit Number: 3-1326-00275/00009
- DEC ID: 3132600275
- 40 CFR 60, Appendix B, Performance Specifications (PS)
- 40 CFR 75, Appendix A and B

1.2.4 Plant Location
- Cricket Valley Energy Center in Dover Plains, New York
  - GPS Coordinates [Latitude 41.67616, Longitude -73.576914]
  - 2241 Route NY 22, Dover Plains, New York 12522
  - Federal Registry System / Facility Registry Service (FRS) No. – 110043333372
  - Source Classification Code (SCC) – 20100209

1.2.5 Equipment Tested
- General Electric, 7F.05, Unit #U-00003
  - NOx Analyzer (TAPI T200M, Serial No. 1014)
  - NH_3 Analyzer (TAPI T200M, Serial No. 1049)
  - CO Analyzer (TAPI T300M, Serial No. 520)
  - O_2 Analyzer (TAPI T803, Serial No. 151)

1.2.6 Emission Points
- Exhaust from the General Electric, 7F.05, Unit #U-00003
- For all gases, one sample point in the exhaust duct from the General Electric, 7F.05, Unit #U-00003, determined after conducting a stratification test

1.2.7 Emission Parameters Measured
- NOx
- CO
- NH_3
- O_2

1.2.8 Date of Emission Test
- April 4, 2020

1.2.9 Federal Certifications

- Stack Testing Accreditation Council AETB Certificate No. 3796.02
- International Standard ISO/IEC 17025:2005 Certificate No. 3796.01

1.3 KEY PERSONNEL

Cricket Valley Energy Center, LLC:	Marc Duquette (mduquette@cricketvalley.com)	617-320-5219
Bechtel:	Chris Putman (csputman@bechtel.com)	703-429-6923
CiSCO:	Reginald Williams (rwilliams@ciscocems.com)	720-419-0177
Air Hygiene:	Matt McBride (mmcbride@airhygiene.com)	918-307-8865
Air Hygiene:	Swanson Bierman	918-307-8865
Air Hygiene:	Jeremy Johnson	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Cricket Valley Energy Center, LLC's General Electric, 7F.05, Unit #U-00003 located at the Cricket Valley Energy Center on April 4, 2020 are summarized in the following table and relate only to the items tested.

TABLE 2.1
SUMMARY OF GENERAL ELECTRIC, 7F.05, UNIT #U-00003 RATA RESULTS

Pollutant	Units	Criteria			Results	Passed / Test Frequency
		CFR	Specification / Section	Standard		
NOx	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 14.33%	YES / ANNUAL
NOx	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	RA = 11.59%	YES / ANNUAL
NOx	lb/MMBtu	Part 75	Appendix A, Section 3.3.2(a),(b) Appendix B, Section 2.3.1.2(a),(f), Figure 2	RA ≤ 10%, or if lb/MMBtu ≤ 0.200, d ≤ ±0.020 lb/MMBtu Annual Incentive RA ≤ 7.5%, or if lb/MMBtu ≤ 0.2, d ≤ ±0.015 lb/MMBtu	RA = 15.05% RM = 0.01 lb/MMBtu d = -0.001 lb/MMBtu BAF=1.000	YES / ANNUAL
O_2	%vd	Part 60	Appendix B, Performance Specification 3, Section 13.2	RA ≤ 20%, or d ≤ ±1.0%	RA = 0.08% d = 0.0 %	YES / ANNUAL
CO	ppmvd@15%O_2	Part 60	Appendix B, Performance Specification 4, 4A, from all Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 ppmv, or ARA ≤ 5%	RA = 131.72% |d|+2.5%CC = 0.2 ppm	YES / ANNUAL
CO	lb/hr	Part 60	Appendix B, Performance Specification 4, 4A Section 13.2	RA ≤ 10%, or d + 2.5% CC ≤ ±5 lb/hr, or ARA ≤ 5%	RA = 131.78% |d|+2.5%CC = 0.2 ppm (|d|+2.5%CC = 0.9 lb/hr)	YES / ANNUAL
NH_3	ppmvd@15%O_2	Assumed Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	ARA = 4.34%	YES / ANNUAL
NH_3	lb/hr	Part 60	Appendix B, Performance Specification 2, Section 13.2	RA ≤ 20%, or ARA ≤ 10%	ARA = 3.84%	YES / ANNUAL
Load	MW	Part 60	Appendix B, Performance Specifications	> 50% max load	351.5	WITHIN TOLERANCE
Load	MW	Part 75	Appendix A and B	normal load range	351.5	WITHIN TOLERANCE

Notes: RA = relative accuracy, ARA = alternative relative accuracy, RM = reference method value, d = difference between RM and CEMS value, CC = confidence coefficient, v = velocity, BAF = bias adjustment factor

The RATA passed for all pollutants (NOx, CO, NH_3, and O_2) in all units (ppm@15%O_2, lb/hr, lb/MMBtu, and %) under all 40 CFR 60 and 40 CFR 75 criteria.

Specifically, NOx in units of ppm@15%O_2 and lb/hr, passed 40 CFR 60 criteria with an RA less than 20 percent. NOx in units of lb/MMBtu passed the 40 CFR 75 alternative annual incentive criteria with an emissions rate of less than 0.200 lb/MMBtu and a difference between the RM and CEMS analyzers of less than 0.015 lb/MMBtu. Also the Bias Adjustment Factor test resulted in an adjustment factor equal to 1.0 (no adjustment required). O_2 in units of % passed the 40 CFR 60 criteria with an RA less than 20 percent. CO in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 alternative criteria with a concentration difference between the RM and CEMS analyzers plus the confidence coefficient of less than 5 ppm and 5 lb/hr respectively. NH_3 in units of ppm@15%O_2 and lb/hr passed the 40 CFR 60 alternative criteria with an ARA less than 10 percent.

Unit load was within the 40 CFR 60 required criteria of greater than 50 percent of the maximum load and also fell within the normal load criteria as defined by the plants Quality Control and Monitoring Plan which defined the upper and lower boundary on the unit and the normal and secondary normal load ranges.

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

Cricket Valley Energy Center, LLC (CVEC) owns and operates the Cricket Valley Energy Center located at 2241 ST RTE 22 in Dover Plains, New York. Located on the Cricket Valley Energy Center are three General Electric (GE) 7F.05 Combustion Turbine Generators (CTGs), designated as U-00001, U-00002, and U-0003, and each unit is equipped with one heat recovery steam generator (HRSG) with supplemental duct firing. Each unit is rated at 381 megawatts (MW). The nominal MW per unit as per the NYSDEC Permit ID 3-1326-00275/00009 is identified as 333 MW.

A single, dedicated dry extraction based continuous emissions monitoring system (CEMS) is installed on each unit. The CEMS configurations include nitrogen oxide (NOx) analyzers, ammonia (NH_3) analyzers, carbon monoxide (CO) analyzers, diluent gas oxygen (O_2) analyzers, and data acquisition and handling systems (DAHS).

3.2 SAMPLING LOCATION

The CTG stack is vertical, circular, and measures 19 feet (ft) (228 inches) in diameter at the test ports which are approximately 265.8 ft above grade level with an exit elevation of approximately 282.5 ft above grade level. The test ports are located approximately 70.8 ft (850 inches) downstream and approximately 16.7 ft (200.4 inches) upstream from the nearest disturbances. Air Hygiene has field verified the measurable dimensions. Non-field verified dimensions are provided by Cricket Valley Energy Center, LLC. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test. During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the General Electric, 7F.05, Unit #U-00003 at the Cricket Valley Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on April 4, 2020.

TABLE 4.1
SUMMARY OF SAMPLING METHODS

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Oxygen	EPA Method 3A	Paramagnetic Cell
Nitrogen Oxides	EPA Method 7E	Chemiluminescent Analyzer
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor
Ammonia and Moisture	EPA Method 320	Fourier Transform Infrared

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 3A, 7E, 10, 19; and 40 CFR 63, Appendix A, Method 320.

Figure 4.1 depicts the sample system used for the real-time gas analyzer tests. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a heated head pump and into the FTIR then to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory / portable analyzer via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the real-time analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in a climate controlled, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NOx calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. For target compounds measured with the Fourier transform infrared (FTIR) spectrometer, interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations. Spectral data was analyzed by the MKS MG2000 software.

Ten test runs of approximately 21 minutes each were conducted on the General Electric, 7F.05, Unit #U-00003 for NOx, CO, NH_3, and O_2.

The stack gas analysis for O_2 concentrations was performed in accordance with procedures set forth in EPA Method 3A. The O_2 analyzer uses a paramagnetic cell detector.

EPA Method 7E was used to determine concentrations of NOx. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO_2 in nitrogen certified gas cylinder was used to verify at least a 90 percent NO_2 conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

An MKS Instruments - MultiGas™ Fourier Transform Infrared (FTIR) spectrometer, or equivalent, was used for NH_3 and H_2O analysis per EPA Method 320. The FTIR spectrometer spectral resolution was 0.5 cm^{-1}. The system employed a silicon carbide infrared source at 1200ºC, a helium neon reference laser, beam splitters, potassium bromide (KBr) cell window, front-surface optical transfer mirrors, and multi-pass absorption cells. MCT detectors were used and cooled with liquid nitrogen in order to maintain a constant temperature of 77 Kelvin. The approximately 5.11-meter multi-pass path cells incorporated aspheric, aberration-correcting mirrors to increase the optical throughput and the detection sensitivity. Transducers and thermocouples were connected directly to the insulated sample cells that provide the pressure and temperatures of the sample streams. During testing, the temperature of the absorption cells was set at 191ºC. Elevated temperature prevented gas condensation within the cell and minimized compound adhesion to the cell walls and mirrors. The volume of the absorption cell was 0.5 liters, so at a sample gas flow rate of 4.0 liters per minute, the sample gas in the cell is refreshed approximately four times each minute. Interferograms consisting of 28 co-added scans were recorded continuously during the test periods, and provided approximately 30-second average concentrations.

TABLE 4.2
ANALYTICAL INSTRUMENTATION

Parameter	Manufacturer and Model	Range	Sensitivity	Detection Principle
NOx	THERMO 42 series	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO_2 to NO. Chemiluminescence of reaction of NO with O_3. Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48 series	User may select up to 10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
NH_3 and H_2O	MKS 2030	User may select from multiple ranges	0.1 ppm	Fourier Transform Infrared – FTIR
O_2	SERVOMEX 1440	0-25%	0.1%	Paramagnetic cell, inherently linear.

APPENDIX A

TEST RESULTS AND CALCULATIONS

TABLE A.1:
EMISSIONS TESTING SCHEDULE

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
U-00003	Base Load	Stratification Test	1	04/04/20	7:28:21	8:07:21	DAHS
U-00003	Base Load	Gas RATA	1	04/04/20	17:23:02	17:43:32	DAHS
U-00003	Base Load	Gas RATA	2	04/04/20	17:52:02	18:12:32	DAHS
U-00003	Base Load	Gas RATA	3	04/04/20	18:20:04	18:40:34	DAHS
U-00003	Base Load	Gas RATA	4	04/04/20	18:51:19	19:11:49	DAHS
U-00003	Base Load	Gas RATA	5	04/04/20	19:20:23	19:40:53	DAHS
U-00003	Base Load	Gas RATA	6	04/04/20	19:48:23	20:08:53	DAHS
U-00003	Base Load	Gas RATA	7	04/04/20	20:20:13	20:40:43	DAHS
U-00003	Base Load	Gas RATA	8	04/04/20	20:49:13	21:09:43	DAHS
U-00003	Base Load	Gas RATA	9	04/04/20	21:17:13	21:37:43	DAHS
U-00003	Base Load	Gas RATA	10	04/04/20	21:50:13	22:10:43	DAHS

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
O_2 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(%vd)	(%vd)	(diff)	($diff^2$)
1	17:23 - 17:43	YES	349.6	13.08	13.08	0.00	0.00
2	17:52 - 18:12	NO	349.8	13.04	13.08		
3	18:20 - 18:40	YES	350.4	13.07	13.07	0.00	0.00
4	18:51 - 19:11	YES	350.7	13.05	13.06	-0.01	0.00
5	19:20 - 19:40	YES	351.5	13.08	13.05	0.03	0.00
6	19:48 - 20:08	YES	351.9	13.05	13.04	0.01	0.00
7	20:20 - 20:40	YES	352.7	13.02	13.03	-0.01	0.00
8	20:49 - 21:09	YES	353.0	13.01	13.02	-0.01	0.00
9	21:17 - 21:37	YES	353.1	13.01	13.02	-0.01	0.00
10	21:50 - 22:10	YES	351.8	13.02	13.02	0.00	0.00
11		NO					
12		NO					
	Total		**3164.7**	**117.38**	**117.39**	**-0.01**	**0.00**
	Average		**351.6**	**13.04**	**13.04**	**0.00**	

Number of Runs	9
Standard Deviation	0.01
T-value	2.306
Confidence Coefficient	0.01

Average Difference =	**0.0**
Relative Accuracy =	**0.1%**

Part 60, Appendix B, Performance Specification 3,
13.2 CEMS Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent of the mean value of the reference method (RM) data. The results are also acceptable if the absolute value of the difference between the mean RM value and the mean CEMS value is less than or equal to 1.0 percent O2 (or CO2).

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	17:23 - 17:43	YES	349.6	1.51	1.70	-0.19	0.04
2	17:52 - 18:12	YES	349.8	1.53	1.70	-0.17	0.03
3	18:20 - 18:40	YES	350.4	1.52	1.70	-0.18	0.03
4	18:51 - 19:11	YES	350.7	1.53	1.70	-0.17	0.03
5	19:20 - 19:40	YES	351.5	1.51	1.70	-0.19	0.04
6	19:48 - 20:08	YES	351.9	1.34	1.55	-0.21	0.04
7	20:20 - 20:40	YES	352.7	1.50	1.73	-0.23	0.05
8	20:49 - 21:09	YES	353.0	1.40	1.60	-0.20	0.04
9	21:17 - 21:37	YES	353.1	1.48	1.70	-0.22	0.05
10	21:50 - 22:10	NO	351.8	1.47	1.70		
11		NO					
12		NO					
	Total		**3162.7**	**13.32**	**15.08**	**-1.76**	**0.35**
	Average		**351.4**	**1.48**	**1.68**	**-0.20**	

Number of Runs	9
Standard Deviation	0.02
T-value	2.306
Confidence Coefficient	0.02

Relative Accuracy = 14.3%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	17:23 - 17:43	YES	349.6	0.00	0.00	0.00	0.00
2	17:52 - 18:12	YES	349.8	0.10	0.00	0.10	0.01
3	18:20 - 18:40	YES	350.4	0.13	0.00	0.13	0.02
4	18:51 - 19:11	YES	350.7	0.17	0.00	0.17	0.03
5	19:20 - 19:40	YES	351.5	0.10	0.00	0.10	0.01
6	19:48 - 20:08	NO	351.9	0.20	0.00		
7	20:20 - 20:40	YES	352.7	0.15	0.00	0.15	0.02
8	20:49 - 21:09	YES	353.0	0.15	0.00	0.15	0.02
9	21:17 - 21:37	YES	353.1	0.15	0.00	0.15	0.02
10	21:50 - 22:10	YES	351.8	0.15	0.00	0.15	0.02
11		NO					
12		NO					
	Total		**3162.6**	**1.10**	**0.00**	**1.10**	**0.15**
	Average		**351.4**	**0.12**	**0.00**	**0.12**	

Number of Runs	9
Standard Deviation	0.05
T-value	2.306
Confidence Coefficient	0.04

Relative Accuracy =	**131.7%**
|d (difference in ppm)| + CC =	**0.16**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(ppmvd@15%O_2)	(ppmvd@15%O_2)	(diff)	(diff^2)
1	17:23 - 17:43	YES	349.6	1.18	0.97	0.21	0.04
2	17:52 - 18:12	YES	349.8	1.25	0.97	0.28	0.08
3	18:20 - 18:40	NO	350.4	1.27	0.99		
4	18:51 - 19:11	YES	350.7	1.23	0.98	0.25	0.06
5	19:20 - 19:40	YES	351.5	0.94	0.98	-0.04	0.00
6	19:48 - 20:08	YES	351.9	0.83	1.18	-0.35	0.12
7	20:20 - 20:40	YES	352.7	0.72	1.02	-0.30	0.09
8	20:49 - 21:09	YES	353.0	0.94	1.21	-0.27	0.08
9	21:17 - 21:37	YES	353.1	0.94	0.99	-0.05	0.00
10	21:50 - 22:10	YES	351.8	1.02	1.00	0.02	0.00
11		NO					
12		NO					
	Total		**3164.1**	**9.03**	**9.30**	**-0.27**	**0.48**
	Average		**351.6**	**1.00**	**1.03**	**-0.03**	

Number of Runs	9
Standard Deviation	0.24
T-value	2.306
Confidence Coefficient	0.19

Relative Accuracy =	**21.6%**
Applicable Standard =	**5.00**
Alternative Relative Accuracy =	**4.3%**

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	17:23 - 17:43	YES	349.6	13.58	14.93	-1.35	1.81
2	17:52 - 18:12	YES	349.8	13.76	14.93	-1.17	1.38
3	18:20 - 18:40	YES	350.4	13.68	14.89	-1.21	1.46
4	18:51 - 19:11	YES	350.7	13.77	14.88	-1.11	1.23
5	19:20 - 19:40	YES	351.5	13.59	14.94	-1.35	1.82
6	19:48 - 20:08	YES	351.9	12.14	13.61	-1.47	2.16
7	20:20 - 20:40	YES	352.7	13.61	15.29	-1.68	2.82
8	20:49 - 21:09	YES	353.0	12.67	14.13	-1.46	2.14
9	21:17 - 21:37	YES	353.1	13.38	15.07	-1.69	2.86
10	21:50 - 22:10	NO	351.8	13.34	15.09		
11		NO					
12		NO					
	Total		**3162.7**	**120.18**	**132.67**	**-12.49**	**17.68**
	Average		**351.4**	**13.35**	**14.74**	**-1.39**	

Number of Runs	9
Standard Deviation	0.21
T-value	2.306
Confidence Coefficient	0.16

Relative Accuracy = 11.6%

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
CO RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	17:23 - 17:43	YES	349.6	0.02	0.00	0.02	0.00
2	17:52 - 18:12	YES	349.8	0.55	0.00	0.55	0.30
3	18:20 - 18:40	YES	350.4	0.70	0.00	0.70	0.50
4	18:51 - 19:11	YES	350.7	0.93	0.00	0.93	0.86
5	19:20 - 19:40	YES	351.5	0.54	0.00	0.54	0.29
6	19:48 - 20:08	NO	351.9	1.09	0.00		
7	20:20 - 20:40	YES	352.7	0.83	0.00	0.83	0.69
8	20:49 - 21:09	YES	353.0	0.84	0.00	0.84	0.71
9	21:17 - 21:37	YES	353.1	0.82	0.00	0.82	0.67
10	21:50 - 22:10	YES	351.8	0.81	0.00	0.81	0.66
11		NO					
12		NO					
	Total		**3162.6**	**6.05**	**0.00**	**6.05**	**4.68**
	Average		**351.4**	**0.67**	**0.00**	**0.67**	

Number of Runs	9
Standard Deviation	0.28
T-value	2.306
Confidence Coefficient	0.21

Relative Accuracy =	**131.8%**
|d (difference in lb/hr)| + CC =	**0.89**

Part 60, Appendix B, Performance Specification 4,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS having span values of 1,000 ppmv CO.
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA or 5 percent when the applicable emission standard (permit limit) is used to calculate RA.

Part 60, Appendix B, Performance Specification 4A,
1.2.1 This specification is for evaluating the acceptability of carbon monoxide (CO) continuous emission monitoring systems (CEMS) at the time of installation or soon after and whenever specified in an applicable subpart of the regulations. This specification was developed primarily for CEMS that comply with low emission standards (less than 200 ppmv).
13.2 Relative Accuracy. The RA of the CEMS must be no greater than 10 percent when the average RM value is used to calculate RA, 5 percent when the applicable emission standard (permit limit) is used to calculate RA, or within 5 ppmv when the RA is calculated as the absolute average difference between the RM and CEMS plus the 2.5 percent confidence coefficient.

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
NH_3 RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/hr)	(lb/hr)	(diff)	($diff^2$)
1	17:23 - 17:43	YES	349.6	3.93	3.09	0.84	0.70
2	17:52 - 18:12	YES	349.8	4.15	3.10	1.05	1.11
3	18:20 - 18:40	NO	350.4	4.23	3.17		
4	18:51 - 19:11	YES	350.7	4.10	3.16	0.94	0.89
5	19:20 - 19:40	YES	351.5	3.13	3.11	0.02	0.00
6	19:48 - 20:08	YES	351.9	2.77	3.79	-1.02	1.05
7	20:20 - 20:40	YES	352.7	2.40	3.32	-0.92	0.85
8	20:49 - 21:09	YES	353.0	3.14	3.93	-0.79	0.63
9	21:17 - 21:37	YES	353.1	3.16	3.25	-0.09	0.01
10	21:50 - 22:10	YES	351.8	3.41	3.28	0.13	0.02
11		NO					
12		NO					
	Total		**3164.1**	**30.19**	**30.03**	**0.16**	**5.26**
	Average		**351.6**	**3.35**	**3.34**	**0.02**	

Number of Runs	9
Standard Deviation	0.81
T-value	2.306
Confidence Coefficient	0.62

Relative Accuracy =	**19.1%**
Applicable Standard* =	**16.66**
Alternative Relative Accuracy =	**3.8%**

* Value calculated using the Applicable Standard of 5 ppm@15%O_2 and the average stack flow and O_2 concentration for the first three runs.

$$NH_3\ {}^{lb}/_{hr} = \frac{(20.9 - \%O_2) * C_{adj} * Q_s * MW}{(20.9 - 15) * 10^6 * G} = \frac{(20.9 - 13.06) * 5 * 56{,}704{,}028 * 17.03}{(20.9 - 15) * 10^6 * 385.23}$$
$$= 16.66$$

Part 60, Appendix B, Performance Specification 2,
8.4.1 RA Test Period. Conduct the RA test according to the procedure given in Sections 8.4.2 through 8.4.6 while the affected facility is operating at more than 50 percent of normal load, or as specified in an applicable subpart.
13.2 Relative Accuracy Performance Specification. The RA of the CEMS must be no greater than 20 percent when RM is used in the denominator of Eq. 2-6 (average emissions during test are greater than 50 percent of the emission standard) or 10 percent when the applicable emission standard (permit limit) is used in the denominator of Eq. 2-6 (average emissions during test are less than 50 percent of the emission standard).
Eq. 2.6 RA=([|d|+|CC|]*100)/RM

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
NOx RATA Data Sheet
Cricket Valley Energy Center

RUN #	RUN TIME	USED	UNIT LOAD	RM	CEMS	RM-CEMS	
			(MW)	(lb/MMBtu)	(lb/MMBtu)	(diff)	($diff^2$)
1	17:23 - 17:43	YES	349.6	0.0056	0.0063	-0.0007	0.0000
2	17:52 - 18:12	YES	349.8	0.0056	0.0063	-0.0007	0.0000
3	18:20 - 18:40	YES	350.4	0.0056	0.0062	-0.0006	0.0000
4	18:51 - 19:11	YES	350.7	0.0056	0.0062	-0.0006	0.0000
5	19:20 - 19:40	YES	351.5	0.0056	0.0063	-0.0007	0.0000
6	19:48 - 20:08	YES	351.9	0.0050	0.0057	-0.0007	0.0000
7	20:20 - 20:40	YES	352.7	0.0055	0.0064	-0.0009	0.0000
8	20:49 - 21:09	YES	353.0	0.0051	0.0059	-0.0008	0.0000
9	21:17 - 21:37	YES	353.1	0.0054	0.0063	-0.0009	0.0000
10	21:50 - 22:10	NO	351.8	0.0054	0.0063		
11		NO					
12		NO					
	Total		**3162.7**	**0.0490**	**0.0556**	**-0.0066**	**0.0000**
	Average		**351.4**	**0.0054**	**0.0062**	**-0.0007**	

Number of Runs	9
Standard Deviation	0.0001
T-value	2.306
Confidence Coefficient	0.0001

Relative Accuracy = 15.05%

If the mean difference is less than or equal to the absolute value of the confidence coefficient, then the Bias Test passes and the bias adjustment factor is not applicable.

Mean Difference =	-0.0007
Confidence Coefficient =	0.0001

BAF = 1 + (abs. value mean difference/avg. CEMS reading)

Average CEMS Reading =	0.0062
BAF =	**1.000**

Part 75, Appendix A,
3.3.2 Relative Accuracy for NOX-Diluent Continuous Emission Monitoring Systems
(a) The relative accuracy for NOX-diluent continuous emission monitoring systems shall not exceed 10.0 percent.
(b) For affected units where the average of the reference method measurements of NOX emission rate (this means lb/MMBtu) during the relative accuracy test audit is less than or equal to 0.200 lb/mmBtu, the difference between the mean value of the continuous emission monitoring system measurements and the reference method mean value shall not exceed ±0.020 lb/mmBtu, wherever the relative accuracy specification of 10.0 percent is not achieved.

7.6.5 Bias Adjustment
(b) For single-load RATAs of SO2 pollutant concentration monitors, NOX concentration monitoring systems, and NOX-diluent monitoring systems and for the single-load flow RATAs required or allowed under section 6.5.2 of this appendix and sections 2.3.1.3(b) and 2.3.1.3(c) of Appendix B to this part, the appropriate BAF is determined directly from the RATA results at normal load, using Equation A-12. Notwithstanding, when a NOX concentration CEMS or an SO2 CEMS or a NOX-diluent CEMS installed on a low-emitting affected unit (i.e., average SO2 or NOX concentration during the RATA ≦ 250 ppm or average NOX emission rate ≦ 0.200 lb/mmBtu) meets the normal 10.0 percent relative accuracy specification (as calculated using Equation A-10) or the alternate relative accuracy specification in section 3.3 of this appendix for low-emitters, but fails the bias test, the BAF may either be determined using Equation A-12, or a default BAF of 1.111 may be used.

Part 75, Appendix B,
2.3.1.2 Reduced RATA Frequencies. Relative accuracy test audits of primary and redundant backup SO2 pollutant concentration monitors, CO2 pollutant concentration monitors (including O2 monitors used to determine CO2 emissions), CO2 or O2 diluent monitors used to determine heat input, moisture monitoring systems, NOX concentration monitoring systems, flow monitors, NOX-diluent monitoring systems or SO2-diluent monitoring systems may be performed annually (i.e., once every four successive QA operating quarters, rather than once every two successive QA operating quarters) if any of the following conditions are met for the specific monitoring system involved:
(a) The relative accuracy during the audit of an SO2 or CO2 pollutant concentration monitor (including an O2 pollutant monitor used to measure CO2 using the procedures in appendix F to this part), or of a CO2 or O2 diluent monitor used to determine heat input, or of a NOX concentration monitoring system, or of a NOX-diluent monitoring system, or of an SO2-diluent continuous emissions monitoring system is ≤ 7.5 percent;

(f) For units with low NOX emission rates (average NOX emission rate measured by the reference method during the RATA ≤ 0.200 lb/mmBtu), when a NOX-diluent continuous emission monitoring system fails to achieve a relative accuracy ≤ 7.5 percent, but the monitoring system mean value from the RATA, calculated using Equation A-7 in appendix A to this part, is within ± 0.015 lb/mmBtu of the reference method mean value;

Figure 2 to Appendix B of Part 75_Relative Accuracy Test Frequency Incentive System.

RATA	Semiannual(percent)(1)	Annual(1)
SO2 or NOX(3)	7.5% < RA ≤ 10.0% or ± 15.0 ppm(2)	RA ≤ 7.5% or ± 12.0 ppm(2)
SO2-diluent	7.5% < RA ≤ 10.0% or ± 0.030 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.025 lb/mmBtu(2)
NOX-diluent	7.5% < RA ≤ 10.0% or ± 0.020 lb/mmBtu(2)	RA ≤ 7.5% or ± 0.015 lb/mmBtu(2)
Flow	7.5% < RA ≤ 10.0% or ± 2.0 fps(2)	RA ≤ 7.5% or ± 1.5 fps
CO2 or O2	7.5% < RA ≤ 10.0% or ± 1.0% CO2/O2(2)	RA ≤ 7.5% or ± 0.7% CO2/O2(2)
Moisture	7.5% < RA ≤ 10.0% or ± 1.5% H2O(2)	RA ≤ 7.5% or ± 1.0% H2O(2)

(1) The deadline for the next RATA is the end of the second (if semiannual) or fourth (if annual) successive QA operating quarter following the quarter in which the CEMS was last tested. Exclude calendar quarters with fewer than 168 unit operating hours (or, for common stacks and bypass stacks, exclude quarters with fewer than 168 stack operating hours) in determining the RATA deadline. For SO2 monitors, QA operating quarters in which only very low sulfur fuel as defined in § 72.2, is combusted may also be excluded. However, the exclusion of calendar quarters is limited as follows: the deadline for the next RATA shall be no more than 8 calendar quarters after the quarter in which a RATA was last performed.
(2) The difference between monitor and reference method mean values applies to moisture monitors, CO2, and O2 monitors, low emitters, or low flow, only.
(3) A NOX concentration monitoring system used to determine NOX mass emissions under § 75.71.

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO_2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH_3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03
Molecular Weight of CO_2 (lb/lb-mole) =	44.01

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO_2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH_3 =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534
Conversion Constant for CO_2 =	0.0000001142434

NOTE: units are lb/ppm*ft^3

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right)$$

2. Correction to % O_2, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O2)}} \right)$$

3. Correction to % O_2 and ISO Conditions

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_O - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh) [ref. EPA EMC FAQ Method 19]

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O_2 based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$

8. Emission Concentration in g/hp*hr

$$E_{g/hp \cdot hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1341.022} or \frac{E_{lb/hr} \times 453.6}{hp}$$

RATA SHEET CALCULATIONS

d = Reference Method Data - CEMS Data

S_d = Standard Deviation

CC = Confident Coefficient

n = number of runs

$t_{0.025}$ = 2.5 percent confidence coefficient T-values

RA = relative accuracy

ARA = alternative relative accuracy

BAF = Bias adjustment factor

n	t	n	t	n	t
2	12.706	7	2.447	12	2.201
3	4.303	8	2.365	13	2.179
4	3.182	9	2.306	14	2.160
5	2.776	10	2.262	15	2.145
6	2.571	11	2.228	16	2.131

1. Difference

$$d = \sum_{i=1}^{n} d_i$$

2. Standard Deviation

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \left[\frac{\left(\sum_{i=1}^{n} d_i \right)^2}{n} \right]}{n-1}}$$

3. Confident Coefficient

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$

4. Relative Accuracy

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$

5. Alternative Relative Accuracy

$$ARA = \frac{|d_{AVG}| + |CC|}{AS} \times 100$$

5. Bias Adjustment Factor

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}} \right)$$

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NOx measured in the spiked sample.
C_{Spike} = Concentration of NOx in the undiluted spike gas.
C_{Calc} = Calculated concentration of NOx in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO2} = NO_2 to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NOxCorr = The NOx concentration corrected for the converter efficiency.
NOxFinal = The final NOx concentration observed during the converter efficiency test in Section 16.2.2.
NOxPeak = The highest NOx concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H_2O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant
B_{wa} = Moisture fraction of ambient air, percent.
Btu = British thermal unit
$\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
$\%_{CO2d}$,$\%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
E = Pollutant emission rate, ng/J (lb/million Btu).
E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
E_{ao}, E_{ai} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
E_d = Average pollutant rate for each sampling period (e.g.,24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
E_{di} = Average inlet SO_2 rate for each sampling period d, ng/J (lb/million Btu).
E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O_2.
E_{jo},E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
E_h = Hourly average pollutant, ng/J (lb/million Btu).
E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O_2.
EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
ft^3 = cubic feet
G = ideal gas conversion factor
(385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
GCM = gross Btu per SCF (constant, compound based)
GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
$\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
$\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
H_r = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
K = volume of combustion component per pound of component (constant)
K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
K_c = (9.57 scm/kg)/% [(1.53 scf/lb)/%].
K_{cc} = (2.0 scm/kg)/% [(0.321 scf/lb)/%].
K_{hd} = (22.7 scm/kg)/% [(3.64 scf/lb)/%].
K_{hw} = (34.74 scm/kg)/% [(5.57 scf/lb)/%].
K_n = (0.86 scm/kg)/% [(0.14 scf/lb)/%].
K_o = (2.85 scm/kg)/% [(0.46 scf/lb)/%].
K_s = (3.54 scm/kg)/% [(0.57 scf/lb)/%].
K_{sulfur} = $2x10^4$ Btu/wt%-MMBtu
K_w = (1.30 scm/kg)/% [(0.21 scf/lb)/%].
lb = pound
ln = Natural log of indicated value.
L_p,L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
$\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
$M_{\%}$ = mole percent
mol = mole
MW = molecular weight (lb/lb-mol)
MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)[1]
NCM = net Btu per SCF (constant based on compound)
$\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
$\%_{O2d}$, $\%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
P_B = barometric pressure, in Hg
P_s = Potential SO2 emissions, percent.
$\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
$\%_{Sf}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
S(wt%) = weight percent of sulfur, per lab analysis by appropriate ASTM standard
S_i = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
$\%S_p$, $\%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
SCF = standard cubic feet
SH = specific humidity, pounds of water per pound of air
$t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
T_{amb} = ambient temperature, °F
W/D Factor = 1.0236 = conv. at 14.696 psia and
68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
X_{CO2}=CO_2 Correction factor, percent.
X_k = Fraction of total heat input from each type of fuel k.

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RHsp (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp}(lb/lb) = \left[\left(\frac{gr}{lb}\right) \times \frac{lb}{7000\ gr}\right]$$

RH_{sp}= 36.54 gr / lb x 1 lb / 7000 gr = 0.005221 lb H_2O / lb Air

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (02-27-14), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS}\right) \times 100$$ Eq. 7E-1

ACE = (4.56 ppm - 4.55 ppm) / 8.90 ppm x 100 = 0.11 %

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (02-27-14), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS}\right) \times 100$$ Eq. 7E-2

SB = (4.58 ppm - 4.56 ppm) / 8.90 ppm x 100 = 0.22 %

Drift Assessment

RM 7E, (02-27-14), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = \left|SB_{final} - SB_t\right|$$ Eq. 7E-4

D = | 0.00 % - 0.22 % | = 0.22 %

Alternative Drift and Bias

RM 7E, (02-27-14), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs – Cdir| is ≤ 0.5 ppmv or if |Cs – Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB/D_{Alt} = \left|C_S - C_{Dir}\right|$$ Eq. Section 13.2 and 13.3

SB / D_{Alt} = | 4.58 ppm - 4.56 ppm | = 0.02 ppm

Bias Adjusted Average

RM 7E, (02-27-14), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = \left(C_{Avg} - C_O\right) \times \left(\frac{C_{MA}}{C_M - C_O}\right)$$ Eq. 7E-5b

C_{Gas} = (1.96 ppm - -0.09 ppm) (4.55 ppm / 4.57 ppm - -0.09 ppm) = 2.00 ppm

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Stack Exhaust Flow (Q_S) - RM19

$$Q_S = \left(\frac{FFactor \times Q_f \times HHV}{1{,}000{,}000}\right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas\,(O2)}}\right)$$

Note: Equation presented in EPA Emission Measurement Center (EMC), Frequently Asked Questions (FAQ) for Method 19

Q_S = 8,710.00 SCF/MMBtu x 2,322,450.00 SCF/hr x 1,050.00 Btu/SCF x MMBtu/10^6 Btu x (20.90% / (20.9% - 13.1 %)) = 56,738,224.23 SCFH

Moisture Correction

RM 7E, (02-27-14), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_W = C_D \times (1 - B_{WS})$$

$$C_D = \frac{C_W}{1 - B_{WS}}$$ Eq. 7E-10

C_D = 1.84 ppmvw / (1 - 0.08) = 2.00 ppmvd or inversely, C_W = 2.00 ppmvd x (1 - 0.08) = 1.84 ppmvw

Diluent-Corrected Pollutant Concentration, O_2 Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O_2 Concentration. Calculate the O_2 corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable) [now contained in applicable Subpart]

$$C_{adj} = C_{Gas\,(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas\,(O2)}}\right)$$ Eq. 20-4

C_{adj} = 2.00 ppm x (20.9% - 15.00 %) / (20.9% - 13.08 %) = 1.51 ppm@15%O_2

Emissions Rate (lb/hr)

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

$E_{lb/hr}$ = 2.00 ppmvd / 10^6 ppm/part x 56,738,224 DSCFH x 46.01 lb/lb-mol / 385.23 SCF/lb-mol = 13.58 lb/hr

Emissions Rate (lb/MMBtu)

RM 19, (02-27-14), 12.2 Emission Rates of PM, SO_2, and NOx. Select from the following sections the applicable procedure to compute the PM, SO_2, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for NOx gas Run 1, if applicable)

Oxygen Based

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O_2 ($\%O_2d$) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O2)}}$$ Eq. 19-1

$E_{lb/MMBtu}$ = 2.00 ppm x 8,710.00 SCF/MMBtu x 0.0000001194 lb/ppm*ft^3 x 20.9% / (20.9% - 13.08 %) = 0.006 lb/MMBtu

Conversion Constant

Convc for NOx

$$Conv_c(lb/ppm \cdot ft^3) = \frac{\frac{MW}{G}}{10^6}$$

$Conv_c$ = (46.01 lb/lb•mole x lb•mole/385.23 SCF) / 10^6 = 0.0000001194 lb/ppm-ft^3

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RATA RESULTS)

Difference (d)

40 CFR 75, App A, (12-17-09), 7.3.1 Arithmetic Mean. Calculate the arithmetic mean of the differences, d , of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$d = \sum_{i=1}^{n} d_i$$ Eq. A-7

d = 0.005 lb/MMBtu - 0.006 lb/MMBtu = -0.001 lb/MMBtu

Standard Deviation

40 CFR 75, App A, (12-17-09), 7.3.2 Standard Deviation. Calculate the standard deviation, Sd, of a data set as follows:
(calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$S_d = \sqrt{\frac{\sum_{i=1}^{n} d_i^2 - \frac{\left[\left(\sum_{i=1}^{n} d_i\right)^2\right]}{n}}{n-1}}$$ Eq. A-8

$$S_d = \sqrt{\frac{0.000 \text{ lb/MMBtu}^2 - \frac{(-0.007 \text{ lb/MMBtu})^2}{9}}{9 - 1}} = 0.000 \text{ lb/MMBtu}$$

Confidence Coefficient

40 CFR 75, App A, (12-17-09), 7.3.3 Confidence Coefficient. Calculate the confidence coefficient (one-tailed), cc, of a data set as follows. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$ Eq. A-9

CC = 2.306 x $\frac{0.000 \text{ lb/MMBtu}}{\sqrt{9}}$ = 0.000 lb/MMBtu

T-Values	n	2	3	4	5	6	7	8	9
	$t_{0.025}$	12.706	4.303	3.182	2.776	2.571	2.447	2.365	2.306

2.5 percent confidence coefficients

Relative Accuracy

40 CFR 75, App A, (12-17-09), 7.3.4 Relative Accuracy. Calculate the relative accuracy of a data set using the following equation. (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$RA = \frac{|d_{AVG}| + |CC|}{RM_{AVG}} \times 100$$ Eq. A-10

RA = $\frac{|-0.001 \text{ lb/MMBtu}| + |0.000 \text{ lb/MMBtu}|}{0.005 \text{ lb/MMBtu}}$ x 100 = 15.05 %

Bias Adjustment Factor (BAF)

40 CFR 75, App A, (12-17-09), 7.6.5 Bias Adjustment. (a) If the monitor or monitoring system fails to meet the bias test requirement, adjust the value obtained from the monitor using the following equation: (calc for NOx lb/MMBtu data, if applicable. Note: This is an example calculation which may not have any bearing on the actual test requirements.)

$$BAF = 1 + \left(\frac{|d_{AVG}|}{CEM_{AVG}}\right)$$ Eq. A-12

d_{AVG}= -0.001 < |CC| = 0.000 ⇨ BAF = 1 + $\frac{|\quad| \text{ lb/MMBtu}}{\text{lb/MMBtu}}$ = 1.000 lb/MMBtu

Note: BAF only applies if the mean difference (d) is greater than the absolute value of the confidence coefficient.

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX B

CEMS AND REFERENCE METHOD DATA

Cricket Valley Energy Center, LLC

Air Permit Number:	3-1326-00275/00009
Plant Name or Location:	Cricket Valley Energy Center
Date:	April 4, 2020
Project Number:	cis-19-cricketvalley.ny-start#1
Manufacturer & Equipment:	General Electric
Model:	7F.05
Unit Number:	U-00003
Test Load:	Base Load
Tester(s) / Test Unit(s):	MM/215

		RUN									
	UNITS	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**10**
Start Time	hh:mm:ss	17:23:02	17:52:02	18:20:04	18:51:19	19:20:23	19:48:23	20:20:13	20:49:13	21:17:13	21:50:13
End Time	hh:mm:ss	17:43:32	18:12:32	18:40:34	19:11:49	19:40:53	20:08:53	20:40:43	21:09:43	21:37:43	22:10:43
Bar. Pressure	in. Hg	29.47	29.48	29.48	29.49	29.49	29.50	29.51	29.51	29.52	29.52
Amb. Temp.	°F	60	58	58	57	56	56	53	53	52	52
Rel. Humidity	%	47	50	52	54	56	58	64	66	66	67
Spec. Humidity	lb water / lb air	0.005221	0.005168	0.005377	0.005384	0.005385	0.005577	0.005514	0.005688	0.005478	0.005562
Turbine Fuel Flow	SCFH	2,322,450	2,324,900	2,327,760	2,327,760	2,331,020	2,335,100	2,339,180	2,342,860	2,344,080	2,346,940
Total Fuel Flow	SCFH	2,322,450	2,324,900	2,327,760	2,327,760	2,331,020	2,335,100	2,339,180	2,342,860	2,344,080	2,346,940
Power Output	megawatts	349.6	349.8	350.4	350.7	351.5	351.9	352.7	353.0	353.1	351.8
O_2 CEMS Data	%vd	13.08	13.08	13.07	13.06	13.05	13.04	13.03	13.02	13.02	13.02
NOx CEMS Data	ppmvd@15%O_2	1.70	1.70	1.70	1.70	1.70	1.55	1.73	1.60	1.70	1.70
	lb/hr	14.93	14.93	14.89	14.88	14.94	13.61	15.29	14.13	15.07	15.09
	lb/MMBtu	0.0063	0.0063	0.0062	0.0062	0.0063	0.0057	0.0064	0.0059	0.0063	0.0063
CO CEMS Data	ppmvd@15%O_2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	lb/hr	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NH_3 CEMS Data	ppmvd@15%O_2	0.97	0.97	0.99	0.98	0.98	1.18	1.02	1.21	0.99	1.00
	lb/hr	3.09	3.10	3.17	3.16	3.11	3.79	3.32	3.93	3.25	3.28
NH_3 RM Data	ppmvd@15%O_2	1.18	1.25	1.27	1.23	0.94	0.83	0.72	0.94	0.94	1.02
	lb/hr	3.93	4.15	4.23	4.10	3.13	2.77	2.40	3.14	3.16	3.41

Created with Comp&RATA&Eng-AHI v20190529

CEMS AND REFERENCE METHOD DATA

CEMS Data
(provided by Cricket Valley Energy Center LLC)

Relative Accuracy Test Data
CEMS Results (NOx)
General Electric, 7F.05, Unit #U-00003

Parameter:	Oxides of Nitrogen
Date of Test:	April 4, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Chemiluminescence
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1014

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	17:23 - 17:43	349.6		1.70	14.93	0.0063
2	17:52 - 18:12	349.8		1.70	14.93	0.0063
3	18:20 - 18:40	350.4		1.70	14.89	0.0062
4	18:51 - 19:11	350.7		1.70	14.88	0.0062
5	19:20 - 19:40	351.5		1.70	14.94	0.0063
6	19:48 - 20:08	351.9		1.55	13.61	0.0057
7	20:20 - 20:40	352.7		1.73	15.29	0.0064
8	20:49 - 21:09	353.0		1.60	14.13	0.0059
9	21:17 - 21:37	353.1		1.70	15.07	0.0063
10	21:50 - 22:10	351.8		1.70	15.09	0.0063
11						
12						

Relative Accuracy Test Data
CEMS Results (CO)
General Electric, 7F.05, Unit #U-00003

Parameter:	Carbon Monoxide
Date of Test:	April 4, 2020
Reference Method:	EPA Method 10
CEMS Analyzer Type:	Infrared Absorption
Manufacturer:	TAPI
Model #:	T300M
Serial #:	520

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	17:23 - 17:43	349.6		0.00	0.00	
2	17:52 - 18:12	349.8		0.00	0.00	
3	18:20 - 18:40	350.4		0.00	0.00	
4	18:51 - 19:11	350.7		0.00	0.00	
5	19:20 - 19:40	351.5		0.00	0.00	
6	19:48 - 20:08	351.9		0.00	0.00	
7	20:20 - 20:40	352.7		0.00	0.00	
8	20:49 - 21:09	353.0		0.00	0.00	
9	21:17 - 21:37	353.1		0.00	0.00	
10	21:50 - 22:10	351.8		0.00	0.00	
11						
12						

Relative Accuracy Test Data
CEMS Results (NH_3)
General Electric, 7F.05, Unit #U-00003

Parameter:	Ammonia
Date of Test:	April 4, 2020
Reference Method:	EPA Method 7E
CEMS Analyzer Type:	Dual NOx w/ NH3 conversion
Manufacturer:	TAPI
Model #:	T200M
Serial #:	1049

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	17:23 - 17:43	349.6		0.97	3.09	
2	17:52 - 18:12	349.8		0.97	3.10	
3	18:20 - 18:40	350.4		0.99	3.17	
4	18:51 - 19:11	350.7		0.98	3.16	
5	19:20 - 19:40	351.5		0.98	3.11	
6	19:48 - 20:08	351.9		1.18	3.79	
7	20:20 - 20:40	352.7		1.02	3.32	
8	20:49 - 21:09	353.0		1.21	3.93	
9	21:17 - 21:37	353.1		0.99	3.25	
10	21:50 - 22:10	351.8		1.00	3.28	
11						
12						

Relative Accuracy Test Data
CEMS Results (O_2)
General Electric, 7F.05, Unit #U-00003

Parameter:	Oxygen
Date of Test:	April 4, 2020
Reference Method:	EPA Method 3A
CEMS Analyzer Type:	Paramagnetic Cell
Manufacturer:	TAPI
Model #:	T802
Serial #:	151

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	17:23 - 17:43	349.6	13.08
2	17:52 - 18:12	349.8	13.08
3	18:20 - 18:40	350.4	13.07
4	18:51 - 19:11	350.7	13.06
5	19:20 - 19:40	351.5	13.05
6	19:48 - 20:08	351.9	13.04
7	20:20 - 20:40	352.7	13.03
8	20:49 - 21:09	353.0	13.02
9	21:17 - 21:37	353.1	13.02
10	21:50 - 22:10	351.8	13.02
11			
12			

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 5:23 PM thru 4/4/2020 5:43 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 17:23	1.72	0.0063	14.94	0.00	0.00	0.96
4/4 17:24	1.71	0.0063	14.94	0.00	0.00	0.96
4/4 17:25	1.71	0.0063	15.00	0.00	0.00	0.95
4/4 17:26	1.71	0.0063	15.11	0.00	0.00	0.96
4/4 17:27	1.71	0.0063	15.00	0.00	0.00	0.96
4/4 17:28	1.70	0.0063	14.94	0.00	0.00	0.96
4/4 17:29	1.70	0.0063	14.94	0.00	0.00	0.96
4/4 17:30	1.71	0.0063	15.11	0.00	0.00	0.97
4/4 17:31	1.71	0.0063	15.06	0.00	0.00	0.97
4/4 17:32	1.68	0.0062	14.65	0.00	0.00	0.97
4/4 17:33	1.67	0.0062	14.71	0.00	0.00	0.97
4/4 17:34	1.67	0.0062	14.82	0.00	0.00	0.97
4/4 17:35	1.68	0.0062	14.87	0.00	0.00	0.97
4/4 17:36	1.67	0.0062	14.71	0.00	0.00	0.97
4/4 17:37	1.68	0.0062	14.71	0.00	0.00	0.97
4/4 17:38	1.71	0.0063	15.00	0.00	0.00	0.97
4/4 17:39	1.72	0.0063	15.11	0.00	0.00	0.96
4/4 17:40	1.72	0.0063	15.00	0.00	0.00	0.97
4/4 17:41	1.71	0.0063	14.89	0.00	0.00	0.97
4/4 17:42	1.70	0.0063	14.94	0.00	0.00	0.97
4/4 17:43	1.70	0.0063	15.06	0.00	0.00	0.96
Average (all)	1.70	0.0063	14.93	0.00	0.00	0.97
Total (all)	--	--	--	--	--	--
Minimum (all)	1.67	0.0062	14.65	0.00	0.00	0.95
Maximum (all)	1.72	0.0063	15.11	0.00	0.00	0.97
Average (valid values only)	1.70	0.0063	14.93	0.00	0.00	0.97
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 5:23 PM thru 4/4/2020 5:43 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 17:23	3.08	13.08	23142.9	230.2	349.7
4/4 17:24	3.08	13.08	23142.9	229.9	349.3
4/4 17:25	3.10	13.08	23228.6	230.3	349.7
4/4 17:26	3.12	13.08	23400.0	230.2	349.7
4/4 17:27	3.10	13.08	23228.6	230.2	349.6
4/4 17:28	3.08	13.08	23142.9	230.3	349.8
4/4 17:29	3.08	13.08	23142.9	230.2	349.7
4/4 17:30	3.12	13.08	23400.0	230.2	349.7
4/4 17:31	3.11	13.08	23314.3	230.1	349.5
4/4 17:32	3.07	13.08	23057.1	230.2	349.7
4/4 17:33	3.08	13.08	23142.9	230.2	349.7
4/4 17:34	3.11	13.08	23314.3	230.0	349.4
4/4 17:35	3.12	13.08	23400.0	230.1	349.6
4/4 17:36	3.08	13.08	23142.9	230.1	349.5
4/4 17:37	3.08	13.08	23142.9	230.0	349.5
4/4 17:38	3.10	13.08	23228.6	230.4	349.9
4/4 17:39	3.12	13.08	23400.0	230.0	348.9
4/4 17:40	3.10	13.08	23228.6	230.2	349.7
4/4 17:41	3.07	13.08	23057.1	230.1	349.6
4/4 17:42	3.08	13.08	23142.9	230.2	349.7
4/4 17:43	3.11	13.08	23314.3	230.2	349.7
Average (all)	3.09	13.08	23224.5	230.2	349.6
Total (all)	--	--	--	--	--
Minimum (all)	3.07	13.08	23057.1	229.9	348.9
Maximum (all)	3.12	13.08	23400.0	230.4	349.9
Average (valid values only)	3.09	13.08	23224.5	230.2	349.6
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 5:52 PM thru 4/4/2020 6:12 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 17:52	1.71	0.0063	15.11	0.00	0.00	0.96
4/4 17:53	1.71	0.0063	15.06	0.00	0.00	0.97
4/4 17:54	1.69	0.0062	14.71	0.00	0.00	0.97
4/4 17:55	1.67	0.0061	14.47	0.00	0.00	0.97
4/4 17:56	1.66	0.0061	14.58	0.00	0.00	0.97
4/4 17:57	1.67	0.0062	14.87	0.00	0.00	0.97
4/4 17:58	1.69	0.0062	14.71	0.00	0.00	0.97
4/4 17:59	1.71	0.0063	14.94	0.00	0.00	0.96
4/4 18:00	1.73	0.0064	15.29	0.00	0.00	0.96
4/4 18:01	1.74	0.0064	15.41	0.00	0.00	0.95
4/4 18:02	1.74	0.0064	15.18	0.00	0.00	0.96
4/4 18:03	1.72	0.0063	14.94	0.00	0.00	0.96
4/4 18:04	1.71	0.0063	15.00	0.00	0.00	0.95
4/4 18:05	1.71	0.0063	15.11	0.00	0.00	0.96
4/4 18:06	1.69	0.0062	14.82	0.00	0.00	0.97
4/4 18:07	1.69	0.0062	14.65	0.00	0.00	0.97
4/4 18:08	1.70	0.0063	14.94	0.00	0.00	0.97
4/4 18:09	1.71	0.0063	15.06	0.00	0.00	0.97
4/4 18:10	1.72	0.0063	15.11	0.00	0.00	0.97
4/4 18:11	1.71	0.0063	14.94	0.00	0.00	0.98
4/4 18:12	1.69	0.0062	14.71	0.00	0.00	0.97
Average (all)	1.70	0.0063	14.93	0.00	0.00	0.97
Total (all)	--	--	--	--	--	--
Minimum (all)	1.66	0.0061	14.47	0.00	0.00	0.95
Maximum (all)	1.74	0.0064	15.41	0.00	0.00	0.98
Average (valid values only)	1.70	0.0063	14.93	0.00	0.00	0.97
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 5:52 PM thru 4/4/2020 6:12 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 17:52	3.12	13.08	23400.0	230.4	350.0
4/4 17:53	3.11	13.08	23314.3	230.4	349.9
4/4 17:54	3.08	13.08	23142.9	230.2	349.7
4/4 17:55	3.08	13.08	23142.9	230.4	350.0
4/4 17:56	3.11	13.08	23314.3	230.4	350.0
4/4 17:57	3.12	13.08	23400.0	230.5	350.0
4/4 17:58	3.08	13.08	23142.9	230.4	350.0
4/4 17:59	3.08	13.08	23142.9	230.2	349.7
4/4 18:00	3.11	13.08	23314.3	230.4	350.0
4/4 18:01	3.13	13.08	23485.7	230.5	350.1
4/4 18:02	3.08	13.08	23142.9	230.3	349.9
4/4 18:03	3.08	13.08	23142.9	230.5	350.1
4/4 18:04	3.10	13.08	23228.6	230.3	349.9
4/4 18:05	3.12	13.08	23400.0	230.4	350.0
4/4 18:06	3.11	13.08	23314.3	230.2	349.5
4/4 18:07	3.07	13.08	23057.1	230.3	349.1
4/4 18:08	3.08	13.08	23142.9	230.5	349.2
4/4 18:09	3.11	13.08	23314.3	230.2	349.2
4/4 18:10	3.12	13.08	23400.0	230.5	349.0
4/4 18:11	3.08	13.08	23142.9	230.3	349.6
4/4 18:12	3.08	13.08	23142.9	230.4	349.9
Average (all)	3.10	13.08	23249.0	230.4	349.8
Total (all)	--	--	--	--	--
Minimum (all)	3.07	13.08	23057.1	230.2	349.0
Maximum (all)	3.13	13.08	23485.7	230.5	350.1
Average (valid values only)	3.10	13.08	23249.0	230.4	349.8
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 6:20 PM thru 4/4/2020 6:40 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 18:20	1.69	0.0062	14.71	0.00	0.00	0.99
4/4 18:21	1.70	0.0062	14.76	0.00	0.00	0.99
4/4 18:22	1.70	0.0063	15.06	0.00	0.00	0.98
4/4 18:23	1.71	0.0063	15.11	0.00	0.00	0.98
4/4 18:24	1.71	0.0063	14.94	0.00	0.00	0.98
4/4 18:25	1.70	0.0063	14.94	0.00	0.00	0.98
4/4 18:26	1.69	0.0062	14.82	0.00	0.00	0.97
4/4 18:27	1.71	0.0063	15.11	0.00	0.00	0.98
4/4 18:28	1.70	0.0063	15.00	0.00	0.00	0.98
4/4 18:29	1.71	0.0063	15.00	0.00	0.00	0.97
4/4 18:30	1.72	0.0063	15.06	0.00	0.00	0.97
4/4 18:31	1.74	0.0064	15.35	0.00	0.00	0.97
4/4 18:32	1.73	0.0064	15.29	0.00	0.00	0.98
4/4 18:33	1.71	0.0063	14.94	0.00	0.00	0.99
4/4 18:34	1.68	0.0062	14.76	0.00	0.00	0.99
4/4 18:35	1.67	0.0062	14.87	0.00	0.00	0.99
4/4 18:36	1.67	0.0061	14.63	0.00	0.00	1.00
4/4 18:37	1.66	0.0061	14.47	0.00	0.00	1.01
4/4 18:38	1.65	0.0061	14.52	0.00	0.00	1.00
4/4 18:39	1.67	0.0061	14.58	0.00	0.00	1.00
4/4 18:40	1.68	0.0062	14.87	0.00	0.00	0.99
Average (all)	1.70	0.0062	14.89	0.00	0.00	0.99
Total (all)	--	--	--	--	--	--
Minimum (all)	1.65	0.0061	14.47	0.00	0.00	0.97
Maximum (all)	1.74	0.0064	15.35	0.00	0.00	1.01
Average (valid values only)	1.70	0.0062	14.89	0.00	0.00	0.99
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 6:20 PM thru 4/4/2020 6:40 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 18:20	3.08	13.08	23142.9	230.6	350.3
4/4 18:21	3.10	13.07	23228.6	230.6	350.2
4/4 18:22	3.11	13.07	23314.3	230.5	350.1
4/4 18:23	3.12	13.08	23400.0	230.5	350.2
4/4 18:24	3.08	13.08	23142.9	230.6	350.3
4/4 18:25	3.08	13.08	23142.9	230.6	350.3
4/4 18:26	3.11	13.07	23314.3	230.8	350.5
4/4 18:27	3.12	13.08	23400.0	230.7	350.4
4/4 18:28	3.10	13.07	23228.6	230.8	350.4
4/4 18:29	3.10	13.06	23228.6	230.9	350.6
4/4 18:30	3.11	13.06	23314.3	231.0	350.8
4/4 18:31	3.12	13.06	23400.0	230.7	350.4
4/4 18:32	3.11	13.07	23314.3	230.7	350.4
4/4 18:33	3.08	13.07	23142.9	230.8	350.5
4/4 18:34	3.10	13.07	23228.6	230.8	350.5
4/4 18:35	3.36	13.07	23400.0	230.8	350.5
4/4 18:36	3.36	13.07	23400.0	230.8	350.5
4/4 18:37	3.32	13.07	23142.9	230.6	350.3
4/4 18:38	3.33	13.07	23228.6	230.9	350.7
4/4 18:39	3.35	13.07	23314.3	230.8	350.5
4/4 18:40	3.36	13.07	23400.0	230.7	350.2
Average (all)	3.17	13.07	23277.6	230.7	350.4
Total (all)	--	--	--	--	--
Minimum (all)	3.08	13.06	23142.9	230.5	350.1
Maximum (all)	3.36	13.08	23400.0	231.0	350.8
Average (valid values only)	3.17	13.07	23277.6	230.7	350.4
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 6:51 PM thru 4/4/2020 7:11 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 18:51	1.65	0.0061	14.47	0.00	0.00	0.99
4/4 18:52	1.65	0.0061	14.58	0.00	0.00	0.99
4/4 18:53	1.66	0.0061	14.63	0.00	0.00	0.99
4/4 18:54	1.67	0.0062	14.76	0.00	0.00	0.99
4/4 18:55	1.67	0.0062	14.71	0.00	0.00	0.99
4/4 18:56	1.69	0.0062	14.76	0.00	0.00	0.98
4/4 18:57	1.72	0.0063	15.11	0.00	0.00	0.97
4/4 18:58	1.75	0.0064	15.29	0.00	0.00	0.97
4/4 18:59	1.75	0.0064	15.18	0.00	0.00	0.96
4/4 19:00	1.74	0.0064	15.18	0.00	0.00	0.96
4/4 19:01	1.75	0.0064	15.29	0.00	0.00	0.96
4/4 19:02	1.75	0.0064	15.41	0.00	0.00	0.96
4/4 19:03	1.74	0.0064	15.18	0.00	0.00	0.97
4/4 19:04	1.71	0.0063	15.00	0.00	0.00	0.98
4/4 19:05	1.69	0.0062	14.76	0.00	0.00	0.99
4/4 19:06	1.68	0.0062	14.93	0.00	0.00	0.99
4/4 19:07	1.66	0.0061	14.58	0.00	0.00	1.00
4/4 19:08	1.66	0.0061	14.47	0.00	0.00	1.00
4/4 19:09	1.66	0.0061	14.52	0.00	0.00	1.00
4/4 19:10	1.68	0.0062	14.87	0.00	0.00	1.00
4/4 19:11	1.69	0.0062	14.87	0.00	0.00	1.00
Average (all)	1.70	0.0062	14.88	0.00	0.00	0.98
Total (all)	--	--	--	--	--	--
Minimum (all)	1.65	0.0061	14.47	0.00	0.00	0.96
Maximum (all)	1.75	0.0064	15.41	0.00	0.00	1.00
Average (valid values only)	1.70	0.0062	14.88	0.00	0.00	0.98
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 6:51 PM thru 4/4/2020 7:11 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 18:51	3.08	13.06	23142.9	231.1	350.9
4/4 18:52	3.11	13.06	23314.3	230.7	350.4
4/4 18:53	3.12	13.06	23400.0	230.9	350.6
4/4 18:54	3.10	13.07	23228.6	230.7	350.4
4/4 18:55	3.08	13.07	23142.9	230.8	350.5
4/4 18:56	3.10	13.06	23228.6	230.9	350.7
4/4 18:57	3.12	13.06	23400.0	231.0	350.7
4/4 18:58	3.11	13.06	23314.3	231.1	350.8
4/4 18:59	3.08	13.06	23142.9	230.9	350.7
4/4 19:00	3.08	13.06	23142.9	231.1	350.9
4/4 19:01	3.11	13.06	23314.3	231.1	350.9
4/4 19:02	3.13	13.06	23485.7	231.0	350.8
4/4 19:03	3.08	13.06	23142.9	231.0	350.8
4/4 19:04	3.10	13.06	23228.6	231.1	350.9
4/4 19:05	3.10	13.06	23228.6	231.1	350.9
4/4 19:06	3.13	13.06	23485.7	231.1	350.9
4/4 19:07	3.35	13.06	23314.3	231.2	351.0
4/4 19:08	3.32	13.06	23142.9	231.2	351.0
4/4 19:09	3.33	13.06	23228.6	231.2	351.0
4/4 19:10	3.36	13.06	23400.0	231.2	350.4
4/4 19:11	3.36	13.06	23400.0	230.9	350.3
Average (all)	3.16	13.06	23277.6	231.0	350.7
Total (all)	--	--	--	--	--
Minimum (all)	3.08	13.06	23142.9	230.7	350.3
Maximum (all)	3.36	13.07	23485.7	231.2	351.0
Average (valid values only)	3.16	13.06	23277.6	231.0	350.7
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 7:20 PM thru 4/4/2020 7:40 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 19:20	1.69	0.0062	14.82	0.00	0.00	0.98
4/4 19:21	1.69	0.0062	14.71	0.00	0.00	0.98
4/4 19:22	1.70	0.0062	14.76	0.00	0.00	0.98
4/4 19:23	1.71	0.0063	15.11	0.00	0.00	0.98
4/4 19:24	1.71	0.0063	15.11	0.00	0.00	0.98
4/4 19:25	1.71	0.0063	15.00	0.00	0.00	0.98
4/4 19:26	1.72	0.0063	15.00	0.00	0.00	0.97
4/4 19:27	1.72	0.0063	15.06	0.00	0.00	0.97
4/4 19:28	1.73	0.0064	15.41	0.00	0.00	0.97
4/4 19:29	1.72	0.0063	15.00	0.00	0.00	0.98
4/4 19:30	1.70	0.0063	15.00	0.00	0.00	0.98
4/4 19:31	1.67	0.0062	14.82	0.00	0.00	0.98
4/4 19:32	1.68	0.0062	14.93	0.00	0.00	0.98
4/4 19:33	1.69	0.0062	14.87	0.00	0.00	0.98
4/4 19:34	1.69	0.0062	14.76	0.00	0.00	0.98
4/4 19:35	1.70	0.0062	14.76	0.00	0.00	0.98
4/4 19:36	1.70	0.0063	15.11	0.00	0.00	0.98
4/4 19:37	1.70	0.0063	15.17	0.00	0.00	0.98
4/4 19:38	1.70	0.0062	14.76	0.00	0.00	0.99
4/4 19:39	1.68	0.0062	14.76	0.00	0.00	0.98
4/4 19:40	1.69	0.0062	14.82	0.00	0.00	0.98
Average (all)	1.70	0.0063	14.94	0.00	0.00	0.98
Total (all)	--	--	--	--	--	--
Minimum (all)	1.67	0.0062	14.71	0.00	0.00	0.97
Maximum (all)	1.73	0.0064	15.41	0.00	0.00	0.99
Average (valid values only)	1.70	0.0063	14.94	0.00	0.00	0.98
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 7:20 PM thru 4/4/2020 7:40 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 19:20	3.11	13.05	23314.3	231.5	351.2
4/4 19:21	3.08	13.05	23142.9	231.6	351.4
4/4 19:22	3.10	13.04	23228.6	231.5	351.3
4/4 19:23	3.12	13.05	23400.0	231.6	351.5
4/4 19:24	3.12	13.05	23400.0	231.3	351.1
4/4 19:25	3.10	13.05	23228.6	231.6	351.4
4/4 19:26	3.10	13.05	23228.6	231.5	351.4
4/4 19:27	3.11	13.05	23314.3	231.3	351.1
4/4 19:28	3.13	13.05	23485.7	231.5	351.4
4/4 19:29	3.10	13.05	23228.6	231.5	351.5
4/4 19:30	3.10	13.05	23228.6	231.7	351.6
4/4 19:31	3.11	13.04	23314.3	231.7	351.6
4/4 19:32	3.13	13.05	23485.7	231.7	351.7
4/4 19:33	3.12	13.05	23400.0	231.7	351.6
4/4 19:34	3.10	13.04	23228.6	231.6	351.5
4/4 19:35	3.10	13.04	23228.6	231.6	351.6
4/4 19:36	3.12	13.04	23400.0	231.7	351.6
4/4 19:37	3.13	13.04	23485.7	231.8	351.7
4/4 19:38	3.10	13.04	23228.6	231.8	351.8
4/4 19:39	3.10	13.04	23228.6	231.8	351.5
4/4 19:40	3.11	13.04	23314.3	231.9	351.4
Average (all)	3.11	13.05	23310.2	231.6	351.5
Total (all)	--	--	--	--	--
Minimum (all)	3.08	13.04	23142.9	231.3	351.1
Maximum (all)	3.13	13.05	23485.7	231.9	351.8
Average (valid values only)	3.11	13.05	23310.2	231.6	351.5
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 7:48 PM thru 4/4/2020 8:08 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 19:48	1.67	0.0061	14.52	0.00	0.00	0.99
4/4 19:49	1.68	0.0062	14.87	0.00	0.00	0.99
4/4 19:50	1.69	0.0062	14.93	0.00	0.00	0.98
4/4 19:51	1.69	0.0062	14.76	0.00	0.00	0.98
4/4 19:52	1.71	0.0063	15.00	0.00	0.00	0.98
4/4 19:53	1.72	0.0063	15.06	0.00	0.00	0.98
4/4 19:54	1.74	0.0064	15.41	0.00	0.00	0.98
4/4 19:55	1.74	0.0064	15.29	0.00	0.00	0.98
4/4 19:56	1.73	0.0064	15.24	0.00	0.00	0.98
4/4 19:57	1.72	0.0063	15.06	0.00	0.00	0.98
4/4 19:58	1.70	0.0063	15.17	0.00	0.00	0.99
4/4 19:59	1.62	0.0060	14.44	0.00	0.00	1.03
4/4 20:00	1.47	0.0054	12.86	0.00	0.00	1.10
4/4 20:01	1.31	0.0048	11.47	0.00	0.00	1.24
4/4 20:02	1.25	0.0046	11.03	0.00	0.00	1.37
4/4 20:03	1.24	0.0046	11.07	0.00	0.00	1.51
4/4 20:04	1.25	0.0046	10.95	0.00	0.00	1.59
4/4 20:05	1.28	0.0047	11.19	0.00	0.00	1.61
4/4 20:06	1.34	0.0049	11.75	0.00	0.00	1.58
4/4 20:07	1.42	0.0052	12.56	0.00	0.00	1.51
4/4 20:08	1.49	0.0055	13.14	0.00	0.00	1.43
Average (all)	1.55	0.0057	13.61	0.00	0.00	1.18
Total (all)	--	--	--	--	--	--
Minimum (all)	1.24	0.0046	10.95	0.00	0.00	0.98
Maximum (all)	1.74	0.0064	15.41	0.00	0.00	1.61
Average (valid values only)	1.55	0.0057	13.61	0.00	0.00	1.18
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 7:48 PM thru 4/4/2020 8:08 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 19:48	3.10	13.04	23228.6	231.8	351.7
4/4 19:49	3.12	13.05	23400.0	231.8	351.6
4/4 19:50	3.13	13.04	23485.7	231.9	351.8
4/4 19:51	3.10	13.05	23228.6	231.8	351.7
4/4 19:52	3.10	13.05	23228.6	232.0	351.9
4/4 19:53	3.11	13.05	23314.3	231.9	351.8
4/4 19:54	3.13	13.05	23485.7	231.8	351.7
4/4 19:55	3.11	13.05	23314.3	232.0	351.9
4/4 19:56	3.10	13.05	23228.6	231.9	351.8
4/4 19:57	3.11	13.04	23314.3	231.9	351.8
4/4 19:58	3.13	13.04	23485.7	232.0	351.9
4/4 19:59	3.37	13.04	23485.7	232.2	352.0
4/4 20:00	3.57	13.05	23228.6	232.0	352.0
4/4 20:01	4.06	13.04	23314.3	232.0	352.0
4/4 20:02	4.56	13.04	23400.0	232.0	352.0
4/4 20:03	4.81	13.04	23485.7	232.1	352.1
4/4 20:04	5.24	13.04	23228.6	232.2	352.2
4/4 20:05	5.24	13.04	23228.6	232.3	352.3
4/4 20:06	5.04	13.04	23400.0	232.1	352.0
4/4 20:07	4.83	13.04	23571.4	232.2	352.0
4/4 20:08	4.54	13.04	23314.3	232.2	351.9
Average (all)	3.79	13.04	23351.0	232.0	351.9
Total (all)	--	--	--	--	--
Minimum (all)	3.10	13.04	23228.6	231.8	351.6
Maximum (all)	5.24	13.05	23571.4	232.3	352.3
Average (valid values only)	3.79	13.04	23351.0	232.0	351.9
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 8:20 PM thru 4/4/2020 8:40 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 20:20	1.67	0.0061	14.74	0.00	0.00	1.28
4/4 20:21	1.73	0.0064	15.29	0.00	0.00	1.19
4/4 20:22	1.79	0.0066	15.77	0.00	0.00	1.11
4/4 20:23	1.82	0.0067	16.01	0.00	0.00	1.05
4/4 20:24	1.84	0.0068	16.37	0.00	0.00	1.01
4/4 20:25	1.84	0.0068	16.31	0.00	0.00	0.99
4/4 20:26	1.82	0.0067	16.01	0.00	0.00	0.97
4/4 20:27	1.79	0.0066	15.77	0.00	0.00	0.96
4/4 20:28	1.76	0.0065	15.59	0.00	0.00	0.97
4/4 20:29	1.72	0.0064	15.46	0.00	0.00	0.97
4/4 20:30	1.69	0.0062	14.82	0.00	0.00	0.98
4/4 20:31	1.67	0.0062	14.82	0.00	0.00	0.99
4/4 20:32	1.66	0.0061	14.58	0.00	0.00	0.99
4/4 20:33	1.67	0.0062	14.93	0.00	0.00	1.00
4/4 20:34	1.67	0.0062	14.87	0.00	0.00	1.00
4/4 20:35	1.67	0.0062	14.82	0.00	0.00	1.00
4/4 20:36	1.69	0.0062	14.87	0.00	0.00	1.00
4/4 20:37	1.70	0.0063	15.17	0.00	0.00	1.00
4/4 20:38	1.70	0.0063	15.17	0.00	0.00	1.00
4/4 20:39	1.69	0.0062	14.82	0.00	0.00	1.00
4/4 20:40	1.69	0.0062	14.87	0.00	0.00	0.99
Average (all)	1.73	0.0064	15.29	0.00	0.00	1.02
Total (all)	--	--	--	--	--	--
Minimum (all)	1.66	0.0061	14.58	0.00	0.00	0.96
Maximum (all)	1.84	0.0068	16.37	0.00	0.00	1.28
Average (valid values only)	1.73	0.0064	15.29	0.00	0.00	1.02
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 8:20 PM thru 4/4/2020 8:40 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 20:20	4.11	13.04	23571.4	232.6	352.5
4/4 20:21	3.82	13.04	23314.3	232.6	352.4
4/4 20:22	3.58	13.04	23314.3	232.4	352.2
4/4 20:23	3.35	13.04	23314.3	232.5	352.5
4/4 20:24	3.37	13.04	23485.7	232.6	352.5
4/4 20:25	3.12	13.04	23400.0	232.7	352.6
4/4 20:26	3.11	13.04	23314.3	232.6	352.6
4/4 20:27	3.11	13.04	23314.3	232.8	352.9
4/4 20:28	3.12	13.04	23400.0	232.6	352.5
4/4 20:29	3.14	13.03	23571.4	232.8	352.8
4/4 20:30	3.11	13.03	23314.3	232.7	352.7
4/4 20:31	3.11	13.03	23314.3	232.7	352.7
4/4 20:32	3.11	13.03	23314.3	232.8	353.0
4/4 20:33	3.37	13.03	23485.7	232.7	352.7
4/4 20:34	3.36	13.03	23400.0	232.8	352.8
4/4 20:35	3.35	13.03	23314.3	232.9	352.9
4/4 20:36	3.36	13.03	23400.0	232.9	352.9
4/4 20:37	3.37	13.03	23485.7	232.7	352.8
4/4 20:38	3.37	13.03	23485.7	232.9	352.9
4/4 20:39	3.35	13.03	23314.3	233.0	352.3
4/4 20:40	3.12	13.03	23400.0	232.6	352.5
Average (all)	3.32	13.03	23391.8	232.7	352.7
Total (all)	--	--	--	--	--
Minimum (all)	3.11	13.03	23314.3	232.4	352.2
Maximum (all)	4.11	13.04	23571.4	233.0	353.0
Average (valid values only)	3.32	13.03	23391.8	232.7	352.7
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 8:49 PM thru 4/4/2020 9:09 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 20:49	1.29	0.0048	11.51	0.00	0.00	1.30
4/4 20:50	1.26	0.0046	11.11	0.00	0.00	1.45
4/4 20:51	1.26	0.0046	11.07	0.00	0.00	1.56
4/4 20:52	1.27	0.0047	11.23	0.00	0.00	1.61
4/4 20:53	1.31	0.0048	11.47	0.00	0.00	1.60
4/4 20:54	1.37	0.0050	12.04	0.00	0.00	1.56
4/4 20:55	1.44	0.0053	12.81	0.00	0.00	1.48
4/4 20:56	1.51	0.0056	13.38	0.00	0.00	1.39
4/4 20:57	1.59	0.0059	14.10	0.00	0.00	1.30
4/4 20:58	1.68	0.0062	14.87	0.00	0.00	1.20
4/4 20:59	1.77	0.0065	15.70	0.00	0.00	1.13
4/4 21:00	1.82	0.0067	16.07	0.00	0.00	1.06
4/4 21:01	1.83	0.0068	16.25	0.00	0.00	1.02
4/4 21:02	1.83	0.0068	16.31	0.00	0.00	0.98
4/4 21:03	1.83	0.0067	16.19	0.00	0.00	0.97
4/4 21:04	1.80	0.0066	15.89	0.00	0.00	0.95
4/4 21:05	1.78	0.0066	15.77	0.00	0.00	0.95
4/4 21:06	1.75	0.0065	15.59	0.00	0.00	0.95
4/4 21:07	1.73	0.0064	15.41	0.00	0.00	0.97
4/4 21:08	1.71	0.0063	15.22	0.00	0.00	0.97
4/4 21:09	1.68	0.0062	14.82	0.00	0.00	0.99
Average (all)	1.60	0.0059	14.13	0.00	0.00	1.21
Total (all)	--	--	--	--	--	--
Minimum (all)	1.26	0.0046	11.07	0.00	0.00	0.95
Maximum (all)	1.83	0.0068	16.31	0.00	0.00	1.61
Average (valid values only)	1.60	0.0059	14.13	0.00	0.00	1.21
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 8:49 PM thru 4/4/2020 9:09 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 20:49	4.32	13.03	23400.0	233.0	353.0
4/4 20:50	4.83	13.03	23571.4	232.8	352.8
4/4 20:51	5.06	13.03	23485.7	233.1	353.1
4/4 20:52	5.26	13.03	23314.3	232.9	352.9
4/4 20:53	5.26	13.02	23314.3	232.8	352.9
4/4 20:54	5.06	13.02	23485.7	232.9	353.0
4/4 20:55	4.83	13.02	23571.4	233.0	353.1
4/4 20:56	4.54	13.03	23314.3	233.1	353.2
4/4 20:57	4.30	13.02	23314.3	233.0	353.1
4/4 20:58	3.84	13.02	23400.0	233.0	353.1
4/4 20:59	3.62	13.03	23571.4	233.0	353.1
4/4 21:00	3.36	13.03	23400.0	233.0	353.1
4/4 21:01	3.35	13.02	23314.3	233.1	353.2
4/4 21:02	3.12	13.02	23400.0	233.1	353.2
4/4 21:03	3.14	13.02	23571.4	233.0	353.1
4/4 21:04	3.13	13.02	23485.7	232.8	352.9
4/4 21:05	3.11	13.02	23314.3	232.9	353.0
4/4 21:06	3.12	13.03	23400.0	233.2	353.3
4/4 21:07	3.13	13.02	23485.7	233.1	353.3
4/4 21:08	3.14	13.03	23571.4	232.9	352.6
4/4 21:09	3.11	13.03	23314.3	233.1	352.8
Average (all)	3.93	13.02	23428.6	233.0	353.0
Total (all)	--	--	--	--	--
Minimum (all)	3.11	13.02	23314.3	232.8	352.6
Maximum (all)	5.26	13.03	23571.4	233.2	353.3
Average (valid values only)	3.93	13.02	23428.6	233.0	353.0
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 9:17 PM thru 4/4/2020 9:37 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 21:17	1.71	0.0063	15.22	0.00	0.00	1.00
4/4 21:18	1.71	0.0063	15.06	0.00	0.00	1.00
4/4 21:19	1.71	0.0063	15.11	0.00	0.00	0.99
4/4 21:20	1.70	0.0063	15.17	0.00	0.00	1.00
4/4 21:21	1.69	0.0062	14.98	0.00	0.00	1.00
4/4 21:22	1.68	0.0062	14.82	0.00	0.00	1.00
4/4 21:23	1.67	0.0062	14.82	0.00	0.00	1.00
4/4 21:24	1.69	0.0062	14.87	0.00	0.00	0.99
4/4 21:25	1.71	0.0063	15.22	0.00	0.00	0.99
4/4 21:26	1.73	0.0064	15.35	0.00	0.00	0.98
4/4 21:27	1.73	0.0064	15.29	0.00	0.00	0.98
4/4 21:28	1.72	0.0063	15.11	0.00	0.00	0.98
4/4 21:29	1.72	0.0063	15.22	0.00	0.00	0.98
4/4 21:30	1.71	0.0063	15.22	0.00	0.00	0.98
4/4 21:31	1.70	0.0063	15.06	0.00	0.00	0.99
4/4 21:32	1.68	0.0062	14.87	0.00	0.00	1.00
4/4 21:33	1.68	0.0062	14.93	0.00	0.00	1.00
4/4 21:34	1.68	0.0062	14.98	0.00	0.00	1.00
4/4 21:35	1.68	0.0062	14.87	0.00	0.00	1.00
4/4 21:36	1.70	0.0063	15.11	0.00	0.00	1.00
4/4 21:37	1.71	0.0063	15.17	0.00	0.00	0.99
Average (all)	1.70	0.0063	15.07	0.00	0.00	0.99
Total (all)	--	--	--	--	--	--
Minimum (all)	1.67	0.0062	14.82	0.00	0.00	0.98
Maximum (all)	1.73	0.0064	15.35	0.00	0.00	1.00
Average (valid values only)	1.70	0.0063	15.07	0.00	0.00	0.99
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 9:17 PM thru 4/4/2020 9:37 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 21:17	3.38	13.02	23571.4	233.4	353.5
4/4 21:18	3.35	13.02	23314.3	233.5	353.6
4/4 21:19	3.12	13.02	23400.0	233.4	353.6
4/4 21:20	3.37	13.02	23485.7	233.4	353.6
4/4 21:21	3.38	13.02	23571.4	233.3	353.6
4/4 21:22	3.35	13.02	23314.3	233.2	353.4
4/4 21:23	3.35	13.02	23314.3	233.1	353.2
4/4 21:24	3.12	13.02	23400.0	233.5	353.7
4/4 21:25	3.14	13.02	23571.4	233.1	353.2
4/4 21:26	3.12	13.02	23400.0	233.3	353.4
4/4 21:27	3.11	13.02	23314.3	233.3	353.3
4/4 21:28	3.12	13.02	23400.0	233.3	353.3
4/4 21:29	3.14	13.02	23571.4	233.2	353.2
4/4 21:30	3.14	13.02	23571.4	233.1	353.1
4/4 21:31	3.11	13.02	23314.3	233.4	353.4
4/4 21:32	3.36	13.02	23400.0	233.5	353.4
4/4 21:33	3.37	13.02	23485.7	233.3	352.1
4/4 21:34	3.38	13.02	23571.4	233.3	352.0
4/4 21:35	3.36	13.02	23400.0	233.4	352.2
4/4 21:36	3.36	13.02	23400.0	233.3	352.1
4/4 21:37	3.13	13.02	23485.7	233.4	352.3
Average (all)	3.25	13.02	23440.8	233.3	353.1
Total (all)	--	--	--	--	--
Minimum (all)	3.11	13.02	23314.3	233.1	352.0
Maximum (all)	3.38	13.02	23571.4	233.5	353.7
Average (valid values only)	3.25	13.02	23440.8	233.3	353.1
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 9:50 PM thru 4/4/2020 10:10 PM

Timestamp	(Turbine 3) NOx ppm @15% O2 1-Min	(Turbine 3) 75-NOx lb/mmBtu 1-Min	(Turbine 3) NOx lb/hr 1-Min	(Turbine 3) CO ppm @15% O2 1-Min	(Turbine 3) CO lb/hr 1-Min	(Turbine 3) NH3 Slip ppm @15% O2 1-Min
4/4 21:50	1.72	0.0063	15.17	0.00	0.00	0.98
4/4 21:51	1.71	0.0063	15.28	0.00	0.00	0.99
4/4 21:52	1.70	0.0063	15.17	0.00	0.00	0.99
4/4 21:53	1.68	0.0062	14.87	0.00	0.00	1.00
4/4 21:54	1.68	0.0062	14.87	0.00	0.00	1.00
4/4 21:55	1.68	0.0062	14.98	0.00	0.00	1.00
4/4 21:56	1.69	0.0062	14.98	0.00	0.00	1.00
4/4 21:57	1.68	0.0062	14.82	0.00	0.00	1.01
4/4 21:58	1.68	0.0062	14.87	0.00	0.00	1.00
4/4 21:59	1.69	0.0062	14.93	0.00	0.00	1.00
4/4 22:00	1.71	0.0063	15.22	0.00	0.00	1.00
4/4 22:01	1.71	0.0063	15.11	0.00	0.00	1.00
4/4 22:02	1.70	0.0063	15.06	0.00	0.00	1.00
4/4 22:03	1.70	0.0063	15.11	0.00	0.00	0.99
4/4 22:04	1.70	0.0063	15.22	0.00	0.00	1.00
4/4 22:05	1.70	0.0063	15.17	0.00	0.00	1.00
4/4 22:06	1.71	0.0063	15.11	0.00	0.00	0.99
4/4 22:07	1.71	0.0063	15.11	0.00	0.00	0.98
4/4 22:08	1.73	0.0064	15.46	0.00	0.00	0.98
4/4 22:09	1.72	0.0063	15.22	0.00	0.00	0.99
4/4 22:10	1.70	0.0063	15.11	0.00	0.00	1.00
Average (all)	1.70	0.0063	15.09	0.00	0.00	1.00
Total (all)	--	--	--	--	--	--
Minimum (all)	1.68	0.0062	14.82	0.00	0.00	0.98
Maximum (all)	1.73	0.0064	15.46	0.00	0.00	1.01
Average (valid values only)	1.70	0.0063	15.09	0.00	0.00	1.00
Total (valid values only)	--	--	--	--	--	--
Count (valid values only)	21	21	21	21	21	21

CeDAR 1-Minute Data

Cricket Valley Energy Center

Data for 4/4/2020 9:50 PM thru 4/4/2020 10:10 PM

Timestamp	(Turbine 3) NH3 Slip lb/hr 1-Min	(Turbine 3) 60-O2 % 1-Min	(Turbine 3) Total Gas Flow hscf/hr 1-Min	(Turbine 3) GT Megawatts 1-Min	(Turbine 3) Total Megawatts 1-Min
4/4 21:50	3.13	13.02	23485.7	233.5	351.8
4/4 21:51	3.15	13.02	23657.1	233.5	351.8
4/4 21:52	3.13	13.02	23485.7	233.5	351.8
4/4 21:53	3.36	13.02	23400.0	233.5	351.8
4/4 21:54	3.36	13.02	23400.0	233.3	351.6
4/4 21:55	3.38	13.02	23571.4	233.5	351.8
4/4 21:56	3.38	13.02	23571.4	233.3	351.6
4/4 21:57	3.35	13.02	23314.3	233.6	351.9
4/4 21:58	3.36	13.02	23400.0	233.6	351.9
4/4 21:59	3.37	13.02	23485.7	233.5	351.8
4/4 22:00	3.38	13.02	23571.4	233.4	351.7
4/4 22:01	3.36	13.02	23400.0	233.5	351.7
4/4 22:02	3.35	13.02	23314.3	233.5	351.8
4/4 22:03	3.12	13.02	23400.0	233.7	351.9
4/4 22:04	3.38	13.02	23571.4	233.7	351.9
4/4 22:05	3.37	13.02	23485.7	233.6	351.8
4/4 22:06	3.12	13.02	23400.0	233.7	351.9
4/4 22:07	3.12	13.02	23400.0	233.6	351.7
4/4 22:08	3.14	13.02	23571.4	233.7	351.8
4/4 22:09	3.14	13.02	23571.4	233.5	351.7
4/4 22:10	3.36	13.02	23400.0	233.6	351.7
Average (all)	3.28	13.02	23469.4	233.5	351.8
Total (all)	--	--	--	--	--
Minimum (all)	3.12	13.02	23314.3	233.3	351.6
Maximum (all)	3.38	13.02	23657.1	233.7	351.9
Average (valid values only)	3.28	13.02	23469.4	233.5	351.8
Total (valid values only)	--	--	--	--	--
Count (valid values only)	21	21	21	21	21

CEMS AND REFERENCE METHOD DATA

Reference Method Data

Relative Accuracy Test Data
Reference Method Results (NOx)
General Electric, 7F.05, Unit #U-00003

Parameter:	Oxides of Nitrogen
Date of Test:	April 4, 2020
Reference Method:	EPA Method 7E
RM Analyzer Type:	Chemiluminescence
Manufacturer:	
Model #:	THERMO 42 series
Serial #:	INST-NX-0049

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	17:23 - 17:43	349.6		1.51	13.58	0.0056
2	17:52 - 18:12	349.8		1.53	13.76	0.0056
3	18:20 - 18:40	350.4		1.52	13.68	0.0056
4	18:51 - 19:11	350.7		1.53	13.77	0.0056
5	19:20 - 19:40	351.5		1.51	13.59	0.0056
6	19:48 - 20:08	351.9		1.34	12.14	0.0050
7	20:20 - 20:40	352.7		1.50	13.61	0.0055
8	20:49 - 21:09	353.0		1.40	12.67	0.0051
9	21:17 - 21:37	353.1		1.48	13.38	0.0054
10	21:50 - 22:10	351.8		1.47	13.34	0.0054
11						
12						

Relative Accuracy Test Data
Reference Method Results (CO)
General Electric, 7F.05, Unit #U-00003

Parameter:	Carbon Monoxide
Date of Test:	April 4, 2020
Reference Method:	EPA Method 10
RM Analyzer Type:	Infrared Absorption
Manufacturer:	
Model #:	THERMO 48 series
Serial #:	INST-CO-0030

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	17:23 - 17:43	349.6		0.00	0.02	
2	17:52 - 18:12	349.8		0.10	0.55	
3	18:20 - 18:40	350.4		0.13	0.70	
4	18:51 - 19:11	350.7		0.17	0.93	
5	19:20 - 19:40	351.5		0.10	0.54	
6	19:48 - 20:08	351.9		0.20	1.09	
7	20:20 - 20:40	352.7		0.15	0.83	
8	20:49 - 21:09	353.0		0.15	0.84	
9	21:17 - 21:37	353.1		0.15	0.82	
10	21:50 - 22:10	351.8		0.15	0.81	
11						
12						

Relative Accuracy Test Data
Reference Method Results (NH_3)
General Electric, 7F.05, Unit #U-00003

Parameter:	Ammonia
Date of Test:	April 4, 2020
Reference Method:	EPA Method 027
RM Analyzer Type:	Fourier Transform infared
Manufacturer:	MKS
Model #:	2030
Serial #:	INST-IR-0004

RUN #	RUN TIME	UNIT LOAD	CONCENTRATIONS		RATES	
		(MW)	(ppmvd)	(ppmvd@15%O_2)	(lb/hr)	(lb/MMBtu)
1	17:23 - 17:43	349.6		1.18	3.93	
2	17:52 - 18:12	349.8		1.25	4.15	
3	18:20 - 18:40	350.4		1.27	4.23	
4	18:51 - 19:11	350.7		1.23	4.10	
5	19:20 - 19:40	351.5		0.94	3.13	
6	19:48 - 20:08	351.9		0.83	2.77	
7	20:20 - 20:40	352.7		0.72	2.40	
8	20:49 - 21:09	353.0		0.94	3.14	
9	21:17 - 21:37	353.1		0.94	3.16	
10	21:50 - 22:10	351.8		1.02	3.41	
11						
12						

Relative Accuracy Test Data
Reference Method Results (O_2)
General Electric, 7F.05, Unit #U-00003

Parameter:	Oxygen
Date of Test:	April 4, 2020
Reference Method:	EPA Method 3A
RM Analyzer Type:	Paramagnetic Cell
Manufacturer: Model #:	SERVOMEX 1440
Serial #:	INST-O2-0033

RUN #	RUN TIME	UNIT LOAD (MW)	CONC. (%vd)
1	17:23 - 17:43	349.6	13.08
2	17:52 - 18:12	349.8	13.04
3	18:20 - 18:40	350.4	13.07
4	18:51 - 19:11	350.7	13.05
5	19:20 - 19:40	351.5	13.08
6	19:48 - 20:08	351.9	13.05
7	20:20 - 20:40	352.7	13.02
8	20:49 - 21:09	353.0	13.01
9	21:17 - 21:37	353.1	13.01
10	21:50 - 22:10	351.8	13.02
11			
12			

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,322,450	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,322,450	SCFH

Weather Data

Barometric Pressure	29.47	in. Hg
Relative Humidity	47	%
Ambient Temperature	60	°F
Specific Humidity	0.005221	lb H_2O / lb air

Unit Data

Unit Load	349.6	megawatts
Stack Exhaust Flow (M19)	56,738,224	SCFH

Base Load Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 17:23:02	9120	13.05	1.99	-0.45	2.02	7.97
04/04/20 17:23:32	9150	13.06	1.99	-0.45	1.89	8.01
04/04/20 17:24:02	9180	13.06	1.97	-0.45	1.79	8.05
04/04/20 17:24:32	9210	13.05	1.97	-0.45	1.70	8.08
04/04/20 17:25:02	9240	13.05	1.98	-0.45	1.65	8.12
04/04/20 17:25:32	9270	13.05	1.98	-0.45	1.58	8.16
04/04/20 17:26:02	9300	13.05	1.98	-0.45	1.56	8.19
04/04/20 17:26:32	9330	13.05	1.98	-0.45	1.56	8.20
04/04/20 17:27:02	9360	13.05	1.96	-0.45	1.53	8.22
04/04/20 17:27:32	9390	13.05	1.95	-0.45	1.50	8.22
04/04/20 17:28:02	9420	13.05	1.94	-0.45	1.49	8.25
04/04/20 17:28:32	9450	13.06	1.95	-0.46	1.46	8.29
04/04/20 17:29:02	9480	13.05	1.97	-0.46	1.45	8.29
04/04/20 17:29:32	9510	13.05	1.97	-0.44	1.44	8.27
04/04/20 17:30:02	9540	13.05	1.97	-0.45	1.41	8.21
04/04/20 17:30:32	9570	13.05	1.96	-0.45	1.38	8.21
04/04/20 17:31:02	9600	13.05	1.96	-0.45	1.34	8.19
04/04/20 17:31:32	9630	13.05	1.95	-0.45	1.34	8.20
04/04/20 17:32:02	9660	13.05	1.94	-0.45	1.33	8.18
04/04/20 17:32:32	9690	13.05	1.92	-0.45	1.33	8.16
04/04/20 17:33:02	9720	13.05	1.93	-0.45	1.31	8.15
04/04/20 17:33:32	9750	13.04	1.93	-0.46	1.35	8.17
04/04/20 17:34:02	9780	13.05	1.94	-0.46	1.33	8.18
04/04/20 17:34:32	9810	13.05	1.96	-0.44	1.32	8.17
04/04/20 17:35:02	9840	13.05	1.96	-0.43	1.34	8.18
04/04/20 17:35:32	9870	13.05	1.94	-0.45	1.33	8.19
04/04/20 17:36:02	9900	13.05	1.93	-0.44	1.31	8.19
04/04/20 17:36:32	9930	13.05	1.93	-0.43	1.33	8.21
04/04/20 17:37:02	9960	13.05	1.97	-0.44	1.33	8.21
04/04/20 17:37:32	9990	13.05	1.97	-0.43	1.32	8.22
04/04/20 17:38:02	10020	13.05	1.99	-0.43	1.34	8.23
04/04/20 17:38:32	10050	13.05	1.98	-0.47	1.35	8.23
04/04/20 17:39:02	10080	13.05	2.01	-0.43	1.34	8.25
04/04/20 17:39:32	10110	13.05	2.01	-0.44	1.36	8.26
04/04/20 17:40:02	10140	13.05	2.00	-0.43	1.35	8.26
04/04/20 17:40:32	10170	13.05	1.99	-0.42	1.36	8.27
04/04/20 17:41:02	10200	13.05	1.95	-0.44	1.37	8.29
04/04/20 17:41:32	10230	13.05	1.95	-0.41	1.37	8.29
04/04/20 17:42:02	10260	13.05	1.95	-0.45	1.39	8.31
04/04/20 17:42:32	10290	13.05	1.98	-0.44	1.38	8.31
04/04/20 17:43:02	10320	13.04	1.98	-0.44	1.38	8.31
04/04/20 17:43:32	10350	13.05	1.97	-0.44	1.37	8.32
RAW AVERAGE		**13.05**	**1.96**	**-0.44**	**1.44**	**8.21**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.03	-0.07	-0.45	
	Final Zero	-0.01	-0.11	-0.45	
	Avg. Zero	-0.02	-0.09	-0.45	
	Initial UpScale	11.93	4.58	5.26	
	Final UpScale	11.98	4.56	5.47	
	Avg. UpScale	11.96	4.57	5.37	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.08	2.00	0.00	1.57
Concentration (ppm@ 15%O_2)	N/A	1.51	0.00	1.18
Emission Rate (lb/hr)	N/A	13.58	0.02	3.93
Emission Rate (lb/MMBtu)	N/A	0.0056	0.000	0.002

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,324,900	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,324,900	SCFH

Weather Data

Barometric Pressure	29.48	in. Hg
Relative Humidity	50	%
Ambient Temperature	58	°F
Specific Humidity	0.005168	lb H_2O / lb air

Unit Data

Unit Load	349.8	megawatts
Stack Exhaust Flow (M19)	56,561,737	SCFH

Base Load Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 17:52:02	10860	12.95	2.08	-0.34	1.28	7.84
04/04/20 17:52:32	10890	12.97	2.04	-0.35	1.33	7.91
04/04/20 17:53:02	10920	12.99	2.01	-0.37	1.39	7.97
04/04/20 17:53:32	10950	13.00	2.00	-0.38	1.44	8.01
04/04/20 17:54:02	10980	13.00	1.97	-0.35	1.44	7.96
04/04/20 17:54:32	11010	13.01	1.95	-0.38	1.50	8.00
04/04/20 17:55:02	11040	13.01	1.94	-0.38	1.56	8.01
04/04/20 17:55:32	11070	13.01	1.95	-0.35	1.57	8.04
04/04/20 17:56:02	11100	13.01	1.95	-0.34	1.61	8.07
04/04/20 17:56:32	11130	13.01	1.95	-0.34	1.62	8.09
04/04/20 17:57:02	11160	13.01	1.98	-0.35	1.61	8.12
04/04/20 17:57:32	11190	13.02	1.98	-0.36	1.64	8.12
04/04/20 17:58:02	11220	13.02	1.98	-0.37	1.63	8.15
04/04/20 17:58:32	11250	13.02	1.97	-0.36	1.65	8.16
04/04/20 17:59:02	11280	13.02	1.98	-0.34	1.65	8.19
04/04/20 17:59:32	11310	13.02	2.03	-0.35	1.63	8.21
04/04/20 18:00:02	11340	13.03	2.03	-0.34	1.63	8.20
04/04/20 18:00:32	11370	13.02	2.05	-0.31	1.58	8.19
04/04/20 18:01:02	11400	13.03	2.02	-0.36	1.59	8.18
04/04/20 18:01:32	11430	13.02	2.04	-0.31	1.57	8.18
04/04/20 18:02:02	11460	13.02	2.04	-0.30	1.58	8.17
04/04/20 18:02:32	11490	13.03	2.02	-0.27	1.57	8.16
04/04/20 18:03:02	11520	13.03	1.99	-0.29	1.54	8.13
04/04/20 18:03:32	11550	13.02	2.00	-0.29	1.54	8.11
04/04/20 18:04:02	11580	13.03	2.00	-0.26	1.54	8.08
04/04/20 18:04:32	11610	13.03	2.00	-0.25	1.50	8.07
04/04/20 18:05:02	11640	13.03	1.98	-0.27	1.53	8.07
04/04/20 18:05:32	11670	13.03	1.99	-0.25	1.51	8.08
04/04/20 18:06:02	11700	13.03	1.96	-0.27	1.52	8.08
04/04/20 18:06:32	11730	13.02	1.96	-0.27	1.50	8.10
04/04/20 18:07:02	11760	13.03	1.99	-0.26	1.51	8.11
04/04/20 18:07:32	11790	13.03	1.97	-0.25	1.51	8.11
04/04/20 18:08:02	11820	13.02	1.98	-0.23	1.48	8.13
04/04/20 18:08:32	11850	13.02	2.03	-0.24	1.49	8.13
04/04/20 18:09:02	11880	13.02	2.01	-0.22	1.47	8.14
04/04/20 18:09:32	11910	13.02	2.03	-0.22	1.49	8.14
04/04/20 18:10:02	11940	13.03	2.00	-0.21	1.49	8.15
04/04/20 18:10:32	11970	13.02	1.97	-0.22	1.50	8.17
04/04/20 18:11:02	12000	13.02	1.99	-0.21	1.47	8.17
04/04/20 18:11:32	12030	13.02	1.98	-0.19	1.47	8.17
04/04/20 18:12:02	12060	13.02	1.96	-0.20	1.48	8.19
04/04/20 18:12:32	12090	13.03	1.97	-0.20	1.48	8.19
RAW AVERAGE		**13.02**	**1.99**	**-0.30**	**1.53**	**8.11**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.01	-0.11	-0.45	
	Final Zero	-0.02	-0.05	-0.45	
	Avg. Zero	-0.02	-0.08	-0.45	
	Initial UpScale	11.98	4.56	5.47	
	Final UpScale	11.93	4.54	5.62	
	Avg. UpScale	11.96	4.55	5.55	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.04	2.04	0.13	1.66
Concentration (ppm@ 15%O_2)	N/A	1.53	0.10	1.25
Emission Rate (lb/hr)	N/A	13.76	0.55	4.15
Emission Rate (lb/MMBtu)	N/A	0.0056	0.000	0.002

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,327,760	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,327,760	SCFH

Weather Data

Barometric Pressure	29.48	in. Hg
Relative Humidity	52	%
Ambient Temperature	58	°F
Specific Humidity	0.005377	lb H_2O / lb air

Unit Data

Unit Load	350.4	megawatts
Stack Exhaust Flow (M19)	56,812,123	SCFH

Base Load Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 18:20:04	90	13.02	1.94	-0.21	1.44	7.86
04/04/20 18:20:34	120	13.03	1.97	-0.22	1.47	7.90
04/04/20 18:21:04	150	13.03	1.97	-0.22	1.54	7.95
04/04/20 18:21:34	180	13.03	1.98	-0.22	1.56	8.00
04/04/20 18:22:04	210	13.03	1.99	-0.20	1.56	7.94
04/04/20 18:22:34	240	13.03	2.01	-0.22	1.61	7.97
04/04/20 18:23:04	270	13.04	2.02	-0.19	1.61	7.99
04/04/20 18:23:34	300	13.04	2.00	-0.21	1.64	8.02
04/04/20 18:24:04	330	13.04	1.97	-0.23	1.65	8.06
04/04/20 18:24:34	360	13.04	1.96	-0.22	1.64	8.08
04/04/20 18:25:04	390	13.05	1.95	-0.21	1.65	8.09
04/04/20 18:25:34	420	13.05	1.97	-0.20	1.67	8.11
04/04/20 18:26:04	450	13.04	1.97	-0.22	1.66	8.13
04/04/20 18:26:34	480	13.04	1.99	-0.19	1.65	8.14
04/04/20 18:27:04	510	13.04	2.00	-0.19	1.64	8.17
04/04/20 18:27:34	540	13.05	1.99	-0.20	1.64	8.16
04/04/20 18:28:04	570	13.04	1.98	-0.19	1.64	8.19
04/04/20 18:28:34	600	13.04	1.99	-0.20	1.64	8.20
04/04/20 18:29:04	630	13.03	1.99	-0.21	1.62	8.22
04/04/20 18:29:34	660	13.03	2.00	-0.20	1.63	8.22
04/04/20 18:30:04	690	13.03	2.02	-0.20	1.62	8.25
04/04/20 18:30:34	720	13.03	2.04	-0.25	1.61	8.28
04/04/20 18:31:04	750	13.03	2.04	-0.20	1.59	8.27
04/04/20 18:31:34	780	13.03	2.01	-0.20	1.58	8.27
04/04/20 18:32:04	810	13.04	2.02	-0.20	1.56	8.25
04/04/20 18:32:34	840	13.04	1.98	-0.22	1.55	8.23
04/04/20 18:33:04	870	13.05	1.97	-0.22	1.49	8.22
04/04/20 18:33:34	900	13.04	1.97	-0.21	1.51	8.19
04/04/20 18:34:04	930	13.04	1.96	-0.18	1.47	8.16
04/04/20 18:34:34	960	13.04	1.92	-0.18	1.49	8.17
04/04/20 18:35:04	990	13.03	1.93	-0.17	1.50	8.16
04/04/20 18:35:34	1020	13.03	1.94	-0.19	1.47	8.15
04/04/20 18:36:04	1050	13.04	1.93	-0.20	1.46	8.15
04/04/20 18:36:34	1080	13.03	1.92	-0.16	1.48	8.14
04/04/20 18:37:04	1110	13.04	1.91	-0.19	1.46	8.15
04/04/20 18:37:34	1140	13.04	1.91	-0.21	1.45	8.16
04/04/20 18:38:04	1170	13.04	1.93	-0.22	1.44	8.16
04/04/20 18:38:34	1200	13.04	1.93	-0.21	1.44	8.16
04/04/20 18:39:04	1230	13.04	1.95	-0.19	1.42	8.16
04/04/20 18:39:34	1260	13.04	1.97	-0.18	1.41	8.17
04/04/20 18:40:04	1290	13.04	1.98	-0.19	1.41	8.18
04/04/20 18:40:34	1320	13.04	1.98	-0.19	1.40	8.18
RAW AVERAGE		**13.04**	**1.97**	**-0.20**	**1.55**	**8.13**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	-0.05	-0.45	
	Final Zero	-0.02	-0.09	-0.35	
	Avg. Zero	-0.02	-0.07	-0.40	
	Initial UpScale	11.93	4.54	5.62	
	Final UpScale	11.97	4.54	5.64	
	Avg. UpScale	11.95	4.54	5.63	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.07	2.02	0.17	1.68
Concentration (ppm@ 15%O_2)	N/A	1.52	0.13	1.27
Emission Rate (lb/hr)	N/A	13.68	0.70	4.23
Emission Rate (lb/MMBtu)	N/A	0.0056	0.000	0.002

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,327,760	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,327,760	SCFH

Weather Data

Barometric Pressure	29.49	in. Hg
Relative Humidity	54	%
Ambient Temperature	57	°F
Specific Humidity	0.005384	lb H_2O / lb air

Unit Data

Unit Load	350.7	megawatts
Stack Exhaust Flow (M19)	56,651,096	SCFH

Base Load Load, Run - 4

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 18:51:19	480	12.95	1.95	-0.09	1.47	7.94
04/04/20 18:51:49	510	12.96	1.96	-0.08	1.52	7.98
04/04/20 18:52:19	540	12.97	1.97	-0.11	1.55	7.94
04/04/20 18:52:49	570	12.98	1.95	-0.13	1.55	8.03
04/04/20 18:53:19	600	12.98	1.96	-0.12	1.56	7.99
04/04/20 18:53:49	630	12.99	1.95	-0.13	1.59	8.00
04/04/20 18:54:19	660	13.00	1.98	-0.10	1.62	8.03
04/04/20 18:54:49	690	13.00	1.96	-0.13	1.62	8.05
04/04/20 18:55:19	720	13.00	1.96	-0.11	1.62	8.06
04/04/20 18:55:49	750	13.01	1.99	-0.11	1.61	8.09
04/04/20 18:56:19	780	13.01	2.00	-0.12	1.64	8.10
04/04/20 18:56:49	810	13.01	2.03	-0.10	1.64	8.11
04/04/20 18:57:19	840	13.01	2.04	-0.08	1.62	8.13
04/04/20 18:57:49	870	13.01	2.06	-0.10	1.63	8.14
04/04/20 18:58:19	900	13.01	2.05	-0.08	1.62	8.15
04/04/20 18:58:49	930	13.01	2.05	-0.10	1.60	8.16
04/04/20 18:59:19	960	13.00	2.03	-0.09	1.61	8.17
04/04/20 18:59:49	990	13.01	2.04	-0.10	1.58	8.20
04/04/20 19:00:19	1020	13.01	2.03	-0.10	1.58	8.23
04/04/20 19:00:49	1050	13.01	2.05	-0.11	1.57	8.26
04/04/20 19:01:19	1080	13.01	2.05	-0.10	1.58	8.26
04/04/20 19:01:49	1110	13.01	2.05	-0.10	1.54	8.24
04/04/20 19:02:19	1140	13.01	2.02	-0.07	1.51	8.22
04/04/20 19:02:49	1170	13.00	2.03	-0.09	1.51	8.21
04/04/20 19:03:19	1200	13.01	2.00	-0.08	1.47	8.19
04/04/20 19:03:49	1230	13.02	1.99	-0.07	1.45	8.17
04/04/20 19:04:19	1260	13.01	1.98	-0.07	1.43	8.15
04/04/20 19:04:49	1290	13.02	1.96	-0.06	1.46	8.13
04/04/20 19:05:19	1320	13.01	1.95	-0.05	1.43	8.13
04/04/20 19:05:49	1350	13.01	1.98	-0.04	1.44	8.13
04/04/20 19:06:19	1380	13.02	1.96	-0.04	1.43	8.14
04/04/20 19:06:49	1410	13.01	1.95	-0.04	1.40	8.16
04/04/20 19:07:19	1440	13.02	1.93	-0.03	1.40	8.15
04/04/20 19:07:49	1470	13.01	1.93	-0.05	1.41	8.15
04/04/20 19:08:19	1500	13.01	1.94	-0.04	1.40	8.15
04/04/20 19:08:49	1530	13.02	1.95	-0.05	1.38	8.16
04/04/20 19:09:19	1560	13.01	1.96	-0.04	1.40	8.16
04/04/20 19:09:49	1590	13.01	1.97	-0.05	1.36	8.17
04/04/20 19:10:19	1620	13.01	1.97	-0.06	1.38	8.18
04/04/20 19:10:49	1650	13.01	1.99	-0.01	1.37	8.18
04/04/20 19:11:19	1680	13.01	1.97	-0.04	1.36	8.19
04/04/20 19:11:49	1710	13.01	2.00	-0.01	1.34	8.19
RAW AVERAGE		**13.00**	**1.99**	**-0.08**	**1.51**	**8.13**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	-0.09	-0.35	
	Final Zero	-0.02	-0.08	-0.32	
	Avg. Zero	-0.02	-0.09	-0.34	
	Initial UpScale	11.97	4.54	5.64	
	Final UpScale	11.91	4.56	5.60	
	Avg. UpScale	11.94	4.55	5.62	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.05	2.04	0.23	1.64
Concentration (ppm@ 15%O_2)	N/A	1.53	0.17	1.23
Emission Rate (lb/hr)	N/A	13.77	0.93	4.10
Emission Rate (lb/MMBtu)	N/A	0.0056	0.000	0.002

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,331,020	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,331,020	SCFH

Weather Data

Barometric Pressure	29.49	in. Hg
Relative Humidity	56	%
Ambient Temperature	56	°F
Specific Humidity	0.005385	lb H_2O / lb air

Unit Data

Unit Load	351.5	megawatts
Stack Exhaust Flow (M19)	56,958,068	SCFH

Base Load Load, Run - 5

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 19:20:23	300	12.99	1.93	-0.11	1.15	7.51
04/04/20 19:20:53	330	13.00	1.93	-0.08	1.14	7.79
04/04/20 19:21:23	360	13.00	1.92	-0.11	1.18	7.87
04/04/20 19:21:53	390	13.01	1.95	-0.11	1.20	7.92
04/04/20 19:22:23	420	13.01	1.95	-0.13	1.23	7.94
04/04/20 19:22:53	450	13.01	1.96	-0.11	1.26	7.97
04/04/20 19:23:23	480	13.01	1.98	-0.14	1.25	7.92
04/04/20 19:23:53	510	13.02	1.97	-0.14	1.26	8.01
04/04/20 19:24:23	540	13.02	1.97	-0.17	1.26	7.96
04/04/20 19:24:53	570	13.02	1.97	-0.11	1.26	7.97
04/04/20 19:25:23	600	13.02	1.97	-0.11	1.28	8.00
04/04/20 19:25:53	630	13.01	1.97	-0.12	1.29	8.05
04/04/20 19:26:23	660	13.01	1.98	-0.13	1.27	8.06
04/04/20 19:26:53	690	13.01	2.01	-0.16	1.26	8.08
04/04/20 19:27:23	720	13.02	1.99	-0.13	1.24	8.09
04/04/20 19:27:53	750	13.02	2.00	-0.16	1.26	8.10
04/04/20 19:28:23	780	13.02	1.99	-0.17	1.25	8.11
04/04/20 19:28:53	810	13.01	2.00	-0.16	1.22	8.13
04/04/20 19:29:23	840	13.01	1.96	-0.14	1.21	8.13
04/04/20 19:29:53	870	13.01	1.93	-0.13	1.19	8.14
04/04/20 19:30:23	900	13.02	1.92	-0.14	1.18	8.15
04/04/20 19:30:53	930	13.02	1.93	-0.16	1.18	8.17
04/04/20 19:31:23	960	13.02	1.94	-0.17	1.16	8.17
04/04/20 19:31:53	990	13.02	1.93	-0.14	1.15	8.17
04/04/20 19:32:23	1020	13.02	1.95	-0.18	1.13	8.19
04/04/20 19:32:53	1050	13.02	1.95	-0.15	1.14	8.23
04/04/20 19:33:23	1080	13.02	1.94	-0.16	1.14	8.24
04/04/20 19:33:53	1110	13.02	1.96	-0.14	1.11	8.23
04/04/20 19:34:23	1140	13.02	1.92	-0.16	1.08	8.24
04/04/20 19:34:53	1170	13.02	1.95	-0.16	1.06	8.22
04/04/20 19:35:23	1200	13.02	1.96	-0.15	1.05	8.21
04/04/20 19:35:53	1230	13.01	1.97	-0.14	1.02	8.20
04/04/20 19:36:23	1260	13.01	1.96	-0.12	1.02	8.19
04/04/20 19:36:53	1290	13.01	1.97	-0.11	1.02	8.18
04/04/20 19:37:23	1320	13.01	1.96	-0.08	1.03	8.17
04/04/20 19:37:53	1350	13.02	1.95	-0.10	1.01	8.16
04/04/20 19:38:23	1380	13.02	1.93	-0.07	0.99	8.14
04/04/20 19:38:53	1410	13.01	1.93	-0.12	0.99	8.15
04/04/20 19:39:23	1440	13.02	1.95	-0.08	0.97	8.16
04/04/20 19:39:53	1470	13.02	1.95	-0.09	0.97	8.15
04/04/20 19:40:23	1500	13.02	1.96	-0.08	0.99	8.16
04/04/20 19:40:53	1530	13.02	1.98	-0.07	0.96	8.16
RAW AVERAGE		**13.01**	**1.96**	**-0.13**	**1.14**	**8.09**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	-0.08	-0.32	
	Final Zero	-0.02	-0.06	-0.23	
	Avg. Zero	-0.02	-0.07	-0.28	
	Initial UpScale	11.91	4.56	5.60	
	Final UpScale	11.93	4.53	5.51	
	Avg. UpScale	11.92	4.55	5.56	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.08	2.00	0.13	1.24
Concentration (ppm@ 15%O_2)	N/A	1.51	0.10	0.94
Emission Rate (lb/hr)	N/A	13.59	0.54	3.13
Emission Rate (lb/MMBtu)	N/A	0.0056	0.000	0.001

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,335,100	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,335,100	SCFH

Weather Data

Barometric Pressure	29.50	in. Hg
Relative Humidity	58	%
Ambient Temperature	56	°F
Specific Humidity	0.005577	lb H_2O / lb air

Unit Data

Unit Load	351.9	megawatts
Stack Exhaust Flow (M19)	56,851,602	SCFH

Base Load Load, Run - 6

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 19:48:23	1980	13.01	1.87	-0.06	0.97	7.97
04/04/20 19:48:53	2010	13.01	1.90	-0.04	0.99	8.04
04/04/20 19:49:23	2040	13.01	1.91	-0.03	1.00	8.07
04/04/20 19:49:53	2070	13.01	1.90	-0.05	1.01	8.08
04/04/20 19:50:23	2100	13.01	1.88	-0.06	1.01	8.10
04/04/20 19:50:53	2130	13.01	1.91	-0.06	1.01	8.08
04/04/20 19:51:23	2160	13.02	1.92	-0.04	1.03	8.08
04/04/20 19:51:53	2190	13.01	1.93	-0.01	1.02	8.06
04/04/20 19:52:23	2220	13.01	1.95	-0.04	1.02	8.05
04/04/20 19:52:53	2250	13.01	1.96	-0.01	1.01	8.02
04/04/20 19:53:23	2280	13.01	1.97	-0.04	1.04	8.02
04/04/20 19:53:53	2310	13.02	1.99	-0.01	1.04	8.02
04/04/20 19:54:23	2340	13.02	1.99	-0.03	1.05	8.03
04/04/20 19:54:53	2370	13.02	1.99	-0.02	1.06	8.06
04/04/20 19:55:23	2400	13.02	1.99	-0.02	1.06	8.08
04/04/20 19:55:53	2430	13.01	1.98	-0.01	1.06	8.07
04/04/20 19:56:23	2460	13.01	1.98	-0.01	1.06	8.08
04/04/20 19:56:53	2490	13.01	1.97	0.00	1.05	8.09
04/04/20 19:57:23	2520	13.01	1.96	-0.01	1.03	8.10
04/04/20 19:57:53	2550	13.01	1.97	-0.02	1.03	8.10
04/04/20 19:58:23	2580	13.02	1.94	0.00	1.04	8.10
04/04/20 19:58:53	2610	13.02	1.89	-0.01	1.03	8.12
04/04/20 19:59:23	2640	13.02	1.69	0.00	1.04	8.13
04/04/20 19:59:53	2670	13.01	1.56	-0.01	1.05	8.14
04/04/20 20:00:23	2700	13.01	1.49	0.01	1.03	8.17
04/04/20 20:00:53	2730	13.02	1.42	-0.04	1.01	8.18
04/04/20 20:01:23	2760	13.02	1.39	-0.05	1.02	8.20
04/04/20 20:01:53	2790	13.01	1.39	-0.02	1.03	8.19
04/04/20 20:02:23	2820	13.01	1.38	0.00	1.04	8.59
04/04/20 20:02:53	2850	13.01	1.41	-0.02	1.01	8.51
04/04/20 20:03:23	2880	13.01	1.39	-0.03	0.99	8.35
04/04/20 20:03:53	2910	13.02	1.41	-0.01	0.99	8.26
04/04/20 20:04:23	2940	13.02	1.41	-0.04	0.99	8.25
04/04/20 20:04:53	2970	13.01	1.43	-0.05	1.00	8.25
04/04/20 20:05:23	3000	13.01	1.46	-0.07	0.97	8.27
04/04/20 20:05:53	3030	13.01	1.50	0.11	0.99	8.27
04/04/20 20:06:23	3060	13.01	1.55	0.51	0.97	8.27
04/04/20 20:06:53	3090	13.01	1.61	0.33	0.98	8.25
04/04/20 20:07:23	3120	13.01	1.67	0.32	0.95	8.23
04/04/20 20:07:53	3150	13.02	1.71	0.23	0.92	8.20
04/04/20 20:08:23	3180	13.01	1.76	0.16	0.93	8.20
04/04/20 20:08:53	3210	13.02	1.77	0.11	0.92	8.19
RAW AVERAGE		**13.01**	**1.74**	**0.02**	**1.01**	**8.15**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.02	-0.06	-0.23	
	Final Zero	-0.04	-0.09	-0.32	
	Avg. Zero	-0.03	-0.08	-0.28	
	Initial UpScale	11.93	4.53	5.51	
	Final UpScale	11.96	4.57	5.55	
	Avg. UpScale	11.95	4.55	5.53	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.05	1.79	0.26	1.10
Concentration (ppm@ 15%O_2)	N/A	1.34	0.20	0.83
Emission Rate (lb/hr)	N/A	12.14	1.09	2.77
Emission Rate (lb/MMBtu)	N/A	0.0050	0.000	0.001

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,339,180	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,339,180	SCFH

Weather Data

Barometric Pressure	29.51	in. Hg
Relative Humidity	64	%
Ambient Temperature	53	°F
Specific Humidity	0.005514	lb H_2O / lb air

Unit Data

Unit Load	352.7	megawatts
Stack Exhaust Flow (M19)	56,758,347	SCFH

Base Load Load, Run - 7

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 20:20:13	270	13.00	1.87	-0.07	0.86	7.87
04/04/20 20:20:43	300	13.00	1.91	-0.10	0.90	7.90
04/04/20 20:21:13	330	13.00	1.93	-0.11	0.92	7.95
04/04/20 20:21:43	360	13.00	1.98	-0.12	0.95	7.98
04/04/20 20:22:13	390	13.00	2.01	-0.12	0.96	7.96
04/04/20 20:22:43	420	13.00	2.03	-0.10	0.94	8.05
04/04/20 20:23:13	450	13.00	2.05	-0.13	0.94	7.99
04/04/20 20:23:43	480	13.00	2.06	-0.12	0.94	8.01
04/04/20 20:24:13	510	13.01	2.07	-0.14	0.94	8.02
04/04/20 20:24:43	540	13.01	2.07	-0.11	0.93	8.02
04/04/20 20:25:13	570	13.00	2.07	-0.11	0.94	8.01
04/04/20 20:25:43	600	13.00	2.06	-0.13	0.92	8.01
04/04/20 20:26:13	630	13.01	2.05	-0.13	0.91	7.98
04/04/20 20:26:43	660	13.01	2.02	-0.09	0.93	7.97
04/04/20 20:27:13	690	13.01	2.00	-0.14	0.92	7.97
04/04/20 20:27:43	720	13.01	2.00	-0.10	0.93	7.98
04/04/20 20:28:13	750	13.01	1.98	-0.11	0.88	8.00
04/04/20 20:28:43	780	13.01	1.94	-0.10	0.91	8.00
04/04/20 20:29:13	810	13.00	1.95	-0.12	0.89	7.99
04/04/20 20:29:43	840	13.00	1.92	-0.12	0.89	8.02
04/04/20 20:30:13	870	13.01	1.92	-0.09	0.88	8.05
04/04/20 20:30:43	900	13.01	1.90	-0.10	0.88	8.07
04/04/20 20:31:13	930	13.00	1.88	-0.11	0.89	8.08
04/04/20 20:31:43	960	13.00	1.89	-0.11	0.88	8.45
04/04/20 20:32:13	990	13.01	1.92	-0.10	0.86	8.33
04/04/20 20:32:43	1020	13.00	1.94	-0.11	0.85	8.18
04/04/20 20:33:13	1050	13.01	1.93	-0.08	0.86	8.14
04/04/20 20:33:43	1080	13.01	1.93	-0.11	0.84	8.12
04/04/20 20:34:13	1110	13.01	1.91	-0.11	0.85	8.12
04/04/20 20:34:43	1140	13.01	1.90	-0.11	0.84	8.14
04/04/20 20:35:13	1170	13.01	1.91	-0.10	0.84	8.14
04/04/20 20:35:43	1200	13.00	1.91	-0.11	0.84	8.15
04/04/20 20:36:13	1230	13.01	1.92	-0.13	0.82	8.15
04/04/20 20:36:43	1260	13.00	1.93	-0.10	0.83	8.15
04/04/20 20:37:13	1290	13.00	1.94	-0.09	0.82	8.18
04/04/20 20:37:43	1320	13.00	1.93	-0.10	0.84	8.17
04/04/20 20:38:13	1350	13.00	1.93	-0.08	0.83	8.18
04/04/20 20:38:43	1380	13.00	1.94	-0.12	0.82	8.18
04/04/20 20:39:13	1410	13.00	1.91	-0.12	0.82	8.21
04/04/20 20:39:43	1440	12.99	1.92	-0.12	0.81	8.24
04/04/20 20:40:13	1470	13.00	1.94	-0.14	0.80	8.19
04/04/20 20:40:43	1500	13.00	1.94	-0.13	0.79	8.19
RAW AVERAGE		**13.00**	**1.96**	**-0.11**	**0.88**	**8.08**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.04	-0.09	-0.32	
	Final Zero	-0.03	-0.10	-0.35	
	Avg. Zero	-0.04	-0.10	-0.34	
	Initial UpScale	11.96	4.57	5.55	
	Final UpScale	11.96	4.54	5.43	
	Avg. UpScale	11.96	4.56	5.49	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.02	2.01	0.20	0.96
Concentration (ppm@ 15%O_2)	N/A	1.50	0.15	0.72
Emission Rate (lb/hr)	N/A	13.61	0.83	2.40
Emission Rate (lb/MMBtu)	N/A	0.0055	0.000	0.001

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,342,860	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,342,860	SCFH

Weather Data

Barometric Pressure	29.51	in. Hg
Relative Humidity	66	%
Ambient Temperature	53	°F
Specific Humidity	0.005688	lb H_2O / lb air

Unit Data

Unit Load	353.0	megawatts
Stack Exhaust Flow (M19)	56,775,373	SCFH

Base Load Load, Run - 8

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 20:49:13	2010	12.98	1.35	-0.12	1.04	7.94
04/04/20 20:49:43	2040	12.98	1.35	-0.12	1.09	7.97
04/04/20 20:50:13	2070	12.99	1.35	-0.14	1.09	7.92
04/04/20 20:50:43	2100	12.99	1.35	-0.14	1.09	8.02
04/04/20 20:51:13	2130	12.99	1.35	-0.13	1.10	7.96
04/04/20 20:51:43	2160	12.99	1.38	-0.13	1.11	7.99
04/04/20 20:52:13	2190	12.99	1.41	-0.12	1.14	8.00
04/04/20 20:52:43	2220	13.00	1.43	-0.13	1.16	8.03
04/04/20 20:53:13	2250	13.00	1.46	-0.15	1.19	8.07
04/04/20 20:53:43	2280	13.00	1.52	-0.12	1.16	8.08
04/04/20 20:54:13	2310	13.00	1.56	-0.15	1.19	8.10
04/04/20 20:54:43	2340	12.99	1.61	-0.14	1.22	8.32
04/04/20 20:55:13	2370	13.00	1.64	-0.16	1.20	8.22
04/04/20 20:55:43	2400	13.00	1.72	-0.16	1.17	8.15
04/04/20 20:56:13	2430	13.00	1.77	-0.14	1.20	8.11
04/04/20 20:56:43	2460	12.99	1.79	-0.17	1.20	8.12
04/04/20 20:57:13	2490	13.00	1.84	-0.15	1.20	8.15
04/04/20 20:57:43	2520	13.00	1.89	-0.15	1.22	8.18
04/04/20 20:58:13	2550	12.99	1.96	-0.17	1.19	8.17
04/04/20 20:58:43	2580	12.99	2.00	-0.17	1.17	8.16
04/04/20 20:59:13	2610	13.00	2.05	-0.18	1.19	8.15
04/04/20 20:59:43	2640	13.00	2.07	-0.16	1.17	8.18
04/04/20 21:00:13	2670	13.01	2.09	-0.17	1.18	8.16
04/04/20 21:00:43	2700	13.00	2.09	-0.17	1.14	8.15
04/04/20 21:01:13	2730	13.01	2.10	-0.18	1.14	8.11
04/04/20 21:01:43	2760	13.01	2.10	-0.16	1.13	8.24
04/04/20 21:02:13	2790	13.01	2.11	-0.15	1.15	8.28
04/04/20 21:02:43	2820	13.00	2.09	-0.18	1.14	8.17
04/04/20 21:03:13	2850	13.00	2.08	-0.15	1.14	8.31
04/04/20 21:03:43	2880	13.00	2.06	-0.17	1.15	8.47
04/04/20 21:04:13	2910	13.00	2.06	-0.16	1.13	8.18
04/04/20 21:04:43	2940	13.00	2.03	-0.18	1.13	8.09
04/04/20 21:05:13	2970	13.00	2.01	-0.15	1.11	8.06
04/04/20 21:05:43	3000	13.00	1.99	-0.18	1.12	8.08
04/04/20 21:06:13	3030	13.00	1.99	-0.18	1.15	8.09
04/04/20 21:06:43	3060	13.00	1.97	-0.17	1.14	8.09
04/04/20 21:07:13	3090	13.01	1.95	-0.18	1.13	8.11
04/04/20 21:07:43	3120	13.00	1.93	-0.19	1.12	8.13
04/04/20 21:08:13	3150	13.00	1.92	-0.17	1.12	8.10
04/04/20 21:08:43	3180	13.01	1.91	-0.18	1.13	8.10
04/04/20 21:09:13	3210	13.01	1.87	-0.19	1.18	8.52
04/04/20 21:09:43	3240	13.01	1.87	-0.17	1.13	8.31
RAW AVERAGE		**13.00**	**1.81**	**-0.16**	**1.15**	**8.14**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.03	-0.10	-0.35	
	Final Zero	-0.03	-0.08	-0.42	
	Avg. Zero	-0.03	-0.09	-0.39	
	Initial UpScale	11.96	4.54	5.43	
	Final UpScale	11.97	4.54	5.41	
	Avg. UpScale	11.97	4.54	5.42	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.01	1.87	0.20	1.25
Concentration (ppm@ 15%O_2)	N/A	1.40	0.15	0.94
Emission Rate (lb/hr)	N/A	12.67	0.84	3.14
Emission Rate (lb/MMBtu)	N/A	0.0051	0.000	0.001

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,344,080	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,344,080	SCFH

Weather Data

Barometric Pressure	29.52	in. Hg
Relative Humidity	66	%
Ambient Temperature	52	°F
Specific Humidity	0.005478	lb H_2O / lb air

Unit Data

Unit Load	353.1	megawatts
Stack Exhaust Flow (M19)	56,765,276	SCFH

Base Load Load, Run - 9

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 21:17:13	3690	12.99	1.86	-0.20	1.05	8.01
04/04/20 21:17:43	3720	12.99	1.87	-0.21	1.05	7.96
04/04/20 21:18:13	3750	12.99	1.87	-0.19	1.09	8.04
04/04/20 21:18:43	3780	12.99	1.88	-0.17	1.09	7.96
04/04/20 21:19:13	3810	12.99	1.89	-0.17	1.14	8.03
04/04/20 21:19:43	3840	12.99	1.88	-0.16	1.15	7.96
04/04/20 21:20:13	3870	13.00	1.88	-0.20	1.15	8.03
04/04/20 21:20:43	3900	12.99	1.89	-0.19	1.17	7.98
04/04/20 21:21:13	3930	12.99	1.89	-0.19	1.19	7.99
04/04/20 21:21:43	3960	13.00	1.89	-0.17	1.21	8.01
04/04/20 21:22:13	3990	13.00	1.87	-0.20	1.20	8.04
04/04/20 21:22:43	4020	13.00	1.87	-0.20	1.22	8.03
04/04/20 21:23:13	4050	12.99	1.89	-0.19	1.22	8.05
04/04/20 21:23:43	4080	12.99	1.90	-0.19	1.21	8.06
04/04/20 21:24:13	4110	13.00	1.93	-0.17	1.22	8.06
04/04/20 21:24:43	4140	13.00	1.95	-0.18	1.22	8.07
04/04/20 21:25:13	4170	13.00	1.97	-0.19	1.22	8.09
04/04/20 21:25:43	4200	13.00	1.97	-0.20	1.20	8.12
04/04/20 21:26:13	4230	13.00	1.96	-0.19	1.21	8.12
04/04/20 21:26:43	4260	13.00	1.95	-0.19	1.21	8.13
04/04/20 21:27:13	4290	13.00	1.94	-0.21	1.21	8.13
04/04/20 21:27:43	4320	13.00	1.94	-0.20	1.22	8.14
04/04/20 21:28:13	4350	13.00	1.95	-0.18	1.18	8.14
04/04/20 21:28:43	4380	13.00	1.96	-0.19	1.18	8.15
04/04/20 21:29:13	4410	13.00	1.96	-0.20	1.17	8.15
04/04/20 21:29:43	4440	13.00	1.93	-0.16	1.17	8.17
04/04/20 21:30:13	4470	13.00	1.93	-0.19	1.17	8.19
04/04/20 21:30:43	4500	13.00	1.92	-0.20	1.17	8.22
04/04/20 21:31:13	4530	13.01	1.91	-0.23	1.19	8.23
04/04/20 21:31:43	4560	13.00	1.91	-0.18	1.17	8.25
04/04/20 21:32:13	4590	13.01	1.88	-0.21	1.16	8.26
04/04/20 21:32:43	4620	13.00	1.88	-0.19	1.16	8.27
04/04/20 21:33:13	4650	13.00	1.90	-0.22	1.14	8.28
04/04/20 21:33:43	4680	13.01	1.91	-0.22	1.12	8.30
04/04/20 21:34:13	4710	13.00	1.90	-0.22	1.12	8.29
04/04/20 21:34:43	4740	13.00	1.93	-0.21	1.10	8.29
04/04/20 21:35:13	4770	13.01	1.92	-0.20	1.14	8.29
04/04/20 21:35:43	4800	13.00	1.92	-0.20	1.09	8.28
04/04/20 21:36:13	4830	13.00	1.94	-0.17	1.07	8.25
04/04/20 21:36:43	4860	13.00	1.95	-0.22	1.07	8.22
04/04/20 21:37:13	4890	13.00	1.94	-0.19	1.06	8.19
04/04/20 21:37:43	4920	13.00	1.95	-0.18	1.04	8.17
RAW AVERAGE		**13.00**	**1.91**	**-0.19**	**1.16**	**8.13**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.03	-0.08	-0.42	
	Final Zero	-0.04	-0.12	-0.41	
	Avg. Zero	-0.04	-0.10	-0.42	
	Initial UpScale	11.97	4.54	5.41	
	Final UpScale	11.97	4.55	5.44	
	Avg. UpScale	11.97	4.55	5.43	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.01	1.97	0.20	1.26
Concentration (ppm@ 15%O_2)	N/A	1.48	0.15	0.94
Emission Rate (lb/hr)	N/A	13.38	0.82	3.16
Emission Rate (lb/MMBtu)	N/A	0.0054	0.000	0.001

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Fuel Data

Fuel Fd factor	8,710	SCF exh/MMBtu
Fuel Heating Value (HHV)	1,050	Btu/SCF fuel
Turbine Fuel Flow	2,346,940	SCFH
Duct Burner Fuel Flow	0	SCFH
Total Fuel Flow	2,346,940	SCFH

Weather Data

Barometric Pressure	29.52	in. Hg
Relative Humidity	67	%
Ambient Temperature	52	°F
Specific Humidity	0.005562	lb H_2O / lb air

Unit Data

Unit Load	351.8	megawatts
Stack Exhaust Flow (M19)	56,928,973	SCFH

Base Load Load, Run - 10

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O_2 (%)	NOx (ppmvd)	CO (ppmvd)	NH_3 (ppmvw)	H_2O (%)
04/04/20 21:50:13	362	12.98	1.80	-0.17	1.26	7.84
04/04/20 21:50:43	392	12.98	1.82	-0.14	1.27	7.92
04/04/20 21:51:13	422	12.99	1.81	-0.19	1.27	7.96
04/04/20 21:51:43	452	12.99	1.81	-0.15	1.26	8.00
04/04/20 21:52:13	482	13.00	1.81	-0.18	1.27	7.93
04/04/20 21:52:43	512	13.00	1.81	-0.16	1.27	8.03
04/04/20 21:53:13	542	13.00	1.80	-0.16	1.24	7.95
04/04/20 21:53:43	572	13.00	1.82	-0.20	1.25	8.02
04/04/20 21:54:13	602	13.00	1.83	-0.16	1.24	7.93
04/04/20 21:54:43	632	13.00	1.86	-0.17	1.27	8.00
04/04/20 21:55:13	662	13.00	1.85	-0.17	1.27	7.93
04/04/20 21:55:43	692	13.00	1.87	-0.18	1.25	8.02
04/04/20 21:56:13	722	13.00	1.89	-0.14	1.26	7.92
04/04/20 21:56:43	752	13.00	1.87	-0.16	1.27	8.02
04/04/20 21:57:13	782	13.00	1.88	-0.16	1.23	7.93
04/04/20 21:57:43	812	13.00	1.88	-0.17	1.31	8.03
04/04/20 21:58:13	842	13.00	1.88	-0.14	1.27	7.97
04/04/20 21:58:43	872	13.00	1.90	-0.20	1.25	7.96
04/04/20 21:59:13	902	13.00	1.91	-0.17	1.25	8.03
04/04/20 21:59:43	932	13.00	1.94	-0.18	1.27	7.99
04/04/20 22:00:13	962	13.00	1.93	-0.19	1.27	8.00
04/04/20 22:00:43	992	13.00	1.93	-0.19	1.30	8.03
04/04/20 22:01:13	1022	13.00	1.93	-0.18	1.27	8.04
04/04/20 22:01:43	1052	13.00	1.93	-0.15	1.25	8.05
04/04/20 22:02:13	1082	13.00	1.91	-0.16	1.27	8.05
04/04/20 22:02:43	1112	13.00	1.92	-0.21	1.24	8.06
04/04/20 22:03:13	1142	12.99	1.93	-0.20	1.25	8.07
04/04/20 22:03:43	1172	12.99	1.93	-0.21	1.24	8.07
04/04/20 22:04:13	1202	12.99	1.92	-0.21	1.25	8.06
04/04/20 22:04:43	1232	12.99	1.91	-0.21	1.21	8.05
04/04/20 22:05:13	1262	12.99	1.93	-0.23	1.26	8.07
04/04/20 22:05:43	1292	13.00	1.92	-0.20	1.24	8.09
04/04/20 22:06:13	1322	13.00	1.93	-0.23	1.23	8.11
04/04/20 22:06:43	1352	12.99	1.94	-0.21	1.19	8.12
04/04/20 22:07:13	1382	12.99	1.95	-0.20	1.22	8.12
04/04/20 22:07:43	1412	13.00	1.97	-0.22	1.20	8.14
04/04/20 22:08:13	1442	13.00	1.97	-0.23	1.19	8.14
04/04/20 22:08:43	1472	12.99	1.96	-0.22	1.18	8.14
04/04/20 22:09:13	1502	13.00	1.95	-0.24	1.20	8.14
04/04/20 22:09:43	1532	13.00	1.92	-0.21	1.25	8.51
04/04/20 22:10:13	1562	13.00	1.93	-0.20	1.20	8.46
04/04/20 22:10:43	1592	13.00	1.92	-0.22	1.19	8.32
RAW AVERAGE		**13.00**	**1.90**	**-0.19**	**1.25**	**8.05**

		O_2	NOx	CO	NH_3
	Serial Number:	INST-O2-0033	INST-NX-0049	INST-CO-0030	INST-IR-0008
		(%)	**(ppmvd)**	**(ppmvd)**	
Bias	**Initial Zero**	-0.04	-0.12	-0.41	
	Final Zero	-0.05	-0.10	-0.40	
	Avg. Zero	-0.05	-0.11	-0.41	
	Initial UpScale	11.97	4.55	5.44	
	Final UpScale	11.94	4.53	5.34	
	Avg. UpScale	11.96	4.54	5.39	
Upscale Cal Gas		11.98	4.55	5.22	

EMISSIONS DATA	O_2	NOx	CO	NH_3
Corrected Raw Average (ppm/% dry basis)	13.02	1.96	0.20	1.36
Concentration (ppm@ 15%O_2)	N/A	1.47	0.15	1.02
Emission Rate (lb/hr)	N/A	13.34	0.81	3.41
Emission Rate (lb/MMBtu)	N/A	0.0054	0.000	0.001

APPENDIX C

CALIBRATION GAS CERTIFICATIONS

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
AETB/QI and PGVP RATA Data Sheet
Cricket Valley Energy Center

AirEmissionTestingData - Level 3

QILastName	QIFirstName	QIMiddleInitial	AETBName	AETBPhoneNumber	AETBEmail	ExamDate	ProviderName	ProviderEmail
McBride	Matthew	S	Air Hygiene International Inc	888-461-8778	info@airhygiene.com	01/27/2019	Source Evaluation Society	qstiprogram@gmail.com

ProtocolGasData - Level 3

GasLevelCode	GasTypeCode	CylinderIdentifier	VendorIdentifier	ExpirationDate
LOW	ZERO			
HIGH	BALN,CO2,O2	CC721614	G12018	11/11/2026
MID	BALN,CO2,O2	CC716390	G12020	2/23/2028
HIGH	BALN,CO,NO,NOX	EB0040961	G12019	10/30/2022
MID	BALN,CO,NO,NOX	CC727541	G12019	9/3/2022

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

CERTIFICATE OF ANALYSIS
(Zero Ambient Nitrogen)

Cylinder Number:	EB0058639	**Certification Date:**	02/25/2020
Product ID Number:	121026	**Expiration Date:**	02/23/2028
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0058639.20200225-0	**Lot Number:**	EB0058639.20200225
Customer PO. NO.:		**Tracking Number:**	074332593
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Composing Material: Zero Ambient Nitrogen, Cert., Sz152

Component	Specification	Concentration
Nitrogen	Balance	Balance
Oxygen as Impurity	<1.0 PPM	<1.0 PPM
Carbon Dioxide as Impurity	<0.5 PPM	<0.5 PPM
Carbon Monoxide as Impurity	<0.5 PPM	<0.5 PPM
Total Oxides of Nitrogen as Impurity	<0.1 PPM	<0.1 PPM
Sulfur Dioxide as Impurity	<0.1 PPM	<0.1 PPM
Total Hydrocarbons as Impurity	<0.1 PPM	<0.1 PPM

Red Ball Technical Gas Service
PGVP Vendor ID # G12020
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

Anthony Cyr
Assistant Operations Manager

26068-000-G27-JQ11-00004
Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0098845	**Certification Date:**	05/03/2019
Product ID Number:	124731	**Expiration Date:**	05/02/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0098845.20190416-0	**Lot Number:**	EB0098845.20190416
Customer PO. NO.:		**Tracking Number:**	095689140
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Nitrogen Dioxide	**48.7 PPM**	±0.6 PPM	FTIR	04/26/2019, 05/03/2019

Air Balance

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0003640	EB0003640.20190102	03/20/2022	GMIS	AIR	NO2	87.8 PPM	1.061	C1579010.01
EB0096848	EB0096848.20190102	03/21/2022	GMIS	AIR	NO2	61.1 PPM	1.072	C1579010.01

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO2	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	04/26/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

26068-000-G27-JQ11-00004
Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC727541	**Certification Date:**	09/04/2019
Product ID Number:	125564	**Expiration Date:**	09/03/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC727541.20190821-0	**Lot Number:**	CC727541.20190821
Customer PO. NO.:		**Tracking Number:**	098853162
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**5.22 PPM**	±0.07 PPM	FTIR	08/27/2019
Nitric Oxide	**4.51 PPM**	±0.06 PPM	Chemiluminescence	08/27/2019, 09/04/2019
Total Oxides of Nitrogen	4.55 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM047128	ALM047128.20171116	11/08/2022	GMIS	N2	NO	9.7 PPM	1.06	12100115
CC238352	CC238352.20180209	07/18/2022	GMIS	N2	NO	5.68 PPM	1.131	12100115
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	08/09/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	08/26/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

LaMeka Dennis

LaMeka Dennis
Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

26068-000-G27-JQ11-00004
Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0040961	**Certification Date:**	10/31/2019
Product ID Number:	124737	**Expiration Date:**	10/30/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0040961.20191017-0	**Lot Number:**	EB0040961.20191017
Customer PO. NO.:		**Tracking Number:**	065159907
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**9.1 PPM**	±0.12 PPM	FTIR	10/30/2019
Nitric Oxide	**8.8 PPM**	±0.10 PPM	Chemiluminescence	10/23/2019, 10/31/2019
Total Oxides of Nitrogen	8.9 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
ALM005307	ALM0053007.20181025	10/09/2022	GMIS	N2	NO	34.2 PPM	1.062	1684B
CC202290	CC202290.20160721	01/11/2025	GMIS	N2	CO	12.14 PPM	1.033	091002
EB0076031	EB0076031.20190205	05/27/2027	GMIS	N2	CO	18.7 PPM	1.036	091002
EB0089797	EB0089797.20171116	11/09/2022	GMIS	N2	NO	9.8 PPM	1.085	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	T42C	42C-68400-360	10/18/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/30/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

26068-000-G27-JQ11-00004
Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12020

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC716390	**Certification Date:**	02/25/2020
Product ID Number:	124606	**Expiration Date:**	02/23/2028
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC716390.20200220-0	**Lot Number:**	CC716390.20200220
Customer PO. NO.:		**Tracking Number:**	098496532
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**8.91 %**	±0.03 %	NDIR	02/25/2020
Oxygen	**11.98 %**	±0.07 %	MPA	02/24/2020
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0007908	EB0007908.20190327	06/18/2027	GMIS	N2	CO2	9.5 %	0.191	C1579010.02
EB0080793	EB0080793.20180118	07/21/2026	GMIS	N2	O2	11.97 %	0.507	071001
EB0087693	EB0087693.20180504	07/21/2026	GMIS	N2	O2	24 %	0.497	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	02/11/2020
CO2	NDIR	Thermo	410i	1162980025	02/25/2020

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

26068-000-G27-JQ11-00004
Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC721614	**Certification Date:**	11/13/2018
Product ID Number:	124605	**Expiration Date:**	11/11/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC721614.20181109-0	**Lot Number:**	CC721614.20181109
Customer PO. NO.:		**Tracking Number:**	098499636
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Dioxide	**19.0 %**	±0.16 %	NDIR	11/13/2018
Oxygen	**21.0 %**	±0.12 %	MPA	11/13/2018
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0004987	EB0004987.20180323	07/15/2026	GMIS	N2	CO2	19.5 %	0.767	101001
EB0005996	EB0005996.20170209	05/09/2026	GMIS	N2	O2	20 %	0.077	071001
EB0032246	EB0032246.20170209	08/05/2025	GMIS	N2	O2	24 %	0.502	071001

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
O2	MPA	Thermo	410i	1162980025	11/06/2018
CO2	NDIR	Thermo	410i	1162980025	10/24/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Amisha Jewitt
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

26068-000-G27-JQ11-00004

Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12020

PJLA Calibration and Testing
Accreditation #62754

CERTIFIED GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0093359	**Certification Date:**	03/26/2020
Product ID Number:	125123	**Expiration Date:**	03/26/2021
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	EB0093359.20200325-0	**Lot Number:**	EB0093359.20200325
Customer PO. NO.:		**Tracking Number:**	095486048
Customer:		**Previous Certification Dates:**	

This mixture is for laboratory use only, not for drug, household or other use.
This mixture is certified in Mole % to be within ±2% of the actual number reported with a confidence of 95%.
This mixture was manufactured by scale; weights traceable to N.I.S.T. Certificate #822/266926-02.
Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Ammonia	**48.9 PPM**	± 2% NIST	FTIR
Sulfur Hexafluoride	**9.74 PPM**	± 2% NIST	FTIR
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
SA18481	70086910005	04/12/2020	PS	N2	NH3	21.1 PPM	1.2	73248226
EB0079029	EB0079029	06/27/2020	PS	N2	SF6	10.1 PPM	5	191064

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NH3	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	
SF6	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Brandon Theus
Laboratory Supervisor
Assay Laboratory: Red Ball TGS
Version 02-G, Revised on 2017-07-02

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses six major areas:

1. Field Qualifications
2. QA reviews of reports, laboratory work, and field testing;
3. Equipment calibration and maintenance;
4. Chain-of-custody;
5. Training; and
6. Knowledge of current test methods

Field Qualifications

Air Hygiene personnel are required to gain and maintain competence with testing methods and techniques according to their job titles and the roles they play during field testing events. Qualifications for each job description include:

Staff Technician - An entry level position with responsibility to test on the stack by performing duties that include: keep trucks and trailers stocked and clean, travel to and from job site, be the "hands of the test" on the stack; stay on a stack during the sample test, set up and tear down equipment on-site, perform maintenance on equipment in the shop and on-site.

Test Technician or Specialist - Acts as the "hands of the test" on the stack by performing duties that include: stay on a stack during the sample test, migrate to the testing trailer and learn the different analyzers and testing methods used on site, set up and tear down testing equipment on site, learn the system for testing from Testing Managers and Project Managers, travel to and from job site; including driving responsibilities under DOT requirements, follow directions of Testing Managers and Project Managers, learn the proper way to conduct on-site test of stationary stacks

Test Manager or Engineer - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Test Managers must hold at least one QSTI certificate.

Project Manager - Directs and coordinates all aspects of a successful test by performing the following duties personally or through subordinate supervisors including: operating analyzers and consoles during testing along with QA/QC procedures, supervise set up and tear down of equipment on site, writing, reviewing, and revising final test reports, working with the client or state personnel while on the job site, managing pre-test checklists and onsite testing procedures, diagnose and repair any problems that may arise with the equipment, safely operate a man lift and drive a truck with or without a trailer, act as crew leader in the field, write protocols and reports, maintain project log of services performed on the job, verify all equipment needed for a job was loaded on the trailer. Project Managers typically hold QSTI certificates in Groups 1 through 4.

QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. In conformance with ASTM D7036 Section 15.3.15, all metering and monitoring equipment meets or exceeds the uncertainty criteria contained in the method language that pertains to that equipment.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3 A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

Reproduction and Distribution Policy

Reproducing portions of this test report may omit critical or substantial documentation or be taken out of context and due care must be exercised in this regard. Furthermore, this test report and its associated data shall not be reproduced in full or in part without the written consent of the customer.

Data Provided by Client

Data provided by the Client is clearly identified in the report. Air Hygiene accepts data provided by the Client as accurate.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

In conformance with ASTM D7036 Section 15.3.11 and 13, all testing was performed without any real or apparent errors, with the exception of those that would be listed in Section 2.0 of this report. In addition, all testing was conducted according to the approved testing protocol, test methods, Air Hygiene Quality Manual, or ASTM D7036, with the exception of specifics noted in Section 2.0 of this report. A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO_2 to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO_2 in a balance of air or nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS
QUALITY ASSURANCE DATA

Date: April 4, 2020
Company: Cricket Valley Energy Center, LLC
Location: Dover Plains, New York
Techs: MM / SB / JJ

Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
April 4, 2020	1	0

Accredited Laboratory

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

Broken Arrow, OK

for technical competence in the field of

Environmental Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2017 *General requirements for the competence of testing and calibration laboratories*. This laboratory also meets the A2LA *R219 – Specific Requirements – TNI Field Sampling and Measurement Organization Accreditation Program*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (*refer to joint ISO-ILAC-IAF Communiqué dated April 2017*).

Presented this 18th day of December 2019

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.01
Valid to August 31, 2021

For the tests to which this accreditation applies, please refer to the laboratory's Envrionmental Scope of Accreditation.

26068-000-G27-JQ11-00004

STAC STACK TESTING ACCREDITATION COUNCIL

A2LA American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

AIR HYGIENE INTERNATIONAL, INC.

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 18th day of December 2019.

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3796.02
Valid to August 31, 2021

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

26068-000-G27-JQ11-00004

SOURCE EVALUATION SOCIETY

Qualified Source Testing Individual

LET IT BE KNOWN THAT

MATTHEW S. McBRIDE

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 27TH DAY OF JANAURY 2019 AND EFFECTIVE UNTIL JANUARY 26TH, 2024

Peter R. Westlin, QSTI/QSTO Review Board

Peter S. Pakalnis, QSTI/QSTO Review Board

Tina Sanderson, QSTI/QSTO Review Board

J. Wade Bice, QSTI/QSTO Review Board

Karen D. Kajiya-Mills , QSTI/QSTO Review Board

Bruce Randall QSTI/QSTO Review Board

CERTIFICATE NO. 2014-847


26068-000-G27-JQ11-00004

Calibration Date: April 4, 2020 **Location: Cricket Valley Energy Center - Unit U-00003**

Client: Cricket Valley Energy Center, LLC


NOx Span (ppm) = 8.90

THERMO 42 series (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.02	-0.22	0.02	YES (%)
4.55	4.56	0.11	0.01	YES (%)
8.90	8.91	0.11	0.01	YES (%)
Linearity = 0.997				




CO Span (ppm) = 9.10

THERMO 48 series (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass (±2%, ≤0.5ppm)
0.00	-0.03	-0.33	0.03	YES (%)
5.22	5.24	0.22	0.02	YES (%)
9.10	9.12	0.22	0.02	YES (%)
Linearity = 0.994				



O_2 Span (%) = 21.00

SERVOMEX 1440 (O_2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass (±2%, ≤0.5%)
0.00	-0.03	-0.14	0.03	YES (%)
11.98	12.08	0.48	0.10	YES (%)
21.00	21.10	0.48	0.10	YES (%)
Linearity = 0.994				



NOx Converter Efficiency

Date: April 4, 2020

Analyzer: INST-NX-0049

RM 7E, (02-27-14), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO_2 to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO_2 concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

Audit Gas:	NO_2 Concentration (C_v), ppmvd	**48.70**
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	**2.05**
	Analyzer Reading, NOx Channel, ppmvd	**48.30**
	Analyzer Reading, NO_2 Channel ($C_{Dir(NO2)}$), ppmvd	**46.25**
	Converter Efficiency, %	**94.97**

RM 7E, (02-27-14), 13.5 NO_2 to NO Conversion Efficiency Test (as applicable). The NO_2 to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

$$Eff_{NO2} = \left(\frac{C_{Dir}}{C_V}\right) \times 100$$

Eq. 7E-7 = $\frac{46.25 \text{ ppmvd}}{48.70 \text{ ppmvd}}$ x 100 = 94.97%

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
04/04/20 06:41:59	290	47.81	2.24
04/04/20 06:42:09	300	47.90	2.22
04/04/20 06:42:19	310	47.92	2.17
04/04/20 06:42:29	320	47.97	2.13
04/04/20 06:42:39	330	48.11	2.17
04/04/20 06:42:49	340	48.09	2.11
04/04/20 06:42:59	350	48.15	2.15
04/04/20 06:43:09	360	48.18	2.04
04/04/20 06:43:19	370	48.21	2.09
04/04/20 06:43:29	***380***	***48.30***	***2.05***
04/04/20 06:43:39	390	47.30	2.04

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
04/04/20	8:13:35	CTS_0056.LAB	9.3888
04/04/20	8:14:05	CTS_0057.LAB	9.3800
04/04/20	8:14:35	CTS_0058.LAB	9.3968
04/04/20	8:15:06	CTS_0059.LAB	9.3958
04/04/20	8:15:35	CTS_0060.LAB	9.1846

PRE TEST AVERAGE **9.35**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 (%)
04/04/20	22:19:36	CTSB_0005.LAB	9.1693
04/04/20	22:19:51	CTSB_0006.LAB	9.1726
04/04/20	22:20:06	CTSB_0007.LAB	9.1679
04/04/20	22:20:21	CTSB_0008.LAB	9.2035
04/04/20	22:20:36	CTSB_0009.LAB	9.2232

POST TEST AVERAGE **9.19**

Analyzer Make: MKS **Analyzer Model:** 2030

CO_2 Cylinder Conc. % = 8.91

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	9.35	4.93	PASS
Post Test	9.19	3.11	PASS

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - PRE TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
04/04/20	17:19:11	CTS2_0034.LAB	48.8800
04/04/20	17:19:25	CTS2_0035.LAB	49.0412
04/04/20	17:19:38	CTS2_0036.LAB	49.1998
04/04/20	17:19:51	CTS2_0037.LAB	49.0355
04/04/20	17:20:04	CTS2_0038.LAB	48.8412

PRE TEST AVERAGE **49.00**

CALIBRATION TRANSFER SPECTRA (CTS SCAN) - POST TEST

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 (ppm)
04/04/20	22:23:51	CTSB_0022.LAB	48.8442
04/04/20	22:24:06	CTSB_0023.LAB	48.9079
04/04/20	22:24:21	CTSB_0024.LAB	48.9559
04/04/20	22:24:36	CTSB_0025.LAB	49.1306
04/04/20	22:24:52	CTSB_0026.LAB	49.0504

POST TEST AVERAGE **48.98**

Analyzer Make: MKS **Analyzer Model:** 2030

NH_3 Cylinder Conc. ppm = 48.90

Run ID	Instrument Response (%)	Error (%)	Pass / Fail ±5%
Pre Test	49.00	0.20	PASS
Post Test	48.98	0.16	PASS

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Calibration Gas #1

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	NH_3 ppmvd	SF_6 ppmvd
04/04/20	22:23:36	CTSB_0021.LAB	48.6860	10.2153
04/04/20	22:23:51	CTSB_0022.LAB	48.8442	10.2344
04/04/20	22:24:06	CTSB_0023.LAB	48.9079	10.2258
04/04/20	22:24:21	CTSB_0024.LAB	48.9559	10.2266
04/04/20	22:24:36	CTSB_0025.LAB	49.1306	10.2361
04/04/20	22:24:52	CTSB_0026.LAB	49.0504	10.2319
04/04/20	22:25:07	CTSB_0027.LAB	49.2306	10.2347
04/04/20	22:25:21	CTSB_0028.LAB	49.3683	10.2500
RAW AVERAGE			**49.022**	**10.232**

Run #1: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/04/20	22:33:07	CTSB_0059.LAB	4.2651	8.0915	1.7034	0.0031
04/04/20	22:33:22	CTSB_0060.LAB	4.2581	8.0522	1.6518	0.0006
04/04/20	22:33:37	CTSB_0061.LAB	4.2569	8.0492	1.6485	0.0005
04/04/20	22:33:52	CTSB_0062.LAB	4.2668	8.0498	1.6222	0.0055
04/04/20	22:34:07	CTSB_0063.LAB	4.2573	8.0426	1.6220	0.0024
04/04/20	22:34:23	CTSB_0064.LAB	4.2685	8.0301	1.5906	0.0007
04/04/20	22:34:37	CTSB_0065.LAB	4.2654	8.0021	1.5668	0.0006
04/04/20	22:34:52	CTSB_0066.LAB	4.2621	7.9999	1.5285	0.0029
RAW AVERAGE			**4.263**	**8.040**	**1.617**	**0.002**

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Run #1: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/04/20	22:42:08	CTSB_0095.LAB	4.0305	7.7345	0.4942	4.0626
04/04/20	22:42:23	CTSB_0096.LAB	4.0376	7.7651	0.4936	3.9688
04/04/20	22:42:38	CTSB_0097.LAB	4.0265	7.7695	0.4924	3.8900
04/04/20	22:42:53	CTSB_0098.LAB	4.0318	7.7804	0.4903	3.8319
04/04/20	22:43:08	CTSB_0099.LAB	4.0295	7.7827	0.4932	3.7853
04/04/20	22:43:23	CTSB_0100.LAB	4.0320	7.7839	0.4908	3.7585
04/04/20	22:43:38	CTSB_0101.LAB	4.0306	7.7898	0.4911	3.7281
04/04/20	22:43:53	CTSB_0102.LAB	4.0265	7.8091	0.4895	3.6937
RAW AVERAGE			**4.031**	**7.777**	**0.492**	**3.840**

Run #2: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/04/20	22:50:54	CTSB_0130.LAB	4.2396	8.2340	2.0941	-0.0001
04/04/20	22:51:09	CTSB_0131.LAB	4.2403	8.2160	2.1179	0.0008
04/04/20	22:51:24	CTSB_0132.LAB	4.2486	8.2090	2.1412	0.0024
04/04/20	22:51:39	CTSB_0133.LAB	4.2342	8.2068	2.1433	-0.0008
04/04/20	22:51:54	CTSB_0134.LAB	4.2542	8.2003	2.1307	-0.0022
04/04/20	22:52:09	CTSB_0135.LAB	4.2522	8.1828	2.1243	0.0014
04/04/20	22:52:24	CTSB_0136.LAB	4.2411	8.1773	2.1472	-0.0002
04/04/20	22:52:39	CTSB_0137.LAB	4.2396	8.1662	2.1328	0.0024
RAW AVERAGE			**4.244**	**8.199**	**2.129**	**0.000**

Run #2: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/04/20	22:57:09	CTSB_0155.LAB	3.9651	7.5314	0.6428	4.7842
04/04/20	22:57:24	CTSB_0156.LAB	3.9720	7.5465	0.6399	4.7476
04/04/20	22:57:39	CTSB_0157.LAB	3.9729	7.5444	0.6386	4.7329
04/04/20	22:57:54	CTSB_0158.LAB	3.9720	7.5525	0.6383	4.7125
04/04/20	22:58:09	CTSB_0159.LAB	3.9839	7.5531	0.6353	4.6664
04/04/20	22:58:24	CTSB_0160.LAB	3.9788	7.5556	0.6350	4.6419
04/04/20	22:58:39	CTSB_0161.LAB	3.9650	7.5462	0.6362	4.6560
04/04/20	22:58:54	CTSB_0162.LAB	3.9846	7.5573	0.6376	4.6419
RAW AVERAGE			**3.974**	**7.548**	**0.638**	**4.698**

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Run #3: Pre-Spike - Native

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	NH_3 ppmvw	SF_6 ppmvw
04/04/20	23:07:25	CTSB_0196.LAB	4.2362	8.2356	2.3106	-0.0032
04/04/20	23:07:40	CTSB_0197.LAB	4.2394	8.2289	2.2898	-0.0001
04/04/20	23:07:55	CTSB_0198.LAB	4.2442	8.2331	2.2394	0.0009
04/04/20	23:08:10	CTSB_0199.LAB	4.2396	8.2368	2.2280	-0.0019
04/04/20	23:08:25	CTSB_0200.LAB	4.2420	8.2425	2.2314	-0.0026
04/04/20	23:08:41	CTSB_0201.LAB	4.2276	8.2344	2.2072	-0.0007
04/04/20	23:08:55	CTSB_0202.LAB	4.2453	8.2493	2.2149	-0.0016
04/04/20	23:09:11	CTSB_0203.LAB	4.2382	8.2375	2.2017	-0.0002
RAW AVERAGE			**4.239**	**8.237**	**2.240**	**-0.001**

Run #3: Spike A

Date (mm/dd/yy)	Time hh:mm:ss	Spectrum File Name	CO_2 %vw	H_2O (%)	SF_6 ppmvw	NH_3 ppmvw
04/04/20	23:14:56	CTSB_0226.LAB	3.9947	7.7115	0.6039	4.7754
04/04/20	23:15:11	CTSB_0227.LAB	3.9852	7.7072	0.6030	4.7017
04/04/20	23:15:26	CTSB_0228.LAB	3.9962	7.6977	0.6019	4.6277
04/04/20	23:15:41	CTSB_0229.LAB	4.0000	7.6946	0.6026	4.5903
04/04/20	23:15:56	CTSB_0230.LAB	4.0006	7.6932	0.6006	4.5569
04/04/20	23:16:11	CTSB_0231.LAB	3.9865	7.6945	0.6026	4.5112
04/04/20	23:16:26	CTSB_0232.LAB	4.0004	7.6688	0.5990	4.4850
04/04/20	23:16:41	CTSB_0233.LAB	3.9826	7.6760	0.6022	4.4402
RAW AVERAGE			**3.993**	**7.693**	**0.602**	**4.586**

Cricket Valley Energy Center, LLC
April 4, 2020
General Electric, 7F.05, Unit #U-00003
Cricket Valley Energy Center

Parameter	Unit	Run 1	Run 2	Run 3
Concentration of NH_3 Cylinder	ppmvd	49.02	49.02	49.02
Concentration of SF_6 Cylinder	ppmvd	10.23	10.23	10.23

Spike A

Stack CO_2 Concentration	%vw	4.263	4.244	4.239
Stack H_2O Concentration	%	8.040	8.199	8.237
Stack NH_3 Concentration	ppmvw	1.617	2.129	2.240
Stack SF_6 Concentration	ppmvw	0.002	0.000	-0.001
Stack + Spike CO_2 Concentration	%vw	4.031	3.974	3.993
Stack + Spike H_2O Concentration	%	7.777	7.548	7.693
Stack + Spike NH_3 Concentration	ppmvw	3.840	4.698	4.586
Stack + Spike SF_6 Concentration	ppmvw	0.492	0.638	0.602
Dilution Ratio		0.052	0.067	0.064
Ideal NH_3 Spike Yield	ppmvd	4.222	5.469	5.410
Percent Recovery NH_3	%	97.73%	88.29%	85.85%

DRIFT AND BIAS CHECK AND RESPONSE TIME CALCULATOR		
Strat Test Pre and Post QA/QC Check	**O_2**	**NOx**
Initial Zero	-0.01	-0.06
Final Zero	0.00	-0.01
Avg. Zero		-0.04
Initial UpScale	11.92	4.47
Final UpScale	11.96	4.39
Avg. UpScale	11.94	4.43
Sys Resp (Zero)	-0.03	-0.02
Sys Resp (Upscale)	12.08	4.56
Upscale Cal Gas	11.98	4.55
Initial Zero Bias	0.10%	-0.45%
Final Zero Bias	0.14%	0.11%
Zero Drift	0.05%	0.56%
Initial Upscale Bias	-0.76%	-1.01%
Final Upscale Bias	-0.57%	-1.91%
Upscale Drift	0.19%	0.90%
Alternative Specification Abs Diff **Initial Zero**	0.02	0.04
Alternative Specification Abs Diff **Final Zero**	0.03	0.01
Alternative Specification Abs Diff **Initial Upscale**	0.16	0.09
Alternative Specification Abs Diff **Final Upscale**	0.12	0.17
Calibration Span	21.00	8.90
3% of Cal. Span (drift)	0.63	0.27
5% of Cal. Span (bias)	1.05	0.45

Respone Time (min)	1.2	1.5
Sys. Response (min)	1.5	

Date/Time mm/dd/yy hh:mm:ss	z	O_2 %-10	s	z	NOx ppm-10	s	INJECTIONS
04/04/20 07:22:31		**12.03**			2.01		x
04/04/20 07:22:41		**12.04**			2.02		
04/04/20 07:22:51		**11.86**			2.01		
04/04/20 07:23:01		3.44			2.02		
04/04/20 07:23:11	x	**0.27**			2.32		
04/04/20 07:23:21		**0.07**			3.48		
04/04/20 07:23:31		**0.04**			**4.27**	x	
04/04/20 07:23:41		**0.02**			**4.29**		
04/04/20 07:23:51		**0.01**			**4.47**		
04/04/20 07:24:01		**0.00**			**4.47**		x
04/04/20 07:24:11		**0.00**			**4.46**		
04/04/20 07:24:21		**-0.01**			**4.45**		
04/04/20 07:24:31		**-0.01**			**4.48**		
04/04/20 07:24:41		**-0.02**			**4.50**		
04/04/20 07:24:51		4.46			**4.51**		
04/04/20 07:25:01		10.92			**4.53**		
04/04/20 07:25:11		**11.75**	x		4.22		
04/04/20 07:25:21		**11.84**			1.96		
04/04/20 07:25:31		**11.87**		x	**0.09**		
04/04/20 07:25:41		**11.88**			**0.05**		
04/04/20 07:25:51		**11.91**			**-0.03**		

DRIFT AND BIAS CHECK			
Base Load Load, Run - 1	**O_2**	**NOx**	**CO**
Raw Average	13.05	1.96	-0.44
Corrected Average	13.08	2.00	0.00
Initial Zero	-0.03	-0.07	-0.45
Final Zero	-0.01	-0.11	-0.45
Avg. Zero	-0.02	-0.09	-0.45
Initial UpScale	11.93	4.58	5.26
Final UpScale	11.98	4.56	5.47
Avg. UpScale	11.96	4.57	5.37
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	0.00%	-0.56%	-4.62%
Final Zero Bias	0.10%	-0.96%	-4.62%
Zero Drift	0.10%	0.39%	0.00%
Initial Upscale Bias	-0.71%	0.22%	0.22%
Final Upscale Bias	-0.48%	0.00%	2.53%
Upscale Drift	0.24%	0.22%	2.31%
Alternative Specification Abs Diff **Initial Zero**	0.00	0.05	0.42
Alternative Specification Abs Diff **Final Zero**	0.02	0.09	0.42
Alternative Specification Abs Diff **Initial Upscale**	0.15	0.02	0.02
Alternative Specification Abs Diff **Final Upscale**	0.10	0.00	0.23
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 2	**O_2**	**NOx**	**CO**
Raw Average	13.02	1.99	-0.30
Corrected Average	13.04	2.04	0.13
Initial Zero	-0.01	-0.11	-0.45
Final Zero	-0.02	-0.05	-0.45
Avg. Zero	-0.02	-0.08	-0.45
Initial UpScale	11.98	4.56	5.47
Final UpScale	11.93	4.54	5.62
Avg. UpScale	11.96	4.55	5.55
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	0.10%	-0.96%	-4.62%
Final Zero Bias	0.05%	-0.34%	-4.62%
Zero Drift	0.05%	0.62%	0.00%
Initial Upscale Bias	-0.48%	0.00%	2.53%
Final Upscale Bias	-0.71%	-0.22%	4.18%
Upscale Drift	0.24%	0.22%	1.65%
Alternative Specification Abs Diff **Initial Zero**	0.02	0.09	0.42
Alternative Specification Abs Diff **Final Zero**	0.01	0.03	0.42
Alternative Specification Abs Diff **Initial Upscale**	0.10	0.00	0.23
Alternative Specification Abs Diff **Final Upscale**	0.15	0.02	0.38
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 3	**O_2**	**NOx**	**CO**
Raw Average	13.04	1.97	-0.20
Corrected Average	13.07	2.02	0.17
Initial Zero	-0.02	-0.05	-0.45
Final Zero	-0.02	-0.09	-0.35
Avg. Zero	-0.02	-0.07	-0.40
Initial UpScale	11.93	4.54	5.62
Final UpScale	11.97	4.54	5.64
Avg. UpScale	11.95	4.54	5.63
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	0.05%	-0.34%	-4.62%
Final Zero Bias	0.05%	-0.79%	-3.52%
Zero Drift	0.00%	0.46%	1.10%
Initial Upscale Bias	-0.71%	-0.22%	4.18%
Final Upscale Bias	-0.52%	-0.22%	4.40%
Upscale Drift	0.19%	0.00%	0.22%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.03	0.42
Alternative Specification Abs Diff **Final Zero**	0.01	0.07	0.32
Alternative Specification Abs Diff **Initial Upscale**	0.15	0.02	0.38
Alternative Specification Abs Diff **Final Upscale**	0.11	0.02	0.40
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 4	**O_2**	**NOx**	**CO**
Raw Average	13.00	1.99	-0.08
Corrected Average	13.05	2.04	0.23
Initial Zero	-0.02	-0.09	-0.35
Final Zero	-0.02	-0.08	-0.32
Avg. Zero	-0.02	-0.09	-0.34
Initial UpScale	11.97	4.54	5.64
Final UpScale	11.91	4.56	5.60
Avg. UpScale	11.94	4.55	5.62
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	0.05%	-0.79%	-3.52%
Final Zero Bias	0.05%	-0.67%	-3.19%
Zero Drift	0.00%	0.12%	0.33%
Initial Upscale Bias	-0.52%	-0.22%	4.40%
Final Upscale Bias	-0.81%	0.00%	3.96%
Upscale Drift	0.29%	0.22%	0.44%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.07	0.32
Alternative Specification Abs Diff **Final Zero**	0.01	0.06	0.29
Alternative Specification Abs Diff **Initial Upscale**	0.11	0.02	0.40
Alternative Specification Abs Diff **Final Upscale**	0.17	0.00	0.36
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 5	**O_2**	**NOx**	**CO**
Raw Average	13.01	1.96	-0.13
Corrected Average	13.08	2.00	0.13
Initial Zero	-0.02	-0.08	-0.32
Final Zero	-0.02	-0.06	-0.23
Avg. Zero	-0.02	-0.07	-0.28
Initial UpScale	11.91	4.56	5.60
Final UpScale	11.93	4.53	5.51
Avg. UpScale	11.92	4.55	5.56
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	0.05%	-0.67%	-3.19%
Final Zero Bias	0.05%	-0.45%	-2.20%
Zero Drift	0.00%	0.22%	0.99%
Initial Upscale Bias	-0.81%	0.00%	3.96%
Final Upscale Bias	-0.71%	-0.34%	2.97%
Upscale Drift	0.10%	0.34%	0.99%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.06	0.29
Alternative Specification Abs Diff **Final Zero**	0.01	0.04	0.20
Alternative Specification Abs Diff **Initial Upscale**	0.17	0.00	0.36
Alternative Specification Abs Diff **Final Upscale**	0.15	0.03	0.27
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 6	**O_2**	**NOx**	**CO**
Raw Average	13.01	1.74	0.02
Corrected Average	13.05	1.79	0.26
Initial Zero	-0.02	-0.06	-0.23
Final Zero	-0.04	-0.09	-0.32
Avg. Zero	-0.03	-0.08	-0.28
Initial UpScale	11.93	4.53	5.51
Final UpScale	11.96	4.57	5.55
Avg. UpScale	11.95	4.55	5.53
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	0.05%	-0.45%	-2.20%
Final Zero Bias	-0.05%	-0.79%	-3.19%
Zero Drift	0.10%	0.34%	0.99%
Initial Upscale Bias	-0.71%	-0.34%	2.97%
Final Upscale Bias	-0.57%	0.11%	3.41%
Upscale Drift	0.14%	0.45%	0.44%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.04	0.20
Alternative Specification Abs Diff **Final Zero**	0.01	0.07	0.29
Alternative Specification Abs Diff **Initial Upscale**	0.15	0.03	0.27
Alternative Specification Abs Diff **Final Upscale**	0.12	0.01	0.31
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 7	**O_2**	**NOx**	**CO**
Raw Average	13.00	1.96	-0.11
Corrected Average	13.02	2.01	0.20
Initial Zero	-0.04	-0.09	-0.32
Final Zero	-0.03	-0.10	-0.35
Avg. Zero	-0.04	-0.10	-0.34
Initial UpScale	11.96	4.57	5.55
Final UpScale	11.96	4.54	5.43
Avg. UpScale	11.96	4.56	5.49
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	-0.05%	-0.79%	-3.19%
Final Zero Bias	-0.01%	-0.90%	-3.52%
Zero Drift	0.03%	0.11%	0.33%
Initial Upscale Bias	-0.57%	0.11%	3.41%
Final Upscale Bias	-0.57%	-0.22%	2.09%
Upscale Drift	0.00%	0.34%	1.32%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.07	0.29
Alternative Specification Abs Diff **Final Zero**	0.00	0.08	0.32
Alternative Specification Abs Diff **Initial Upscale**	0.12	0.01	0.31
Alternative Specification Abs Diff **Final Upscale**	0.12	0.02	0.19
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 8	**O_2**	**NOx**	**CO**
Raw Average	13.00	1.81	-0.16
Corrected Average	13.01	1.87	0.20
Initial Zero	-0.03	-0.10	-0.35
Final Zero	-0.03	-0.08	-0.42
Avg. Zero	-0.03	-0.09	-0.39
Initial UpScale	11.96	4.54	5.43
Final UpScale	11.97	4.54	5.41
Avg. UpScale	11.97	4.54	5.42
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	-0.01%	-0.90%	-3.52%
Final Zero Bias	0.00%	-0.67%	-4.29%
Zero Drift	0.01%	0.22%	0.77%
Initial Upscale Bias	-0.57%	-0.22%	2.09%
Final Upscale Bias	-0.52%	-0.22%	1.87%
Upscale Drift	0.05%	0.00%	0.22%
Alternative Specification Abs Diff **Initial Zero**	0.00	0.08	0.32
Alternative Specification Abs Diff **Final Zero**	0.00	0.06	0.39
Alternative Specification Abs Diff **Initial Upscale**	0.12	0.02	0.19
Alternative Specification Abs Diff **Final Upscale**	0.11	0.02	0.17
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 9	**O_2**	**NOx**	**CO**
Raw Average	13.00	1.91	-0.19
Corrected Average	13.01	1.97	0.20
Initial Zero	-0.03	-0.08	-0.42
Final Zero	-0.04	-0.12	-0.41
Avg. Zero	-0.04	-0.10	-0.42
Initial UpScale	11.97	4.54	5.41
Final UpScale	11.97	4.55	5.44
Avg. UpScale	11.97	4.55	5.43
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	0.00%	-0.67%	-4.29%
Final Zero Bias	-0.05%	-1.12%	-4.18%
Zero Drift	0.05%	0.45%	0.11%
Initial Upscale Bias	-0.52%	-0.22%	1.87%
Final Upscale Bias	-0.52%	-0.11%	2.20%
Upscale Drift	0.00%	0.11%	0.33%
Alternative Specification Abs Diff **Initial Zero**	0.00	0.06	0.39
Alternative Specification Abs Diff **Final Zero**	0.01	0.10	0.38
Alternative Specification Abs Diff **Initial Upscale**	0.11	0.02	0.17
Alternative Specification Abs Diff **Final Upscale**	0.11	0.01	0.20
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

DRIFT AND BIAS CHECK			
Base Load Load, Run - 10	**O_2**	**NOx**	**CO**
Raw Average	13.00	1.90	-0.19
Corrected Average	13.02	1.96	0.20
Initial Zero	-0.04	-0.12	-0.41
Final Zero	-0.05	-0.10	-0.40
Avg. Zero	-0.05	-0.11	-0.41
Initial UpScale	11.97	4.55	5.44
Final UpScale	11.94	4.53	5.34
Avg. UpScale	11.96	4.54	5.39
Sys Resp (Zero)	-0.03	-0.02	-0.03
Sys Resp (Upscale)	12.08	4.56	5.24
Upscale Cal Gas	11.98	4.55	5.22
Initial Zero Bias	-0.05%	-1.12%	-4.18%
Final Zero Bias	-0.10%	-0.90%	-4.07%
Zero Drift	0.05%	0.22%	0.11%
Initial Upscale Bias	-0.52%	-0.11%	2.20%
Final Upscale Bias	-0.67%	-0.34%	1.10%
Upscale Drift	0.14%	0.22%	1.10%
Alternative Specification Abs Diff **Initial Zero**	0.01	0.10	0.38
Alternative Specification Abs Diff **Final Zero**	0.02	0.08	0.37
Alternative Specification Abs Diff **Initial Upscale**	0.11	0.01	0.20
Alternative Specification Abs Diff **Final Upscale**	0.14	0.03	0.10
Calibration Span	21.00	8.90	9.10
3% of Cal. Span (drift)	0.63	0.27	0.27
5% of Cal. Span (bias)	1.05	0.45	0.46

AIR HYGIENE

RATA - FIELD DATA SHEET

Company:	Cricket Valley
Location:	Cricket Valley
Date:	4/4/20 Project Code:
Unit Make and Model:	GE
Unit Number:	4
Serial Number:	
Data Recorded By:	MM
Tested With AHI Unit(s):	Truck(s): 215 Trailer(s): 187
LDEQ Warmup/Cal Req:	On (Day/Time): 4/4/20 Cal (Day/Time): 2:00

Stack Dia. = _____
Measured By: _____
Measured With: _____

CYLINDER SERIAL NUMBERS		O_2	NOx	CO
	Low	EB0058629		
	Mid	CC716390	CC722541	
	High	CC01614	EB0046961	

CYLINDER SERIAL NUMBERS		NH3 THC	CO_2	SO_2
	Low			
	Mid			
	High	EB0043354		

RUN INFORMATION	Run #1	Run #2	Run #3	Run #4	Run #5	Run #6	Run #7	Run #8	Run #9	Run #10	Run #11	Run #12
Time Start (hh:mm:ss)	17:23:02	17:52:02	18:21:02	18:51:02	19:20:25	19:48:23	20:20:13	20:49:13	21:17:13	21:50:13		
Time Stop (hh:mm:ss)	17:43:32	18:12:32	18:41:32	19:11:32	19:46:53	20:08:53	20:40:43	21:05:43	21:31:43	22:10:43		
Rated Power (MW or hp)												
Actual Power (MW or hp)												
Barometric Pressure (in. Hg)	29.47	29.48	29.48	29.49	29.49	29.50	29.51	29.51	29.52	29.52		
Ambient Temperature (°F)	60	59	58	57	56	56	53	53	52	52		
Relative Humidity (%)	47	50	52	54	56	58	64	66	66	67		
CEMS DATA for O_2												
CEMS DATA for NOx												
CEMS DATA for CO												
CEMS DATA for SO_2												

CALIBRATION	O_2		NOx		CO		SO_2	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas	0.0	-.03	0.0	-.02	0.0	-.03		
Low Gas	11.98	12.02	4.55	4.56	5.22	5.24		
Mid Gas	21.00	21.10	8.90	8.91	9.10	9.12		
High Gas								

NO_2 CONVERSION	
NO_2 Gas (ppm)	48.7
NO Reading (ppm)	2.05
NOx Reading (ppm)	48.3
Cylinder Num	EB0043354

BIAS	O_2		NOx		CO		SO_2	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Run #1	-.03	11.93	-.07	4.58	-.45	5.26		
Run #1 / Run #2	-.01	11.98	-.11	4.56	-.45	5.47		
Run #2 / Run #3	-.02	11.93	-.05	4.54	-.45	5.62		
Run #3 / Run #4	-.02	11.97	-.09	4.54	-.35	5.64		
Run #4 / Run #5	-.02	11.91	-.08	4.56	-.32	5.60		
Run #5 / Run #6	-.02	11.93	-.06	4.53	-.23	5.57		
Run #6 / Run #7	-.04	11.90	-.09	4.57	-.32	5.55		
Run #7 / Run #8	-.03	11.96	-.10	4.51	-.35	5.43		
Run #8 / Run #9	-.03	11.94	-.08	4.54	-.42	5.41		
Run #9 / Run #10	-.04	11.97	-.12	4.59	-.41	5.44		
Run #10 / Run #11	-.05	11.94	-.10	4.53	-.40	5.36		
Run #11 / Run #12								
Run #12 Final								
Bias Gas Actual Conc.								

REPORT INFORMATION	INSTRUMENT	SERIAL #
O_2	Servo	02-0033
NOx	42C	NX-0045
CO	48C	CO-0032
THC NH3	NK2030	JR.0028
CO_2		
SO_2		

RESPONSE TIME	TIME (hh:mm)	RESP (min)
Gas Inject	/ /	
1st Inst. @ 95%	/ /	
2nd Inst. @ 95%	/ /	/ /

APPENDIX E

STRATIFICATION TEST DATA

Source Information	
Company	Cricket Valley Energy Center, LLC
Plant Name	Cricket Valley Energy Center
Equipment	General Electric (GE) 7F.05 Combustion Turbine
Location	Dover Plains, New York

Test Information	
Date	04/04/20
Project #	cis-19-cricketvalley.ny-start#1
Unit Number	U-00003
Load	Base Load
Number of Ports Available	4
Number of Ports Used	4

Stack and Test Type

- ○ Isokinetic Traverse (Wet Chemistry Testing)
- ○ Velocity Traverse (Flow and Flow RATA Test)
- ○ Stratification Traverse (Compliance Test) ☐ RM 20
- ◉ **Stratification Traverse (RATA)** ☐ Part 60 ☑ Part 75

Circular Stack

Created with Traverse-AHI v20190211


METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Cricket Valley Energy Center, LLC	**Date**	04/04/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})	236.00	in.
Distance to Near Wall of Stack	(L_{nw})	8.00	in.*
Diameter of Stack	(D)	228.00	in.
Area of Stack	(A_s)	283.53	ft^2

*assume 8 in. reference (must be measured and verified in field)

Distance from Disturbances to Port			
Distance Upstream	(A)	200.40	in.
Diameters Upstream	(A_D)	0.88	diameters
Distance Downstream	(B)	850.00	in.
Diameters Downstream	(B_D)	3.73	diameters




Number of Traverse Points Required

Diameters to Flow Disturbance		Minimum Number of[1] Traverse Points		Minimum Number of Traverse Points Comp Stratification	
Down (B_D)	Up (A_D)	Particulate	Velocity	Criteria	Points
Stream	Stream	Points	Points		
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12		
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12[2]	8 or 12[2]	**Minimum Number of**	
Upstream Spec		24	16	**Traverse Points**	
Downstream Spec		24	16	**RATA Stratification**	
Traverse Pts Required		24	16	**Criteria**	**Points**

[1] Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.


[2] 8 for Circular Stacks 12 to 24 inches
12 for Circular Stacks over 24 inches

○	Part75/60	12 RM1 pts
○	75 abrv (a)	3 points
○	75 abrv (b)	6 points
		points



Number of Traverse Points Used				
4	**Ports by**	3	**Pts / port**	**Stratification Traverse (RATA)**
12	**Pts Used**	12	**Required**	

Traverse Point Locations			
Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	4.4%	10	18
2	14.6%	33 2/8	41 2/8
3	29.6%	67 4/8	75 4/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRATIFICATION TRAVERSE (RATA) RESULTS

Company	Cricket Valley Energy Center, LLC	**Date**	04/04/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	7:28:21	**Run End**	8:07:21

Traverse Point	**Time Per Point**	**Point Start Time**	**Point Stop Time (Reading)**	**O_2**	**Percent Difference**	**NOx**	**Percent Difference**
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	3.00	7:28:21	7:31:21	12.04	**0.04%**	1.98	**2.33%**
D-2	3.00	7:31:21	7:34:21	12.04	**0.04%**	1.94	0.26%
D-1	3.00	7:34:21	7:37:21	12.04	**0.04%**	1.95	0.78%
C-3	5.00	7:37:21	7:42:21	12.05	**0.04%**	1.95	0.78%
C-2	3.00	7:41:21	7:44:21	12.05	**0.04%**	1.93	0.26%
C-1	3.00	7:44:21	7:47:21	12.05	**0.04%**	1.91	1.29%
B-3	4.00	7:47:21	7:51:21	12.04	**0.04%**	1.91	1.29%
B-2	3.00	7:51:21	7:54:21	12.04	**0.04%**	1.93	0.26%
B-1	3.00	7:54:21	7:57:21	12.05	**0.04%**	1.96	1.29%
A-3	4.00	7:57:21	8:01:21	12.05	**0.04%**	1.92	0.78%
A-2	3.00	8:01:21	8:04:21	12.05	**0.04%**	1.93	0.26%
A-1	3.00	8:04:21	8:07:21	12.04	**0.04%**	1.91	1.29%
Average				12.05		1.94	

RATA SAMPLE POINTS FOR CIRCULAR STACK

Company	Cricket Valley Energy Center, LLC	**Date**	04/04/20
Plant Name	Cricket Valley Energy Center	**Project #**	cis-19-cricketvalley.ny-start#1
Equipment	General Electric (GE) 7F.05 Combustion Turbine	**# of Ports Available**	4
Location	Dover Plains, New York	**# of Ports Used**	4

Stack Dimensions				**Traverse Data**			
Diameter or Length of Stack	(D)	228.00	in.	4	**Ports by**	3	**Pts / port**
Width of Stack	(W)		in.	12	**Pts Used**	12	**Required**
Area of Stack	(A_s)	283.53	ft^2	**Run Start**	7:28:21	**Run End**	8:07:21


40 CFR 75 Criteria

Stratification Results	
Maximum Percent Difference	0.04 % for O_2
Maximum Pollutant Conc. Diff.	0.04 ppm for NOx
Maximum Diluent Conc. Diff.	0.01 % for O_2
Stratification Conclusions	
Comparison	at least one diluent/pollutant
Stack Diameter	D > 93.6 in.

Under Part 75 criteria at least one measured pollutant or diluent demonstrates a non-stratified stack with subsequent testing from a single point located at least one meter away from the stack wall.

Traverse Point Number	**Percent of Stack Diameter**	**Distance from Inside Wall**	**Distance Including Reference Length**
	%	in.	in.
1	>17.27%	>39.37	>47.37
2			
3			

Test Type
- ☐ Moisture, for MW
- ☐ Moisture, for wet-to-dry
- ☑ Gas
- ☐ e 6.5.6.3(a) points?
- ☐ 5.6(b)(2) alt. points could apply



this page intentionally left blank
end of report

APPENDIX 7

FUEL FLOWMETER ACCURACY TEST/PRIMARY ELEMENT VISUAL INSPECTION DOCUMENTATION

26068-000-G27-JQ11-00004

Endress+Hauser

People for Process Automation

Certificate

Flow Calibration with Adjustment

30436784

American Association for Laboratory Accreditation, Cert. No 1897.01

Calibration laboratory accredited according to ISO/IEC 17025:2005


3003821102 Purchase order number	FCP-7.1.F / gravimetric Calibration rig/Method
CORETECH INDUSTRIAL CORPORATION Customer	4776.682 lb/min (≙ 100%) Calibrated full scale
US-3005985002-10 / Endress+Hauser Flowtec Order N°/Manufacturer	Service interface Calibrated output
PROMASS 83 F 6" Transmitter/Sensor	0.90011 Calibration factor
N600E816000 / N600E816000 Serial N°	15 Zero point
125T3664G001, GE PO# 610575460/3 Tag N°	71.2 °F ±0.11 °F Water temperature
New Condition	0.048 % Expanded uncertainty of measurement

Flow [%]	Flow [lb/min]	Duration [s]	m target [lb]	m meas. [lb]	Δ o.r.* [%]	Outp.** [mA]
20.0	953.972	60.2	957.184	957.219	0.004	7.20
35.7	1705.92	35.2	1000.72	1000.94	0.022	9.72
49.7	2371.62	30.2	1193.67	1194.06	0.033	11.95
75.0	3583.86	30.2	1803.81	1803.99	0.010	16.01
99.6	4755.55	30.2	2394.30	2394.52	0.009	19.93
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–

*o.r.: of reading

**Calculated value (4 - 20 mA)

Measured error % o.r.



For detailed data concerning output specifications of the unit under test, see Technical Information (TI), chapter Performance characteristics.

Calibration, traceable to NIST, has been completed on the instruments used in the equipment calibration process (see attached listing).

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approx. 95%. The expanded uncertainty of measurement includes uncertainty components of the reference, the calibration method, the environment and of the device under test. A typical value is used for the uncertainty component of the device

GE Power Generation — GENERAL ELECTRIC COMPANY GREENVILLE, S.C.

VENDOR SUPPLIED DRAWING

GE NOT TO REVISE. GE REVISION LEVEL IS AS SHOWN ON THIS APPLIQUE. THIS DOCUMENT IS FILED UNDER THE GE DRAWING NUMBER.

THIS DOCUMENT SHALL BE REVISED IN ITS ENTIRETY. ALL SHEETS OF THIS DOCUMENT ARE THE SAME REVISION LEVEL AS INDICATED IN THIS VENDOR SUPPLIED DRAWING APPLIQUE.

FIRST MADE FOR: MLI: 0639 1 OF 2

GE SIGNATURES	DATE	GE DRAWING NUMBER	REV.
CHECKED:		130V5924	-
ISSUED:			

Scott Newcomer

06-11-2018
Date of calibration

S. Newcomer
Operator

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

This certificate shall not be published or reproduced other than in full, except with the prior written approval of the issuing laboratory.

CRICKET VALLEY ENERGY CENTER
BECHTEL INFRASTRUCTURE AND POWER CORPORATION
PURCHASE ORDER NO: 26068-230-POA-MS00-00001
EQUIPMENT SCOPE: GAS TURBINE

GE Proprietary Information - Class II (Internal) US EAR - NLR

VENDOR SUPPLIED - GE NOT TO REVISE. THIS DOCUMENT IS FILED UNDER THE GE DRAWING NUMBER AND GE REVISION LEVEL.

26068-000-G27-JQ11-00004

Endress+Hauser
People for Process Automation

Certificate Addendum

CORETECH INDUSTRIAL CORPORATION	12020 - BALLSTON SPA
Customer name	Customer address
Endress+Hauser Flowtec, Div. USA	6"
Manufacturer	Nominal diameter
US-3005985002-10 / 83F1F-CP77/0	FCP-7.1.F
Customer order N°/Order code	Calibration rig
N600E816000 / N600E816000	30436784
Serial N°	Record N°
New	06-11-2018
Condition	Calibration date
-	0.048 %
Customer specified calibration due date	Uncertainty of measurement (o.r.%)
PRD-TI-024	
Calibration work procedure	

Instruments used in the calibration rig:

Asset N°	Manufacturer	Model	Description	NIST/Cert N°	Cal. date	Cal. due date
F10795	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008909	05-24-2018	05-31-2019
F10796	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008910	05-24-2018	05-31-2019
F10797	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Outlet)	008911	05-24-2018	05-31-2019
F10798	Endress+Hauser	TST434-K1B3A0	RTD - Ambient	008920	05-24-2018	05-31-2019
F10799	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008912	05-24-2018	05-31-2019
F10800	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008913	05-24-2018	05-31-2019
F10801	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008914	05-24-2018	05-31-2019
F10802	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008915	05-24-2015	05-31-2019
F10803	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008917	05-24-2018	05-31-2019
F10804	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008916	05-24-2018	05-31-2019
F10806	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008918	05-24-2018	05-31-2019
F10807	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008919	05-24-2018	05-31-2019
F10808	Endress+Hauser	-	Large Scale Diverter	008905	05-10-2018	05-31-2019
F10809	Beckhoff	KL1501	Counter/Timer	008907 / 00890	05-24-2018	05-31-2019
F10810	Beckhoff	KL1501	Counter/Timer	008906	05-24-2018	05-31-2019
F10811	Endress+Hauser	-	Small Scale Diverter	008904	05-10-2018	05-31-2019
F10813	HBM	DMP 40	Digital Scale Amplifier and scales	008903	05-10-2018	05-31-2019
-	-	-	-	-	-	-

Calibration traceable to NIST has been completed on the instrument listed above by using known working procedures and standards certified by the manufacturers and/or secondary testing laboratories to traceable to NIST. This calibration has been completed using standards having a minimum accuracy of at least four times greater than the instrument listed above. This calibration was conducted in accordance with ISO 17025:2005 and ANSI/NCSL Z540-1. Reported uncertainties represent expanded uncertainties expressed at approximately 95% confidence level using a coverage factor of k=2.

Debbie Carver

ilac-MRA A2LA ACCREDITED

Certified according to ISO 17025:2005
Certification N° 1897.01

Debbie Carver
Calibration supervisor

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

GE Proprietary Information - Class II (Internal) US EAR - NLR

ENDRESS + HAUSER INC.
2350 Endress Place
Greenwood, IN 46143
Phone: (888)ENDRESS

Endress+Hauser
People for Process Automation

CERTIFICATE OF COMPLIANCE

CUSTOMER NAME : CORETECH INDUSTRIAL CORPORATION

CUSTOMER P.O.#: 111611

ALL ITEMS FURNISHED WITH THIS SHIPMENT ARE IN COMPLIANCE WITH THE MODEL NUMBERS ORDERED ON THE REFERENCED PURCHASE ORDER, AND PUBLISHED ENDRESS+HAUSER SPECIFICATION REQUIREMENTS.
THE INSTRUMENT(S) PROVIDED ARE MANUFACTURED, TESTED, AND INSPECTED IN ACCORDANCE WITH ACCEPTED INDUSTRY MANUFACTURING PRACTICES, ISO9001 GUIDELINES, THE GRAVIMETRIC METHOD USED IN ACCORDANCE WITH ASME MFC 9M:2006 AND ENDRESS+HAUSER SPECIFICATIONS.

ENDRESS+HAUSER SALES ORDER NUMBER: 3800374688

Signed and Dated By: Gregg Miller 02/12/2020
(Dispatching Manager)

S.O. LINE	MODEL NUMBER	QTY	EXT. MODEL NUMBER	TAG NUMBER	SERIAL NUMBER
10	83F1F-CP77/0	1	83F1F-CABSBGR4BABN+Z1	125T3664G001 GE PO# 610575460/2	N4012116000

EMERSON

24 February, 2018

Emerson Automation Solutions
8200 Market Blvd
Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information

Name: FORNEY CORP
PO: 790542

Manufacturer Information

Sales Order: 5116125
Line: 3

Device Information

Device Type: Pressure Transmitter
Customer Ref/ID: N/A
Serial No: 0011953

Model No: 3051SMV5M13G3R2A11A1AC12C2E5M5Q4

Module Serial No: 14966796
Output: Linear
Device ID: 33193

Calibration Information

Factory: Chanhassen, MN, USA
Station Name: CHAN_DPFLOW_CALIBRATION_01
Operator ID: 45565
Calibration Date: 02/23/2018 08:47:14 AM

Internal Ref #: 30073092

Permanent Tag Information

DUCT BURNER
FLOW TRANSMITTER

Wire-On Tag Information

Attached Models

0305RC92B21B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-58610	Load Box	7/20/2018 2:17:00PM
E3-60655	Multimeter	9/20/2018 3:07:00PM
E3-60786	Precision Resistance Decade	7/9/2018 10:38:00AM
P3-54917	Pressure Controller	4/12/2018 1:13:00PM
P3-55113	Pressure Controller	5/2/2018 10:27:00AM

Calibration Data

DP

Reference of Calibration: Differential

Range: 0.000 TO 150.000 InH2O@68degF

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (InH2O@68degF)	% Span Error	Pass/Fail
99.994	5.409 PSI	149.99050 InH2O@68degF	149.99210	0.00107	PASS
79.991	4.327 PSI	119.98680 InH2O@68degF	119.98590	-0.00060	PASS
59.989	3.245 PSI	89.98320 InH2O@68degF	89.96931	-0.00926	PASS
39.986	2.163 PSI	59.97956 InH2O@68degF	59.96970	-0.00657	PASS
19.984	1.081 PSI	29.97591 InH2O@68degF	29.97540	-0.00034	PASS
0.000	0.000 PSI	0.00000 InH2O@68degF	-0.00136	-0.00091	PASS

SP

Reference of Calibration: Gauge

Range: 0.000 TO 100.000 PSI

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (PSI)	% Span Error	Pass/Fail
100.000	100.000 PSI	100.00000 PSI	99.99935	-0.00065	PASS
80.000	80.000 PSI	80.00000 PSI	79.99359	-0.00641	PASS
60.000	60.000 PSI	60.00000 PSI	59.99270	-0.00730	PASS
40.000	40.000 PSI	40.00000 PSI	39.99899	-0.00101	PASS
20.000	20.000 PSI	20.00000 PSI	19.99092	-0.00908	PASS
0.000	0.000 PSI	0.00000 PSI	-0.00486	-0.00486	PASS

PT

Range: 0.000 TO 150.000 DEG F

Damping: 0.40 seconds

% of Range	Applied Resistence	Applied Resistence	Digital Output (DEG F)	Error (DEG F)	Pass/Fail
100.000	125.373 Ohms	150.00000 DEG F	149.97640	-0.02360	PASS
80.000	118.969 Ohms	120.00000 DEG F	119.98160	-0.01840	PASS
60.000	112.533 Ohms	90.00000 DEG F	89.99405	-0.00595	PASS
40.000	106.066 Ohms	60.00000 DEG F	60.01852	0.01852	PASS
20.000	99.566 Ohms	30.00000 DEG F	30.03536	0.03536	PASS
0.000	93.033 Ohms	0.00000 DEG F	0.02816	0.02816	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Heather Matthiesen
Quality Manager

From: Keiper, Evan
To: Carr, Peter
Cc: Relange, Julien (GE Power); Habib Alfraiheen; Reginald Williams
Subject: RE: Orifice Plate Inspection Statement
Date: Friday, April 10, 2020 12:22:24 PM

Peter,

As the responsible I&C Startup lead on the project, I can attest that the Unit 3 duct burner fuel flow meter including the orifice run was installed correctly onsite and no nonconformances or defects were noted during its initial checkout and placement into operation. Similarly, the orifice plate and transmitter taps were installed per design and are correctly orientated for proper fuel flow measurement. I have also reviewed the AGA calibration records related to the Unit 3 fuel flow meter and noted no issues.

Regards,

Evan Keiper
Bechtel Infrastructure and Power Corp.
Cricket Valley Energy Center
Startup Instrumentation & Controls
D: 571-392-6330
M: 234-207-0424

Level 3 - Bechtel Internal and Selected External Distribution

[redacted]





APPENDIX 8

GAS CYLINDER CERTIFICATION SHEETS

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401543888-1
Cylinder Number:	ALM-026215	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 22, 2019

Expiration Date: Jul 22, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	177.0 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019, 07/22/2019
NITRIC OXIDE	180.0 PPM	176.7 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019, 07/22/2019
CARBON MONOXIDE	1700 PPM	1707 PPM	G1	+/- 1.0% NIST Traceable	07/15/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060130	KAL004288	249.9 PPM NITRIC OXIDE/NITROGEN	+/- 0.4%	Nov 08, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401543888-1
Cylinder Number:	SG9147577BAL	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 22, 2019

Expiration Date: Jul 22, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	176.9 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019, 07/22/2019
NITRIC OXIDE	180.0 PPM	176.8 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019, 07/22/2019
CARBON MONOXIDE	1700 PPM	1711 PPM	G1	+/- 0.6% NIST Traceable	07/15/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060130	KAL004288	249.9 PPM NITRIC OXIDE/NITROGEN	+/- 0.4%	Nov 08, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019
Nicolet 6700 AHR0801549 NO	FTIR	Jun 27, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401515527-1
Cylinder Number:	CC338501	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jun 19, 2019

Expiration Date: Jun 19, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.879 PPM	G1	+/- 0.9% NIST Traceable	06/12/2019, 06/19/2019
NITRIC OXIDE	9.000 PPM	8.841 PPM	G1	+/- 0.9% NIST Traceable	06/12/2019, 06/19/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060622	CC442581	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060622	CC442581 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	May 22, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	May 22, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401545928-1
Cylinder Number:	CC409686	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jul 24, 2019

Expiration Date: Jul 24, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.819 PPM	G1	+/- 0.9% NIST Traceable	07/17/2019, 07/24/2019
NITRIC OXIDE	9.000 PPM	8.791 PPM	G1	+/- 0.9% NIST Traceable	07/17/2019, 07/24/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jul 18, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jul 18, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401543673-1
Cylinder Number:	CC512404	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jul 17, 2019

Expiration Date: Jul 17, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	7.044 PPM	G1	+/- 0.7% NIST Traceable	07/17/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08011106	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	+/- 0.5%	May 24, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jul 02, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A2039	Reference Number:	160-401543673-1
Cylinder Number:	EB0092627	Cylinder Volume:	144.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	350
Gas Code:	CO,BALN	Certification Date:	Jul 17, 2019

Expiration Date: Jul 17, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	7.000 PPM	6.980 PPM	G1	+/- 0.7% NIST Traceable	07/17/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08011106	KAL003958	9.855 PPM CARBON MONOXIDE/NITROGEN	+/- 0.5%	May 24, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR - CO - 000928781	FTIR	Jul 02, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI78E15A0124	Reference Number:	160-401435090-1
Cylinder Number:	ALMO47793	Cylinder Volume:	146.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Mar 04, 2019

Expiration Date: Mar 04, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	22.00 %	22.20 %	G1	+/- 0.4% NIST Traceable	03/04/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060507	CC401541	23.204 % OXYGEN/NITROGEN	0.2%	Dec 24, 2021

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS OXYMAT 61 S01062 O2	PARAMAGNETIC	Feb 18, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI78E15A0124	Reference Number:	160-401525182-1
Cylinder Number:	CC270907	Cylinder Volume:	146.3 CF
Laboratory:	124 - Plumsteadville - PA	Cylinder Pressure:	2015 PSIG
PGVP Number:	A12019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jun 17, 2019

Expiration Date: Jun 17, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	22.00 %	22.22 %	G1	+/- 0.3% NIST Traceable	06/17/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS OXYMAT 6 - W5951 - O2	PARAMAGNETIC	May 23, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0131	Reference Number:	122-401550341-1
Cylinder Number:	CC415620	Cylinder Volume:	144.3 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22019	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Aug 01, 2019

Expiration Date: Aug 01, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.053 PPM	G1	+/- 1.0% NIST Traceable	07/25/2019, 08/01/2019
NITRIC OXIDE	9.000 PPM	9.036 PPM	G1	+/- 0.9% NIST Traceable	07/25/2019, 08/01/2019
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060612	CC442569	50.42 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Jun 27, 2020
NTRM	16060612	CC442569 NOx	50.49 PPM NOx/NITROGEN	+/- 0.8%	Jun 27, 2020

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
THERMO NO 42I-1308857345	Chemiluminescence	Jul 18, 2019
THERMO NOX 42I-1308857345	Chemiluminescence	Jul 18, 2019

Triad Data Available Upon Request

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A09J6	Reference Number:	122-401722350-1
Cylinder Number:	CC435700	Cylinder Volume:	144.4 CF
Laboratory:	124 - Durham (SAP) - NC	Cylinder Pressure:	2015 PSIG
PGVP Number:	B22020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 11, 2020

Expiration Date: Feb 11, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	180.2 PPM	G1	+/- 1.2% NIST Traceable	02/04/2020, 02/11/2020
NITRIC OXIDE	180.0 PPM	180.1 PPM	G1	+/- 1.2% NIST Traceable	02/04/2020, 02/11/2020
CARBON MONOXIDE	1700 PPM	1679 PPM	G1	+/- 1.1% NIST Traceable	02/04/2020
NITROGEN	Balance			-	

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	17060225	EB0079096	100.3 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jul 23, 2023
PRM	PRM	D562879	10.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.9%	Aug 17, 2018
GMIS	124206889114	CC322698	4.432 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Aug 15, 2021
NTRM	09010339	KAL004580	970.0 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801549 CO	FTIR	Jan 08, 2020
Nicolet 6700 AHR0801549 NO	FTIR	Feb 05, 2020
Nicolet 6700 AHR0801549 NO	FTIR	Feb 05, 2020

Triad Data Available Upon Request

Signature on file

Approved for Release

26068-000-G27-JQ11-00004
Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12019

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC712750	**Certification Date:**	06/28/2019
Product ID Number:	125597	**Expiration Date:**	06/27/2022
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC712750.20190613-0	**Lot Number:**	CC712750.20190613
Customer PO. NO.:		**Tracking Number:**	097026895
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**48.8 PPM**	±0.13 PPM	FTIR	06/19/2019
Nitric Oxide	**49.4 PPM**	±0.5 PPM	Chemiluminescence	06/19/2019, 06/28/2019
Total Oxides of Nitrogen	49.7 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
FF18347	04-L-68	04/04/2021	SRM	N2	CO	49.136 PPM	0.132	1678c
CC238430	CC238430.20181025	02/03/2027	GMIS	N2	NO	92 PPM	1.06	12100115
CC726153	CC726153.20190328	06/04/2027	GMIS	N2	CO	48.6 PPM	0.239	1678c
EB0049172	EB0049172.20181025	02/05/2022	GMIS	N2	NO	34 PPM	1.104	12100115
EB0078547	EB0078547.20171228	07/17/2026	GMIS	N2	NO	62.4 PPM	1.064	12100115

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	42i-HL	1152610017	06/05/2019
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	06/06/2019

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Jasmine Godfrey
Analytical Chemist
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

26068-000-G27-JQ11-00004
Red Ball Technical Gas Service
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150
PGVP Vendor ID # G12018

PJLA Calibration and Testing
Accreditation #62754

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	CC719253	**Certification Date:**	09/26/2018
Product ID Number:	124122	**Expiration Date:**	09/24/2026
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	- Shreveport - LA
COA #	CC719253.20180910-0	**Lot Number:**	CC719253.20180910
Customer PO. NO.:		**Tracking Number:**	098490608
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle	Assayed On
Carbon Monoxide	**113.0 PPM**	±0.9 PPM	FTIR	09/24/2018
Nitric Oxide	**109.4 PPM**	±0.8 PPM	Chemiluminescence	09/17/2018, 09/26/2018
Total Oxides of Nitrogen	110.8 PPM			
Nitrogen	Balance			

Analytical Measurement Data Available Online.

Reference Standard(s)

Serial Number	Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
CC349590	CC349590.20170821	12/03/2025	GMIS	N2	NO	294 PPM	0.451	2735
EB0024184	EB0024184.20171228	05/22/2026	GMIS	N2	NO	91 PPM	1.061	12100115
EB0059475	EB0059475.20180102	09/18/2026	GMIS	N2	CO	710 PPM	0.635	1681B

Analytical Instrumentation

Component	Principle	Make	Model	Serial	MPC Date
NO	Chemiluminescence	Thermo	42i-HL	1152610017	08/31/2018
CO	FTIR	MKS	MKS 2031DJG2EKVS13T	017146467	09/24/2018

SMART-CERT

This is to certify the gases referenced have been calibrated/tested, and verified to meet the defined specifications. This calibration/test was performed using Gases or Scales that are traceable through National Institute of Standards and Technology (NIST) to the International System of Units (SI). The basis of compliance stated is a comparison of the measurement parameters to the specified or required calibration/testing process. The expanded uncertainties use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from Red Ball Technical Gas Services. If not included, the uncertainty of calibrations are available upon request and were taken into account when determining pass or fail.

Anthony Cyr
Assistant Operations Manager
Assay Laboratory: Red Ball TGS
Version 02-J, Revised on 2018-09-17

HiQ® Certificate / Certificat HiQ®

LINDE CANADA LIMITED
530 Watson St. East
Whitby, ON, Canada L1N 5R9

CERTIFICATE OF ANALYSIS — EPA PROTOCOL MIXTURE

Purchase order # 110585036
Lot # 1263941
Cylinder Number: EB 0049417

PGVP ID # L12013
Procedure: G1
Gas Type Code: OC2
Cylinder pressure: 2000 psig

Certification date
August 12, 2013

Expiration Date
August 13, 2021

ANALYTICAL RESULTS

Component	Requested Concentration ± blending tolerance	Date of Assay	Mean Concentration	Certified Concentration Uncertainty expressed at 95% confidence
Carbon Dioxide	5 % ± 5%	August 12, 2013	5.01 %	5.01 ± 0.02 %
Oxygen	6 % ± 5%	August 9, 2013	6.03 %	6.03 ± 0.01 %

BALANCE GAS: Nitrogen

REFERENCE STANDARDS

Component	Type	Serial Number	Reference Number	Concentration	Expiration Date
Carbon Dioxide	GMIS	SX 21992	1187915	10 ± 0.02 %	August 20, 2013
	NTRM	SG 9916842	101001	19.98 ± 0.14 %	April 15, 2016
Oxygen	GMIS	SX 31579	1107503	9.975 ± 0.06 %	August 18, 2013
	NTRM	CC 237234	071001	24.12 ± 0.12 %	March 27, 2017

CERTIFICATION INSTRUMENTS

Component	Make/Model	Measurement Principle	Serial Number	Last Calibration
Carbon Dioxide	SICK MCS 100E	Infrared Photometer	04310670	August 1, 2013
Oxygen	Servomex 04100 C1	Paramagnetic Sensor	392350	August 9, 2013

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE 2012 EPA PROTOCOL *PROCEDURE*

DO NOT USE THIS CYLINDER WHEN THE PRESSURE FALLS BELOW 100 PSIG

Analyst: Keith Cybulski Signature _____ Date 08/12/13

Notes:

Tel: 1-(866) 385-5349 Fax:1-(866) 385-5347 service@lindecanada.com

Assay Laboratory: Red Ball TGS
555 Craig Kennedy Way
Shreveport, LA 71107
800-551-8150

EPA PROTOCOL GAS CERTIFICATE OF ANALYSIS

Cylinder Number:	EB0053431	**Certification Date**:	06/15/2015
Product ID Number:	124822	**Expiration Date:**	06/13/2023
Cylinder Pressure:	1900 PSIG	**MFG Facility:**	RBTGS-Shreveport-LA
COA #	EB0053431.20150611-0	**Lot Number:**	EB0053431.20150611
Customer PO. NO.:		**Tracking Number:**	074201901
Customer:		**Previous Certification Dates:**	

This calibration standard has been certified per the May 2012 EPA Traceability Protocol, Document EPA-600/R-12/531, using procedure G1.

Do Not Use This Cylinder Below 100 psig (0.7 Megapascal).

Certified Concentration(s)

Component	Concentration	Uncertainty	Analytical Principle
Oxygen	**13.46 %**	±0.06 %	MPA
Nitrogen	Balance		

Analytical Measurement Data Available Online.

Reference Standard(s)

Lot	Expiration	Type	Balance	Component	Concentration	Uncertainty(%)	NIST Reference
EB0055414.20140228-1C	10/07/2022	GMIS	N2	O2	23.8 %	0.505	071001
LD131022.115903.1G	10/07/2022	GMIS	N2	O2	11.97 %	0.527	071001

Analytical Instrumentation

Component	Analytical Principle	Make	Model	Serial	MPC Date
O2	MPA	Horiba	VA-3013	H0000P11	5/22/2015 12:35:56 PM

Red Ball Technical Gas Service
PGVP Vendor ID # G12015
Information and Ordering
800-551-8150
Fax (318-425-6309)

Accreditation #62754

LaMeka Dennis
Assistant Operations Manager

<<<<END OF DOCUMENT>>>>

APPENDIX J: CEMS MONITORING PLAN

CUSTOM INSTRUMENTATION SERVICES CORPORATION

CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
ORIS CODE: 57185
UNITS U-00001, U-00002, and U-00003

40 CFR 75 MONITORING PLAN

PREPARED FOR: CRICKET VALLEY ENERGY CENTER

PREPARED BY: CUSTOM INSTRUMENTATION SERVICES, CORP.

Date: May 17, 2019
Revision B

7841 SOUTH WHEELING COURT • ENGLEWOOD, COLORADO 80112
TEL: (303) 790-1000 FAX: (303) 790-1000

TABLE OF CONTENTS

PART 1 – MONITORING PLAN
- SUPPLEMENTAL INFORMATION
- LIST OF EXPECTED DATA TYPES FOR QUARTERLY SUBMISSION FILE
- EMISSIONS COLLECTION & MONITORING PLAN SYSTEM (ECMPS) ELECTRONIC MONITORING PLAN PRINTOUT

PART 2 – MONITOR LOCATION INFORMATION
- SCHEMATIC DIAGRAMS/CEMS SAMPLE LOCATION
- DATA FLOW DIAGRAM

ATTACHMENT 1 – CERTIFICATION TEST PROTOCOL
ATTACHMENT 2 – FUEL FLOWMETER DOCUMENTS
ATTACHMENT 3 – FUEL ANALYSIS DOCUMENT
ATTACHMENT 4 – STACK DRAWINGS

PART 1

- **SUPPLEMENTAL INFORMATION**
- **LIST OF EXPECTED DATA TYPES FOR QUARTERLY SUBMISSION FILE**
- **EMISSIONS COLLECTION & MONITORING PLAN SYSTEM (ECMPS) ELECTRONIC MONITORING PLAN PRINTOUT**

CRICKET VALLEY ENERGY CENTER
DOVER PLAINS, NEW YORK
ORIS CODE: 57185
UNITS U-00001, U-00002, and U-00003

40CFR75 MONITORING PLAN

SUPPLEMENTAL INFORMATION

FACILITY DESCRIPTION

Cricket Valley Energy Center is a facility located in Dover Plains, New York. The facility consists of three natural gas-fired combined cycle electric generating units identified as U-00001, U-00002, and U-00003. This monitoring plan document pertains to the three General Electric (GE) Model 7FA.05 combustion turbine generators (CTGs) operating in combined-cycle mode with supplemental firing of the heat recovery steam generators (HRSGs) which has a generating capacity of 1,000 MW. Natural gas will be the sole fuel fired in the CTGs and duct burners. In addition to the air emitting equipment, the Facility will include three steam turbine generators (STGs), an air cooled condenser (ACC) and associated auxiliary equipment and systems. Each combined cycle generating unit consisting of the CTG, HRSG and STG will be exhausted through its own stack. Both dry-low NO_X burners (DLNB) and Selective Catalytic Reduction (SCR) are used for NO_X control on the all three Units. Exhaust gases from the turbines are discharged into the atmosphere through a stack approximately 282.5 feet above grade. A dedicated CEMS will monitor NO_X, and O_2 emissions and gas fuel flow from each of the three units.

This monitoring plan document pertains to the Continuous Emission Monitoring Systems (CEMS) for oxides of nitrogen (NO_x) and oxygen (O_2) that will be used to demonstrate continuous compliance with the reporting requirements set forth in Title 40 Code of Federal Regulations (CFR), Part 75.

GAS-FIRED STATUS

The combustion turbine generators will be fired exclusively with pipeline quality natural gas. Therefore, the Units will qualify as "gas-fired" under the definitions in 40 CFR §72.2 and are exempt from opacity monitoring requirements per 40 CFR §75.14(c).

SO_2 EMISSION CALCULATIONS

U-00001, U-00002, and U-00003 will utilize natural gas to fire the gas turbines. The natural gas fuel meets the definition of "pipeline natural gas" in 40 CFR §72.2 (i.e., contains 0.5 grains or less of total sulfur per 100 standard cubic feet). In addition, it must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 Btu per standard cubic foot. Therefore, the National Allowance Data Base (NADB) default emission rate of 0.0006 pounds of SO_2 per million British thermal units and heat input will be used to calculate SO_2 mass emissions as per 40 CFR Part 75 Appendix D, Formula D-5.

CO_2 EMISSION CALCULATIONS

Carbon dioxide mass emissions will be calculated based on fuel flow as per the procedures in 40 CFR Part 75, Appendix G, Formula G-4.

NO_X AND HEAT INPUT MONITORING SYSTEM DESCRIPTION

Units U-00001, U-00002, and U-00003 extractive continuous emission monitoring system at the Cricket Valley Energy Center was manufactured by Custom Instrumentation Services Corporation of Englewood, Colorado. The portion of the CEMS used for 40 CFR Part 75 includes a NO_X and O_2 analyzer, programmable logic controller (PLC) and a data acquisition and handling system (DAHS). All analyses are on a "dry" basis from undiluted samples. Heat input is calculated using fuel flow (scf/hr) and the gross calorific value (Btu/scf) as per the procedures in 40 CFR Part 75, Appendix F, Section 5.5.2.

DATA TYPES

Data is written on an hourly basis to a Microsoft SQL Server database by CISCO CeDAR CEMS software, exported quarterly to an Extensible Mark-up Language (XML) file with CISCO Breez75x software, and submitted quarterly to the U.S. Environmental Protection Agency using their Emissions and Collection Monitoring Plan System (ECMPS) software. The following values are recorded on an hourly basis:

- NO_X ppm.
- Percent O_2.
- Natural gas fuel flow.
- Turbine load

In addition, fuel heating values (Btu/scf) are entered in the DAHS from fuel analysis performed according to 40 CFR 75 Appendix D, Section 2.3.4. These two values are used to calculate heat input on an hourly basis. NO_X lb/MMBtu is calculated using 40 CFR 75 Appendix F, Equation F-5, and SO_2 and CO_2 mass emissions are calculated based on fuel flow. Calibration results for the NO_X and O_2 analyzers are recorded daily.

MISSING DATA PROCEDURES

The DAHS will use the standard missing data procedures in 40 CFR Part 75.

- For periods of missing NO_X and/or O_2 data, the NO_X emission rate (lb/MMBtu) will be substituted based on load following 40 CFR Part 75, Subpart D. When required, the maximum NO_X emission rate (MER) will be substituted during the missing period.
- For periods of missing gas flow the missing data procedures for NO_X and SO_2 in 40 CFR §75.33 and 40 CFR Part 75, Appendix D, Section 2.4 will be used.
- For periods of missing fuel flow rate (hscf/hr) the data will be substituted based on lookback procedures as per 40 CFR Part 75, Appendix D §2.4.2.2.1.
- The maximum potential fuel flow rate will be substituted if no data in the lookback period at the corresponding or higher load range when only the same fuel was combusted exists.
- The Substitution routines have a maximum lookback period of 26280 hours.

NO_X CONTROL EQUIPMENT

The emission control system for NO_X consists of dry low NO_X burner (DLNB) and selective catalytic reduction (SCR) during natural gas firing.

VALUES IN MONITORING PLAN

The NO_X maximum potential concentration (MPC) of 150 ppm is used as per 40 CFR 75 Appendix A, Section 2.1.2, Table 2-2. The dual range NO_X analyzers have span low and high values set to 10 ppm and 200 ppm, respectively. The full-scale range of the NO_X analyzers is 10 ppm and 200 ppm. The O_2 span and range will be 25 percent. The maximum expected concentrations (MEC) for the low range of the analyzer is 2 ppm as stated in the New York State Department of Environmental Conservation Permit No. 3-1326-00275/00009. The majority of readings will fall between 20 - 80 percent of the analyzer range. The maximum emission rate (MER) was determined using the EPA Table value in Table 2-2 as per 40 CFR Part 75, Appendix A 2.1.2.1 (a) Option 2. The 150 ppm MPC, 19% O_2, and 8710 F_d factor were used to calculate the NO_X MER value as 1.716 lb/MMBtu using formula F-5.

To meet the 40 CFR 75 initial certification and ongoing quality assurance criteria calibration error tests and linearities will be performed. Calibration (zero and mid/high) and linearity (low, mid and high) gas levels will be based on the aforementioned span values, where zero, low-, mid- and high-level gases correspond to 0 to 20; 20 to 30; 50 to 60; and 80 to 100 percentages of span, respectively. All gases will meet the EPA Protocol Gas Verification Program (PGVP) requirements. Detailed information is provided in the attached Certification Protocol.

CRICKET VALLEY ENERGY CENTER
ORIS CODE: 57185

LIST OF EXPECTED DATA TYPES FOR QUARTERLY SUBMISSION FILE

Description
Unit Characteristics
Facility Identification
Facility Location and Identification Information
Unit
Unit Capacity
Unit Control
Unit Fuel
Unit Program
Reporting Frequency
Emission Data
Heat Input
NO_X Emission Rate Data (lb/MMBtu)
Heat Input Rate (MMBtu/hr)
SO_2 Mass Emissions Rate (lb/hr)
CO_2 Mass Emissions Rate (tons/yr)
Daily Calibration Test Data and Results
Unit Operating Parameters
Monitoring Plan
Methods
Components
Systems.
Formulas
Defaults
Non-Flow Span
Load Data
Location Attributes
QA/Certification Test Data
7-Day Calibration Error Test
Linearity Test
Linearity Check Results
RATA and Bias Test
Cycle Time Test
Fuel Flowmeter Accuracy Test
Transmitter/Transducer Test
Online/Offline Calibration Test (Optional)
Miscellaneous Tests
QA/Certification Event

CRICKET VALLEY ENERGY CENTER
ORIS CODE: 57185

ELECTRONIC MONITORING PLAN PRINTOUT

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL):	57185
Monitoring Plan Location IDs:	U001
State:	NY
County:	Dutchess County
Latitude:	41.6762
Longitude:	-73.5806

Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
U001	Q - Quarterly	2019 QTR 3	

Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Cross Area Exit	Cross Area Flow	Material Code	Shape Code	Begin Date	End Date
U001		435	283	284		OTHER	ROUND	09/01/2019	

Unit Operation Information

Unit Identifier	Non-Load Based Ind	Commence Commercial Operation Date	Commence Operation Date	Boiler/Turbine Type			Max Heat Input		
				Code	Begin Date	End Date	Value (mmBtu)	Begin Date	End Date
U001	0	05/01/2019		CC	05/01/2019		2587.8	05/01/2019	

Unit Type Codes: CC - Combined cycle

Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
U001	ARP	P2	05/01/2019	
	CSNOX	A	05/01/2019	
	CSOSG2	A	05/01/2019	
	CSSO2G1	A	05/01/2019	

Unit Fuel

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
U001	PNG	P				05/01/2019	

Fuel Type Codes: PNG - Pipeline Natural Gas

Fuel Indicator Codes: P - Primary

Unit Controls

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
U001	NOX	DLNB	Y				
	NOX	SCR	Y				

Control Equipment Descriptions: SCR - Selective Catalytic Reduction

DLNB - Dry Low NOx Burners

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
U001	CO2	AD	SPTS		09/01/2019 00	
	HI	AD	SPTS		09/01/2019 00	
	NOX	NOXR			09/01/2019 00	
	NOXR	CEM	SPTS		09/01/2019 00	
	OP	EXP			09/01/2019 00	
	SO2	AD	SPTS		09/01/2019 00	

Parameter Codes: SO2 - SO2 Hourly Mass Rate (lb/hr)
OP - Opacity
NOXR - NOx Emission Rate (lb/mmBtu)
NOX - NOx Hourly Mass Rate (lb/hr)
HI - Heat Input Rate (mmBtu/hr)
CO2 - CO2 Hourly Mass Rate (ton/hr)

Methodology Codes: NOXR - NOx Mass Calculated from NOx Emission Rate
EXP - Exempt
CEM - Continuous Emission Monitor
AD - Appendix D

Substitute Data Codes: SPTS - Standard Part 75 for Missing Data

Monitoring System / Analytical Components

Unit/Stack /Pipe Identifier	System					Component									
	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	BAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour	Hg Convert Indicator
U001	G10	GAS	P	05/01/2019 00		170	GFFM	COR		ENDRESS+HAUSER	PROMASS 83F 6"	N301CF16000	05/01/2019 00		
						175	GFFM	ORF		FLUIDIC TECHNIQUES	6" 300#	FAB-3206-1	05/01/2019 00		
						D01	DAHS			CISCO CEMS	CEDAR BREEZ75X	N/A	05/01/2019 00		
						PL1	PLC			ALLEN BRADLEY	CONTROLOGIX	N/A	05/01/2019 00		
	N10	NOX	P	09/01/2019 00		110	NOX	EXT	D	TELEDYNE	T200M	1012	09/01/2019 00		
						120	O2	EXT	D	TELEDYNE	T802M	128	09/01/2019 00		
						D01	DAHS			CISCO CEMS	CEDAR BREEZ75X	N/A	09/01/2019 00		
						PL1	PLC			ALLEN BRADLEY	CONTROLOGIX	N/A	09/01/2019 00		
						PR1	PRB	EXT		CISCO CEMS	EP750	10011081-1	09/01/2019 00		

System Types Descriptions:
GAS - Gas Fuel Flow
NOX - NOx Emission Rate

System Designations Descriptions:
P - Primary

Sample Acquisition Method (SAM):
ORF - Orifice
EXT - Dry Extractive
COR - Coriolis

Component Types Descriptions:
GFFM - Gas Fuel Flowmeter
DAHS - Data Acquisition and Handling System
PLC - Programmable Logic Controller
NOX - NOx Concentration
O2 - O2 Concentration
PRB - Probe

Monitoring System Fuel Flow

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
U001	G10	PNG	27375.6	HSCF	UMX	05/01/2019 00	

System Fuel Codes Descriptions: PNG - Pipeline Natural Gas
Units of Measure Descriptions: HSCF - Hundred Standard Cubic Feet / Hour
Source Codes Descriptions: UMX - Unit Maximum Rate

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dual Range Indicator	Begin Date/Hour	End Date/Hour
U001	NOX	110	Auto Ranging	Y	09/01/2019 00	
	O2	120	High Range		09/01/2019 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Emissions Formulas

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
U001	NOXR	11G	F-5		09/01/2019 00	
	NOX	11M	F-24A		09/01/2019 00	
	FGAS	12G	N-GAS		05/01/2019 00	
	HI	13G	F-20		05/01/2019 00	
	SO2	15G	D-5		09/01/2019 00	
	CO2	16G	G-4		09/01/2019 00	

Parameter Codes Descriptions: NOXR - NOx Emission Rate (lb/mmBtu)
NOX - NOx Hourly Mass Rate (lb/hr)
FGAS - Gas Hourly Flow Rate (hscf)
HI - Heat Input Rate (mmBtu/hr)
SO2 - SO2 Hourly Mass Rate (lb/hr)
CO2 - CO2 Hourly Mass Rate (ton/hr)

Formula Codes Descriptions: N-GAS - FGAS (net gas flow rate)

G-4 - CO2 (from HI, Fc)

F-5 - NOXR/SO2R (from NOX or SO2 dry, O2 dry, Fd)

F-24A - NOX (from NOX rate, HI)

F-20 - HI (same as D-6)

D-5 - SO2 (from gas SO2 emission rate, HI)

Span Values

Unit/Stack /Pipe Identifier	Comp Type	Scale	Method	MPC/ MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)		Flow Span Value (SCFH)		Begin Date/Hour	End Date/Hour
U001	NOX	H	TB	150.0		2.0	200.000	200.000	PPM	9.0					09/01/2019 00	
	NOX	L	PL			2.0	10.000	10.000	PPM	9.0					09/01/2019 00	
	O2	H					25.000	25.000	PCT						09/01/2019 00	

Component Types Descriptions: NOX - NOx Concentration

O2 - O2 Concentration

Span Method Codes Descriptions: TB - Table Defaults from Part 75 or 40 CFR Part 63, Subpart UUUUU, Appendix A

PL - Permit Limit for NOX MEC

Units of Measure Descriptions: PPM - Parts per Million

PCT - Percentage

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
U001	385	MW	381	241	High	Mid	Yes		05/01/2019 00	

Units of Measure Descriptions: MW - Megawatt

Monitoring Defaults

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
U001	NORX	1.7160	LBMMBTU	MD	NFS	A	DEF	09/01/2019 00	
	O2X	19.0000	PCT	DC	NFS	A	DEF	09/01/2019 00	

Parameter Codes Descriptions: O2X - Maximum O2 Concentration (pct)
NORX - Maximum NOx Emission Rate (lb/mmBtu)

Units of Measure Descriptions: PCT - Percentage
LBMMBTU - Pounds / mmBtu

Purpose Codes Descriptions: MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default
DC - Diluent Cap

Fuel Type Codes Descriptions: NFS - Non-Fuel Specific

Operating Conditions Descriptions: A - Any Hour

Source Codes Descriptions: DEF - Default Value from Part 75

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL):	57185
Monitoring Plan Location IDs:	U002
State:	NY
County:	Dutchess County
Latitude:	41.6762
Longitude:	-73.5806

Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
U002	Q - Quarterly	2019 QTR 3	

Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Cross Area Exit	Cross Area Flow	Material Code	Shape Code	Begin Date	End Date
U002		435	283	284		OTHER	ROUND	09/01/2019	

Unit Operation Information

Unit Identifier	Non-Load Based Ind	Commence Commercial Operation Date	Commence Operation Date	Boiler/Turbine Type			Max Heat Input		
				Code	Begin Date	End Date	Value (mmBtu)	Begin Date	End Date
U002	0	05/01/2019		CC	05/01/2019		2587.8	05/01/2019	

Unit Type Codes: CC - Combined cycle

Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
U002	ARP	P2	05/01/2019	
	CSNOX	A	05/01/2019	
	CSOSG2	A	05/01/2019	
	CSSO2G1	A	05/01/2019	

Unit Fuel

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
U002	PNG	P				05/01/2019	

Fuel Type Codes: PNG - Pipeline Natural Gas

Fuel Indicator Codes: P - Primary

Unit Controls

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
U002	NOX	DLNB	Y				
	NOX	SCR	Y				

Control Equipment Descriptions: SCR - Selective Catalytic Reduction

DLNB - Dry Low NOx Burners

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
U002	CO2	AD	SPTS		09/01/2019 00	
	HI	AD	SPTS		09/01/2019 00	
	NOX	NOXR			09/01/2019 00	
	NOXR	CEM	SPTS		09/01/2019 00	
	OP	EXP			09/01/2019 00	
	SO2	AD	SPTS		09/01/2019 00	

Parameter Codes:
SO2 - SO2 Hourly Mass Rate (lb/hr)
OP - Opacity
NOXR - NOx Emission Rate (lb/mmBtu)
NOX - NOx Hourly Mass Rate (lb/hr)
HI - Heat Input Rate (mmBtu/hr)
CO2 - CO2 Hourly Mass Rate (ton/hr)

Methodology Codes:
NOXR - NOx Mass Calculated from NOx Emission Rate
EXP - Exempt
CEM - Continuous Emission Monitor
AD - Appendix D

Substitute Data Codes:
SPTS - Standard Part 75 for Missing Data

Monitoring System / Analytical Components

Unit/Stack /Pipe Identifier	System					Component									
	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	BAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour	Hg Converter Indicator
U002	G20	GAS	P	05/01/2019 00		270	GFFM	COR		ENDRESS+HAUSER	PROMASS 83F 6"	N4012116000	05/01/2019 00		
						275	GFFM	ORF		FLUIDIC TECHNIQUES	LATER6" 300#	FAB-3206-2	05/01/2019 00		
						D01	DAHS			CISCO CEMS	CEDAR BREEZ75X	N/A	05/01/2019 00		
						PL2	PLC			ALLEN BRADLEY	CONTROLOGIX	N/A	05/01/2019 00		
	N20	NOX	P	09/01/2019 00		210	NOX	EXT	D	TELEDYNE	T200M	1013	09/01/2019 00		
						220	O2	EXT	D	TELEDYNE	T802M	129	09/01/2019 00		
						D01	DAHS			CISCO CEMS	CEDAR BREEZ75X	N/A	09/01/2019 00		
						PL2	PLC			ALLEN BRADLEY	CONTROLOGIX	N/A	09/01/2019 00		
						PR2	PRB	EXT		CISCO CEMS	EP750	10011081-2	09/01/2019 00		

System Types Descriptions:
GAS - Gas Fuel Flow
NOX - NOx Emission Rate

System Designations Descriptions:
P - Primary

Sample Acquisition Method (SAM):
ORF - Orifice
EXT - Dry Extractive
COR - Coriolis

Component Types Descriptions:
GFFM - Gas Fuel Flowmeter
DAHS - Data Acquisition and Handling System
PLC - Programmable Logic Controller
NOX - NOx Concentration
O2 - O2 Concentration
PRB - Probe

Monitoring System Fuel Flow

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
U002	G20	PNG	27375.6	HSCF	UMX	05/01/2019 00	

System Fuel Codes Descriptions: PNG - Pipeline Natural Gas

Units of Measure Descriptions: HSCF - Hundred Standard Cubic Feet / Hour

Source Codes Descriptions: UMX - Unit Maximum Rate

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dual Range Indicator	Begin Date/Hour	End Date/Hour
U002	NOX	210	Auto Ranging	Y	09/01/2019 00	
	O2	220	High Range		09/01/2019 00	

Component Types Descriptions: NOX - NOx Concentration

O2 - O2 Concentration

Emissions Formulas

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
U002	NOXR	21G	F-5		09/01/2019 00	
	NOX	21M	F-24A		09/01/2019 00	
	FGAS	22G	N-GAS	HSCF/HR (GAS) = (S#(G10-170)+S#(G10-175))	05/01/2019 00	
	HI	23G	F-20		05/01/2019 00	
	SO2	25G	D-5		09/01/2019 00	
	CO2	26G	G-4		09/01/2019 00	

Parameter Codes Descriptions: NOXR - NOx Emission Rate (lb/mmBtu)

NOX - NOx Hourly Mass Rate (lb/hr)

FGAS - Gas Hourly Flow Rate (hscf)

HI - Heat Input Rate (mmBtu/hr)

SO2 - SO2 Hourly Mass Rate (lb/hr)

CO2 - CO2 Hourly Mass Rate (ton/hr)

Formula Codes Descriptions: N-GAS - FGAS (net gas flow rate)
G-4 - CO2 (from HI, Fc)

F-5 - NOXR/SO2R (from NOX or SO2 dry, O2 dry, Fd)

F-24A - NOX (from NOX rate, HI)

F-20 - HI (same as D-6)

D-5 - SO2 (from gas SO2 emission rate, HI)

Span Values

Unit/Stack /Pipe Identifier	Comp Type	Scale	Method	MPC/ MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)	Flow Span Value (SCFH)	Begin Date/Hour	End Date/Hour
U002	NOX	H	TB	150.0	2.0	200.000	200.000	PPM	9.0				09/01/2019 00	
	NOX	L	PL		2.0	10.000	10.000	PPM	9.0				09/01/2019 00	
	O2	H				25.000	25.000	PCT					09/01/2019 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Span Method Codes Descriptions: TB - Table Defaults from Part 75 or 40 CFR Part 63, Subpart UUUUU, Appendix A
PL - Permit Limit for NOX MEC

Units of Measure Descriptions: PPM - Parts per Million
PCT - Percentage

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
U002	385	MW	381	241	High	Mid	Yes		05/01/2019 00	

Units of Measure Descriptions: MW - Megawatt

Monitoring Defaults

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
U002	NORX	1.7160	LBMMBTU	MD	NFS	A	DEF	09/01/2019 00	
	O2X	19.0000	PCT	DC	NFS	A	DEF	09/01/2019 00	

Parameter Codes Descriptions: O2X - Maximum O2 Concentration (pct)
NORX - Maximum NOx Emission Rate (lb/mmBtu)

Units of Measure Descriptions: PCT - Percentage
LBMMBTU - Pounds / mmBtu

Purpose Codes Descriptions: MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default
DC - Diluent Cap

Fuel Type Codes Descriptions: NFS - Non-Fuel Specific

Operating Conditions Descriptions: A - Any Hour

Source Codes Descriptions: DEF - Default Value from Part 75

Facility Name: Cricket Valley Energy Center

Facility Details

Facility ID (ORISPL):	57185
Monitoring Plan Location IDs:	U003
State:	NY
County:	Dutchess County
Latitude:	41.6762
Longitude:	-73.5806

Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
U003	Q - Quarterly	2019 QTR 3	

Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Cross Area Exit	Cross Area Flow	Material Code	Shape Code	Begin Date	End Date
U003		435	283	284		OTHER	ROUND	09/01/2019	

Unit Operation Information

Unit	Non-Load	Commence Commercial	Commence	Boiler/Turbine Type			Max Heat Input		
Identifier	Based Ind	Operation Date	Operation Date	Code	Begin Date	End Date	Value (mmBtu)	Begin Date	End Date
U003	0	05/01/2019		CC	05/01/2019		2587.8	05/01/2019	

Unit Type Codes: CC - Combined cycle

Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
U003	ARP	P2	05/01/2019	
	CSNOX	A	05/01/2019	
	CSOSG2	A	05/01/2019	
	CSSO2G1	A	05/01/2019	

Unit Fuel

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
U003	PNG	P				05/01/2019	

Fuel Type Codes: PNG - Pipeline Natural Gas

Fuel Indicator Codes: P - Primary

Unit Controls

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
U003	NOX	DLNB	Y				
	NOX	SCR	Y				

Control Equipment Descriptions: SCR - Selective Catalytic Reduction

DLNB - Dry Low NOx Burners

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
U003	CO2	AD	SPTS		09/01/2019 00	
	HI	AD	SPTS		09/01/2019 00	
	NOX	NOXR			09/01/2019 00	
	NOXR	CEM	SPTS		09/01/2019 00	
	OP	EXP			09/01/2019 00	
	SO2	AD	SPTS		09/01/2019 00	

Parameter Codes: SO2 - SO2 Hourly Mass Rate (lb/hr)
OP - Opacity
NOXR - NOx Emission Rate (lb/mmBtu)
NOX - NOx Hourly Mass Rate (lb/hr)
HI - Heat Input Rate (mmBtu/hr)
CO2 - CO2 Hourly Mass Rate (ton/hr)

Methodology Codes: NOXR - NOx Mass Calculated from NOx Emission Rate
EXP - Exempt
CEM - Continuous Emission Monitor
AD - Appendix D

Substitute Data Codes: SPTS - Standard Part 75 for Missing Data

Monitoring System / Analytical Components

Unit/Stack /Pipe Identifier	System					Component									
	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	BAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour	Hg Converter Indicator
U003	G30	GAS	P	05/01/2019 00		370	GFFM	COR		ENDRESS+HAUSER	PROMASS 83F 6"	N600E816000	05/01/2019 00		
						375	GFFM	ORF		FLUIDIC TECHNIQUES	6" 300#	FAB-3206-3	05/01/2019 00		
						D01	DAHS			CISCO CEMS	CEDAR BREEZ75X	N/A	05/01/2019 00		
						PL3	PLC			ALLEN BRADLEY	CONTROLOGIX	N/A	05/01/2019 00		
	N30	NOX	P	09/01/2019 00		310	NOX	EXT	D	TELEDYNE	T200M	1014	09/01/2019 00		
						320	O2	EXT	D	TELEDYNE	T802M	151	09/01/2019 00		
						D01	DAHS			CISCO CEMS	CEDAR BREEZ75X	N/A	09/01/2019 00		
						PL3	PLC			ALLEN BRADLEY	CONTROLOGIX	N/A	09/01/2019 00		
						PR3	PRB	EXT		CISCO CEMS	EP750	10011081-3	09/01/2019 00		

System Types Descriptions:
GAS - Gas Fuel Flow
NOX - NOx Emission Rate

System Designations Descriptions:
P - Primary

Sample Acquisition Method (SAM):
ORF - Orifice
EXT - Dry Extractive
COR - Coriolis

Component Types Descriptions:
GFFM - Gas Fuel Flowmeter
DAHS - Data Acquisition and Handling System
PLC - Programmable Logic Controller
NOX - NOx Concentration
O2 - O2 Concentration
PRB - Probe

Monitoring System Fuel Flow

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
U003	G30	PNG	27375.6	HSCF	UMX	05/01/2019 00	

System Fuel Codes Descriptions: PNG - Pipeline Natural Gas

Units of Measure Descriptions: HSCF - Hundred Standard Cubic Feet / Hour

Source Codes Descriptions: UMX - Unit Maximum Rate

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dual Range Indicator	Begin Date/Hour	End Date/Hour
U003	NOX	310	Auto Ranging	Y	09/01/2019 00	
	O2	320	High Range		09/01/2019 00	

Component Types Descriptions: NOX - NOx Concentration

O2 - O2 Concentration

Emissions Formulas

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
U003	NOXR	31G	F-5		09/01/2019 00	
	NOX	31M	F-24A		09/01/2019 00	
	FGAS	32G	N-GAS	HSCF/HR (GAS) = (S#(G10-170)+S#(G10-175))	05/01/2019 00	
	HI	33G	F-20		05/01/2019 00	
	SO2	35G	D-5		09/01/2019 00	
	CO2	36G	G-4		09/01/2019 00	

Parameter Codes Descriptions: NOXR - NOx Emission Rate (lb/mmBtu)

NOX - NOx Hourly Mass Rate (lb/hr)

FGAS - Gas Hourly Flow Rate (hscf)

HI - Heat Input Rate (mmBtu/hr)

SO2 - SO2 Hourly Mass Rate (lb/hr)

CO2 - CO2 Hourly Mass Rate (ton/hr)

Formula Codes Descriptions: N-GAS - FGAS (net gas flow rate)
G-4 - CO2 (from HI, Fc)

F-5 - NOXR/SO2R (from NOX or SO2 dry, O2 dry, Fd)

F-24A - NOX (from NOX rate, HI)

F-20 - HI (same as D-6)

D-5 - SO2 (from gas SO2 emission rate, HI)

Span Values

Unit/Stack /Pipe Identifier	Comp Type	Scale	Method	MPC/ MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)	Flow Span Value (SCFH)	Begin Date/Hour	End Date/Hour
U003	NOX	H	TB	150.0	2.0	200.000	200.000	PPM	9.0				09/01/2019 00	
	NOX	L	PL		2.0	10.000	10.000	PPM	9.0				09/01/2019 00	
	O2	H				25.000	25.000	PCT					09/01/2019 00	

Component Types Descriptions: NOX - NOx Concentration
O2 - O2 Concentration

Span Method Codes Descriptions: TB - Table Defaults from Part 75 or 40 CFR Part 63, Subpart UUUUU, Appendix A
PL - Permit Limit for NOX MEC

Units of Measure Descriptions: PPM - Parts per Million
PCT - Percentage

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
U003	385	MW	381	284	High	Mid	Yes		05/01/2019 00	

Units of Measure Descriptions: MW - Megawatt

Monitoring Defaults

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
U003	NORX	1.7160	LBMMBTU	MD	NFS	A	DEF	09/01/2019 00	
	O2X	19.0000	PCT	DC	NFS	A	DEF	09/01/2019 00	

Parameter Codes Descriptions: O2X - Maximum O2 Concentration (pct)
NORX - Maximum NOx Emission Rate (lb/mmBtu)

Units of Measure Descriptions: PCT - Percentage
LBMMBTU - Pounds / mmBtu

Purpose Codes Descriptions: MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default
DC - Diluent Cap

Fuel Type Codes Descriptions: NFS - Non-Fuel Specific


Operating Conditions Descriptions: A - Any Hour

Source Codes Descriptions: DEF - Default Value from Part 75

PART 2

- **SCHEMATIC DIAGRAMS / CEMS SAMPLE LOCATION**
- **DATA FLOW DIAGRAM**

CRICKET VALLEY ENERGY CENTER
ORIS CODE: 57185
UNIT U-00001
SCHEMATIC DIAGRAM / CEMS SAMPLE LOCATION




MONITOR LOCATION INFORMATION
A –STACK HEIGHT ABOVE GRADE – 282.5 FEET
B –STACK INSIDE DIAMETER AT TEST PORT – 19.0 FEET
C - INSIDE CROSS-SECTIONAL AREA AT TEST PORT –284 FT^2
D1 - CEMS SAMPLE PROBE ELEVATION
1. ABOVE GRADE – 266.5 FEET
2. ABOVE LAST DISTURBANCE
    A. FEET – 121.4
    B. STACK DIAMETERS – 6.39
3. PRIOR TO STACK EXIT
    A. FEET – 16.0
    B. STACK DIAMETERS – 0.8

D2 - EPA TEST PORT ELEVATION
1. ABOVE GRADE – 267.0 FEET
2. ABOVE LAST DISTURBANCE
    A. FEET – 121.9
    B. STACK DIAMETERS – 6.41
3. PRIOR TO STACK EXIT
    A. FEET – 15.5
    B. STACK DIAMETERS – 19.0

E –INSIDE CROSS-SECTIONAL AREA AT FLUE EXIT – 284 FT^2
F - STACK BASE ELEVATION – 435 FEET ABOVE MEAN SEA LEVEL

CRICKET VALLEY ENERGY CENTER
ORIS CODE: 57185
UNIT U-00002

SCHEMATIC DIAGRAM / CEMS SAMPLE LOCATION




MONITOR LOCATION INFORMATION
A –STACK HEIGHT ABOVE GRADE – 282.5 FEET
B –STACK INSIDE DIAMETER AT TEST PORT – 19.0 FEET
C - INSIDE CROSS-SECTIONAL AREA AT TEST PORT –284 FT^2
D1 - CEMS SAMPLE PROBE ELEVATION
1. ABOVE GRADE – 266.5 FEET
2. ABOVE LAST DISTURBANCE
    A. FEET – 121.4
    B. STACK DIAMETERS – 6.39
3. PRIOR TO STACK EXIT
    A. FEET – 16.0
    B. STACK DIAMETERS – 0.8

D2 - EPA TEST PORT ELEVATION
1. ABOVE GRADE – 267.0 FEET
2. ABOVE LAST DISTURBANCE
    A. FEET – 121.9
    B. STACK DIAMETERS – 6.41
3. PRIOR TO STACK EXIT
    A. FEET – 15.5
    B. STACK DIAMETERS – 19.0

E –INSIDE CROSS-SECTIONAL AREA AT FLUE EXIT – 284 FT^2
F - STACK BASE ELEVATION – 435 FEET ABOVE MEAN SEA LEVEL

CRICKET VALLEY ENERGY CENTER
ORIS CODE: 57185
UNIT U-00003

SCHEMATIC DIAGRAM / CEMS SAMPLE LOCATION




MONITOR LOCATION INFORMATION
A –STACK HEIGHT ABOVE GRADE – 282.5 FEET
B –STACK INSIDE DIAMETER AT TEST PORT – 19.0 FEET
C - INSIDE CROSS-SECTIONAL AREA AT TEST PORT –284 FT^2
D1 - CEMS SAMPLE PROBE ELEVATION
1. ABOVE GRADE – 266.5 FEET
2. ABOVE LAST DISTURBANCE
    A. FEET – 121.4
    B. STACK DIAMETERS – 6.39
3. PRIOR TO STACK EXIT
    A. FEET – 16.0
    B. STACK DIAMETERS – 0.8

D2 - EPA TEST PORT ELEVATION
1. ABOVE GRADE – 267.0 FEET
2. ABOVE LAST DISTURBANCE
    A. FEET – 121.9
    B. STACK DIAMETERS – 6.41
3. PRIOR TO STACK EXIT
    A. FEET – 15.5
    B. STACK DIAMETERS – 19.0

E –INSIDE CROSS-SECTIONAL AREA AT FLUE EXIT – 284 FT^2
F - STACK BASE ELEVATION – 435 FEET ABOVE MEAN SEA LEVEL

CRICKET VALLEY ENERGY CENTER
ORIS CODE: 57185

DATA FLOW DIAGRAM



- PLC
  - COLLECTS NO_X AND O_2 READINGS
  - CONTROLS CEMS FUNCTIONS (i.e., CALIBRATION)
  - COLLECTS FUEL FLOW AND MW SIGNALS FROM PLANT
  - TRANSMITS DATA TO DAHS VIA DATA ETHERNET

- DAHS COMPUTER:
  - CALCULATES 1 HOUR DATABASE
  - PERFORMS MISSING DATA ROUTINES
  - LOGS CALIBRATIONS
  - CREATES XML FILES
  - PERFORMS MASS EMISSIONS CALCULATIONS
  - CALCULATES HEAT INPUT BASED ON FUEL FLOW AND GCV

- PERIPHERALS
  - PRINTER
  - EXTERNAL HARD DRIVE FOR DATA BACKUP

ATTACHMENT 1

CERTIFICATION TEST PROTOCOL

ATTACHMENT 2

FUEL FLOWMETER DOCUMENTS

Combustion Turbine Fuel Meters

Endress+Hauser

People for Process Automation

Standard Density Calibration with Adjustment

31128647-4374500-5130590

PROMASS 83 F 6"
Transmitter/Sensor


N301CF16000
Serial N°

FCP-7.1.F
Calibration rig

C0 = -2138.5 C1 = 1.8178E+8
Density coefficient

C2 = -87071 C3 = 8543.6
Density coefficient

Medium	Temp. [°F]	ρ target [kg/m³]	ρ meas. [kg/m³]	Δρ [kg/m³]	Freq. [Hz]
Air	70.1	1.20	1.20	0.00	290.1
Water	67.3	999.07	999.07	0.00	239.7
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–



Endress+Hauser Flowtec operates ISO/IEC 17025 accredited calibration facilities in Reinach (CH), Cernay (FR), Greenwood (USA), Aurangabad (IN), Suzhou (CN) and Itatiba (BR).

Scott Newcomer

03-14-2018
Date of calibration

S. Newcomer
Operator

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Certified acc. to
ISO 9001, Reg.-N° 030502.2
ISO 14001, Reg.-N° EMS561046

Endress+Hauser
People for Process Automation

Certificate

Flow Calibration with Adjustment

30427954

American Association for Laboratory Accreditation, Cert. No 1897.01

Calibration laboratory accredited according to ISO/IEC 17025:2005


3800368764 Purchase order number	FCP-7.1.F / gravimetric Calibration rig/Method
CORETECH INDUSTRIAL CORPORATION Customer	4776.682 lb/min (≙ 100%) Calibrated full scale
US-3005947899-10 / Endress+Hauser Flowtec Order N°/Manufacturer	Service interface Calibrated output
PROMASS 83 F 6" Transmitter/Sensor	0.90972 Calibration factor
N301CF16000 / N301CF16000 Serial N°	-35 Zero point
Manufacture for GE, Supplier:Core Tech Tag N°	66.9 °F ±0.12 °F Water temperature
New Condition	0.048 % Expanded uncertainty of measurement

Flow [%]	Flow [lb/min]	Duration [s]	m target [lb]	m meas. [lb]	Δ o.r.* [%]	Outp.** [mA]
20.0	956.801	60.3	961.151	961.091	-0.006	7.20
35.5	1696.51	35.3	997.569	997.711	0.014	9.68
49.6	2367.42	30.3	1194.72	1194.68	-0.003	11.93
75.2	3592.07	30.3	1813.13	1812.86	-0.015	16.03
99.0	4727.02	30.3	2385.52	2385.44	-0.003	19.83
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–

*o.r.: of reading

**Calculated value (4 - 20 mA)

Measured error % o.r.



For detailed data concerning output specifications of the unit under test, see Technical Information (TI), chapter Performance characteristics.

Calibration, traceable to NIST, has been completed on the instruments used in the equipment calibration process (see attached listing).

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approx. 95%. The expanded uncertainty of measurement includes uncertainty components of the reference, the calibration method, the environment and of the device under test. A typical value is used for the uncertainty component of the device

Scott Newcomer

03-14-2018
Date of calibration

S. Newcomer
Operator

This certificate shall not be published or reproduced other than in full, except with the prior written approval of the issuing laboratory.

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Certificate Addendum

Endress+Hauser
People for Process Automation

CORETECH INDUSTRIAL CORPORATION	12020 - BALLSTON SPA
Customer name	Customer address
Endress+Hauser Flowtec, Div. USA	6"
Manufacturer	Nominal diameter
US-3005947899-10 / 83F1F-CP77/0	FCP-7.1.F
Customer order N°/Order code	Calibration rig
N301CF16000 / N301CF16000	30427954
Serial N°	Record N°
New	03-14-2018
Condition	Calibration date
-	0.048 %
Customer specified calibration due date	Uncertainty of measurement (o.r.%)
PRD-TI-024	
Calibration work procedure	

Instruments used in the calibration rig:

Asset N°	Manufacturer	Model	Description	NIST/Cert N°	Cal. date	Cal. due date
F10795	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008066	05-19-2017	06-01-2018
F10796	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008067	05-19-2017	06-01-2018
F10797	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Outlet)	008068	05-19-2017	06-01-2018
F10798	Endress+Hauser	TST434-K1B3A0	RTD - Ambient	008078	05-19-2017	06-01-2018
F10799	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008069	05-19-2017	06-01-2018
F10800	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008070	05-19-2017	06-01-2018
F10801	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008072	05-19-2017	06-01-2018
F10802	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008073	05-19-2017	06-01-2018
F10803	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008075	05-19-2017	06-01-2018
F10804	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008074	05-19-2017	06-01-2018
F10806	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008076	05-19-2017	06-01-2018
F10807	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008077	05-19-2017	06-01-2018
F10808	Endress+Hauser	-	Large Scale Diverter	008062	05-19-2017	06-01-2018
F10809	Beckhoff	KL1501	Counter/Timer	008064	05-19-2017	06-01-2018
F10810	Beckhoff	KL1501	Counter/Timer	008063	05-19-2017	06-01-2018
F10811	Endress+Hauser	-	Small Scale Diverter	008061	05-19-2017	06-01-2018
F10813	HBM	DMP 40	Digital Scale Amplifier and scales	008060	05-19-2017	06-01-2018
-	-	-	-	-	-	-

Calibration traceable to NIST has been completed on the instrument listed above by using known working procedures and standards certified by the manufacturers and/or secondary testing laboratories to traceable to NIST. This calibration has been completed using standards having a minimum accuracy of at least four times greater than the instrument listed above. This calibration was conducted in accordance with ISO 17025:2005 and ANSI/NCSL Z540-1. Reported uncertainties represent expanded uncertainties expressed at approximately 95% confidence level using a coverage factor of k=2.

Debbie Carver

ilac-MRA A2LA ACCREDITED

Certified according to ISO 17025:2005
Certification N° 1897.01

Debbie Carver
Calibration supervisor

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Endress+Hauser

People for Process Automation

Abnahmeprüfzeugnis nach EN 10204 – 3.1
Inspection certificate acc. to EN 10204 – 3.1

Zeugnis-Nr./Certificate No. US – 3005947899

Es wird bescheinigt, dass die gelieferten Erzeugnisse den Vereinbarungen bei der Bestellung entsprechen. Darüber hinaus wird bescheinigt, dass bei der Herstellung der nachstehend aufgeführten Erzeugnisse die vorgeschriebenen Prüfungen und/oder die zusätzlich aufgeführten Prüfungen nach den bestehenden Prüfvorgaben durchgeführt und die erforderlichen Freigaben erteilt wurden. Die unten aufgeführten Prüfungen wurden durch eine dazu autorisierte Person durchgeführt.

It is certified that the products supplied are in compliance with the requirements of the order. Furthermore, it is confirmed that during the manufacturing of the subsequently listed products the specified inspections and/or the additionally ordered tests have been performed according to the valid procedures and the necessary releases have been given. The subsequently listed inspections have been performed by especially authorized personnel.

Kunde/Customer	:	CORETECH INDUSTRIAL CORPORATION US – 12020 – BALLSTON SPA
Kunden Bestell-Nr./Customer Order No.	:	111063
E+H-Auftrags-Nr./E+H Order No.	:	3800368764

Pos./Item	Menge/Qty.	Produktbezeichnung/Description
10	1	83F1F-CP77/0 PROMASS 83 F 6" S/N.: N301CF16000 Tag-Nr.: Manufacture for GE, Supplier:Core Tech

Abnahmeprüfzeugnisse nach EN 10204 – 3.1/Inspection Certificates acc. to EN 10204 – 3.1:
Messrohr/Measuring tube: 51588, Franz Iten AG
Verteilerstück/Flow splitter: 270138, Bächler Feintech AG
Prozessanschluss/Process connection: 16CT12819, Jiangyin Unique Flange Manufacturing Co., Ltd.

Datum/Date 03-15-2018

Endress+Hauser Flowtec, Division USA
Greenwood, IN 46143 USA

Chris Brown

Abnahmebeauftragter
Inspector

Dieses Dokument wurde elektronisch nach EN 10204 erstellt und ist ohne Unterschrift gültig.
This document was generated electronically acc. to EN 10204 and is valid without signature.

Endress+Hauser

People for Process Automation

Parameter Setting

30409322-4374500

3800368764	PROMASS 83 F
Purchase order number	Transmitter/Sensor
3005947899-10 / Endress+Hauser Flowtec	6"
Order N°/Manufacturer	Nominal diameter
83F1F-CP77/0	Manufacture for GE, Supplier:Core Tech
Order code	Tag N°
N301CF16000	
Serial N°	

The below parameters are set according to your order.
Please refer to the Operating Manual for any parameters not mentioned.

Communication type	MODBUS RS485
Device software	V3.06.10
Device address	247
<u>Current output 1</u>	
Current span	4-20 mA US
Value 0/4 mA	0 lb/min
Value 20 mA	4800 lb/min
Time constant	1 s
Failsafe mode	Minimum current
<u>Pulse output 1</u>	
Pulse value	200 lb
Pulse width	100 ms
Output signal	passive/positive
Failsafe mode	Fallback value

03-13-2018
Date

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Endress+Hauser

People for Process Automation


Standard Density Calibration with Adjustment

31129417-4401946-5132403

PROMASS 83 F 6"	C0 = -2134.6 C1 = 1.8192E+8
Transmitter/Sensor	Density coefficient
N4012116000	C2 = -87141 C3 = 8550.4
Serial N°	Density coefficient
FCP-7.1.F	
Calibration rig	

Medium	Temp. [°F]	ρ target [kg/m³]	ρ meas. [kg/m³]	Δρ [kg/m³]	Freq. [Hz]
Air	70.3	1.20	1.20	0.00	290.5
Water	68.4	998.92	998.92	0.00	239.9
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–
–	–	–	–	–	–

Measuring precision · Tolerance limit - - - - -



Endress+Hauser Flowtec operates ISO/IEC 17025 accredited calibration facilities in Reinach (CH), Cernay (FR), Greenwood (USA), Aurangabad (IN), Suzhou (CN) and Itatiba (BR).

Scott Newcomer

04-09-2018
Date of calibration

S. Newcomer
Operator

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Certified acc. to
ISO 9001, Reg.-N° 030502.2
ISO 14001, Reg.-N° EMS561046

Endress+Hauser
People for Process Automation

Certificate

Flow Calibration with Adjustment

30430257

American Association for Laboratory Accreditation, Cert. No 1897.01

Calibration laboratory accredited according to ISO/IEC 17025:2005


3800374688 Purchase order number	FCP-7.1.F / gravimetric Calibration rig/Method
CORETECH INDUSTRIAL CORPORATION Customer	4776.682 lb/min (≙ 100%) Calibrated full scale
US-3005965821-10 / Endress+Hauser Flowtec Order N°/Manufacturer	Service interface Calibrated output
PROMASS 83 F 6" Transmitter/Sensor	0.90798 Calibration factor
N4012116000 / N4012116000 Serial N°	17 Zero point
125T3664G001, GE PO# 610575460/2 Tag N°	68.4 °F ±0.11 °F Water temperature
New Condition	0.048 % Expanded uncertainty of measurement

Flow [%]	Flow [lb/min]	Duration [s]	m target [lb]	m meas. [lb]	Δ o.r.* [%]	Outp.** [mA]
20.0	953.135	60.3	957.461	957.767	0.032	7.19
35.6	1701.59	35.3	1000.63	1000.63	0.000	9.70
50.2	2398.77	30.3	1210.39	1210.52	0.011	12.04
75.2	3592.23	30.3	1812.98	1813.10	0.007	16.03
99.3	4742.11	30.3	2393.59	2393.54	-0.002	19.88
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–
–	–	–	–	–	–	–

*o.r.: of reading

**Calculated value (4 - 20 mA)

Measured error % o.r.



For detailed data concerning output specifications of the unit under test, see Technical Information (TI), chapter Performance characteristics.

Calibration, traceable to NIST, has been completed on the instruments used in the equipment calibration process (see attached listing).

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approx. 95%. The expanded uncertainty of measurement includes uncertainty components of the reference, the calibration method, the environment and of the device under test. A typical value is used for the uncertainty component of the device

Scott Newcomer

04-09-2018
Date of calibration

S. Newcomer
Operator

This certificate shall not be published or reproduced other than in full, except with the prior written approval of the issuing laboratory.

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Certificate Addendum

Endress+Hauser
People for Process Automation

CORETECH INDUSTRIAL CORPORATION	12020 - BALLSTON SPA
Customer name	Customer address
Endress+Hauser Flowtec, Div. USA	6"
Manufacturer	Nominal diameter
US-3005965821-10 / 83F1F-CP77/0	FCP-7.1.F
Customer order N°/Order code	Calibration rig
N4012116000 / N4012116000	30430257
Serial N°	Record N°
New	04-09-2018
Condition	Calibration date
-	0.048 %
Customer specified calibration due date	Uncertainty of measurement (o.r.%)
PRD-TI-024	
Calibration work procedure	

Instruments used in the calibration rig:

Asset N°	Manufacturer	Model	Description	NIST/Cert N°	Cal. date	Cal. due date
F10795	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008066	05-19-2017	06-01-2018
F10796	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Inlet)	008067	05-19-2017	06-01-2018
F10797	Endress+Hauser	PMC71-AAA1P1	Pressure Gauge (Measure Outlet)	008068	05-19-2017	06-01-2018
F10798	Endress+Hauser	TST434-K1B3A0	RTD - Ambient	008078	05-19-2017	06-01-2018
F10799	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008069	05-19-2017	06-01-2018
F10800	Endress+Hauser	TST310-A3A1A3	RTD - Measuring Section	008070	05-19-2017	06-01-2018
F10801	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008072	05-19-2017	06-01-2018
F10802	Endress+Hauser	TST310-A3A1A3	RTD - 4000 kg Tank	008073	05-19-2017	06-01-2018
F10803	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008075	05-19-2017	06-01-2018
F10804	Endress+Hauser	TST310-A3A1A3	RTD - Master Tower	008074	05-19-2017	06-01-2018
F10806	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008076	05-19-2017	06-01-2018
F10807	Endress+Hauser	TST310-A3A1A3	RTD - 400 kg Tank	008077	05-19-2017	06-01-2018
F10808	Endress+Hauser	-	Large Scale Diverter	008062	05-19-2017	06-01-2018
F10809	Beckhoff	KL1501	Counter/Timer	008064	05-19-2017	06-01-2018
F10810	Beckhoff	KL1501	Counter/Timer	008063	05-19-2017	06-01-2018
F10811	Endress+Hauser	-	Small Scale Diverter	008061	05-19-2017	06-01-2018
F10813	HBM	DMP 40	Digital Scale Amplifier and scales	008748	03-16-2018	06-01-2018
-	-	-	-	-	-	-

Calibration traceable to NIST has been completed on the instrument listed above by using known working procedures and standards certified by the manufacturers and/or secondary testing laboratories to traceable to NIST. This calibration has been completed using standards having a minimum accuracy of at least four times greater than the instrument listed above. This calibration was conducted in accordance with ISO 17025:2005 and ANSI/NCSL Z540-1. Reported uncertainties represent expanded uncertainties expressed at approximately 95% confidence level using a coverage factor of k=2.

Debbie Carver

ilac-MRA A2LA ACCREDITED

Certified according to ISO 17025:2005
Certification N° 1897.01

Debbie Carver
Calibration supervisor

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Endress+Hauser

People for Process Automation

Abnahmeprüfzeugnis nach EN 10204 – 3.1
Inspection certificate acc. to EN 10204 – 3.1

Zeugnis-Nr./Certificate No. US – 3005965821

Es wird bescheinigt, dass die gelieferten Erzeugnisse den Vereinbarungen bei der Bestellung entsprechen. Darüber hinaus wird bescheinigt, dass bei der Herstellung der nachstehend aufgeführten Erzeugnisse die vorgeschriebenen Prüfungen und/oder die zusätzlich aufgeführten Prüfungen nach den bestehenden Prüfvorgaben durchgeführt und die erforderlichen Freigaben erteilt wurden. Die unten aufgeführten Prüfungen wurden durch eine dazu autorisierte Person durchgeführt.

It is certified that the products supplied are in compliance with the requirements of the order. Furthermore, it is confirmed that during the manufacturing of the subsequently listed products the specified inspections and/or the additionally ordered tests have been performed according to the valid procedures and the necessary releases have been given. The subsequently listed inspections have been performed by especially authorized personnel.

Kunde/Customer	:	CORETECH INDUSTRIAL CORPORATION US – 12020 – BALLSTON SPA
Kunden Bestell-Nr./Customer Order No.	:	111611
E+H-Auftrags-Nr./E+H Order No.	:	3800374688

Pos./Item	Menge/Qty.	Produktbezeichnung/Description
10	1	83F1F-CP77/0 PROMASS 83 F 6" S/N.: N4012116000 Tag-Nr.: 125T3664G001, GE PO# 610575460/2

Abnahmeprüfzeugnisse nach EN 10204 – 3.1/Inspection Certificates acc. to EN 10204 – 3.1:
Messrohr/Measuring tube: 51588, Franz Iten AG
Verteilerstück/Flow splitter: 272967, Bächler Feintech AG
Prozessanschluss/Process connection: 16CT12819, Jiangyin Unique Flange Manufacturing Co., Ltd.

Datum/Date 04-10-2018

Endress+Hauser Flowtec, Division USA
Greenwood, IN 46143 USA

Chris Brown

Abnahmebeauftragter
Inspector

Dieses Dokument wurde elektronisch nach EN 10204 erstellt und ist ohne Unterschrift gültig.
This document was generated electronically acc. to EN 10204 and is valid without signature.

Endress+Hauser

People for Process Automation

Parameter Setting

30411757-4401946

3800374688	PROMASS 83 F
Purchase order number	Transmitter/Sensor
3005965821-10 / Endress+Hauser Flowtec	6"
Order N°/Manufacturer	Nominal diameter
83F1F-CP77/0	125T3664G001, GE PO# 610575460/2
Order code	Tag N°
N4012116000	
Serial N°	

The below parameters are set according to your order.
Please refer to the Operating Manual for any parameters not mentioned.

Communication type	MODBUS RS485
Device software	V3.06.10
Device address	247
Current output 1	
Current span	4-20 mA US
Value 0/4 mA	0 lb/min
Value 20 mA	4800 lb/min
Time constant	1 s
Failsafe mode	Minimum current
Pulse output 1	
Pulse value	200 lb
Pulse width	100 ms
Output signal	passive/positive
Failsafe mode	Fallback value

04-09-2018

Date

Endress+Hauser Flowtec, Division USA
2330 Endress Place
Greenwood, IN 46143

Duct Burner Fuel Meters

CALIBRATION OF:

(3) 6” 300# AGA METER RUNS

TAG NUMBER: B10255-341-01

SERIAL NO.: FAB-3206-1
SERIAL NO.: FAB-3206-2
SERIAL NO.: FAB-3206-3

FOR:

FLUIDIC TECHNIQUES, LP

PURCHASE ORDER NUMBER: 60160, JOB FAB-3206

JANUARY 2018 - REPORT NUMBER: 2181FLT006-R1

CERTIFIED BY

Philip S. Stacy

ALDEN RESEARCH LABORATORY, INC.

30 SHREWSBURY STREET

HOLDEN, MASSACHUSETTS 01520

All Client supplied information and calibration results are considered proprietary and confidential to the Client. If a third party is a witness during calibrations or if the Client requests transmittal of data to a third party, Alden considers that the Client has waived confidentiality for the Witness.

In the event the Client distributes any report issued by Alden outside its own organization, such report shall be used in its entirety, unless Alden approves a summary or abridgment for distribution.

No advertising or publicity containing any reference to Alden or any employee, either directly or by implication, shall be made use of by Client without Alden's written approval.

INTRODUCTION

Meters referenced within this report were calibrated at Alden Research Laboratory, Inc. (Alden). Alden's standard test procedures in QMSM-01 Revision 8 were used for testing. Flow meter performance is presented in both tabular and graphical format.

FLOW ELEMENT INSTALLATION

Each meter under test (MUT) was installed in one of the four test lines in the Allen High Reynolds Number Facility, which is shown in plan view in Figure 1. One or two 300 horsepower centrifugal pumps, which are used singularly or in parallel, provide a maximum head of about 130 ft at a flow of about 44 ft^3/second in Line 2. A separate pump provides a maximum head of about 300 ft at a flow of about 12 ft^3/s in Lines 3 and 4. Water is provided from a heated 180,000 gallon sump under the test floor. The Gravimetric Method was used to measure flow.

The detailed piping arrangement, immediately upstream and downstream of the flow element, including all significant fittings and pipe lengths, is shown in the included figures. Careful attention was given to align the flow element with the test line piping, and to assure no gaskets between flanged sections protruded into the flow. Vents were provided at critical locations of the test line to purge the system of air.

TEST PROCEDURE

After checking the installation, water was introduced into the system to equalize line and primary element temperature to water temperature. The downstream control valve was then closed and vent valves in the test line were opened to remove air from the system.

Prior to the test run, the control valve was set to produce the desired flow, while the flow was directed to waste. Sufficient time was allowed to stabilize both the flow and the instrument readings, after which the weigh tank discharge valve was closed and the weigh tank scale indicator and the electric timer were both zeroed. To begin the test run, flow was diverted into the weigh tank, which automatically started the timer.

At the start of the water collection a computer based data acquisition system was activated to read the meter output, such that the meter output was averaged while the weigh tank was filling. At the end of the run, flow was diverted away from the weigh tank and the timer and data acquisition system were stopped to terminate the test run. The weight of water in the tank, elapsed time, water temperature, and

average meter output were recorded on a data sheet. The data were entered into the computer to determine the flow and the results were plotted so that each test run was evaluated before the next run began. The control valve was then adjusted to the next flow and the procedure repeated.

FLOW MEASUREMENT METHOD

Flow was measured by the gravimetric method using a tank mounted on scales having capacities of 1,000, 10,000 and 100,000 pounds with resolution of 0.1, 0.2 and 1.0 pound, respectively. Alden's flow meter calibrations using the gravimetric flow measurement method comply with ASME/ANSI MFC-9M-1988 Measurement of Liquid Flow in Closed Conduits by Weighing Method. Water passing through the flow element was diverted into the tank with a hydraulically operated knife edge passing through a rectangular jet produced by a diverter head box. A Hewlett-Packard 10 MHz Frequency Counter with a resolution 0.001 sec was started upon flow diversion into the tank by an optical switch, which is positioned at the center of the jet. The timer was stopped upon flow diversion back to waste and the elapsed diversion time was recorded. An RTD thermometer measured water temperature to allow calculation of water density. Volumetric flow was calculated by Equation (1).

$$q_a = \frac{W}{T\rho_w B_c} \tag{1}$$

where q_a = actual flow, ft^3/sec

W = mass of water collected, lb_m

T = time, sec

ρ_w = water density, lb_m/ft^3

B_c = buoyancy correction, $1-\rho_a/\rho_w$

The buoyancy correction includes air density calculated by perfect gas laws with the standard barometric pressure, a relative humidity of 75%, and measured air temperature. The weigh tank is periodically calibrated to full scale using 10,000 lbm of cast iron weights, whose calibration is traceable to NIST. Flow calculations are computerized to assure consistency. Weigh tank calibration data and water density as a function of temperature, are stored on disk file. Data were recorded manually and on disk file for later review and reporting.

DISCHARGE COEFFICIENT CALCULATIONS

If applicable, the MUT discharge coefficient, C, is defined by Equation (2) and plotted versus pipe or throat Reynolds number. Calculations of the discharge coefficient of differential producing flow meters are in accordance with ASME/ANSI MFC-3M-2004 Measurement of Fluid Flow in Pipes Using Orifice, Nozzle and Venturi, and ASME 19.5-2004 Flow Measurement. The discharge coefficient relates the theoretical flow to the actual flow.

$$C = \frac{q_a}{q_{th}} = \frac{q_a}{F_a K_M \sqrt{\Delta h}} \quad (2)$$

where C = discharge coefficient, dimensionless

q_{th} = theoretical flow, ft^3/sec

F_a = thermal expansion factor, dimensionless

Δh = differential head, ft at line temperature

K_M = meter constant, $ft^{2.5}/sec$

The theoretical proportionality constant, K_M, between flow and square root of differential head is a function of the meter throat area, the ratio of throat to pipe diameter, and the local gravitational constant, as defined by Equation (3).

$$K_M = \frac{a_t \sqrt{2 g_l}}{\sqrt{1-\beta^4}} \quad (3)$$

where a_t = throat area, $\pi d^2/4$, ft^2

d = throat diameter, ft

g_l = local gravitational constant, 32.1625 ft/sec^2 at Alden

β = ratio of throat to pipe diameter, d/D, dimensionless

D = pipe diameter, ft

The effect of fluid properties, viscosity and density, on the discharge coefficient is determined by Reynolds number, the ratio of inertia to viscous forces. Pipe Reynolds number, R_D, or throat Reynolds number, R_d is determined by Equation (4).

$$R_D = \frac{q_a D}{a_p \gamma} \qquad \left(R_d = \frac{q_a d}{a_t \gamma}\right) \tag{4}$$

where a_p = pipe area, $\pi D^2/4$, ft^2, (throat area $a_t = \pi d^2/4$, ft^2)

γ = kinematic viscosity, ft^2/sec

HEAD LOSS CALCULATION

If applicable , to determine the unrecoverable head loss if the MUT, pairs of pressure taps were installed approximately two pipe diameters upstream and ten pipe diameters downstream of the flow meter. This gross head loss was measured during the determination of the discharge coefficient. Thereafter, the flow meter was removed from the test line and the head loss due to the pipe was measured over a similar range of flows to determine the unique coefficients of k_p and n in Equation 5 below.

$$k_p = \frac{\Delta H_{fric}}{{q_a}^n} \tag{5}$$

Where:

k_p = friction loss coefficient, ft$^{5/2}$/s

ΔH_{fric} = pipe friction loss, feet

q_a = actual flow, ft^3/sec

n = Coefficient

Equivalent pipe losses were calculated by solving Equation 5 for pipe loss, DH_{fric}:

$$\Delta H_{fric} = k_p {q_a}^n \tag{6}$$

Pipe losses, characterized by Equation 6 were subtracted from the measured gross loss for the calculation of meter unrecoverable head loss as shown by Equation (7). The meter unrecoverable head loss is presented as a percent of the meter differential head.

$$\Delta H_{net\ meter} = \Delta H_{static} - \Delta H_{fric} \quad (7)$$

where: ΔH_{net} = meter unrecoverable head loss, feet

ΔH_{static} = measured static head difference, feet

FLOW METER SIGNAL RECORDING

The MUT indicated flow was recorded at the end of each weigh tank run. The method employed was according to the requirements of each meter and may include; gating the meter to totalize collected gallons, interrogating a mA output, totalized pulses, or manual reading of the MUT display. For MUT producing a differential pressure, the secondary element, which converts the primary element signal into engineering units, was one of several "Smart" differential pressure transmitters having a range of 250 inches of water column, 1,000 inches of water column and 100 psi. Each transmitter was calibrated with a pneumatic or a hydraulic dead weight tester having an accuracy of 0.02% of reading. Transmitter signals were recorded by a PC based data acquisition system having a 16 bit A to D board. Transmitter calibrations were conducted with the PC system such that an end to end calibration was achieved. Transmitter output was read simultaneously with the diversion of flow into the weigh tank at a rate of about 34 Hz for each test run (flow) and averaged to obtain a precise differential head. Average transmitter reading was converted to feet of flowing water using a linear regression analysis of the calibration data and line water temperatures to calculate appropriate specific weight.

TEST RESULTS

The results are presented in tabular and graphical format. The calculated flow, meter signal and meter performance are listed in the table(s) in the following pages.

Analysis indicates that the flow measurement uncertainty is within 0.25% of the true value for each test run. Calibrations of the test instrumentation (temperature, time, weight, and length measurements) are traceable to the National Institute of Standards and Technology (formerly the National Bureau of Standards) and Alden's Quality Assurance Program is designed to meet ANSI/NCSL Z540-1-1994 "Calibration Laboratories and Test Equipment-General Requirements" (supercedes MIL-STD-45662A).





Figure 1

Allen High Reynolds Number Facility Test Lines 1, 2, 3 and 4

Plan View Allen Facility Line 3



FLUIDIC TECHNIQUES, LP
Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUNS
January 2018

FLUIDIC TECHNIQUES, LP

Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-1
Tag Number: B10255-341-01

CALIBRATION
DATE: January 22, 2018
PIPE DIAMETER = 6.0650
THROAT DIAMETER = 3.8490

TAP SET 1


Run #	Line Temp Deg F	Air Temp Deg F	Net Weight lb.	Run Duration secs.	Output [see note]	Flow GPM	H Line FT H20	Pipe Rey. # x 10^6	Coef
1	106	72	9528	37.102	4.958~	1863.	94.737	1.5008	0.6022
2	106	71	9517	40.500	9.577~	1705.	79.254	1.3722	0.6024
3	106	72	9469	44.418	8.237~	1547.	65.232	1.2444	0.6024
4	106	73	9550	49.898	7.024~	1388.	52.540	1.1154	0.6026
5	106	73	9508	56.054	5.943~	1230.	41.231	0.9879	0.6029
6	106	74	9456	64.022	4.986~	1071.	31.220	0.8594	0.6033
7	106	74	9448	75.159	4.161~	912.2	22.593	0.7312	0.6036
8	106	73	9436	90.902	7.881~	753.3	15.395	0.6039	0.6038
9	106	72	9434	115.521	5.636~	592.6	9.517	0.4749	0.6041
10	106	73	7182	120.252	3.939~	433.4	5.074	0.3474	0.6051
11	106	73	4524	120.165	7.996~	273.2	2.009	0.2190	0.6062
12	106	73	2789	180.165	3.008~	112.3	0.337	0.0900	0.6086

~ dp transmitter volts

The data reported on herein was obtained by measuring equipment the calibration of which is traceable to NIST , following the installation and test procedures referenced in this report, resulting in a flow measurement uncertainty of +/- 0.25% or less.

CALIBRATED BY: DAV

CERTIFIED BY:



$$q_a = C F_a K_M \sqrt{\Delta h}$$

q_a =	Actual Flow (ft^3/sec)		
C =	Discharge Coefficient (Dimensionless)		
Δh =	Pressure Differential (Feet of Water at Run Temperature)		
K_M =	Meter Constant = $\frac{a\sqrt{2g}}{\sqrt{1 - ß^4}}$	=	0.7080
F_a =	Average Thermal Expansion Factor	=	1.0007
a =	Throat Area (ft^2)	=	0.0808
g =	Local Acceleration of Gravity (ft/sec^2)	=	32.1625
ß =	Ratio of Throat to Pipe Diameter (Dimensionless)	=	0.6346
	Pipe Diameter (Inches)	=	6.0650
	Throat Diameter (Inches)	=	3.8490

Dimensions By: FLUIDIC TECHNIQUES, LP

FLUIDIC TECHNIQUES, LP
Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-1
Tag Number: B10255-341-01
January 22, 2018

TAP SET 1

Certified By:

FLUIDIC TECHNIQUES, LP

Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-1
Tag Number: B10255-341-01

CALIBRATION
DATE: January 22, 2018
PIPE DIAMETER = 6.0650
THROAT DIAMETER = 3.8490

TAP SET 2


Run #	Line Temp Deg F	Air Temp Deg F	Net Weight lb.	Run Duration secs.	Output [see note]	Flow GPM	H Line FT H20	Pipe Rey. # x 10^6	Coef
1	106	72	9528	37.102	4.953~	1863.	94.773	1.5008	0.6021
2	106	71	9517	40.500	9.574~	1705.	79.326	1.3722	0.6021
3	106	72	9469	44.418	8.229~	1547.	65.233	1.2444	0.6024
4	106	73	9550	49.898	7.023~	1388.	52.606	1.1154	0.6022
5	106	73	9508	56.054	5.940~	1230.	41.256	0.9879	0.6027
6	106	74	9456	64.022	4.985~	1071.	31.253	0.8594	0.6029
7	106	74	9448	75.159	4.159~	912.2	22.593	0.7312	0.6036
8	106	73	9436	90.902	7.885~	753.3	15.394	0.6039	0.6038
9	106	72	9434	115.521	5.638~	592.6	9.515	0.4749	0.6042
10	106	73	7182	120.252	3.940~	433.4	5.073	0.3474	0.6052
11	106	73	4524	120.165	7.997~	273.2	2.009	0.2190	0.6062
12	106	73	2789	180.165	3.006~	112.3	0.337	0.0900	0.6082

~ dp transmitter volts

The data reported on herein was obtained by measuring equipment the calibration of which is traceable to NIST , following the installation and test procedures referenced in this report, resulting in a flow measurement uncertainty of +/- 0.25% or less.

CALIBRATED BY: DAV

CERTIFIED BY:



$$q_a = C F_a K_M \sqrt{\Delta h}$$

q_a =	Actual Flow (ft^3/sec)		
C =	Discharge Coefficient (Dimensionless)		
Δh =	Pressure Differential (Feet of Water at Run Temperature)		
K_M =	Meter Constant = $\frac{a\sqrt{2g}}{\sqrt{1 - ß^4}}$	=	0.7080
F_a =	Average Thermal Expansion Factor	=	1.0007
a =	Throat Area (ft^2)	=	0.0808
g =	Local Acceleration of Gravity (ft/sec^2)	=	32.1625
ß =	Ratio of Throat to Pipe Diameter (Dimensionless)	=	0.6346
	Pipe Diameter (Inches)	=	6.0650
	Throat Diameter (Inches)	=	3.8490

Dimensions By: FLUIDIC TECHNIQUES, LP

FLUIDIC TECHNIQUES, LP
Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-1
Tag Number: B10255-341-01
January 22, 2018

TAP SET 2

Certified By:

FLUIDIC TECHNIQUES, LP

Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-2
Tag Number: B10255-341-01

CALIBRATION
DATE: January 23, 2018
PIPE DIAMETER = 6.0650
THROAT DIAMETER = 3.8470

TAP SET 1


Run #	Line Temp Deg F	Air Temp Deg F	Net Weight lb.	Run Duration secs.	Output [see note]	Flow GPM	H Line FT H20	Pipe Rey. # x 10^6	Coef
1	106	71	9560	37.180	4.962~	1866.	94.855	1.5051	0.6033
2	106	72	9676	41.146	9.584~	1706.	79.331	1.3752	0.6033
3	106	73	9471	44.344	8.247~	1550.	65.338	1.2481	0.6038
4	106	73	9534	49.774	7.027~	1390.	52.573	1.1185	0.6037
5	106	73	9514	56.082	5.939~	1231.	41.190	0.9895	0.6040
6	106	73	9497	64.284	4.987~	1072.	31.232	0.8612	0.6041
7	106	74	9483	75.319	4.166~	913.6	22.650	0.7334	0.6045
8	106	73	9424	90.643	7.893~	754.5	15.425	0.6055	0.6049
9	106	73	9410	115.079	5.640~	593.4	9.528	0.4761	0.6053
10	106	73	7194	120.436	3.938~	433.4	5.071	0.3478	0.6061
11	106	73	4562	121.077	8.001~	273.4	2.010	0.2192	0.6073
12	106	74	2793	180.325	3.011~	112.4	0.338	0.0901	0.6089

~ dp transmitter volts

The data reported on herein was obtained by measuring equipment the calibration of which is traceable to NIST , following the installation and test procedures referenced in this report, resulting in a flow measurement uncertainty of +/- 0.25% or less.

CALIBRATED BY: DAV

CERTIFIED BY:



$$q_a = C F_a K_M \sqrt{\Delta h}$$

q_a =	Actual Flow (ft^3/sec)		
C =	Discharge Coefficient (Dimensionless)		
Δh =	Pressure Differential (Feet of Water at Run Temperature)		
K_M =	Meter Constant = $\frac{a\sqrt{2g}}{\sqrt{1 - ß^4}}$	=	0.7071
F_a =	Average Thermal Expansion Factor	=	1.0007
a =	Throat Area (ft^2)	=	0.0807
g =	Local Acceleration of Gravity (ft/sec^2)	=	32.1625
ß =	Ratio of Throat to Pipe Diameter (Dimensionless)	=	0.6343
	Pipe Diameter (Inches)	=	6.0650
	Throat Diameter (Inches)	=	3.8470

Dimensions By: FLUIDIC TECHNIQUES, LP

FLUIDIC TECHNIQUES, LP
Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-2
Tag Number: B10255-341-01
January 23, 2018

TAP SET 1

Certified By:

FLUIDIC TECHNIQUES, LP

Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-2
Tag Number: B10255-341-01

CALIBRATION
DATE: January 23, 2018
PIPE DIAMETER = 6.0650
THROAT DIAMETER = 3.8470

TAP SET 2


Run #	Line Temp Deg F	Air Temp Deg F	Net Weight lb.	Run Duration secs.	Output [see note]	Flow GPM	H Line FT H20	Pipe Rey. # x 10^6	Coef
1	106	71	9560	37.180	4.958~	1866.	94.936	1.5051	0.6031
2	106	72	9676	41.146	9.573~	1706.	79.324	1.3752	0.6033
3	106	73	9471	44.344	8.249~	1550.	65.452	1.2481	0.6033
4	106	73	9534	49.774	7.024~	1390.	52.618	1.1185	0.6034
5	106	73	9514	56.082	5.938~	1231.	41.234	0.9895	0.6037
6	106	73	9497	64.284	4.985~	1072.	31.249	0.8612	0.6039
7	106	74	9483	75.319	4.167~	913.6	22.681	0.7334	0.6041
8	106	73	9424	90.643	7.907~	754.5	15.453	0.6055	0.6043
9	106	73	9410	115.079	5.646~	593.4	9.536	0.4761	0.6050
10	106	73	7194	120.436	3.941~	433.4	5.076	0.3478	0.6058
11	106	73	4562	121.077	8.012~	273.4	2.014	0.2192	0.6067
12	106	74	2793	180.325	3.007~	112.4	0.338	0.0901	0.6093

~ dp transmitter volts

The data reported on herein was obtained by measuring equipment the calibration of which is traceable to NIST , following the installation and test procedures referenced in this report, resulting in a flow measurement uncertainty of +/- 0.25% or less.

CALIBRATED BY: DAV

CERTIFIED BY:



$$q_a = C F_a K_M \sqrt{\triangle h}$$

q_a =	Actual Flow (ft^3/sec)		
C =	Discharge Coefficient (Dimensionless)		
$\triangle h$ =	Pressure Differential (Feet of Water at Run Temperature)		
K_M =	Meter Constant = $\frac{a\sqrt{2g}}{\sqrt{1 - ß^4}}$	=	0.7071
F_a =	Average Thermal Expansion Factor	=	1.0007
a =	Throat Area (ft^2)	=	0.0807
g =	Local Acceleration of Gravity (ft/sec^2)	=	32.1625
ß =	Ratio of Throat to Pipe Diameter (Dimensionless)	=	0.6343
	Pipe Diameter (Inches)	=	6.0650
	Throat Diameter (Inches)	=	3.8470

Dimensions By: FLUIDIC TECHNIQUES, LP

FLUIDIC TECHNIQUES, LP
Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-2
Tag Number: B10255-341-01
January 23, 2018

TAP SET 2

Certified By:

FLUIDIC TECHNIQUES, LP

Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-3
Tag Number: B10255-341-01

CALIBRATION
DATE: January 23, 2018
PIPE DIAMETER = 6.0650
THROAT DIAMETER = 3.8480

TAP SET 1


Run #	Line Temp Deg F	Air Temp Deg F	Net Weight lb.	Run Duration secs.	Output [see note]	Flow GPM	H Line FT H20	Pipe Rey. # x 10^6	Coef
1	106	74	9511	36.955	4.954~	1867.	94.592	1.5057	0.6043
2	106	74	9525	40.470	9.564~	1708.	79.125	1.3763	0.6043
3	106	74	9497	44.446	8.231~	1550.	65.172	1.2483	0.6044
4	106	74	9486	49.480	7.016~	1391.	52.466	1.1189	0.6044
5	106	74	9531	56.139	5.934~	1232.	41.138	0.9900	0.6045
6	106	71	9482	64.088	4.983~	1073.	31.199	0.8628	0.6049
7	106	72	9500	75.479	4.158~	913.4	22.566	0.7331	0.6050
8	106	73	9434	90.762	7.871~	754.3	15.369	0.6055	0.6055
9	106	73	9424	115.264	5.630~	593.3	9.500	0.4760	0.6057
10	106	74	7184	120.247	3.935~	433.5	5.063	0.3476	0.6063
11	106	74	4537	120.528	7.983~	273.1	2.005	0.2190	0.6071
12	106	74	2798	180.274	3.013~	112.6	0.339	0.0903	0.6090

~ dp transmitter volts

The data reported on herein was obtained by measuring equipment the calibration of which is traceable to NIST , following the installation and test procedures referenced in this report, resulting in a flow measurement uncertainty of +/- 0.25% or less.

CALIBRATED BY: DAV

CERTIFIED BY:



$$q_a = C F_a K_M \sqrt{\Delta h}$$

q_a =	Actual Flow (ft^3/sec)		
C =	Discharge Coefficient (Dimensionless)		
Δh =	Pressure Differential (Feet of Water at Run Temperature)		
K_M =	Meter Constant = $\frac{a\sqrt{2g}}{\sqrt{1 - ß^4}}$	=	0.7076
F_a =	Average Thermal Expansion Factor	=	1.0007
a =	Throat Area (ft^2)	=	0.0808
g =	Local Acceleration of Gravity (ft/sec^2)	=	32.1625
ß =	Ratio of Throat to Pipe Diameter (Dimensionless)	=	0.6345
	Pipe Diameter (Inches)	=	6.0650
	Throat Diameter (Inches)	=	3.8480

Dimensions By: FLUIDIC TECHNIQUES, LP

FLUIDIC TECHNIQUES, LP
Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-3
Tag Number: B10255-341-01
January 23, 2018

TAP SET 1

Certified By:

FLUIDIC TECHNIQUES, LP

Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-3
Tag Number: B10255-341-01

CALIBRATION
DATE: January 23, 2018
PIPE DIAMETER = 6.0650
THROAT DIAMETER = 3.8480

TAP SET 2


Run #	Line Temp Deg F	Air Temp Deg F	Net Weight lb.	Run Duration secs.	Output [see note]	Flow GPM	H Line FT H20	Pipe Rey. # x 10^6	Coef
1	106	74	9511	36.955	4.941~	1867.	94.371	1.5057	0.6050
2	106	74	9525	40.470	9.538~	1708.	78.958	1.3763	0.6049
3	106	74	9497	44.446	8.215~	1550.	65.096	1.2483	0.6048
4	106	74	9486	49.480	6.998~	1391.	52.337	1.1189	0.6052
5	106	74	9531	56.139	5.921~	1232.	41.060	0.9900	0.6050
6	106	71	9482	64.088	4.975~	1073.	31.148	0.8628	0.6054
7	106	72	9500	75.479	4.153~	913.4	22.529	0.7331	0.6055
8	106	73	9434	90.762	7.870~	754.3	15.356	0.6055	0.6057
9	106	73	9424	115.264	5.627~	593.3	9.486	0.4760	0.6062
10	106	74	7184	120.247	3.933~	433.5	5.054	0.3476	0.6069
11	106	74	4537	120.528	7.984~	273.1	2.005	0.2190	0.6071
12	106	74	2798	180.274	3.012~	112.6	0.339	0.0903	0.6086

~ dp transmitter volts

The data reported on herein was obtained by measuring equipment the calibration of which is traceable to NIST , following the installation and test procedures referenced in this report, resulting in a flow measurement uncertainty of +/- 0.25% or less.

CALIBRATED BY: DAV

CERTIFIED BY:



$$q_a = C F_a K_M \sqrt{\Delta h}$$

q_a =	Actual Flow (ft^3/sec)		
C =	Discharge Coefficient (Dimensionless)		
Δh =	Pressure Differential (Feet of Water at Run Temperature)		
K_M =	Meter Constant = $\frac{a\sqrt{2g}}{\sqrt{1 - ß^4}}$	=	0.7076
F_a =	Average Thermal Expansion Factor	=	1.0007
a =	Throat Area (ft^2)	=	0.0808
g =	Local Acceleration of Gravity (ft/sec^2)	=	32.1625
ß =	Ratio of Throat to Pipe Diameter (Dimensionless)	=	0.6345
	Pipe Diameter (Inches)	=	6.0650
	Throat Diameter (Inches)	=	3.8480

Dimensions By: FLUIDIC TECHNIQUES, LP

FLUIDIC TECHNIQUES, LP
Purchase Order Number: 60160, JOB: FAB-3206
6" - 300# AGA METER RUN
Serial Number: JOB: FAB-3206-3
Tag Number: B10255-341-01
January 23, 2018

TAP SET 2

Certified By:

THERMAL EXPANSION FACTOR

The dimensions of a differential producing flow meter are affected by the operating temperature, requiring a Thermal Expansion Factor (F_a) to be included in the calculations. The calculation requires the temperature at which the meter dimensions were measured be known. If this information is not available, an ambient temperature of 68˚ F is assumed. The Thermal Expansion Factor is calculated according to the American Society of Mechanical Engineers Standard ASME MFC-3M-1989, Equation 17 (pg 11).

$$F_a = 1 + \frac{2}{1-\beta^4}\left(\alpha_{PE} - \beta^4{}_{meas}\ \propto_p\right)(t - t_{meas})$$

where β = ratio of throat diameter to pipe diameter, dimensionless

α_{PE} = thermal expansion factor of primary element, (in./in./°F)

$\propto_p$ = thermal expansion factor of pipe, (in./in./°F)

t = temperature of flowing fluid, ˚F

t_{meas} = temperature of measurements, ˚F

Thermal expansion factors, α, excerpted from MFC-3M-1989, are listed in the Table below for six typically used materials at three temperatures. Linear interpolation is used to determine the coefficients at flowing temperature.

Mean Coefficient of Thermal Expansion = $\frac{A}{10^6}$ (in./in./°F)

Material	Coef.	-50 ˚F	70 ˚F	200 ˚F
Bronze 4-10	A	9.15	9.57	10.03
300 Series Stainless Steel	A	8.90	9.11	9.34
Monel	A	7.15	7.48	7.84
.2 to 1.1% C Steel	A	5.80	6.07	6.38
5% Chrome Moly	A	5.45	5.73	6.04
410 to 430 Stainless Steel	A	5.00	5.24	5.50

WATER DENSITY*

Temperature Fahrenheit	Density lb_m / ft^3	Temperature Fahrenheit	Density lb_m / ft^3	Temperature Fahrenheit	Density lb_m / ft^3
32	62.4179	62	62.3549	92	62.0903
33	62.4201	63	62.3489	93	62.0788
34	62.4220	64	62.3427	94	62.0671
35	62.4235	65	62.3363	95	62.0552
36	62.4246	66	62.3296	96	62.0432
37	62.4255	67	62.3228	97	62.0311
38	62.4260	68	62.3157	98	62.0188
39	62.4262	69	62.3084	99	62.0063
40	62.4261	70	62.3010	100	61.9937
41	62.4257	71	62.2933	101	61.9810
42	62.4250	72	62.2855	102	61.9681
43	62.4240	73	62.2774	103	61.9551
44	62.4227	74	62.2692	104	61.9419
45	62.4211	75	62.2608	105	61.9286
46	62.4193	76	62.2522	106	61.9151
47	62.4171	77	62.2434	107	61.9015
48	62.4147	78	62.2344	108	61.8878
49	62.4121	79	62.2252	109	61.8739
50	62.4092	80	62.2159	110	61.8599
51	62.4060	81	62.2063	111	61.8458
52	62.4025	82	62.1966	112	61.8315
53	62.3988	83	62.1868	113	61.8172
54	62.3949	84	62.1767	114	61.8027
55	62.3907	85	62.1665	115	61.7880
56	62.3863	86	62.1561	116	61.7733
57	62.3816	87	62.1456	117	61.7584
58	62.3768	88	62.1348	118	61.7434
59	62.3716	89	62.1239	119	61.7284
60	62.3663	90	62.1129	120	61.7132
61	62.3607	91	62.1017	121	61.6978

* Distilled water values used in all calculation

EMERSON

24 February, 2018

Emerson Automation Solutions
8200 Market Blvd
Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information

Name: FORNEY CORP
PO: 790542

Manufacturer Information

Sales Order: 5116125
Line: 1

Device Information

Device Type: Pressure Transmitter
Customer Ref/ID: N/A
Serial No: 0011949

Model No: 3051SMV5M13G3R2A11A1AC12C2E5M5Q4

Module Serial No: 18019960
Output: Linear
Device ID: 33194

Calibration Information

Factory: Chanhassen, MN, USA
Station Name: CHAN_DPFLOW_CALIBRATION_01
Operator ID: 59869
Calibration Date: 02/23/2018 08:22:01 AM

Internal Ref #: 30073090

Permanent Tag Information

DUCT BURNER
FLOW TRANSMITTER

Wire-On Tag Information

Attached Models

0305RC92B21B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-58610	Load Box	7/20/2018 2:17:00PM
E3-60655	Multimeter	9/20/2018 3:07:00PM
E3-60786	Precision Resistance Decade	7/9/2018 10:38:00AM
P3-54917	Pressure Controller	4/12/2018 1:13:00PM
P3-55113	Pressure Controller	5/2/2018 10:27:00AM

Calibration Data

DP

Reference of Calibration: Differential

Range: 0.000 TO 150.000 InH2O@68degF

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (InH2O@68degF)	% Span Error	Pass/Fail
99.994	5.409 PSI	149.99050 InH2O@68degF	149.98700	-0.00233	PASS
79.991	4.327 PSI	119.98680 InH2O@68degF	119.98820	0.00093	PASS
59.989	3.245 PSI	89.98320 InH2O@68degF	89.97474	-0.00564	PASS
39.986	2.163 PSI	59.97956 InH2O@68degF	59.97218	-0.00492	PASS
19.984	1.081 PSI	29.97591 InH2O@68degF	29.97556	-0.00023	PASS
0.000	0.000 PSI	0.00000 InH2O@68degF	-0.00493	-0.00329	PASS

SP

Reference of Calibration: Gauge

Range: 0.000 TO 100.000 PSI

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (PSI)	% Span Error	Pass/Fail
100.000	100.000 PSI	100.00000 PSI	100.00050	0.00050	PASS
80.000	80.000 PSI	80.00000 PSI	80.00269	0.00269	PASS
60.000	60.000 PSI	60.00000 PSI	60.00123	0.00123	PASS
40.000	40.000 PSI	40.00000 PSI	40.00577	0.00577	PASS
20.000	20.000 PSI	20.00000 PSI	20.00554	0.00554	PASS
0.000	0.000 PSI	0.00000 PSI	0.00476	0.00476	PASS

PT

Range: 0.000 TO 150.000 DEG F

Damping: 0.40 seconds

% of Range	Applied Resistence	Applied Resistence	Digital Output (DEG F)	Error (DEG F)	Pass/Fail
100.000	125.373 Ohms	150.00000 DEG F	149.98980	-0.01020	PASS
80.000	118.969 Ohms	120.00000 DEG F	119.97740	-0.02260	PASS
60.000	112.533 Ohms	90.00000 DEG F	90.00949	0.00949	PASS
40.000	106.066 Ohms	60.00000 DEG F	59.98681	-0.01319	PASS
20.000	99.566 Ohms	30.00000 DEG F	29.95533	-0.04467	PASS
0.000	93.033 Ohms	0.00000 DEG F	-0.03553	-0.03553	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Heather Matthiesen
Quality Manager

EMERSON

24 February, 2018

Emerson Automation Solutions
8200 Market Blvd
Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information

Name: FORNEY CORP
PO: 790542

Manufacturer Information

Sales Order: 5116125
Line: 3

Device Information

Device Type: Pressure Transmitter
Customer Ref/ID: N/A
Serial No: 0011952

Model No: 3051SMV5M13G3R2A11A1AC12C2E5M5Q4

Module Serial No: 18018756
Output: Linear
Device ID: 33342

Calibration Information

Factory: Chanhassen, MN, USA
Station Name: CHAN_DPFLOW_CALIBRATION_02
Operator ID: 71573
Calibration Date: 02/24/2018 04:39:28 AM

Internal Ref #: 30073091

Permanent Tag Information

DUCT BURNER
FLOW TRANSMITTER

Wire-On Tag Information

Attached Models

0305RC92B21B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-58786	Load Box	6/20/2018 10:40:00AM
E3-59313	Multimeter	3/20/2018 2:03:00PM
E3-60787	Precision Resistance Decade	6/9/2018 3:57:00PM
P3-55112	Pressure Controller	5/2/2018 8:18:00AM
P3-55114	Pressure Controller	5/2/2018 10:04:00AM
P3-55115	Pressure Controller	5/2/2018 11:00:00AM

Calibration Data

DP

Reference of Calibration: Differential

Range: 0.000 TO 150.000 InH2O@68degF

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (InH2O@68degF)	% Span Error	Pass/Fail
99.994	5.409 PSI	149.99050 InH2O@68degF	149.98920	-0.00087	PASS
79.991	4.327 PSI	119.98680 InH2O@68degF	119.97230	-0.00967	PASS
59.989	3.245 PSI	89.98320 InH2O@68degF	89.97919	-0.00267	PASS
39.986	2.163 PSI	59.97956 InH2O@68degF	59.97625	-0.00221	PASS
19.984	1.081 PSI	29.97591 InH2O@68degF	29.96889	-0.00468	PASS
0.000	0.000 PSI	0.00000 InH2O@68degF	0.00153	0.00102	PASS

SP

Reference of Calibration: Gauge

Range: 0.000 TO 100.000 PSI

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (PSI)	% Span Error	Pass/Fail
100.000	100.000 PSI	100.00000 PSI	99.99738	-0.00262	PASS
80.000	80.000 PSI	80.00000 PSI	79.99007	-0.00993	PASS
60.000	60.000 PSI	60.00000 PSI	59.98510	-0.01490	PASS
40.000	40.000 PSI	40.00000 PSI	39.98647	-0.01353	PASS
20.000	20.000 PSI	20.00000 PSI	19.99307	-0.00693	PASS
0.000	0.000 PSI	0.00000 PSI	-0.00645	-0.00645	PASS

PT

Range: 0.000 TO 150.000 DEG F

Damping: 0.40 seconds

% of Range	Applied Resistence	Applied Resistence	Digital Output (DEG F)	Error (DEG F)	Pass/Fail
100.000	125.373 Ohms	150.00000 DEG F	150.00770	0.00770	PASS
80.000	118.969 Ohms	120.00000 DEG F	119.97980	-0.02020	PASS
60.000	112.533 Ohms	90.00000 DEG F	89.99532	-0.00468	PASS
40.000	106.066 Ohms	60.00000 DEG F	59.99119	-0.00881	PASS
20.000	99.566 Ohms	30.00000 DEG F	30.02257	0.02257	PASS
0.000	93.033 Ohms	0.00000 DEG F	-0.00505	-0.00505	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Heather Matthiesen
Quality Manager

24 February, 2018

Emerson Automation Solutions
8200 Market Blvd
Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information

Name: FORNEY CORP
PO: 790542

Manufacturer Information

Sales Order: 5116125
Line: 3

Device Information

Device Type: Pressure Transmitter
Customer Ref/ID: N/A
Serial No: 0011953

Model No: 3051SMV5M13G3R2A11A1AC12C2E5M5Q4

Module Serial No: 14966796
Output: Linear
Device ID: 33193

Calibration Information

Factory: Chanhassen, MN, USA
Station Name: CHAN_DPFLOW_CALIBRATION_01
Operator ID: 45565
Calibration Date: 02/23/2018 08:47:14 AM

Internal Ref #: 30073092

Permanent Tag Information

DUCT BURNER
FLOW TRANSMITTER

Wire-On Tag Information

Attached Models

0305RC92B21B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-58610	Load Box	7/20/2018 2:17:00PM
E3-60655	Multimeter	9/20/2018 3:07:00PM
E3-60786	Precision Resistance Decade	7/9/2018 10:38:00AM
P3-54917	Pressure Controller	4/12/2018 1:13:00PM
P3-55113	Pressure Controller	5/2/2018 10:27:00AM

Calibration Data

DP

Reference of Calibration: Differential

Range: 0.000 TO 150.000 InH2O@68degF

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (InH2O@68degF)	% Span Error	Pass/Fail
99.994	5.409 PSI	149.99050 InH2O@68degF	149.99210	0.00107	PASS
79.991	4.327 PSI	119.98680 InH2O@68degF	119.98590	-0.00060	PASS
59.989	3.245 PSI	89.98320 InH2O@68degF	89.96931	-0.00926	PASS
39.986	2.163 PSI	59.97956 InH2O@68degF	59.96970	-0.00657	PASS
19.984	1.081 PSI	29.97591 InH2O@68degF	29.97540	-0.00034	PASS
0.000	0.000 PSI	0.00000 InH2O@68degF	-0.00136	-0.00091	PASS

SP

Reference of Calibration: Gauge

Range: 0.000 TO 100.000 PSI

Damping: 0.40 seconds

% of Range	Applied Pressure	Requested Applied Pressure	Digital Output (PSI)	% Span Error	Pass/Fail
100.000	100.000 PSI	100.00000 PSI	99.99935	-0.00065	PASS
80.000	80.000 PSI	80.00000 PSI	79.99359	-0.00641	PASS
60.000	60.000 PSI	60.00000 PSI	59.99270	-0.00730	PASS
40.000	40.000 PSI	40.00000 PSI	39.99899	-0.00101	PASS
20.000	20.000 PSI	20.00000 PSI	19.99092	-0.00908	PASS
0.000	0.000 PSI	0.00000 PSI	-0.00486	-0.00486	PASS

PT

Range: 0.000 TO 150.000 DEG F

Damping: 0.40 seconds

% of Range	Applied Resistence	Applied Resistence	Digital Output (DEG F)	Error (DEG F)	Pass/Fail
100.000	125.373 Ohms	150.00000 DEG F	149.97640	-0.02360	PASS
80.000	118.969 Ohms	120.00000 DEG F	119.98160	-0.01840	PASS
60.000	112.533 Ohms	90.00000 DEG F	89.99405	-0.00595	PASS
40.000	106.066 Ohms	60.00000 DEG F	60.01852	0.01852	PASS
20.000	99.566 Ohms	30.00000 DEG F	30.03536	0.03536	PASS
0.000	93.033 Ohms	0.00000 DEG F	0.02816	0.02816	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Heather Matthiesen
Quality Manager

ATTACHMENT 3

FUEL ANALYSIS DOCUMENT

9.3 Delivery Point Conforming Gas Quality Maximums. The gas to be made available to or on behalf of Shipper at the Delivery Point(s) on Transporter's system, as measured at the applicable monitoring point, shall not exceed any of the following maximum average daily requirements unless Transporter and Delivery Point Operator that would be receiving such non-conforming gas otherwise agree:


a) Heating Value - one thousand one hundred ten (1,110) Btu's per cubic foot; and
b) Wobbe Index - one thousand three hundred seventy three (1,373) Btu's per cubic foot through 12/31/2011; one thousand four hundred (1,400) Btu's per cubic foot on and after 1/1/2012; and
c) Cricondentherm Hydrocarbon Dew Point - fifteen (15) degrees Fahrenheit; and
d) Non-methane Hydrocarbons (C2+) - eight and one-quarter percent (8.25%) by volume through 12/31/2011; twelve percent (12%) by volume on and after 1/1/2012: and
e) Heavy Hydrocarbons (C4+) - one and one half percent (1.5%) by volume; and
f) Temperature - one hundred twenty (120) degrees Fahrenheit; and
g) Sulfur - one and one quarter (1.25) grains per one hundred cubic feet; and
h) Hydrogen Sulfide - one quarter (0.25) grain per one hundred cubic feet; and
i) Oxygen - two-tenths of one percent (0.2%) by volume; and
j) Carbon Dioxide - two percent (2.0%) by volume; and
k) Nitrogen and Oxygen - two and one-half percent (2.5%) by volume of a combined total of nitrogen and oxygen components through 12/31/2011; two and three-quarters percent (2.75%) by volume of a combined total of nitrogen and oxygen components on and after 1/1/2012; and
l) Carbon Dioxide and Nitrogen - Not more than four percent (4%) by volume of a combined total of carbon dioxide and nitrogen components, and
m) Entrained Water - four (4) pounds per million cubic feet, at a pressure base of fourteen and seventy-three hundredths (14.73) pounds per square inch and a temperature of sixty (60) degrees Fahrenheit as determined by dew-point apparatus approved by the National Institute of Standards and Technology or such other apparatus as may be mutually agreed upon; and
n) Polychlorinated Biphenyl (PCB) - one-tenth (0.1) part PCB per billion parts natural gas.


The limitations set forth above in this Section 9.3 shall each apply independently.

ATTACHMENT 4


STACK DRAWINGS


IHG-000201-DOJO-2521






TYPICAL SHOP WELD
SCALE 6"=1'-0"






SECTION "A-A"
SCALE 1/4" = 1'-0"

EARTHING LUG
(2) PLACES 42° & 222°
SCALE: 3"=1'-0"




SECTION "A1-A1"
SCALE 1"=1'-0"


SECTION "A2-A2"
SCALE: 3"=1'-0"



SECTION "G-G"
SCALE 3/8"=1'-0"




SECTION "M-M"
T.O.S. EL. 261'-3½"
SCALE: 3/8"=1'-0"




SECTION "I-I"

TEST PORT ORIENTATIONS
(ALL PORT DETAILS REF. DWG. 2516 UNIT2)
SCALE 1/4" = 1'-0"



KEY PLAN
(SCALE: 1/16"=1'-0")



DETAIL-'K'
SCALE 6"=1'-0"

TYPICAL FIELD WELD FOR CIRC. SEAM
SCALE 3"=1'-0"

NOTES:

1. FOR GENERAL NOTES, MATERIAL SPEC'S, ERECTOR NOTES AND REFERENCE DRAWINGS SEE DRAWING IHG-000201-DOJO-2515.

D	PERSONNEL PROTECTION REMOVED THUS REVISED AS CLOUDED MARK.			
	SKD	AP	SD	20JAN18
C	SCALLOPED CLIPS ADDED & TMD UPDATED AS CLOUD MARKED.			
	SKD	AP	SD	07NOV17
B	REVISED AS CLOUD MARKED			
	SKD	JP	SD	27OCT17
A	INITIAL ISSUE			
	SKD	CJ	SD	18JUN17
	DRAWN BY	CHECKED BY	APPROVED BY	DATE

CONTRACT NO.: IHG-000201 UNIT NO.: 03

HRSG STACK 03 ARRANGEMENT - RIGHT SIDE ELEVATION
CRICKET VALLEY ENERGY CENTER
BECHTEL INFRASTRUCTURE AND POWER CORPORATION
PURCHASE ORDER NO: 26068-230-POA-MS00-00001

IHG-000201-DOJO-2520

GAS FLOW

EL. 155'-0" S.V.
EL. 137'-5½" F.V.
EL. 130'-0" S.V.
EL. 105'-0" S.V.
EL. 95'-8½" F.V. (DWG. 2521)
EL. 90'-0" S.V.
EL. 65'-0" S.V.
EL. 57'-8" F.V.
EL. 51'-8½" F.V.
EL. 40'-0" S.V.
EL. 30'-0" S.V.
EL. 15'-0" S.V.

25'-0" (9/16" THK PLATE)
25'-0" (5/8" THK PLATE)
15'-0" (5/8" THK PLATE)
25'-0" (3/4" THK PLATE)
25'-0" (3/4" THK PLATE)
25'-0" (3/4" THK PLATE)
10'-0" (7/8" THK PLATE)
15'-0" (7/8" THK PLATE)
15'-0" (7/8" THK PLATE)

RING STIFFENER 3/4" THK x 8-7/8" WIDE (TYP.)
4'-0" TYP.
SCAFFOLD CLIPS TYP.
4"x2"x1/4" (304L S.S)
UPPER RINGS 1" THK x 18" WIDE SEE MAT'L SPEC. #7
LOWER RINGS 1" THK x 18" WIDE SEE MAT'L SPEC. #7
4'-10" BETWEEN THE RINGS
OUTLET DUCT (REF.)
11'-11 13/16"
27'-4" OUTSIDE PLATE
27'-0" BREECH OPENING
5 SPACES @ 4'-0" = 20'-0"
8'-3½"
4'-1¼"
5'-0 7/16"
43'-6¾"
℄ OF STACK
℄ OF BREECH OPENING
℄ OF 18' DIA OPENING

N.S. 14, 15 · F.S. 13 · N.S. 11, 12 · F.S. 10 · N.S. 8, 9 · F.S. 7 · N.S. 5, 6 · F.S. 4 · N.S. 29 · F.S. 25, 26 · N.S. 31, 32 · F.S. 27, 28 · N.S. 30

'A3' 'A3' · 'B' 'B' · 'G' 'G' · 'K' 'K' · 'L' 'L' · 'C' 'C' · 'S1'

19'-0" STACK I.D.

EL. 282'-6" TOP OF STACK
'J' 'J'
TUNED MASS DAMPER HANGER ASS'Y BY THD VENDOR
'I' 'I'
EL. 267'-10"
EL. 267'-4"
EL. 266'-4"
EL. 265'-10"
EL. 265'-4"
L5x5x3/8 PLATFORM SUPPORT RING
EL. 259'-10⅝"
EL. 257'-5½" F.V.
EL. 253'-4½" ℄ OF SUPPORT BRACKET PAINTER TROLLEY E-HRSG-2025
EL. 240'-0" S.V.
EL. 217'-5½" F.V.
EL. 210'-0" S.V.
EL. 180'-0" S.V.
EL. 177'-5½" F.V.
EL. 155'-0" S.V.
'M' 'M'

1'-2¾" · 4'-0" · 11'-0" · 10'-10⅝" · 5'-2⅝" · 2'-7" · 6'-4⅞"
42'-6" (1¼" THK PLATE)
30'-0" (3/8" THK PLATE)
25'-0" (1/2" THK PLATE)
14 SPC'S @ 11'-5⅜" = 172'-2¼"
3'-8½"

N.S. 22 · F.S. 23, 24 · N.S. 20, 21 · F.S. 19 · F.S. 17, 18 · N.S. 16

'A1' 'A1' · 'A2' 'A2' · 'I' 'I' · 'M' 'M'

SECTION "A-A"
SCALE 1/4" = 1'-0"

C DRAIN PIPE · 6" TYP. · 3" TYP. · 1½" TYP. · 90° TYP.
INSIDE STACK
5/16 5/16 1/2" THK. x3"x4 3/4" MAT'L ASTM A-36
EL. 3'-10 3/4"
(2) 1/2"x 13 UNC THREADED HOLE
1 3/4"

EARTHING LUG
(2) PLACES 42° & 222°
SCALE: 3"=1'-0"

33 · 34 · 4'-9" · 4'-9" · ℄ STACK · 180° · 0° · 270°
DRAIN SLOPE
UPPER BASE RING PLATE 22'-5¾" OD x 19'-1¾" ID x 1" THK
LOWER BASE RING PLATE 22'-5¾" OD x 18'-11" ID x 1" THK
4" DIA HOLES @ LOWER & UPPER BASE RING (60) HOLES EQUALLY SPACED ON 19'-11" DIA B.C. TEMPLATE TO BE USED FOR HOLE DRILLING (FOR TEMPLATE REF. DRG. NO. 2525)

2" SCH. 40 (C.S.) PIPE W/3" 150# R.F. SLIP ON FLG. TP-039 SEE DWG. 'TBD'
3/16 · 3/8" THK FLOOR PLATE · 1'-0" · 2 1/2" GAP · C200x80x7.5x11
SCALE 3"=1'-0"

SEAL 3/8 · 3/8" THK FLOOR · 2"x1/4" THK. ROLLED BAR · 3/16

33 · 34 · C.J.P. · 3/16 3-12 · C200x80x7.5x11

SECTION "A2-A2"
SCALE: 3"=1'-0"

1'-8" · 1" THK x 20' WIDE UPPER BASE RING · 5/8 5/8 · 3 SIDES TYP. 5/8 5/8 · C1 TYP. · (120) 7/8" THK STIFFENER · 7/8" THK · 1" THK x 21⅜" THK WIDE LOWER BASE RING · 1½" REF. · 5/8 5/8 EL. 0'-0" · 1'-9 3/8" · 19'-11⅛" B.C.D. · 19' STACK I.D.
1' UPPER BASE RING · 1' LOWER BASE RING · 2'-8"

BV36x238 · 1" THK. X 18" WIDE RING STIFF'S (2) ELEVATIONS TYP. · R50 (MIN.) SHELL OPENING

SECTION "G-G"
SCALE 3/8"=1'-0"

SECTION "A1-A1"
SCALE 1"=1'-0"

60° · ½" · FOR CIRC. SEAM · FOR LONG. SEAM

TYPICAL SHOP WELD
SCALE 6"=1'-0"

8'-11 5/16" · 9'-8 7/8" · 11'-5" · SEE DETAIL 5 DWG-2518 · 'M4' · 90° · 'M3' · 'M2' · 'M1' · 180° · 0° · 270° · 45° · 5'-1" · 5'-1 1/16" · 22.5° · 12.6° · 47.1° · 30.3° · 24.5° · 4'-7 7/8" · ℄ STACK UNIT 1' · SEE DETAIL '68' DWG-2518 · C250x90 (TYP.) · KB · TYP. 5 PLCS
8'-11 3/8" · 6'-3 7/8" · 6'-3 15/16" · 8'-6 1/16" · 30'-1 1/4"
12'-7 13/16" · 8'-11 5/16" · 8'-11 3/8" · 6'-7 1/8" · 8'-8 3/16" · 6'-9 3/16" · 8'-6 1/16" · 30'-6 1/2" · NO. 1 PLATE

SECTION "M-M"
T.O.S. EL. 260'-8½"
SCALE: 3/8"=1'-0"

E VELOCITY · F TE · C CEMS · B EPA · E VELOCITY & OPACITY · D · 90° · 60° · 27° · 15° · 0° TE F · 330° · 297° · 285° · 270° · 255° · 207° · 195° · 180° · 117° · 105°

R42I R42I

SECTION "I-I"
TEST PORT ORIENTATIONS
(ALL PORT DETAILS REF. DWG. 2516 UNIT 2)
SCALE 1/4" = 1'-0"

VIEW FROM THIS SIDE
℄ STACK UNIT 03 · ℄ STACK UNIT 01 · ℄ STACK UNIT 02 · GAS FLOW · 90° · 180° · 270° · 0° · N

KEY PLAN
(SCALE: 1/16"=1'-0")

¼" · 3/8" · DUCT INSIDE 1/4 1/4 · 18' DIA. ROUND OUTLET DUCT

DETAIL-'K'
SCALE 6"=1'-0"

MUST BE CONTINUOUS · 3/16 · C.J.P. · 1 1/2" · 2" · 1/4" THK. BAR · SHELL I.D.

TYPICAL FIELD WELD FOR CIRC. SEAM
SCALE 3"=1'-0"

3" · 1 1/2" · 1/4" BAR · 8½" · 3/16 3-12

1'-6" · 5/16 5/16 TYP.

90° · 56° ALTERNATING FIELD WELD · 36° · 156° · 176° · 180° · 0° · 120° OVERLAPPING SECTIONS
FIELD WELD PC. MARKS 1 THROUGH 3 · PC. MARKS 7 THROUGH 9 · PC. MARKS 13 THROUGH 15 · PC. MARKS 19 THROUGH 21

NOTES:


1. FOR GENERAL NOTES, MATERIAL SPEC'S, ERECTOR NOTES AND REFERENCE DRAWINGS SEE DRAWING IHG-000201-DOJO-2515.

REV	DRAWN BY	CHECKED BY	APPROVED BY	DATE
D	PERSONNEL PROTECTION REMOVED THUS REVISED AS CLOUDED MARK.	SKB	AP	SD	30JAN18
C	SCALLOPED CLIPS ADDED & TKD UPDATED AS CLOUD MARKED.	SKB	AP	SD	07NOV17
B	REVISED AS CLOUDED MARKED.	SKB	IP	SD	27OCT17
A	INITIAL ISSUE	SKB	CJ	SD	16JUN17

CONTRACT NO. : IHG-000201 · UNIT NO. : 01

HRSG STACK 01 ARRANGEMENT - RIGHT SIDE ELEVATION
CRICKET VALLEY ENERGY CENTER
BECHTEL INFRASTRUCTURE AND POWER CORPORATION
PURCHASE ORDER NO. 26068-220-PPA-MS00-00001

IHG-000201-DOJO-2516



A421

A421

NOTES:

1. FOR NOTES AND REFERENCE DRAWINGS SEE DRAWING IHG-000201-DOJO-2515


D	SCAFFOLD CLIP ADDED & TKD UPDATED AS CLOUD MARKED.			
	SKD	CJ	SD	06NOV17
C	BOTTOM L ELEVATION CHANGED, SECTION P2-P2 ADDED & HOLD REMOVED FROM TUNE MASS DAMPER.			
	SKD	CJ	SD	27OCT17
B	DUPLICATE DIMS. REMOVED, RING STIFF. THK. CORRECTED & OPACITY AND TE TEST PORT MODIFIED AS CLOUD MARKED			
	SKD	CJ	SD	13JUNE17
A	INITIAL ISSUE			
	SK	JP	SD	29MAR17


CONTRACT NO.: IHG-000201 UNIT NO.: 02

HRSG STACK ARRANGEMENT - RIGHT SIDE ELEVATION


CRICKET VALLEY ENERGY CENTER
BECHTEL INFRASTRUCTURE AND POWER CORPORATION
PURCHASE ORDER NO: 26068-230-POA-MS00-00001
EQUIPMENT SCOPE: HRSG

IHG-000201-DODO-2102






DETAIL "2"
(DWG -2102 & -2104)
SCALE 1½"=1'-0"



TYP. BRACING DETAIL FOR CO/SCR SUPPORT
SCALE : 1-1/2"=1'-0"



4" NOx ANALYZER CONNECTION DETAIL

NOTES:

1. FOR NOTES AND REFERENCE DRAWINGS SEE DRAWING IHG-000201-DODO-2100.

G	STIFFENER UPDATED			
	AG	CJ	SD	26SEPT17
F	NOx ANALYZER ADDED & REVISED AS CLOUDED			
	AG	CJ	SD	07SEPT17
E	REVISED AS CLOUD			
	AG	AP	SD	08AUG17
D	DETAIL MARKING & MATERIAL MARKING DELETED			
	AG	CJ	SD	26JULY17
C	TIE BEAM, ACCESS DOOR & TESTPORT LOCATION & ORIENTATION OF TIE-BEAM UPDATED			
	AG	CJ	SD	18JULY17
B	HOLD REMOVED & REVISED AS CLOUDED			
	AG	IP	SD	7JULY17
A	INITIAL ISSUE			
	SKD	RN	SD	10MAR17
	DRAWN BY	CHECKED BY	APPROVED BY	DATE

CONTRACT NO. : IHG-000201 UNIT NO. : 01, 02, 03

HRSG BOILER CASING - RIGHT SIDE ELEVATION
CRICKET VALLEY ENERGY CENTER
BECHTEL INFRASTRUCTURE AND POWER CORPORATION
PURCHASE ORDER NO. 26068-230-POA-MS00-00001